



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

**BHARAT HEAVY ELECTRICALS LIMITED**  
(A Govt. of India Undertaking)

**TCN - 03**

Ref.: PSER:SCT:SPT-F2389:TCN-03

Date: 25-09-2025

Sub	<b>Tender Change Notice (TCN) - 03</b>	
Job	PROVIDING SERVICES OF 1 NO. 350MT OR ABOVE CAPACITY MRHL (MID RANGE HEAVY LIFT) HYDRAULIC CRAWLER CRANE HAVING LATTICE BOOM & LUFTING JIB WITH CRITICAL LOAD LIFTING CAPACITY OF 60MT (MINIMUM) BELOW HOOK AT AROUND 28M (MINIMUM) RADIUS WITH MAIN BOOM AND LUFTING JIB COMBINATION TO OBTAIN CLEAR HEIGHT BELOW HOOK OF 86M (MINIMUM) ABOVE GROUND LEVEL ON MONTHLY RENTAL BASIS AT BHEL-PSER, 1X800 MW NTPC SIPAT STPP STAGE-III PO- UJJWAL NAGAR, SIPAT, DIST – BILASPUR, CHHATTISGARH 495555	
Ref	1.0	Tender No. PSER:SCT:SPT-F2389:25
	2.0	BHEL's NIT, vide Reference No. PSER:SCT: SPT-F2389:11158 Date: 10-09-2025
	3.0	BHEL's TCN-01, vide Reference No. PSER:SCT:SPT-F2389:TCN-01, dated 20-09-2025
	4.0	BHEL's TCN-02, vide Reference No. PSER:SCT:SPT-F2389:TCN-02, dated 24-09-2025
	5.0	All other pertinent issues till date

With reference to above, following points/ documents, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Clarifications attached vide Annexure - A of TCN-03.
- 2.0 Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.
- 3.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,  
for BHARAT HEAVY ELECTRICALS LTD

MANAGER (SCT)

Encl.: As above

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796

**FORMAT FOR NO DEVIATION CERTIFICATE**  
**(To be submitted in the bidder's letter head)**

BHARAT HEAVY ELECTRICALS LIMITED,  
 Power Sector - Eastern Region,  
 Plot no 9/1, DJ Block, Sector - II, Salt Lake City,  
 Kolkata – 700 091

Sub	No Deviation Certificate	
Job	PROVIDING SERVICES OF 1 NO. 350MT OR ABOVE CAPACITY MRHL (MID RANGE HEAVY LIFT) HYDRAULIC CRAWLER CRANE HAVING LATTICE BOOM & LUFFING JIB WITH CRITICAL LOAD LIFTING CAPACITY OF 60MT (MINIMUM) BELOW HOOK AT AROUND 28M (MINIMUM) RADIUS WITH MAIN BOOM AND LUFFING JIB COMBINATION TO OBTAIN CLEAR HEIGHT BELOW HOOK OF 86M (MINIMUM) ABOVE GROUND LEVEL ON MONTHLY RENTAL BASIS AT BHEL-PSER, 1X800 MW NTPC SIPAT STPP STAGE-III PO- UJJWAL NAGAR, SIPAT, DIST – BILASPUR, CHHATTISGARH 495555	
Ref.	1.0	Tender No. PSER:SCT:SPT-F2389:25
	2.0	BHEL's NIT, vide Reference No. PSER:SCT: SPT-F2389:11158 Date: 10-09-2025
	3.0	BHEL's TCN-01, vide Reference No. PSER:SCT:SPT-F2389:TCN-01, dated 20-09-2025
	4.0	BHEL's TCN-02, vide Reference No. PSER:SCT:SPT-F2389:TCN-02, dated 24-09-2025
	5.0	BHEL's TCN-03, vide Reference No. PSER:SCT:SPT-F2389:TCN-03, dated 25-09-2025
	6.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted/uploaded offer/documents in accordance with tender instructions with acceptance of the terms & conditions of the tender by us and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized  
 representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091  
 फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796

ANNEXURE-A

PROVIDING SERVICES OF 1 NO. 350MT OR ABOVE CAPACITY MRHL (MID RANGE HEAVY LIFT) HYDRAULIC CRAWLER CRANE HAVING LATTICE BOOM & LUFFING JIB WITH CRITICAL LOAD LIFTING CAPACITY OF 60MT (MINIMUM) BELOW HOOK AT AROUND 28M (MINIMUM) RADIUS WITH MAIN BOOM AND LUFFING JIB COMBINATION TO OBTAIN CLEAR HEIGHT BELOW HOOK OF 86M (MINIMUM) ABOVE GROUND LEVEL ON MONTHLY RENTAL BASIS AT BHEL-PSER, 1X800 MW NTPC SIPAT STPP STAGE-III PO- UJJWAL NAGAR, SIPAT, DIST – BILASPUR, CHHATTISGARH 495555

Tender No.: PSER:SCT:SPT-F2389:25

CLARIFICATION / MODIFICATION

Sl. No.	Reference clause of tender document	Existing Provision	Bidder's Query	BHEL's Clarification/Reply
1	Clause no.1.14 & 5.7.4- Specical Conditions of contract (Service) and Techncial Specification	<p>Clause No.1.14 : CONTRACTOR IS REQUIRED TO BRING SUFFICIENT NUMBERS OF STEEL PLATES/MATS FOR PLACEMENT UNDER CRAWLER &amp; WHEREEVER APPLICABLE FOR PLACEMENT OF CRANES DURING EXECUTION OF JOB AT SITE ON ITS OWN WITHOUT ANY COST TO BHEL.</p> <p>Clause No.5.7.4:SUFFICIENT NUMBERS OF STEEL PLATES/MATS FOR PLACEMENT UNDER CRAWLER FOR MOVEMENT OF CRANES FROM ONE LOCATION TO OTHER LOCATION AT SITE WILL BE PROVIDED BY BHEL/ BHEL CONTRACTOR FREE OF COST ON SHARING BASIS.</p>	Kindly Consider Clause no.5.7.4, sufficient number of steel plates / mats for placement under crawler crane for movement of cranes from one location to other location at site will be provided by BHEL / BHEL Contractor free of cost on sharing basis. Please delete the clause no.1.14.	SHALL BE AS PER TENDER
2	Clause no.5.5.1- Specical Conditions of contract (Service) and Technical Specification	FOR UNLOADING, ASSEMBLY, DISASSEMBLY & LOADING OF THE CRANE, BHEL OR BHEL'S ERECTION CONTRACTOR SHALL PROVIDE SUITABLE ASSISTING CRANE(S) WITH OPERATOR, WHEREAS SUCCESSFUL BIDDER SHALL ARRANGE NECESSARY FUEL FOR ASSISTING CRANE(S), SLINGS, D-SHACKLES, ETC AT THEIR OWN COST. FOR REARRANGEMENT, EXTENSION, REDUCTION, ETC OF BOOM AND JIB AS PER JOB REQUIREMENT DURING THE HIRING PERIOD, BHEL OR BHEL'S ERECTION CONTRACTOR SHALL PROVIDE SUITABLE ASSISTING CRANE(S) WITH OPERATOR, WHEREAS SUCCESSFUL BIDDER SHALL ARRANGE NECESSARY SLINGS, D-SHACKLES, ETC AT THEIR OWN COST. NO CLAIM IN THIS REGARD WILL BE ENTERTAINED BY BHEL.	As per this clause only supporting cranes will be provided for unloading and other activities. Kindly provide necessary fuel, slings, D-shackles for crane unloading, assembly, disassembly & loading of the crane by BHEL Free of cost. Necessary Slings and Belts below hook will be provided by BHEL free of cost on returnable basis as our scope is providing of services of crane only.	SHALL BE AS PER TENDER
3	NOTICE INVITING TENDER /PSER:SCT: SPT- F2389:11158/ Page 1 of 27	<p>Issue of Tender Documents :</p> <p>Start :10.09.2025, Time :17:30Hrs</p> <p>Closes: 20.09.2025, Time :01:00PM IST</p>	<p>We have downloaded the tender documents and currently reviewing the tender requirements.</p> <p>For the purpose of submitting most competitive offer to you and also due to weekend and upcoming holiday (Monday), We request you to kindly extend the bid submission date by atleast one week.</p>	SHALL BE AS PER NIT
	SPECIAL CONDITIONS OF CONTRACT (SERVICE) AND TECHNICAL SPECIFICATION / VOLUME-ID & II/ Page 02 of 16	CRANE DETAILS: 350MT OR ABOVE CAPACITY MRHL (MID RANGE HEAVY LIFT) HYDRAULIC CRAWLER CRANE HAVING LATTICE BOOM & LUFFING JIB WITH CRITICAL LOAD LIFTING CAPACITY OF 60MT (MINIMUM) BELOW HOOK AT AROUND 28M (MINIMUM) RADIUS WITH MAIN BOOM AND LUFFING JIB COMBINATION TO OBTAIN CLEAR HEIGHT BELOW HOOK OF 86M (MINIMUM) ABOVE GROUND LEVEL WITH 85% CAPACITY OF RATED SAFE WORK LOAD AT LIFT RADIUS OF THE CRANE.	<p>Based on the crane availability in our fleet database, currently we can offer LR 1400-2, kindly confirm -</p> <p>Main Boom – 84 Mtr</p> <p>Luffer Boom – 84 Mtr ( 60 M Minimum)</p> <p>Crawler width – 8.7 Mtr</p>	SHALL BE AS PER TENDER

## ANNEXURE-A

PROVIDING SERVICES OF 1 NO. 350MT OR ABOVE CAPACITY MRHL (MID RANGE HEAVY LIFT) HYDRAULIC CRAWLER CRANE HAVING LATTICE BOOM & LUFFING JIB WITH CRITICAL LOAD LIFTING CAPACITY OF 60MT (MINIMUM) BELOW HOOK AT AROUND 28M (MINIMUM) RADIUS WITH MAIN BOOM AND LUFFING JIB COMBINATION TO OBTAIN CLEAR HEIGHT BELOW HOOK OF 86M (MINIMUM) ABOVE GROUND LEVEL ON MONTHLY RENTAL BASIS AT BHEL-PSER, 1X800 MW NTPC SIPAT STPP STAGE-III PO- UJJWAL NAGAR, SIPAT, DIST – BILASPUR, CHHATTISGARH 495555

Tender No.: PSER:SCT:SPT-F2389:25

## CLARIFICATION / MODIFICATION

Sl. No.	Reference clause of tender document	Existing Provision	Bidder's Query	BHEL's Clarification/Reply
5	SPECIAL CONDITIONS OF CONTRACT (SERVICE) AND TECHNICAL SPECIFICATION / VOLUME-ID & II/ Page 03 of 16	<p>BROAD SCOPE OF WORK :</p> <p>Model/Age of Crane - THE AGE OF THE CRANE SHOULD NOT BE MORE THAN TWELVE (12) YEARS AS ON LAST DATE OF SUBMISSION OF TENDER.</p>	<p>We have utmost priority of Safety and Quality and in no way, we compromise on same. We maintain Global reputation for delivering best quality services and in order to achieve we maintain our crane to highest level of preventive Maintenance along with experienced operators and have in-house unique maintenance program. Our cranes irrespective of age have been working at most critical applications in various sectors particularly Thermal energy , Oil &amp; Gas etc.</p> <p>We understand the criticality of heavy capacity cranes and accordingly request to relax YOM criteria to 20 years. We can provide suitable fitness certificate and also open to inspection of cranes if required.</p> <p>We request to kindly relax the age and modify the clause as "THE AGE OF THE CRANE SHOULD NOT BE MORE THAN TWENTY (20) YEARS AS ON LAST DATE OF SUBMISSION OF TENDER"</p>	SHALL BE AS PER TENDER
6	SPECIAL CONDITIONS OF CONTRACT (SERVICE) AND TECHNICAL SPECIFICATION / VOLUME-ID & II/ Page 06 of 16	<p>2.2 DEPLOYMENT OF CRANE(S)</p> <p>CONTRACT PERIOD OF THE CRANE SHALL BE FOR 19 (NINETEEN) MONTHS FROM THE START DATE OF CONTRACT WITH A PROVISION OF 06 (SIX) MONTHS EXTENSION PERIOD FOR THE CONTRACT.</p>	IN CASE OF EXTENSION BEYOND CONTRACT PERIOD of 19 (NINETEEN) MONTHS, THE SAME SHALL BE INTIMATED BY BHEL TO CONTRACTOR ONE (1) MONTH BEFORE EXPIRY OF CONTRACT PERIOD AND THEN THIS CONTRACT WILL BE EXTENDED ON MUTUALLY AGREED TERMS AND CONDITIONS.	SHALL BE AS PER TENDER
7	SPECIAL CONDITIONS OF CONTRACT (SERVICE) AND TECHNICAL SPECIFICATION / VOLUME-ID & II/ Page 10 of 16	<p>5.27 HEAVY WEIGHT:</p> <p>BIDDER MAY PLEASE NOTE DURING MOBILIZATION OF CRANE FOR MOVEMENT OF HEAVY CONSIGNMENTS WEIGHING MORE THAN 20MT &amp; WIDTH MORE THAN 10.5 FT., ADVANCE ROAD SURVEY AND LOGISTIC PLANNING SHALL BE DONE BY BIDDER OR BIDDER'S TRANSPORTER</p>	Notwithstanding anything herein, the Contractor shall not be liable under any circumstances for any sub-soil or hydrological conditions.	SHALL BE AS PER TENDER
8	SPECIAL CONDITIONS OF CONTRACT (SERVICE) AND TECHNICAL SPECIFICATION / VOLUME-ID & II/ Page 09 of 16	<p>5.17 INSURANCE:</p> <p>NECESSARY INSURANCE COVERAGE FOR THE CRANES INCLUDING THIRD PARTY LIABILITY AND FOR THE WORKMEN (COVERING WORKMEN'S COMPENSATION ACT, ETC.) ENGAGED BY THE CONTRACTOR ARE TO BE TAKEN AT HIS COST AND COPY OF THE SAME SHOULD BE SUBMITTED TO BHEL AT SITE BEFORE WORK COMMENCEMENT. IF ANY ACCIDENT/ INJURY OCCURS TO ANY OTHER PERSONS/ PUBLIC DUE TO PROVEN NEGLIGENCE/ NON[1]ADHERENCE TO RELEVANT SAFETY AND OTHER PRECAUTIONS ON THE PART OF CONTRACTOR/ ITS EMPLOYEES, THE CONTRACTOR SHALL REMAIN LIABLE TO PAY NECESSARY COMPENSATION AND OTHER EXPENSE, AS DECIDED BY APPROPRIATE AUTHORITIES/ AS PER STATUTORY NORMS.</p>	<p>Kindly add the following clause -</p> <p>Notwithstanding anything contained herein, BHEL will effect and maintain a CAR/EAR insurance covering the works and/or services under this agreement including entrusted goods and/or goods on hook. Contractor shall be named as additional insured and shall be waiver of subrogation by insurers.</p>	SHALL BE AS PER TENDER

## ANNEXURE-A

PROVIDING SERVICES OF 1 NO. 350MT OR ABOVE CAPACITY MRHL (MID RANGE HEAVY LIFT) HYDRAULIC CRAWLER CRANE HAVING LATTICE BOOM & LUFFING JIB WITH CRITICAL LOAD LIFTING CAPACITY OF 60MT (MINIMUM) BELOW HOOK AT AROUND 28M (MINIMUM) RADIUS WITH MAIN BOOM AND LUFFING JIB COMBINATION TO OBTAIN CLEAR HEIGHT BELOW HOOK OF 86M (MINIMUM) ABOVE GROUND LEVEL ON MONTHLY RENTAL BASIS AT BHEL-PSER, 1X800 MW NTPC SIPAT STPP STAGE-III PO- UJJWAL NAGAR, SIPAT, DIST – BILASPUR, CHHATTISGARH 495555

Tender No.: PSER:SCT:SPT-F2389:25

## CLARIFICATION / MODIFICATION

Sl. No.	Reference clause of tender document	Existing Provision	Bidder's Query	BHEL's Clarification/Reply
9	SPECIAL CONDITIONS OF CONTRACT (SERVICE) AND TECHNICAL SPECIFICATION / VOLUME-ID & II/ Page 11 of 16	<p>7. LIQUIDATED DAMAGES</p> <p>SINCE TIME IS THE MAIN ESSENCE OF THE CONTRACT, CRANE TO BE MOBILIZED AT SITE WITHIN THE TIME LIMIT PRESCRIBED IN SL. NO. 2.2.2 ABOVE AND MOBILIZATION SHALL BE CONSIDERED AS DEFINED IN SL. NO. 2.2.2, 2.2.3 AND 2.2.4 ABOVE. IN CASE CONTRACTOR MOBILIZES THE CRANE BEYOND THE PERIOD SPECIFIED IN SL. NO. 2.2.2 ABOVE, BHEL WILL HAVE NO OBLIGATION TO ACCEPT THE CRANE AND RESERVES THE RIGHT TO LEVY LIQUIDATED DAMAGES AT THE RATE OF 0.5% (HALF PERCENT) OF CONTRACT PRICE OF PARTICULAR CRANE FOR DELAY PER WEEK OR PART THEREOF WITHOUT PREJUDICE TO ANY OTHER RELIEF OR COMPENSATION DUE TO BHEL UNDER ANY OTHER CONDITIONS OF THE ORDER SUBJECT TO A MAXIMUM LIMIT OF 10% OF THE CONTRACT PRICE. HERE, LD SHALL BE APPLICABLE FOR THE DELAY ATTRIBUTABLE TO VENDOR.</p>	<p>Kindly add the following clause –</p> <p>Notwithstanding anything herein, the aforesaid liquidated damages/fines shall be applicable / levied only in case of the delays occurring due to such reasons which are solely attributable to the negligence of the Contractor. Further levy of such liquidated damages/fines shall form the sole financial remedy against the Contractor in an event of said delays and/or non-performance.</p>	SHALL BE AS PER TENDER
10	VOLUME-IB: GENERAL CONDITIONS OF CONTRACT (SERVICE) TENDER NO. PSER:SCT:KDS-F2369:25 / Page 38 of 39	<p>2.24 PERFORMANCE GUARANTEE FOR WORKMANSHIP</p> <p>2.24.1 Even though the work will be carried out under the supervision of BHEL Engineers the Contractor will be responsible for the quality of the workmanship and shall guarantee the work done for a period of Twelve months from the date of commencement of guarantee period as defined in Technical Conditions of Contract, for good workmanship and shall rectify free of cost all defects due to faulty erection detected during the guarantee period. In the event of the Contractor failing to repair the defective works within the time specified by the Engineer, BHEL may proceed to undertake the repairs of such defective works at the Contractor's risk and cost, without prejudice to any other rights and recover the same from the Security Deposit</p>	<p>Kindly add the following clause –</p> <p>Notwithstanding anything herein, there shall be no warranty/guarantee period.</p>	SHALL BE AS PER TENDER
11	VOLUME-IB: GENERAL CONDITIONS OF CONTRACT (SERVICE) TENDER NO. PSER:SCT:KDS-F2369:25 / Page 38 of 39	<p>2.27 LIMITATION ON LIABILITY:</p> <p>Notwithstanding anything to the contrary in this Agreement or the Work Order or any other mutually agreed document between the parties, the maximum liability, for damages, of the contractor, its servants, or agents, shall under no circumstances exceed an amount equal to the Price of the Agreement or the Work Order. The Supplier shall not in any case be liable for loss of profit or special, punitive, exemplary, indirect, or consequential losses whatsoever. This shall not be applicable on the recoveries made by Customer from BHEL on account of Contractor, any other type of recoveries for workmanship, material, T&amp;P etc. due from the contractor.</p>	<p>Kindly add the following clause -</p> <p>At all times when the equipment of the Contractor is at the site or performing this contract, same shall be considered as under control, care or custody of the BHEL, BHEL shall protect, defend and indemnify the Contractor against any liabilities, claims, demands, losses, costs or expenses arising out of connection with any injury or death of any person and/or damage to any property of the Contractor and or the BHEL, third parties unless the same is caused by the gross negligence and/or willful default of the Contractor.</p>	SHALL BE AS PER TENDER
12	VOLUME-IB: GENERAL CONDITIONS OF CONTRACT (SERVICE) TENDER NO. PSER:SCT:KDS-F2369:25 / Page 38 of 39	<p>2.27 LIMITATION ON LIABILITY:</p> <p>Notwithstanding anything to the contrary in this Agreement or the Work Order or any other mutually agreed document between the parties, the maximum liability, for damages, of the contractor, its servants, or agents, shall under no circumstances exceed an amount equal to the Price of the Agreement or the Work Order. The Supplier shall not in any case be liable for loss of profit or special, punitive, exemplary, indirect, or consequential losses whatsoever. This shall not be applicable on the recoveries made by Customer from BHEL on account of Contractor, any other type of recoveries for workmanship, material, T&amp;P etc. due from the contractor.</p>	<p>Kindly add the following clause -</p> <p>Contractor shall have right to suspend its performance under this contract and to immediately de-mobilize its equipment's, solely at risk and cost of the BHEL and without any liability in an event of being non-paid even after its due for 7 or more days.</p>	SHALL BE AS PER TENDER

ANNEXURE-A

PROVIDING SERVICES OF 1 NO. 350MT OR ABOVE CAPACITY MRHL (MID RANGE HEAVY LIFT) HYDRAULIC CRAWLER CRANE HAVING LATTICE BOOM & LUFFING JIB WITH CRITICAL LOAD LIFTING CAPACITY OF 60MT (MINIMUM) BELOW HOOK AT AROUND 28M (MINIMUM) RADIUS WITH MAIN BOOM AND LUFFING JIB COMBINATION TO OBTAIN CLEAR HEIGHT BELOW HOOK OF 86M (MINIMUM) ABOVE GROUND LEVEL ON MONTHLY RENTAL BASIS AT BHEL-PSER, 1X800 MW NTPC SIPAT STPP STAGE-III PO- UJJWAL NAGAR, SIPAT, DIST – BILASPUR, CHHATTISGARH 495555

Tender No.: PSER:SCT:SPT-F2389:25

CLARIFICATION / MODIFICATION

Sl. No.	Reference clause of tender document	Existing Provision	Bidder's Query	BHEL's Clarification/Reply
13	VOLUME-IB: GENERAL CONDITIONS OF CONTRACT (SERVICE) TENDER NO. PSER:SCT:KDS-F2369:25 / Page 38 of 39	<p>2.27 LIMITATION ON LIABILITY:</p> <p>Notwithstanding anything to the contrary in this Agreement or the Work Order or any other mutually agreed document between the parties, the maximum liability, for damages, of the contractor, its servants, or agents, shall under no circumstances exceed an amount equal to the Price of the Agreement or the Work Order. The Supplier shall not in any case be liable for loss of profit or special, punitive, exemplary, indirect, or consequential losses whatsoever. This shall not be applicable on the recoveries made by Customer from BHEL on account of Contractor, any other type of recoveries for workmanship, material, T&amp;P etc. due from the contractor.</p>	<p>Kindly add the following clause -</p> <p>Notwithstanding anything herein, the maximum liability of the Contractor shall not exceed 50% of the total contract price. Further, the Contractor shall not be liable for any special or indirect or consequential losses or damages, loss of profit, loss of revenue, loss of work etc.</p>	SHALL BE AS PER TENDER
14	VOLUME-ID & II	<p>As per the tender title "PROVIDING SERVICES OF 1 NO. 350MT OR ABOVE CAPACITY MRHL (MID RANGE HEAVY LIFT) HYDRAULIC CRAWLER CRANE HAVING LATTICE BOOM &amp; LUFFING JIB WITH CRITICAL LOAD LIFTING CAPACITY OF 60MT (MINIMUM) BELOW HOOK AT AROUND 28M (MINIMUM) RADIUS"</p> <p>However</p> <p>FOR CRITICAL LOAD AND OTHER LOAD LIFTING, CAPACITY UTILIZATION OF THE CRANE SHALL NOT EXCEED 85% CAPACITY OF RATED SAFE WORK LOAD AT LIFT RADIUS AS PROVIDED IN THE LOAD CHART</p>	<p>Please clarify for below queries:</p> <p>Hence, the capacity of the crane in the load chart at 28 m has to be 60 T? or else 60 T is the weight of the job and capacity of the crane is required as such that 60 T is under 85% capacity. Because in later scenario, we will have to offer a crane with lifting capacity of 70 T at 28 m radius.</p>	For lifting critical load with main boom and luffing jib combination bidders may refer the example provided in the SCC & TS (Volume ID & II), Clause No. 1.1.1