

TENDER SPECIFICATION

NUMBER: BHE/PW/PUR/BSJI-PLT/559

HANDLING OF PAINTS AT SITE STORES/STORAGE YARD, TRANSPORTATION TO SITE OF WORK, **APPLICATION OF PAINTS** FOR BOILERS AND THEIR AUXILIARIES, TG & AUXILIARIES, LP PIPING, CW PIPING AND STRUCTURES AND HANGERS & SUPPORTS OF LP PIPINGS AND POWER CYCLE PIPING, TANKS AND VESSELS, AND OTHER EQUIPMENTS, PAINTING OF COLOUR BANDS, LETTERING, MARKING AND SIGNS FOR DIRECTION OF FLOW/ ROTATION, NAME PLATES ETC OF 2x250 MW UNITS -1&2

AT

**2X250 MW, BESCL, EXPANSION PROJECT
BHILAI
DIST-DURG(C.G)**

PART:I – TECHNICAL BID

(TECHNICAL BID SPECIFICATION, NOTICE INVITING TENDER and GCC)



BOOK NO.

BHARAT HEAVY ELECTRICALS LIMITED

(A Government Of India Undertaking)
POWER SECTOR - WESTERN REGION
SHREEMOHINI COMPLEX
345, KINGSWAY - NAGPUR 440 001

CONTENTS			
SN	DESCRIPTION	SECTION/ APPENDIX NO.	NO OF PAGES
1	Tender Specification issue details	--	1
2	Procedure for Submission of Sealed Tender	--	1
3	Project Information	--	2
4	Check List	--	2
5	Declaration by Bidder's Authorized Signatory	--	1
6	Certificate of No-Deviation	--	1
7	Notice Inviting Tender (includes Qualification Requirements etc.)	--	\$
8	General Conditions of Contract	Sections-1 & 2	#
9	Offer of Bidder	Section-3	1
SPECIAL CONDITIONS OF CONTRACT			
10	Scope of Work	Section-4	25
11	Obligations of the Contractor (Tools, Tackles & Consumables)	Section-5	05
12	Contractor's Obligation with Regard to Employment of Supervisory Staff and Workmen	Section-6	02
13	Obligations of BHEL	Section-7	03
14	Inspection/ Quality Assurance/ Quality Control/ Statutory Inspection	Section-8	03
15	Safety Measures	Section-9	15
16	Drawings and Documents	Section-10	01
17	Time Schedule/Mobilization/ Progress Monitoring/ Overrun/ Variation/Advance payment etc.	Section-11	05
18	Terms of Payment	Section-12	06
19	Extra Charges for Modification/Rectification	Section-13	02
20	Insurance	Section-14	02
21	EMD & Security Deposit	Section-15	02
Appendices			
22	Analysis of Unit Rate	Appendix-I	01
23	Month-wise Manpower Deployment Plan by the Contractor	Appendix-II	01
24	Details of Concurrent Commitment	Appendix-III	01
25	Details of Similar Jobs done in last seven years	Appendix -IV	01
26	Painting Schedule	Appendix-V	23

CONTENTS			
SN	DESCRIPTION	SECTION/ APPENDIX NO.	NO OF PAGES
27	Rate Schedule (Part-II :Price Bid)	Price Bid	@

LEGEND:

- \$:** PLACED BEFORE 'GENERAL CONDITIONS OF CONTRACT' IN BOTH HARD AND SOFT COPY DOCUMENTS.
- #:** ATTACHED AT THE END OF HARD COPY OF TENDER SPECS. PART-I (TECHNICAL BID) AND AS A SEPARATE FILE TITLED '**WEB_NIT_GCC**' AS SOFT COPY HOSTED IN WEB PAGE.
- @:** ISSUED AS SEPARATE BOOKLET IN HARD COPY AS **PRICE BID (PART-II)** AND AS SEPARATE FILE TITLED 'PRICE_BID' AS SOFT COPY HOSTED IN WEB PAGE.

NOTE: Bidders must Visit BHEL web site www.bhel.com for NIT, Qualifying Requirement of this work(QR), GCC etc. Further all corrigenda, addenda, amendments and clarifications to Tender Specifications will be hosted in this web page. Bidders shall keep themselves updated with all such amendments

BHARAT HEAVY ELECTRICALS LIMITED

(A GOVERNMENT OF INDIA UNDERTAKING)
POWER SECTOR - WESTERN REGION
SHREEMOHINI COMPLEX
345, KINGS WAY - NAGPUR 440 001
PH: 0712-530641, FAX: 0712-530640

TENDER SPECIFICATION No. *BHE/PW/PUR/BSJI-PLT/559.*

NAME OF THE WORK:HANDLING OF PAINTS AT SITE STORES/STORAGE YARD, TRANSPORTATION TO SITE OF WORK, APPLICATION OF PAINTS FOR BOILERS AND THEIR AUXILIARIES, TG & AUXILIARIES, LP PIPING, CW PIPING AND STRUCTURES AND HANGERS & SUPPORTS OF LP PIPINGS AND POWER CYCLE PIPING, TANKS AND VESSELS, AND OTHER EQUIPMENTS, PAINTING OF COLOUR BANDS, LETTERING, MARKING AND SIGNS FOR DIRECTION OF FLOW/ ROTATION, NAME PLATES ETC OF 2X250 MW UNIT -1&2 AT, **MW, BESCL, EXPANSION ,PROJECT,BHILAI,DIST-DURG(C.G)**

EARNEST MONEY DEPOSIT : RS.1,00,000/- (Rupees ONE lakh only) .FOR DETAIL PL REFER SECTION-15 OF THIS TENDER.

OFFERS SHALL BE RECEIVED UPTO 17:00 HOURS OF.....

These Tender Documents containing Part-I Technical Bid and Part-II Price Bid are issued to

M/s

.....

.....

(THESE TENDER DOCUMENTS ARE NOT TRANSFERABLE)

For Bharat Heavy Electricals Limited

SENIOR MANAGER (PUR)

PLACE: NAGPUR

DATE:

BHARAT HEAVY ELECTRICALS LIMITED

(A GOVT. OF INDIA UNDERTAKING)

POWER SECTOR: WESTERN REGION

345, KINGS WAY, NAGPUR 440 001

Procedure for Submission of Sealed Tenders & Instructions to Bidders

The bidder must submit their tenders as required in two parts in separate sealed covers prominently super scribed as part-I technical bid and part-II price bid and also indicating on each of the covers the tender specification number and due date and time as mentioned in the tender notice.

Part-I (Technical Bid) Cover-I:

Excepting rate schedule, all other schedules, data sheets and details called for in the specification shall be enclosed in part-I "Technical Bid" only.

EARNEST MONEY DEPOSIT (EMD)

EMD of Rs. 2.00 lakh (Rupees Two lacs only) shall be included in the Technical Bid. **EMD shall be paid by bidders only in the manner specified in Section-15 Special Conditions of Contract.** No other mode of payment of EMD shall be acceptable. Provisions under clause no. 1.4 of the General Conditions of Contract shall not be applicable for this tender.

Bidder may opt to deposit "One Time EMD" of Rs. 2.0 lacks with this office (BHEL:PSWR:Nagpur) which will enable them to participate in the present and all the future tender enquiries in respect of Erection and Commissioning services issued from this office. Interested bidders may send their explicit consent for converting the present EMD into an "One Time EMD" in their offer.

Bidders who have already submitted such "One Time EMD" will be exempted from submission of any EMD for this tender. However bidder shall furnish details of the "One Time EMD" in his offer including the Check List furnished herein.

Part-II (Price Bid) Cover-II:

All indications of price shall be given in this part-II "Price Bid". **EMD shall not be included in this cover.**

These two separate covers-I and II (part-I and part-II) shall together be enclosed in a third envelope (cover-III) along with requisite EMD as indicated earlier and this sealed cover shall be super scribed and submitted to Senior Manager (Purchase) at the above-mentioned address on or before the due date as indicated.

The qualified bidder will be intimated separately about the status of their offer.

Bidder are requested to make specific note of the following conditions:

Contractor should have adequate resources including major T&P at his disposal for this job.

Contractor should have sound financial stability.

Bidder should meet quality requirement regarding workmanship, deployment of personnel, erection tools and necessary inspection, measurement & testing instruments.

All information as called for in various appendices and clauses of tender specification, should be furnished in completeness. Please refer the checklist.

The bidder, if any, shall obtain clarification on Tender Specifications, before submitting their offer.

Offers must be submitted without any deviation.

Offers received with any deviation or without relevant information as described above are liable to be rejected. Price bids received in the form other than specified in part-II (price bid) are liable to be rejected.

Bidder must sign & stamp all pages of this tender specification as a acceptance of tender conditions.

Bidder shall note that their offer will be considered subject to the approval of BHEL's customer.

PROJECT INFORMATION

INTROCUCTION

Bhilai Electric Supply Company Private Limited (BESCL), a joint venture of NTPC & SAIL, is going for expansion of Bhilai CPP-II by addition of two coal fired thermal units of 250 MW \pm 20%.

The proposed plant is located near the town of Bhilai, in Durg District of Chhattisgarh state. Contractor is advised to visit the site and appraise himself about the conditions of the site and infrastructure available in the area for fulfilling their commitment under the contract.

APPROACH TO SITE

The site is approximately 40 km from Raipur. The nearest railway station (Broad Gauge) is Durg under South Central Railway. Durg is on Mumbai-Howrah main line.

3.0 CLIMATIC CONDITIONS

Maximum temperature	:	42.8 Deg Celsius
b).Minimum temperature	:	8.9 Deg Celsius
c) Maximum Relative Humidity	:	100%
d) Minimum Relative Humidity	:	---
e) Average Annual rainfall	:	----
f) Seismic Zone	:	II
g) Height above MSL	:	294.0 M

THE TENDERERS ARE HOWEVER, ADVISED TO ACQUAINT THEMSELVES WITH THE SITE CONDITIONS, BEFORE QUOTING. NO COMPENSATION WHATSOEVER, ON ACCOUNT OF NON-FAMILIARISATION WITH THE SITE CONDITION, WILL BE ENTERTAINED.

Check List			
(Vide Para 1.3 Of Section-I of General Conditions Of Contract)			
1	Name of the Bidder with Postal Address for Correspondence		
2	Name of Contact Person with Telephone & Fax No.	Mr./Ms Tel No. Fax No.	
3	Nature of the firm	PROPRIETARY / PARTNERSHIP / LIMITED CO.	
4	Details of EMD Please Indicate whether 1) One Time EMD or, 2) Only for this Tender	DD No. DD Date..... Name of Bank..... Amount: Rs.....	
5	Validity of Offer (BHEL's Requirement: 180 days from Due Date)	Validity _____ days	
6	Mobilization Time (Please refer Section- 11 of SCC)	Mobilization Time _____	
7	Whether any conditions stipulated?	Yes (vide Document reference:	No
		Bidder to note that tender with conditions unacceptable to BHEL shall be rejected.	
8	Bidder has visited the project site and acquainted with the site conditions	Yes	No
9	Details of concurrent jobs are furnished (Appendix- VI)	Yes	No
10	Headquarters organization is furnished	Yes	No
11	Proposed site organization is furnished	Yes	No
12	Names and particulars of directors/partners are furnished	Yes	No
13	Financial status of the firm (Annexure 'A' of GCC) is furnished	Yes	No
14	Copy of Audited Profit & Loss Account for preceding three years duly authenticated on each copy by bidders Chartered Accountants	Yes	No

Check List (Vide Para 1.3 Of Section-I of General Conditions Of Contract)			
15	Latest Certificate by Bidder's Banker for Overdraft & BG Limits is Furnished (Certificate shall not be older than six months from the Last Date for offer submission)	Yes	No
16	Latest copy of IT Return along with copy of PAN Card are Furnished	Yes	No
17	Month-wise Manpower Deployment Plan (Appendix – IV) is furnished	Yes	No
18	Analysis of Unit Rates quoted (Appendix-III) is furnished	Yes	No
19	Month-wise deployment plan for major T&P (Appendix-IV) is furnished	Yes	No
20	Whether all the pages of the Tender Specification documents are read, understood and signed	Yes	No
21	Power of Attorney enclosed in favour of person making offer	Yes	No
22	Bidder has familiarized himself with all Relevant Local Laws & Local Conditions	Yes	No
23	Safety Requirement of this work in a Running plant Premises has been understood.	Yes	No
24	Erection and Commissioning programme furnished	Yes	No
25	List of Jobs completed in last seven years is furnished (Appendix-VII)	Yes	No
26	Whether copies of detailed Work Orders (with BOQ) and Completion Certificates in support of above furnished	Yes	No
27	Whether contractor has left any job unfinished? If so, give reasons.	Yes	No
28	Whether any client has terminated the contractor's work before completion? If so, furnish reasons for the same	Yes	No
29	BIDDER MUST FURNISH HERE THE FOLLOWING DETAIL FOR RELEASING EMD AND OTHER PAYMENTS. 1 Name of the Company----- 2 Name of Bank----- 3 Name of Bank Branch----- 4 City/Place----- 5 Account Number----- 6 Account type----- 7 IFSC code of the Bank Branch----- 8 MICR Code of the Bank Branch-----	Yes	No

Note: strike off or tick '**yes**' or '**no**', as applicable

BIDDERS MUST SUBMIT ALL NECESSARY DOCUMENTS AS BEING ASKED IN ABOVE CHECK LIST AND FILL – UP ALL DETAILS IN THIS CHECK LIST.

Declaration by Bidder's Authorized Signatory

I hereby
certify that all the information and data furnished by me with regard to this tender
specification No. *BHE/PW/PUR/BSJI-PLT/559* is true and complete to the best of my
knowledge. I have gone through the specification, conditions and stipulations in detail
and agree to comply with the requirements and intent of the specification. I further certify
that I am duly authorised representative of the under mentioned bidder and a **valid
power of attorney to this effect is also enclosed with the offer.**

Bidder's name and address

Authorised representative's signature with
Name and Address

Date:

CERTIFICATE OF NO-DEVIATION

TENDER SPECIFICATION No. *BHE/PW/PUR/BSJI-PLT/559*.

I/WE, M/s

HEREBY CERTIFY THAT NOTWITHSTANDING ANY CONTRARY INDICATIONS/ CONDITIONS ELSEWHERE IN OUR OFFER DOCUMENTS, I/WE HAVE NEITHER SET ANY TERMS AND CONDITIONS NOR THERE IS ANY DEVIATION TAKEN FROM THE CONDITIONS OF BHEL'S TENDER SPECIFICATIONS, EITHER TECHNICAL OR COMMERCIAL, AND I/WE AGREE TO ALL THE TERMS AND CONDITIONS MENTIONED IN BHEL'S TENDER SPECIFICATION WITH ASSOCIATED AMENDMENTS AND CLARIFICATIONS.

Date:

Signature of the Bidder

**CERTIFICATE OF DECLARATION FOR CONFIRMING KOWLEDGE ON SITE
CONDITIONS**

We, M/s

hereby declare and confirm that we have visited the project site at 2X250 MW UNIT -1&2 AT, **MW, BESCL, EXPANSION ,PROJECT,BHILAI,DIST-DURG(C.G)** as referred in BHEL's Tender Specification No. *BHE/PW/PUR/BSJI-ENB/559*. and acquired full knowledge and information about the site conditions. We further confirm that the above information is true and correct and we shall not be eligible for any additional payment of any nature due to lack of knowledge or non-familiarization of site conditions.

BIDDER'S NAME AND ADDRESS

SIGNATURE & OFFICIAL SEAL OF
AUTHORISED SIGNATORY

PLACE:

DATE:

SECTION-3

OFFER OF BIDDER

TO,
THE SR. MANAGER (PURCHASE)
M/s BHARAT HEAVY ELECTRICALS LIMITED
POWER SECTOR - WESTERN REGION
SHREEMOHINI COMPLEX
345, KINGS WAY
NAGPUR 440 001

DEAR SIR,

WE HEREBY OFFER TO CARRY OUT THE WORK DETAILED IN TENDER SPECIFICATION NO. *BHE/PW/PUR/ - ENB/...* ISSUED BY **BHARAT HEAVY ELECTRICALS LIMITED**, POWER SECTOR- WESTERN REGION, NAGPUR, IN ACCORDANCE WITH THE TERMS AND CONDITIONS THEREOF. I/WE HAVE CAREFULLY PERUSED THE FOLLOWING LISTED DOCUMENTS CONNECTED WITH THE ABOVE WORK AND AGREE TO ABIDE BY THE SAME.

1. INSTRUCTIONS TO TENDERERS
2. GENERAL CONDITIONS OF CONTRACT
3. SPECIAL CONDITIONS OF CONTRACT
4. OTHER SECTIONS, APPENDICES, SCHEDULES AND DRAWINGS.

WE HAVE DEPOSITED / FORWARDED HERewith THE EARNEST MONEY DEPOSIT FOR A SUM OF Rs. 2,00,000/- (RUPEES TWO LAKH ONLY) DETAILS OF EMD PAYMENT ARE FURNISHED IN THE CHECK LIST.

EMD SHALL BE REFUNDED SHOULD OUR OFFER NOT BE ACCEPTED / EMD **NEED NOT BE REFUNDED AND THE AMOUNT MAY BE TREATED AS "ONE TIME EMD" FOR ERECTION AND COMMISSIONING TENDERS OF BHEL-PSWR, NAGPUR.** SHOULD OUR OFFER BE ACCEPTED, I/WE FURTHER AGREE TO DEPOSIT SECURITY DEPOSIT FOR THE WORK AS PROVIDED FOR IN THE TENDER SPECIFICATION WITHIN THE STIPULATED TIME AS MAY BE INDICATED BY BHEL, POWER SECTOR-WESTERN REGION, NAGPUR.

WE FURTHER AGREE TO EXECUTE ALL THE WORKS REFERRED TO IN THE SAID DOCUMENTS UPON THE TERMS AND CONDITIONS CONTAINED OR REFERRED TO THEREIN AND AS DETAILED IN THE APPENDICES ANNEXED THERETO.

SIGNATURE OF BIDDER:

PLACE:

DATE:

WITNESSES WITH THEIR ADDRESS

SN	SIGNATURE	NAME	ADDRESS
1.			
2.			

SECTION- 4
SPECIAL CONDITIONS OF CONTRACT

4.0 SCOPE OF WORK INVOLVING SURFACE CLEANING AND APPLICATION OF PAINTS

THE WORK TO BE CARRIED OUT UNDER THE SCOPE OF THESE SPECIFICATIONS COVERS THE COMPLETE WORK OF LOADING, HANDLING, TRANSPORTING, UNLOADING, SURFACE CLEANING, APPLICATION OF PRIMER AND FINISH/FINAL PAINTS ETC OF BOILER & AUXILIARIES, TG & AUXILIARIES, LP PIPING, CW PIPING AND STRUCTURES AND HANGERS & SUPPORTS OF LP PIPINGS AND POWER CYCLE PIPING, TANKS AND VESSELS, AND OTHER EQUIPMENTS, PAINTING OF COLOUR BANDS, LETTERING, MARKING AND SIGNS FOR DIRECTION OF FLOW/ ROTATION, NAMEPLATES ETC OF 2 X 250 MW UNIT 1&2, BESCL,BHILAI . THE WORK SHALL CONFORM TO INSTRUCTIONS/SPECIFICATIONS/STANDARD PRACTICES AND APPROVED COLOUR CODES THAT WILL BE PROVIDED BY BHEL FROM TIME TO TIME. IF ANY PORTION OF THE WORK IS FOUND TO BE DEFECTIVE IN WORKMANSHIP OR NOT CONFORMING TO SPECIFICATIONS, THE CONTRACTOR SHALL CLEAN THE SURFACE AND RE-DO THE WORK AT HIS COST FAILING WHICH THE WORK WILL BE GOT DONE BY ENGAGING OTHER AGENCIES OR DEPARTMENTALLY AND RECOVERIES WILL BE EFFECTED FROM CONTRACTORS BILL TOWARDS EXPENDITURE INCURRED INCLUDING 30% DEPARTMENTAL CHARGES. ALL TOOLS, TACKLES, FIXTURES, EQUIPMENTS, MATERIALS, MANPOWER, SUPERVISORS/ ENGINEERS, CONSUMABLES ETC REQUIRED FOR THIS SCOPE OF WORK SHALL BE PROVIDED BY THE CONTRACTOR. ALL EXPENDITURE INCLUDING TAXES AND INCIDENTALS IN THIS CONNECTION WILL HAVE TO BE BORNE BY HIM UNLESS OTHERWISE SPECIFIED IN THE RELEVANT CLAUSE. THE CONTRACTOR'S QUOTED RATES SHOULD BE INCLUSIVE OF ALL SUCH CONTINGENCIES. SCOPE OF WORK IS FURTHER DETAILED HEREAFTER.

PAINT, PRIMER & THINNER REQUIRED FOR THE WORK DEFINED IN THIS TENDER SPECIFICATION SHALL BE PROVIDED BY BHEL FREE OF COST. ALL OTHER MATERIALS AND T&Ps REQUIRED TO EXECUTE THE WORK SPECIFIED IN THIS TENDER IS IN CONTRACTORS SCOPE.

4.1.0 SCOPE OF WORK

- 4.1.1 All exposed metal parts of the equipments including, piping, structures, railings, valves, hangers etc wherever applicable after installation unless otherwise surface protected shall be first painted with at least one coat of suitable primer which matches the shop primer paint used, after thorough cleaning all such parts of all dirt, rust, scales, greases, oils and other foreign materials by solvents before starting mechanical cleaning viz. wire brushing, scrapping or sand blasting and the same being inspected and approved by the BHEL/CUSTOMER engineer for painting. Afterwards the

above parts shall be finished with three coats of Synthetic enamel/Aliphatic polyurethane paint.

4.1.2

ABRADED OR DAMAGED AREAS OF SHOP PRIMED SURFACES SHALL BE CLEANED AND TOUCHUP PAINTED BEFORE APPLYING FINISH PAINT SYSTEM. ABRADED OR DAMAGED AREAS OF SHOP FINISH PAINTED SURFACES SHALL BE REPAIRED BY SPOT PRIMING AND REPAINTING. REPAIR PAINTING SHALL BE APPLIED AS REQUIRED TO PRODUCE A FINISH EQUAL TO THE SHOP PAINT FINISH.

4.1.3

THE SCOPE OF WORK INCLUDES PAINTING OF COLOUR BANDS, LETTERING, MARKING AND SIGNS FOR DIRECTION OF FLOW/ROTATION, NAMES ETC OF APPROVED COLOURS AS PER THE STANDARD COLOUR CODES AND SPECIFICATIONS SPECIFIED IN TENDER SPECIFICATION OR AS ADVISED BY BHEL/CUSTOMER ENGINEER AT SITE FOR THE EQUIPMENTS/ COMPONENTS COVERED IN THESE SPECIFICATIONS.

4.1.4

ALL EXPOSED METAL PARTS OF THE EQUIPMENT INCLUDING PIPING, STRUCTURES, HAND RAILING, VALVES, HANGERS, GRATING ETC SHALL BE THOROUGHLY CLEANED OFF DUST, RUST, SCALES AND OTHER FOREIGN MATERIALS BY MANUAL OR MECHANISED WIRE BRUSHING, SCRAPPING, SAND BLASTING ETC AND THE SAME BEING INSPECTED AND APPROVED BY BHEL/CUSTOMER ENGINEER BEFORE APPLICATION OF PRIMER. AFTERWARDS, THE ABOVE PARTS SHALL BE FINISH PAINTED WITH SPECIFIED NUMBER OF COATS AS PER SPECIFICATION.

4.1.5

SURFACE TO BE PAINTED SHOULD BE FREE OF ALL DIRT, DUST, SAND, GRIT, MUD, OIL, GREASE, LOOSE MILL SCALE, AND OTHER OBJECTIONABLE SUBSTANCES. SURFACE CLEANED BY CHEMICAL AGENT, IF REQUIRED, SHALL BE TREATED FURTHER AS PRESCRIBED IN USE OF SUCH CLEANING AGENTS. THE CONTRACTOR AT HIS OWN COST SHALL PROVIDE ALL THE CONSUMABLES AND APPLICATION IMPLEMENTS.

4.1.6

DURING THE PREPARATION OF SURFACE, IF THE SHOP COAT IS DAMAGED BY CHEMICAL CLEANING OR BY MECHANICAL MEANS, CONTRACTOR SHALL REPAIR THE SAME FREE OF COST TO BHEL. BHEL WILL MAKE AVAILABLE ONLY THE PRIMER AND PAINTS FREE OF ANY CHARGE TO CONTRACTOR.

4.1.7

SPECIFIED DRYING TIME SHALL BE PERMITTED FROM ONE TO ANOTHER COAT.

4.1.8

ANY FINISH COATS WHICH SHOW SAGS, CHECKS, BLISTERS, TEARDROPS, OR FAT EDGES SHALL BE REMOVED AND REAPPLIED. DEFECTS IN ANY UNDERCOATS, INCLUDING SHOP COATS, SHALL BE REPAIRED.

4.1.9

THIS WORK REQUIRES WORKING AT HIGHER ALTITUDES FROM GROUND LEVEL TO AS HIGH AS 60 M AND MORE. THE WORK SPREAD IS ALSO SUBSTANTIAL INVOLVING SUBSTANTIAL RUN OF STRUCTURES AND PIPING. CONTRACTOR SHALL TAKE SUFFICIENT PRECAUTIONS TO AVOID ANY ACCIDENT AND HAZARD IN ALL RESPECTS. THE ROPES, LADDERS, SCAFFOLDING MATERIALS, CLAMPS ETC AND CLIMBER USED SHOULD BE OF STANDARD QUALITY FOR SAFE AND SMOOTH EXECUTION OF WORK.

4.1.10

CONTRACTOR SHALL CARRY OUT THE WORK IN SUCH A WAY THAT OTHER ERECTED EQUIPMENT, STRUCTURE, CIVIL FOUNDATIONS AND OTHER PROPERTY ARE NOT DAMAGED. FOR DAMAGES IN ANY OF SUCH CASES DUE TO LAPSES BY CONTRACTOR, BHEL SHALL HAVE THE RIGHT TO RECOVER THE COST OF SUCH DAMAGES FROM THE CONTRACTOR.

4.1.11

CONTRACTOR SHALL TAKE DUE CARE TO COVER/PROTECT THE EQUIPMENT WHICH ARE ALREADY PAINTED WHILE CARRYING OUT THE PAINTING OF OTHER ADJACENT EQUIPMENT. IF SO HAPPENS, IT SHALL BE CLEANED AND REPAINTED BY THE CONTRACTOR WITHOUT ANY EXTRA CHARGES.

4.1.12

IN GENERAL, PAINTING OF STRUCTURAL PARTS AND COLOUR BANDS, LETTERING, MARKING OF DIRECTION OF FLOW/ROTATION ETC WILL BE CARRIED OUT BY BRUSH PAINTING. HOWEVER, AREAS/EQUIPMENT INACCESSIBLE FOR MANUAL PAINTING HAVE TO BE PAINTED BY SPRAY PAINTING. THE DECISION OF BHEL ENGINEER, IN THIS REGARD, SHALL BE FINAL AND BINDING ON THE CONTRACTOR. FOR THE PURPOSE OF SPRAY PAINTING, AIR AT ONE POINT WILL BE MADE AVAILABLE BY BHEL FREE. LAYING OF AIR HOSE PIPE AND ANY OTHER LINE REQUIRED SHALL BE DONE BY CONTRACTOR AT HIS COST. THE CONTRACTOR SHALL PROVIDE SPRAY EQUIPMENT SET.

4.1.13

APPROXIMATE QUANTITY OF WORK INVOLVED IS INDICATED VIDE APPENDIX-I ONLY FOR GENERAL INFORMATION. THESE MAY VARY TO ANY EXTENT. NO CLAIM WHATSOEVER ON ACCOUNT OF ANY VARIATION IN THESE QUANTITIES SHALL BE ENTERTAINED.

4.2.0 COLLECTION OF MATERIALS AND STORAGE ETC.

4.2.1

THE CONTRACTOR SHALL TAKE DELIVERY OF PAINTS, PRIMER ETC FROM THE STORAGE YARD/STORES/SHEDS OF BHEL/CUSTOMER, WHICH IS WITHIN A RADIUS OF 2 KM.

4.2.2

THE CONTRACTOR SHALL PROVIDE ACCOUNT OF ALL THE ITEMS ISSUED TO HIM AND RETURN ALL PRIMER, PAINTS ETC REMAINING EXTRA OVER THE NORMAL REQUIREMENT WITH PROPER IDENTIFICATION TAGS IN A PACKED CONDITION TO

BHEL STORES. IN CASE OF ANY MISUSE OR EXCESS USE OVER THE NORMAL REQUIREMENT, BHEL RESERVES THE RIGHT TO RECOVER THE COST OF SUCH MISUSE/ EXCESS USE. DECISION OF BHEL ENGINEER IN THIS REGARD WILL BE FINAL AND BINDING ON THE CONTRACTOR.

4.2.3

THE CONTRACTOR SHALL MAKE ADEQUATE SECURITY ARRANGEMENTS INCLUDING EMPLOYMENT OF SECURITY PERSONNEL AND ENSURE PROTECTION FROM THEFT, FIRE, PILFERAGE, DAMAGE AND LOSS OF PAINTS ETC ISSUED TO HIM FOR THE WORK.

4.3.0 SITE CLEANLINESS

4.3.1

DURING THE COURSE OF WORK, SCRAP LUMBER WITH PROTRUDING NAILS, SHARP EDGES ETC AND ALL THE DEBRIS SHALL BE KEPT CLEARED FROM WORKING AREA, PASSAGE WAYS AND STAIRS IN AND AROUND SITE. PROPER HOUSEKEEPING IS THE RESPONSIBILITY OF THE CONTRACTOR. CONTRACTOR SHALL DEPOSIT ALL THE SCRAP, PACKING MATERIAL, RUBBISH, UNUSED AND OTHER MATERIALS AT SPECIFIED PLACE.

4.3.2

THE CONTRACTOR SHALL PROVIDE NECESSARY FIRST AID FACILITIES AND SAFETY APPLIANCES AND OUTFIT FOR ALL HIS EMPLOYEES, REPRESENTATIVES AND WORKMEN WORKING AT SITE.

4.4.0 GENERAL

4.4.1

THE WORK COVERED UNDER THIS SPECIFICATION REQUIRES THE BEST QUALITY OF WORKMANSHIP. THE CONTRACTOR SHOULD ENSURE TIMELY COMPLETION OF WORK. THE CONTRACTOR MUST HAVE ADEQUATE QUANTITY OF TOOLS, CONSTRUCTION IMPLEMENTS, EQUIPMENTS ETC, IN HIS POSSESSION. HE MUST ALSO HAVE ON HIS ROLLS ADEQUATE, TRAINED, QUALIFIED & EXPERIENCED SUPERVISORY STAFF AND SKILLED PERSONNEL.

4.4.2

THE WORK SHALL BE EXECUTED UNDER THE USUAL CONDITIONS AFFECTING MAJOR POWER PLANT CONSTRUCTION AND IN CONJUNCTION WITH NUMEROUS OTHER OPERATIONS AT SITE. THE CONTRACTOR AND HIS PERSONNEL SHALL CO-OPERATE WITH THE PERSONNEL OF OTHER OF OTHER AGENCIES, CO-ORDINATE HIS WORK WITH OTHERS AND PROCEED IN A MANNER THAT SHALL NOT DELAY OR HINDER THE PROGRESS OF WORK AS A WHOLE.

4.4.3

ALL THE WORK SHALL BE CARRIED OUT AS PER THE INSTRUCTIONS OF BHEL ENGINEER. BHEL ENGINEERS DECISION REGARDING THE CORRECTNESS OF THE WORK AND METHOD & SEQUENCE OF WORKING SHALL BE FINAL AND BINDING ON THE CONTRACTOR.

4.4.4

ALL THE NECESSARY CERTIFICATES AND LICENSES WHEREVER REQUIRED TO CARRYOUT THIS WORK ARE TO BE ARRANGED BY THE CONTRACTOR EXPEDITIOUSLY AT HIS COST.

4.4.5

THE TERMINAL POINTS AS DECIDED BY BHEL SHALL BE FINAL AND BINDING ON THE CONTRACTOR.

4.4.6

CONTRACTOR IS STRICTLY PROHIBITED FROM USING THE REGULAR COMPONENTS LIKE ANGLES, CHANNELS, BEAMS, PLATES, PIPE/TUBES, AND HANDRAILS ETC FOR ANY TEMPORARY SUPPORTING OR SCAFFOLDING WORKS. CONTRACTOR SHALL ARRANGE HIMSELF ALL SUCH MATERIALS. IN CASE OF SUCH MISUSE OF BHEL MATERIALS, A SUM AS DETERMINED BY BHEL ENGINEER WILL BE RECOVERED FROM CONTRACTOR'S BILLS. THE DECISION OF BHEL ENGINEER IS FINAL AND BINDING ON THE CONTRACTOR.

4.4.7

THE CONTRACTOR SHOULD VISIT THE SITE BEFORE QUOTING HIS RATES, EVALUATE THE VOLUME/ QUANTITY TO BE PAINTED, GET ACQUAINTED WITH SITE CONDITIONS AND SUBMIT HIS RATES. NO REVISION OF RATES SHALL BE ALLOWED UNDER ANY CIRCUMSTANCES.

4.5 EXCLUSIONS

FOLLOWING ARE EXCLUDED FROM THE CONTRACTOR'S SCOPE OF WORK UNDER THIS TENDER SPECIFICATION:

01 SUPPLY OF PRIMER, PAINTS AND THINNER

SECTION-5

SPECIAL CONDITIONS

5.0 OBLIGATIONS OF THE CONTRACTOR (TOOLS, TACKLES, CONSUMABLES) ETC

5.1 TOOLS AND TACKLES AND MMDs

5.1.1

CONTRACTOR IS REQUIRED TO PROVIDE ALL NECESSARY TOOLS AND PLANTS, MEASURING INSTRUMENTS (ELCOMETER ETC) AND HANDLING EQUIPMENTS FOR THIS SCOPE OF WORK. BHEL IS NOT PROVIDING ANY T & P FOR THIS WORK.

5.1.2

THE CONTRACTOR SHALL PROVIDE ALL THE NECESSARY SCAFFOLDING MATERIALS, TEMPORARY STRUCTURES AND NECESSARY SAFETY DEVICES ETC, DURING EXECUTION OF THE WORK.

5.1.3

TIMELY DEPLOYMENT OF ADEQUATE QUANTITY OF T&P IS THE RESPONSIBILITY OF THE CONTRACTOR. THE CONTRACTOR SHALL BE PREPARED TO AUGMENT THE T&P AT SHORT NOTICE TO MATCH THE PLANNED PROGRAMME AND TO ACHIEVE THE MILESTONES.

5.2.0 CONSUMABLES

5.2.1

THE CONTRACTOR SHALL PROVIDE ALL CONSUMABLES REQUIRED FOR CARRYING OUT THE WORK COVERED UNDER THIS SCOPE OF WORK EXCEPTING THOSE WHICH ARE SPECIFICALLY INDICATED AS BHEL SUPPLY.

5.2.2

ALL CONSUMABLES, TO BE PROCURED AND USED FOR THE WORK SHALL HAVE PRIOR APPROVAL OF BHEL ENGINEER IN REGARD TO BRAND AND QUALITY SPECIFICATION.

5.3 ACCOMMODATION, DRINKING WATER & LOCAL TRANSPORTATION FOR THE LABOUR OTHER EMPLOYEES (ONLY OPEN SPACE FOR CONSTRUCTION OF LABOUR WILL BE PROVIDED BY CLIENT)

- a) DEVELOPMENT OF THE LAND AND CONSTRUCTION OF LABOUR COLONY, WITH ARRANGEMENTS OF LIGHTING, DRINKING WATER, AND SANITATION ETC IS IN CONTRACTOR'S SCOPE.
- b) FOR ELECTRICITY FOR LABOUR COLONY, CONTRACTOR SHALL MAKE ARRANGEMENT FOR DRAWING AND FURTHER DISTRIBUTION CONFORMING TO

THE STATUTORY & SAFETY REQUIREMENTS. THE ELECTRICITY FOR LABOUR CAMP WILL BE ON CHARGEABLE BASIS AT THE PREVAILING RATE OF STATE ELECTRICITY BOARD.

- c) FOR DRINKING WATER CONTRACTOR HAS TO MAKE HIS OWN ARRANGEMENT INCLUDING DIGGING OF BORE-WELL IF REQUIRED.
- d) THE CONTRACTOR HAS TO MAKE HIS OWN ARRANGEMENT FOR TRANSPORTATION OF HIS WORKMEN AND OTHER EMPLOYEES. BHEL/CLIENT SHALL NOT PROVIDE ANY FACILITY IN THIS REGARD.
- e) SPACE FOR CONSTRUCTION OF LABOUR COLONY WILL BE PROVIDED BY CLIENT FREE OF COST.

5.4.0 FIELD OFFICE

5.4.1

THE CONTRACTOR SHALL MAKE HIS OWN ARRANGEMENTS FOR FIELD OFFICE AND STORES FOR ACCOMMODATING NECESSARY EQUIPMENTS, TOOLS ROOM FOR EXECUTION OF THE WORK. ONLY OPEN SPACE WILL BE PROVIDED BY BHEL CUSTOMER FREE OF CHARGES WITHIN THE PROJECT PREMISES AS PER THE AVAILABILITY OF SPACE.

5.4.2

ON COMPLETION OF WORK, ALL THE TEMPORARY BUILDINGS, STRUCTURES ETC SHALL BE DISMANTLED AND LEVELED AND DEBRIS SHALL BE REMOVED AS PER INSTRUCTION OF BHEL BY THE CONTRACTOR AT HIS COST. IN THE EVENT OF HIS FAILURE TO DO SO, THE SAME WILL BE ARRANGED TO BE REMOVED AND EXPENDITURE THEREOF WILL BE RECOVERED FROM THE CONTRACTOR. THE DECISION OF BHEL ENGINEER IN THIS REGARD SHALL BE FINAL. HOWEVER, THE SCOPE OF DISMANTLING AND LEVELING THE AREA IS LIMITED ONLY TO THE CONTRACTOR'S SITE OFFICE, YARD AND OTHER SPACES OCCUPIED BY THE CONTRACTOR.

5.5.0 AREA LIGHTING

5.5.1

CONTRACTOR SHALL ARRANGE ADEQUATE FLOODLIGHTS, HAND LAMPS AND AREA LIGHTING. PROVISION OF DISTRIBUTION LINES FOR LIGHTING FROM THE SINGLE POINT TO THE REQUIRED PLACE WITH PROPER DISTRIBUTION BOARDS, OBSERVING THE SAFETY RULES LAID DOWN BY THE ELECTRICAL AUTHORITIES OF THE STATE SHALL BE DONE BY THE CONTRACTOR INCLUDING ALL THE MATERIALS LIKE CABLES, FUSES, SWITCH BOARDS ETC

5.6.0 CONSTRUCTION POWER & WATER

5.6.1

CONSTRUCTION POWER (415 V) WILL BE PROVIDED FREE OF COST AT A SINGLE POINT NEAR WORK SITE. HOWEVER THE TAXES & DUTIES (IF ANY) AS CHARGED BY CUSTOMER SHALL BE PAYABLE BUY CONTRACTOR. ADDITIONAL SOURCE AT THE DISCRETION OF BHEL MAY ALSO BE PROVIDED IF NEED ARISES. THE CONTRACTOR SHALL PROVIDE ALL NECESSARY CABLES, FUSES, SWITCHES, SWITCHBOARDS, ENERGY METERS ETC, AND ANY OTHER INSTALLATION AS SPECIFIED BY STATUTORY AUTHORITY IN THIS REGARD FOR FURTHER DRAWL OF POWER. OBTAINING APPROVALS / CLEARANCE OF SUCH INSTALLATIONS, PRIOR TO THEIR BEING PUT TO USE OR AS MAY BE SPECIFIED, SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR.

5.6.2

IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO PROVIDE, MAINTAIN THE COMPLETE INSTALLATION ON THE LOAD SIDE OF THE SUPPLY WITH DUE REGARD TO THE SAFETY REQUIREMENTS AT SITE. ALL CABLING AND INSTALLATIONS SHALL COMPLY IN ALL RESPECTS WITH THE APPROPRIATE STATUTORY REQUIREMENTS.

5.6.3

THE CONTRACTOR SHALL MAKE HIS OWN ARRANGEMENT FOR CONSTRUCTION/DRINKING WATER BY DRILLING SUITABLE BORE WELLS OR ANY OTHER ARRANGEMENT AT HIS COST.

5.6.4

CONTRACTOR SHALL BE WELL EQUIPPED WITH BACK-UP ARRANGEMENT TO TACKLE SITUATIONS ARISING DUE TO FAILURE OF CUSTOMER SUPPLIED POWER, SO AS TO ENSURE CONTINUITY AND COMPLETION OF CRITICAL PROCESSES THAT ARE UNDERWAY AT THE TIME OF POWER FAILURE OR IMPORTANT ACTIVITIES PLANNED IN IMMEDIATE FUTURE.

5.6.5

BHEL IS NOT RESPONSIBLE FOR ANY LOSS OR DAMAGE TO THE CONTRACTOR'S EQUIPMENT AS A RESULT OF VARIATIONS IN VOLTAGE OR FREQUENCY OR INTERRUPTIONS IN POWER SUPPLY.

5.7 CONTRACTOR SHALL AUGMENT HIS RESOURCES SO AS TO MEET THE PROGRAMME OF COMPLETION CONVEYED FROM TIME TO TIME DURING EXECUTION OF WORK.

5.8 RESPONSIBILITIES WITH REGARD TO LABOUR EMPLOYMENT ETC.

REFER CLAUSE 2.8 OF GENERAL CONDITIONS OF CONTRACT ALSO IN THIS REGARD.

5.8.1

CONTRACTOR SHALL ALSO COMPLY WITH THE REQUIREMENTS OF LOCAL AUTHORITIES/ PROJECT AUTHORITIES CALLING FOR POLICE VERIFICATION OF ANTECEDENTS OF THE WORKMEN, STAFF ETC.

5.8.2

BHEL / CUSTOMER MAY INSIST FOR WITNESSING THE REGULAR PAYMENT TO THE LABOUR. THEY MAY ALSO LIKE TO VERIFY THE RELEVANT RECORDS FOR COMPLIANCE WITH STATUTORY REQUIREMENTS. CONTRACTOR SHALL ENABLE SUCH FACILITIES TO BHEL / CUSTOMER.

5.8.3

IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO ARRANGE GATE PASS FOR ALL HIS EMPLOYEES, T&P ETC FOR ENTERING THE PROJECT PREMISES. NECESSARY COORDINATION WITH CUSTOMER OFFICIALS IS THE RESPONSIBILITY OF THE CONTRACTOR. CONTRACTOR TO FOLLOW ALL THE PROCEDURES LAID DOWN BY THE CUSTOMER FOR MAKING GATE PASSES. WHERE PERMITTED, BY CUSTOMER / BHEL, TO WORK BEYOND NORMAL WORKING HOURS, THE CONTRACTOR SHALL ARRANGE NECESSARY WORK PERMITS FOR WORKING BEYOND NORMAL WORKING HOURS.

5.8.4

CONTRACTOR SHALL PROVIDE AT DIFFERENT ELEVATION SUITABLE ARRANGEMENT FOR URINAL AND DRINKING WATER FACILITY WITH NECESSARY PLUMBING & DISPOSAL ARRANGEMENT INCLUDING CONSTRUCTION OF SEPTIC TANK. THESE INSTALLATION SHALL BE MAINTAINED IN HYGIENIC CONDITION AT ALL TIMES.

5.9 OTHER IMPORTANT TERMS AND CONDITIONS

5.9.0 TAXES, DUTIES, LEVIES

5.9.1

Refer to Clause 2.8.4 of General Conditions of Contract. Notwithstanding anything contained therein, the following provisions shall be applicable for this contract.

5.9.2

The contractor shall pay all (save the specific exclusions as enumerated in this contract) taxes, fees, license charges, deposits, duties, tools, royalty, commissions or other charges which may be levied on the input goods & services consumed and output goods & services delivered in course of his operations in executing the contract. In case BHEL is forced to pay any of such taxes, BHEL shall have the right to recover the same from his bills or otherwise as deemed fit.

However, provisions regarding Service Tax and Value Added Tax (VAT) on output services and goods shall be as per following clauses.

5.9.3 Service Tax & Cess on Service Tax

Service Tax and Cess on Service Tax as applicable on output Services are excluded from contractor's scope; therefore contractor's price/rates shall be **exclusive** of Service Tax and Cess on Output Services. In case, it becomes mandatory for the contractor under provisions of relevant act/law to collect the Service Tax & Cess from BHEL and deposit the same with the concerned tax authorities, such applicable amount will be paid by BHEL. Contractor shall submit to BHEL documentary evidence of Service Tax registration and remittance record of such tax immediately after depositing the tax with concerned authorities. Contractor shall obtain prior written consent from BHEL before billing the amount towards such taxes.

With introduction of Cenvat Credit Rules 2004, which came into force w.e.f. 10.09.2004, Excise Duty paid on Input Goods including Capital Goods and Service Tax paid on Input Services that are used for providing the output services can be taken credit of against the Service Tax payable on output services. However BHEL may opt for availing the abatement provision in which case cenvat credit may not be available on input duty.

5.9.4 VAT (Sales Tax /WCT)

As regards Value Added Tax (VAT) on transfer of property in goods involved in Works Contract (previously known as Works Contract Tax) applicable as per local laws, the price quoted by the contractor shall be **exclusive** of the same. Where such taxes are required to be paid by the contractor, this will be reimbursed on production of proof of payment made to the authorities by the Contractor. In any case the Contractor shall register himself with the respective Sales Tax authorities of the state and submit proof of such registration to BHEL along with the first RA bill. The contractor has to take all necessary steps to **minimize tax on input goods** by purchasing the materials from any registered dealer of the concerned state only. In case contractor opts for composition, it will be with the prior express consent of BHEL. Deduction of tax at source shall be made as per the provisions of law unless otherwise found exempted. In case tax is deducted at source as per the provisions of law, this is to be construed as an advance tax paid by the contractor and no reimbursement thereof will be made unless specifically agreed to.

5.9.5 Modalities of Tax Incidence on BHEL

Wherever the relevant tax laws permit more than one option or methodology for discharging the liability of tax/levy/duty, BHEL will have the right to adopt the appropriate one considering the amount of tax liability on BHEL/Client as well as procedural simplicity with regard to assessment of the liability. The option chosen by BHEL shall be binding on the Contractor for discharging the obligation of BHEL in respect of the tax liability to the Contractor.

5.9.6 New Taxes/Levies

In case the Government imposes any new levy/tax on the output service/ goods/work after award of the contract, the same shall be reimbursed by BHEL at actual.

In case any new tax/levy/duty etc. becomes applicable after the date of Bidder's offer, the Bidder/Contractor must convey its impact on his price duly substantiated by documentary evidence in support of the same **before opening of Price Bid**. Claim for any such impact after opening the Price Bid will not be considered by BHEL for reimbursement of tax or reassessment of offer.

No reimbursement/recovery on account of increase/reduction in the rate of taxes, levies, duties etc. on input goods/services/work shall be made. Such impact shall be taken care of by the Price Variation/Adjustment Clause (PVC) if any. In case PVC is not applicable for the contract, Bidder has to make his own assessment of the impact of future variation if any, in rates of taxes/duties/levies etc. in his price bid.

5.10.0 SUBMISSION OF PERIODICAL REPORTS

CONTRACTOR SHALL SUBMIT PERIODICAL REPORTS IN RESPECT OF FOLLOWING ASPECTS OF OPERATION:

1. CONSUMPTION OF CONSTRUCTION POWER
2. AVAILABILITY AND UTILIZATION OF BHEL'S CRANES (IF ANY)
3. MANPOWER REPORTS - DAILY
4. PROGRESS REPORTS - DAILY
5. CALIBRATION REPORTS OF INSTRUMENTS
6. RECORD OF WAGES PAYMENT, PF REMITTANCES
7. RECONCILIATION OF BHEL SUPPLIED MATERIALS – MONTHLY
8. ACCIDENT REPORT (IF ANY) WITHIN 24 HRS.

BHEL AT SITE WILL INFORM FORMATS FOR THESE REPORTS.

IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO ARRANGE GATE PASS FOR ALL HIS EMPLOYEES, T&P ETC. NECESSARY COORDINATION WITH CUSTOMER OFFICIALS IS THE RESPONSIBILITY OF THE CONTRACTOR. CONTRACTOR TO FOLLOW ALL THE PROCEDURES LAID DOWN BY THE CUSTOMER FOR MAKING GATE PASSES. WHERE PERMITTED, BY CUSTOMER/BHEL, TO WORK BEYOND NORMAL WORKING HOURS, THE CONTRACTOR SHALL ARRANGE NECESSARY WORK PERMIT FOR WORKING BEYOND NORMAL WORKING HOURS.

5.8.1 THE SCOPE OF WORK UNDER THIS CONTRACT IS DEEMED TO BE COMPLETE ONLY WHEN SO CERTIFIED BY THE ENGINEER INCHARGE OF BHEL.

5.11.0 INSURANCE:

(A) BHEL SHALL ARRANGE INSURANCE COVERAGE FOR THE MATERIALS AND PROPERTIES OF BHEL/CUSTOMER COVERING THE RISKS DURING TRANSIT, STORAGE, ERECTION AND COMMISSIONING.

(B) THE CONTRACTOR HAS TO ARRANGE ON HIS OWN, INSURANCE FOR ALL MATERIALS LIKE CEMENT AND OTHER BOUGHT OUT ITEMS, AND FOR THEIR ALL T & P AND OTHER FIXED ASSETS WHICH THEY MAY HAVE TO ACQUIRE AND DEPLOY AT SITE. IT IS ALSO THE RESPONSIBILITY OF THE CONTRACTOR TO ARRANGE FOR ACCIDENT RISK POLICY/WORKMEN COMPENSATION POLICY. THE CONTRACTOR HAS TO ARRANGE ON HIS OWN INSURANCE FOR THEIR SUPPLIED MATERIALS LIKE CEMENT, AND OTHER VALUABLE BUILDING MATERIALS DURING ITS TRANSPORT, STORAGE, TILL IT GOES TO THE PERMANENT WORK.

(C)

IT IS THE ENTIRE RESPONSIBILITY OF THE CONTRACTOR TO INSURE HIS WORKMEN AGAINST ACCIDENT AND INJURY WHILE AT WORK AS REQUIRED BY THE RELEVANT RULES AND TO PAY COMPENSATION, IF ANY, TO THEIR WORKMEN AS PER WORKMEN'S COMPENSATION ACT. THE CONTRACTOR HAS ALSO TO INSURE HIS STAFF AGAINST ACCIDENT/INJURY. THE CONTRACTOR HAS TO TAKE INSURANCE COVER FOR HIS TOOLS AND PLANTS, ASSETS ETC. (D) THESE INSURANCE COVERS HAVE TO BE TAKEN PRIOR TO START OF HIS WORK AT THE SUBJECT PROJECT AND HE SHALL MAKE AVAILABLE THE POLICY TO BHEL SITE IN-CHARGE FOR NECESSARY VERIFICATION BEFORE COMMENCEMENT OF WORK. HOWEVER, IRRESPECTIVE OF SUCH VERIFICATION/ACCEPTANCE, THE SOLE RESPONSIBILITY TO MAINTAIN ADEQUATE INSURANCE COVER FOR HIS WORKMEN, T&P, ASSETS ETC. AT ALL TIMES DURING THE PERIOD OF CONTRACT SHALL LIE WITH THE CONTRACTOR. REGARDING THE AFORESAID INSURANCE COVER, THE CONTRACTOR SHALL DIRECTLY DEAL WITH THE INSURANCE COMPANY FOR ALL MATTERS REGARDING THE INSURANCE IN HIS SCOPE.

SECTION-6

SPECIAL CONDITIONS OF CONTRACT

6.0 CONTRACTOR'S OBLIGATION WITH REGARD TO EMPLOYMENT OF SUPERVISORY STAFF AND WORKMEN

6.1 SUPERVISORY STAFF AND LABOUR

6.1.1

The contractor shall supply all the skilled/unskilled labour for the work. BHEL reserves the right to decide on the suitability of the workers and other personnel who will be employed by the contractor. BHEL reserves the right to insist on removal of any employee of the contractor at any time if he is found to be unsuitable and the contractor shall forthwith remove him.

6.1.2

It is the responsibility of the contractor to engage his workmen in shifts and or on overtime basis for achieving the target set by BHEL. This target may be set to suit BHEL's commitments to its customer or to advance date of completion of events or due to other reasons. The decision of BHEL in regard to setting the targets will be final and binding on the contractor.

6.1.3

Contractor shall employ only qualified and experienced engineers/supervisors for this job. They shall have professional approach in executing the work having adequate knowledge and experience in the fields. Contractor shall give an organization chart indicating the staffing pattern.

6.2 INDUSTRIAL RELATIONS AND LABOUR LAWS

6.2.1

An industrial relations supervisor shall coordinate for the implementation of local labour laws, maintenance of records as required by contract labour (regulation and abolition act) and also coordinate with the local labour authorities. Contractor has to ensure minimum wages payment to their labours as per the rule of the state and they have to produce documentary evidence to that effect to BHEL.

6.2.2

Contractor shall provide the names and details of Engineer/ Supervisors at the time of mobilization to BHEL as per the proposed organization chart.

6.2.3

In case at any time the contractor is not in a position to deploy the required Engineers/Supervisors due to any reason, BHEL shall have the option to deploy their Engineers/supervisors. The expenditure incurred with overheads on this account will be recovered from the contractor's bills.

6.2.4

The contractor's supervisory staff shall execute the work in the most substantial and workmanlike manner in the stipulated time. Accuracy of work and aesthetic finish are essential part of this contract. They shall be responsible to ensure that the assembly and workmanship conform to dimensions and tolerances given in the drawings/ instructions given by BHEL Engineer from time to time.

6.2.5

The supervisory staff employed by the contractor shall ensure proper outturn of work and discipline on the part of the labour put on the job by the contractor and in general, see that the works are carried out in a safe and proper manner and in coordination with other labour and staff employed directly by BHEL or other contractors of BHEL or BHEL's Client.

6.2.6

Contractor will deduct the necessary amount from his employees towards provident fund and contribute the equal amount as per Government of India rules. This amount will be deposited regularly to the Provident Fund Commissioner and an account code obtained. Contractor shall submit the above account code duly certified by PF Commissioner to BHEL project in-charge. Also all other employees' benefits are to be borne by the contractor as per statutory laws.

6.2.7

The contractor shall obtain independent Labour License under the Contract Labour (regulation and abolition) Act from the concerned authorities based on the certificate (form-V) issued by the principal employer/customer.

6.2.8

The contractor shall pay for all taxes, fees, license charges, local body clearance, duties, tools, royalty, commissions and other charges, Gate passes which may be leviable on account of his operation in executing the contract. In case BHEL is forced to make any such payments, BHEL shall have the right to recover the same from Contractor's bills.

SECTION-7

SPECIAL CONDITIONS OF CONTRACT

- 7.0 OBLIGATIONS OF BHEL
- 7.1 FACILITIES PROVIDED BY BHEL
 - 7.1.1 SPACE FOR FIELD OFFICE
REFER SECTION-5 IN THIS REGARD.
 - 7.1.2 CONSTRUCTION WATER
REFER SECTION-5 IN THIS REGARD.
 - 7.1.3 CONSTRUCTION POWER
REFER SECTION-5 IN THIS REGARD.
 - 7.1.4 OTHER MATERIALS AND CONSUMABLES:
BHEL SHALL NOT PROVIDE ANY MATERIAL/CONSUMABLES EXCEPT
THOSE SPECIFICALLY MENTIONED IN THIS TENDER SPECIFICATION.
- 7.2 TOOLS & PLANTS

BHEL IS NOT PROVIDING ANY TOOLS AND PLANTS AND MEASURING INSTRUMENTS FOR THIS WORK.

SECTION-8

SPECIAL CONDITIONS OF CONTRACT

- 8.0 INSPECTION/QUALITY ASSURANCE/QUALITY CONTROL/ STATUTORY INSPECTION**
- 8.1 Various inspection/quality control/quality assurance procedures/ methods at various stages of erection and commissioning will be as per BHEL/customer quality control procedure/codes/IBR and other statutory provisions and as per BHEL engineer's instructions.
- 8.2 Preparation of quality assurance log sheets and protocols with customer/consultants/statutory authority, welding logs, NDE and post weld heat treatment records, testing & calibration records and other quality control and quality assurance documentation as per BHEL engineer's instructions, is within the scope of work/specification. These records shall be submitted to BHEL/customer for approval from time to time.
- 8.3 A daily logbook of all measurements and testing/calibration should be maintained by contractor on the job for detailing inspection details of various equipments.
- 8.4 The performance of HP welders will be reviewed from time to time as per the BHEL/IBR standards. High-pressure welders' performance record shall be furnished periodically. Corrective action as informed by BHEL shall be taken in respect of those welders not conforming to these standards. This may include removal/ discontinuance of concerned welder(s). Contractor shall arrange for the alternate welders immediately.
- 8.5 All the welders including HP welders shall carry identity cards as per the pro-forma prescribed by BHEL only welders duly authorised by BHEL/boiler inspector/customer/consultant shall be engaged on the work.
- 8.6 Contractor shall provide all the inspection, measurement and monitoring devices (MMD) required for completion of the work satisfactorily. These MMD shall conform to job requirement in respect of measurement range, accuracy level & any other specification. The list will be reviewed by BHEL and the contractor shall meet any augmentation needed.
- 8.7 The MMD deployed by the contractor shall, at all stages of work, have valid and current calibration. The calibration of these MMD shall be got done from the agencies accredited/ approved by BHEL. Copy of calibration certificates in respect of these MMD has to be submitted to BHEL. Periodical status report regarding validity of calibration has to be submitted to BHEL. Re-calibration/ re-validation shall be done periodically as per BHEL specifications. Contractor shall conform to the specifications of BHEL regarding storage of the MMD.

- 8.8 Re-work necessitated on account of use of invalid MMD shall be entirely to the contractor's account. He shall be responsible to take all corrective actions, including resource augmentation if any, as specified by BHEL to make-up for the loss of time.
- 8.9 In the course of work BHEL may counter/ finally check the measurements with their own MMD. Contractor shall render all assistance in conduct of such counter/final measurements.
- 8.10 Vibration indicators/vibration recorders/vibration analysers will be provided by BHEL for checking and analysing vibration levels of rotating equipments with necessary operators. Contractor shall be provided necessary labour for carrying out such tests. Similarly, BHEL will provide the oscilloscope for any specific requirement.
- 8.11 Total quality is the watchword of the work and contractor shall strive to achieve the quality standards, procedures laid down by BHEL. He shall follow all the instructions as per BHEL drawings and quality standards. Contractor shall provide for the services of quality assurance engineer.
- 8.12 **STAGE INSPECTION BY FES/QA ENGINEERS**
- 8.12.1 Apart from day-to-day inspection by BHEL engineers stationed at site and also by customer's engineers, stage inspection of equipments under erection and commissioning at various stages of erection and commissioning by teams of engineers from field engineering services of BHEL's manufacturing units and quality assurance teams from field quality assurance factory quality assurance and commissioning engineers from technical services of BHEL will also be conducted. Contractor shall arrange all labour, tools and tackles etc, for such stage inspections as part of work.
- 8.13 **STATUTORY INSPECTION OF WORK**
- 8.13.1 The work to be executed under these specifications has to be offered for inspection, at appropriate stages of work completion, to various relevant statutory authorities to show compliance with applicable regulations.
- 8.13.2 The work related statutory inspections, though not limited to, are as under:
- 1) Inspectorate of steam boilers and smoke nuisance
 - 2) Any other authority connected to this work.
- The scope includes getting the approvals from the statutory authorities, which includes arranging for inspection visits of statutory authority periodically as per BHEL engineer's instructions, submitting documents, radiographs etc And following up the matter with them. Contractor shall also make all arrangements for offering the products/systems for inspection, as applicable, to the concerned authority.

- 8.13.3 The contractors shall pay all fees connected with testing of his welders/workers and testing, inspection & calibration of his MMD and T&P.
- 8.13.4 It shall be contractor's responsibility to obtain approval of statutory authorities, whenever applicable, for the conducting of any work which comes under the purview of these authorities. Any cost arising from this shall be contractor's account.
- 8.13.5 BHEL will pay fees for visits, inspection fees etc Of these statutory authorities. All other expenses shall be borne by the contractor. In case these inspections have to be repeated due to default/fault of the contractor and fees have to be paid again, the contractor has to bear the charges.
- 8.13.6 Contractor should be qualified to execute pressure parts & piping work coming under the purview of IBR, for which he should register himself with CIB concerned state. Similarly it is the responsibility of contractor to obtain license from chief electrical inspector, concerned state for carrying out high voltage work. Contractor also should be aware of the latest IBR regulations and electricity act, including the amendments thereof.
- 8.14.0 The quality management system of BHEL, Power Sector – Western Region (PS-WR) has already been certified and accredited under I.S.O. 9002 standards in this regard. The basic philosophy of the quality management system is to define the organizational responsibility, work as per documented procedures, verify the output with respect to acceptance norms, identify the non-conforming product/ procedure and take corrective action for removal of non-conformance specifying the steps for avoiding recurrence of such non-conformities, & maintain the relevant quality records. The non-conformities are to be identified through the conduct of periodical audit of implementation of quality systems at various locations/stages of work. Suppliers/vendors of various products/services contributing in the work are also considered as part of the quality management system. .as such the contractor is expected not only to conform to the quality management system of BHEL but also it is desirable that they themselves are accredited under any quality management system standard.

SECTION-9

SPECIAL CONDITIONS OF CONTRACT

SAFETY, OCCUPATIONAL HEALTH AND ENVIRONMENTAL MANAGEMENT

BHEL PSWR has been certified for Environmental Management under ISO 14001:1996 standard and Occupational Health & Safety under OHSAS 18001 by DNV. In order to comply with the above standards, it shall be the endeavour of BHEL and all its subcontractors to meet and implement the requirements by following the guidelines issued under Environmental, Occupational Health and Safety Management (EHS) manual a copy of which will be available with the BHEL Site-in-charge.

Contractor shall also enter into a "Memorandum of Understanding" as given in clause 9.9 in case of award of contract.

9.0 RESPONSIBILITY OF THE CONTRACTOR IN RESPECT OF SAFETY OF MEN, EQUIPMENT, MATERIAL AND ENVIRONMENT.

9.1 THE CONTRACTOR SHALL

- 9.1.1 Abide by the Safety Regulations applicable for the Site/Project and in particular as mentioned in the booklet "Safe Work Practices" issued by BHEL. Contractors are also to ensure that their employees and workmen use safety equipments as stipulated in the Factories Act (Latest Revision) during the execution of the work. Failure to use safety equipment as required by BHEL Engineer will be a sufficient reason for issuance of memo, which shall become part of Safety evaluation of the contractor at the end of the Project. Also all site work may be suspended if it is found that the workmen are employing unsafe working practice and all the costs/losses incurred due to suspension of work shall be borne by contractor. A comprehensive list of National Standards from which the contractor can draw references for complying with various requirements under this section is given under 9.10
- 9.1.2 Hold BHEL harmless and indemnified from and against all claims, cost and charges under Workmen's Compensation Act 1923 and 1933 and any amendment thereof and the contractor shall be solely responsible for the same.
- 9.1.3 Abide by the Procedure governing entry/exit of the contractor's personnel within the Customer/Client premises. All the contractors employees shall be permitted to enter only on displaying of authorized Photo passes or any other documents as authorised by the Customer/Client
- 9.1.4 Be fully responsible for the identity, conduct and integrity of the personnel/ workers engaged by them for carrying out the contract work and ensure that none of them are ever engaged in any anti national activity
- 9.1.5.1 Prepare a signboard giving the following information and display it near work site:
 - Name of Contractor
 - Name of Contractor Site-in-charge & Telephone number
 - Job Description in short
 - Date of start of job
 - Date of expected completion
 - Name of BHEL Site-in-charge.

9.1.5 Abide by the rules and regulations existing during the contract period as applicable for the contractors at the Project premises.

9.1.6 Observe the timings of work as advised by BHEL Engineer-in-charge for carrying out the contract work.

9.2 **SPECIAL CONDITIONS**

9.2.1 **SAFETY**

9.2.1.1 **SAFETY PLAN**

Before commencing the work, contractor shall submit a “safety plan” to the authorised BHEL official. The safety plan shall indicate in detail the measures that would be taken by the contractor to ensure safety to men, equipment, material and environment during execution of the work. The plan shall take care to satisfy all requirements specified hereunder.

The contractor shall submit “safety plan” before start of work. During negotiations, before placing of work order and during execution of the contract, BHEL shall have right to review and suggest modifications in the safety plan. Contractor shall abide by BHEL’s decision in this respect.

9.2.1.2 The contractor shall take all necessary safety precautions and arrange for appropriate appliances and/or as per direction of BHEL or it’s authorised person to prevent loss of human lives, injuries to men engaged and damage to property and environment.

9.2.1.3 The contractor shall provide to his work force and also ensure the use of Personnel Protection Equipment (PPE) as found necessary and/or as directed and advised by BHEL officials without which permission is liable to be denied.

- Safety helmets conforming to IS 2925/1984 (1990)
- Safety belts conforming to IS 3521/1989
- Safety shoes conforming to IS 1989 part-II /1986(1992)
- Eye and face protection devices conforming to IS 2573/1986(1991), IS 6994 (1973), part-I (1991), IS 8807/1978 (1991), IS 8519/1977(1991).
- Other job specific PPEs of standard ISI make as may be prescribed

9.2.1.4 All tools, tackles, lifting appliances, material handling equipment, scaffolds, cradles, cages, safety nets, ladders, equipment, etc used by the contractor shall be of safe design and construction. These shall be tested and certificate of fitness obtained before putting them to use and from time to time as instructed by authorised BHEL official who shall have the right to ban the use of any item found to be unsafe

9.2.1.5 All electrical equipment, connections and wiring for construction power, its distribution and use shall conform to the requirements of Indian Electricity Act and Rules. Only electricians licensed by the appropriate statutory

authority shall be employed by the contractor to carryout all types of electrical works. All electrical appliances including portable electric tools used by the contractor shall have safe plugging system to source of power and be appropriately earthed.

- 9.2.1.6 The contractor shall not use any hand lamp energised by electric power with supply voltage of more than 24 volts. For work in confined spaces, lighting shall be arranged with power source of not more than 24 volts.
- 9.2.1.7 The contractor shall adopt all fire safety measures as per relevant Indian Standards
- 9.2.1.8 Where it becomes necessary to provide and/or store petroleum products, explosives, chemicals and liquid or gaseous fuel or any other substance that may cause fire or explosion, the contractor shall be responsible for carrying out such provisions and/or storage in accordance with the rules and regulations laid down by the relevant government acts, such as petroleum act, explosives act, petroleum and carbides of calcium manual of the chief controller of explosives, Government of India etc. The contractor in all such matters shall also take prior approval of the authorised BHEL official at the site.
- 9.2.1.9 Proper means of access must be used e.g. ladders, scaffolds, platforms etc. No makeshift access such as oil drums or pallets shall be used. Design of these will be in accordance with relevant standards and certified by competent persons before use.
- 9.2.1.10 Temporary arrangements made at Site for lifting , platforms, approach, access etc should be properly designed and approved before being put to use.
- 9.2.1.11 All excavations and openings must be securely and adequately fenced/barricaded and warning signs erected when considered necessary as per relevant code of practice.
- 9.2.1.12 No persons shall remove guard rails, covers or protective devices unless authorised by a responsible supervisor and alternative precautions have been taken
- 9.2.1.13 Access ways, means of escape and fire exits shall be clearly marked, kept clear and unobstructed at all times
- 9.2.1.14 Only authorised persons holding relevant license will drive and operate site plant and equipments eg cranes, dumpers, excavators, transport vehicles etc
- 9.2.1.15 Only authorised personnel are allowed to repair, commission electrical equipments.

- 9.2.1.16 Gas cylinders shall be handled and stored as per Gas Cylinder Rules and relevant safe working practices
- 9.2.1.17 All wastes generated at Site shall be segregated and collected in a designated place so as to prevent spillage/contamination/scattering at Site, until the waste is lifted for disposal to designated disposal area as advised by BHEL official.
- 9.2.1.18 The contractor shall arrange at his cost (wherever not specified) appropriate illumination at all work spots for safe working when natural day light is not adequate for clear visibility.
- 9.2.1.19 The contractor shall train adequate number of workers/supervisors for administering "FIRST AID". List of competent first aid administrators should be prominently displayed.
- 9.2.1.20 The contractor shall display at strategic places and in adequate numbers the following in fluorescent markings
- Emergency telephone numbers
 - Exit, Walkways
 - Safe working load charts for wire ropes, slings, D shackles etc
 - Warning signs
- 9.2.1.21 The contractor shall be held responsible for any violation of statutory regulations (local, state or central) and BHEL instructions that may endanger safety of men, equipment, material and environment in his scope of work or other contractors or agencies. Cost of damage, if any, to life and property arising out of such violation of statutory regulations and BHEL instructions shall be borne by the contractor.
- 9.2.1.22 In case of a fatal or disabling injury/accident to any person at construction sites due to lapses by the contractor, the victim and/or his/her dependents shall be compensated by the contractor as per statutory requirements. However, if considered necessary, BHEL shall have the right to impose appropriate financial penalty on the contractor and recover the same from payments due to the contractor for suitably compensating the victim and/or his/her dependents. Before imposing any such penalty, appropriate enquiry shall be held by BHEL giving opportunity to the contractor to present his case.
- 9.2.1.23 In case of any damage to property due to lapses by the contractor, BHEL shall have the right to recover cost of such damages from payments due to the contractor after holding an appropriate enquiry.
- 9.2.1.24 In case of any delay in the completion of a job due to mishaps attributable to lapses by the contractor, BHEL shall have the right to recover cost of such delay from payments due to the contractor after notifying the contractor suitably and giving him opportunity to present his case.

- 9.2.1.25 If the contractor fails to improve the standards of safety in its operation to the satisfaction of BHEL after being given a reasonable opportunity to do so, and/or if the contractor fails to take appropriate safety precautions or to provide necessary safety devices and equipment or to carry out instructions regarding safety issued by the authorised BHEL official, BHEL shall have the right to take corrective steps at the risk and cost of the contractor after giving a notice of not less than seven days indicating the steps that would be taken by BHEL.

EMERGENCY RESPONSE

BHEL will have an Emergency Response Plan for each Project Site in consultation with the Owner as the case may be, detailing the procedure for mobilisation of personnel and equipment, and defining the responsibilities of the personnel indicated, in order to prepare for any emergency that may arise in order to ensure the priorities of

- Safeguard of life
- Protect assets under construction or neighbouring
- Protect environment
- Resumption of normal operations as soon as the emergency condition is called off

All Contractors shall also be part of the Emergency response Plan and the personnel so nominated shall be aware of their duties and responsibilities in an emergency response situation.

- 9.2.1.26 At least 5% Contractors supervisors and workmen shall undergo training in administering 'First Aid'. The trained persons should represent for all categories of work and for all areas of work. Adequate number of trained persons should be available for each shift. These first aiders shall be included in the emergency response team. Contractor employees and workmen are encouraged to participate in first aid training programmes whenever organised by BHEL.

9.2.2 OCCUPATIONAL HEALTH

- 9.2.2.1 Specific occupational health hazards will be identified through the hazard evaluation processes in consultation with BHEL engineers and the necessary prevention/reduction/elimination methods implemented.
- 9.2.2.2 All personnel working in an activity with a potential risk to health shall be made aware of all those risks and the actions they must take to reduce/control/eliminate the risk
- 9.2.2.3 Safety coordinator shall conduct periodic checks to ensure that every group of workers engaged in similar activities are aware of potential risks to health and the actions required to be taken to mitigate the risk

- 9.2.2.4 In order to protect personnel from associated health hazards, the following main areas will be focussed
- Issue of approved Personnel Protective Equipment
 - Verification that the PPEs are adequate/maintained and worn by all staff involved in operations that are potentially hazardous to their health
 - Ensure that the personnel deployed are physically fit for the operation/work concerned
 - Provide hygienic and sanitary working conditions
- 9.2.2.5 Contractor workers employees engaged in noise risk areas shall be issued with hearing protection aids and the use of the same will be enforced. Further, these workers will be educated on the hazards of noise
- 9.2.2.6 Contractor workers engaged in dust environment shall be issued with necessary dust protection aids and the use of the same shall be enforced.
- 9.2.2.7 Workers engaged in exposure to bright light/rays as in welding or radiation shall be issued with eye protection devices and the use of the same shall be enforced
- 9.2.2.8 Adequate arrangements shall be made to provide safe drinking water
- 9.2.2.9 Health monitoring records on at least sample basis for contractor employees & workmen shall be maintained for persons engaged in specified categories of work. These shall include
- Noise induced hearing loss
 - Lung Function test
 - Ergonomic Test
 - Eye Test for Welders, Grinders, Drivers etc

9.2.3.0 HYGIENE AND HOUSEKEEPING

- 9.2.3.1 Good house keeping and proper hygiene is one of the key requirements of Occupational Health Safety and Environment management. Towards this the contractor shall encourage his workers and supervisors to maintain cleanliness in their area of work.
- 9.2.3.2 The Contractor shall arrange to place waste bins/chutes at convenient locations for the collection of scrap and other wastes. The bins shall be clearly marked and segregated for metal, non-metal, hazardous and non hazardous wastes.
- 9.2.3.3 BHEL may take up appropriate remedial measures at the cost of the contractors if the contractors fail in good housekeeping and if there is an imminent risk of pollution

9.2.4 ENVIRONMENT MANAGEMENT

9.2.4.1 BHEL has a sound environmental management system, which is to be maintained and implemented by all the contractors. The system allows for project specific objectives to be set and developed sensitive to client requirements, applicable environmental legislation and BHEL's own objectives and policy. BHEL engineers will assess and monitor the environmental impact of their work and lay out objectives for their minimisation. The contractors shall implement the objectives for continual improvement of environmental performance. BHEL shall regularly audit environmental impacts and their improvements.

9.2.4.2 WASTE MANAGEMENT

9.2.4.3.1 The objective of waste management is to ensure the safe and responsible disposal of waste, ensuring that it is correctly disposed of and being able to audit the process to ensure compliance.

9.2.4.3.2 Chemical wastes if any shall be collected separately and disposed of to BHEL designated refuse yard as per BHEL advise

9.2.4.3.3 No dangerous chemicals, noxious waste products or materials will be disposed off on or off site without approval obtained through BHEL.

9.2.4.3.4 All disposal of wastes generated during construction shall be in accordance with all relevant legislation.

9.2.4.3.5 Acid and alkali cleaning wastes shall be neutralised to acceptable norms before disposal to the designated area.

9.2.4.3.6 All necessary measures shall be taken to ensure safe collection and disposal of waste oils. In particular to ensure the prevention of their discharge into surface waters, ground waters, coastal waters or drainages

9.3 SUPERVISION

9.3.1 Contractor must provide at least one full time on site safety coordinator when the manpower engaged is in excess of 50 for the contract activities in the premises. If the manpower is less than 50, the on site safety coordination responsibilities shall be assumed by any one of the contractor's other supervisory staff; however in both the cases, the contractor must specify in writing the name of such persons to the BHEL Engineer in Charge .

9.3.2 Contractor's safety coordinator or his supervisor responsible for safety as the case may be shall conduct at his work site, and document formal safety inspection and audits at least once in a week. Such documents are to be submitted to BHEL Engineer in Charge for his review and record

Contractor, supervisor must attend all schedule safety meetings as would be intimated to him by the BHEL Engineer in Charge.

9.3.3 Before starting work under any contract, the contractor must ensure that a job specific safety procedures/field practices as required over and above the safety

permit conditions are prepared and followed .He should also ensure that all supervisors and workers involved understand and follow this procedures /field practices.

- 9.3.4 Contractor must ensure that in his work site appropriate display boards are put displaying signs for site safety , potential hazards and precautions required

9.4.0 **TRAINING & AWARENESS**

- 9.4.1 Contractor shall deploy experienced supervisors and other manpower who are well conversant with the safety and environment regulations of the Project. The electricians to be deployed on the job should have wireman license.

- 9.4.2 All Supervisors & Workmen of the Contractor shall undergo Fire safety training/demonstration whenever arranged by BHEL with the help of either Customer's Fire and Safety department or outside faculty so as to acquire knowledge of fire prevention and also to be able to make use of appropriate fire extinguishers.

- 9.4.3 Contractor must familiarize himself from BHEL Engineer in Charge about all known potential fire, explosion or toxic release hazards related to the contract. He in turn will ensure that same information has been passed to the supervisors and workmen

- 9.4.4 Contractor must ensure that all his supervisors are properly trained and each employee has received and understood from his supervisor necessary training and briefing about the safety requirement. Necessary document as a means to verify that employees have understood the training is to be maintained.

- 9.4.5 The contractor supervisors shall also give a small safety briefing to all the workmen under his charge before undertaking any new work and specially understand the safety requirements that are mandatory

9.5.0 **REPORTING**

- 9.5.1 The contractor shall submit report of all accidents, fires and property damage, dangerous occurrences to the authorised BHEL official immediately after such occurrence but in any case not later than twelve hours of the occurrence. Such report shall be furnished in the manner prescribed by BHEL and also to meet statutory requirement.

- 9.5.2 Any injury sustained by any of the contractor's employees within the Project premises must be reported to BHEL supervisor and FIRST AID should be immediately administered. The Contractor shall be responsible for keeping and maintaining proper records of Accidents to his personnel.

- 9.5.3 Contractor must arrange to immediately investigate, properly document and report any injury, accident or near miss involving any of his employees and take appropriate follow up action. He must furnish within 12 hours of the incident a written report to BHEL Engineer in charge and the Safety Section.

9.5.4 According to the Factory Act and the Employees state Insurance Act & regulation, any person sustaining any injury within the project premises and absenting himself from work for more than 46 hours, his accident report has to be sent to the respective Government Authorities. Therefore contractor shall inform the owner's representative such matter immediately for their needful action.

9.5.5 In addition, contractor shall submit periodic reports on safety to the authorized BHEL official from time to time as prescribed.

9.5.6 Before commencing the work, the contractor shall appoint/nominate a responsible officer to supervise implementation of all safety measures and liaison with his counterpart of BHEL.

9.6 **AUDIT REVIEW AND INSPECTION**

9.6.1 BHEL shall conduct audit on the contractor performance and compliance with the project specific requirements of the Environment and Occupational Health & Safety Management systems. The programme of audit shall cover all activities under the contract but will focus particularly on high-risk activities. The Construction Manager shall decide the schedule of audit. The audit findings shall be communicated to the contractors and necessary remedial action as advised by BHEL Engineers shall be under taken within the stipulated time.

9.6.2 Inspections shall be carried out regularly by the contractors and by BHEL Engineers on activities, facilities, equipment, documentation, to cover the following aspects.

- Compliance with procedures and systems
- Availability, condition and use of PPEs
- Condition of maintenance tools, equipments, facilities
- Availability of fire fighting equipments and its condition
- Use of fire fighting equipments and first aid kit
- Awareness of occupational health hazard
- Awareness of safe working practices
- Presence of quality supervision
- Housekeeping

The Safety Co-ordinator shall visit and inspect work sites daily. All unsafe acts, unsafe conditions that have imminent potential for causing harm/injury/damage will be immediately corrected. He shall maintain a daily logbook giving details of unsafe acts or conditions observed and the corrective action taken and recommendations for preventing recurrence. Adequacy of corrective actions will be verified

The contractor shall take remedial measures as per the findings of each inspection

Besides the above, the contractor shall be required to carry out the following inspections

SN	Equipment	Scope of inspection	Inspection by	Schedule
1	Hand tools	To identify unsafe/defective tool	User	Daily
2	Power tools	To identify unsafe/defective tool	User	Daily
3	Fire Extinguishers	To check pressure and any defect	User / Safety Coordinator	Daily Every month
4	Lifting equipment/ tackles	To check for defects and efficacy of brakes	User Third party	Daily Every Year
5	PPE	To check for defects	User	Daily

9.7 **NON COMPLIANCE:-**

9.7.1 NONCONFORMITY OF SAFETY RULES AND SAFETY APPLIANCES WILL BE VIEWED SERIOUSLY AND THE BHEL HAS RIGHT TO IMPOSE FINES ON THE CONTRACTOR AS UNDER **for every instance of violation noticed:**

SN	VIOLATION OF SAFETY NORM	FINE (RS.)
01	Not Wearing Safety Helmet	50/-
02.	Not wearing Safety Belt	100/-
03.	Grinding Without Goggles	50/-
04.	Not using 24 V Supply For Internal Work	500/-
05.	Electrical Plugs Not used for hand Machine	100/-
06.	Not Slinging property	200/-
07.	Using Damaged Sling	200/-
08.	Lifting Cylinders Without Cage	500/-
09.	Not Using Proper Welding Cable With Lot of Joints And Not Insulated Property.	200/-
10.	Not Removing Small Scrap From Platforms	200/-
11.	Gas Cutting Without Taking Proper Precaution or Not Using Sheet Below Gas Cutting	200/-
12.	Not Maintaining Electric Winches Which are Operated Dangerously	500/-
13.	Improper Earthing Of Electrical T&P	500/-
14.	Accident Resulting in Partial Loss in Earning Capacity	25,000/- per victim
15.	Fatal Accident/Accidents Resulting in total loss in Earning Capacity	1,00,000/- per victim

Any other non-conformity noticed not listed above will also be fined as deemed fit by BHEL. The decision of BHEL engineer is final on the above. The amount will be

deducted from running bills of the contractor. The amount collected above will be utilised for giving award to the employees who could avoid accident by following safety rules. Also the amount will be spent for purchasing the safety appliances and supporting the safety activity at site.

- 9.8** **CITATION**:-If safety record of the contractor in execution of the awarded job is to the satisfaction of safety department of BHEL, issue of an appropriate certificate to recognise the safety performance of the contractor may be considered by BHEL after completion of the job

9.9 **MEMORANDUM OF UNDERSTANDING**

After Award Of Work, Contractors Are Required To Enter Into A Memorandum Of Understanding As Given Below:

4 **MEMORANDUM OF UNDERSTANDING**

BHEL, PSWR is committed to Health, Safety and Environment Policy (EHS Policy) as given in the booklet titled “ Safe Working Practices” issued to all contractors.

M/s _____ do hereby also commit to the same EHS Policy while executing the Contract Number _____

M/s _____ shall ensure that safe work practices not limited to the above booklet are followed by all construction workers and supervisors. Spirit and content therein shall be reached to all workers and supervisors for compliance.

BHEL will be carrying out EHS audits twice a year and M/s _____ shall ensure to close any non-conformity observed/reported within fifteen days.

Signed by authorised representative of M/s-----

Name :

Place & Date:

9.10 Comprehensive list of National Standards for reference and use wherever applicable in the execution of Civil, Erection and Commissioning Contracts

IS No	YEAR	Amd upto	DESCRIPTION
IS 10204	1982		PORTABLE FIRE EXTINGUISHERS MECHANICAL FOAM TYPE
IS 10245	1994		SPECIFICATION FOR BREATHING APPARATUS
IS 10291	1982		SAFETY CODE FOR DRESS DRIVERS IN CIVIL ENGINEERING WORKS
IS 10658	1983		HIGHER CAPACITY DRY POWDER FIRE EXTINGUISHERS (TROLLEY MOUNTED)
IS 10662	1992		COLOUR TELEVISION
IS 10667	1983		GUIDE FOR SELECTION OF INDUSTRIAL SAFETY EQUIPMENT FOR PROTECTION OF FOOT AND LEG
IS 11037	1984		ELECTRONIC FAN REGULATORS
IS 11057	1984		INDUSTRIAL SAFETY NETS
IS 11451	1998		RECOMMENDATION FOR SAFETY AND HEALTH REQUIREMENT RELATING TO OCCUPATION EXPOSURE TO ASBESTOS
IS 1169	1967		PEDESTAL FANS
IS 1179	1967		SPECIFICATION FOR EQUIPMENT FOR EYE AND FACE PROTECTION DURING WELDING
IS 11833	1986		DRY POWDER FIRE EXTINGUISHERS FOR METAL FIRES
IS 11972	1987		CODE OF PRACTICE FOR SAFETY PRECAUTION TO BE TAKEN WHEN ENTERING A SEWAGE SYSTEM
IS 1287	1986		ELECTRIC TOASTER
IS 13063	1991		STRUCTURAL SAFETY OF BUILDINGS ON SHALLOW FOUNDATIONS ON ROCKS
IS 13385	1992		SPECIFICATIONS FOR FIRE EXTINGUISHERS 50 LITRE WHEEL MOUNTED WATER TYPE (GAS CARTRIDGES)
IS 13386	1992		SPECIFICATIONS FOR FIRE EXTINGUISHERS 50 LITRE MECHANICAL FOAM TYPE
IS 13415	1992		CODE OF SAFETY FOR PROTECTIVE BARRIERS IN AND AROUND BUILDINGS
IS 13416	1992		RECOMMENDATIONS FOR PREVENTIVE MEASURES AGAINST HAZARDS AT WORKING PLACE PART 1 TO PART 5
IS 13430	1992		CODE OF PRACTICE FOR SAFETY DURING ADDITIONAL CONSTRUCTION AND ALTERATION TO EXISTING BUILDINGS
IS 13849	1993		PORTABLE FIRE EXTINGUISHERS DRY POWDER TYPE (CONSTANT PRESSURE)
IS 1446	1985		CLASSIFICATION OF DANGEROUS GOODS (FIRST REVISION)
IS 1476	1979		REFRIGERATORS
IS 1641	1988		CODE OF PRACTICE FOR FIRE SAFETY OF BUILDINGS (GENERAL): GENERAL PRINCIPLES OF FIRE GRADING AND CLASSIFICATION
IS 1642	1989		CODE OF PRACTICE FOR FIRE SAFETY OF BUILDINGS- DETAILS OF CONSTRUCTION
IS 1643	1988		CODE OF PRACTICE FOR FIRE SAFETY OF

IS No	YEAR	Amd upto	DESCRIPTION
			BUILDINGS (GENERAL): EXPOSURE HAZARD
IS 1646	1997		CODE OF PRACTICE FOR FIRE SAFETY OF BUILDINGS (GENERAL): ELECTRICAL INSTALLATIONS
IS 1904	1986		CODE OF PRACTICE FOR DESIGN AND CONSTRUCTION OF FOUNDATIONS IN SOIL
IS 1905	1987		STRUCTURAL SAFETY OF BUILDINGS MASONARY WALLS
IS 2082	1985		ELECTRICAL GEYSERS
IS 2171	1985		PORTABLE FIRE EXTINGUISHERS DRY POWDER TYPE (CARTRIDGE)
IS 2309	1989		PRACTICE FOR THE PROTECTION OF BUILDINGS AND ALLIED BUILDINGS AGAINST LIGHTENING
IS 2312	1967		EXHAUST FANS
IS 2361	1994		SPECIFICATION FOR BUILDING GRIPS - FIRST REVISION
IS 2418	1977		TUBULAR FLUORSCENT LAMPS IS 2418 (FT-1)
IS 2750	1964		STEEL SCAFFOLDINGS
IS 2762	1964		SAFE WORKING LOADS IN KGS FOR WIRE ROPE SLINGS
IS 2878	1986		FIRE EXTINGUISHERS CARBON DIOXIDE TYPE (PORTABLE AND TROLLEY MOUNTED)
IS 2925	1984		SPECIFICATION FOR INDUSTRIAL SAFETY HELMETS
IS 3016	1982		CODE OF PRACTICE FOR FIRE PRECAUTIONS IN WELDING AND CUTTING OPERATIONS- FIRST REVISION
IS 3315	1974		DESERT COOLERS
IS 3521	1989		INDUSTRIAL SAFETY BELTS AND HARNESS
IS 368	1983		IMMERSION WATER HEATERS
IS 3696	1991		SAFETY CODE OF SCAFFOLDS AND LADDERS PART 1 TO 2
IS 3737	1996		LEATHER SAFETY BOOTS FOR WORKERS IN HEAVY METAL INDUSTRIES
IS 374	1979		CEILING FANS INCLUDING REGULATORS
IS 3764	1992		EXCAVATION WORK - CODE OF SAFETY
IS 3786	1983		METHOD FOR COMPUTATION OF FREQUENCY AND SEVERITY RATES FOR INDUSTRIAL INJURIES AND CLASSIFICATION OF INDUSTRIAL ACCIDENTS
IS 3935	1966		CODE OF PRACTICE FOR COMPOSITE CONSTRUCTION
IS 4014	1967		CODE OF PRACTICE FOR STEEL TUBULAR SCAFFOLDING
IS 4081	1986		SAFETY CODE FOR BLASTING AND RELATED DRILLING OPERATIONS
IS 4082	1977	1996	STACKING AND STORAGE OF CONSTRUCTION MATERIALS AND COMPONENTS AT SITE
IS 4130	1991		DEMOLITION OF BUILDINGS - CODE OF SAFETY PART 1 TO 2
IS 4138	1977		SAFETY CODE FOR WORKING IN COMPRESSED AIR (FIRST REVISION)
IS 4155	1966		GLOSSARY OF TERMS RELATING TO CHEMICAL AND

IS No	YEAR	Amd upto	DESCRIPTION
			RADIATION HAZARDS AND HAZARDOUS CHEMICALS
IS 4209	1967		CODE OF SAFETY FOR CHEMICAL LABORATORY
IS 4250	1980		FOOD MIXERS
IS 4262	1967		CODE OF SAFETY FOR SULFURIC ACID
IS 4756	1978		SAFETY CODE FOR TUNNELING WORK
IS 4912	1978		SAFETY REQUIREMENTS FOR FLOOR AND WALL OPENINGS, RAILINGS AND TOE BOARDS
IS 5121	1969		SAFETY CODE FOR PILING AND OTHER DEEP FOUNDATIONS
IS 5182	1969	1982	METHODS FOR MEASUREMENT OF AIR POLLUTION
IS 5184	1969		CODE OF SAFETY FOR HYDROFLUORIC ACID
IS 5216	1982	2000	RECOMMENDATIONS ON SAFETY PROCEDURES AND PRACTICE IN ELECTRICAL WORK PART I AND II
IS 555	1979		TABLE FANS
IS 5557	1995		INDUSTRIAL AND SAFETY LINED RUBBER BOOTS (SECOND REVISION)
IS 5916	1970		SAFETY CODE FOR CONSTRUCTION INVOLVING USE OF HOR BITUMINOUS MATERIALS
IS 5983	1980		SPECIFICATION FOR EYE PROTECTORS - FIRST REVISION
IS 6234	1986		PORTABLE FIRE EXTINGUISHERS WATER TYPE (STORED PRESSURE)
IS 692	1994		CRITERIA FOR SAFETY AND DESIGN OF STRUCTURES SUBJECTED TO UNDERGROUND BLASTS
IS 6994	1973		SPECIFICATION FOR SAFETY GLOVES
IS 7155	1986		CODE OF RECOMMENDED PRACTICE FOR CONVEYOR SAFETY (PART 1 TO 8)
IS 7205	1974		SAFETY CODE FOR ERECTION OF STRUCTURAL STEEL WORK
IS 7293	1974		SAFETY CODE FOR WORKING WITH CONSTRUCTION MACHINERY
IS 7323	1994		GUIDELINES FOR OPERATIONS OF RESERVOIRS
IS 7812	1975		CODE OF SAFETY FOR MERCURY
IS 7969	1975		SAFETY CODE FOR HANDLING AND STORAGE OF BUILDING MATERIALS
IS 8089	1976		CODE OF SAFE PRACTICE FOR LAYOUT OF OUTSIDE FACILITIES IN AN INDUSTRIAL PLANT
IS 8091	1976		CODE OF PRACTICE FOR INDUSTRIAL PLANT LAYOUT
IS 8095	1976		ACCIDENTS PREVENTION TAGS
IS 818	1968	1997	CODE OF PRACTICE FOR SAFETY AND HEALTH REQUIREMENTS IN ELECTRIC AND GAS WELDING, AND CUTTING OPERATIONS
IS 8448	1989		AUTOMATIC LINE VOLTAGE CORRECTOR (STABILISER)
IS 8519	1977		GUIDE FOR SELECTION OF INDUSTRIAL SAFETY

IS No	YEAR	Amd upto	DESCRIPTION
			EQUIPMENT FOR BODY PROTECTION
IS 8520	1977		GUIDE FOR SELECTION OF INDUSTRIAL SAFETY EQUIPMENT FOR EYE, FACE AND EAR PROTECTION
IS 875	1987		STRUCTURAL SAFETY OF BUILDING: LOADING STANDARD PART 1 TO 5
IS 8807	1978		GUIDE FOR SELECTION OF INDUSTRIAL SAFETY EQUIPMENT FOR PROTECTION OF ARMS AND HANDS
IS 8978	1985		INSTANTANEOUS WATER HEATERS
IS 8989	1978		SAFETY CODE FOR ERECTION OF CONCRETE FRAMED STRUCTURES
IS 940	1989		PORTABLE FIRE EXTINGUISHERS WATER TYPE (GAS CARTRIDGE)
IS 9457	1980		SAFETY COLOURS AND SIGNS
IS 9679	1980		CODE OF SAFETY FOR WORK ENVIRONMENTAL MONITORING
IS 9706	1997		CODE OF PRACTICE FOR THE CONSTRUCTION OF AERIAL RPEWAYS FOR THE TRANSPORTATION OF MATERIAL
IS 9759	1981		GUIDELINES FOR DEWATERING DURING CONSTRUCTION
IS 9815	1989		SERVO MOTOR OPERATED LINE VOLTAGE CORRECTOR (SERVO STABILISER)
IS 9944	1992		RECOMMENDATIONS ON SAFE WORKING LOAD FOR NATURAL AND MAN-MADE FIBRE ROPE SLINGS
IS 996	1979		SINGLE PHASE ELECTRIC MOTORS
ISO 3873	1977		SAFETY HELMET

SECTION-10

SPECIAL CONDITIONS OF CONTRACT

10.0 DRAWINGS AND DOCUMENTS

10.1

The detailed drawings, specifications available with BHEL engineers will also form part of this tender specification. Revision of drawings/documents may take place due to various considerations as is normal in such large project. Work will have to be carried out as per revised drawings/ documents. These documents will be made available to the contractor during execution of work at site.

10.2

One set of necessary drawings/documents to carry out the erection work will be furnished to the contractor by BHEL on loan that shall be returned to BHEL after completion of the work. Contractor's personnel shall take care of these documents given to them.

10.3

The data furnished in various sections and appendices and the drawings enclosed with this tender specification describe the equipment to be installed, tested and commissioned under this specification, briefly. However, the changes in the design and in the quantity may be expected to occur as is usual in any such large scale of works.

10.4

If any error or ambiguity is discovered in the specification/information contained in the documents/ drawings and tender, the contractor shall forthwith bring the same to the notice of BHEL before submission of offer.

10.5

In case an ambiguity is detected after award of work, the same must be brought to the notice of bhel before commencement of the work/activity. BHEL's interpretation in such cases will be final and binding on the contractor.

10.6

In case of any conflict between general instructions to tenderers, general conditions of contract contained in sections 1 & 2 respectively and special conditions of contract contained in sections 4 to 15 and appendices, provisions contained in special conditions of contract in sections 4 to 15 and appendices shall prevail.

10.7

In case of discrepancy between quoted item rate and corresponding amount in the rate schedule, the **quoted item rates shall be reckoned as correct and amount recalculated.** Quoted item rates shall also prevail for arriving at the total price quoted for offer evaluation. Total price of all the items of Price Bid shall be reckoned for evaluation of tender.

10.8

Bank Guarantees to be furnished by the Contractor towards Security Deposit and Performance Guarantee (Last 5% payment against Workmanship Warranty/Defect Liability) shall have a claim period of six months over and above the validity period required for the case.

---000---

SECTION-11

SPECIAL CONDITIONS

TIME SCHEDULE, MOBILISATION, PROGRESS AND MONITORING, COMPLETION, VARIATION ETC.

11.1 TIME SCHEDULE

CONTRACTOR HAS TO MOBILISE HIS RESOURCES AND WORK FORCE IN SUCH A MANNER THAT THE ENTIRE WORK AS DETAILED IN THIS SPECIFICATION IS COMPLETED SATISFACTORILY IN ALL RESPECTS IN **6 (SIX) MONTHS** FROM START OF WORK AT SITE.

11.2 GRACE PERIOD

A GRACE PERIOD OF 01 (ONE) MONTHS BEYOND THE TIME SCHEDULE SPECIFIED ABOVE IS PROVIDED.

11.3 MOBILISATION

11.3.1

THE CONTRACTOR SHOULD REACH SITE AND ESTABLISH HIS SITE OFFICE AND MOBILISE TO COMMENCE THE WORK AS PER DIRECTIONS OF BHEL ENGINEER. THE DATE OF START OF PAINTING WORK ON ANY EQUIPMENT AS DIRECTED BY BHEL ENGINEER AND SO CERTIFIED BY BHEL ENGINEER WILL BE CONSIDERED AS THE DATE OF START OF CONTRACT. THE TIME TAKEN FOR PREPARATORY WORK SHALL NOT BE CONSIDERED FOR RECONING THE COMMENCEMENT CONTRACT.

11.3.2

CONTRACTOR SHALL MOBILISE AND ARRANGE HIS RESOURCES FOR COMPLETION OF WORK TO SUIT THE PEAK REQUIREMENTS AS ALSO TO ACHIEVE MONTHLY PROGRAMMES AND TARGETS SET BY BHEL ENGINEER. IN A PROJECT OF THIS MAGNITUDE, PREPONEMENT OF SCHEDULES ARE TO BE EXPECTED AND ALSO NORMAL DELAYS IN MATERIAL SUPPLIES AND FRONT AVAILABILITY ARE LIKELY. CONTRACTOR'S OFFER SHALL ACCOUNT FOR ALL SUCH CONTINGENCIES.

11.4.1 PROGRESS MONITORING

Progress will be reviewed periodically including month end review vis-à-vis the plans drawn as above. The contractor shall submit periodical progress reports, and other reports/ information including manpower, consumables etc, as desired by BHEL.

11.4.2 ASCERTAINING AND ESTABLISHING THE REASONS FOR SHORTFALL

The onus probandi that the causes leading to extension in the contract period is not due to any reasons attributable to the contractor is on him (the contractor). Review of the performance as stated vide Cl. 11.4.1 above will be

made considering the availability of components to be erected and other constraints over which the contractor has no control. The programme will be reviewed area-wise and the following facts will be recorded in case of shortfall at the end of every month:

- A) Erection/commissioning programme not achieved owing to non-availability of fronts.
- B) Erection/commissioning programme not achieved owing to non-availability of materials.
- C) Erection/commissioning programme not achieved owing to non-availability of tools and plants, manpower and consumables by the contractor or any other reason attributable to the contractor.

11.4.3 CONTRACT EXTENSION

If the completion of work as detailed in these specification gets delayed beyond the end of contract period and grace period then depending on the balance work left out, BHEL at its discretion may extend the contract.

- 11.4.4 A joint programme shall be drawn for the work to be completed during the extended contract period. Review of the program and record of shortfall as describe vide clause no. 11.4.2 shall be done during the extended period. The over run charges will be paid in proportion to the achievement of the respective month vis-à-vis the plan for the month (for assessing the performance, the agreed plan shall be reduced by shortfall attributable to the BHEL). BHEL may disallow contractor's claim for over run charges if the monthly programme as mentioned here not made by him.

- 11.4.5 The part of extension attributable to the contractor, if any, in total contract extension shall be exhausted first i.e. immediately after end of grace period. This shall be followed by the extension on account of force majeure conditions, if any, and then on account of BHEL.

11.4.6 OVERRUN COMPENSATION

If the contract is extended for any reason other than those attributable to the contractor or force majeure conditions, the contractor will be compensated by payment of over run charges at the rate of Rs.30,000/- (Rupees Thirty Thousand Only) per month. Overrun compensation will be paid for the extension attributable to BHEL. No overrun compensation will be payable for the extension on account of reasons attributable to contractor and/or force majeure conditions.

11.5 PRICE VARIATION

THE RATES QUOTED BY THE CONTRACTOR SHALL REMAIN FIRM DURING THE CONTRACT PERIOD AND GRACE PERIOD AS ALSO DURING THE EXTENDED PERIOD, IF ANY.

No price variation is applicable under this contract. Accordingly, the clause no. 2.15 of general conditions of contract shall not be applicable.

11.6 VARIATION IN QUANTITIES

THE QUANTITIES OF VARIOUS ITEMS OF WORK COVERED UNDER THESE SPECIFICATIONS AND INDICATED IN RELEVANT APPENDICES ARE LIKELY TO VARY. ACCEPTED ITEM RATES SHALL REMAIN FIRM FOR ANY VARIATION EITHER UPWARD OR DOWNWARD IN THESE QUANTITIES AND ONLY THE PRO-RATA PAYMENT BASED ON ACTUAL QUANTITY EXECUTED APPLIED WITH ACCEPTED ITEM RATE SHALL BE MADE. However, no additional/extra payment will be made on account of any variation of quantities.

11.7 INTEREST BEARING RECOVERABLE ADVANCE

Interest bearing (rate of interest will be 1% per annum more than bank interest rate, on monthly reducing balance basis) recoverable advance limited to 5% of the contract value may be paid by BHEL at its discretion depending on the merit of the case against receipt & acceptance of bank guarantee from the contractor for the amount sought. This bank guarantee (BG) shall be valid at least for one year or the recovery duration. In case recovery of dues does not get completed within the aforesaid BG validity period, the contractor must renew the validity of BG or submit fresh BG for the outstanding amount and remaining recovery period. BHEL is entitled to make recovery of the entire outstanding amount in case the contractor fails to comply with the BG requirement as above.

Recovery of dues will be made minimum @ 10% of the admitted gross running bill amount from the first applicable running bill onwards till entire due (principal plus interest) is recovered. In the event sufficient time duration is not left for recovery @10%, the rate of recovery shall be suitably enhanced so that entire due is recovered within the contract period (including extensions granted or foreclosure if any).

11.8 DEFINITION OF WORK COMPLETION

The work under the scope of contractor will be deemed to have been completed in all respect, only when all the activities in these specifications are completed satisfactorily and so certified by BHEL Construction Manager. The decision of BHEL in this regard shall be final and binding on the contractor.

11.9 SECURED ADVANCE

No Secured advance is payable under this contract.

11.10 SPLITTING OF WORK

BHEL reserves the right to split up the work and award to more than one agency in case contractor fails to provide adequate resources, manpower etc. to achieve the desired progress of work

11.11 liquidated damages (L D)

L D shall be applicable as per General Terms & Conditions (GCC) of contract.

SECTION-12 SPECIAL CONDITIONS

12.0 TERMS OF PAYMENT

12.0.1

The contractor shall submit his monthly on account bills with all the details required by BHEL on specified date every month covering progress of work in all respects and areas from the 25th of previous calendar month to 24th of the current month.

12.0.2

Clause 2.6 of general conditions of contract shall be referred to as regards mode of payment, and measurement of the work completed.

12.0.3

Release of payment in each running bill will be restricted to 95% of the value of work admitted, as per the percentage break-up for the stage of work completion stipulated vide clauses hereinafter.

The 5% thus remaining shall be on account of workmanship guarantee of work executed. The same will be released after completion of the guarantee period of **12 months** from the date of completion of entire work as certified by BHEL.

However, on specific request of vendor, this amount may be released on pro rata basis for the value of work executed and accepted by BHEL, along with any RA Bill and onwards, subject to receipt and acceptance of bank guarantee of equal amount in BHEL's prescribed format. The BG shall be kept valid till completion of such guarantee period and an additional six months claim period. This is also subject to the condition that the contractor has started the work and also furnished/remitted the initial Security Deposit as per contract.

12.0.4

The payment for running bills will normally be released within around 30 days of submission of running bill with measurement sheets. Contractor shall make his own arrangement for making payment of impending labour wages and other dues in the meanwhile.

12.0.5

BHEL will release payment through Electronic Fund Transfer (EFT)/RTGS. In order to implement this system, the following details are to be furnished by the Contractor pertaining to his Bank Accounts where proceeds will be transferred through BHEL's banker:

- 1 Name of the Company
- 2 Name of Bank
- 3 Name of Bank Branch
- 4 City/Place
- 5 Account Number
- 6 Account type
- 7 IFSC code of the Bank Branch
- 8 MICR Code of the Bank Branch

BHEL may also choose to release payment by other alternative modes as suitable.

12.1 STAGE-WISE BREAK UP FOR PRO-RATA PROGRESSIVE PAYMENT

12.1.1

98% OF THE ITEM RATE ON PRORATA BASIS ON COMPLETION OF SURFACE CLEANING, COATINGS OF PRIMER AS APPLICABLE AND APPLICATION OF SPECIFIED COATS OF FINISH PAINTS AS PER THE REQUIREMENT.

12.1.2

2% OF THE ITEM RATE ON PRORATA BASIS ON COMPLETION OF COLOUR BAND MARKING, LEGENDS, DIRECTION OF FLOW/ROTATION ETC.

12.2 MEASUREMENT OF THE WORK COMPLETED

- A) WHERE PAYMENT IS TO BE MADE ON THE BASIS OF WEIGHT, THE WEIGHT PER UNIT GIVEN IN THE BHEL DOCUMENT ONLY SHALL BE TAKEN IN TO CONSIDERATION. IN CASE SUCH INFORMATION IS NOT AVAILABLE IN BHEL DOCUMENTS, THEN THE LATEST RELEVANT INDIAN STANDARDS IN THIS REGARD MAY BE APPLIED.
- B) SPARES, SURPLUS QUANTITY, ERECTION CONTINGENCY MATERIALS WILL NOT BE PAID FOR UNLESS THE SAME HAS BEEN CONSUMED IN PLACE OF REGULAR ITEM OF MEASURABLE WORK AS PER THE RATE SCHEDULE.
- C) WHERE THE PAYMENT IS MADE ON THE BASIS OF ITEM RATE, ACTUAL EXECUTED QUANTITY MEASURED JOINTLY SHALL ONLY BE PAID FOR.
- D) IT IS CLARIFIED THAT AS FAR AS WEIGHT CONSTITUTED BY WELDING CONSUMABLES AND OTHER CONSUMABLES SUPPLIED BY BHEL AS WELL AS BY THE CONTRACTOR, SHALL BE IGNORED FOR THE PURPOSE PAYMENT.
- E) BHEL ENGINEER'S DECISION REGARDING STAGE OF PAYMENT CORRESPONDING TO PROGRESS OF WORK, CALCULATION OF WEIGHT ETC. WILL BE FINAL AND BINDING ON THE CONTRACTOR.

SECTION-13

SPECIAL CONDITIONS OF CONTRACT

EXTRA WORK FOR MODIFICATIONS: NOT APPLICABLE

SECTION-14

SPECIAL CONDITIONS

14.0 INSURANCE

14.1 MARINE, STORAGE CUM ERECTION (MCE) INSURANCE AND REPAIRING DAMAGES

14.1.1

BHEL/client has an MCE insurance cover, inter-alia, for all the permanent project equipments/components supplied by BHEL under scope of this work by way of a transit and storage cum erection policy covering liability against damages/ losses etc.

14.2 REPORTING DAMAGES AND CARRYING OUT REPAIRS

14.2.1

Checking all components/equipments at siding/site and reporting to transporter and /or insurance authorities of any damages/losses will be done by BHEL.

14.2.2

Contractor shall render all help to BHEL in inspection including handling, re-stacking etc, assessing and preparing estimates for repairs of components damaged during transit, storage and erection, commissioning and preparing estimates for fabrication of materials lost/damaged during transit, storage and erection. Contractor shall help BHEL to furnish all the data required by railways, insurance company or their surveyors.

14.2.3

Contractor shall report to BHEL in writing any damages to equipments/ components on receipt, storing, and during drawl of the materials from stores, in transit to site and unloading at place of work and during erection and commissioning. The above report shall be as prescribed by BHEL site management. Any consequential loss arising out of non-compliance of this stipulation will be borne by contractor.

14.2.4

Contractor shall carry out fabrication of any material lost/damaged as per instructions from BHEL engineer.

14.2.5

BHEL, however, retains the right to award or not to award to the contractor any of the rectification/rework/repairs of damages and also fabrication of components.

14.2.6

All the repairs/rectification/rework of damages and fabrication of materials lost, if any, shall be carried out by a separately identifiable gang for certification of man-hours. Daily log sheets should be maintained for each work separately and should be signed by contractor's representative and BHEL engineer. Signing of log sheets does not necessarily mean the acceptance of these as extra works.

14.2.7

All rectification, repairs, rework and fabrication of components lost, which are minor and incidental to erection work (consuming not more than 100 man-hours on each occasion) shall be treated as part of work without any extra cost.

14.2.8

Insurance cover under this policy will generally be as per clauses 2.10.1 to 2.10.4 of General Conditions of Contract unless and otherwise specified differently in the Special Conditions.

14.2.9

In case the loss/damage is not attributable to the contractor, Payments of all extra works on account of repair / rectification / reworks of damages and fabrication of materials lost will be as per provisions of Section-13 of SCC.

14.2.10

In case the repairs/rectification/rework and fabrication of materials lost, the work has been done by more than one agency including the contractor, the payment towards extra charges will be on pro-rata basis and the decision of BHEL in this regard is final and binding on the contractor.

14.2.11

In case of theft / damage / loss of materials due to **repeated and continued instances of negligence/failure** attributable to the contractor, the expenses incurred on account of repair/ replacement of such components including BHEL's overhead expenses as applicable (presently @ 30%) in excess of the amount realized from the underwriters, if any, shall be recovered from the contractor. Recovery will be limited to Normal Deductible Franchise (DF)/Excess as per applicable Insurance (TAC) tariff guidelines for every incidence of loss/damage.

14.2.12

In case any insurance claim does not become tenable due to **willful** negligence/ damage/loss attributable to the contractor, the total cost of repair/replacement including BHEL overhead expenses shall be recovered from the contractor.

14.3 INSURANCE BY THE CONTRACTOR AND INDEMNIFICATION OF BHEL

14.3.1

BHEL has taken a third party liability insurance, indicating in the proposal for such insurance that sub-contractors will be taking part in the erection work detailed in this tender. However, the bidder has to bear any expenses /consequences over and above the amount that may be reimbursed to BHEL by such coverage of third party liability insurance taken by BHEL.

Such additional liability will be to cover and indemnify BHEL and its customer of all liabilities which may come up and cause harm/damage to other contractors/customer/BHEL properties/ personnel or all or anybody rendering service to BHEL/ customer or is connected with BHEL/ customer's work in any manner whatsoever. The bidders specific attention is also invited to clause 2.10 of General Conditions of Contract.

14.3.2

Contractor shall obtain suitable statutory as well as non-statutory insurance policies for all the properties belonging to him and also for his personnel deployed at project for execution of the contract work.

SECTION-15

SPECIAL CONDITION OF CONTRACT

15.0 EARNEST MONEY DEPOSIT & SECURITY DEPOSIT

15.1 EARNEST MONEY DEPOSIT:

EMD for this tender is **Rs. 1,00,000/-** (Rupees One lakh only). Bidders who have already deposited One Time EMD of Rs. 2.00 lakh will be exempted from submission of any EMD now for this tender.

EMD is to be paid in **cash** (as permissible under Income Tax Act), Pay order or **Demand Draft** only in favour of Bharat Heavy Electricals Limited and payable at Nagpur. **No other form of EMD is acceptable.**

15.1.1 EMD by the Tenderer will be forfeited as per Tender Documents if

- i) After opening the tender, the tenderer revokes his tender within the validity period or increases his earlier quoted rates.
- ii) The tenderer does not commence the work within the period as per LOI / Contract. In case the LOI / contract is silent in this regard then within 15 days after award of contract.

15.1.2 EMD shall not carry any interest.

15.1.3 In the case of unsuccessful bidders, the Earnest Money will be refunded to them after acceptance of tender by successful bidder

15.1.4 SECURITY DEPOSIT

15.1.5 Security Deposit shall be furnished by the successful tenderer. The rate of Security Deposit will be as below:

SN	CONTRACT VALUE	SECURITY DEPOSIT AMOUNT
1	Up to Rs. 10 lakhs	10% of Contract Value
2	Above Rs. 10 lakhs upto Rs.50 lakhs	1 lakh + 7.5% of the Contract Value exceeding Rs. 10 lakhs.
3	Above Rs. 50 lakhs	Rs 4 lakhs + 5% of the Contract Value exceeding Rs. 50 lakhs.

The Security Deposit based on award value shall be furnished before start of the work by the contractor. Amount of Security Deposit shall be aligned with the actual executed value at appropriate stages of the contract period if there is variation from the award value.

15.1.6 Security Deposit may be furnished in any one of the following forms

- i) Cash (as permissible under the Income Tax Act)

- ii) Pay Order, Demand Draft in favour of BHEL.
- iii) Local cheques of scheduled banks, subject to realization.
- iv) Securities available from Post Offices such as National Savings Certificates, Kisan Vikas Patras etc. (Certificates should be held in the name of Contractor furnishing the security and duly pledged in favour of BHEL and discharged on the back).
- v) Bank Guarantee from Scheduled Banks / Public Financial Institutions as defined in the Companies Act subject to a maximum of 50% of the total security deposit value. The balance 50% has to be remitted either by cash or in the other form of security. The Bank Guarantee format should have the approval of BHEL.
- vi) Fixed Deposit Receipt issued by Scheduled Banks / Public Financial Institutions as defined in the Companies Act. The FDR should be in the name of the contractor, A/C BHEL, duly discharged on the back.
- vii) Security Deposit can also be recovered at the rate of 10% of admitted value from the running bills. However in such case, at least 50% of the security deposit should be remitted (by bank guarantee or demand draft) before start of the work and the balance 50% may be recovered from the running bills.
- viii) EMD of the successful tenderer shall be converted and adjusted against the Security Deposit excepting the cases with One Time EMD.
- ix) The security deposit shall not carry any interest.

NOTE: Acceptance of Security Deposit against Sl. No. (iv) and (vi) above will be subject to hypothecation or endorsement on the documents in favour of BHEL. However, BHEL will not be liable or responsible in any manner for the collection of interest or renewal of the documents or in any other matter connected therewith.

15.1.7 Security Deposit shall not be refunded to the contractor except in accordance with the terms of the contract.

APPENDIX-I

ANALYSIS OF TOTAL QUOTED RATE

SL. NO.	DESCRIPTION	% OF QUOTED RATE	REMARKS
01	SITE FACILITIES VIZ., ELECTRICITY, WATER OTHER INFRASTRUCTURE.		
02	SALARY AND WAGES + RETRENCHMENT BENEFITS		
03	CONSUMABLES		
04	T&P DEPRECIATION & MAINTENANCE		
05	ESTABLISHMENT & ADMINISTRATIVE EXPENSES		
06	OVERHEADS		
07	PROFIT		
	TOTAL	100%	

DATE
SIGNATURE OF THE BIDDER

APPENDIX-II

FORMAT FOR MONTH-WISE MANPOWER DEPLOYMENT PLAN (CATEGORY-WISE NUMBERS TO BE INDICATED FOR EACH MONTH)

Use additional sheet for remaining period

SN	CATEGORY	MONTHS										
		1	2	3	4	5	6	7	8	9	10	So on
01	RESIDENT ENGINEER											
02	APPLICATION ENGINEERS											
03	QUALITY ASSURANCE ENGINEER											
04	SAFETY ENGINEER											
05	MATERIALS MANAGEMENT SUPERVISORS											
06	SKILLED LABOURS(SUCH AS PAINTERS)											
07	STORE KEEPERS											
08	ELECTRICIANS											
09	SEMISKILLED/ UNSKILLED WORKERS											
	MONTH WISE TOTAL											

SIGNATURE OF BIDDER

DATE:

APPENDIX-III

CONCURRENT COMMITMENTS

SN	FULL POSTAL ADRESS OF CLIENT AND NAME OF OFFICER IN- CHARGE	DESCRIPTION OF THE WORK	VALUE OF THE CONTRACT	COMMENC- EMENT DATE	SCHEDU- LED COMPLE- TION	% COMPL- TD. AS ON DATE	ANTICIPA- TED COMPLN. DATE	REMARKS

SIGNATURE OF THE BIDDER
DATE:

APPENDIX-IV

DETAILS OF SIMILAR WORK DONE DURING THE LAST SEVEN YEARS

SL.NO.	FULL POSTAL ADDRESS OF CLIENT & NAME OF OFFICER IN CHARGE	DESCRIPTION OF WORK	VALUE OF CONTRACT	DATE OF AWARD OF WORK	DATE OF COMMENCEMENT OF WORK	TIME SCHEDULE (MONTHS)	DATE OF ACTUAL COMPLETION OF WORK	REMARKS

SIGNATURE OF TENDERER WITH SEAL

- PLEASE USE ADDITIONAL SHEET IF NEEDED IN THE SAME FORMAT.
- PLEASE ENCLOSE COPIES OF WORK ORDERS INCLUDING DETAILED BILL OF QUANTITIES, COMPLETION CERTIFICATES IN SUPPORT OF THIS STATEMENT

PAINTING SCHEDULE – ANNEX-V

CONTENTS

Cover Page	Page 60
Part – I: Painting schemes for Boiler components (Cust. No: 0378& 0379) (Including Valves & Piping)	61 -67(Sheet no.1-8)
Part – II: Painting schemes for APH, ESP, Fans and Gates/Dampers (Cust. No: : 0378& 0379)	68-88(Sheet no.1-21)
Part – III: General Notes for Painting	89
Part –I V: Details of Paint procurement and its application	90-91

Part – I:Painting schedule for Boiler Components(Including Valves)

Prepared by	M. Somu Manager Surface Protection/QA		Document No: Q: PL: C3 - PS / 0378
Reviewed by	R.Sundaraman DM / PE / FB		Revision No: 00 Dated: 02.12 2005
Approved by	R.Easwaran SDGM/QA &Plant Lab		

RECORD OF REVISIONS

Rev. No	Date	Details of revision	Remarks
00	09.05.2003	New	--

Q: PL: C3 – PS / 0378/00	Sheet No.:2 of 8
--------------------------	------------------

Part – I

Painting schemes for Boiler components (Including Valves)

Sl.No.	PGMA /Description	Surface Prepa- ration & Surface Profile	Primer coat		Intermediate coat		Finish coat			Total DFT μm (min)
			Paint	No. of coats	Paint	No. of coats	Paint	No. of coats	Shade	
1	Drum (Except Internals), Drum suspension 04 – 126,146,196	SSPC-SP3/ Power Tool Cleaning	Red Oxide Zinc Phosphate Primer (Alkyd Base) to IS 12744 DFT= 30μm per coat	2	--	--	Synthetic Enamel paint (Long Oil Alkyd) to IS 2932 DFT= 20μm per coat	3	Inter- national- Orange Shade No: 592 of IS 5	100
2	Drum internals 04 – 136	SSPC-SP1/ or SSPC – SP3 Solvent / Power Tool Cleaning	Rust Preventive Fluid to PR: CHEM: 09 – 04 DFT=25μm per coat	1	--	--	--	--	--	25

Q: PL: C3 – PS / 0378 Rev 00	Part - I	Page 3 of 8
------------------------------	----------	-------------

SL.No.	PGMA / Description	Surface Preparation & Surface Profile	Primer coat		Intermediate coat		Finish coat			Total DFT μm (min)
			Paint	No. of coats	Paint	No. of coats	Paint	No. of coats	Shade	
3	Buck stays 08 – 101, 104, 107 , 111, 380, 400 08 – 500, 700, 800, 900 Boiler supporting structures 21-601 35 – 110, 120,130,140,150,160, 190 35 – 210,220, 230 35 – 311,321,331,341 35 – 351,361,380,390 35 – 441,443,453,511,513 35-521,523,531,532,533,700, 35-821,823 Galleries & Stair-ways 36 –310,311,320,321,322,330,331,340 36 – 341,342,350 36 –351,360,361 36 – 380, 391,392,393 36 – 610,611,613,620,621,740 Interconnecting walkways 38 – 110,210,299,310,380,410 38 – 510,610,710 ID system structures 39 –140,150,300,301 39 – 302,303,304,305 48- 205,225,385,435,465,468,485,495,815,85 5,865,885	Blast cleaning to Sa 2 with surface profile 35-50 μm	Inorganic Ethyl Zinc Silicate Primer DFT=75 μm per coat.	1	Polyamide Epoxy Tie Coat DFT=100-150 μm (Polyamide cured Epoxy Tio2 pigmented intermediate DFT=75 Micron per coat .)	2*	Aliphatic Polyurethane Paint DFT=50 to 75 μm (Aliphatic acrylic Polyurethane to DFT 30Micron per coat.)	2@	Grey white RAL Shade No: 9002	225-325

- * DFT 100 to 150 shall be built up in 2 coats
- @ DFT 50 to 75 mic. shall be built up in 2 coats and will be applied at site.

Q: PL: C3 – PS / 0378 Rev 00	Part - I	Page 4 of 8
------------------------------	----------	-------------

Sl.No.	PGMA / Description	Surface Prepn &- Surface Profile	Primer coat		Intermediate coat		Finish coat			Total DFT µm (min)
			Paint	No. of coats	Paint	No. of coats	Paint	No. of coats	Shade	
4	Components>95° C Insulated/Uninsulated other than components in Column 5&7 Ring Headers, Down Comers, Hot air Headers outside the gas path etc. 18-002, 003, 010, 020 21-600, 24-200,215,220,225,235,275 30-103,105,211,215,219,220 31-010,102,104 48-132,205,207,209,212,222,223,225 48-232,382,385,403 48-432,433 48-460,462,464 48-465,466,468,480,482,485 48-486,489,490,492,495,810,812,813, 817,852,862,863,867,872,873,882,883	SSPC – SP3 / Power tool cleaning	Heat Resistant Aluminium Paint to IS 13183 Gr.II/DFT 20µm per coat	2	--	--	--	--	--	40
5	Loose tubes, SH, RH & Eco.coils, 07 – 215,216,217,218,223,225,226 07 – 231,232 11 – 236,238,274,278,487,634,685,686 12 –178,184,187,535,803,805,850 12 – 852,900,903,906,917,924 12 – 928,948,954,968 16 – 277,275 17-900,904,919,929 19-114,124,802,851	SSPC – SP2 or SSPC – SP3 Hand tool / Power tool cleaning	Red Oxide Zinc Phosphate Dip/brush coat primer DFT=30µm per coat	1	--	--	--	--	--	30

Q: PL: C3 – PS / 0378 Rev 00	Part - I	Page 5 of 8
------------------------------	----------	-------------

SL.No.	PGMA / Description	Surface Prepn &- Surface Profile	Primer coat		Intermediate coat		Finish coat			Total DFT µm (min)
			Paint	No. of coats	Paint	No. of coats	Paint	No. of coats	Shade	
6 contd..	Components < 95° C but Insulated 45-325,326 48-010,012,013,015,022,033,110 48-112,113,115,132,133,141,142,143,145 48-152,160,200,202,203,665,800,803 65-736 67-204,272,276,283,801,802,803	SSPC-SP3/ Power Tool Cleaning	Red oxide Zinc Phosphate Primer (Alkyd Base) to IS 12744 DFT= 30µm per coat	2	--	--	Syn. Enamel paint (Long Oil Alkyd) to IS 2932 DFT= 20µm per coat	3	Smoke Grey Shade No: 692 of IS5	100

Q: PL: C3 – PS / 0378 Rev 00	Part – I	Page 6 of 8
------------------------------	----------	-------------

Sl.No.	PGMA / Description	Surface Preparation & Surface Profile	Primer coat		Intermediate coat		Finish coat			Total DFT μm (min)
			Paint	No. of coats	Paint	No. of coats	Paint	No. of coats	Shade	
7 contd..	Components > 95° C coming in the gas path 05-137,139,147,158,159,227,229,231,251 06-400,631,633,634,637,641,643 06-644,647,651,653,655,670 07-102,104,106,107,402,403,404,405 07-420,431 10-135,178,182,183,185,191,195,218 10-235,278,283,291,295,315,687 11-688,691,694 12-914 15-174,274 16-275 19-701,702,753,763,783,903,905,906,907 32-010,110,120,310,410,510,520,710 35-995	SSPC-SP3/ Power Tool Cleaning	Red oxide Zinc Phosphate Primer (Alkyd Base) to IS 12744 DFT= 30 μm per coat	2	--	--	--	--	--	60
8	Hand rails and posts, ladders / rungs 35 – @ 822, @823,851 36 – @820,851,852,853 38 – @820,850 39 – @820,850 ** Floor Grills, Step threads 35-811,36-811 to 814,38-810,39 – 810	a) Hot dip Galvanizing to a coating weight of 610 gm per sq.m (minimum) and to a coating thickness of 87.0 microns (minimum). Refer Notes given below **								

Notes **: The Guard plates and Stringer channels shall be painted as per painting scheme prescribed in sl.no: 03.

Q: PL: C3 – PS / 0378 Rev 00	Part – I	Page 7 of 8
------------------------------	----------	-------------

Sl.No.	PGMA / Description	Surface Preparation & Surface Profile	Primer coat		Intermediate coat		Finish coat			Total DFT μm (min)
			Paint	No. of coats	Paint	No. of coats	Paint	No. of coats	Shade	
09	Cast carbon steel valves (Conventional) Cast alloy steel valves (Conventional) All API valves, QCNRV, SV & SRV Silencers	SSPC-SP3/ Power Tool Cleaning	Heat resistant Aluminum paint to IS 13183 Gr. I	2	--	--	--	--		40
	Forged valves	Phosphating	To a coating weight of 1500 mg per sq.ft.	--	--	--	--	--	--	--
	Soot Blower components	SSPC-SP6/ Comml. Blast Cleaning 35-50 μm	Red oxide Zinc Phosphate Primer (Alkyd Base) to IS 12744 DFT= 30 μm per coat	2	--	--	Syn. Enamel paint (Long Oil Alkyd) to IS 2932 DFT= 20 μm per coat	3	Verdigris Green Shade No. 280 of IS5	100
	HP / LP system	SSPC-SP6/ Comml. Blast Cleaning 35-50 μm	Heat Resistant Aluminium Paint to IS 13183 Gr.I	2	--	--	--	--	--	40
10	For CLH & VLH PGs 07,08,12,17,19,21,24,47,48 & 80	Abrasive Blast cleaning to Sa2 with surface profile 35-50 μm	Epoxy zinc rich primer to IS 14589 Gr.II %VS=35.0,min DFT=40.0 microns per coat	1	--	--	Aliphatic acrylic Poly-urethane paint to IS 13213 %VS=40.0 (min) DFT=30.0 microns per coat	1	Phirozi Blue Shade No. 176 of IS5	70
11	47-229	Power Tool Cleaning to St 3	Aluminium paint to IS 2339	2	--	--	--	--	Aluminium	40

Q: PL: C3 – PS / 0378 Rev 00	Part - I	Page 8 of 8
------------------------------	----------	-------------

Part – II :Painting schedule for APH,ESP,Fans and Gates/Dampers

Record of Revisions	Rev 00	Original Issues	Dated: 14/09/2005
	Rev 01	Revised based customer feed back.	Dated:03/12/2005
	Rev 02	Revised based on Contract review meeting with BESCL and BHEL at Trichy on 28/12/2005	Dated:29/12/2005

Q: PL: C3 – PS / 0378 Rev 00	Part - II	Page 1 of 21
-------------------------------------	------------------	---------------------

I-Air Pre Heater(APH)

Sl.No.	Surface Location	PGMA	Surface Preparation & Surface Profile	Primer coat		Finish Coat		Total DFT μm (min)
				Paint	DFT (μm) min.	Paint	DFT (μm) min.	
1	Module assembly	52010	Power Tool Cleaning to St3 (SSPC-SP3)	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats)	50	----	----	50
2	Heating Element with baskets	52010	Temporary Rust preventive Oil application(Wet) Note: Heating elements are assembled in module assy after dipping in the rust preventive fluid. --					

Q: PL: C3 – PS / 0378 Rev 00	Part - II	Page 2 of 21
------------------------------	-----------	--------------

Sl.No.	Surface Location		PGMA	Surface Preparation & Surface Profile	Primer coat		Finish coat		Total DFT μm (min)
					Paint	DFT (μm) min.	Paint	DFT (μm) min.	
3	Rotor Post assembly		52011	Power Tool Cleaning to St3 (SSPC-SP3)	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats).	50	---	--	50
4	Pin Rack assembly		52 012	---do--	Temperature Rust Preventive	20	---	---	20
5	Radial seals	T Bars	52 013	---do--	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats).	50	----	--	50
		Seals			Temperature Rust Preventive	20			20
6	Rotor Housing assembly	Insulated side	52 030	---do--	Heat Resistant Aluminium Paint Gr 2 to IS 13183 (Two Coats)	40	---	-----	40
		Flue gas swept surface			Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats)	50			50

Q: PL: C3 – PS / 0378 Rev 00	Part - II	Page 3 of 21
------------------------------	-----------	--------------

Sl.No.	Surface Location		PGMA	Surface Preparation & Surface Profile	Primer coat		Finish coat		Total DFT μm (min)
					Paint	DFT (μm) min.	Paint	DFT (μm) min.	
7	Hot and Cold End Connecting Plate assembly	Insulated side	52041 52042	Power Tool Cleaning to St3 (SSPC-SP3)	Heat Resistant Aluminium Paint Gr 2 to IS 13183 (Two Coats)	40			40
		Flue gas swept surface			Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats)	50			50
8	Axial seals		52 054	---do--	Temperature Rust Preventive Oil	20			20
9	Bypass seals		52 055	---do--	---do--	20			20
10	Rotor Drive assembly with bracket, Air Motor, Gear Box		52 100	---do--	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats)	40	Synthetic Enamel to IS 2932 Grey shade 692 of IS 5 (Three Coat)	60	100
11	Access door		52 210	---do--	Heat Resistant Aluminium Paint Gr 2 to IS 13183 (Two Coats)	40			40

Q: PL: C3 – PS / 0378 Rev 00	Part - II	Page 4 of 21
------------------------------	-----------	--------------

Sl.No.	Surface Location	PGMA	Surface Preparation & Surface Profile	Primer coat		Finish coat		Total DFT μm (min)
				Paint	DFT (μm) min.	Paint	DFT (μm) min.	
12	Air seal piping	52 211	Power Tool Cleaning to St3 (SSPC-SP3)	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats)	40	Synthetic Enamel to IS 2932 Grey shade 692 of IS 5 (Three Coat)	60	100
13	Observation port with light	52 212	No painting, as the same is made of Glass					
14	Other than glass part	52 213	---do--	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats)	50	----	---	50
15	Rotor Stoppage alarm	52 217	Made of Aluminium (No painting is required)					
	Other than Aluminium		Power Tool Cleaning to St3 (SSPC-SP3)	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats)	50	----	----	50
16	Air reciever	52 220	---do--	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats)	40	Synthetic Enamel to IS 2932 Grey shade 692 of IS 5 (Three Coat)	-----	40
17	Lifting beams, special tools, tools & tackles	52 220 52 000	---do--	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats)	40	---do--	-----	40
18	Guide Bearing Assembly	52 261	---do--	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats)	40	---do--	60	100

Q: PL: C3 – PS / 0378 Rev 00	Part - II	Page 5 of 21
------------------------------	-----------	--------------

Sl.No.	Surface Location	PGMA	Surface Preparation & Surface Profile	Primer coat		Finish coat		Total DFT μm (min)
				Paint	DFT (μm) min.	Paint	DFT (μm) min.	
19	Supporting Bearing Assembly	52 262	Power Tool Cleaning to St3 (SSPC-SP3)	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats)	40	Synthetic Enamel to IS 2932 Grey shade 692 of IS 5 (Three Coat)	60	100
20	Oil piping Hot End	52 271	---do--	---do--	40	---do--	60	100
21	Oil piping Cold End	52 272	---do--	---do--	40	---do--	60	100
22	Oil Circulating Units	52 274	---do--	---do--	40	---do--	60	100
23	Washing manifold & deluge assy. and items	52 301 52 302	---do--	---do--	40	---do--	60	100
24	Cleaning device assemblies Tube with nozzle	52 326	---do--	---do--	40	---do--	60	100
25	Cleaning device drive	52 329	---do--	---do--	40	---do--	60	100
26	TC Pipe Assy.(Stainless Steel)	52 360	No painting					

Sl.No.	Surface Location	PGMA	Surface Prepa- ration & Surface Profile	Primer coat		Finish coat		Total DFT μm (min)
				Paint	DFT (μm) min.	Paint	DFT (μm) min.	
27	TC Pipe Assy.(None Stainless Steel part)	52 360 52042	Power Tool Cleaning to St3 (SSPC- SP3)	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats)	40	Synthetic Enamel to IS 2932 Grey shade 692 of IS 5 (Three Coat	60	100
28	Commissioning Spares	52 988	As per respective items as above.					

II-Fans

Sl.No.	Surface Location	PGMA	Surface Preparation & Surface Profile	Primer coat		Finish Coat		Total DFT μm (min)
				Paint	DFT (μm) min.	Paint	DFT (μm) min.	
1	Foundation Material	55 010 55 030 55 020	Power Tool Cleaning to St3 (SSPC-SP3)	Temporary Rust Preventive	20	----	----	20
2	<u>FD FAN</u> Static Parts: Insulated	55 214	---do--	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats).	40	Synthetic Enamel to IS 2932 Grey shade 692 of IS 5 (Three Coat)	60	100
	Static Parts UnInsulated & Rotating parts							
03	<u>PA FAN</u> Static Parts: Insulated	55 334	---do--	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats).	40	---do--	60	100
	Static Parts UnInsulated & Rotating parts							
04	Coupling	55 810 55 830	---do--	---do--	40	---do--	60	100

Q: PL: C3 – PS / 0378 Rev 00	Part - II	Page 8 of 21
------------------------------	-----------	--------------

Sl.No.	Surface Location		PGMA	Surface Preparation & Surface Profile	Primer coat		Finish Coat		Total DFT μm (min)
					Paint	DFT (μm) min.	Paint	DFT (μm) min.	
05	Tools		56 000	Power Tool Cleaning to St3 (SSPC-SP3)	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats).	40	Synthetic Enamel to IS 2932 Grey shade 692 of IS 5 (Three Coat)	60	100
06	ID FAN (Comprising of static parts and rotary parts)	Insulated and Uinsulated	55 227	---do--	Heat Resistant Aluminium Paint Gr 2 to IS 13183 (Two Coats)	40	----	----	40
		Flue gas Swept Surfaces.			Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats).	50	----	----	50
07	Lub Oil System		55 910 55 930 55 920	---do--	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats).	40	Synthetic Enamel to IS 2932 Grey shade 692 of IS 5 (Three Coat)	60	100
08	Silencer for FD & PA Fan		55 911 55 931	---do--	---do--	40	---do--	60	100
09	Seal Air Fan		55 971	---do--	---do--	40	---do--	60	100
10	Seal Air Fan Motor base Frame		55 970	---do--	---do--	40	---do--	60	100

Q: PL: C3 – PS / 0378 Rev 00	Part - II	Page 9 of 21
------------------------------	-----------	--------------

11	Base Frame frames for actuators of FD and PA fans	56 913	Power Tool Cleaning to St3 (SSPC-SP3)	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats).	40	Synthetic Enamel to IS 2932 Grey shade 692 of IS 5 (Three Coat)	60	100
12	Commissioning Spares	56 988	As per respective items as above.					

III-Electrostatic Precipitator(ESP)

Sl.No.	Surface Location	PGMA	Surface Preparation & Surface Profile	Primer coat		Finish Coat		Total DFT μm (min)
				Paint	DFT (μm) min.	Paint	DFT (μm) min.	
01	Insulator Housing assy.	78-X06	Power Tool Cleaning to St3 (SSPC-SP3)	Heat Resistant Aluminium Paint Gr 2 to IS 13183(Two coat)	40	----	----	40
02	Gas distribution assy.	78-X08	---do--	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats).	50	----	----	50
03	GD rapping mechanism	78-X09	---do--	---do--	50	----	----	50
04	GD drive arrangements	78-X10	---do--	---do--	40	Synthetic Enamel to IS 2932 Grey shade 692 of IS 5 (Three Coat)		40
07	Emitting Electrode rapping	78-X16	---do--	---do--	50	----	----	50
08	Drive arrangement for collecting electrodes	78-X17	---do--	---do--	40	Synthetic Enamel to IS 2932 Grey shade 692 of IS 5 (Three Coat)	60	100

Q: PL: C3 – PS / 0378 Rev 00	Part - II	Page 10 of 21
------------------------------	-----------	---------------

Sl.No.	Surface Location	PGMA	Surface Preparation & Surface Profile	Primer coat		Finish Coat		Total DFT μm (min)
				Paint	DFT (μm) min.	Paint	DFT (μm) min.	
09	Suspension arrangement for collecting electrode	78-X19	Power Tool Cleaning to St3 (SSPC-SP3)	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats).	50	----	----	50
10	Frame of emitting system-Top	78-X21	---do--	---do--	50	----	----	50
11	Frame of emitting system-Bottom	78-X22	---do--	---do--	50	----	----	50
12	Inspection doors	78-X23	---do--	---do--	40	Synthetic Enamel to IS 2932 Grey shade 692 of IS 5 (Three Coat)	60	100
13	Shock bars	78-X24	---do--	---do--	50	----	----	50
14	CE rapping mechanism	78-X25	---do--	---do--	50	----	----	50
15	Drive arrangements for CE rapping	78-X26	---do--	---do--	40	Synthetic Enamel to IS 2932 Grey shade 692 of IS 5 (Three Coat)	60	100
16	Frame of emitting system-Middle	78-X32	---do--	---do--	50	----	----	50

Q: PL: C3 – PS / 0378 Rev 00	Part - II	Page 11 of 21
------------------------------	-----------	---------------

Sl.No.	Surface Location		PGMA	Surface Preparation & Surface Profile	Primer coat		Finish Coat		Total DFT μm (min)
					Paint	DFT (μm) min.	Paint	DFT (μm) min.	
17	Outer roof.		78-X42	Power Tool Cleaning to St3 (SSPC-SP3)	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats)	40	Synthetic Enamel to IS 2932 Grey shade 692 of IS 5 (Three Coat)	60	100
18	Hopper Ridges		78-X43	---do--	---do--	50	-----	-----	50
19	Hopper Upper part	Insulated side	78-X44	---do--	Heat Resistant Aluminium Paint Gr 2 to IS 13183(Two coat)	40	-----	-----	40
		Flue gas Swept surfaces		---do--	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats)	50	-----	-----	50

Q: PL: C3 – PS / 0378 Rev 00	Part - II	Page 12 of 21
------------------------------	-----------	---------------

Sl.No.	Surface Location		PGMA	Surface Preparation & Surface Profile	Primer coat		Finish Coat		Total DFT μm (min)
					Paint	DFT (μm) min.	Paint	DFT (μm) min.	
20	Hopper lower& middle part	Insulated side	78-X45	Power Tool Cleaning to St3 (SSPC-SP3)	Heat Resistant Aluminium Paint Gr 2 to IS 13183(Two coat)	40	-----	-----	40
		Flue gas Swept surfaces		---do--	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats)	50	-----	-----	50
21	Insulator Support Panel	Insulated side	78-X46	Power Tool Cleaning to St3 (SSPC-SP3)	Heat Resistant Aluminium Paint Gr 2 to IS 13183(Two coat)	40	-----	-----	40
		Flue gas Swept surfaces		---do--	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats)	50	-----	-----	50

Sl.No.	Surface Location		PGMA	Surface Preparation & Surface Profile	Primer coat		Finish Coat		Total DFT μm (min)
					Paint	DFT (μm) min.	Paint	DFT (μm) min.	
22	Roof Panel assy.	Insulated side	78-X47	Power Tool Cleaning to St3 (SSPC-SP3)	Heat Resistant Aluminium Paint Gr 2 to IS 13183(Two coat)	40	----	----	40
		Flue gas Swept surfaces		---do--	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats)	50	----	----	50
23	Casing Structure		78-X48	---do--	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats).	50	----	----	50

Q: PL: C3 – PS / 0378 Rev 00	Part - II	Page 14 of 21
------------------------------	-----------	---------------

Sl.No.	Surface Location		PGMA	Surface Preparation & Surface Profile	Primer coat		Finish Coat		Total DFT μm (min)
					Paint	DFT (μm) min.	Paint	DFT (μm) min.	
22	Casing(Shell, side panels, cables & GD housing)	Insulated side	78-X48	Power Tool Cleaning to St3 (SSPC-SP3)	Heat Resistant Aluminium Paint Gr 2 to IS 13183(Two coat)	40	-----	-----	40
		Flue gas Swept surfaces		---do--	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats)	50	-----	-----	50
23	ESP Funnels	Insulated side	78-X50	Power Tool Cleaning to St3 (SSPC-SP3)	Heat Resistant Aluminium Paint Gr 2 to IS 13183(Two coat)	40	-----	-----	40
		Flue gas Swept surfaces		---do--	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats)	50	-----	-----	50

Q: PL: C3 – PS / 0378 Rev 00	Part - II	Page 15 of 21
------------------------------	-----------	---------------

Sl.No.	Surface Location	PGMA	Surface Preparation & Surface Profile	Primer coat		Finish Coat		Total DFT μm (min)
				Paint	DFT (μm) min.	Paint	DFT (μm) min.	
26	ESP Pent house	78-X55	Power Tool Cleaning to St3 (SSPC-SP3)	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats)	40	Synthetic Enamel to IS 2932 Grey shade 692 of IS 5 (Three Coat)	60	100
27	Splitters & Guide Vanes	78-X57	---do--	---do--	50	-----	-----	50
28	ESP test equipment	78-X61	---do--	---do--	40	Synthetic Enamel to IS 2932 Grey shade 692 of IS 5 (Three Coat)	60	100
29	Water Washing system	78-X66	---do--	---do--	40	---do--	60	100
30	ESP Gallery & stair case(Refer sl no.39 for stringers& Guard plates)	89-610	---do--	---do--	40	---do--	60	100
31	Tools & Tackles	7X-996	---do--	---do--	40	---do--	60	100

Q: PL: C3 – PS / 0378 Rev 00	Part - II	Page 16of 21
------------------------------	-----------	--------------

Sl.No.	Surface Location	PGMA	Surface Prepa- ration & Surface Profile	Primer coat		Finish Coat		Total DFT μm (min)
				Paint	DFT (μm) min.	Paint	DFT (μm) min.	
32	Commissioning Spares	7X-996	As per respective items above					
33	Foundation Material for ESP & Shims & 7X-X81 column	7X-X80	All threaded and other surfaces of foundation bolt and its materials shall be coated with temporary rust preventive fluid and during execution of civil works; the dried film of coating will be removed using organic solvents.					
34	Handrails, Posts Step treads, Floor grills,	89-610 7X-165	Hot dip Galvanizing to 610 gm per sq.m(Minimum) and coating thickness of 87 μm.					
35	Collecting electrodes	7X-120	Rust Preventive application					
	Lifting beam		Power Tool Cleaning to St3 (SSPC- SP3)	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats)	40	Synthetic Enamel to IS 2932 Grey shade 692 of IS 5 (Three Coat)	60	100
36	Emitting electrodes	7X-115	Rust Preventive application on Hook(Electrode wire is Stainless Steel)					

Q: PL: C3 – PS / 0378 Rev 00	Part - II	Page 17 of 21
------------------------------	-----------	---------------

Sl.No.	Surface Location	PGMA	Surface Preparation & Surface Profile	Primer coat		Finish Coat		Total DFT μm (min)
				Paint	DFT (μm) min.	Paint	DFT (μm) min.	
37	Supporting structure for ESP	78-181	} Blast Cleaning to Sa 2 ½(Near white metal with Surface profile 35- 50 microns	Primer: Inorganic Ethyl Zinc Silicate primer(Solid by Volume min 60%) DFT=75 μm minimum as per IS 14946				
38	Hopper approach platform(For items other than mentioned in s. no. 34)	78-165		Intermediate coat: Epoxy based TiO ₂ pigmented(Solid by Volume min 40%) DFT=100 μm minimum				
39	Stringer for stairs case and guard plates	89-610		Finish Coat: Aliphatic Polyurethane paint (solid Volume min 40%) DFT=50 μm . Minimum at site as per IS 13213 <u>Note:</u> a) Finish paint shall be applied at site either by spray or brush(Shade GREY-RAL 9002) b) The total paint thickness-(Primer + Intermediate + Finish with polyurethane) shall be DFT=225-microns minimum c) Thickness of individual coat shall be ensured separately and the same shall meet the specified minimum thickness of each coat as given above.				

Q: PL: C3 – PS / 0378 Rev 00	Part - II	Page18 of 21
------------------------------	-----------	--------------

IV-Gates & Damper

Sl.No.	Surface Location	PGMA	Surface Preparation & Surface Profile	Primer coat		Finish Coat		Total DFT μm (min)
				Paint	DFT (μm) min.	Paint	DFT (μm) min.	
01	Gates & Damper more than 95 ° C	48-XXX	Power Tool Cleaning to St3 (SSPC-SP3)	Heat Resistant Aluminium Paint Gr 2 to IS 13183(Two coat)	40	-----	-----	40
02	Gates & Damper less than 95 ° C	48-XXX	---do--	Red Oxide Zinc Phosphate Primer to IS 12744 (Two Coats	40	Synthetic Enamel to IS 2932 Grey shade 692 of IS 5 (Three Coat	60	100

Q: PL: C3 – PS / 0378 Rev 00	Part - II	Page 19 of 21
------------------------------	-----------	---------------

General Notes:

- 1) No painting is required for Galvanized items, Non-ferrous items & stainless steel items, except as indicated above.
- 2) Machined items are to be applied with one coat of temporary rust preventive oil.
- 3) PGMA's under Sub-Vendor items viz SCAPH, HYD.Lifting cylinder, Chain pulley block, Air motor, Pups, Oil coolers, Pent house ventilation fan & its coupling, seal air fan coupling, bearing housing, Universal Joint, ESP support bearing, D Shackle etc. are not indicated. Please refer respective engineering documents/approved drawing/spec.
- 4) In components, wherever plates/sheets of thickness less than or equal to 5 mm and rods are used, power tool or hand tool cleaning to SSPC-SP3/SP2 shall be followed.
- 5) Ground shade/colour of finish paints and identification tag/band for equipments, Fans, piping, pipe services, supporting structures and other components shall be followed as per NTPC doc. at site.

Q: PL: C3 – PS / 0378 Rev 00	Part - II	Page 20 of 21
------------------------------	-----------	---------------

PAINTING OF DAMAGED AREAS

(Areas where paint has deteriorated badly by erosion and areas where the paint film has lost its adhesion and where the steel has rusted appreciably, should be repainted as per following)

01	Paint damaged components falling under Sl. No. 37 to 39 of ESP	Surface Preparation: Power tool cleaning to bare metal	Primer: One coat of Epoxy Zinc rich primer to IS 14589 GrII to DFT of 75 microns Intermediate and Finish: As given in respective scheme
02	Paint damaged components falling under Sl. Nos. of APH & Fan and ESP	Surface Preparation: Power tool cleaning to bare metal	Primer and Finish: As given in respective scheme

Q: PL: C3 – PS / 0378 Rev 00	Part - II	Page 21 of 21
-------------------------------------	------------------	----------------------

Part – III

General Notes for Painting

NOTES:

1. Rust Preventive Coating should be given on HSFG Bolt threads.
2. Machined surfaces are to be applied with a coating of Temporary Rust Preventive oil.
3. All threaded and other surfaces of foundation bolts and its materials, insulation pins, Anchor channels, Sleeves shall be coated with Temporary Rust Preventive Fluid and during execution of civil works; the dried film of coating shall be removed using organic solvents.
4. All shade numbers are as per IS 5. Unless otherwise specified Color / Shade of the finish coat shall be Smoke gray Shade No. 692 of IS 5.
5. PGMA's under Sub-Vendor items are not indicated. Please refer respective Engg. Document.
6. These Painting Schemes are valid for only Customer No: 0378&0379
07. No painting is required for Stainless Steel components.
08. Wherever inside surfaces of Expansion Joints, Ducts & Dampers under PGMA 48 – XXX, need protection till erection, two coats of Red-oxide zinc phosphate primer paint to IS 12744 to a DFT of 60 microns shall be applied.
09. The Temporary Rust Preventive coating that already been applied on any components, tubes, pipes etc., shall be removed by suitable solvents / heating to 350 -400 °C for an hour before primer paint application -but, in this case, it should be ensured that the minimum surface cleanliness required for primer paint application shall be SSPC - SP2 (equivalent - Hand Tool cleaning).
10. In components, wherever plates / sheets of thickness less than or equal to 5 mm and rods are used, power tool / hand tool cleaning to SSPC - SP3 / SP2 shall be followed and the painting shall be done as described in Scheme No: 06
11. For all commissioning components- The erection materials (XX-993) are coated with onecoat of Red oxide zinc phosphate primer to IS 12744 after power tool cleaning
12. Ground Shade / Colour of Finish paints & identification Tag / Band for equipments , piping, pipe service, boiler supporting structures and other boiler components shall be followed as given in NTPC doc. QS-01-DIV-W-4(Rev.1) which is available with BHEL.
13. Touch-up painting of damaged areas shall be carried out as per clause 4.01.04, part B. Sub section V of the NTPC Technical Specification.

Q: PL: C3 – PS / 0378 Rev 00	Part - III	Page1 of 1
-------------------------------------	-------------------	-------------------

Part - IV

Detail of Paints for procurement and paint application

Sl.No.	Generic nature of paint	Theoretical Covering Capacity Sq.m per Litre.	No. of pack	Volume solids, % (min)**	DFT in microns (min) per coat	Shade	Shade No. to IS5	Mode of appln.	Over coating interval, Hrs.
1	Inorganic ethyl zinc silicate to IS14946	8	2	60	75	Grey	--	Spray Only	16
2	Polyamide cured Epoxy based Tio2 pigmented intermediate coat	6	2	50	75	Grey	--	# Spray	24
3	Aliphatic acrylic Polyurethane based colour pigmented finish paint to IS 13213	10	2	40	30	Grey	RAL 9002	Spray	24
4	Aliphatic acrylic Polyurethane based colour pigmented finish paint to IS 13213	10	2	40	30	Phirozi Blue.	176	Spray	24
5	Heat resistant aluminium paint to IS 13183 Grade I	10	1	--	20	--	--	Brush /Spray	24
6	Red oxide zinc phosphate primer paint to IS 12744	10	1	--	30	----	--	Brush /Spray	12
7	Red oxideZinc Phosphate Dip coat primer paint to PR: CHEM: 09-03	10	1	----	30	--	---	Dip	12
8	Long oil alkyd synthetic enamel finish paint to IS 2932	10	1	35	20	Reqd. shade	Corrpdg. Shade no.	Brush /Spray	12
9	Temporary Rust preventive fluid to PR: CHE: 09 - 04	10	1	--	25	--	--	--	12
10	Epoxy zinc rich primer paint to IS 14589Grade II.	8	2	35	40	Grey	--	spray	24
11	Aluminium Paint to IS 2339	10	2	--	20	---	--	Brush	18

1.0 ## Brush application may be permitted if permitted by Paint suppliers.

2.0 The covering capacity of paints specified is only for procurement purposes

3.0 The paints and Rust Preventive fluid shall be procured from BHEL's approved suppliers.

4.0 ** Values are indicative. The final values shall be as per paint manufacturers, finally selected for supply of paint.

Q: PL: C3 – PS / 0378 Rev 00	Part -I V	Page 1 of 1
-------------------------------------	------------------	--------------------

DETAILS OF PAINTING REQUIREMENT AT 2X250 MW, BESCL, BHILAI

	BOILER AREA	UNIT	QTY/UNIT	QTY. FOR U #1&2
1	BOILER --STRUCTURE	MT	4100	8200
2	ESP-- STRUCTURE	MT	842	1684
3	MOTORS ID+FD+PA+SEAL AIR, LUB OIL SYSTEM, COUPLING, HOOD TO SILENCER (PA & FD ONLY) ETC	SET	10	20
4	MILLS WITH MOTORS/ LUB OIL SYSTEMS, FEEDERS ETC	SET	7	14
5	COAL PIPING + BENDS + FEEDER TO ZERO MTR COAL REJECT	SQ MTR	950	1900
6	HANGERS+ SUPPORTS FOR ABOVE	MT	50	100
	TG AREA			
7	CONDENSER	SQ MTR	620	1240
8	TURBINE/ GENERATOR			
9	OTHER EQUIPS.LIKE MISC. PUMPS/ MOTORS/ COOLERS/ PHE/ RACKS (OIL & WATER)/ OIL TANKS			
10	OIL PIPING (GEN+LUB+CONTROL)	SQ MTR	500	1000
	COMMON			
1	LP PIPING STRUCTURE /HANGERS/ SUPPORTS/ PUMPS/ TANKS	MT	30	
2	PC PIPING STRUCTURE /HANGERS/ SUPPORTS/ TANKS	MT	300	
3	LP PIPING	SQ MTR	18000	
4	CW PIPING	SQ MTR	nil	

