

=====

TENDER SPECIFICATION

TENDER NO. BHEL/ NR/SCT/ KOSTI /ELEC/ 836

FOR

“ERECTION, TESTING, COMMISSIONING TRIAL OPERATION AND HANDING OVER OF BALANCE WORKS OF ELECTRICAL PACKAGE 4 X 125 MW AT KOSTI TPS, SUDAN.”

PART I – TECHNICAL BID



Bharat Heavy Electricals Limited
(A Govt. Of India Undertaking)
Power Sector – Northern Region,
Plot No. 25 , Sector - 16A ,
Distt. Gautam Budh Nagar, NOIDA – 201 301(INDIA)



ISO 9001, ISO 14001,
OHSAS 18001 & SA 8000
certified company
SubContract and Purchase
Deptt.

Bharat Heavy Electricals Limited
(A Govt. Of India Undertaking)
Power Sector – Northern Region,
Plot No. 25 , Sector - 16A ,
Distt. Gautam Budh Nagar, NOIDA – 201 301(INDIA)
Phone: 0091-0120- 2416286 / 2515440
Fax 091-0120-2416528
Email: vkg@bhel.com / msd@bhel.com

TENDER NO. [BHEL/ NR/SCT/ KOSTI /ELEC/ 836](#)

IMPORTANT NOTE

PURCHASER OF THIS TENDER DOCUMENT IS ADVISED TO CHECK AND ENSURE COMPLETION OF ALL PAGES OF TENDER DOCUMENT AND REPORT ANY DISCREPANCY TIMELY FOR CORRECTIVE ACTION, IF ANY, TO THE ISSUING AUTHORITY BEFORE THE BIDS ARE SUBMITTED. ORIGINAL COPY OF TENDER DOCUMENT COMPLETE IN ALL RESPECTS MUST BE SUBMITTED BACK AS PART OF THE BID WITHOUT WHICH THE SAME IS LIABLE TO BE REJECTED BY BHEL.

THIS TENDER SPECIFICATION ISSUED TO:

M/S-----

Rev 00
6th July
2010

NOTICE INVITING TENDER

(Document No PS:MSX:NIT)

Bharat Heavy Electricals Limited



NOTICE INVITING TENDER (NIT)
NOTE: BIDDER MAY DOWNLOAD FROM WEB SITES
OR
PURCHASE TENDERS FROM THIS OFFICE ALSO

To

Dear Sir/Madam,

Sub: NOTICE INVITING TENDER

Sealed offers in two part bid system are invited from reputed & experienced bidders for the subject job by the undersigned on the behalf of BHARAT HEAVY ELECTRICALS LIMITED as per the tender document. Following points relevant to the tender may please be noted and complied with.

1.0 Salient Features of NIT

SL NO	ISSUE	DESCRIPTION	
i	TENDER NUMBER	TENDER NO. BHEL/ NR/SCT/ KOSTI /ELEC/ 836	
ii	Broad Scope of job	“ERECTION, TESTING, COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF PIPING WORKS AT 4 X 125 MW KOSTI TPS, SUDAN.”	
iii	DETAILS OF TENDER DOCUMENT		
a	Volume-IA	<i>Technical Conditions of Contract (TCC) consisting of Scope of work, Technical Specification, Drawings, Procedures, Bill of Quantities, Terms of payment, etc</i>	<i>Applicable</i>
b	Volume-IB	<i>Special Conditions of Contract (SCC)</i>	<i>Applicable</i>
c	Volume-IC	<i>General Conditions of Contract (GCC)</i>	<i>Applicable</i>
d	Volume-ID	<i>Forms and Procedures</i>	
e	Volume-II	<i>Price Schedule (Absolute value).</i>	<i>Applicable</i>
iv	Issue of Tender Documents	1. <u>Sale from BHEL PS Regional office at :</u> Start 17.10.2011 , Time : 11.00 hrs (IST) Closes: 27.10.2011 , Time : 15.00 hrs (IST) 2. From BHEL website (www.bhel.com) Tender documents can however be downloaded from website till due date of submission 	<i>Applicable</i>
v	DUE DATE & TIME OF OFFER SUBMISSION	Date : 27.10.2011, Time : 15.00 HRS(INDIAN STD TIME) Place : NOIDA(UP)--INDIA	<i>Applicable</i>
vi	OPENING OF TENDER	1/2 hour after the latest due date and time of Offer submission Notes: (1) In case the due date of opening of tender becomes a non-working day, tenders shall be opened on next working day at the same time. (2) Bidder may depute representative to witness the opening of tender	<i>Applicable</i>
vii	EMD AMOUNT	Rs. 2.0 lakhs (Rupees Two lakhs only) / Euros 3000/ SDG (12500)/ USD 4000	Applicable
viii	COST OF TENDER	Rs 2000/-.	Applicable/Not Applicable
ix	LAST DATE FOR SEEKING	Date: 20.10.2011. Along with soft version also, addressing to	Applicable

	CLARIFICATION	<i>undersigned & to others as per contact address given below</i>	
x	SCHEDULE OF Pre Bid Discussion (PBD)	Date : ___/___/___, Time : Place :	<i>Applicable / Not applicable.</i>
xi	INTEGRITY PACT & DETAILS OF INDEPENDENT EXTERNAL MONITOR (IEM)	Shri J M Lyngdoh, IAS (Retd) Plot No. 144-145, Pragati Resort, Proddator Village & P.O., Shankarpally Road, Rangareddy Distt. (AP)- 500 033	<i>Applicable/Not Applicable</i>
xii	Latest updates	Latest updates on the important dates, Amendments, Correspondences, Corrigenda, Clarifications, Changes, Errata, Modifications, Revisions, etc to Tender Specifications will be hosted in BHEL webpage (www.bhel.com -->Tender Notifications →View Corrigendums) and not in the newspapers . Bidders to keep themselves updated with all such information	

- 2.0 The offer shall be submitted as per the instructions of tender document and as detailed in this NIT. Bidders to note specifically that all pages of tender document, including these NIT pages of this particular tender together with subsequent correspondences shall be submitted by them, duly signed & stamped on each page, as part of offer. **Rates/Price including discounts/rebates, if any, mentioned anywhere/in any form in the techno-commercial offer other than the Price Bid, shall not be entertained.**
- 3.0 Unless specifically stated otherwise, bidder shall remit cost of tender and courier charges if applicable, in the form of Demand Draft drawn in favour of Bharat Heavy Electricals Ltd, payable at Power Sector Regional HQ at Noida issuing the Tender, along with techno-commercial offer. Bidder may also choose to deposit the Tender document cost by cash at the Cash Office as stated above against sl no iv of 1, on any working day; and in such case copy of Cash receipt is to be enclosed with the Techno Commercial offer. Sale of tender Documents shall not take place on National Holidays, holidays declared by Central or State Governments and BHEL PS HQ at Noida, Sundays and second/ last Saturdays
- 4.0 Unless specifically stated otherwise, bidder shall deposit EMD through Demand Draft/Pay Order in favour of Bharat Heavy Electricals Ltd, payable at Noida. For other details and for 'One Time EMD' please refer General Conditions of Contract.
- 5.0 **Procedure for Submission of Tenders:** The Tenderers must submit their Tenders to Officer inviting Tender, as detailed below:
- PART-I consisting of 'PART-I A (Techno Commercial Bid)' & 'PART-I B (EMD/COST of TENDER)' in two separate sealed and superscribed envelopes (ENVELOPE-I & ENVELOPE-II)
 - PART-II (Price Bid) – in sealed and superscribed envelope (ENVELOPE-III)
- 6.0 The contents for ENVELOPES and the superscription for each sealed cover/Envelope are as given below. **(All pages to be signed and stamped)**

Sl no	Description	Remarks
	Part-I A	
	ENVELOPE – I superscribed as : PART-I (TECHNO COMMERCIAL BID) TENDER NO : NAME OF WORK : PROJECT: DUE DATE OF SUBMISSION: ----- CONTAINING THE FOLLOWING:-	

i.	Covering letter/Offer forwarding letter of Tenderer.	
ii.	Duly filled-in 'No Deviation Certificate' as per prescribed format to be placed after document under sl no (i) above. Note: a. In case of any deviation, the same should be submitted separately for technical & commercial parts, indicating respective clauses of tender against which deviation is taken by bidder. The list of such deviation shall be placed after document under sl no (i) above. It shall be specifically noted that deviation recorded elsewhere shall not be entertained. b. BHEL reserves the right to accept/reject the deviations without assigning any reasons, and BHEL decision is final and binding. i). In case of acceptance of the deviations, appropriate loading shall be done by BHEL ii). In case of unacceptable deviations, BHEL reserves the right to reject the tender	
iii.	Supporting documents/ annexure/ schedules/ drawing etc as required in line with Pre-Qualification criteria. It shall be specifically noted that all documents as per above shall be indexed properly and credential certificates issued by clients shall distinctly bear the name of organization, contact ph no, FAX no, etc.	
iv.	All Amendments/Correspondences/Corrigenda/Clarifications/Changes/ Errata etc pertinent to this NIT.	
v.	Integrity Pact Agreement (Duly signed by the authorized signatory)	If applicable
vi.	Duly filled-in annexures, formats etc as required under this Tender Specification/NIT	
vii.	Notice inviting Tender (NIT)	
viii.	Volume – I A : <u>Technical</u> Conditions of Contract (TCC) consisting of Scope of work, Technical Specification, Drawings, Procedures, Bill of Quantities, Terms of payment, etc	
ix.	Volume – I B : Special Conditions of Contract (SCC)	
x.	Volume – I C : General Conditions of Contract (GCC)	
xi.	Volume – I D : Forms & Procedures	
xii.	Volume – II (UNPRICED – without disclosing rates/price, but mentioning only 'QUOTED' or 'UNQUOTED' against each item	
xiii.	Any other details preferred by bidder with proper indexing.	

	PART-I B	
	ENVELOPE – II superscribed as: PART-I (EMD/COST of TENDER) TENDER NO : NAME OF WORK : PROJECT: DUE DATE OF SUBMISSION: CONTAINING THE FOLLOWING:-	Applicable
i.	1. Earnest Money Deposit (EMD) in the form as indicated in this Tender OR Documentary evidence for 'One Time EMD' with the Power Sector Region of BHEL floating the Tender 2. Cost of Tender (Demand Draft or copy of Cash Receipt as the case may be)	Applicable

PART-II	
	PRICE BID consisting of the following shall be enclosed
	ENVELOPE-III superscribed as: PART-II (PRICE BID) TENDER NO : NAME OF WORK : PROJECT: DUE DATE OF SUBMISSION: CONTAINING THE FOLLOWING
i	Covering letter/Offer forwarding letter of Tenderer enclosed in Part-I
ii	Volume II – PRICE BID (Duly Filled in Schedule of Rates – rate/price to be entered in words as well as figures)

OUTER COVER	
	ENVELOPE-IV (MAIN ENVELOPE / OUTER ENVELOPE) superscribed as: TECHNO-COMMERCIAL BID, PRICE BID & EMD TENDER NO: NAME OF WORK: PROJECT: DUE DATE OF SUBMISSION: CONTAINING THE FOLLOWING:
i	<ul style="list-style-type: none"> ○ Envelopes I ○ Envelopes II ○ Envelopes III

SPECIAL NOTE: All documents/ annexures submitted with the offer shall be properly annexed and placed in respective places of the offer as per enclosure list mentioned in the covering letter. BHEL shall not be responsible for any missing documents.

Offer can also be sent through e-mail at following mail address. In such a case both Part-I and Part-II of the offer should be sent and offer in two parts must reach before due date and time of submission. Part-II (Price Bid) should be sent as pass word protected. Pass Word shall be communicated by the bidder to the undersigned on the date of price bid opening. Original copy of the offer should be dispatched prior to due date of submission of offer.

Mail ID - vkg@bhel.com

- 7.0 No Deviation with respect to tender clauses and no additional clauses/ suggestions/ in Techno-commercial bid/ Price bid shall normally be considered by BHEL. Bidders are requested to positively comply with the same.
- 8.0 BHEL reserves the right to accept or reject any or all Offers without assigning any reasons thereof. BHEL also reserves the right to cancel the Tender wholly or partly without assigning any reason thereof. Also BHEL shall not entertain any correspondence from bidders in this matter (except for the refund of EMD).
- 9.0 **Assessment of Capacity of Bidders:**
Bidders capacity for executing the job under tender shall be assessed as per the following:

I. **Assigning Weightages (A) for Similar Jobs Under-Execution:** Weightages shall be worked out and assigned based on the average number of Similar Works under execution including works yet to be commenced by the agency, in the following manner:

i). **Number of Similar Jobs**

- a) No. of jobs in BHEL, PSER : Say 'J'
- b) No. of jobs in BHEL, PSSR : Say 'K'
- c) No. of jobs in BHEL, PSWR : Say 'L'
- d) No. of jobs in BHEL, PSNR : Say 'M'
- e) No. of jobs with other customers* : Say 'N' (*: Other than BHEL PSER, PSSR, PSWR & PSNR)
- f) Average No. of Jobs is 'P' = (J+K+L+M+N) divided by 5

ii) **Weightage "A" assigned to bidders based on Average Number of jobs "P":**

- a) If 'P' = 0-1, "A" will be equal to '3'
- b) If 'P' = 2-3, "A" will be equal to '2'
- c) If 'P' = 4-5, "A" will be equal to '1'
- d) If 'P' is Above 5, "A" will be equal to '0'

II. **Weightage "B" for Quarterly Performance Reports of Vendors:** This shall be based on the averages of the net weighted score obtained by the bidder for the jobs under execution (excluding works not commenced) for the quarter previous to the last quarter reckoned from the date of latest due date of submission, in all four Regions i.e BHEL PSER, PSSR, PSWR & PSNR, in the following manner.

i). **Ratings by Power Sector Region:**

- a) PS ER's Rating 'Rer' = $(X_1 + X_2 + \dots + X_n)$ divided by n
- b) PS WR's Rating 'Rwr' = $(X_1 + X_2 + \dots + X_n)$ divided by n
- c) PS SR's Rating 'Rsr' = $(X_1 + X_2 + \dots + X_n)$ divided by n
- d) PS NR's Rating 'Rnr' = $(X_1 + X_2 + \dots + X_n)$ divided by n
- e) **Over all Power Sector Region Rating 'R_{BHEL}' = (Rer+ Rwr+ Rsr+ Rnr) divided by 4**

(where "X₁, X₂, X₃,...X_n" is the net weighted score obtained by the bidder as per the "Evaluation of Contractor Performance (Quarterly)" against the various contracts 'n' under execution in the respective Region).

ii) **Weightage "B" assigned to bidders based on Overall Power Sector Rating (R_{BHEL}):**

- a) If R_{BHEL} is 80% and above, "B" will be equal to '6'
- b) If R_{BHEL} is > 70% < 80%, "B" will be equal to '5'
- c) If R_{BHEL} is > 60% < 70%, "B" will be equal to '4'
- d) If R_{BHEL} is = < 60%, "B" will be equal to '0'

III. **Evaluation of Bidders capacity to execute the job under tender:** shall be based on the sum of scores obtained in 'A' and 'B', as below:

- a) **6 or above : Considered 'Qualified' for the job under tender**
- b) **Less than 6: Considered 'NOT Qualified' for the job under tender**

IV. **Explanatory note:**

- a) Similar work means Boiler or Turbine or Civil or Electrical or CI, etc irrespective of rating of Plant
- b) Quarter shall be as per the quarter defined in the "Evaluation of Contractor performance (Quarterly)". For contracts where annexed Quarterly Evaluation performance was not part of the contract, 'Quarterly Performance Reports' previous to the last quarter reckoned from the date of

latest due date of submission, given by the respective project site against the contract will be the basis for evaluation.

- c) Vendors who are not executing any jobs presently in the Region and first timers to the Region, may be considered subject to satisfying all other tender conditions
 - d) 'Under execution' shall mean works in progress upto Boiler Steam Blowing (for Boiler and Auxilliaries) or Synchronisation (for all other jobs including Civil) shall be considered.
- 10.0 Since the job shall be executed at site, bidders must visit site/ work area and study the job content, facilities available, availability of materials, prevailing site conditions including law & order situation etc before quoting for this tender. They may also consult this office before submitting their offers, for any clarifications regarding scope of work, facilities available at sites or on terms and conditions. No additional claim shall be entertained by BHEL in future, on account of non-acquaintance of above.
- 11.0 For any clarification on the tender document, the bidder may seek the same in writing or through e-mail, as per specified format, within the scheduled date for seeking clarification, from the office of the undersigned. BHEL shall not be responsible for receipt of queries after due date of seeking clarification due to postal delay or any other delays. Any clarification / query received after last date for seeking clarification may not be normally entertained by BHEL and no time extension will be given.
- 12.0 BHEL may decide holding pre-bid discussion [PBD] with all intending bidders as per date indicated in the NIT. The bidder shall ensure participation for the same at the appointed time, date and place as may be decided by BHEL. Bidders shall plan their visit accordingly. The outcome of pre-bid discussion (PBD) shall also form part of tender.
- 13.0 In the event of any conflict between requirement of any clause of this specification/ documents/drawings/data sheets etc or requirements of different codes/standards specified, the same to be brought to the knowledge of BHEL in writing for clarification before due date of seeking clarification (whichever is applicable), otherwise, interpretation by BHEL shall prevail. Any typing error/missing pages/ other clerical errors in the tender documents, noticed must be pointed out before pre-bid meeting/submission of offer, else BHEL's interpretation shall prevail.
- 14.0 Unless specifically mentioned otherwise, bidder's quoted price shall deemed to be in compliance with tender including PBD.
- 15.0 Bidders shall submit Integrity Pact Agreement (Duly signed by authorized signatory who signs in the offer), **if applicable**, along with techno-commercial bid. This pact shall be considered as a preliminary qualification for further participation. **The names and other details of Independent External Monitor (IEM) for the subject tender is as given at point (xi) of 1 above.**
- 16.0 The Bidder has to satisfy the Pre Qualifying Requirements stipulated for this Tender in order to be qualified. The Price Bids of only those bidders will be opened who will be qualified for the subject job on the basis of pre-qualification evaluation/ techno-commercial bids, approval/ acceptance of customer (as applicable), etc. and date of opening of price bids shall be intimated to only such bidders.
- 17.0 In case BHEL decides on a 'Public Opening', the date & time of opening of the sealed PRICE BID shall be intimated to the qualified bidders and in such a case, bidder may depute one authorised representative to witness the price bid opening. BHEL reserves the right to open 'in-camera' the 'PRICE BID' of any or all Unsuccessful/Disqualified bidders under intimation to the respective bidders.
- 18.0 Validity of the offer shall be for **six months** from the latest due date of offer submission (including extension, if any) or specified otherwise in SCC of tender.
- 19.0 BHEL reserves the right to decide the successful bidder on the basis of Reverse Auction process. In such case all qualified bidders will be intimated regarding procedure/ modality for Reverse Auction process prior to Reverse Auction and price will be decided as per the rules for Reverse Auction. .

However, if reverse auction process is unsuccessful as defined in the RA rules/procedures, or for whatsoever reason, then the sealed 'PRICE BIDS' will be opened for deciding the successful bidder. BHEL's decision in this regard will be final and binding on bidder.

- 20.0 On submission of offer, further consideration will be subject to compliance to tender & qualifying requirement and customer's acceptance, as applicable.
- 21.0 In case the bidder is an "Indian Agent of Foreign Principals", 'Agency agreement has to be submitted along with Bid, detailing the role of the agent along with the terms of payment for agency commission in INR, along with supporting documents.
- 22.0 The bidders shall not enter into any undisclosed M.O.U. or any understanding amongst themselves with respect to tender.
- 23.0 In case Consortium Bidding is allowed as per Pre Qualifying Requirement, then Prime Bidder and Consortium Partner shall enter into Consortium Agreement. Validity period of Consortium Agreement shall be 6 months after which the same can be re validated.

'Stand alone' bidder cannot become a '**prime bidder**' or a '**consortium bidder**' in a consortium bidding. Prime bidder shall neither be a consortium partner to other prime bidder nor take any other consortium partners. However, consortium partner may enter into consortium agreement with other prime bidders. In case of non compliance, consortium bids of such Prime bidders will be rejected. .

- 24.0 The bidder shall submit documents in support of possession of 'Qualifying Requirements" duly self certified and stamped by the authorized signatory, indexed and properly linked in the format for PQR. In case BHEL requires any other documents/proofs, these shall be submitted immediately.
- 25.0 The bidder may have to produce original document for verification if so decided by BHEL.
- 26.0 Order of Precedence
In the event of any ambiguity or conflict between the Tender Documents, the order of precedence shall be in the order below:
- a. Amendments/Clarifications/Corrigenda/Errata etc issued in respect of the tender documents by BHEL
 - b. Notice Inviting Tender (NIT)
 - c. Price Bid
 - d. Technical Conditions of Contract (TCC)—Volume-1A
 - e. Special Conditions of Contract (SCC) —Volume-1B
 - f. General Conditions of Contract (GCC) —Volume-1C
 - g. Forms and Procedures —Volume-1D

For BHARAT HEAVY ELECTRICALS LTD

(SCT)

Enclosure

01. Annexure-1: Pre Qualifying criteria.
02. Annexure-2: Check List.
03. Annexure-3: GENERAL TERMS AND CONDITIONS OF REVERSE AUCTION (RA)
04. Annexure-4: Authorization of representative who will participate in the on line Reverse Auction Process
05. Annexure-5: INTEGRITY PACT

ANNEXURE - 1

PRE QUALIFYING CRITERIA

JOB	"ERECTION, TESTING, COMMISSIONING, TRIAL OPERATION AND HANDING OVER OF PIPING WORKS AT 4 X 125 MW KOSTI TPS, SUDAN."
TENDER NO.	TENDER NO. BHEL/ NR/SCT/ KOSTI /ELEC/ 836

QUALIFYING REQUIREMENTS (QR):

S. No.	CRITERIA
1.0	Tenderers should have an average annual turnover of minimum of INR 78 million or Euro 1.147 million or USD 1.591 million or SDG 4.258 million based on the audited accounts of last three financial years (2007-08, 2008-09 & 2009-10) OR (2008-09, 2009-10 & 2010-11). Bidders shall submit audited annual accounts (balance sheets and profit & loss account) in support of this. Financial year in line with calendar year may also be considered e.g closing in Dec 2009 as 2009-10.
2.0	Bidder who wish to participate should have completed, during last 7 years as on the date of opening of Technical Bid, works of similar nature covered in this tender in power plant / industrial unit as per the following :
2.1	<p>2.1.1) One single work of similar nature valuing each of minimum INR 208 million or Euro 3.058 million or USD 4.243 million or SDG 11.354 million</p> <p style="text-align: center;">OR</p> <p>2.1.2) Two works of similar nature valuing each of minimum INR 130 million or Euro 1.911 million or USD 2.652 million or SDG 7.097 million</p> <p style="text-align: center;">OR</p> <p>2.1.3) Three works of similar nature valuing each of minimum INR 104 million or Euro 1.529 million or USD 2.122 million or SDG 5.677 million</p>
	OR
2.2	<p>Should have completed works, during last seven years as on the date of opening of Technical Bid:</p> <p>2.2.1) Electrical works in a power plant consisting of</p> <p style="margin-left: 20px;">a) Power Transformers (60 MVA)</p> <p style="margin-left: 20px;">b) HT Bus Ducts</p> <p style="margin-left: 20px;">c) HT Swgr.</p> <p style="text-align: center;">OR</p> <p>2.2.2) At least one contract of Electrical works in any industry consisting of a,b & c of 2.2.1 of minimum value of INR 10 million OR Euro 0.147 million OR USD 0.204 million OR SDG 0.546 Million</p>
	AND

	<p>2.2.3) C&I works for BTG/GT OR C&I works consisting of DCS/DDC/Station C&I in one unit of at least 60 MW rating OR 2.2.4) At least one contract of C&I works consisting of DCS/DDC/Station C&I in any industry with its minimum value INR 10 million OR Euro 0.147 million OR USD 0.204 Million OR 0.546 Million.</p>
	Relevant documents in support of above shall be submitted by the bidder
3.0	<p>Submission of Integrity Pact duly signed</p> <p>“Tenderers is required to enter into an Integrity Pact (IP) with BHEL against this tender/ contract by signing and stamping all the pages of IP by authorized representative as per the Format enclosed. Tenderer, who do not accept at this and do not comply with this requirement shall not be considered against this tender”</p>
4.0	Tie-Up Arrangement
4.1	<p>The Tenderer should meet all the QR at SL NO. 1, 2 & 3 above. However in case of 2.2 the tenderer having experience of Electrical works (2.2.1 OR 2.2.2) but do not possess requisite experience in Control and Instrumentation (2.2.3 OR 2.2.4) or vice versa, shall be allowed to have a tie-up with another associate having requisite experience for the works for which the tenderer does not possess the requisite experience.</p> <p>Maximum one tie up shall be permitted. The tenderer shall be the Lead Partner and he will submit documents in support of his experience and experience of his partner in line with all the Technical QRs. However, the tie up arrangement is subject to approval of BHEL. In such a case of tie up, the tenderer (Lead Partner) shall submit documents related to their Tie-up arrangement in Part-I bid (Technical Bid). The composition of the Tie-up arrangement and role and responsibility of each constituent must be well defined and the document submitted shall clearly indicate who shall be the lead partner.</p>
	The tenderer (Lead Partner) shall meet all Financial QR criteria given at SI No 1.0.

Notes

1. If the Qualifying work is executed in the 7 years period as specified above, even if it has been started earlier, the same will also be considered meeting the qualifying requirements.

Legend : **DCS** : Data Control System; **DDC** : Digital distributed control system ;
BTG : Boiler Turbine Generator ; **GT** : Gas Turbine ;
C&I : Controls & Instrumentation

ANNEXURE - 2

CHECK LIST

NOTE:- Tenderers are required to fill in the following details and no column should be left blank

1	Name and Address of the Tenderer		
2	Details about type of the Firm/Company		
3	Details of Contact person for this Tender	Name : Mr/Ms Designation: Telephone No: Mobile No: Fax No:	
4	EMD DETAILS	DD No: Date : Bank : Amount: <u>Please tick (√) whichever applicable:-</u> ONE TIME EMD / ONLY FOR THIS TENDER	
5	Validity of Offer	TO BE VALID FOR SIX MONTHS FROM DUE DATE	
		APPLICABILITY	BIDDER REPLY
6	Whether the format for compliance with PRE QUALIFICATION CRITERIA (ANNEXURE-I) is understood and filled with proper supporting documents referenced in the specified format	Applicable	YES / NO
7	Audited profit and Loss Account for the last three years	Applicable/Not Applicable	YES/NO
8	Copy of PAN Card	Applicable/Not Applicable	YES/NO
9	Whether all pages of the Tender documents including annexures, appendices etc are read understood and signed	Applicable/Not Applicable	YES/NO
10	Integrity Pact	Applicable/Not Applicable	YES/NO
11	Declaration by Authorised Signatory	Applicable/Not Applicable	YES/NO
12	No Deviation Certificate	Applicable/Not Applicable	YES/NO
13	Declaration confirming knowledge about Site Conditions	Applicable/Not Applicable	YES/NO
14	Declaration for relation in BHEL	Applicable/Not Applicable	YES/NO
15	Non Disclosure Certificate	Applicable/Not Applicable	YES/NO
16	Bank Account Details for E-Payment	Applicable/Not Applicable	YES/NO
17	Capacity Evaluation of Bidder for current Tender	Applicable/Not Applicable	YES/NO
18	Tie Ups/Consortium Agreement are submitted as per format	Applicable/Not Applicable	YES/NO
19	Power of Attorney for Submission of Tender/Signing Contract Agreement	Applicable/Not Applicable	YES/NO
20	Analysis of Unit rates	Applicable/Not Applicable	YES/NO

NOTE : STRIKE OFF 'YES' OR 'NO', AS APPLICABLE

DATE :

AUTHORISED SIGNATORY
(With Name, Designation and Company seal)

ANNEXURE- 3

GENERAL TERMS AND CONDITIONS OF REVERSE AUCTION (RA)

Against this enquiry for the subject item / system with detailed scope of supply as per our tender specification, BHEL-PSNR, NOIDA may resort to “REVERSE AUCTION PROCEDURE” i.e. **ONLINE BIDDING on INTERNET.**

1. For the proposed reverse auction, technically and commercially acceptable bidders only shall be eligible to participate.
2. BHEL will engage the services of a service provider who will provide all necessary training and assistance before commencement of on line bidding on Internet.
3. In case BHEL decides to conduct reverse auction, BHEL’s service provider shall contact the vendor directly and impart them the training.
4. Business rules like event date, time, start price, bid decrement, extensions, etc. also will be communicated through service provider for compliance.
5. Vendors have to fax the compliance form in the prescribed (provided by service provider) before start of Reverse auction. Without this the vendor will not be eligible to participate in the event.
6. **Total Price quoted shall be inclusive of all taxes except service tax in line with the NIT conditions for the subject work in Indian Rupees (INR), which is to be worked out as per the BOQ (Rate Schedule) given in tender enquiry and subsequent changes made, if any. EXCEL Sheet shall be provided, if applicable.**
7. Reverse auction will be conducted on schedule date & time.
8. At the end of reverse auction event, the lowest bidder value will be known on the network.
9. The lowest bidder has to fax the duly signed filled-in prescribed format as provided on case-to-case basis to BHEL through service provider after completion of event on the same day preferably.
10. Any variation between the on-line bid value and signed document will be considered as sabotaging the tender process and will invite disqualification of vender to conduct business with BHEL as per prevailing procedure.
11. In case BHEL decides not to go for Reverse auction procedure for this tender enquiry, the price bids and price impacts, if any already submitted and available with BHEL shall be opened as per BHEL standard practice.

ANNEXURE- 4

Authorization of representative who will participate in the on line Reverse Auction Process;

1	NAME & DESIGNATION OF OFFICIAL	
2	POSTAL ADDRESS (COMPLETE)	
3	TELEPHONE NOS. (LAND LINE & MOBILE BOTH)	
4	FAX NO.	
5	E-MAIL ADDRESS	
6	NAME OF PLACE/ STATE/ COUNTRY, WHEREFROM S/HE WILL PARTICIPATE IN THE REVERSE AUCTION	

INTEGRITY PACT

Between

Bharat Heavy Electricals Ltd. (BHEL), a company registered under the Companies Act 1956 and having its registered office at “BHEL House”, Siri Fort, New Delhi – 110049 (India) hereinafter referred to as “The Principal”, which expression unless repugnant to the context or meaning hereof shall include its successors or assigns of the ONE PART

and

_____, (description of the party along with address), hereinafter referred to as “The Bidder/ Contractor” which expression unless repugnant to the context or meaning hereof shall include its successors or assigns of the OTHER PART

Preamble

The Principal intends to award, under laid-down organizational procedures, contract/s for

_____. The Principal values full compliance with all relevant laws of the land, rules and regulations, and the principles of economic use of resources, and of fairness and transparency in its relations with its Bidder(s)/ Contractor(s).

In order to achieve these goals, the Principal will appoint Independent External Monitor(s), who will monitor the tender process and the execution of the contract for compliance with the principles mentioned above.

Section 1 – Commitments of the Principal

- 1.1 The Principal commits itself to take all measures necessary to prevent corruption and to observe the following principles:-
 - 1.1.1 No employee of the Principal, personally or through family members, will in connection with the tender for, or the execution of a contract, demand, take a promise for or accept, for self or third person, any material or immaterial benefit which the person is not legally entitled to.
 - 1.1.2 The Principal will, during the tender process treat all Bidder(s) with equity and reason. The Principal will in particular, before and during the tender process, provide to all Bidder(s) the same information and will not provide to any Bidder(s) confidential / additional information through which the Bidder(s) could obtain an advantage in relation to the tender process or the contract execution.
 - 1.1.3 The Principal will exclude from the process all known prejudiced persons.
- 1.2 If the Principal obtains information on the conduct of any of its employees which is a penal offence under the Indian Penal Code 1860 and Prevention of Corruption Act 1988 or any other statutory penal enactment, or if there be a substantive suspicion in this regard, the Principal will inform its Vigilance Office and in addition can initiate disciplinary actions.

Section 2 – Commitments of the Bidder(s)/ Contractor(s)

- 2.1 The Bidder(s)/ Contractor(s) commit himself to take all measures necessary to prevent corruption. He commits himself to observe the following principles during his participation in the tender process and during the contract execution.
 - 2.1.1 The Bidder(s)/ Contractor(s) will not, directly or through any other person or firm, offer, promise or give to the Principal or to any of the Principal's employees involved in the tender process or the execution of the contract or to any third person any material, immaterial or any other benefit which he / she is not legally entitled to, in

order to obtain in exchange any advantage of any kind whatsoever during the tender process or during the execution of the contract.

- 2.1.2 The Bidder(s)/ Contractor(s) will not enter with other Bidder(s) into any illegal or undisclosed agreement or understanding, whether formal or informal. This applies in particular to prices, specifications, certifications, subsidiary contracts, submission or non-submission of bids or any other actions to restrict competitiveness or to introduce cartelization in the bidding process.
- 2.1.3 The Bidder(s)/ Contractor(s) will not commit any penal offence under the relevant IPC/ PC Act; further the Bidder(s)/ Contractor(s) will not use improperly, for purposes of competition or personal gain, or pass on to others, any information or document provided by the Principal as part of the business relationship, regarding plans, technical proposals and business details, including information contained or transmitted electronically.
- 2.1.4 The Bidder(s)/ Contractor(s) will, when presenting his bid, disclose any and all payments he has made, and is committed to or intends to make to agents, brokers or any other intermediaries in connection with the award of the contract.
- 2.2 The Bidder(s)/ Contractor(s) will not instigate third persons to commit offences outlined above or be an accessory to such offences.

Section 3 – Disqualification from tender process and exclusion from future contracts

If the Bidder(s)/ Contractor(s), before award or during execution has committed a transgression through a violation of Section 2 above, or acts in any other manner such as to put his reliability or credibility in question, the Principal is entitled to disqualify the Bidders(s)/ Contractor(s) from the tender process or take action as per the separate “Guidelines for Suspension of Business Dealings with Suppliers/ Contractors” framed by the Principal.

Section 4 – Compensation for Damages

- 4.1 If the Principal has disqualified the Bidder(s) from the tender process prior to the award according to Section 3, the Principal is entitled to demand and recover the damages equivalent to Earnest Money Deposit/ Bid Security.
- 4.2 If the Principal has terminated the contract according to Section 3, or if the Principal is entitled to terminate the contract according to section 3, the Principal shall be entitled to demand and recover from the Contractor liquidated damages equivalent to 5% of the contract value or the amount equivalent to Security Deposit/Performance Bank Guarantee, whichever is higher.

Section 5 – Previous Transgression

- 5.1 The Bidder declares that no previous transgressions occurred in the last 3 years with any other company in any country conforming to the anti-corruption approach or with any other Public Sector Enterprise in India that could justify his exclusion from the tender process.
- 5.2 If the Bidder makes incorrect statement on this subject, he can be disqualified from the tender process or the contract, if already awarded, can be terminated for such reason.

Section 6 – Equal treatment of all Bidders/ Contractors/ Sub-contractors

- 6.1 The Bidder(s)/ Contractor(s) undertake(s) to demand from his sub-contractors a commitment consistent with this Integrity Pact. This commitment shall be taken only from those sub-contractors whose contract value is more than 20% of Bidder's/ Contractor's contract value with the Principal.
- 6.2 The Principal will enter into agreements with identical conditions as this one with all Bidders and Contractors.
- 6.3 The Principal will disqualify from the tender process all bidders who do not sign this pact or violate its provisions.

Section 7 – Criminal Charges against violating Bidders/ Contractors /Sub-contractors

If the Principal obtains knowledge of conduct of a Bidder, Contractor or Subcontractor, or of an employee or a representative or an associate of a Bidder, Contractor or Subcontractor which constitutes corruption, or if the Principal has substantive suspicion in this regard, the Principal will inform the Vigilance Office.

Section 8 –Independent External Monitor(s)

- 8.1 The Principal appoints competent and credible Independent External Monitor for this Pact. The task of the Monitor is to review independently and objectively, whether and to what extent the parties comply with the obligations under this agreement.
- 8.2 The Monitor is not subject to instructions by the representatives of the parties and performs his functions neutrally and independently. He reports to the CMD, BHEL.
- 8.3 The Bidder(s)/ Contractor(s) accepts that the Monitor has the right to access without restriction to all contract documentation of the Principal including that provided by the Bidder(s)/ Contractor(s). The Bidder(s)/ Contractor(s) will grant the monitor, upon his request and demonstration of a valid interest, unrestricted and unconditional access to his contract documentation. The same is applicable to Sub-contractor(s). The Monitor is under contractual obligation to treat the information and documents of the Bidder(s)/ Contractor(s) / Sub-contractor(s) with confidentiality.
- 8.4 The Principal will provide to the Monitor sufficient information about all meetings among the parties related to the contract provided such meetings could have an impact on the contractual relations between the Principal and the Contractor. The parties offer to the Monitor the option to participate in such meetings.
- 8.5 As soon as the Monitor notices, or believes to notice, a violation of this agreement, he will so inform the Management of the Principal and request the Management to discontinue or

take corrective action, or heal the situation, or to take other relevant action. The Monitor can in this regard submit non-binding recommendations. Beyond this, the Monitor has no right to demand from the parties that they act in a specific manner, refrain from action or tolerate action.

- 8.6 The Monitor will submit a written report to the CMD, BHEL within 8 to 10 weeks from the date of reference or intimation to him by the Principal and, should the occasion arise, submit proposals for correcting problematic situations.
- 8.7 The CMD, BHEL shall decide the compensation to be paid to the Monitor and its terms and conditions.
- 8.8 If the Monitor has reported to the CMD, BHEL, a substantiated suspicion of an offence under relevant IPC / PC Act, and the CMD, BHEL has not, within reasonable time, taken visible action to proceed against such offence or reported it to the Vigilance Office, the Monitor may also transmit this information directly to the Central Vigilance Commissioner, Government of India.
- 8.9 The number of Independent External Monitor(s) shall be decided by the CMD, BHEL.
- 8.10 The word 'Monitor' would include both singular and plural.

Section 9 – Pact Duration

- 9.1 This Pact begins when both parties have legally signed it. It expires for the Contractor 12 months after the last payment under the respective contract and for all other Bidders 6 months after the contract has been awarded.
- 9.2 If any claim is made / lodged during this time, the same shall be binding and continue to be valid despite the lapse of this pact as specified as above, unless it is discharged/ determined by the CMD, BHEL.

Section 10 – Other Provisions

- 10.1 This agreement is subject to Indian Laws and jurisdiction shall be registered office of the Principal, i.e. New Delhi.
- 10.2 Changes and supplements as well as termination notices need to be made in writing. Side agreements have not been made.
- 10.3 If the Contractor is a partnership or a consortium, this agreement must be signed by all partners or consortium members.
- 10.4 Should one or several provisions of this agreement turn out to be invalid, the remainder of this agreement remains valid. In this case, the parties will strive to come to an agreement to their original intentions.
- 10.5 Only those bidders/ contractors who have entered into this agreement with the Principal would be competent to participate in the bidding. In other words, entering into this agreement would be a preliminary qualification.

 For & On behalf of the Principal
 (Office Seal)

 For & On behalf of the Bidder/ Contractor
 (Office Seal)

Place-----

Date-----

Witness: _____
 (Name & Address) _____

Witness: _____
 (Name & Address) _____

FOR OFFICIAL USE ONLY
NOT FOR PUBLICATION

TENDERER'S COPY
ORIGINAL COPY

TECHINICAL CONDITIONS OF CONTRACT (TCC)

TENDER NO. BHEL/ NR/SCT/ KOSTI /ELEC/ 836

FOR

ERECTION, TESTING, COMMISSIONING TRIAL OPERATION AND
HANDING OVER OF BALANCE WORKS OF ELECTRICAL PACKAGE 4
X 125 MW AT KOSTI TPS, SUDAN.

PART- I OF TCC



Bharat Heavy Electricals Limited
(A Govt. Of India Undertaking)
Power Sector – Northren Region,
Plot No. 25 , Sector - 16A ,
Distt. Gautam Budh Nagar, NOIDA – 201 301 (INDIA)



ISO 9001, ISO 14001,
OHSAS 18001 & SA 8000
certified company
SubContract and Purchase
Deptt.

Bharat Heavy Electricals Limited
(A Govt. Of India Undertaking)
Power Sector – Northern Region,
Plot No. 25 , Sector - 16A ,
Distt. Gautam Budh Nagar, NOIDA – 201 301(INDIA)
Phone: 0091-0120- 2416286 / 2515440
Fax 091-0120-2416528
Email: vkg@bhelpsnr.co.in / msd@bhelpsnr.co.in

TENDER NO. BHEL/ NR/ SCT/ KOSTI /ELEC/ 836

IMPORTANT NOTE

PURCHASER OF THIS TENDER DOCUMENT IS ADVISED TO CHECK AND ENSURE COMPLETION OF ALL PAGES OF TENDER DOCUMENT AND REPORT ANY DISCREPANCY TIMELY FOR CORRECTIVE ACTION, IF ANY, TO THE ISSUING AUTHORITY BEFORE THE BIDS ARE SUBMITTED. ORIGINAL COPY OF TENDER DOCUMENT COMPLETE IN ALL RESPECTS MUST BE SUBMITTED BACK AS PART OF THE BID WITHOUT WHICH THE SAME IS LIABLE TO BE REJECTED BY BHEL.

THIS TENDER SPECIFICATION ISSUED TO:

M/S-----



PART-I OF TCC

S.No.	DESCRIPTION	Chapter No.	PAGE NO.
	Part-I: Contract specific details		
1.	Project Information	Chapter-I	
2.	Scope of Works	Chapter-II	
3.	Facilities in the scope of Contractor/BHEL (Scope Matrix)	Chapter-III	
4.	T&Ps and MMEs to be deployed by Contractor	Chapter-IV	
5.	T&Ps and MMEs to be deployed by BHEL on s basis	Chapter-V	
6.	Time Schedule	Chapter-VI	
7.	Terms of Payment	Chapter-VII	
8.	Taxes and other Duties	Chapter-VIII	
9.	Others	Chapter-IX	
10.	Annexures	Chapter-X	
11.	Rate Schedule	Chapter-XI	

PROJECT SYNOPSIS

Kosti Thermal Power Project to be constructed is a Greenfield project with 4x125 MW Thermal units having gas/oil fired boilers & aux., steam turbine generators & aux., BFPs, switchyard etc. to be executed on EPC basis by BHEL at Sudan. The owner of the Project is National Electricity Corporation(NEC), Sudan, which is a Govt. of Sudan entity. The plant will supply electricity to South & West Sudan.

Kosti lies south of Khartoum (Capital of Sudan) on an Asphalt road with latitude 13.10 N and longitude 090.14E. The Kosti site is centrally located just 350 KM south of Khartoum. The river Nile is passing near by and the site has easy connectivity by road.

Distance of project site from Port of Sudan (only port in Sudan) is 1200 km and the project site is about 600 Mtrs. from Sinar Highway.

Temperature Data:

- (a) Maximum ambient temperature : 45 Deg C
- (b) Minimum ambient temperature : 16 Deg C

Mean(Design) annual humidity:

- (a) Maximum 71% in August
- (b) Minimum 26% in April

Wind Data:

- (a) Maximum speed of wind 11 Km/h
- (b) Wind direction is Southern (May to September) and Northern in the rest of the year.

2.0 SCOPE OF WORK

2.1 BHEL has been awarded the work of Design, Manufacture, supply, installation, erection & commissioning of EPC package of **4x125 MW units at Kosti ,Sudan**.The equipment consists of boiler, Electro-static precipitator, Fans, milling systems, steam turbines, generators, boilers feed pumps, condensate extraction pumps and piping along with the associated auxiliary supports and controls , Complete BOP and Electrical Systems .

The broad scope of Supply of Equipments under this project for 4 X125 MW set Electrical Package is as under :

ELECTRICAL :

1. Erection and commissioning of Generator Transformers, Station Transformers, Unit Transformers
2. Erection and commissioning of Isolated phase bus ducts, LAVT, NG cubicle, Current transformers etc.
3. Erection and commissioning of Digital automatic voltage regulator panel
4. Erection and commissioning of soot blower MCC/Starter Panel/Marshalling Boxes etc.
5. Supply of adequate quantity of touch up paint and paints as required for items covered in scope of works.
6. Supply as well as installation of material for sealing and making vermin/ dust proof unused openings, if any, in panels/ JB's

INSTRUMENTATION :

7. Commissioning of Boiler, Steam turbine & Station C&I control panels etc.
8. Erection and commissioning of All Types of Field Instruments like Temperature, Pressure and Flow instruments (local & remote) and special instruments like EWLI, SWAS System, Flue Gas analyser etc.
9. Erection and commissioning Man Machine Interface & Data Acquisition System consists of Operator Workstations (max Station),Engineering station (common for SG/TG/GT),Computers / PLC based Equipments, Laser printers (B/W-A3),Ethernet Switches
- 10.Erection of all types of Hardware like impulse pipes, cable trays & tray supports etc.
- 11.Fabrication and installation of steel supports, wherever required

12. Erection Installation of canopy for outdoor pushbutton stations/motors/panels/ instrumentation.
13. Commissioning of all Types of Electrical/ Pneumatic operated Valves/Actuators/ Controllers and Relief Valves.
14. Supply of adequate quantity of touch up paint and paints as required for items covered in scope of works
15. Erection and commissioning of UPS Panel and ACDB etc.

CABLING :

16. Fixing of Bolted Type Cable Tray Support Structure to concrete foundations / brick walls by anchor bolts or to steel structure by suitable clamps , including fabrication / fixing of any other structure required to install the support structure .
17. Fixing of cable trays and tray bends and accessories to the tray supporting structure including modification of the trays to suit the local tray route conditions is to be carried out .
18. Laying, dressing & clamping of the cables in the cable trays / angles / conduit pipes as per the cable schedule and as instructed by the BHEL Engineer . Nylon / PVC ties required for dressing / clamping shall be provided to the Contractor .
19. The cable tags , as approved by the BHEL Engineer , are to be provided by the contractor (at both ends and at regular intervals as advised by BHEL Engineer) at his cost . Similarly Wire ferrules of approved category is to be provided by the Contractor at his cost .
20. While laying cables, existing cable trench covers and false flooring may require to be removed and re-fixed. The same has to be done at no extra cost to BHEL
21. Gland plate hole drilling is to be carried out by the contractor at no extra cost
22. Cable Termination shall be carried out by the contractor as per approved drawings / as per instructions of the Engineer . Lugs , Glands , cable termination kits will be supplied by BHEL . Wire ferrules of approved category is to be provided by the Contractor at his cost . All required crimping tools and other tools will be provided by the Contractor

COMMON :

23. Installation of Danger Board, First aid box
24. Supply of all consumables required for installation
25. Assistance for demonstration of Trial run of 4 x 125 MW Unit (s) as a whole.
26. Assistance during PG Testing of main equipment along with all auxiliaries. Completion of punch points and assistance for handing over of unit (s) to customer.
27. Unit trial operation, resolving any deficiencies observed and handing over

2.2 The contractor has to provide the following manpower services for 56 man months exclusively for BHEL within the quoted price:

- a) Skilled computer operator – 8 manmonths
- b) Skilled worker - 16 manmonths
- c) UnSkilled worker - 32 manmonths

Persons so deployed shall have to work in extended hours whenever required. Workmen provided as per the above provisions shall be fully trained and experienced in the nature of work for which they are deployed.

In case contractor fails to provide above-mentioned manpower as desired by BHEL, the latter shall have the right to hire such services from other agencies at the risk and cost of the contractor. However, if BHEL does not utilize the man months as per above provision, fully or partly; recovery at the rate of the prevailing minimum wages at Kosti Sudan, for the categories given plus 10% will be made from the final bill of the contractor.

2.3 Contractor shall ensure following:

- I. Contractor has to maintain contact with local hospital having ambulance facility, scanning & other ultra modern medical facilities required during emergency.
- II. Contractor has to ensure pre employment medical check for all staff & workers.
- III. Contractor has to ensure that adequate First Aid facilities with trained nurse are available at work site for emergency purpose. This emergency set-up should include, but not limited to, following
 - Male nurse (in shifts)
 - Oxygen set up
 - Breathing apparatus
 - Eye wash facility
 - Stretcher
 - Trauma blanket
 - Medicines.

In addition to above, BHEL (through its other contractor) has arranged ambulance at work site for emergency purpose, which can be utilized by the contractor in case of emergency. The charges for the same will be decided mutually at site. In case, under unavoidable circumstances, if the ambulance is not available / being used elsewhere, the contractor will have to arrange for the same as under clause 2.3 (I).

2.4 The contractor shall comply with following towards Social Accountability;

- a) The contractor shall not employ any employee less than 15 years of age in pursuant to ILO convention. If any child labour were found to have been engaged, the Contractor shall be levied with expenses of bearing his education expenditure which will include stipend to substantiate appropriate education or employ any other member of family enabling to bear the child education expenditure.
- b) The Contractor shall abide by UN convention w.r.t. Human Rights and shall be liable for Discrimination/ Corporal punishment for failure in meeting with relevant requirements.
- c) The Contractor shall arrange potable drinking water to its employees & workers.

2.5 Major Equipments / Systems to be Installed, Tested and Commissioned under this Project :

However, changes in design may occur as is usual in any such large scale work for which no compensation will be payable and contractor shall complete the entire work as detailed in tender specifications within finally accepted rates / prices.

The brief description of major equipment/ items to be erected, tested and commissioning in the project is described below . **For the scope of work under this package , refer to the BOQ in the Rate Schedule . Since some of the equipments are already placed in position , the scope under this contract consists of 2 types of work:**

- 1. BE+C : Balance Erection and Commissioning – applicable for the equipments / systems in which erection / placement is partially is done as on date .**
- 2. E+C : Erection and Commissioning – applicable for the equipments / systems in which no work is done till date**

However change in design/specification may occur as is usual in any such large work for which no compensation will be payable. Contractor shall complete the entire work as detailed in tender specification including dry out / centrifuging of transformers within the contractual rates. In case during testing, commissioning, post commissioning, trial operation the IR valves of electrical equipment is found low, the contractor shall make arrangements and dry out the equipment within the quoted rates. Removing & reconnection of equipment will be the part of scope at no extra cost to BHEL.

A. EHV SYSTEM :

The EHV System comprises of 220 kV Switchyard Electrical System Equipments and the other auxiliaries associated with the Switchyard Island . The scope also includes installation of 11 kV Outdoor equipments .Brief description of the major equipments of the Switchyard to be installed is as under :

SI No	Equip Description	Unit	Qty	Appx Size (L X D X H)
1	245 kV, 2000 / 3150 A, 40 kA, 3- phase, SF6 Circuit Breaker WITH SUPPORTING LATTICE	nos	9	

	STRUCTURE,			
2	245 kV, 2000 /3150A, 40 kA, 3- phase, HCB, Isolator with one/two Earth Switch (mechanically ganged) COMPLETE	nos	18	
3	245 kV, 2000 /3150A, 40 kA, 3- phase, HCB, Isolator without Switch (mechanically ganged) COMPLETE	nos	6	
4	245 kV Single Tension / Suspension String insulator hardware set with all hardware accessories including Corona ring , tension clamp and with / without Turn Buckle set suitable for Twin / Three TARANTULA AAC Conductor(Sub conductor spacing 250mm).	nos	186	
5	120 kN Disc Insulators for above	nos	4000	
6	Bus Post Insulator with Structure	nos	40	
7	Bay Marshalling Box	nos	9	
8	245 kV CT / VT /CVT with Structure , marshalling Box	nos	54	
9	245 kV Lightning Arrestor with Structure , marshalling Box	nos	18	
10	250 sq mm Underground Copper Earth Conductor	KM	17	
11	20 mm dia copper rod electrode	Nos	80	
13	Shield Wire complete with all clamps	RM	3000	
14	AAC TARANTULA Conductor complete with all clamps	KM	17	
15	4" IPS aluminium tube including cutting, bending, al. welding with sleeves, radiography testing & d.p. testing of 100 % welded joints, fixing corona end bells etc. to complete	RM	1200	
16	Galvanized Iron Pipe 50/100mm NB	RM	1500	
17	2/3-tier cable rack assembly 400 /700 mm wide with anchor fasters	nos	610	
18	Cable trays 600 / 300 / 150 mm wide	Nos	1200	
19	Control / Protection Panels	Nos	20	750 x 800 x 2355
20	SCADA Panels	Nos	5	750 x 800 x 2355
21	Disturbance Recorder panels	Nos	4	600 x 800 x 2315
22	Metering panel	Nos	2	800 x 800 x 2315
23	100 A 110 V battery Charger	Nos	2	75 X 700 X 2415

24	376 AH , 110 V Ni Cd battery bank	Nos	2	4400 X 800
25	LT Control Cables	KM	94	
26	LT Power cables	KM	20	
27	630 kVA, 6.6 / 0.415 V Oil Filled Transformer	Nos	2	
28	415 V SP Busduct	Nos	2	
29	415 V LT MCC	Nos	1	8400 X 1000 X 2415
30	110 V DCDB	Nos	1	3200 X 550 X 2415
31	AC Lighting Distribution Board	nos	1	2000 X 1500 X 1500
32	DC Lighting Distribution Board	nos	1	600 X 500 X 700
33	AC / DC Lighting Panel Indoor	nos	151	
34	AC / DC Lighting Panel Outdoor	nos	15	
35	Outdoor Flood Lights 1 / 2 x 125 / 400 W	nos	53	
36	Indoor Lighting Fixtures / Fans/ Power Points with surface / concealed conduiting , Copper wiring and GI earthing	nos	168	
37	9 m / 4.5 m Swaged Poles for Lighting	nos	7	
38	Air cooled Package unit of 15 TR nominal capacity complete with Reciprocating Compressor, Condenser coil with condenser fan, DX cooling Coilwith Air handling unit, Copper refrigrant interconnecting Piping, self contained Control Panel . All are housed in sturdy construction enclosure.	nos	3	750 x 800 x 2355
39	Duct Mounted Fine Filter 610x610x300 mm - 8 Nos. , Duct Mounted Booster Fan ,	nos	1	
40	GI Sheet for Ducting Gr.275 with frames , hangers , grills , diffusers , etc	Sq M	242	
41	Thermal Insulation with 50 mm thick Aluminium foil faced Poly Eurethene Foam pasted with CPRX compound 50mm width. Self adhesive Pvc.	Sq M	218	
42	Copper hard Drawn Refrigerant piping with all accesseries to inter connect Air cooled Condenser and Package AC unit.	Rmt	140	
43	Misc Items – Humidstat , Pan Humidifier ,Thermostat , Level switch , Temp / Humidity indicator , Strip Heaters	Nos.	6	
44	Solenoid operated Fire Dampers	Nos.	4	
45	Axial Flow Fresh Air Fan complete with TEFC sq. Motor ,rain protection cowl with bird screen, Back Draft damper		1	

46	Axial Flow Exhaust Fan complete with TEFC sq. Motor ,rain protection cowl with bird screen, Back Draft damper	Nos.	4	
47	HVAC MCC	No.	1	2650 X 650 X 2415
48	HVAC Annunciation Panel	No.	1	
49	80/ 150 nb Fire Fighting Hydrant piping Corrosive Protective tapes of thickness 4 mm (in two layers) of coal tar Type A as per AWWA C 203	Mtr.	720	
50	GM Hydrant Valve , Branch Pipes	Nos.	36	
51	Fire Hose with Glass fronted cabinet	Nos.	72	750 x 800 x 2355
52	Hume Pipes / CI Gate Valves			
53	Addressable Multi sensor / photoelectric smoke / Heat detector	Nos.	30	
54	Response Indicator . Manual Call Point ,	Nos.	18	
55	Fire alarm Panel with Hooter , Control Modules etc	Nos.	5	500 X 200 X 400
56	Portable Fire Extinguishers	Nos.	14	
57	Lattice Structure for Towers / LM (31 / 11.7 / 16.2 m) , Beams (18 m) , Shield wire Peak (5 m)	MT	270	
58	11 kV Outdoor Breaker with Supporting Structure	Nos.	2	
59	11 kV Outdoor CT with Supporting Structure	Nos.	2	
60	11 kV Outdoor Isolator with Earth Switch and Supporting Structure	Nos.	6	
61	11 kV Outdoor LA with Supporting Structure	Nos.	2	
62	Phase Discs , Danger Boards , Bay Identifiers	Lot	1	

A) POWER TRANSFORMERS :

2 nos Station Transformer of 25 MVA , 230 kV / 6.9 kV , Star Star, ONAN / ONAF with On Load Tap Changer . The shipping weight of the Nitrogen filled Tank is about 49 MT and the quantity of oil for the first fill is appx 31000 L . The weight of the accessories is appx 13 MT . The appx tank dimensions 5950x 2300 x 3700 mm and the overall dimensions is 10000 x 5800 x 7200 mm

4 nos Generator Transformer of 150 MVA , 230/11 kV , Star Delta , OFAF with Off Load Tap Changer . The shipping weight of the Nitrogen filled Tank is about 128 MT and the quantity of oil for the first fill is appx 48000 L . The weight of the accessories

is appx 15 MT . The appx tank dimensions is 7650 x 3650 x 4125 mm and the overall dimensions is 13200 x 7350 x 8000 mm .

4 nos Unit Auxillary Transformer of 16 MVA , 11kV / 6.9 kV , Delta Star, ONAN / ONAF with On Load Tap Changer . The shipping weight of the Nitrogen filled Tank is about 26 MT and the quantity of oil for the first fill is appx 9700 L . The weight of the accessories is appx 4 MT . The appx tank dimensions is 4200 x 3000 x 2250 mm. and the overall dimensions is 6900 x 6200 x 3400mm

B) ISOLATED PHASE BUSDUCT :

4 nos 11 kV , 10000 A , Al Conductor , Al Alloy Enclosure Busduct . The Busduct connects Gen Transformer to the Generator and has Tap Off for 1 nos UAT , LAVT and NG Cubicle . In the Nuetral Side , the Star Formation is is made to form the star point and the Generator is earthed thru the NG Transformer . The average per phase route length of the Main Run , UAT Tap Off , LAVT is 50 m , 5 m , 5 m respectively . The conductor section in the Main Run is 465 mm OD , 15 mm thick and that of Tap Off is 114.3 OD , 8.56 mm thk . The duct diameters for Main and TapOff is 1000 mm , 6.35 thk and 680 mm , 4.78 mm thk . The total number of welded joints (butt and flexible) on the Main Run and Tap Off are 25 nos and 20 nos respectively .The appx weights of the supporting structure is 20 MT . In addition the there is 1 set of 3 nos LAVT having dimensions 2450 mm x 1200 mm x 2900 mm and having weight of 1.5 MT each . Total nos of CTs envisaged is 42 nos and nos of VTs is 9 . 1 nos NG Cubicle consisting of 1 nos NGT and 1 nos NGR and having a total weight of 1.6 MT is envisaged .Hot Air Blowing Unit having a total weight of 1.0 MT is envisaged .Seal Off Bushing and Rubber bellows are also provided in the busduct .

C) **6.6 kV SWITCHGEAR :**

6.6 kV Switchgear System consists of One board consisting of 25 panels (Breakers) The Switchgear is Spring Operated Metal Clad Vacuum Interrupters with Protection and Metering CTs , PTs , Relays and Meters .

The weight of each Panel (including trolley) is appx 1.5 MT and panels will be shipped in sections of 2-3 panels . In addition , 1 no each FEB and BEB will be supplied with each panel

Sl no	Name of Board	No of Panel	Panel dimensions
1	Unit Board – 1CA	13 nos	11310 X 2692 X 2355
2	Unit Board – 1CB	11 nos	9570 X 2692 X 2355
3	Unit Board – 2CA	13 nos	11310 X 2692 X 2355
4	Unit Board – 2CB	11 nos	9570 X 2692 X 2355
5	Unit Board – 3CA	13 nos	11310 X 2692 X 2355
6	Unit Board – 3CB	11 nos	9570 X 2692 X 2355
7	Unit Board – 4CA	13 nos	11310 X 2692 X 2355

8	Unit Board – 4CB	11 nos	9570 X 2692 X 2355
9	Station Board – 0CA	13 nos	11310 X 2692 X 2355
10	Station Board – 0CB	13 nos	11310 X 2692 X 2355
11	Station Board – 0CC	13 nos	11310 X 2692 X 2355
12	Station Board – 0CD	12 nos	10440 X 2692 X 2355
13	Station Board – 0CE	14 nos	12180 X 2692 X 2355

D) 6.6 kV SPB :

6.6 kV Segregated Phase Busduct consists of Aluminums Bus Ducts and conductor supported on Steel structure and consists of all bolted connections . The list of SPB is as under :

Sl no	Name of Board	Length	Section
1	UAT-1 - 1CA / 1CB	65 M	1600 A / 800 A
2	UAT-2 - 2CA / 2CB	65 M	1600 A / 800 A
3	UAT-3 - 3CA / 3CB	65 M	1600 A / 800 A
4	UAT-4 - 4CA / 4CB	65 M	1600 A / 800 A
5	STN TRF -1 - 0CA / 0CB	125 M	2500A / 1250 A
6	STN TRF -2 - 0CC / 0CD	125 M	2500A / 1250 A
7	0CA – 1CA	12 M	800 A
8	0CA – 2CA	55 M	800 A
9	0CB – 1CB	12 M	800 A
10	0CB – 2CB	45 M	800 A
11	0CA – 0CC	120 M	2500 A
Sl no	Name of Board	Length	Section
12	0CB– 0CD	120 M	2500 A
13	0CC – 3CA	12 M	800 A
14	0CC – 4CA	55 M	800 A
15	0CD – 3CB	12 M	800 A
16	0CD – 4CB	45 M	800 A

Section Sizes and weights are as under :

SL NO	SPB Current rating	Enclosure Dimension(MM)	BusBar Dimensions (MM)	Weight per M (KG)
1	2500 A	1435 X 535 X 3.15 TK	2 X 127 X 48 X 8 TK	110
2	1250 A /	1285 X 485 X 3.15	2 X 101.6 X 42 X 6.68	110

	1600 A	TK	TK	
3	800 A	1285 X 485 X 3.15 TK	101.6 X 42 X 6.68 TK	100

LT SWITCHGEAR

The applicable panel are listed below :

<u>Sl No</u>	PANEL NAME	CODE	LENGTH (MM)	DEPTH (MM)	HEIGHT (MM)
1	415V UNIT PCC-1	1DA	10400	1200	2435
2	415V UNIT PCC-2	2DA	10400	1200	2435
3	415V UNIT PCC-3	3DA	10400	1200	2435
4	415V UNIT PCC-4	4DA	10400	1200	2435
5	415V DG PCC-1	0DG	9300	1200	2435
6	415V EMERGENCY MCC-1	1EA	10300	1200	2435
7	415V EMERGENCY MCC-2	2EA	9400	1200	2435
8	415V EMERGENCY MCC-3	3EA	10300	1200	2435
9	415V EMERGENCY MCC-4	4EA	9400	1200	2435
10	415V BOILER & BOILER VALVE MCC-1	1HA	11700	1200	2435
11	415V BOILER & BOILER VALVE MCC-2	2HA	12000	1200	2435
12	415V BOILER & BOILER VALVE MCC-3	3HA	11700	1200	2435
13	415V BOILER & BOILER VALVE MCC-4	4HA	12000	1200	2435
14	415V TURBINE & TURBINE VALVE MCC-1	1KA	19500	1200	2435
<u>Sl No</u>	PANEL NAME	CODE	LENGTH (MM)	DEPTH (MM)	HEIGHT (MM)
15	415V TURBINE & TURBINE VALVE MCC-2	2KA	19200	1200	2435
16	415V TURBINE & TURBINE VALVE MCC-3	3KA	19500	1200	2435
17	415V TURBINE & TURBINE VALVE MCC-4	4KA	19200	1200	2435
18	415V STATION PCC-1	0DA	8600	1200	2435
19	415V STATION PCC-2	0DB	8600	1200	2435
20	415V WORKSHOP DB	0SE	0		
21	415V FUEL OIL PMCC	0DE	9600	1200	2435
22	415V VANTILLATION MCC-1	0QA	11200	1200	2435

23	415V VANTILLATION MCC-2	0QB	11200	1200	2435
24	415V MISC. MCC-1	0QC	8500	1200	2435
25	415V MISC. MCC-2	0QD	8500	1200	2435
26	415V CONTROL ROOM A/C MCC	0QE	7200	1200	2435
27	415V SERVICE BUILDING A/C MCC	0QF	5400	1200	2435
28	415V ESP AREA MCC-1	1QA	1800	1200	2435
29	415V ESP AREA MCC-2	2QA	1800	1200	2435
30	415V CT PMCC-1	1DC	10300	1200	2435
31	415V CT PMCC-3	3DC	12200	1200	2435
32	415V CLWPH SWGR	0DC	13500	1200	2435
33	415V ETP MCC	0SA	8100	1200	2435
34	415V DM PLANT MCC	0SB	9000	1200	2435
35	415V PT PLANT MCC	0SC	6300	1200	2435
36	415V CHLORINATION PLANT MCC	0SG	7200	1200	2435
37	415V RAW WATER PH (PLANT SIDE) MCC	0SF	7200	1200	2435
38	415V RAW WATER PH (RIVER SIDE) MCC	0DD	6300	1200	2435
39	110V UNIT DC DB-1	1FA	10000	700	2435
40	110V UNIT DC DB-2	2FA	10000	700	2435
41	110V UNIT DC DB-3	3FA	10000	700	2435
42	110V UNIT DC DB-4	4FA	10000	700	2435
43	415V ADMIN BUILDING MCC	0QG	6300	1200	2435
44	SOOTBLOWER MCC PANEL	(4 NOS)	2500	1000	2400

E) NGR :

8 nos Nuetral Grounding Resistance are supplied for the UAT and Station Transformer . The NGR are structure mounted with structure having dimension 950 x 650 x 2000 mm and weight of appx 250 kg . The size of the NGR is 1818 x 685 x 1210 and weighs appx 400 kg . The NGR will be supplied in knocked down condition and is to be assembled at site .

F) LT SERVICE TRANSFORMERS :

36 nos Unit Service Transformers Transformer of ratings and details given below are envisaged . All Oil filled transformers will be partially filled at the time of dispatch

Sl No	Tranf Rating	Type	Nos	Oil Qty (Ltr)	Dimension (L X D X H) (MM)	Weight (KG)
1	1000 kVA , 6.6 kV / 433 V , Off CTS	Dry	8	-	2500 X 1700 X 2500	4500
	1600 KVA , 6.6 kV / 433 V , Off CTS	Dry	4	-	2800 X 2100 X 2700	7000
2	1000 kVA , 6.6 kV / 433 V , Off CTS	Oil	10	740	2510 X 1975 X 2710	3500
3	1600 kVA , 6.6 kV / 433 V , Off CTS	Oil	4	1050	2665 X 2630 X 2750	4700
4	2000 kVA , 6.6 kV / 433 V , Off CTS	Oil	2	1200	2750 X 3050 X 2550	5500
5	2500 kVA , 6.6 kV / 11.5 kV , Off CTS	Oil	2	1400	2545 X 3365 X 3955	6500
6	2500 kVA , 11 kV /6.9 kV, Off CTS	Oil	2	1400	2545 X 3365 X 3955	6500
7	630 kVA , 6.6 kV / 433 V , Off CTS	Oil	4	525	2200 X 1900 X 2200	2750

G) LT SEGREGATED PHASE BUSDUCT :

400 V , Al conductor , Al Alloy Enclosure Busduct connecting Service Transformers and the LT Switchgear . The bus duct is supplied in sections and is to be installed at site with loose supplied components Viz. structure, bus duct section, JBs, seal off bushings, split covers, , earthing strip, Jointing of various sections supplied shall be done by bolting as specified. The installation includes wiring / cabling of space heaters is to be done at site .

Busduct Rated 1600A – 10 Set (oil filled transformer)

2500A – 16 Set (12 dry type transformer+ 4 oil filled transformer)

3000A – 2 Set (oil filled transformer)

H) LOCAL PUSH BUTTON STATIONS AND STARTERS :

300 nos LPBs (average size - 200 mm x 200 mm x 200 mm) and 80 nos Local starters (average size - 200 mm x 200 mm x 200 mm)are envisaged

I) DC SYSTEM :

The DC System consists of 8 sets of 110 V Battery Chargers and 110 V Ni-Cd. Battery Bank .The Float cum Boost Battery Charger size is 2200*1000*2200 mm and there are 2 nos Fuse Boxes (1000 x 1000 mm) also supplied.Each Battery Bank consists of 80 cells of 645 AH and each Bank dimension is 2 x (1600 x 924) .

J) UPS SYSTEM :

The UPS System envisaged is as under

SL NO	NAME of equipment	Nos	PANELS	DIMENSIONS (EACH PANEL) (MM)		
				Length	Depth	Height
1	35 kVA UPS	1 set	UPS	3700	900	1870
		1 no	ACDB	2400	900	1850
		1 no	VOLTAGE STAB	900	900	1850
	KPH 120P	276 nos	BATTERY	1900	3200	
2	60 kVA UPS	4 sets	UPS	4900	900	1870
		4 no	ACDB-1	2400	900	1850
		4 no	ACDB -2	2400	900	1850
		4 no	VOLTAGE STAB	900	820	1600
	KPH 206	276 nos	BATTERY	3700	2760	
3	250 kVA UPS	1 set	UPS	8800	900	1870
		1 no	ACDB	3000	900	1850
		1 no	VOLTAGE STAB	2000	800	1850
			KPH 890	276 nos	BATTERY	3700

K) CONTROL AND RELAY PANELS :

The Dimensions of the Relay and Control Panels , Instrumentation of the Steam Turbine Generator , Auxillaries is as under :

SL NO	NAME of equipment	NO OF PANELS	DIMENSIONS (EACH PANEL) (MM)		
			Length	Depth	Height
1	U C P	4	1400	1000	2355
2	E C P	2	3656	1000	2355
3	GEN/ GT / UAT Protection Panel	4	3000	1000	2295
4	Station Trf Relay Panel	2	1000	1000	2295
5	AVR Panel	4	3050	750	2295
6	Unit Control Desk	8	6000	1000	776
7	DCS PANELS – SG , TG , BOP, HMI	232	750	750	2355
8	VIBRATION MONITORING SYSTEM PANEL	4	800	800	2415
9	FURNACE TEMP PROBE STARTER BOX	4	300	300	600
10	DC SCANNER AIR FAN STARTER BOX	4	900	375	1120
11	BHEL-VISION EWLI ASCERTOR CABINET	8	600	350	600
12	BHEL-VISION EWLI DISPLAY UNIT	8	99	81	194
13	FURNACE CCTV – LOCAL UNIT		1200	800	2415
14	LARGE VIDEO SCREEN	2	2030	1400	2834
15	MASTER CLOCK PANEL	4	900	600	2415
16	CCTV PANEL	4	1200	800	2415
17	SWAS – PRIMARY SAMPLING RACK	4	1500	600	2000
18	SWAS – PRIMARY SAMPLING RACK	4	600	600	2000
19	SWAS – WET PANEL	4	3000	1500	2300
20	SWAS DRY PANEL	4	1900	600	2300
21	SWAS - CHILLER	4	3040	1340	1800
22	SWAS – HOTWELL	8	400	300	400

	CONDUCTIVITY BOX				
23	DG AMF CONTROL PANEL	3	800	830	2100
24	DG MCC PANEL	1	10500	1200	2435
25	DG 24 V CHARGER	3	700	750	1230
26	DG 24 V BATTERY	3	1000	500	1000
27	DG Aux ACDB	3 sets	3400	650	2325

L) **INSTRUMENTATION:**

The total Instrumentation of the Boiler Steam Turbine Generator and associated Auxillaries comprises of panels , Instruments and Hook Up materials as specified below . The instruments of the BOP packages are listed in the respective Packages

SI No	Name	UNIT	QTY
1	Pressure / Temp / Level Gauges	NOS	1862
2	Pressure / Temp / Level Switches	NOS	548
3	Pressure / Temp/ Level Transmitters	NOS	966
4	Analysers	NOS	92
5	Flow meters	NOS	8
SI No	Name	UNIT	QTY
6	DWLI / EWLI	NOS	16
7	RTDs / Thermocouples	NOS	733
8	MTM Thermocouples	NOS	292
9	Bearing thermo Elements	NOS	124
10	Opacity Monitor with accesories	NOS	4
11	Relative / Absolute Vibration Sensors (with proximeters)	NOS	168
12	Shaft Expansion Sensors (with proximeters)	NOS	16
13	Axial Shift Sensors (with proximeters)	NOS	12

14	Speed Probes	NOS	24
15	Calibration of SOV operated Trip Valves	NOS	50
16	Callibration / commissioning of regulating Control Valves with positioners / LS / PFT	NOS	80
17	Commissioning of motorised actuators	NOS	400
18	Flame Scanner Assembly	NOS	48
19	Pnuematic Power Cylinders with PFT (Boiler)	NOS	192
20	Limit Switches /Heavy duty Limit Switches (for BTPS)	NOS	228
21	Air Filter Regulators + I / P Convertor	NOS	72
22	Flexible hoses - $\frac{1}{4}$ " (2 meter long) , 1" (3 meter long)	NOS	48
23	Temperature / controller	NOS	40
24	Position Transmitters	NOS	50
25	Junction Boxes – 6/12/24/36/48way	NOS	248
26	Junction Boxes – 64/72/96 way	NOS	321
27	SS / Copper Tubing ($\frac{1}{4}$ " , $\frac{1}{2}$ ")	RM	2800
28	1/2 , 3/4 " CS impulse Pipe	RM	24,000
SI No	Name	UNIT	QTY
29	1/2 , 3/4 " AS impulse Pipe	RM	1800
30	3/4",1/2 " SS impulse Pipe	RM	5160
31	Special Pipes – Cr- Mo	RM	2000
32	Gi Pipe – $\frac{1}{2}$ " , $\frac{3}{4}$ " , 1" , 1 $\frac{1}{2}$ "	RM	3000
33	LOCAL INSTRUMENT RACK (LIR) TYPE A/B	NOS	171
34	LOCAL INSTRUMENT PANEL (LIE) TYPE A/B	NOS	56
35	PC set with monitor / keyboard / power supply unit	NOS	40

36	UCB Loose Supplied Inserts	NOS	58
----	----------------------------	-----	----

The wiring for the installed instruments to the Junction Boxes also have to be done . In addition , certain mechanical equipments will be installed on the skids at site for which the wiring connections will have to be completed .

The Instrumentation scope for the ALL Mechanical Packages are covered in their respective Packages .

M) COMMUNICATION SYSTEM:

The Communication System consists of the following systems:

- a) 500 line **Telephone Exchange** and the communication network over the entire plant with about 400 Desk Top telephones , 20 nos Weather and Dust Proof Tel Kisoks to be installed Other than the Telephone Exchange (appx size 750 x 750 x 2300 mm) , PC based Operator Console and a 48 V Battery and Charger system, the system consists of the cable network and the other equipments eg Junction Boxes , handsets etc.
- b) **PA System** : The system consists of 3 nos operator console , cabinet for recorder , amplifier etc and approx. 20 loudspeakers in the field . The cabinet size is 750 x 750 x 1500 mm
- c) **CCTV System** : This consists of Desk Top Monitor , PC Keyboard besides the cabinet for the matrix switcher , recorder , multiplexer etc .The cabinet size is 750 x 750 x 1500 mm . 16 cameras are to be installed in the plant along with the power supplies
- d) **Master Clock System** : The system consists of the Main Clock Panel along with about 20 clocks to me mounted in the plant area . GPS antenna is also envisaged .

N) UNDER GROUND AND OVER GROUND EARTHING :

The Over ground and Underground Earthing is by Stranded Bare Tinned / Untinned Conductor . The total quantity of Bare Conductor of various sizes being supplied is appx 27.40 KM . The conductors are to be joined by Thermo-welding , for which sufficient kits will be supplied .

For underground earthing , while the major civil works will be carried out by a different agency , minor civil works will have to be carried out by the contractor . Further , approx. 220 Copper Clad Steel Earthing electrodes are to be installed . **The installation of the Electrode , all electrical connections and the civil works are to be done by the Contractor.**

O) STATION LIGHTING :

The Station Lighting System provided lighting for the entire Power Station – both indoors and outdoors . The System broadly consists of the following sub-systems :

i. Lighting Distribution Boards (AC + DC)	--	11 nos
ii. Lighting Panels (AC + DC)	--	86 nos
iii. Lighting Fixtures (AC + DC)	--	2600 nos
iv. Receptacles	--	425 nos
v. Street Lighting Poles	--	225 nos
vi. Emergency Lighting Units	--	60 nos
vii. Ceiling Fans	--	10 nos
viii. Switch Board for Local Control	--	140 nos
ix. GI Conduit	--	45 KM
x. Wires (1 core)	--	95 KM
xi. Earthing Wire	--	50 KM
xii. Structural steel	--	25 MT

P) STATION CABLING :

The Cabling System consists of Cable Tray Installation , Cable Laying and Cable Termination . The brief description of the systems is as under :

a. CABLE TRAYS (MAIN PLANT):

The cable Tray system consists of Boltable Cable Support system . The total quantity of Single and Double Channel is 10000 m and 1500 m respectively . Fixing of the Base Plates to the concrete is by Anchor Bolts (M10) and to steel structures by Clamps and Fittings .

The total quantity of trays envisaged is 31.7 kms and is of Ladder Type . Also included are various bends , reducers and Tees .

For Instrumentation system , 30 km of branch trays is envisaged .

For the EHV System trays , refer to EHV section

Contractor shall erect, test, commission all the equipment, cabinets, panels, instruments etc. as per sequence prescribed by BHEL Engineer at site. The sequence of erection / commissioning methodology will be decided by the BHEL Engineer depending upon the availability of materials / work fronts etc. No claim for extra payment from the contractor will be entertained on the grounds of deviation from the methods of erection / commissioning adopted in erection / commissioning of similar jobs elsewhere or for any reasons whatsoever.

- 2.6 The customer NEC may depute their representative for checking and supervision of important stages of work. The contractor shall be required to provide all facilities for inspection of works, without any cost implications to the Engineer. Any defect in quality of work or deviations from drawings / specifications pointed out during such inspection shall be made good by the contractor in the same way if pointed out by the Engineer, without any cost implication to BHEL.

- 2.7 Contractor shall plan and transport equipment / components from storage yard sheds to erection site and erect them in such a manner and in a sequence that material accumulation at site should not lead to congestion. Contractor shall plan activities considering plying of his vehicles on ring road also. Materials shall be stacked neatly, preserved and stored in the contractor's shed and work areas in an orderly manner. If required, the contractor shall arrange shifting of surplus material expeditiously failing which the same will be arranged by BHEL at contractor's risk and cost.

2.8 FINISH PAINTING

- 2.8.1 All equipment within the scope of these specifications shall be received duly painted. However during storage and handling the same may get peeled off / damaged / deteriorate. All such surfaces are to be thoroughly cleaned and to be touch up painted with suitable approved primer / finish paint matching with shop paint / approved final colour. Besides above two coats of approved primer paint and at least two coats of approved finish paint to get the desired dry film thickness, is to be applied on various loose equipment, all impulse lines and structures fabricated and erected at site. **All paints, tools and other consumables including scaffolding materials required for painting shall be arranged and provided by contractor within the quoted rates. Paint and other materials so purchased shall be approved by BHEL and painting should be as per colour scheme and quality approved / specified by Engineer.** Valid Test certificate for the paint so supplied shall be made available before use of the same on work. The contractor shall provide legend on equipment in size specified by Engineer. Letter writing shall be done in Hindi / English or in both language. The printer have to under go test and only qualified painters will be allowed to work.
- 2.8.2 Certain equipment shall require spray painting (touch up). The contractor shall make arrangements of the required equipment for spray painting of such equipment at his own cost. Spray painting at the job site shall be permitted only at times and locations approved by the owner / Engineer.
-

Chapter - III: Facilities in the scope of Contractor/BHEL

3.0 FACILITIES IN THE SCOPE OF CONTRACTOR/BHEL

S.No.	Description	Scope /to be taken care by		Remarks
		BHEL	CONTRACTOR	
1.1.0	ESTABLISHMENT			
1.1.1	FOR CONSTRUCTION PURPOSE			
A.	Open space for office	YES		Limited space. (Free)
B.	Open space for storage	YES		Limited space.(Free)
1.1.2	FOR LABOUR COLONY			
A	Open space	YES		Limited space.(Free)
1.2.0	ELECTRICITY			
1.2.1.	Electricity for construction purposes (chargeable/free)			Free
1.2.1.1	Single point source	YES		
1.2.1.2	Further distribution for the work to be done which include supply of materials & execution		YES	
1.2.2	Electricity for the office, stores , camp etc of the bidder which include:			
1.2.2.1	Distribution from single point including supply of materials & service		YES	
1.2.2.2	Supply, Installation & connection of material of		YES	

	energy meter including operation & maintenance			
1.2.2.3	Duties & deposits including statutory clearances for above		YES	
1.2.2.4	Demobilization of the facilities after completion of works		YES	
1.2.2.5	Electricity for living accommodation of the bidder's Staff, engineers, supervisors etc. on the above lines		YES	
1.3.0	WATER SUPPLY			
1.3.1	FOR CONSTRUCTION & LABOUR COLONY:			
1.3.1.1	Making the water available at single point	YES		
1.3.1.2	Further distribution as per the requirement of work including supply of materials & execution		YES	
1.4.0	LIGHTING			
1.4.1	For construction work (supply of all materials) 1. At office storage area 2. At preassembly area 3. At construction site/area		YES	
1.4.2	For construction work (execution of lighting work/arrangements) 1. At office storage area 2. At preassembly area 3. At construction site/area		YES	
	Providing the necessary consumables like bulbs, Switches, etc during the course of construction		YES	
1.5.0	Communications facilities for site operations			

	of the bidder			
	Telephone, fax , internet ,intranet, email etc.		YES	
1.6.0	COMPRESSED AIR SUPPLY			
1.6.1	Supply of compressor and all other equipments required for compressor & compressed air system including pipes, valves, storage system etc.		YES	For erection purposes
1.6.2	Installation of the above system and operation & maintenance of the same		YES	
1.6.3	Supply of all the consumables for the above system during the contract period.		YES	
	ERECTION FACILITIES			
2.1.1	Providing erection drawings for all the Equipments covered under this scope	YES		
2.1.2	Drawings for construction method	YES	YES	In consultation with BHEL
2.1.3	As-built-drawings-where ever deviations Observed & executed and also based on Decisions taken at site		YES	do
2.1.4	Shipping lists etc for reference & planning the activities	YES	YES	do
2.1.5	Preparation of site erection schedules and other input requirements		YES	do
2.1.6	Review of performance & revision of site erection schedules in order to achieve the end dates & commitments	YES	YES	do
2.1.7	Weekly erection schedule based on Sl. No.2.1.5		YES	do
2.1.8	Daily erection/work plan based on Sl. No.2.1.7		YES	do
2.1.9	Periodic visit of senior official of bidder to site to review the progress so that works are completed		YES	

	as per schedule. It is suggested this review by the senior official of the bidder should be done once in every two month			
2.1.10	Preparation of preassembly bay		YES	

- 3.1** BHEL will not be responsible for any loss or damage to the contractor's equipment as a result of variation in voltage or frequency or interruptions in power supply.
- 3.2** The Contractor shall be responsible for providing all necessary facilities like residential accommodation, transport, electricity, water, medical facilities etc. at his own cost as required under various labour laws and statutory rules and regulations framed there under to the personnel employed by him.
- 3.3** Provision of distribution lines of both electrical power and water from the central points to the required place with proper distribution boards observing the safety rules laid down by the electrical authorities of the state shall be done by the contractor, supplying all the materials like cables, distribution board, switch boards, TPN, CBS, ELCBS/ MCCBS/ Copper / Brass clamps, copper conductor, change over switches pipes etc. at his own cost. If any failure is caused in supply of the power and water, it is the responsibility of the contractor to make alternate arrangements at his cost. The contractor shall adjust his working shifts / hours accordingly and deploy additional manpower if necessary so as to achieve the targets. **The energy meter to be installed by the contractor & shall be tested at bidder's cost.**
- 3.4** The contractor while drawing construction power supply from Distribution Board should strictly adhere to following points.
- All electrical installations should be as per Indian Electricity rules.
 - All distribution Boards installed by the contractor should be constructed with fireproof materials viz. Steel frames, Bakelite sheets etc.
 - Connection for single phase should be taken from phase and neutral. Nowhere the connection should be taken with earth as neutral.
 - All electrical connections should be made through connectors, nuts and bolts, switches, plug and sockets. Loose connections or hooking up of wires shall not be permitted.
 - Contractor have to make their own earthing arrangement for their equipment / DB earthing.
 - All electrical equipment / tools and plants should be properly earthed. DBs to be earthed diagonally opposite at two points.
 - Contractor should use "MCCB" and "ELCB" either on incoming or outgoing connections to the DBs.
 - Contractor should ensure that all the CBs / TPNs/ Fuses/ MCCB / ELCB cables etc. should be of adequate rating/ capacity.

- i) For permission of supply connections contractor has to submit a test report of their installations with a single line diagram of connected/ proposed loads.
- 3.5** ELCB will be tested once in a week or as directed by BHEL by actually simulating the earth leakage for all installations and the same shall be recorded in the logbook to be maintained by the contractor.
- 3.6** In case of power cuts / load shedding no compensation for idle labour or extension of time for completion of work will be given to contractor.
- 3.7** On completion of work or as and when required by BHEL, all the temporary buildings, structures, pipe lines, cables etc. shall be dismantled and levelled and debris shall be removed, as per instructions of BHEL, by the contractor at his cost. In the event of his failure to do so, the Engineer will get it done and expanses incurred shall be recovered from the contractor along with prevailing overheads. The decision of BHEL Engineer in this regard shall be final.
- 3.8** Compressor required capacity for construction purposes shall be arranged by Contractor.
- 3.9** **Contractor should install a PC ALONG WITH MODEM to connect with our server (LAN) AT SITE.**

Chapter - IV: T&Ps and MMEs to be deployed by Contractor**T&P AND MMD DEPLOYED BY CONTRACTOR****INDICATIVE LIST OF T & P TO BE ARRANGED BY THE CONTRACTOR FOR ELECTRICAL WORKS**

SL NO	EQUIPMENT	QUANTITY
1.	75 MT Crane	1 no
2.	18 / 20 MT Crane	2 nos
3.	12 / 15 MT Hydra	3 nos
4.	100 T Hydraulic Jacks suitable for handling of Power Transformers	4 nos
5.	10,000 litre Oil Tank	2 no
6.	6000 LPH Hi- Vacuum Oil Filter Machine suitable for HT Transformers	1 no
7.	High Vacuum Pump suitable for HT Transformers	1 no
8.	1000 LPH Hi- Vacuum Oil Filter Machine suitable for HT Transformers	1no
9.	MIG / TIG Welding Machine	3 nos
10.	Welding Transformers	APR
11.	Radiography Setup	APR
12.	Calibrated Torque wrenches for Bus duct / Panel application	3 nos
13.	Pedestal mounted Drill Machine (upto 36 mm)	3 nos
14.	Pull Lifts & Ratchet hoist	APR
15.	Hydraulic crimping tool	2 no
16.	Hand crimping tools	Adequate numbers
17.	Electrical Tool Box	Adequate numbers
18.	Cable Drum Winch (SIZE WISE)	3 no
19.	Portable Compressor	2 nos
20.	Air Compressor for Maxi Gun	1 no
21.	Special Tools for EHV Cables	set
22.	Brazing Kit	set
23.	Electrical Connectors of various sizes	Adequate numbers.

**TENTATIVE LIST OF MAJOR ELECTRICAL TESTING INSTRUMENTS / EQUIPMENT
ARRANGED BY CONTRACTOR AT HIS OWN COST.**

SL. No.	DESCRIPTION	RANGE	ACCURAC	QTY
1.	Motorised Megger 2.5 / 5 kV			3 no
2.	500 V / 1000V, (Hand operated) megger			5 no
3.	Transformer Oil Testing Kit (Motor operated)	0-100 KV		1 no
4.	Digital Multimeters			15 no
5.	Primary Injection Kit			2 no
6.	Secondary Injection Kit			2 no
7.	Relay Testing Kit			2 no
8.	Tong Testers			Range Wise
9.	HV Test Kit	0-50 kV		1 no
10.	Micro ohm meter with 100Amps DC Source			1 no
11.	Motor checker , TTR			1 no each
12.	KELVIN DOUBLE BRIDGE			1 no
13.	PPM Measuring Kit			1 no
14.	Analog Multimeters			5 no
15.	Single / three phase variac			2 no each
16.	Decade Box / Rheostat			Range Wise
17.	Phase Sequence Indicator			3 no
18.	Dead Weight Tester	0-600Kg/cm ²	LC-0.5Kg/cm ²	2 no
19.	Comparison test set	0-4 k g/cm ² 0-6 Kg/cm ² 0-10kg/cm ² 0-25Kg/cm ² 0-60Kg/cm ² 0-250 Kg/cm ²	+0.25%Lc-0.25	set
20.	Variable DC regulated supply	0-30V DC	0.2%	1 no

21	Oil bath with thermostat Stirrer and sub-standard Glass Thermometers in Multiple ranges	0-300 Degree Cel.		2 no
22	Glass U tube mercury mano-meter with standard steel Scale having leveling arrangement	0-760 mm		2 no
23	mA/mV source with Digital display	0-200 mA/200mV		2 no

NOTES:

1	The above list of testing instruments/equipment required for testing / commissioning only for guidance to contractor and not complete. Any other / additional instruments / equipment required for timely and satisfactory completion of job will be arranged by contractor at his own cost.
2	Contractor must re-ascertain / recheck range and accuracy of each IMTE from BHEL Engineer well in advance before arranging calibration / deployment.
3	Other terms and conditions regarding above items shall be as per clause no. 38 (plants / testing & measuring instruments).

APR-As per requirement*NOTES:**

- The above list specifies only major T&P/MMD (may not be complete to be deployed by the contractor. All additional/ other tools and plants which are required for satisfactory & timely completion of work shall also be deployed by the contractor within finally accepted rate/ price..**
- If works gets delayed due to non-availability of T&P and MMD, BHEL reserves the right to get work done at the risk & cost of contractor without prejudice to right of BHEL as in GCC
- Contractor must re-ascertain/ recheck range and accuracy of each IMTE from BHEL Engineer well in advance before arranging calibration/ deployment.
- Other terms and conditions regarding above items shall be as per T&P clause in SCC

Chapter - V: T&P AND MMD DEPLOYED BY BHEL ON SHARING BASIS

LIST OF T&P and MMD being provided by BHEL for use of contractor free of hire charges on sharing basis.

S.NO.	EQUIPMENT	CAPACITY	QTY
T&Ps			
24.	EOT Crane (in T.G. hall)	125 T / 25T	1 No.

5.0 T&P AND MMD DEPLOYED BY BHEL ON SHARING BASIS

NIL

NOTES:

- Cl.4.2.2.16 c. of SCC shall be read as** day-to-day upkeep and running maintenance like filling topping up of lubricants, changing filters, etc including repair of self starter, batteries and dynamo of these cranes shall be the responsibility of the contractor. If on checking it is found that the same is not followed, BHEL will exercise its right to get the job/works done at the risk and cost of contractor. BHEL may also provided cranes through crane hiring agencies in which case the day-to-day upkeep and running maintenance shall be excluded from scope of contractor.
- The Cranes will be provided as per requirement and for special package handling only at the discretion of the BHEL Engineer**
- Other terms and conditions regarding above items shall be as per T&P clause in SCC

Chapter - VI: TIME SCHEDULE

6.0 TIME SCHEDULE

6.1 The contractor is required to commence the work within 7 days from the date of issue of LOI unless BHEL decides to fix any other later date. However, the actual date of start of work, to fix up the zero date of the contract, will be certified by BHEL Engineer after adequate mobilisation of manpower and T&Ps by the contractor.

6.2 Entire work as detailed in the tender specifications shall be completed within **8 months** from the Zero date as per programme/ milestones indicated by BHEL Engineer. Contractor has to mobilise adequate resources to meet BHEL's commitments to their customer as indicated from time to time.

In case due to reasons not attributable to the contractor, the work gets delayed and additional manpower / resources have to be mobilized so as to expedite the work to meet various milestones, same shall be done within the quoted rates as per Rate Schedule, at no extra cost to BHEL. In the event the contractor fails to respond to these requirements, BHEL shall take appropriate actions to meet customer's commitments in line with the provisions of General Conditions of Contract.

6.3 The various milestones dates to be achieved under this tender is as :

SN	MAJOR MILESTONE	COMPLETI
1	ELECTRICAL START	Start of work
2	COMPLETION OF ELECTRICALSYSTEM FOR START UP POWER	4 weeks
3	COMPLETION OF ELECTRICALSYSTEM FOR START UP WATER SYSTEM	8 weeks
4	COMPLETION OF ELECTRICALSYSTEM FOR U-4 BOILER LIGHT UP	9 weeks
5	COMPLETION OF ELECTRICALSYSTEM FOR U-4 SYNCHRONISATION	14 weeks
6	COMPLETION OF ELECTRICALSYSTEM FOR U-3 LIGHT UP	12 weeks
7	COMPLETION OF ELECTRICALSYSTEM FOR U-3 SYNCHRONISATION	16 weeks
8	COMPLETION OF ELECTRICALSYSTEM FOR U-2 LIGHT UP	16 weeks
9	COMPLETION OF ELECTRICALSYSTEM FOR U-2 SYNCHRONISATION	20 weeks
10	COMPLETION OF ELECTRICALSYSTEM FOR U-1 LIGHT UP	20 weeks
10	COMPLETION OF ELECTRICAL SYSTEM FOR U-1 SYNCHRONISATION	24 weeks

Note:

In order to meet above schedule in general, and any other intermediate targets set, to meet customer/ project schedule requirements, contractor shall arrange & augment all necessary resources from time to time on the instructions of BHEL. This project is a fast track project. Customer is making all out efforts to advance the project schedule. In case the civil inputs are advanced by customer, Piping completion may have to be advanced to suit project requirement. No extra payment whatsoever shall be paid on this account.

- 6.4 The contractor has to ensure that work is completed in all respects leaving no pending points. However the punch list/ pending points, which are possible to be attended at site, shall be fully liquidated within two months from successful trial operation of the unit.
- 6.5 The work under the scope of this contract is deemed to be complete in all respects, only when the contractor has discharged all the responsibilities laid down in the contract. The decision of BHEL on completion date shall be final and binding on the contractor.

Chapter - VII: TERMS OF PAYMENT

7.0 TERMS OF PAYMENT

- 7.1 The 'Engineer' will certify regarding the actual work executed in the measurement books and bills, which shall be accepted by the contractor in measurement book.
- 7.2 Contractor shall submit bills for the work completed under the specification, once in a month detailing work done during the month. The format for billing shall be approved by BHEL before raising invoices.
- 7.3 Subject to any deduction, which BHEL may be authorised to make under the contract, the contractor on the certificate of the Engineer at site be entitled for payment as explained hereunder.

7.4 MODE OF PAYMENT:

- (a) Payments shall be made by cheque or bank transfer.
- (b) BHEL Engineer shall certify regarding the actual work executed in the measurement books in line with approved billing schedule. The contractor shall submit progressive bills for the works completed in line with approved billing schedule, once in a month. The Contractor shall be paid monthly running bill to a maximum of 95% of the value of the work actually executed on site provided the work has been executed to the satisfaction of the Engineer.
- (c) Any certificate relating to the work done may be modified by any subsequent interim certificates or by the final certificates and no certificate of the Engineer supporting an advance payment shall by itself be conclusive evidence that any work or materials to which it relates are in accordance with the contract.

(d) Currency of Payment and Exchange Rate

(i) Payment IN Euros

85% of the Total Contract Price will be paid in Euros subject to Reserve Bank of India (RBI) guidelines.

Bidder has to ensure that total imports (CIF Value) from 3rd country i.e. steel (wherever required), cement and other materials which is going directly from the 3rd Country to Kosti Site in Sudan shall not be more than 50% of the Total Contract Price to ensure that total Imports from the 3rd country going directly to Sudan Site shall meet the RBI guidelines.

(ii) Local Currency Payment

Balance 15% of the Total Contract Price will be paid in local currency (i.e. Sudanese Pounds) for the supplies and services carried out in Sudan.

Exchange rate from one currency to another applicable for the entire period of contract including extended period, if any, shall be the rate prevailing on the date

of opening of technical bid (Part-I). For conversion from EURO to Sudanese Pounds, buying rate of EURO as available on the website of Bank Of Sudan (www.bankofsudan.org) on the date of opening of technical bids (Part-I), shall be considered and will be applicable for the entire period of Contract including extended period, if any. If the date happens to be a holiday, the exchange rate of next working day will be considered

7.5 Advance Payment

5% of the contract value shall be paid as interest bearing advance shall be paid as per Clause No. 2.13 of GCC.

7.6. PROGRESSIVE PAYMENT ON PRORATA BASIS PAYMENT TERMS :

7.6.1 : 95 % of contract value payable on fulfilment of following conditions:

(A) EQUIPMENT PACKAGE

(AA) For Items under E+C :

For Equipment / items such as Panels, , JB, impulse pipe, tubing etc. where no calibration is required

- a) 55 % of item rate shall be payable on erection \ installation /cable laying
- b) 25 % of item rate on final alignment, welding, clamping, termination etc.
- c) 10% of item rate on testing, pre-commissioning, charging etc.
- d) 5% of item rate on pending point clearance

(AB) For equipment/items where calibration and testing is required.

- a) 30% of item rate on calibration and testing
- b) 30% of item rate on erection, installation alignment and termination wherever involved.
- c) 20% of item rate on individual device loop checking/hydro test/ charging of installation and panels.
- d) 10% of item rate on system loop checks, pre-commissioning checks by simulation/ field calibration or with actual system operation.
- e) 5% of item rate on pending points clearance

In case of items under BE+C , the erection part of the payment will be released

(B) CABLING SYSTEM**95% of Unit Rates for Item of rate schedule:**

Erection of Cable Tray / Laying Of Cable	60% / 45 %
Final Clearance of Trays / Termination of Cable.	30% / 30 %
Testing, pre-commissioning , charging of Cables	0% / 15 %
Cable Tray Covering / Cable Dressing , Tagging Comple	5% / 5 %

7.6.2 : 5 % of contract value will be payable on achieving the milestones mentioned below

- | | |
|--|-------------|
| i. Readiness of Start Up Power | : 0.5 % |
| ii. Readiness of Water System start Up | : 0.5 % |
| iii. Readiness for Unit BLU | : 4 x 0.5 % |
| iv. Readiness for Unit Synchronisation | : 4 x 0.5 % |

Note:

1. If the commissioning activities could not be carried out due to no fault of contractor, BHEL Site in-charge, at his discretion, after recording reasons for exercising such option, can split and release payment up to 50% of milestone payment on completion of work, to the extent possible, required for carrying out that particular milestone/ commissioning activity.
2. Recovery & refund of retention amount shall be as per clause No. 2.22., 2.23.2 & 2.24.2 of GCC.

Chapter - VIII: TAXES, DUTIES, LEVIES

8.0 TAXES, DUTIES, LEVIES

The bidder shall quote their rates inclusive of all taxes/duties applicable for this work, except otherwise expressly set forth herein or under clause no. 8.3.2 of TCC given below. The Contractor shall be responsible for paying any and all Taxes/Duties assessed on the Contractor, its Sub-Contractor and Suppliers or their respective employees

8.1 LOCAL TAXES AT SUDAN

8.1.1 Customer shall obtain from the competent Sudanese Authorities all taxes exemption or pay on behalf of Contractor relating to the project including Business Profit Tax and Value Added Tax etc. However, Income Tax for personnel shall be borne by the Contractor.

8.1.2 Taxes as required to be deducted at source as per Local Sudanese Laws / Indian Law (applicable in case of only those contractors having their office in India), if any, at prevailing rates shall be deducted on gross invoice value from the running bills unless Exemption Certificate from appropriate Tax Authority is furnished.

8.2 CUSTOM DUTY & CUSTOM CLERANCE

8.2.1 Custom duty and demurrage occurred in Port Sudan and Khartoum airport for all equipment, facilities and materials imported by the Contractor for the Project shall be paid by BHEL's Customer (M/s NEC). The contractor shall furnish list of all such items including their temporary imported equipments(temporary imported equipments to be defined and listed clearly) well in advance. However, custom duty , if any, paid by the Contractor for any reason whatsoever shall not be reimbursed.

8.2.2 BHEL or its Customer(NEC) shall be responsible for the custom clearance agency to clear out the Equipment, tools, materials imported (Plant Materials) and Contractor's equipment and vehicles temporarily imported for the Project as per Procedure given below at 8.2.3. However, the Contractor shall take all actions for chasing/follow up and bear all expenditure on his own for the same. A bank guarantee shall be issued by the Contractor, if necessary according to the custom authority for custom clearance. The bidders to assume amount of BG equivalent to custom duty pertaining to their equipments/T&Ps brought by them on repatriable basis. The Contractor shall submit all relevant dispatch/shipment documents to Project Coordinator- Sudan, BHEL, PSNR, NOIDA(UP)-India / Construction Manager, BHEL Site, Kosti TPP. The Contractor shall take delivery of materials at Port of Sudan or at Khartoum airport and responsibility of handling (unloading/loading etc) and its transportation to Kosti Power Plant shall be of Contractor at their own cost. Payment of any Que/Quay dues at Port, will be the responsibility of the Contractor. "Que/Quay dues" are applicable for delay in

unloading at the port, the rate will be as applicable.

For BG of the custom duty if necessary may be in EURO. BG should be issued preferably through any of the Schedule Banks in India.

8.2.3 CUSTOMS CLEARANCE PROCEDURE

- (A) For all the supplies/ dispatches related to this Project, the consignee will be NEC, SUDAN and the name of supplier to be mentioned either as "BHEL" or "on account of BHEL". The Contractor will submit original + 7 copies of despatch documents to BHEL /BHEL's bankers after despatch of consignment from India. BHEL bankers in India will forward these documents after necessary endorsement to Bank of Sudan in Sudan. Bank of Sudan after stamping will send these original documents to NEC, Khartoum(BHEL's Customer).
- (B) The Contractor shall submit scanned / fax copies of documents such as invoice, packing list, certificate for country of origin, insurance, bill of landing etc to BHEL/ NEC, Khartoum after despatch of consignment from India.
- (C) NEC (BHEL's customer) at Khartoum will process the document and obtain certification from Sudan customs / Government for zero custom duty and payment exemption for all other applicable taxes, duties, levies etc.
- (D) NEC (BHEL's customer) at Khartoum shall forward these documents with certification to NEC-Port Sudan.
- (E) NEC (BHEL's customer) at Port Sudan after necessary clearance permit will hand over the documents to the Contractor through BHEL's representative/Transporter for taking delivery and transport to power plant site at Kosti. The Contractor will sign that he has received the consignment

8.2.4 In case the temporary imported equipment is not defined and listed by the Contractor, the responsibility of custom clearance and payment of custom duty/taxes shall lie with them. When it is produced at any time it shall be considered as part of this Contract (i.e it will be considered as BHEL's Customer property)

8.2.5 Any demurrage incurred due to the reason of the Contractor's delay in unloading at the Port Sudan or airport shall be the Contractor's responsibility. Any other demurrage incurred during custom clearance for reasons other than those attributable to BHEL or its Customer (M/s NEC), shall also be borne by the Contractor

8.2.6 For all the items like T&Ps, Erection equipments, consumables, establishment items etc. to be exported by the Contractor to Sudan on repatriable basis, the Contractor shall furnish list and value of such items to BHEL prior to dispatch. The Contractor shall also give an undertaking to BHEL prior to dispatch declaring these

items as returnable/consumable.

8.3 COMPLIANCE TO REGULATIONS AND BYELAWS :

8.3.1 The Contractor shall conform to the provisions of any statute relating to the work and regulations and bylaws of any local authority and of any water and lighting Companies or Undertaking with whose system the work is proposed to be connected. He shall, before making any variation from the drawings or the specifications that may be necessitated for such connections give the Engineer, notice specifying the variation proposed to be made and the reasons therefore and shall not carryout any such variation until he has received instructions from the Engineer in respect thereof. The Contractor shall be bound to give all notices required by statute, regulations or bye-laws as aforesaid and to pay all fees and taxes payable to any authority in respect thereof.

8.3.2 The Contract shall be governed by the applicable Laws of Sudan Govt. and the bidders to ensure considering latest Sudanese Laws before quoting. If during Contract execution there may be any Change in such Law which might cause additional or reduced cost to the Contractor in the execution of the works, such additional or reduced cost, if fully justified and approved by BHEL or its Customer (M/s NEC), shall be paid to 'OR' recovered from the Contractor, as the case may be.

8.3.3 The Contractor shall ensure conformance in all respects with the provisions of all state and local laws, regulations or other laws in force in Sudan or elsewhere including all regulations and by-laws of any local or other duly constituted authority within Sudan or elsewhere which may be applicable to the performance of the Contract and the rules and regulations of all public bodies and companies whose property or rights are affected or may be affected in any way by the Works or any Temporary Works (which are herein referred to as "Laws"), and shall give all notices and pay all fees required to be given or paid thereby and shall keep BHEL and/or its Customer (NEC) indemnified against all penalties and liability of any kind for breach of any of the same.

The Contractor shall comply with all applicable Sudan Government's safety and sanitary laws, transportation rules, regulations and ordinances, as well as the established safety rules and practices of BHEL's Customer (NEC). The Contractor shall also provide insurance cover for his workmen throughout the contract period, under prevailing local Laws.

Chapter - IX: Others

9.0 OTHERS

- I. It shall be the responsibility of the Contractor to pay salaries and other benefits to its employees/personnel engaged by it as per the agreement with them, and in keeping in line with the local laws in Sudan. The Contractor shall submit to Construction Manager, BHEL Site, Kosti, Sudan regularly, the details/statement of wages paid to its workers in India/back home, besides wages paid in Sudan.**
- II. All traveling and transportation expenses including air fares etc shall be borne by the Contractor for all his employees. The Contractor shall also bear air fare and other expenses for those employees sent back to their place on account of misconduct, disobedience, improper behavior, sickness, unsatisfactory work or any other reason whatsoever.**
- III. Contractor shall arrange passports for all his staff and labour. BHEL will assist Contractor for issue of visas including multi-entry visas and other permits as per requirement for the job. However, the Contractor shall arrange for attestation of certificates and other documents required for travel arrangements, medical tests as applicable and comply with other formalities. All expenses for all these activities will be borne by the Contractor.**
- IV. The delay in obtaining the passports and other travel documents or compliance with the various formalities for the deputation of the contractor's personnel shall not absolve the contractor from his obligations under the Contract including completion of the work strictly in accordance with the time schedule.**
- V. The Contractor shall in all dealings with persons in his employment have due regard to all recognised festivals, days of rest/weekly off, and religious or other customs in Sudan and shall make special arrangements whenever the exigencies of the construction program demand that work shall proceed during such festivals and days of rest**
- VI. The Contractor shall plan and schedule the activities on Site such that they happen strictly during the specified working hours.**
- VII. The Contractor shall not otherwise than in accordance with Sudanese State Laws import, sell, give, barter, or otherwise dispose of any alcoholic liquor or drugs or any arms or ammunition to any person or persons whatsoever, nor permit or suffer any such importation, sale, gift, barter, or other disposal by his employees. The Contractor shall submit a request to BHEL for issue of an identity card to each and every person employed at the Site by him along with passport size photographs and other documents as may be required for the purpose. No person will be allowed to enter the project premises without an identity card. All identity cards will be surrendered by the Contractor to BHEL in respect of each person on completion of assignment of such person.**
- VIII. The Contractor shall deliver to BHEL before 10:00 hrs on each first working day of the week; a report in detail, in such form as BHEL or its Customer (M/s NEC) may prescribe, showing the supervisory staff and the numbers of the several classes of labour, from time to time employed by the Contractor on the Site. The Contractor shall at all times take all requisite precautions and use his best endeavors to prevent any riotous or unlawful behavior by or amongst the labourers and others employed by him for the purpose of or in connection with the Contract and for the**

preservation of the peace and the protection of the inhabitants and the security of property on or in the neighborhood of the Site.

- IX.** The Contractor shall in collaboration with, and to the requirements of, any duly constituted medical or sanitary authority, ensure that suitable arrangements are made on the Site for the maintenance of health, the prevention and overcoming of epidemics, and for adequate first-aid, welfare, and hygiene services. The Contractor, his partners, foreign workers and employees and their families shall not be involved by any manner in any political activity during their residence in the Employer's country.

10.0 SECURITY DEPOSIT (SD)

10.1 The contractor shall submit Security Deposit in Euros within 15 days from the date of issue of LOI as per the General Conditions of Contract (GCC). For calculation purpose, SD as per GCC will be worked out in Euros based on the SBI TT selling rate prevailing on the date of technical bid opening. For conversion of any amount in this tender/contract from one currency to the other currency, wherever required, exchange rates as applicable on the date of technical bid opening shall be considered.

10.2 In case the contractor opts to furnish Bank Guarantee as a part of Security Deposit, the BG shall be issued as per the Performa enclosed in this tender and also that the BG should be issued preferably through any of the Schedule Banks in India. The BG may also be accepted from a Foreign Bank at the sole discretion of BHEL, provided the BG is duly endorsed by any of the Indian Schedule Banks.

- 11** For reverse auction/ for Price Bid opening, only those bidders will be considered who will be qualified for the subject job on the basis of pre-qualification evaluation/ Techno-commercial bids. BHEL reserves the right to reject the bidders with unsatisfactory past performance in the execution of a contract. BHEL's decision in this regard shall be final & binding.

Chapter - X: ANNEXURES

NOT APPLICABLE

ANNEXURE-III

TERMINAL POINTS

ELECTRICALSYSTEM

SYSTEMS	TERMINAL POINTS
---------	-----------------

Switchyard

Rabak Switchyard

ANNEXURE-IV

EXCLUSIONS

- 1 All civil works other than dressing and chipping of foundation surfaces, fixing of supports and hangers in trenches, walls & grouting of equipments
- 2 Supply of all shims and gaskets, which go finally as part of equipment.
- 3 All lugs and glands for cabling .

Chapter - XI: RATE SCHEDULE

RATE SCHEDULE

Rate Schedule is attached separately

NOTES:

1. The quantities indicated above are tentative and are liable to vary depending upon the site requirement. The contractor has to handle / erect / commission all the items indicated by BHEL for achieving the milestones and completion of work.
2. Evaluation of bids shall be done on total price against this Rate Schedule / BOQ.
3. In case of any mismatch in Rate and amount on Price discrepancy, the same will be dealt as per clause No. 1.4 of GCC.

Sl no	Name of Board / Equipment	UOM	Nos	SCOPE	RATE	AMOUNT
A	SWITCHYARD					
	Switchyard Equipments	SET	1	BE+C		
B	MAIN TRANSFORMER					
1	Generator Transformer-	NO	1	BE+C		
2	Unit Aux Transformer-04,3	NO	2	BE+C		
3	Station Transformer -2	NO	1	BE+C		
4	Generator Transformer-3,2,1	NO	3	E+C		
5	Unit Aux Transformer-2,1	NO	2	E+C		
6	Station Transformer -1	NO	1	E+C		
C	IP HT BUSDUCT					
1	Generator IP Busduct	NO	4	E+C		
D	6.6 kV SWITCHGEAR					
1	Unit Board – 1CA - 13 Panels	NO	1	E+C		
2	Unit Board – 1CB - 11 Panels	NO	1	E+C		
3	Unit Board – 2CA- 13 Panels	NO	1	E+C		
4	Unit Board – 2CB - 11 Panels	NO	1	E+C		
5	Unit Board – 3CA- 13 Panels	NO	1	BE+C		
6	Unit Board – 3CB - 11 Panels	NO	1	BE+C		
7	Unit Board – 4CA - 13 Panels	NO	1	BE+C		
8	Unit Board – 4CB - 11 Panels	NO	1	BE+C		
9	Station Board – 0CA - 13 Panels	NO	1	E+C		
10	Station Board – 0CB - 13 Panels	NO	1	E+C		
11	Station Board – 0CC - 13 Panels	NO	1	BE+C		
12	Station Board – 0CD - 12 Panels	NO	1	BE+C		
13	Station Board – 0CE - 14 Panels	NO	1	E+C		
E	SP HT BUSDUCT	NO				
1	UAT-1 - 1CA / 1CB	NO	1	E+C		
2	UAT-2 - 2CA / 2CB	NO	1	E+C		
3	UAT-3 - 3CA / 3CB	NO	1	BE+C		
4	UAT-4 - 4CA / 4CB	NO	1	BE+C		
5	STN TRF -1 - 0CA / 0CB	NO	1	E+C		
6	STN TRF -2 - 0CC / 0CD	NO	1	BE+C		
7	0CA – 1CA	NO	1	E+C		
8	0CA – 2CA	NO	1	E+C		
9	0CB – 1CB	NO	1	E+C		
10	0CB – 2CB	NO	1	E+C		
11	0CA – 0CC	NO	1	E+C		
12	0CB– 0CD	NO	1	BE+C		
13	0CC – 3CA	NO	1	BE+C		
14	0CC – 4CA	NO	1	BE+C		

15	OCD – 3CB	NO	1	BE+C		
16	OCD – 4CB	NO	1	BE+C		
F	NUETRAL GROUDING RESISTOR	NO				
1	NGR for UAT-4,3 , ST -2	NO	4	BE+C		
2	NGR for UAT-1,2 , ST -1	NO	4	E+C		
G	LT MCC					
1	415V UNIT PCC-1	NO	1	E+C		
2	415V UNIT PCC-2	NO	1	BE+C		
3	415V UNIT PCC-3	NO	1	BE+C		
4	415V UNIT PCC-4	NO	1	BE+C		
5	415V DG PCC-1	NO	1	BE+C		
6	415V EMERGENCY MCC-1	NO	1	E+C		
7	415V EMERGENCY MCC-2	NO	1	E+C		
8	415V EMERGENCY MCC-3	NO	1	BE+C		
9	415V EMERGENCY MCC-4	NO	1	BE+C		
10	415V BOILER & BOILER VALVE MCC-1	NO	1	E+C		
11	415V BOILER & BOILER VALVE MCC-2	NO	1	E+C		
12	415V BOILER & BOILER VALVE MCC-3	NO	1	BE+C		
13	415V BOILER & BOILER VALVE MCC-4	NO	1	BE+C		
14	415V TURBINE & TURBINE VALVE MCC-1	NO	1	E+C		
15	415V TURBINE & TURBINE VALVE MCC-2	NO	1	E+C		
16	415V TURBINE & TURBINE VALVE MCC-3	NO	1	BE+C		
17	415V TURBINE & TURBINE VALVE MCC-4	NO	1	BE+C		
18	415V STATION PCC-1	NO	1	E+C		
19	415V STATION PCC-2	NO	1	BE+C		
20	415V WORKSHOP DB	NO	1	E+C		
21	415V FUEL OIL PMCC	NO	1	BE+C		
22	415V VENTILLATION MCC-1	NO	1	E+C		
23	415V VENTILLATION MCC-2	NO	1	BE+C		
24	415V MISC. MCC-1	NO	1	BE+C		
25	415V MISC. MCC-2	NO	1	BE+C		
26	415V CONTROL ROOM A/C MCC	NO	1	BE+C		
27	415V SERVICE BUILDING A/C MCC	NO	1	E+C		
28	415V ESP AREA MCC-1	NO	1	E+C		
29	415V ESP AREA MCC-2	NO	1	BE+C		
30	415V CT PMCC-1	NO	1	E+C		
31	415V CT PMCC-3	NO	1	E+C		
32	415V CLWPH SWGR	NO	1	E+C		
33	415V ETP MCC	NO	1	E+C		
34	415V DM PLANT MCC	NO	1	BE+C		
35	415V PT PLANT MCC	NO	1	BE+C		

36	415V CHLORINATION PLANT MCC	NO	1	BE+C		
37	415V RAW WATER PH (PLANT SIDE) MCC	NO	1	BE+C		
38	415V RAW WATER PH (RIVER SIDE) MCC	NO	1	E+C		
39	110V UNIT DC DB-1	NO	1	E+C		
40	110V UNIT DC DB-2	NO	1	E+C		
41	110V UNIT DC DB-3	NO	1	BE+C		
42	110V UNIT DC DB-4	NO	1	BE+C		
43	415V ADMIN BUILDING MCC	NO	1	E+C		
44	SOOTBLOWER MCC PANEL	NO	4	E+C		
H	SERVICE TRANSFORMERS	NO				
1	1000 kVA , 6.6 kV / 433 V , Off CTS - Dry Type	NO	6	BE+C		
2	1000 kVA , 6.6 kV / 433 V , Off CTS - Dry Type	NO	2	E+C		
3	1600 KVA , 6.6 kV / 433 V , Off CTS- Dry Type	NO	2	BE+C		
4	1600 KVA , 6.6 kV / 433 V , Off CTS- Dry Type	NO	2	E+C		
5	1000 kVA , 6.6 kV / 433 V , Off CTS - Oil Filled	NO	6	BE+C		
6	1000 kVA , 6.6 kV / 433 V , Off CTS - Oil Filled	NO	4	E+C		
7	1600 kVA , 6.6 kV / 433 V , Off CTS - Oil Filled	NO	2	BE+C		
8	1600 kVA , 6.6 kV / 433 V , Off CTS - Oil Filled	NO	2	E+C		
9	2000 kVA , 6.6 kV / 433 V , Off CTS - Oil Filled	NO	2	BE+C		
11	2500 kVA , 6.6 kV / 11.5 kV , Off CTS - Oil Filled	NO	2	BE+C		
14	2500 kVA , 11 kV /6.9 kV, Off CTS - Oil Filled	NO	2	E+C		
16	630 kVA , 6.6 kV / 433 V , Off CTS - Oil Filled	NO	4	E+C		
I	<u>LT SEGREGATED PHASE BUSDUCT :</u>					
1	Busduct Rated 1600A	NO	6	BE+C		
2	Busduct Rated 2500A	NO	6	BE+C		
3	Busduct Rated 3000A	NO	1	BE+C		
4	Busduct Rated 1600A	NO	4	E+C		
5	Busduct Rated 2500A	NO	10	E+C		
6	Busduct Rated 3000A	NO	1	E+C		
J	<u>LOCAL PUSH BUTTON STATIONS AND STARTERS :</u>					

1	LPBs	NO	230	E+C		
2	LPBs	NO	70	BE+C		
3	Local starters	NO	80	E+C		
K	DC SYSTEM :					
1	110 V Battery Chargers	NO	4	E+C		
2	110 V Battery Chargers	NO	4	BE+C		
3	110 V Ni-Cd. Battery Bank .	NO	4	E+C		
4	110 V Ni-Cd. Battery Bank .	NO	4	BE+C		
L	UPS					
1	35 kVA UPS	NO	1	BE+C		
2	ACDB	NO	1	BE+C		
3	VOLTAGE STAB	NO	1	BE+C		
4	BATTERY KPH 120P	set	1	BE+C		
5	60 kVA UPS	NO	4	BE+C		
6	ACDB-1	NO	4	BE+C		
7	ACDB -2	NO	4	BE+C		
8	VOLTAGE STAB	NO	4	BE+C		
9	BATTERY KPH 206	set	4	BE+C		
10	250 kVA UPS	NO	1	E+C		
11	ACDB	NO	1	E+C		
12	VOLTAGE STAB	NO	1	E+C		
13	BATTERY KPH 890	set	1	E+C		
M	CONTROL PANELS	NO				
1	U C P	NO	4	BE+C		
2	E C P	NO	2	BE+C		
3	GEN/ GT / UAT Protection Panel	NO	4	BE+C		
4	Station Trf Relay Panel	NO	2	BE+C		
5	AVR Panel	NO	4	BE+C		
6	Unit Control Desk	NO	8	BE+C		
7	DCS PANELS – SG , TG , BOP, HMI	NO	232	BE+C		
8	PLC PANELS – BOP System	NO	6	E+C		
9	PLC PANELS – BOP System	NO	2	BE+C		
10	VIBRATION MONITORING SYSTEM PANEL	NO	4	BE+C		
11	FURNACE TEMP PROBE STARTER BOX	NO	4	BE+C		
12	DC SCANNER AIR FAN STARTER BOX	NO	4	BE+C		
13	BHEL-VISION EWLI ASCERTOR CABINET	NO	8	BE+C		
14	BHEL-VISION EWLI DISPLAY UNIT	NO	8	BE+C		
15	FURNACE CCTV – LOCAL UNIT	NO	4	E+C		
16	LARGE VIDEO SCREEN	NO	2	BE+C		
17	MASTER CLOCK PANEL	NO	4	BE+C		
18	CCTV PANEL	NO	4	BE+C		
19	SWAS – PRIMARY SAMPLING RACK	NO	4	BE+C		

20	SWAS – PRIMARY SAMPLING RACK	NO	4	BE+C		
21	SWAS – WET PANEL	NO	4	BE+C		
22	SWAS DRY PANEL	NO	4	BE+C		
23	SWAS - CHILLER	NO	4	BE+C		
24	SWAS – HOTWELL CONDUCTIVITY BOX	NO	8	BE+C		
25	DG AMF CONTROL PANEL	NO	3	BE+C		
26	DG MCC PANEL	NO	1	BE+C		
27	DG 24 V CHARGER	NO	3	BE+C		
28	DG 24 V BATTERY	NO	3	BE+C		
29	DG Aux ACDB	NO	3	BE+C		
N	FIELD INSTRUMENTS	NO				
1	Pressure / Temp / Level Gauges	NO	1362	E+C		
2	Pressure / Temp / Level Gauges	NO	500	BE+C		
3	Pressure / Temp / Level Switches	NO	411	E+C		
4	Pressure / Temp / Level Switches	NO	137	BE+C		
5	Pressure / Temp/ Level Transmitters	NO	716	E+C		
6	Pressure / Temp/ Level Transmitters	NO	250	BE+C		
7	Analysers	NO	70	E+C		
8	Analysers	NO	20	BE+C		
9	Flow meters	NO	4	E+C		
10	Flow meters	NO	4	BE+C		
11	DWLI / EWLI	NO	12	E+C		
12	DWLI / EWLI	NO	4	BE+C		
13	RTDs / Thermocouples	NO	583	E+C		
14	RTDs / Thermocouples	NO	150	BE+C		
15	MTM Thermocouples	NO	219	E+C		
16	MTM Thermocouples	NO	73	BE+C		
17	Bearing thermo Elements	NO	124	E+C		
18	Opacity Monitor with accesories	NO	4	E+C		
19	Relative / Absolute Vibration Sensors (with proximeters)	NO	168	E+C		
20	Shaft Expansion Sensors (with proximeters)	NO	16	E+C		
21	Axial Shift Sensors (with proximeters)	NO	12	E+C		
22	Speed Probes	NO	24	E+C		
23	Calibration of SOV operated Trip Valves	NO	50	E+C		
24	Callibration / commissioning of regulating Control Valves with positioners / LS / PFT	NO	80	E+C		
25	Commissioning of motorised actuators	NO	400	E+C		
26	Flame Scanner Assembly	NO	48	E+C		
27	Pnuematic Power Cylinders with PFT (Boiler)	NO	192	E+C		

28	Limit Switches /Heavy duty Limit Switches (for BTPS)	NO	228	E+C		
29	Air Filter Regulators + I / P Convertor	NO	72	E+C		
30	Flexible hoses - $\frac{1}{4}$ " (2 meter long) , 1" (3 meter long)	NO	48	E+C		
31	Temperature / controller	NO	40	E+C		
32	Position Transmitters	NO	50	E+C		
33	Junction Boxes – 6/12/24/36/48way	NO	188	E+C		
34	Junction Boxes – 6/12/24/36/48way	NO	60	BE+C		
35	Junction Boxes – 64/72/96 way	NO	241	E+C		
36	Junction Boxes – 64/72/96 way	NO	80	BE+C		
37	SS / Copper Tubing ($\frac{1}{4}$ " , $\frac{1}{2}$ ")	RM	2800	E+C		
38	1/2 , 3/4 " CS impulse Pipe	RM	21000	E+C		
39	1/2 , 3/4 " CS impulse Pipe	RM	3000	BE+C		
40	1/2 , 3/4 " AS impulse Pipe	RM	1300	E+C		
41	1/2 , 3/4 " AS impulse Pipe	RM	500	BE+C		
42	3/4",1/2 " SS impulse Pipe	RM	5160	E+C		
43	Special Pipes – Cr- Mo	RM	2000	E+C		
44	Gi Pipe – $\frac{1}{2}$ " , $\frac{3}{4}$ " , 1" , 1 $\frac{1}{2}$ "	RM	3000	E+C		
45	LOCAL INSTRUMENT RACK (LIR) TYPE A/B	NO	111	E+C		
46	LOCAL INSTRUMENT RACK (LIR) TYPE A/B	NO	60	BE+C		
47	LOCAL INSTRUMENT PANEL (LIE) TYPE A/B	NO	42	E+C		
48	LOCAL INSTRUMENT PANEL (LIE) TYPE A/B	NO	14	BE+C		
49	PC set with monitor / keyboard / power supply unit	NO	30	E+C		
50	PC set with monitor / keyboard / power supply unit	NO	10	BE+C		
51	UCB Loose Supplied Inserts	NO	58	E+C		
O	ELECTRICAL SYSTEMS					
1	500 line Telephone Exchange and the communication network as described in tech details	SET	1	E+C		
2	PA System : The system consists of 3 nos operator console as described in tech details	SET	1	E+C		
3	CCTV System : This consists of Desk Top Monitor as described in tech details	SET	1	E+C		
4	Master Clock System : The system consists of the Main Clock Panel as described in tech details	SET	1	E+C		
				E+C		
P	STATION LIGHTING			E+C		

	The Station Lighting System provided lighting for the entire Power Station – both indoors and outdoors . The System broadly consists of the following sub-systems :					
1	Lighting Distribution Boards (AC + DC) -	NO	10	E+C		
2	Lighting Panels (AC + DC)	NO	43	E+C		
3	Lighting Fixtures (AC + DC)	NO	400	E+C		
4	Receptacles	NO	365	E+C		
5	Street Lighting Poles	NO	252	E+C		
6	Emergency Lighting Units	NO	30	E+C		
7	Ceiling Fans	NO	10	E+C		
8	Switch Board for Local Control	NO	70	E+C		
9	Lighting Distribution Boards (AC + DC) -	NO	20	BE+C		
10	Lighting Panels (AC + DC)	NO	43	BE+C		
11	Lighting Fixtures (AC + DC)	NO	2200	BE+C		
12	Receptacles	NO	60	BE+C		
13	Street Lighting Poles	NO	0	BE+C		
14	Emergency Lighting Units	NO	30	BE+C		
15	Ceiling Fans	NO	0	BE+C		
16	Switch Board for Local Control	NO	70	BE+C		
Q	<u>FIRE SEALING SYSTEM:</u>					
1	Fire Sealing System will be applied to close all cable openings . The system will be Mortar type or Foaming Type .	SQ M	1165	E+C		
R	6.6 kV HT Cu Cable					
1	3C X 120 Sq. mm.	MTR	7500	E+C		
2	3C X 150 Sq. mm.	MTR	1500	E+C		
3	1C X 300 Sq. mm.	MTR	750	E+C		
S	1.1 kV LT Cu Power Cable					
1	3C-240	MTR	5250	E+C		
2	3C-185	MTR	7500	E+C		
3	3C-95	MTR	1500	E+C		
4	3C-50	MTR	2250	E+C		
5	3C-25	MTR	4500	E+C		
6	3C-16	MTR	1500	E+C		
7	3C-10	MTR	7500	E+C		
8	3C-06	MTR	7875	E+C		
9	3C-04	MTR	9000	E+C		
10	3.5C-150	MTR	5625	E+C		

11	3.5C-35	MTR	9375	E+C		
12	1C-630	MTR	5250	E+C		
13	1C-400	MTR	14250	E+C		
14	2C-185	MTR	1125	E+C		
15	2C-50	MTR	750	E+C		
16	2C-25	MTR	8250	E+C		
17	2C-16	MTR	7125	E+C		
18	2C-10	MTR	3000	E+C		
19	2C-06	MTR	2250	E+C		
20	5C-04	MTR	10500	E+C		
21	4C-16	MTR	8625	E+C		
T	1.1 kV LT Cu Control Cable					
1	2C – 2.5 Sq. mm	MTR	78000	E+C		
2	3C – 2.5 Sq. mm	MTR	138000	E+C		
3	4C – 2.5 Sq. mm	MTR	57000	E+C		
4	7C – 2.5 Sq. mm	MTR	84000	E+C		
5	12C – 2.5 Sq. mm	MTR	54000	E+C		
6	19C – 2.5 Sq. mm	MTR	34500	E+C		
7	24C – 2.5 Sq. mm	MTR	3000	E+C		
U	Signal Cable					
1	2P, 0.5	MTR	120500	E+C		
2	4P, 0.5	MTR	341000	E+C		
3	6P, 0.5	MTR	43000	E+C		
4	8P,0.5	MTR	79500	E+C		
5	12P, 0.5	MTR	20500	E+C		
6	24P, 0.5	MTR	3000	E+C		
7	Compensating Cable	MTR	74000	E+C		
V	Special Cables					
1	UTP Cable for DCS	MTR	18750	E+C		
2	Fibre Optic cables for CCTV	MTR	11250	E+C		
3	Pre fab cables	MTR	3750	E+C		
W	Galvanised Ladder Type Cable Tray complete with Coupler Plates, Fasteners, Clamps and Fixing Hardwares					
1	600 mm wide	MTR	12,500	E+C		
2	450 mm wide	MTR	7,500	E+C		
3	300 mm wide	MTR	1,000	E+C		
4	150 mm wide	MTR	750	E+C		

5	100 mm wide	MTR	500	E+C		
X	Galvanised Perforated Type Cable Tray complete with Coupler Plates, Fasteners, Clamps and Fixing Hardwarees					
1	600 mm wide	MTR	3,000	E+C		
2	450 mm wide	MTR	1,000	E+C		
3	300 mm wide	MTR	2,500	E+C		
4	150 mm wide	MTR	750	E+C		
Y	Earthing System					
1	Installation of Above ground Earthing Conductor	MTR	13,000	E+C		
2	Installation of Below ground Earthing Conductor	MTR	10,000	E+C		
3	Installation of Earthing Electrodes	NOS	150	E+C		
Z	Hot dip galvanised MS sheet 1.6mm thick for covering of cable shaft	SQ. M	150	E+C		

TECHINICAL CONDITIONS OF CONTRACT (TCC)

TENDER NO. BHEL/ NR/SCT/ KOSTI /ELEC/ 836

FOR

ERECTION, TESTING, COMMISSIONING TRIAL OPERATION AND
HANDING OVER OF 4 X 125 MW PIPING AT KOSTI TPS, SUDAN.

PART- II OF TCC



Bharat Heavy Electricals Limited
(A Govt. Of India Undertaking)
Power Sector – Northren Region,
Plot No. 25 , Sector - 16A ,
Distt. Gautam Budh Nagar, NOIDA – 201 301 (INDIA)

PART-II

SI	<u>DESCRIPTION</u>	<u>Chapter No.</u>	<u>PAGES</u>
	Part-II: Technical Specifications		
1.	GENERAL	Chapter-I	59-61
2.	CIVIL WORKS, FOUNDATION, GROUTING	Chapter-II	61-62
3.	ERECTION	Chapter-III	63-68
4.	WELDING, HEAT-TREATMENT, RADIOGRAPHY AND N	Chapter-IV	69-73
5.	APPLICATION OF INSULATION	Chapter-V	74-75
6.	PAINTING INCLUDING FINISH PAINTING	Chapter-VI	76-77
7.	TESTING, PRE-COMMISSIONING, COMMISSIONING, / POST-COMMISSIONING	Chapter-VII	78-80

PART-II

Chapter - 1: GENERAL

1.0 GENERAL

- 1.1** The intent of this specification is to provide services for execution of project according to most modern and proven techniques and codes. The omission of specific reference to any method, equipment or material necessary for the proper and efficient services towards installation of the plant shall not relieve the contractor of the responsibility of providing such services / facilities to complete the work or portion of work awarded to him. The quoted / accepted rates / lump sum price shall deem to be inclusive of all such contingencies.
- 1.2** The contractor shall carry out the work in accordance with standard practices / codes / instructions / drawings / documents / specification supplied by BHEL from time to time.
- 1.3** The work shall conform to dimensions and tolerances given in various drawings and documents that will be provided during execution. If any portion of work is found to be defective in workmanship, not conforming to drawings or other stipulations, the contractor shall dismantle and redo the work duly replacing the defective materials at his cost failing which the job will be carried out by BHEL by engaging other agencies / departmentally and recoveries will be affected from contractor's bills towards expenditure incurred including BHEL's usual overhead charges.
- 1.4** Following shall be the responsibility of contractor and have to be provided within finally accepted rates / prices.
- A** Provision as required of all types of labour, supervisors, engineers, watch and ward, tools & tackles, calibrated inspection, measuring and test equipments as specified and otherwise required for the work, consumables for erection, testing and commissioning including material handling.
 - B** Proper out-turn as per BHEL's plan and commitment
 - C** Completion of work as per BHEL Schedule.
 - D** Good quality and accurate workmanship for proper performances of equipment.
 - E** Repair and rectification
 - F** Preservation / Re-conservation of all components during storage / erection till handing over.
 - G** HOUSE KEEPING-The contractor is supposed to carryout house keeping of the work area on regular basis to keep the work place neat and tidy and available for the SAFE Working. The scrap, generated daily during the Execution

activities, is to be dumped at designated area as decided by BHEL/ FCE on daily basis. The erection materials issued to the contractor and kept near the work area should also be staged properly at site. Compliance report on above shall be submitted by the contractor to BHEL on Daily basis. In case the contractor fails to do so, BHEL have rights to carryout the same from the other party at the Risk and cost of the contractor. The cost applicable with BHEL overheads shall also be recovered from the monthly running bills of contractor.

1.5 PRELIMINARY WORKS

- 1.51** The contractor shall, as a first field activity check the foundations for turbine, generator and all auxiliaries for the correctness of the same as per the drawings and satisfy himself in all aspects. He should ensure location of foundations, their consolidation, absence of voids, levels, correctness of boltholes, pockets levels and centerlines etc. All measurements should be recorded and submitted to Engineer for approval before erection
- 1.52** Before starting erection job, contractor shall ensure that TG area is sufficiently enclosed against ingress of dust and water, and all debris have been cleared off from the floor to a designated area as per instruction of Engineer. The contractor shall arrange to get the working area and surroundings cleaned daily to ensure a dust free atmosphere for working.
- Contractor shall first cover all openings on operating floor and put temporary hand railings on all sides of the floor to avoid any accident to the personal working. Material for above work, if available can be issued by BHEL on returnable basis.
- 1.53** The contractor shall provide his tool stores for special tools and instruments at a convenient location near to the place of working in TG hall. Necessary area shall be provided to contractor by BHEL. This is to be cleared after completion of the work. If so required he will have shift the same if required to give fronts to other agencies engaged at site.
- 1.54** The contractor shall set up longitudinal and transverse axes and two or more level bench marks accurately on TG floor. BHEL Engineer shall certify these. The certified TG-Center lines and datum level shall be the reference for TG and all auxiliaries' erection and alignment work. The contractor shall transfer these axes to all the floors to facilitate further execution.
- 1.55** All matching surfaces of components shall be well cleaned with cleaning agent and burrs shall be removed by filing and blue matched wherever required. Wherever necessary sealing/ lubricating/ anti-seize compounds shall be applied as per recommendation of Engineer. Machining/ grinding required for fitting of keys, pins, packers & dowels etc. shall be carried out by contractor at his cost. The contractor is expected to have his own arrangements for machining activities.
- 1.56** The accuracy of all equipment/ instruments and their functioning shall be established before they are permitted for use on the job. If the Engineer doubts the accuracy of the precision tools, any time during erection, the contractor shall arrange the checking/ calibration of tools/ equipment/ instruments at his cost.

Chapter - II: CIVIL WORKS, FOUNDATION, GROUTING

2.0 CIVIL WORKS, FOUNDATION, GROUTING

- 2.1** BHEL shall provide all equipment foundations. For the correctness of these foundations as per drawings, the contractor shall check the dimensions & locations of the foundations, pockets, anchor-bolt pitch. Further, top elevation of foundations shall be checked with respect to benchmark. All minor adjustments of foundation level, dressing and chipping of foundation surfaces up to 50 mm, enlarging the pockets in foundations etc., as may be required for the erection of equipment / plants shall be carried out by the contractor.
- 2.2** While on the job, care is essential to avoid too much chipping and resultant lowering of level. In case of excess chipping, contractor has to arrange additional packing plates as per requirements provided BHEL Engineer allows it. When required by manufacturers, the embedded sub-sole plates shall be scraped and checked with prussian blue to get the required contact with frames.
- 2.3** The contractor shall ensure perfect matching of packer plates including machining, scraping and blue matching with foundation by dressing the foundation, as well as perfect matching between the packer plates and the base plate of equipment to the satisfaction of BHEL Engineer. If required the packer plates may have to aligned and fixed on the foundations using special high strength, non-shrinking and quick-setting grouts. The minimum thickness below the packer plate should be 20 mm. The material required for this has to be arranged for by the contractor at his cost.
- 2.4** The Grouting of all the equipments will have to be carried out by the Contractor. The contractor has to arrange for all materials required for carrying out the grouting including supply of the Special Grout as indicated in the drawings and as approved by the Engineer. .
- 2.5** The contractor has to ensure that all the matching joints which are not to be grouted shall be kept free from the grouting mixture by applying tape or any other alternative method approved by Engineer. All assistance required has to be provided by the contractor
- 2.6** The contractor shall check and verify the alignment of equipment, alignment of shafts of rotating machinery, the slopes of all bearing pedestals, centering of rotors with respect to their sealing bores, couplings etc. as applicable and the like items to ensure that no displacement had taken place during grouting. The values recorded prior to grouting shall be used during post grouting check up and verifications. Such pre and post grout records of alignment details shall be maintained by the contractor in a manner acceptable to the Engineer.
- 2.7** Besides grouting as above, any civil works required for safe and efficient operation of tools and tackles like grouting / excavation/ casting of foundation / anchor points for derricks, winches, guy ropes fastening, etc / foundations

required for chemical cleaning pumps, tanks and any other temporary supports shall also be the contractor's responsibility. For these civil works all materials including cement and required facilities will have to be arranged by contractor at his own cost.

Chapter - III: ERECTION

3.0 ERECTION

- 3.1 All works such as cleaning, checking, levelling, aligning, assembling, temporary erection for alignment, dismantling of certain equipment for checking, cleaning, surface preparation, fabrication at site, cutting, grinding, straightening, blue matching, chamfering, filing, chipping, drilling, machining, surface grinding, shaping, fitting up etc. as may be applicable in such erection works are to be treated as incidental to erection and necessary to complete the work satisfactorily and shall be carried out by the contractor as part of the work.
- 3.2 Any fixtures, scaffolding materials, concrete block supports, steel structures required for temporary supporting, for pre-assembly or checking, welding, lifting and handling during pre-assembly and erection shall be arranged by contractor at his cost.
- 3.3 The following provisions cover the technical requirements for some of equipment installation. The brief idea about the work involved is indicated below however the work is to be carried out in accordance with the recommendations of the equipment manufacturer drawings, documents furnished to the contractor by BHEL or as directed by BHEL Engineer.

(A) HT TRANSFORMERS

Scope of work includes checking and preparation foundation, erection of accessories and auxiliaries, carrying out minor modification wherever required; Preparation of oil and oil filling under vacuum, dry out of transformer, testing of transformer, oil and other auxiliaries, laying of cable trays upto marshalling box, cabling upto marshalling box and termination for auxiliaries, earthing of accessories to earth conductor / riser, testing of all auxiliaries, pre-commissioning and back charging of transformers.

Painting of Transformer as approved by BHEL Engineer .

(B) ISOLATED PHASE BUSDUCT :

Foundation checking and carrying out minor modifications wherever required , erection of Structure , Busduct , LAVT , NG Cubicle etc , alignment of total busduct and readiness for welding , Welding of Bus , Ducts and shunts , by MIG /TIG and NDT and X-ray tests . Fixing of Rubber Bellows , SOB , Wall Frame assembly , Flexible and Rigid Bus Connections , CTs , VTs , NGT and NGR . Erection of earth Conductors, HAB equipment and carrying out Water and Air Tightness Tests . Cabling of CTs upto Marshalling Box after MB erection , testing of CTs and wiring and other tests , Hipot of Main Busduct .

Painting of Busduct as approved by BHEL Engineer .

(C) SEGREGATED PHASE BUSDUCT:

Foundation checking and carrying out minor modification wherever required, erection of structures, Busduct sections, and other loose items as per relevant drawings / documents, alignments and jointing by bolting of total Busduct , fixing of Rubber Bellows, seal Off Bushings, wall frame assembly, Flexible & rigid Bus connections, erection of earth conductors,, cabling upto JB / Marshalling Box , contact resistance checks on bus duct, Hi-pot of Busduct, earthing of system with main earth conductor / riser.

Painting of Busduct with paint as approved by BHEL Engineer .

(D) 6.6 KV SWITCH GEAR

Erection of Panels after foundation checking and carrying out minor modification wherever required, Jointing of panels, inter panel wiring, busbar & earthbar connections, mounting of loose supplied items, testing of complete panels, BEB, FEB and spare trucks, HV test of main and Control bus, testing & commissioning of breakers after scheme checking including testing / calibration of all instruments and relays.

(E) LT SERVICE TRANSFORMERS :

Scope of work includes checking and preparation foundation, erection of accessories and auxiliaries, carrying out minor modification wherever required; Preparation of oil and oil filling under vacuum, dry out of transformer, testing of transformer, oil and other auxiliaries, laying of cable trays upto marshalling box, cabling upto marshalling box and termination for auxiliaries, earthing of accessories to earth conductor / riser, testing of all auxiliaries, pre-commissioning and back charging of transformers.

Painting of Transformer as approved by BHEL Engineer .

(F) DC BATTERY CHARGERS / UPS

Erection of Panels after foundations checking / fabrication of base frames or stools (wherever applicable) and carrying out minor modification wherever required; Joining of panels, inter-panel wiring, busbar & earthbar connections, mounting of loose supplied items, Testing of complete board & including testing / calibration of all instruments and schemes; Dummy load test of Chargers including arranging of dummy load and temporary power supply etc.

(G) DC BATTERY

Erection of battery after assembly of battery stands, inter-connection of batteries and first charging; Capacity testing using dummy load and subsequent recharging (in case of failure of capacity test, the charging Discharging cycle is to be repeated) Dummy load test of chargers includes arrangement of dummy load and temporary connection in absence of regular power supply.

(H) PANELS – POWER , CONTROL & RELAY (LTMCCs , STRP / GCPs ,ECB etc.)

Erection at site / control room including chipping of floor, fabrication and fixing of base channel frame, levelling & alignment with spirit level, welding the base channel to the embedded plates / channels, grouting, fixing of anti-vibration pads, termination of inter panel connections, mounting / connections of loose instruments, inter panel bus bar connections, commissioning including loop checking, system checking, and putting necessary controls on automatics. Terminations of cables will be by conventional screwed connections. Checking of internal wiring, rectification, testing and calibration of equipment mounted inside is in the scope of contractor. The contractor may have to change / replace items found faulty without any extra cost, however materials for this shall be provided by BHEL. Mostly panels will be delivered fully wired. However wherever required termination of loose wires, bus wires is to be done. Canopy for panels will be supplied loose & shall be installed by the contractor after erection of panels. The cleaning of panels have to be done with electrical vacuum cleaner, besides conventional cleaning with brush etc. The drilling of holes in the gland plates for cable entry shall be part of panel erection. All blank holes / gaps in the gland plates / boxes etc. shall be properly sealed. The base frames shall be painted suitably. The contractor shall carry out the plugging and sealing of left out holes in the gland plates and other openings at the bottom of panels at his own cost by using fire retardant mortar or good quality sealing material as advised by BHEL. Any minor alterations required in the bus bar arrangement, wiring in the panels/ cubicles shall also form part of the work. During testing, commissioning, some equipment / modules may need replacement / repairs. All such replacements / repairs and assistance during commissioning and running of the unit till handing over to the Customer are part of the scope as some of the test / commissioning will have to be done after the machine is running on various loads..
Touch-Up Painting as approved by BHEL Engineer .

(N) CABLING:

- a) Fixing of Cable Tray Support Structure to concrete foundations / brick walls by anchor bolts or to steel structure by suitable clamps, including fabrication / fixing of any other structure required to install the support structure .
- b) Fixing of cable trays and tray bends and accessories to the tray supporting structure including modification of the trays to suit the local tray route conditions is to be carried out .
- c) Laying, dressing & clamping of the cables in the cable trays / angles / conduit pipes as per the cable schedule and as instructed by the BHEL Engineer . Nylon / PVC ties / Tre Foil Clamps required for dressing / clamping shall be provided to the Contractor .
- d) The cable tags, as approved by the BHEL Engineer, are to be provided by the contractor (at both ends and at regular intervals as advised by BHEL Engineer) at his cost . Similarly Wire ferrules of approved category is to be provided by the Contractor at his cost .
- e) While laying cables, existing cable trench covers and false flooring may require to be removed and re-fixed. The same has to be done at no extra cost to BHEL
- f) Gland plate hole drilling is to be carried out by the contractor at no extra cost
- g) Cable Termination shall be carried out by the contractor as per approved drawings / as per instructions of the Engineer . Lugs, Glands, cable termination kits will be supplied by BHEL . **Wire ferrules of approved category is to be provided by the Contractor at his cost .** All required crimping tools and other tools will be provided by the Contractor

O) STATION LIGHTING :

Erection of lighting boards ,panels, light poles, fittings and other suitable fixtures required for light fittings, conduiting, cabling and wiring as per drawing, testing of wiring and circuit checking, energizing of system forms part of erection job. All conduits, lighting fittings / panels and accessories required for lighting work shall be supplied by BHEL .

Fabrication / erection of required supporting structures and control-gear of respective fitting , all civil work for lighting poles including supply of cement , all civil works for buried cables etc is included in the scope of the Contractor

- 3.1 All equipment within the scope of these specifications shall be received duly painted. However during storage and handling the same may get peeled off / damaged / deteriorate. All such surfaces are to be thoroughly cleaned and to be touch up painted with suitable approved primer / finish paint matching with shop paint / approved final colour. Besides above two coats of approved primer paint and at least two coats of approved finish paint to get the desired dry film thickness, is to be applied on various loose equipment, all impulse lines and structures fabricated and erected at site. **All paints, tools and other consumables including scaffolding materials required for painting shall be arranged and provided by contractor within the quoted rates. Paint and other materials so purchased shall be approved by BHEL and painting should be as per colour scheme and quality approved / specified by Engineer.** Valid Test certificate for the paint so supplied shall be made available before use of the same on work. The contractor shall provide legend on equipment in size specified by Engineer. Letter writing shall be done in Hindi / English or in both language. The printer have to under go test and only qualified painters will be allowed to work.
- 3.2 Certain equipment shall require spray painting (touch up). The contractor shall make arrangements of the required equipment for spray painting of such equipment at his own cost. Spray painting at the job site shall be permitted only at times and locations approved by the owner / Engineer.
- uiting required for light fittings shall also include fixing of conduit accessories like bends, tees, 3 / 4 way JB's etc. and the laying of PVC wires in respective conduit as per circuits shown in drawing.

P) INSTRUMENTATION**i. GUAGES / SWITCHES / TRANSMITTERS :**

For instruments supplied loose, the scope includes issue from stores, calibration, erection (including fabrication and fixing of frames / stands by welding to steel structure or by chipping & grouting with RCC columns / floor) and charging / loop checking. The work includes installation of housing connecting manifold / PG valve on supports / racks to be suitably fabricated for the instruments being supplied loose.

For instruments supplied duly mounted on skids / racks / gauge boards , the scope includes erection of gauge board / rack, dismantling from skids / racks / gauge board, reinstallation after testing / calibration, restoring electrical connections, if any ,

pressure testing of connected piping and charging / loop checking. Servicing of manifolds PG valves shall also form part of erection job.

Some instruments may need repeated calibration / replacement. The same will be carried out by the contractor including calibration of instruments needed for replacement, which will be supplied by BHEL. Erection of thermoelements like RTDs & Thermocouples includes erection of thermowells, wherever required, at no extra cost to BHEL.

ii. DETECTORS / VIBRATION , SPEED & OTHER TURBOVISORY PICK UPS:

Blue matching with the assembly fixtures / main equipment surface, trial fixing, fixing by drilling / tapping, final doweling. Moreover some detectors may have piggy-backs signal detectors mounted on them as such these forms part of detectors assembly. The integral cables of the above shall be routed & dressed properly up to their JB / Proximeter. Erection of proximitors, proximitor housings / JB required for respective pick up and calibration / commissioning of pick ups will be included in quoted / accepted item rate of respective pickup.

iii. PROCESS CONNECTIONS

a. PNEUMATIC TUBES (COPPER / SS TUBING) :

Fabrication and erection of single angle supports / tray supports for single multi run tube. Laying tubes in the angles / trays from the panel to the equipment, instrument to instrument, air supply line to drive / instrument, air line connections, clamping properly as per standard ferruling and termination at both ends. This includes all fittings and needle valves, stop valves etc. also. Proper tagging of valves and pneumatic tubes on both ends shall be done for proper identification

b. IMPULSE LINE (CS/ AS / SS)

Fabrication and erection of channel / angle / slotted angle supports, cleaning impulse pipe with wire brush and compressed air, edge preparation, cold bending, laying to the required slopes, clamping, welding of isolation / drain valves and fittings by butt / socket welding / swoze lock joints. Servicing of valves, connecting with the process end and to the instruments, NDT, Hydraulic testing the impulse lines, and painting the lines as per requirement of BHEL engineer. The impulse line may have to be cleaned chemically for removing grease / rusting. Proper tagging of valves and impulse lines on both ends shall be done for proper identification.

c. RIGID PIPE/CONDUITS

Cutting / threading of standard lengths of conduits, laying on fabricated supports or on floor, using screwed fittings, clamping, sealing of open ends. Approved Good quality sealant shall be used to make the joint water proof.

d. PLICA FLEXIBLE CONDUIT

Laying of conduits in cable trays, end connection with instrument / J.B. / panel, using suitable connectors / unions etc. (which shall be supplied by BHEL). Suitable thread / Plica sealant shall be used to make the conduit system water proof. Aluminum painting, clamping and tagging in tray / angle forms part of erection job.

Q) JUNCTION BOX, PUSH BUTTONS ETC

Includes fabrication / fixing / painting of stands for junction boxes / push buttons / frame mounted panels etc

R) COMPUTERS / PLC BASED EQUIPMENTS

All computer related items / equipment like CRT, monitors, printers, key boards, pre-fabricated connecting leads etc shall be installed in control room and control desk as per direction of BHEL Engineer. The Software installation and commissioning is not included in the scope of this contract. However, any assistance required for testing / commissioning have to be provided by the contractor within the quoted price. Hardware found defective during testing / commissioning and till handing over to Customer, have to be removed for repair / replacement and reinstalled within the quoted rates.

S) SAMPLE HANDLING SYSTEM / ANALYZER SYSTEM

Includes installation of main analyzer panel, analyzer, probes, sensors and other accessories like sample gas cylinders, mechanical / electrical interconnections (including SS Tubing & Electrical heat Tracing, wherever required) between various components, energizing, testing & commissioning .

T. ELECTRONIC WATER LEVEL INDICATOR SYSTEM

EWLI includes fixing of electrodes, local and remote indicator panel / display units and interconnection of these by cables. Only cost of laying cables for interconnection of EWLI system shall be measured and paid separately. Erection of all other equipments / panels/ display units forming EWLI system shall be included in the quoted rate per system.

U. CALIBRATION OF CONTROL VALVES , DAMPERS

The work also includes minor rectification / alterations in tubing, servicing of accessories, setting of limit switches, calibration of Actuators and position feedback transmitters.

V. POWER CYLINDER ERECTION

Platforms on which Power Cylinders are to be mounted are usually provided by the Civil Contractor / other agency. However minor structure work required shall form a part of the work within the quoted rate of the the respective cylinder . Fabrication /

erection of stands for mounting of the cylinders The work also includes minor rectifications/alteration in the tubing , servicing of accessories , setting of limit switches , calibration of actuators and feedback position transmitters

- 3.4 Any cutting of masonry work, which is necessary shall be done by the contractor at his own cost and shall be made good to match the original work. The Contractor shall obtain prior approval before cutting any masonry / concrete work.
- 3.5 Conduits shall be thoroughly cleaned before pulling in the cable.
- 3.6 Pipes sent in standard length shall be cut to suit the site conditions and the layouts. Tubes or pipes wherever deemed to be convenient will be sent in running lengths with sufficient bends. Bends upto 80 mm Nb will have to be fabricated at site.
- 3.7 Contractor shall fabricate and erect stands / supports for Junction boxes, push button stations, fixing of push button and plugging of holes in JB's. This is considered inclusive in the item erection.
- 3.8 For calibration of pneumatic valves / controllers / power cylinders etc., the contractor shall attend to minor leakages from the tubing etc., and prepare exact cam-profiles as part of the work, if required.
- 3.9 DRIP SHIELDS shall be fabricated for all field mounted panels / instruments / instrument racks / JB Racks / control cabinets etc. The hardware / material shall be supplied by BHEL. The fabrication forms part of erection work.
- 3.10 The Motors, power cylinders, control valve actuators, motorised valves actuators and solenoid valves will be erected by other agency. However their electrical and C&I commissioning is to be carried out by the agency within the subject scope of work. The staff earmarked for commissioning will carry out the work in association and guidance of BHEL Engineer as a part of system commissioning for which no extra cost will be paid by BHEL.
- 3.11 Certain instrumentation like gauges, transmitters, switches and indicators are received in assembled condition and will be erected along with main equipment by other agency. Contractor for subject work will get these equipment dismantled for calibration and will reinstall them in original location as and when directed by BHEL. Payment for above work shall be released as per respective items indicated in the price bid
- 3.12 In case of Transformers if any leakage / sweating is observed from field assembled / shop assembled gasket joints, valves, welded joints the same shall be attended by the contractor including draining of oil, refilling of oil & centrifuging if required at no extra cost to BHEL till handing over period. Sealing compound

and any other consumable, if needed, shall be arranged by the contractor with in the quoted rates.

- 3.13 Calibration log-sheets / history cards of all the instruments, panels, drives, relay testing etc. under the scope shall be recorded and submitted on BHEL approved formats. Proper logging will form a part of calibration / erection activity for the purpose of monthly running bills payments.
- 3.14 The contractor shall use only SHEARING machine or HACKSAW for cutting angles, flats, channels and trays. No gas cutting is permitted . Drill machine shall be used for drilling holes.**
- 3.15 The contractor should note that after execution of work they will hand over marked up drawings "as erected" drawings to BHEL Engineer at site for preparation of firm "as built" drawings. "As erected" drawings will bear the signature of BHEL Engineer and contractor.
- 3.16 The contractor shall paint the name / put tag numbers on all the equipment / instruments / cables etc. erected by him. Materials for tagging shall be supplied by the contractor . The adhesive etc. shall also be arranged by contractor at his cost.

Chapter - IV: RADIOGRAPHY AND NDT

4.0 RADIOGRAPHY AND NDT (as applicable for Electrical and C&I systems)

- 4.1** The pressure parts, equipment and piping shall be erected in conformity with the provisions of Indian / Sudanese Boiler Regulation and as may be directed by BHEL as per any standard / specification in practice in BHEL. The method of welding (arc, gas, TIG or other method) may be indicated in the detailed drawings / schedules. BHEL Engineer will have the option of changing the method of welding as per site requirements.
- 4.2** Welding of pressure parts, equipment, piping, high tensile structural steel shall be done by certified high pressure welders who possess valid certificate of CIB of the State in which the equipment is erected as per provision of IBR. The H.P. welder who possesses necessary certificate shall ensure re-validation as per relevant provisions of IBR and keep the certificate valid till the completion of work. The services of such welders, the validity of whose certificates have expired shall not be utilized for high-pressure works.
- 4.3** All welders including tack welders, structural and high pressure welder shall be tested as per ASME section IX / IBR and approved by BHEL Engineer before they are actually engaged on work even though they may possess a valid IBR certificate. BHEL reserves the right to reject any welder if the welder's performance is not found to be satisfactory. The contractor shall maintain the records of qualification of welders. BHEL Engineer will issue all the welders qualified for the work, an identity card. The welder will keep the same with him at work place at all times. He may be stopped from work if he is not found in possession of the same.
- 4.4** Engineer may stop any welder from the work if his performance is unsatisfactory for any reason or if there is a high percentage of rejection in the joints welded by him. The welder having passed qualification tests does not absolve the contractor of contractual obligation to continuously check the welder's performance.
- 4.5** Faulty welds caused by the poor workmanship shall be cut and re-welded at the contractor's expense. The Engineer, prior to any repair being made, shall approve the procedure for the repair of defective welds. After the repair has been carried out, the compliance shall be submitted to the engineer.
- 4.6** The contractor shall carry out the root run welding of all HP / LP piping, valves by TIG welding method only. The contractor shall have to carry out full TIG welding of butt weld joints of tubes / pipes of lesser thickness if required. During the root runs of stainless steel joints, the contractor shall before and during welding have to purge the pipes with inert gas. All arrangements required for the above shall be the responsibility of the contractor at no additional cost.
- 4.7** All expenses for testing of contractor's welders including destructive and nondestructive tests conducted by BHEL at site or at laboratory shall have to be borne by the contractor only. Limited quantity of raw material required for making test pieces will be supplied by BHEL free of cost.

- 4.8 The regulators used on welding machines shall be calibrated before putting these into use for work. The Contractor at his cost shall also arrange periodic calibration for the same.
- 4.9 **Only BHEL/ CUSTOMER approved electrodes and filler wire are to be arranged and used by the contractor, within the finally quoted price. BHEL/ FCE reserve the right to test from the certified lab of approved electrode being used by the contractor. Testing charges for the same shall be borne by the contractor.** All electrodes shall be baked and dried in the electric electrode-drying oven to the required temperature for the period specified by the Engineer before these are used in erection work. All welders shall have electrodes drying portable oven at the work spot. The electrodes brought to the site will have valid manufacturing test certificate. The test certificate should have a co-relation with the lot number/ batch number given on electrode packets. No electrodes will be used in the absence of above requirement. The thermostat and thermometer of electrode drying oven will be also calibrated and test certificate from Govt. approved/ accredited test house traceable to National/ International standards will be submitted to BHEL before putting the oven in use. The contractor shall also arrange periodical calibration for the same.
- 4.10 All butt / fillet welds shall be subject to dye penetration test as per the instructions of the engineer at no additional cost.
- 4.11 The contractor shall maintain a record in the form as prescribed by BHEL of all operations carried out on each weld. He has to maintain a record indicating the number of welds, the names of welders who welded the same, date and time of start and completion, preheat temperature, radiographic results, rejection if any, percentage of rejection etc. and submit copies of the same to the BHEL Engineer as required. Interpretation of the BHEL Engineer regarding acceptability or other wise of the welds shall be final.
- 4.12 The contractor shall carry out the edge preparation of weld joints at site in accordance with the details acceptable to BHEL Engineer. Wherever possible machining or automatic flame cutting should be done. Gas cutting will be allowed only wherever edge preparation otherwise is impractical. All slag / burrs shall be removed from the edge and all the hand cuts shall be ground smooth to the satisfaction of engineer.
- 4.13 All welds shall be painted with anticorrosive red oxide paint once radiography and stress relieving works are over. Necessary consumables and scaffolding etc including paints shall be provided by contractor at his own cost.
- 4.14 Radiography and other NDT tests, post heating and stress relieving after welding of tubes, pipes, including attachment welding wherever necessary, are part of erection work and shall be carried out by the contractor in accordance with the instructions of the Engineer. Contractor at his cost shall arrange all equipment and consumables essential for carrying out the above process.
- 4.15 Not Applicable
- 4.16 The contractor shall also be equipped for carrying out other NDT like LPI / MPI / Hardness test etc. as required as per welding schedules / drawings within the finally accepted price / rates. Ultrasonic testing, wherever required, will be arranged by BHEL. Necessary help in conducting the UT shall however be rendered by contractor.

- 4.17** The technical particulars, specification and other general details for radiography work shall be in accordance with ASME, IBR or ISO as specified by BHEL.
- 4.18** Contractor for radiography work shall use iridium-192. The geometric unsharpness shall not exceed 1.5 mm. The contractor should take adequate safety precautions while carrying out radiography. Contractor at his cost shall arrange necessary safe guards required for radiography (including personnel from BARC).
- 4.19** Low speed high contrasts, fine grain films (D-7 or equivalent) in 10 cm width only be used for weld joint radiography. Film density shall be between 1.5 to 2.0.
- 4.20** All radiographs shall be free from mechanical, chemical or process marks, to the extent they should not confuse the radiographic image and defect finding. Penetrameter as per ASME or ISO must be used for each exposure.
- 4.21** Lead numbers and letters are to be used (generally 6mm size) for identification of radiographs. Contract number, joint identification, source used, welder's identification and SFD are to be noted down on paper cover of radiograph.
- 4.22** Lead intensifying screens for front and back of the film should be used as per the above-referred ASME specification.
- 4.23** The joint is to be marked with permanent mark A, B, C to identify the segments. For this a low stress stamp shall be used to stamp the pipe on the down streamside of the weld.
- 4.24** For multiple exposures on pipes, an overlap of about 25-mm of film should be provided.
- 4.25** Radiography personnel with sufficient experience and certified by M/s BARC for conducting radiographic tests in accordance with safety rules laid down by Division of Radiological protection only have to be deployed. These personnel should also be registered with DRP / BARC for film badge service.
- 4.26** All arrangements for carrying out radiography work including dark room and air conditioner and other accessories shall be provided by contractor within the space allotted for office at his cost. As an alternative the contractor may deploy an agency having all above facilities and who are duly approved / accredited by BARC and / or other Regulatory authorities. Detailed particulars of such agencies will be submitted and got approved by BHEL Engineer before the actual deployment of agency for radiography work.
- 4.27** The contractor shall have a dark room fully equipped with radiography equipment, film (un-exposed), chemicals and any other dark room accessories.
- 4.28** Contractor shall note that 100% radiography will be done at the initial stages on all the piping welding joints. Subsequently radiographic inspection will be done on the basis of quality of welding. However minimum percentage of joints to be radiographed shall not be less than the requirement of BHEL welding schedule / IBR / Customer's requirements. The percentage may be increased depending upon the quality of joints and at the discretion of BHEL. Radiography on LP piping joints is not envisaged. However other NDT test as called for in the FQP including LPI, MPI and HT will have to be carried out

- 4.29** All the Radiographs shall be properly preserved and shall become the property of BHEL. They are to be reconciled with the work done, joints radiographed and submitted to BHEL / customer.
- 4.30** Since radioisotopes are being used, all precautions and safety rules as prescribed by BHEL/BARC/ Customer shall be strictly followed. BARC / DRP certificate to be provided before taking up the work.
- 4.31** Radiography of joints shall be so planned after welding that the same is done either on the same day or next day of the welding to assess the performance of HP welders. If the performance of welder is unsatisfactory, he is to be replaced immediately.
- 4.32** Wherever radiographs are not accepted, on account of bad shot, joints shall be re-radiographed and re- submitted for evaluation.
- 4.33** However, if the defect persists after first repair, further repair work followed with radiography shall be repeated till the joint is made acceptable. In case the joint is not repairable, the same shall be cut, re-welded and re-radiographed at contractor's cost.
- 4.34** If the contractor does not carry out radiography work due to non-availability of source / film / chemical / operator etc., BHEL will get the work done departmentally or through some other agency at the risk and cost of the contractor.
- 4.35** Heat treatment and radiography may be required to be carried out at any time (day and night) to ensure the continuity of progress. The contractor shall make all necessary arrangements including labour, supervisors/ Engineer required for the work as per directions of BHEL.
- 4.36** The contractor shall assist BHEL Engineer in preparing complete field welding schedule for all the field welding activities to be carried out in respect of piping and equipment erected by him involving high pressure welding at least 30 days prior to the scheduled start of erection work at site. The contractor shall strictly adhere to such schedules.
- 4.37** The pressure parts, equipment and piping shall be erected in conformity with the provisions of Indian Boiler Regulation and as may be directed by BHEL as per any standard / specification in practice in BHEL. The method of welding (arc, gas, TIG or other method) may be indicated in the detailed drawings / schedules. BHEL Engineer will have the option of changing the method of welding as per site requirements.
- 4.38** **Check shots as per the requirement of BHEL/ FCE will be taken at your cost.**

Chapter - V: APPLICATION OF INSULATION

5.0 APPLICATION OF INSULATION

5.1 NOT APPLICABLE

Chapter - VI: PAINTING INCLUDING FINISH PAINTING

6.0 PAINTING INCLUDING FINISH PAINTING

- 6.1 All equipment within the scope of these specifications shall be received duly painted. However during storage and handling the same may get peeled off / damaged / deteriorate. All such surfaces are to be thoroughly cleaned and to be touch up painted with suitable approved primer / finish paint matching with shop paint / approved final colour. Besides above two coats of approved primer paint and at least two coats of approved finish paint to get the desired dry film thickness, is to be applied on various loose equipment, all impulse lines and structures fabricated and erected at site. **All paints, tools and other consumables including scaffolding materials required for painting shall be arranged and provided by contractor within the quoted rates. Paint and other materials so purchased shall be approved by BHEL and painting should be as per colour scheme and quality approved / specified by Engineer.** Valid Test certificate for the paint so supplied shall be made available before use of the same on work. The contractor shall provide legend on equipment in size specified by Engineer. Letter writing shall be done in Hindi / English or in both language. The printer have to under go test and only qualified painters will be allowed to work.
- 6.2 Certain equipment shall require spray painting (touch up). The contractor shall make arrangements of the required equipment for spray painting of such equipment at his own cost. Spray painting at the job site shall be permitted only at times and locations approved by the owner / Engineer.

Chapter - VII: TESTING, PRE-COMMISSIONING, COMMISSIONING, AND POST-COMMISSIONING

7.0 TESTING, PRE-COMMISSIONING, COMMISSIONING, AND POST-COMMISSIONING

7.1 The contractor shall carry out all the required tests and pre-commissioning and commissioning activities required for their successful and reliable operation. These would include, chemical cleaning, alkali flushing and water flushing of piping, oil flushing of oil system etc. as instructed by BHEL.

All the chemicals required for carrying out these activities will be supplied by BHEL free of cost.

All required tests (Mechanical and electrical) indicated by BHEL and their clients for successful commissioning are included in the scope of these specifications. These tests / activities may not have been listed in these specifications.

Specialized test equipment, if any, shall be provided by BHEL / its client free of hire charges. However contractor has to take proper care of the equipment issued to him.

7.1 Site testing shall be required for all equipment installed by the contractor to ensure proper installation, setting, connection and functioning in accordance with drawings, specifications and manufacturer's recommendations.

7.2 Commissioning protocols are to be prepared as advised by BHEL Engineer for getting approved by customer/ Consultant.

7.3 Testing, and pre-commissioning checks shall be as per relevant codes / practices and BHEL drawings / specifications/ approved commissioning Protocols and same shall include, but not be limited to the following :

I TRANSFORMERS

- (a) Insulation resistance and earth resistance checks.
- (b) Oil testing like BDV of oil of each drum before pouring, after processing and in the course of dry out, moisture content tests as and when required. Provision should be made for preparation of oil in a separate tank before filling in the main transformer tank.
- (c) Checking of Buchholz Relay, oil level indicator PRV, calibration of OTI, WTI etc.
- (d) Winding resistance, vector group, turns ratio test on different taps, magnetizing current, core balance check etc.
- (d) After installation the contractor will get oil samples tested at an accredited test lab as advised by BHEL Engineer and submit the test results, in case the test results are found unsatisfactory the tests will be got repeated by the contractor after reprocessing of oil & submitted to BHEL for approval/acceptance.
- (e) Turns ratio, polarity, insulation resistance and winding resistance checks on all CT's.

II. HT / LT SWITCHGEAR PANELS:

- (a) IR test of power and control circuits & High voltage test of Bus bar.
- (b) Checking of protections and interlocks of all related schemes.
- (c) Calibration of all indicating & metering instruments, relays, timers etc.
- (d) Checking of operation of all relays and other protective devices e.g. thermal overload relays, single phasing preventers etc.
- (e) Carrying out of suitable modifications as per system requirement.
- (f) Operation of all illumination, space heating circuits etc.

III. BUSDUCTS

- (a) Insulation and earth resistance checks.
- (b) High voltage test on Bus bars after drawing out VTs and disconnecting lightning arresters surge capacitors and other connected equipment e.g. generator , generator transformer etc.
- (c) Measurement of contact resistance of joints, bus bar loop resistance etc.
- (d) Testing of CTs, VTs, NGC including primary and secondary injection tests.
- (e) Making all arrangements for testing of the Generator , Gen Trf and UAT
- (f) Testing pre-commissioning & trial run of hot air blowing unit.

IV. BATTERY AND BATTERY CHARGER / UPS

- (a) Checking of battery charger panel.
- (b) Calibration of all indicating and measuring instruments.
- (c) Dummy load test of battery charger.
- (d) Charging of battery and recharging after carrying out battery discharge test/ capability test of battery using dummy load.
- (e) In the absence of regular power supply to battery chargers arrangements are to be made for battery charging from temporary construction power supply points.

(V) CONTROL & PROTECTION PANELS

- (a) Checking of complete wiring and insulation resistance.
- (b) IR test and loop checking of all field wiring in the panel.
- (c) Checking of all protection, metering and indicating schemes.
- (d) Calibration of all indicating and measuring instruments, relays, timers.
- (e) Checking of all auxiliary schemes e.g. space heating, illumination.
- (f) Checking of operation of all relays, switches and other indicators.
- (g) Commissioning of total scheme including relevant internal equipment.
- (h) Carrying out suitable modifications as per system requirement.

- (i) Carrying out primary injection, secondary injection, stability checks etc.

I) INSTRUMENTATION

- a) All instruments shall be checked for proper installation, supports, impulse lines, cabling etc. and corrected, wherever required.
- b) All instruments shall be calibrated before installation and proper calibration record shall be maintained to the satisfaction of BHEL Engineer. Instruments received in assembled condition in panels etc. shall also be dismantled, calibrated and re-assembled as per advise of BHEL Engineer.
- c) All impulse and pneumatic lines shall be properly cleaned (oil flushed / chemical cleaned / air blown/ steam blown/ Hydraulic tested etc.) before being charged.
- d) Some of the instruments may require re-calibration during commissioning. The contractor shall remove such instruments, recalibrate and install within the quoted rates.

(II) DRIVES AND CONTROLLERS

- a) All drives such as power cylinders, pneumatic / motorised valves / dampers etc. and controllers shall be checked for proper installation supports etc. before commissioning.
- b) All transmitters shall be calibrated and limit switches shall be adjusted.
- c) All pneumatic and impulse lines shall be cleaned as per instructions of BHEL Engineer.
- d) All drives shall be operated by simulating various conditions to ensure healthiness of components of the system.
- e) Re-calibration / rectification wherever required shall be carried out by the contractor within the quoted rates.
- f) Remote operation of all drives, valves, dampers shall be checked from control room as per instruction of BHEL Engineer.

7.4 In case any defect is noticed during tests, trial runs and commissioning such as loose components, undue noise or vibration, strain on connected equipment etc. the contractor shall immediately attend to these defects and take necessary corrective measures. If any readjustment and realignment are necessary, the same shall be done as per Engineer's instructions including repair, rectification and replacement work by the contractor at his cost. The parts to be replaced shall be provided by BHEL.

7.5 During this period, though the BHEL's / Client's staff will also be associated in the work, the contractor's responsibility will be to arrange for the complete requirement of supervision , labour , consumable, T&P and IMTEs required till such time the commissioned units are taken over by the BHEL's customer.

7.6 During commissioning activities and for carrying out various tests, special instruments etc , have to be temporarily erected and commissioned to suit the commissioning

- activities. Contractor will provide the necessary equipment. Contractor has to carry out the erection, calibration, dismantling of the same. After completion of activities the temporary systems have to be removed and to be taken back at no extra cost to BHEL.
- 7.7 During erection of various equipment, prior to commissioning and after commissioning, protocols have to be made with BHEL's customer. The proforma and formats as approved have to be printed by the contractor in adequate numbers. The pre-commissioning activities will start with various trials, commissioning operations shall continue till units are handed over to customer. Simultaneous commissioning activities will be progress in various areas, checking of equipment erected, making ready for trial runs, all these works need specialized gangs including electricians / instrument technicians in each area to render assistance to BHEL commissioning staff. Contractor shall earmark separate manpower for various commissioning activities. The manpower shall not be disturbed or diverted.
- 7.8 It shall be the responsibility of the contractor to provide workmen of various categories in sufficient numbers along with Engineers/ Supervisors including necessary consumables, T&P etc. during pre-commissioning, commissioning and post commissioning period for commissioning of equipment and attending any problem in equipment erected by the contractor till handing over. The rates quoted shall include all these contingencies also.
- 7.9 It shall be specifically noted that the above employees of the contractor may have to work round the clock alongwith BHEL commissioning Engineer and hence overtime payment by the contractor to his employees may be involved. The contractor's accepted rates shall be inclusive of all these factors also.
- 7.10 In case, any rework is required because of contractor's faulty erection which is noticed during commissioning , the same has to be rectified by the contractor at his cost. If any equipment / part is required to be inspected during commissioning, the contractor will dismantle / open up the equipment / part and reassemble/redo the work without any extra claim.
- 7.11 During commissioning, opening and closing of valves, attending to leakage, changing of gaskets, modifications in wiring, realigning of equipment, re-calibration of instrument, attending to leakage, minor adjustments of erected equipment may arise. The accepted rates shall include all such works.

INDICATIVE LIST OF T & P TO BE ARRANGED BY THE CONTRACTOR FOR ELECTRICAL WORKS

	EQUIPMENT	QUANTITY
1.	75 MT Crane	APR
2.	18 / 20 MT Crane	2 nos
3.	12 / 15 MT Hydra	3 nos
4.	100 T Hydraulic Jacks suitable for handling of Transformers	4 nos
5.	10,000 litre Oil Tank	2 no
6.	6000 LPH Hi- Vacuum Oil Filter Machine suitable Transformers	1 no
7.	High Vacuum Pump suitable for HT Transformers	1 no
8.	1000 LPH Hi- Vacuum Oil Filter Machine suitable Transformers	1no
9.	MIG / TIG Welding Machine	3 nos
10.	Welding Transformers	APR
11.	Radiography Setup	APR
12.	Calibrated Torque wrenches for Bus duct / Panel appli	3 nos
13.	Pedestal mounted Drill Machine (upto 36 mm)	3 nos
14.	Pull Lifts & Ratchet hoist	APR
15.	Hydraulic crimping tool	2 no
16.	Hand crimping tools	Adequate num
17.	Electrical Tool Box	Adequate num
18.	Cable Drum Winch (SIZE WISE)	3 no
19.	Portable Compressor	2 nos
20.	Air Compressor for Maxi Gun	1 no
21.	Special Tools for EHV Cables	set
22.	Brazing Kit	set
23.	Electrical Connectors of various sizes	Adequate num

TENTATIVE LIST OF MAJOR ELECTRICAL TESTING INSTRUMENTS / EQUIPMENT TO BE ARRANGED BY CONTRACTOR AT HIS OWN COST.

SL. No	DESCRIPTION	RANGE	ACCURAC	QTY
1.	Motorised Megger 2.5 / 5 kV			3 no
2.	500 V / 1000V, (Hand operated) megger			5 no
3.	Transformer Oil Testing Kit (Motor operated)	0-100 KV		1 no
4.	Digital Multimeters			15 no
5.	Primary Injection Kit			2 no
6	Secondary Injection Kit			2 no
7	Relay Testing Kit			2 no
8	Tong Testers			Range Wise
9	HV Test Kit	0-50 kV		1 no
10	Micro ohm meter with 100Amps DC Source			1 no
11	Motor checker , TTR			1 no each
12	KELVIN DOUBLE BRIDGE			1 no
13	PPM Measuring Kit			1 no
14	Analog Multimeters			5 no
15	Single / three phase variac			2 no each
16	Decade Box / Rheostat			Range Wise
17	Phase Sequence Indicator			3 no
18	Dead Weight Tester	0-600Kg/cm ²	LC-0.5Kg/cm ²	2 no
19	Comparison test set	0-4 k g/cm ² 0-6 Kg/cm ² 0-10kg/cm ² 0-25Kg/cm ² 0-60Kg/cm ² 0-250 Kg/cm ²	+0.25%Lc-0.25	set
20	Variable DC regulated supply	0-30V DC	0.2%	1 no
21	Oil bath with thermostat Stirrer and sub-standard Glass Thermometers in Multiple ranges	0-300 Degree Cel.		2 no

22	Glass U tube mercury manometer with standard steel Scale having leveling arrangement	0-760 mm		2 no
23	mA/mV source with Digital display	0-200 mA/200mV		2 no

TENDER - SPECIFICATIONS

VOLUME- IB (SCC)



Bharat Heavy Electricals Limited
(A Govt. Of India Undertaking)
Power Sector – Northern Region,
Plot No. 25 , Sector - 16A ,
Distt. Gautam Budh Nagar, NOIDA – 201 301(INDIA)

Rev 00
6th JULY
2010

SPECIAL CONDITIONS OF CONTRACT (SCC)

(Document No PS:MSX:SCC)

BHARAT HEAVY ELECTRICALS LIMITED



SPECIAL CONDITIONS OF CONTRACT (SCC)

Contents

SN	DESCRIPTION	Chapter	No. OF PAGES
1	General Intent of the Specifications	Chapter-I	
2	General Services to be rendered by the Bidder	Chapter-II	
3	General Technical Requirements (Codes and Standards)	Chapter-III	
4	Obligations of Contractor (In respect of Tools, Tackles, Consumables, etc employment of supervisory staff and workmen)	Chapter-IV	
5	Responsibilities of Contractor (In respect of employment of Labour, Supervisory staff, etc)	Chapter-V	
6	Material Handling, Storage, Preservation, etc	Chapter-VI	
7	Drawings and Documents	Chapter-VII	
8	Inspection and Quality	Chapter-VIII	
9	HSE & OHSAS Obligations	Chapter-IX	
10	RA Bill Payment	Chapter-XI	
11	Performance Monitoring	Chapter-XII	
12	Suspension of Business Dealings	Chapter-XII	

SPECIAL CONDITIONS OF CONTRACT (SCC)

Chapter - I : General Intent of Specifications

1.0	INTENT OF THE SPECIFICATION
1.1	The intent of this erection specification is to provide services for execution of the project according to most modern and proven techniques and codes. The omission of specific reference to any method, equipment or material necessary for the proper and efficient services towards installation of the plant shall not relieve the contractor of the responsibility of providing such services / facilities to complete the work or portion of work awarded to him. The quoted / accepted rates / price shall deem to be inclusive of all such contingencies.
1.2	The work shall conform to dimensions and tolerances given in various drawings and documents that will be provided during erection. If any portion of works is found to be defective in workmanship and not conforming to drawings / documents or other stipulations, the contractor shall dismantle and re-do the work duly replacing the defective materials at their own cost, failing which recoveries, as determined by BHEL, shall be effected from contractor's bills.
1.3	It is not the intent of this specification to specify herein all the details of erection and commissioning. However, the system shall conform in all respects to high standards of quality and workmanship for performing the required duties in a manner acceptable to purchaser who will interpret the meaning of drawings and specifications and shall be entitled to reject any work or material, which in his judgments is not in full accordance herewith.
1.4	The omission of specific reference to any fabrication / erection or other method, equipment or material necessary for proper and efficient working of the plant shall not relieve the tenderer of the responsibility of providing such facilities to complete the work at quoted rates. Any mismatch/ defect found due to mistake in fabrication / erection shall have to be rectified by the vendor free of cost. Inspection by BHEL/Customer does not relieve vendor of his responsibility of executing quality erection.
1.5	The work covered under this specification is of highly sophisticated nature, requiring the best quality workmanship, supervision, engineering and construction management. The contractor should ensure proper planning and successful and timely completion of the work to meet the overall project schedule. The contractor must deploy adequate quantity of tools & plants, modern / latest construction aids etc. He must also deploy adequate trained, qualified and experienced supervisory staff and skilled personnel.

SPECIAL CONDITIONS OF CONTRACT (SCC)

Chapter - I : General Intent of Specifications

1.6	Contractor shall erect and commission all the equipments and auxiliaries as per the sequence & methodology prescribed by BHEL depending upon the technical requirements. Availability of materials and fronts will decide this. BHEL Engineer's decision regarding correctness of the work and method of working shall be final and binding on the contractor. No claims for extra payment from the contractor will be entertained on the ground of deviation from the methods / sequence adopted in erection of similar sets elsewhere.
1.7	Following shall be the minimum responsibility of contractor and have to be provided within finally accepted rates / prices:
1.7.1	Provision as required of all types of labour, supervisors, engineers, watch and ward, tools & tackles, calibrated IMTEs (Inspection, measuring and testing equipment) as specified and otherwise required for the work, consumables for erection, testing and commissioning including material handling
1.7.2	Achieving Proper out-turn / Turn-over as per BHEL plan and commitment.
1.7.3	Completion of work as per BHEL Schedule
1.7.4	Good quality and accurate workmanship for proper performance of the equipment
1.7.5	Repair and rectification
1.7.6	Preservation / Re-conservation of all components during storage / erection / commissioning till handing over.

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter - II : General Services to be rendered by the Bidder

2.0	GENERAL SERVICES TO BE RENDERED BY THE BIDDER
2.1	Services for construction, fabrication, equipment erection testing as well as trial run & commissioning of various equipment and accessories under the contract shall include but not be limited to the following:
2.2	Issuing materials from store/open yard from time to time for erection as per the construction programme. The Contractor shall be the custodian of all the materials issued till the plant/equipment is officially taken over by the owner / BHEL after complete erection any successful trial run & commissioning.
2.3	Transport of material to their respective places of erection and erection of the complete plant & equipment as supplied under this specification.
2.4	Trial run and commissioning of individual equipment / sub-systems to the satisfaction of Owner/BHEL.
2.5	Deployment of all skilled and unskilled manpower required for erection, supervision of erection, watch & ward, commissioning and other services to be rendered under this specification.
2.6	Deployment of all erection tools & tackle, construction machinery, transportation vehicles and all other implements in adequate number and size, appropriate for the erection work to be handled under scope of this specification except otherwise specified.
2.7	Supply of all consumables, eg welding electrodes, cleaning agents, diesel oil, lubricant etc as well as materials required for temporary supports, scaffolding etc as necessary for such erection work, unless specified other wise.
2.8	Providing support services for the contractor's erection staff eg construction of site offices, temporary stores, residential accommodation and transport to work site for erection personnel, watch and ward for security and safety of the materials under the Contractor's custody etc. as required.
2.9	Maintaining proper documentation of all the site activities undertaken by the Contractor as per the proforma mutually agreed with BHEL, Submission of monthly progress reports and any such document as and when desired by BHEL/owner, taking approval of all statutory authorities, as applicable for respective portions of work fall under the jurisdiction of such statutes of laws.
2.10	Any other service, although not specifically called for but required for a contract of the size and nature indicated in the specification.

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter - III : General Technical Requirements (Codes and Standards)

3.0	GENERAL TECHNICAL REQUIREMENTS (CODES AND STANDARDS)
3.1	Except where otherwise specified, the plant/equipment shall comply with the appropriate Indian Standard or an agreed internationally accepted Standard Specification as mentioned elsewhere in contract specifications, each incorporating the latest revisions at the time of tendering. Where no internationally accepted standard is applicable, the Bidder shall give all particulars and details as necessary, to enable BHEL to identify all of the plant/equipment in the same detail as would be possible had there been a Standard Specification.
3.2	Where the Bidder proposes alternative codes or standards he shall include in his tender one copy (in English) of each Standard Specification to which materials offered shall comply. In such case, the adopted alternative standard shall be equivalent or superior to the standards mentioned in the specification.
3.3	In the event of any conflict between the codes and standards referred above, and the requirements of this specification, the requirements which are more stringent shall govern.
3.4	Tools used during erection and commissioning shall not be accepted except with the specific approval of the Engineer.

SPECIAL CONDITIONS OF CONTRACT (SCC)

Chapter - IV : Obligations of Contractor

4.0	OBLIGATIONS OF CONTRACTOR
4.1	CONSUMABLES & OTHER ITEMS
4.1.1	The contractor shall provide within finally accepted price / rates, all consumables (excepting those indicated in BHEL scope) like welding electrodes (including alloy steel and stainless steel), filler wires, TIG filler wires (over & above as supplied by the unit along with the plant materials, which will be given free of cost to bidder), gases (inert, welding, cutting), soldering material, dye penetrants, radiography films, etc. Other erection consumables such as tapes, jointing compound, grease, mobile oil, M-seal, Araldite, petrol, CTC / other cleaning agents, grinding and cutting wheels are to be provided by the contractor. Steel, packers, shims, wooden planks, scaffolding materials hardware items etc required for temporary works such as supports, scaffoldings are to be arranged by the contractor. Sealing compounds, gaskets, gland packing, wooden/concrete sleepers, for temporary work, required for completion of work except those which are specifically supplied by manufacturing unit are also to be arranged by the contractor.
4.1.2	All the shims, gaskets and packing, which go finally as part of plant equipment, shall be supplied by BHEL free of cost.
4.1.3	It shall be the responsibility of the contractor to plan the activities and store sufficient quantity of consumables. Non-availability of any consumable materials or equivalent suggested by BHEL cannot be considered as reason for not attaining the required progress or for additional claim.
4.1.4	TIG Filler wire for Boiler and Filler wires for Electrodes for P91/T91 piping: These shall be supplied by BHEL free of cost as supplied by BHEL Manufacturing Units as part of regular supply. Required quantity as arrived at by calculation / standards will only be supplied. It would be the contractors' responsibility to account for the consumption of these filler wires. Additional consumption beyond standard / calculated quantity will be at cost recovery basis only unless and otherwise accounted for. Surplus quantity of TIG filler wire, if any, shall be properly stored and returned to BHEL stores
4.1.5	It shall be the responsibility of the contractor to obtain prior approval of BHEL, regarding suppliers, type of electrodes etc before procurement of welding electrodes. On receipt of electrodes at site these shall be subjected to inspection and approval by BHEL. The contractor shall inform BHEL details regarding type of electrodes, batch number, date of expiry etc and produce test certificate for each lot / batch with correlation of batch / lot number with respective test certificate. No electrode without a valid test certificate will to be used.

SPECIAL CONDITIONS OF CONTRACT (SCC)

Chapter - IV : Obligations of Contractor

4.1.6	BHEL reserves the right to reject the use of any consumable including electrodes, gases, lubricants / special consumables if it is not found to be of the required standard / make / purity or when shelf life has expired. Contractor shall ensure display of shelf life on consumable wherever required and records maintained.
4.1.7	Storage of all consumables including welding electrodes shall be done as per requirement / instruction of the Engineer by the contractor at his cost.
4.1.8	In case of improper arrangement for procurement of any consumable, BHEL reserves the right to procure the same from any source and recover the cost from the Contractor's first subsequent bill at market value plus the departmental charges of BHEL from time to time. Postponement of such recovery is normally not permitted. The decision of Engineer in this regard shall be final and binding on the Contractor.
4.1.9	All lubricants and chemicals required for pre-commissioning, commissioning, testing, preservation and lubricants for trial runs of the equipment shall be supplied by BHEL / BHEL's client. All services including labour and T&P will be provided by the contractor for handling, filling, emptying, refilling etc. The consumption of lubricants / chemicals shall be properly accounted for. Surplus material if any shall be properly stacked/tagged and returned to BHEL/ CUSTOMER stores at no extra cost to BHEL. BHEL reserves the right to recover costs for wastage by the contractor.
4.1.10	Transportation of oil drums, from stores, filling of oil for flushing, first filling, subsequent changeover if any, topping/making up till the unit is fully commissioned and handed over to customer is included in scope of this contract. The contractor shall have to return all the empty drums to BHEL / BHEL's client store at no extra cost. Any loss / damage to above drums shall be to contractor's account.
4.1.11	All charges on account of taxes, duties, any charges etc & other duties on materials obtained from any source for carrying out the works in the scope of the contractor shall be borne by the contractor.
4.2	TOOLS AND PLANTS / MEASURING AND MONITORING EQUIPMENT (MMEs)
4.2.1	T&Ps and MMEs to be provided by Contractor
4.2.1.1	All T&Ps and MMEs excepting those specifically indicated in BHEL scope are to be provided by the Contractor. Contractor has to make his own arrangement at his cost for completing the formalities, for bringing their materials, plants and equipments at site for the execution of work under this contract.

SPECIAL CONDITIONS OF CONTRACT (SCC)

Chapter - IV : Obligations of Contractor

4.2.1.2	All suitable cranes, lifting and transport equipments for material handling at stores/yard/siding of BHEL/Customer are included in scope. BHEL's cranes will not be available for this purpose unless otherwise specifically permitted as per contract conditions
4.2.1.3	All T&Ps to be deployed by the contractor shall have the approval of BHEL Engineer with regard to brand, quality and specification.
4.2.1.4	Indicative list of Major T&Ps in the scope of Contractor are given in the Technical Conditions of Contract. Bidders to note that these are only indicative and as such all other T&P necessary for timely and satisfactory completion of work in scope shall be mobilized by Contractor
4.2.1.5	Timely deployment of adequate T&Ps is the responsibility of the contractor. The contractor shall be prepared to augment the T&P at short notice to match the planned programme and to achieve the milestones.
4.2.1.6	Contractor shall maintain and operate his tools and plants in such a way that major breakdowns are avoided. In the event of major breakdown, contractor shall make alternative arrangements expeditiously so that the progress of work is not hampered.
4.2.1.7	In the event of contractor failing to arrange the required tools, plants, machinery, equipment, material or non-availability of the same owing to breakdown, BHEL will make alternative arrangement at the risk and cost of the contractor. Decision of BHEL shall be final and binding on the contractor
4.2.1.8	The T&P to be arranged by the contractor shall be in proper working condition and their operation shall not lead to unsafe condition. The movements of cranes, and other equipment should be such that no damage / breakage occurs to foundations, other equipments, material, property and men. All arrangements for the movement of the T&P etc shall be the contractor's responsibility.
4.2.1.9	Use of welding generators/ rectifiers only shall be permitted for welding. Use of welding transformers will be subject to specific approval of BHEL engineer.
4.2.1.10	The contractor at his cost shall carry out periodical testing of his construction equipments. Test certificates shall be furnished to BHEL.
4.2.1.11	Contractor shall ensure deployment of serviced and healthy T&Ps including cranes, lifting tackles, wire ropes, manila ropes, winches and slings etc. History card and maintenance records for major T&Ps will be maintained by the contractor and will be made available to BHEL Engineer for inspection as and when required. Fitness certificate / Test Certificates of T&P shall have to be submitted before it is put in use. Identification for such T&Ps will be done as per BHEL Engineer's advice.

SPECIAL CONDITIONS OF CONTRACT (SCC)

Chapter - IV : Obligations of Contractor

	BHEL reserves the right to permit only new slings up to 20 mm and lifting tackles up to 3 MT capacities.
4.2.1.12	Contractor shall ensure deployment of reliable and calibrated MMEs (Inspection measuring and Monitoring equipment). The MMEs shall have test / calibration certificates from authorized / Government approved / accredited agencies traceable to National / International standards. Each MME shall have a label indicating calibration status i.e. date of calibration, calibration agency and due date for calibration. A list of such instruments deployed by contractor at site with its calibration status is to be submitted to BHEL Engineer for control.
4.2.1.13	Re-testing / re-calibration shall also be arranged at regular intervals during the period of use as advised by BHEL Engineer within the contract price. The contractor will also have alternate arrangements for such MME so that work does not suffer when the particular instrument is sent for calibration. If any MMEs not found fit for use, BHEL shall have the right to stop the use of such item. It will be necessary for the contractor to deploy proper item. Any readings taken by the defective instrument will be recalled and repeat the readings taken by that instrument with a proper one. In case he fails to do so, BHEL may deploy MMEs and retake the readings at contractor's cost.
4.2.1.14	BHEL shall have lien on all T&P, MMEs and other equipment of the contractor brought to the site for the purpose of erection, testing and commissioning. BHEL shall continue to hold the lien on all such items throughout the period of contract / extended period. The contractor and / or his sub-contractors, without the prior written approval of the Engineer, shall remove no material brought to the site.
4.2.1.15	The month wise T&P deployment plan to execute the work is to be submitted as per relevant format as per the instruction of BHEL. It shall be the contractor's responsibility to deploy the required T&P, for timely and successful completion of the job, to any extent.
4.2.2	Obligations in respect of T&Ps and MMEs provided by BHEL
4.2.2.1	T&P / MMEs being provided by BHEL to sub-contractor free of hire charges shall be shared by other subcontractors working for BHEL at site and the allotment done by BHEL Engineer shall be final and binding.
4.2.2.2	BHEL T&P will be issued in basic assembled condition. Additional loose components / sub-assemblies / attachments as and when necessary, will be issued by BHEL. Assembly of such additional loose components/sub-assemblies/ attachments is in contractor's scope.
4.2.2.3	In case of non-availability of the T&Ps to be provided by BHEL due to breakdown, major overhauls, distribution pattern or any other reason, the contractor shall plan /

SPECIAL CONDITIONS OF CONTRACT (SCC)

Chapter - IV : Obligations of Contractor

	amend / alter his activities to meet erection / commissioning targets in consultation with BHEL.
4.2.2.4	void
4.2.2.5	The contractor shall engage trained and experienced operators for the operation of BHEL's T&Ps. Their skill / performance will be checked by BHEL Engineer before they are allowed to operate the same. However checking of skills by BHEL does not absolve the contractor of his responsibilities for proper and safe handling of equipment, consistent good performance of operators and regular performance evaluation of operators.
4.2.2.6	<p>The day to day operation and maintenance of BHEL's T&Ps (Other than cranes) shall be carried out by contractor as per manufacturer's / BHEL's maintenance schedule at his cost. The contractor shall arrange, at his own cost, trained operators, fuel and other consumables for their operation. BHEL shall arrange all spares needed for upkeep of major T&Ps provided like Huck Bolting Machine*, DG Set, Induction Machine and Hydraulic Test pumps. The contractor has to arrange for fixing of the spares; supervision in specialized cases will be provided by BHEL. For upkeep of all other T&Ps supplied by BHEL, spares shall be arranged by the Contractor. BHEL supplied T&Ps shall be maintained in good working condition during the entire period of use. T&Ps in defective / damaged condition shall be rectified promptly to the full satisfaction of BHEL engineer. Contractor shall maintain records for maintenance of major T&Ps. These shall be made available for inspection whenever required. In case of any lapses on the part of the contractor, BHEL at its own discretion shall get the servicing / repair of equipment done at the risk and cost of the contractor along with BHEL overheads. Further, if there are breakdowns / damages due to negligence of the contractor, the complete service / repair charges and cost of all the spares damaged with BHEL overheads shall be recovered from contractor's RA bills.</p> <p>*: for operation and maintenance of ESP Huck bolting machine, BHEL shall provide the basic power rig and hose. Balance toolings ie Guns, chuck jaws etc are to be arranged by contractor.</p>
4.2.2.7	void
4.2.2.8	Increasing / shortening of the crane boom to suit work requirements shall have to be arranged by the indenting contractor at his cost including restoration to a state as directed by BHEL. All necessary manpower tools, support, consumables, illumination etc. will have to be arranged by contractor at his cost. If required,

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter - IV : Obligations of Contractor

	contractor has to return the crane with original boom.
4.2.2.9	The area and infrastructure development of the area to be carried out by the customer. However in construction projects of this magnitude it is possible that all the areas / approaches may not be ready. In such cases backfilling of approaches where ever necessary, consolidation of ground and arrangement of sleepers / sand bag filling etc for safe operation / movement of equipment including cranes / trailers etc shall be the responsibility of the contractor at his cost. No compensation on this account shall be payable.
4.2.2.10	In the event of contractor not using and maintaining BHEL T&Ps according to BHEL's instructions. BHEL will have the right to withdraw such item without any notice and no claim in this regard shall be entertained and contractor shall be responsible for delay in execution on this account.
4.2.2.11	The contractor shall furnish regular utilization report of the BHEL T&Ps, as per requirement of BHEL.
4.2.2.12	Any loss / damage to any part of BHEL T&Ps and MMEs shall be to the contractor's account and any expenditure on these accounts by BHEL will be recovered from the contractor's bill in case the contractor fails to make good the loss.
4.2.2.13	It shall be responsibility of the contractor to take delivery of T&Ps and MMEs from stores or place of use by other contractor at project site, transport the same to site and return the same to BHEL store / place as intimated by Engineer in project site in good working conditions after use.
4.2.2.14	The contractor shall return BHEL T&Ps and MMEs issued to him in good working condition as and when desired by BHEL (on completion or reduction of workload). If contractor delays return of T&P and MME, hire charges as applicable shall be levied by BHEL from time, it was requisitioned till the time of actual return. T&Ps and MMEs returned in damaged / unserviceable condition shall be got repaired by BHEL at its own discretion and entire cost of repair with BHEL overheads shall be recovered from the contractor.
4.2.2.15	Replacement cost including BHEL overheads in respect of irreparable / completely damaged / non return of T&Ps and MMEs shall be recovered from the contractor's running / final bills

SPECIAL CONDITIONS OF CONTRACT (SCC)

Chapter - IV : Obligations of Contractor

4.2.2.16	Obligations in respect of Cranes provided by BHEL
a)	BHEL will make available the cranes (as per Technical Conditions of Contract) free of charge to the contractor on sharing basis mainly for the purposes enumerated/indicated therein. BHEL cranes have to be shared with other agencies / contractors of BHEL. The allocation of cranes shall be the discretion of BHEL engineer, which shall be binding on the contractor.
b)	BHEL Cranes may be initially issued in basic assembled condition. Any alteration/addition like boom reduction / extension, assembly of components/sub-assemblies needed for modulating the capacity/reach/other features of cranes and restoration to the state as directed by BHEL shall be the contractor's responsibility.
c)	<p>In case the BHEL cranes are not covered under AMC of BHEL, then the day-to-day upkeep and running maintenance like filling / topping up of lubricants, changing filters, etc including repair of self starter and dynamo of these cranes shall be the responsibility of the contractor. If on checking it is found that the same is not followed, BHEL will exercise its right to get the job/works done at the risk and cost of contractor.</p> <p>In case BHEL cranes are covered under AMC awarded by BHEL, then the day-to-day upkeep and running maintenance as described above are excluded from scope. However any additional helpers if any required during Preventive/Breakdown Maintenance, Assembly/disassembly shall be provided by contractor at no extra cost.</p> <p>BHEL may also provided cranes through crane hiring agencies in which case the day-to-day upkeep and running maintenance shall be excluded from scope of contractor.</p>
d)	Minor consumables like cotton cloth, cotton waste, etc is to be supplied by Contractor. All spares and lubricants/grease is excluded from scope. Contractor to give the requirements of these items well in advance in case the cranes provided by BHEL are BHEL owned cranes.
e)	Unless otherwise specified, trained operators for BHEL owned cranes shall be provided by the contractor. These operators should possess valid license for heavy vehicle.
f)	BHEL cranes will be withdrawn for regular and capital maintenance as per the respective schedule of maintenance. As far as possible such schedules will be intimated to the contractor in advance and may be adjusted depending on the work requirements at site. However no claim whatsoever will be entertained on account

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter - IV : Obligations of Contractor

	of non-availability of cranes.
g)	Where the services of the cranes provided by BHEL are to be shared by other agencies/ contractors of BHEL, the contractor's responsibilities defined above will also be apportioned accordingly to the beneficiary agency. Working arrangements in this regard will be done at site by BHEL engineer and in any case his decision shall be final and binding.
h)	Major breakdowns will be attended to by BHEL. However, in case of breakdowns or damages due to negligence of the contractor, the complete service/repair charges including cost of spares shall be to the account of the contractor, along with BHEL overheads.
4.2.2.17	Obligations in respect of Construction Lift/Elevators provided by BHEL
a)	The total erection including commissioning, maintenance, statutory clearances shall be included in scope of work. Supervision by the original equipment supplier or their authorized agency shall be arranged for by BHEL, in case found necessary.
b)	All day to day and routine maintenance and checking is to be carried out by the contractor as per the recommendations of the supplier. He should periodically check the brakes and carry out the all works to ensure the safety of all those using the lift/elevator. BHEL shall arrange spares required for upkeep of Construction lift/elevator
c)	The construction lift/elevator should never be overloaded as this can lead to serious accidents. Ensuring all safety aspects in operation of the lift shall be the responsibility of the contractor. Erection of all the required number of landing platforms is included in scope. Landing platforms are to be provided with proper barricades and hand railings.
d)	After completion of contractual scope of work or as per BHEL advice, the temporary elevator/lift shall be dismantled and handed over to BHEL neatly identified/tagged. Temporary structures/platforms etc erected for the elevators/lifts are also to be dismantled and materials to be returned to stores as applicable. The construction and dismantling of the foundations required for the construction/elevator lifts is included in the scope of the contractor.

SPECIAL CONDITIONS OF CONTRACT (SCC)
**Chapter – V : Responsibilities of Contractor in respect of Labour,
 Supervisory Staff, etc.**

5.0	RESPONSIBILITIES OF CONTRACTOR IN RESPECT OF LABOUR, SUPERVISORY STAFF, ETC.
5.1	Refer relevant clauses of General Conditions of Contract (GCC) also in this regard
5.2	The contractor shall deploy all the necessary skilled/semiskilled/ unskilled labour including highly skilled workmen etc. These workmen should have previous experience on similar job. They shall hold valid certificates wherever necessary. BHEL reserves the right to insist on removal of any employee of the contractor at any time if he is found to be unsuitable and the contractor shall forthwith remove him.
5.3	Contractor shall also comply with the requirements of local authorities/ project authorities calling for police verification of antecedents of the workmen, staff etc.
5.4	It is the responsibility of the contractor to engage his workmen in shifts and or on overtime basis for achieving the targets set by BHEL. This target may be set to suit BHEL's commitments to its customer or to advance date of completion of events or due to other reasons. The decision of BHEL in regard to setting the erection and commissioning targets will be final and binding on the contractor.
5.5	Contractor shall provide at different elevation suitable arrangement for urinal and drinking water facility with necessary plumbing & disposal arrangement including construction of septic tank. These installations shall be maintained in hygienic condition at all times.
5.6	NOT APPLICABLE
5.7	NOT APPLICABLE
5.8	NOT APPLICABLE
5.9	BHEL / customer may insist for witnessing the regular payment to the labour. They may also like to verify the relevant records for compliance with statutory requirements. Contractor shall enable such facilities to BHEL / Customer.
5.10	Contractor shall deploy only qualified and experienced engineers/ supervisors. They shall have professional approach in executing the work.
5.11	The contractor's supervisory staff shall execute the work in the most professional manner in the stipulated time. Accuracy of work and aesthetic finish are essential part of this contract. They shall be responsible to ensure that the assembly and workmanship conform to dimensions and tolerances given in the drawings/instructions given by BHEL engineer from time to time.

SPECIAL CONDITIONS OF CONTRACT (SCC)

Chapter – V : Responsibilities of Contractor in respect of Labour, Supervisory Staff, etc.

5.12	The supervisory staff employed by the contractor shall ensure proper outturn of work and discipline on the part of the labour put on the job by the contractor. Also in general they should see that the works are carried out in a safe and proper manner and in coordination with other labour and staff employed directly by BHEL or other contractors of BHEL or BHEL's client.
5.13	It is the responsibility of the contractor to arrange gate pass for all his employees, T&P etc for entering the project premises. Necessary coordination with customer officials is the responsibility of the contractor. Contractor to follow all the procedures laid down by the customer for making gate passes. Where permitted, by customer / BHEL, to work beyond normal working hours, the contractor shall arrange necessary work permits for working beyond normal working hours.
5.14	The actual deployment will of Labour and Engineer/supervision staff shall be so as to satisfy the erection and commissioning targets set by BHEL. If at any time, it is found that the contractor is not in a position to deploy the required engineers/supervisors/workmen due to any reason, BHEL shall have the option to make alternate arrangements at the contractor's risk and cost. The expenditure incurred along with BHEL overheads thereon shall be recovered from the contractor
5.15	Contractor shall not deploy women labour at night.

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter – VI: Material Handling, Storage & preservation

6.0	MATERIAL HANDLING, STORAGE AND PRESERVATION ETC
6.1	MATERIAL HANDLING AND STORAGE
6.1.1	All the equipments/materials furnished under this contract shall be received from the project stores, sheds / storage yards and transported to pre assembly area / erection site and stored in the storage spaces in a manner so that they are easily retrievable till the contractor erects them. While drawing/lifting material from BHEL / customer stores, the contractor shall ensure that the balance / other materials are stacked back immediately. No claim is admissible on this account
6.1.2	While BHEL will endeavor to store / stack / identify materials properly in their open / close / semi closed / tarpaulins covered storage yard / shed, it shall be contractor's responsibility to assist BHEL in identifying materials well in time for erection. They should take the delivery of the same, following the procedure indicated by BHEL, and transport the material safely to pre-assembly yard / erection site in time, according to program.
6.1.3	The contractor shall take delivery of components, equipment / consumables from storage area after getting the approval of BHEL Engineer on standard indent forms.
6.1.4	The contractor shall identify and deploy necessary Engineers / supervisors / workmen for the above work in sufficient number as may be needed by BHEL, for areas covering their scope.
6.1.5	All the equipment shall be handled very carefully to prevent any damage or loss. No untested wire ropes / slings etc. shall be used for unloading / handling. The equipment shall be properly protected to prevent damage either to the equipment or to the floor where they are stored. The equipment from the stores shall be moved to the actual location at the appropriate time so as to avoid damage of such equipment at site.
6.1.6	Contractor shall ensure that while lifting slings shall be put over the points indicated on the equipment or as indicated in the manufacturer's drawings. Slings / shackles of proper size shall be used for all lifting and rigging purposes. All care shall be taken to safe guard the equipment against any damage. Dragging of piping / valves should be avoided. In case of any damage the cost shall be covered from the contractor.
6.1.7	Approach road conditions from the stores / yards to the erection site may not be equipped and ideal for smooth transportation of the equipment. Contractor

SPECIAL CONDITIONS OF CONTRACT (SCC)

Chapter – VI: Material Handling, Storage & preservation

	may have to be adequately prepared to transport the materials under the above circumstances without any extra cost. . The contractor may familiar himself with soil conditions at site.
6.1.8	Contractor shall be responsible for examining all the plant and materials issued to him and notify the Engineer immediately of any damage, shortage, discrepancy etc before they are moved out of the stores / storage area. The contractor shall be solely responsible for any shortages or damages in transit, handling, storage and erection of the equipment once received by him. As the erection work will be spread in different areas / locations of the project, contractor has to arrange sufficient number of watch / ward personal to avoid any pilferage of material
6.1.9	The contractor shall maintain an accurate and exhaustive record-detailing out the list of all equipment received by him for the purpose of erection and keep such record open for the inspection of the engineer at any time.
6.1.10	All the material in the custody of contractor and stored in the open or dusty locations must be covered with suitable weather proof / fire retardant covering material wherever applicable and shall be blocked up on raised level above ground. All covering materials including blocks and sleeper shall be arranged by the contractor at his cost.
6.1.11	If the material belonging to the contractor are stored in area other than those earmarked for his operation the engineer will have the right to get it moved to the area earmarked for the contractor at the contractors risk and cost.
6.1.12	The contractor shall be responsible for making suitable indoor storage facilities to store all equipment (drawn by the contractor from BHEL / customer stores), which require indoor storage till the time of their installation. The Engineer will direct the contractor in this regard, which item in his opinion will require indoor storage, and the contractor shall comply with Engineer's decision.
6.1.13	The contractor shall ensure that all surplus / damaged / scrap / unused material, packing wood / containers/ special transporting frames etc are returned to BHEL at a place in project area identified by the Engineer. The contractor will maintain an account for all items received and returned to BHEL. Any shortage in returning such items shall be chargeable to the contractor except allowable wastage for packing wood only.
6.1.14	The contractor shall hand over all parts / materials remaining extra over the normal requirement with proper identification tags to the stores as directed by the concerned BHEL engineer.

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter – VI: Material Handling, Storage & preservation

6.1.15	The contractor shall ensure that all the packing materials and protective devices installed on equipment during transit and storage are removed before installation.
6.1.16	It shall be the responsibility of the contractor to keep the work / storage areas in neat, tidy and working conditions. All surplus/unusable packing and other materials shall be removed and deposited at location(s) specified by BHEL within the project premises. If required weighing of the same within the project premises will have to be carried out.
6.2	PRESERVATION OF COMPONENTS
6.2.1	After taking delivery from BHEL / customer's stores, plant materials storage shall be subjected to the following protection besides other provisions indicated in these specifications elsewhere.
6.2.1.1	Items stored outdoors shall be stacked up at least six inches (6") off the ground. Items should not be stored in a low lying area where water logging is a possibility. Contractor should have sufficient numbers of wooden / concrete / steel sleepers for the job.
6.2.1.2	Motors, valves, electrical equipment, control equipment and instruments, and special or precision items requiring special care, etc shall be stored indoors. Motor windings shall be kept dry by use of external heat or space heaters.
6.2.1.3	Bearings and other wearing surfaces of plant materials shall be protected against corrosion and kept clean and should be regularly monitored.
6.2.1.4	Insulation materials shall be stored indoors or otherwise protected against getting wet/ damaged, using suitable measures and should be protected from direct rain.
6.2.2	It shall be the responsibility of the contractor to apply preservatives / touch up paints (primer) on equipment handled and erected by him till such time of final painting. It shall be contractor's responsibility to arrange for required paints (primer), thinners, labour, scaffolding materials, cleaning materials like wire brush, emery sheets, etc, cleaning of surface and provide one coat of preservatives / paints (primer) from time to time as decided by BHEL engineer. The accepted rate shall include this work also. It is to be noted that such painting may have to be done as and when required till such time the final painting is carried out.
6.2.3	The contractor shall effectively protect the finished work from action of weather and from damage or defacement and shall cover the finished parts then and there for their protection.

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter – VI: Material Handling, Storage & preservation

6.2.4	Any failure on the part of contractor to carry out works according to above clauses will entail BHEL to carry out the job from any other party and recover the cost from contractor.
--------------	--

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter – VII: Drawings and documents

7.0	DRAWINGS AND DOCUMENTS
7.1	The detailed drawings, specifications available with BHEL engineers will be made available to the contractor during execution of work at site. The contractor will also ensure availability of all drawings / documents at work place.
7.2	Necessary drawings to carry out the erection work will be furnished to the contractor by BHEL on loan, which shall be returned to BHEL Engineer at site after completion of work. Contractor shall ensure safe storage and quick retrieval of these documents.
7.3	The contractor shall maintain a record of all drawings and documents available with him in a register as per format given by BHEL Engineer. Contractor shall ensure use of pertinent drawings / data / documents and removal of obsolete ones from work place and returning to BHEL.
7.4	The data furnished in various annexure enclosed with this tender specification are only approximate and for guidance. However, the change in the design and in the quantity may occur as is usual in any such large scale of work. The contractors quoted rates shall be inclusive of the above factor
7.5	Should any error or ambiguity be discovered in the specification or information the contractor shall forthwith bring the same to the notice of BHEL before commencement of work. BHEL's interpretation in such cases shall be final and binding on the contractor.
7.6	Deviation from design dimensions should not exceed permissible limit. The contractor shall not correct or alter any dimension / details, without specific approval of BHEL.

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter – VIII: Inspection and Quality

8.0	INSPECTION AND QUALITY
8.1	Inspection, Quality Assurance, Quality Control
8.1.1	Preparation of quality assurance log sheets and protocols with customer/consultants/statutory authority, welding logs, NDE records, testing & calibration records and other quality control and quality assurance documentation as per BHEL engineer's instructions, is within the scope of work/specification. These records shall be submitted to BHEL/customer for approval from time to time.
8.1.2	The protocols between contractor and customer/ BHEL shall be made prior to installation for correctness of foundations, materials, procedures, at each stage of installation, generally as per the requirement of customer/ BHEL. This is necessary to ensure elimination of errors or keeping them within tolerable limits and to avoid accumulation and multiplication of errors.
8.1.3	<p>A daily log book should be maintained by every supervisor/engineer of contractor on the job in duplicate (one for BHEL and one for contractor) for detailing and incorporating alignment/clearance / centering / leveling readings and inspection details of various equipments etc.</p> <p>High pressure welding details like serial number of weld joints, welders name, date of welding, details of repair, heat treatment etc. will be documented in welding log as per BHEL Engineer's instructions.</p> <p>Record of radiography containing details like serial number of weld joints, date of radiography, repairs, if any, re-shots etc shall also be maintained as per BHEL Engineer's instructions.</p> <p>Record of heat treatments performed shall be maintained as prescribed by BHEL</p>
8.1.4	The performance of welders will be reviewed from time to time as per the BHEL standards. Welders' performance record shall be furnished periodically furnished for scrutiny of BHEL's Engineer. Corrective action as informed by BHEL shall be taken in respect of those welders not conforming to these standards. This may include removal/ discontinuance of concerned welder(s). Contractor shall arrange for the alternate welders immediately
8.1.5	All the welders shall carry identity cards as per the proforma prescribed by BHEL/Customer/Consultant. Only welders duly authorized by BHEL/customer/consultant shall be engaged on the work.

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter – VIII: Inspection and Quality

8.1.6	Contractor shall provide all the Measuring Monitoring Equipments (MMEs) required for completion of the work satisfactorily. These MMEs shall be of brand, quality and accuracy specified by BHEL Engineer and should have necessary calibration and other certificates as per the requirement of BHEL Engineer. Decision of BHEL Engineer regarding acceptance or otherwise of the measuring instruments/gauges/tools for the work under this specification, is final and binding on the contractor. BHEL may give an indicative list of MMEs required for this work and to be made available by the contractor. The list will be reviewed by BHEL and the contractor shall meet any augmentation needed wherever required.
8.1.7	It is the responsibility of the contractor to prove the accuracy of the testing/measuring/calibrating equipments brought by him based on the periodicity of calibration as called for in the BHEL's quality assurance standards/BHEL Engineer's instructions.
8.1.8	Any re-laying or re-termination of cables/re-erection of instruments/recalibration of instruments etc. required due to contractor's mistake or design requirement and found at any stage inspection, shall be carried out by the contractor at no extra cost.
8.1.9	BHEL, Power Sector Regions (PSNR/PSER/PSWR/PSSR) have already been accredited with ISO 9001 certification and as such this work is subject to various audits to meet ISO 9001 requirements. One particular aspect which needs special mention is about arrangement of calibration of instruments by the contractor. Contractor shall ensure deployment of reliable and calibrated MMEs (Measuring and Monitoring Equipments). The MMEs shall have test / calibration certificates from authorised / Government approved / Accredited agencies traceable to National / International Standards. Re-testing / recalibration shall also be arranged at regular intervals during the period of use as advised by BHEL Engineer within the contract price. The contractor will also have alternate arrangements for such MMEs so that work does not suffer when the particular equipment / instrument is sent for calibration. Also if any MMEs not found fit for use, BHEL shall have the right to stop the use of such item and instruct the contractor to deploy proper item and recall ie repeat the readings taken by that instrument, failing which BHEL may deploy MME and retake the readings at Contractor's cost.
8.1.10	Re-work necessitated on account of use of invalid MMEs shall be entirely to the contractor's account. He shall be responsible to take all corrective actions,

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter – VIII: Inspection and Quality

	including resource augmentation if any, as specified by BHEL to make-up for the loss of time.
8.1.11	In the courses of erection, it may become necessary to carry repeated checks of the work with instruments recently calibrated, re-calibrated. BHEL may counter/ finally check the measurements with their own MMEs. Contractor shall render all assistance in conduct of such counter/final measurements.
8.1.12	Total Quality is the watchword of the work and Contractor shall strive to achieve the Quality Standards, procedures laid down by BHEL. He shall follow all the instructions as per BHEL drawings and Quality Standards.
8.2	Stage Inspection By FES/QA Engineers
8.2.1	Apart from day-to-day inspection by BHEL Engineers stationed at Site and Customer's Engineers, stage inspection of equipments under erection and commissioning at various stages shall also be conducted by teams of Engineers from Field Engineering Services of BHEL's Manufacturing Units, Quality Assurance teams from Field Quality Assurance, Unit/Factory Quality Assurance and Commissioning Engineers from Technical Services etc. Contractor shall arrange all labour, tools and tackles etc along with proper access for such stage inspections free of cost.
8.2.2	Any modifications suggested by BHEL FES and QA Engineers' team shall be carried out. Claims of contractor, if any, shall be dealt as per Section 13, and provided such modifications have not arisen for reasons attributable to the contractor.
8.3	Statutory Inspection of Work
8.3.1	The work to be executed under these specifications has to be offered for inspection, at appropriate stages of work completion, to various statutory authorities as per Sudanese Laws for compliance with applicable regulations. The scope includes getting the approvals from the statutory authorities, which includes arranging for inspection visits of statutory authority periodically as per BHEL Engineer's instructions, arranging materials/documents for ground inspection, submitting co-related inspection reports, documents, etc and following up the matter with them. Contractor shall also make all arrangements for offering the Products / Systems for inspection at location, as applicable, to the concerned authority.

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter – VIII: Inspection and Quality

8.3.2	Contractor should be qualified to execute pressure parts & piping work coming under the purview of Sudanese law/ regulation, for which he should register himself with Sudanese authority concerned. Contractor also should be aware of the latest IBR regulations and Electricity Act, including the amendments thereof.
8.3.3	Contractor shall comply with 'Qualification Tests for welders engaged in welding of Boilers and Steam Pipes under Construction, Erection and Fabrication at Site .It shall be contractor's responsibility to obtain approval of Statutory Authorities, wherever applicable, for the conducting of any work which comes under the purview of these authorities, at his cost.
8.3.4	NOT APPLICABLE
8.4	The Quality Management System of BHEL, Power Sector Regions (PSNR/PSER/PSWR/PSSR) have already been certified and accredited under ISO 9002 standards in this regard. The basic philosophy of the Quality Management System is to define the organizational responsibility, work as per documented procedures, verify the output with respect to acceptance norms, identify the non-conforming product/ procedure and take corrective action for removal of non-conformance specifying the steps for avoiding recurrence of such non-conformities, & maintain the relevant quality records. The non conformities are to be identified through the conduct of periodical audit of implementation of quality systems at various locations/stages of work. Suppliers/vendors of various products/services contributing in the work are also considered as part of the quality management system. .as such the contractor is expected not only to conform to the quality management system of BHEL but also it is desirable that they themselves are accredited under any quality management system standard.
8.5	Field Quality Assurance
8.5.1	Contractor shall carry out all activities conforming to the approved Field Quality Plan (FQP) as revised from time to time. Total quality shall be the watchword of the work and contractor shall strive to achieve the quality standards, procedures laid down by BHEL. He shall follow all the instructions as per BHEL drawings and quality standards. Contractor shall provide the services of quality assurance engineer as per the relevant clauses.

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter-IX:HSE & OHSAS

9.0	<p>OCCUPATIONAL HEALTH, SAFETY & ENVIRONMENT MANAGEMENT/ QUALITY ASSURANCE PROGRAMME : BHEL, Power Sector Regions (PSNR/ER/WR/SR) are each certified for ISO 9001. Quality of work to customer's satisfaction and fulfillment of system requirements are the essence of ISO 9001 certification. BHEL, PS Regions have HSE certification (ISO 14001 & OHSAS 18001) and therefore Contractor also shall organise/ plan/ perform all their activities to meet with the applicable requirements of these standards.</p>
9.1	<p>HSE (Health, safety & Environment): Contractor will comply with HSE (Health, safety & Environment) requirements of BHEL. HSE requirements in brief, are given below :-</p>
9.1.1	<p>Contractor will nominate one of their qualified and experienced employees as Safety Officer, who will be responsible for all HSE related issues of contractors work area. Safety Officer will have authority to stop any activity, in case he observes that the activity is not being carried out in safe manner. He will conduct surprise inspection as well as periodic inspection/drill (at least once in a month) and submit such reports to BHEL. He will conduct periodic meetings with supervisors of different working groups and explain HSE issues and use of PPEs to them. Reports of such meetings will be submitted to BHEL. Contractor will develop suitable work procedures based upon HSE guidelines and OCPs and implement it. Such work procedures will consist of Area of work, T&P Details, Work Procedure, PPE requirements etc.</p> <p>Contractor should highlight the requirement of safety to staff and labour through daily tool box meeting before start of the days job</p>
9.1.2	<p>The contractor shall ensure that proper job specific health check-up is done by medical professional for their employees during initial mobilization and thereafter if there is any change of job.</p>
9.1.3	<p>Following personnel protective equipments (PPEs), in adequate numbers, will be made available at site & their regular use by all concerned will be ensured :-</p> <ul style="list-style-type: none"> - HELMET - SAFETY GOGGLES & WELDING FACE SHIELDS - SAFETY BELTS AND PROTECTIVE NET FOR WORKING AT HEIGHT - SAFETY SHOES - EAR PLUG - ANY OTHER SAFETY EQUIPMENT REQUIRED FOR SAFE COMPLETION OF THE WORK

SPECIAL CONDITIONS OF CONTRACT (SCC)

Chapter-IX:HSE & OHSAS

9.1.4	Providing appropriate First Aid facilities for prompt treatment of injuries and illness at work place. Arranging training to contractor workmen/ employees for giving first aid.
9.1.5	Arranging ambulance in case of any emergency situation .
9.1.6	Identification of nearest hospital and health check-up of workmen/employees
9.1.7	Providing filtered drinking water at work place in cool container.
9.1.8	Providing Canteen, Rest Room, Washing facilities to the contracted employees as per provisions of Contract Labour Regulation Act 1970 (Chapter V).
9.1.9	Providing appropriate fire fighting equipment at designated work place and nominate a fire officer/warden adequately trained for his job.
9.1.10	Identification of nearest fire station and display contact telephone nos. / person's name around work places for cases of emergencies .
9.1.11	Providing adequate no. of 24 V sources and ensure that no hand lamps are operating at voltage level above 24 Volts.
9.1.12	Fulfilling safety requirements at all power tapping points.
9.1.13	Red & White caution tape of proper width(1.5 to 2 inch) to be used for cordoning unsafe area such as open trench, excavation area etc.
9.1.14	Providing contractors company logo on cloths /uniform/ proper identity cards with photographs, for correct identification of people working at project site .
9.1.15	High/ Low pressure welders to be identified with separate colour clothings. No welders will be deployed without passing appropriate tests and holding valid welding certificates. Approved welding procedure should be displayed at work place.
9.1.16	Displaying safe handling procedures for all chemicals such as lube oil, acid, alkali, sealing compounds etc , at work place .
9.1.17	All scaffolding/ platforms should be made from materials of appropriate quality/grade so that these are safe for use. It should be certified/declared safe for use by an experienced contractor person, before any scaffolding/platform is used.
9.1.18	All T&Ps/ MMEs should be of reputed brand/appropriate quality & must have valid test/calibration certificates bearing endorsement from competent authority of BHEL.
9.1.19	Ensure that the regulatory requirement of excessive weight limit (to carry/lift/ move weights beyond prescribed limits) for male and female workers are complied with.
9.1.20	Safety slogan, Safety/ Caution boards , wherever required to be displayed in consultation with BHEL.

SPECIAL CONDITIONS OF CONTRACT (SCC)

Chapter-IX:HSE & OHSAS

9.1.21	Take suitable measures for waste management and environment related laws/legislation as a part of normal construction activities. Compliance with the legal requirements on storage/ disposal of paint drums (including the empty ones), Lubricant containers, Chemical Containers, and transportation and storage of hazardous chemicals will be strictly maintained. Ensure proper cleanliness of work place, housekeeping and waste management (including proper waste disposal) on daily basis.
9.1.22	It is imperative on the part of the contractor to join and effectively contribute in joint measures such as tree plantation, environment protection, contributing towards social upliftment, conversion of packing woods to school furniture, keeping good relation with local populace etc.
9.1.23	The contractor shall carry out periodic air and water quality check and illumination level checking in his area of work place and take suitable control measure.
9.1.24	The Contractor is required to provide proper safety net systems where ever the hazard of fall from height is present as per instruction of BHEL Engineer. The safety nets shall be fire resistant, duly tested and shall be of ISI Mark and the nets shall be located as per site requirements to arrest or to reduce the consequences of a possible fall of persons working at different heights.
9.1.25	All applicable OCPs (Operational control procedures) will be followed by contractor as per BHEL instructions. This will be done as part of normal scope of work. List of such OCPs is given below . In case any other OCP is found to be applicable during the execution of work at site, then contractor will follow this as well, within quoted rate. These OCPs (applicable ones) will be made available to contractor during work execution at site. However for reference purpose, these are kept with Safety Officer of BHEL at the Power Sector Regional HQ, or available in downloadable format in the website, which may be refereed by contractor, if they so desire.
	■ OCP for safe handling of chemicals
	■ OCP for Electrical safety
	■ OCP for energy conservation
	■ OCP for safe welding and gas cutting operation
	■ OCP for fire safety
	■ OCP for safety in use of hand tools
	■ OCP for first aid
	■ OCP for food safety at canteen
	■ OCP for safety in use of cranes
	■ OCP for storage and handing of gas cylinders

SPECIAL CONDITIONS OF CONTRACT (SCC)

Chapter-IX:HSE & OHSAS

■	OCP for manual arc welding
■	OCP for safe use of helmets
■	OCP for good house keeping
■	OCP for working at height
■	OCP for safe excavation
■	OCP for safe filling of Hydrogen in cylinder
■	OCP for illumination
■	OCP for handling and erection of heavy metals
■	OCP for safe acid cleaning
■	OCP for safe alkali boil out
■	OCP for safe oil flushing
■	OCP for steam blowing
■	OCP for safe working in confined area
■	OCP for safe operation of passenger lift, material hoists & cages
■	OCP for Vehicle maintenance
■	OCP for safe radiography
■	OCP for waste disposal
■	OCP for working at night
■	OCP for blasting
■	OCP for DG Set
■	OCP for handling & storage of mineral wool
■	OCP for drilling, reaming and grinding(machining) etc.
■	OCP for hydraulic test
■	OCP for spray insulation
■	OCP for trial run of rotary equipment
■	OCP for stress relieving
■	OCP for material preservation
■	OCP for cable laying/tray work
■	OCP for electrical maintenance
■	OCP for transformer charging
■	OCP for safe handling of battery system
■	OCP for computer operation
■	OCP for storage in open yard
■	OCP for sanitary maintenance
■	OCP for batching
■	OCP for piling rig operation
■	OCP for gas distribution test

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter-IX:HSE & OHSAS

	<ul style="list-style-type: none"> ■ OCP for cleaning of hotwell / deaerator ■ OCP for electro-resistance heating ■ OCP for compressor operation ■ OCP for O&M of control of AC plant & system ■ OCP for air compressor ■ OCP for passivation ■ OCP for Safe EDTA Cleaning ■ OCP for Safe Chemical cleaning of Pre boiler system ■ OCP for Safe Boiler Light up ■ OCP for Safe Rolling and Synchronisation ■ OCP for Safe Loading of Unit
9.2	<p>SAFETY AND CLEANLINESS :</p> <p>The contractor shall take all necessary safety precautions and arrange for appropriate appliances as per discretion of BHEL or its authorised officials (Site Construction Manager) to prevent loss of human lives, injuries, to personnel engaged and damage to property. Before commencing the work, the contractor shall submit a “Safety Plan” to the above authorised BHEL official and obtain approval on the same. The safety plan shall indicate in detail the measures that would be taken by the contractor to ensure safety of men, equipment, materials and environment during execution of the work. This will also include an organization structure, role and responsibilities of the concerned key personnel, the safety practices that will be followed, PPEs deployed, plan for handling critical activities and emergencies.</p>
9.3	<p>If the contractor fails to take appropriate safety precautions or to provide necessary safety devices and equipment or to carry out instructions issued by the authorised BHEL official, BHEL shall have the right to take corrective steps at the risk and cost of the contractor.</p>
9.4	<p>During the course of construction, alternation or repairs, scrap with protruding nail, sharp edge etc and all other debris shall be kept clean from working areas, passage, ways and stairs in and around site.</p>
9.5	<p>Combustible scrap and debris shall be removed at regular intervals during the course of execution. Safe means shall be provided to facilitate such removal. The combustible scrap should be stored in safe place away from the plant materials to avoid fire accidents. The area shall be chosen in consultation with the Engineer and to be cordoned off.</p>
9.6	<p>Rigging equipment for materials handling shall be inspected prior to use in each shift and as necessary during its use to ensure that it is safe. Defective</p>

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter-IX:HSE & OHSAS

	rigging equipment will be removed from service.
9.7	Rigging equipment shall not be loaded in excess of its recommended safe working load. Rigging equipment, when not in use, shall be removed from the original work area so as not to present a hazard to employees.
9.8	Contractor shall notify the engineer, of his intention to bring on to site any equipment or any container, with liquid or gaseous fuel or other substance which may create a hazard. The Engineer shall have the right to prescribe the condition under which such equipment or container may be handled and used during the performance of the works and the contractor shall strictly adhere to such instructions. The Engineer shall have the right to inspect any construction tool and to forbid its use, if in his opinion it is unsafe. No claim due to such prohibition will be entertained.
9.9	Where it is necessary to provide and/or store petroleum products or petroleum mixture & explosives, the contractor shall be responsible for carrying out such provision / storage in accordance with the rules & regulations laid down in the relevant petroleum act, explosive act and petroleum and carbide of calcium manual, published by the chief inspector of explosives of India. All such storage shall have prior approval if necessary from the chief inspector of explosives or any other statutory authority. The contractor shall be responsible for obtaining the same.
9.10	Cylinders shall be moved by tilting and rolling them on their bottom edges. They shall not be intentionally dragged, struck or permitted to strike each other violently.
9.11	When cylinders are transported by powered vehicle they shall be secured in a vertical position.
9.12	All workmen of the contractor working on construction area shall wear safety shoes, hand gloves, safety helmets and safety belt as applicable. The contractor shall provide to its workforce and ensure the use of following personnel protective equipment as found necessary and as directed by BHEL.
9.12.1	Safety Helmets conforming to IS-2965 : 1984 or equivalent International Standards
9.12.2	Safety Belts conforming to IS-3521:1983 or equivalent International Standards
9.12.3	Safety Shoes conforming to IS-1989 : 1978 or equivalent International Standards

SPECIAL CONDITIONS OF CONTRACT (SCC)

Chapter-IX:HSE & OHSAS

9.12.4	Eye and face protection devices conforming to IS – 8620 : 1977 & IS – 8950 : 1978. or equivalent International Standards
9.12.5	Hand and body protection devices conforming to IS – 2575 : 1975 and IS – 6994 : 1973, IS – 8907 : 1970 & 8619 : 1977 or equivalent International Standards
9.13	The contractor shall insure his workmen against all accidents and the policy shall be presented to BHEL Engineer on demand. Other wise, BHEL will arrange the same and the expenditure towards this will be debited to the contractor. In case of a fatal or disabling injury accident to any person at construction site due to lapses by the contractor, the victim and/or his/her dependants shall be compensated by the contractor as per statutory requirements. However, if considered necessary BHEL shall have the right to impose appropriate financial penalty on contractor and recover the same from payments due to the contractor for suitably compensating the victim and/or his/her dependence before imposing any such penalty. Appropriate enquiry shall be held by BHEL giving opportunity to the contractor for presenting his case. Above safety conditions are not exhaustive but gives an idea for the contractor and contractor shall adhere to all safety precaution given by the Engineer at site.
9.14	The contractor shall arrange at his cost adequate lighting facilities e.g. flood lighting, hand lamps, area lighting etc. at various levels for safe and proper working operations during night hours at the work spot as well as at the pre-assembly area.
9.15	The contractor shall be responsible for provision of all the safety notices and safety equipment as enjoined on him by the application of relevant statutory regulation / provisions and/or as called upon by BHEL from time to time. He shall be held responsible for any violation of statutory regulations (local, state or central) and BHEL instruction that may endanger safety of men, equipment and material.
9.16	The contractor shall provide temporary fencing wherever required as a safety measure against accident and damage to properties. Suitable caution notices shall be displayed where access to any part is found to be unsafe and hazardous.
9.17	Contractor shall ensure safety of all the workmen, material and equipment either belonging to him or to others working at site. He shall observe safety rules and codes applied by BHEL without exception.

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter-IX:HSE & OHSAS

9.18	It will be the responsibility of the contractor to ensure safe lifting of the equipment, taking due precaution to avoid any accident and damage to other equipment and personnel. All requisite tests and inspection of handling equipment, tools & tackle shall be periodically done by the contractor. Defective equipment shall be removed from service. Any equipment shall not be loaded in excess of its recommended safe working load.
9.19	The contractor shall provide necessary first aid facilities for all his employees, representatives and workmen at site and BHEL shall have no obligation in this regard. The first aid boxes should be placed at various elevations so as to make them available within the reach and at the quickest possible time. The contractor should conduct periodical first –aid classes to keep his supervisor and Engineers properly trained for attending to any emergency.
9.20	All the contractor’s supervisory personnel and sufficient number of workers shall be trained for fire protection systems. Enough number of such trained personnel must be available during the tenure of contract. Contractor should nominate his supervisor to coordinate and implement the safety measures.
9.21	Contractor shall provide enough fire protecting equipment of the types and numbers at his office, stores, temporary structure in labour colony etc. Such fire protection equipment shall be easy and kept open at all times. The fire extinguishers shall be properly refilled and kept ready which should be certified at periodic intervals. The date of changing should be marked on the Cylinders. All other fire safety measures as laid down in the “codes for fire safety at construction site” issued by safety coordinator of BHEL shall be followed. Non-compliance of the above requirement under fire protection shall in no way relieve the contractor of any of his responsibility and liabilities to fire accident occurring either to his materials or equipment or those of others.
9.22	The contractor shall at his cost, remove from vicinity of work at least once each day all combustible waste, scrap, panting materials, rubbish, unused or other materials and deposit them in places specified by BHEL to keep the work site clear and tidy. Use of undercoated canvas paper, corrugated paper, fabricated carton, plastic or other flammable materials shall be restricted to the minimum and promptly removed.
9.23	The contractor shall not use any hand lamp energized by Electric power with supply voltage of more than 24 volts in confined spaces like inside water boxes, turbine casings, condensers etc.
9.24	All portable electric tools used by the contractor shall have safe plugging

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter-IX:HSE & OHSAS

	system to source of power and be appropriately earthed. Only electricians licensed by appropriate statutory authority shall be employed by the contractor to carry out all types of electrical works.
9.25	In case of any delay in completion of a job due to mishaps attributable to lapses by the contractor, BHEL shall have the right to recover cost of such delay from the payments due to the contractor, after notifying the contractor suitably.
9.26	Valve protection caps shall be kept in place and secured.
9.27	The contractor shall be responsible for the safe storage and handling of his radio-active sources as per applicable Sudanese rules/ International rules and regulations.
9.28	Tarpaulin being inflammable should not be used (instead, only non infusible covering materials shall be used) as protective cover while preheating, welding, stress relieving etc. at site.
9.29	If the contractor fails to improve the standards of safety in its operation to the satisfaction of BHEL after being given reasonable opportunity to do so and/or if the contractor fails to take appropriate safety precautions or to provide necessary safety devices and equipment or to carry out instruction regarding safety issued by BHEL, BHEL shall have the right to take corrective steps at the risk and cost of the contractor after giving a notice of not less than 7 days indicating the steps that would be taken by BHEL.
9.30	If the contractor succeeds in carrying out its job in time with out any fatal or disabling injury accident and without any damage to property BHEL may, at its sole discretion, favorably consider to reward the contractor suitably for the performance.
9.31	The contractor shall carefully follow the safety requirement of BHEL/ the purchaser with the regard to voltages used in critical areas.
9.32	The contractor shall use only properly insulated and armored cables which conform to the requirement of Indian Electricity Act and Rules for all wiring, electrical applications at site. BHEL reserves the right to replace any unsafe electrical installations, wiring, cabling etc. at the cost of the contractor. All electrical appliances used in the work shall be in good working condition and shall be properly earthed. No maintenance work shall be carried out on live equipment. The contractor shall maintain adequate number of qualified electricians to maintain his temporary electrical installations.

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter-IX:HSE & OHSAS

9.33	The contractor shall arrange adequate number of persons specifically for clearing any debris and for house keeping of the erection area including restacking of components in the erection areas.
9.34	In case of any damage to property due to lapses by the contractor, BHEL shall have the right to recover the cost of such damages from the contractor after holding an appropriate enquiry.
9.35	The contractor shall submit report of all accidents, fires and property damage etc to the Engineer immediately after such occurrence, but in any case not later than 24 hours of the occurrence. Such reports shall be furnished in the manner prescribed by BHEL. In addition periodic reports on safety shall also be submitted by the contractor to BHEL from time to time as prescribed by the Engineer.
9.36	Before commencing the work, the contractor shall appoint/nominate a responsible person to supervise implementation of all safety measures and liaison with his counterpart of BHEL.
9.37	Suitable scaffolds shall be provided for workman for all works that cannot safely be done from the ground, or from solid construction except in the case of short duration of work which can be done safely from ladders. When a ladder is used, it shall be of rigid construction made of steel. The steps shall have a minimum width of 45 cm and a maximum rise of 30 cm. Suitable handholds of good quality wood or steel shall be provided and the ladder shall be given an inclination not steeper than $\frac{1}{4}$ horizontal and 1 vertical.
9.38	Scaffolding or staging more than 3.6 m above the ground floor, swung or suspended from an overhead support or erected with stationery support shall have a guard rail properly bolted, braced or otherwise secured, at least 90 cm above the floor or platform of such scaffolding or staging and extending along the entire length of the out side and ends thereof with only such openings as may be necessary for the delivery of materials. Such scaffolding or staging shall be so fastened as to prevent it from savor, from swaying, from the building or structure.
9.39	Working platforms, gangways and stairways shall be so constructed that they do not sag unduly or unequally and if the height of the platform gangways provided is more than 3.6 m above ground level or floor level, they shall be closely boarded and shall have adequate width which shall not be less than 750 mm and be suitably fenced as described above.

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter-IX:HSE & OHSAS

9.40	Every opening in the floor or a building or in a working platform shall be provided with suitable means to prevent the fall of persons or materials by providing suitable fencing or railing whose minimum height shall be 90 cm.
9.41	Wherever there are open excavation in ground, they shall be fenced off by suitable railing and danger signals installed at night so as to prevent persons slipping into the excavations.
9.42	Safe means of access shall be provided to all working places. Every ladder shall be securely fixed. No portable single ladder shall be over 9 m in the length while the width between side rails in rung ladder shall in no case be less than app. 29.2 cm for ladder upto and including 3 m in length. For longer ladders this width shall be increased at least ¼” for each additional foot of length.
9.43	A sketch of the ladders and scaffolds proposed to be used shall be prepared and approval of the Engineer obtained prior to Construction.
9.44	All personnel of the Contactor working within the plant site shall be provided with safety helmets. All welders shall wear welding goggles while doing welding work and all metal worker shall be provided with safety gloves. Persons employed on metal cutting and grinding shall wear safety glasses.
9.45	Adequate precautions shall be taken to prevent danger for electrical equipment. No materials on any of the sites of work shall be so stacked or placed as to cause danger or inconvenience to any person or the public.
9.46	All trenches, four feet or more in depth, shall at all times be supplied with at least one ladder for each 30 m in length or fraction thereof. The ladder shall be extended from bottom of the trench to at least 90 cm above the surface of the ground. Sides of the trenches which are 1.50 m or more in depth shall be stepped back to give suitable slope or securely held by timer bracing, so as to avoid the danger of sides collapsing. The excavated materials shall not be placed within 1.5 m of the edges of the trench or half of the depth of the trench whichever is more. Cutting shall be done from top to bottom. Under no circumstances undermining or undercutting shall be done.
9.47	The Contactor shall take all measures at the sites of the work to protect all persons from accidents and shall be bound to bear the expenses of defense of every suit, action or other proceeding at law that may be brought by any persons for injury sustained or death owing to neglect of the above precautions and to pay any such persons such compensation or which may with the consent of the Contractor be paid to compromise any claim by any such person should such claim proceeding be filed against BHEL, the Contractor hereby agrees to

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter-IX:HSE & OHSAS

	indemnify BHEL against the same.
9.48	Before any demolition work is commenced and also during the process of the work the following shall be ensured:
9.48.1	All roads and open areas adjacent to the work site shall either be closed or suitably protected.
9.48.2	No electric cable or apparatus which is liable to be a source of danger nor a cable or an apparatus used by the operator shall remain electrically charged.
9.48.3	All practical steps shall be taken to prevent danger to persons employed from the risks of fire or explosion or flooding. No floor, roof or other part of the building shall be so overloaded with debris or materials as to render them unsafe.
9.49	All necessary personnel safety equipment as considered adequate by the Engineer should be kept available for the use of the persons employed in the Site and maintained in a condition suitable for immediate use and the Contactor should take adequate steps to ensure proper use of equipment by those concerned.
9.49.1	Workers employed on mixing asphalted materials, cement and lime mortars shall be provided with protective foot wear and protective goggles.
9.49.2	Those engaged in white washing and mixing or stacking of cement bags or any materials which is injurious to the eyes shall be provided with protective goggles.
9.49.3	Those engaged in welding works shall be provided with welder's protective eyesight lids.
9.49.4	Stone breakers shall be provided with protective goggles and protective clothing and seated sufficient to safe intervals.
9.49.5	Where workers are employed in sewers and manholes, which are in use, the Contractor shall ensure that the manhole covers are opened and ventilated at least for an hour before the workers are allowed to get into manhole, and the manholes so opened shall be cordoned off with suitable railing and provided with warning signals or boards to prevent accident to the public.
9.49.6	The Contractor shall not employ men below the age of 18 years and women on the work of painting with products containing lead in any form. Wherever men above the age of 18 are employed on the work of lead painting, the following precautions should be taken.

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter-IX:HSE & OHSAS

9.49.6.1	No paint containing lead or lead products shall be used except in the form of paste or ready made paint.
9.49.6.2	Suitably face masks should be supplied for use by the workers where paints are applied in the form of spray or a surface having lead paint dry rubbed and scrapped.
9.49.6.3	Overalls shall be supplied by the Contractor to the workmen and adequate facilities shall be provided to enable the working painters to wash during the cessation of work.
9.50	When the work is being done near any place where there is risk of drowning all necessary equipment should be provided and kept ready for use and all necessary steps taken for prompt rescue of any person in danger and adequate provision should be made for prompt first aid treatment of all injuries likely to be sustained during the course of the work.
9.51	Motors, gearing, transmission, electric wiring and other dangerous parts of hoisting appliances should be provided with efficient safe guards. Hoisting appliance should be provided with such means as will reduce to the minimum the risk of any part of a suspended load becoming accidentally displaced. When workers employed on electrical installations which are already energized, insulting mats, wearing apparel, such as gloves, sleeves and boots as may be necessary should be provided. The worker should not wear any rings, watches and carry keys or other materials which are good conductor of electricity.
9.52	All scaffolds, ladders and other safety devices mentioned or described herein shall be maintained in safe condition and no scaffold, ladder or equipment shall be altered or removed while it is in use. Adequate washing facilities should be provided at or near the places of work.
9.53	The contractor shall maintain and ensure necessary safety measures as required for inspection and tests HV test, Pneumatic test, Hydraulic test, Spring test, Bend test etc as applicable, to enable. inspection Agency for performing Inspection. If any test equipment is found not complying with proper safety requirements then the Inspection Agency may withhold inspection, till such time the desired safety requirements are met.
9.54	The Contractor shall notify BHEL of his intention to bring to site any equipment or material which may create hazard. BHEL shall have the right to prescribe the conditions under which such equipment or materials may be handled and the contractor shall adhere to such instructions. BHEL may prohibit the use of any construction machinery, which according to him is unsafe. No claim for

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter-IX:HSE & OHSAS

	compensation due to such prohibition will be entertained by BHEL.													
9.55	All safety precautions shall be taken for welding and cutting operations as per IS-818. All safety precautions shall be taken for foundation and other excavation marks as per IS-3764.													
9.56	These safety provisions should be brought to the notice of all concerned by display on a notice board at a prominent, place at work spot. The persons responsible for compliance of the safety code shall be named therein by the Contractor.													
9.57	To ensure effective enforcement of the rules and regulations relating to safety precautions the arrangement made by the contract shall be open to inspection by the Engineer of the Engineer's Representative.													
9.58	Keeping the work area clean/ free from debris, removed scaffoldings, scraps, insulation/sheeting wastage /cut pieces, temporary structures, packing woods etc. will be in the scope of the contractor. Such cleanings has to be done by contractor within quoted rate, on daily basis by an identified group. If such activity is not carried out by contractor / BHEL is not satisfied, then BHEL may get it done by other agency and actual cost alongwith BHEL overheads will be deducted from contractor's bill. Such decisions of BHEL shall be binding on the contractor.													
9.59	Notwithstanding the above clauses there is nothing to exit the Contractor from the operations of any other Act or Rule in force in area of work in this respect. Provided always that all safety measures apart from those specifically provided in this agreement which are brought to the notice of the Contractor from time to time by the Engineer shall be complied by the Contractor. Provided further that all consequences, damages, or losses arising by reason of any safety code shall be met with by the Contractor.													
9.60	<p><u>NON COMPLIANCE:-</u> NONCONFORMITY OF SAFETY RULES AND SAFETY APPLIANCES WILL BE VIEWED SERIOUSLY AND BHEL HAS RIGHT TO IMPOSE FINES ON THE CONTRACTOR AS UNDER <u>for every instance of violation noticed:</u></p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 10%;">SN</th> <th style="width: 70%;">Violation of Safety Norms</th> <th style="width: 20%;">Fine (in Euro)</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">01</td> <td>Not Wearing Safety Helmet</td> <td style="text-align: center;">50/-</td> </tr> <tr> <td style="text-align: center;">02.</td> <td>Not wearing Safety Belt</td> <td style="text-align: center;">100/-</td> </tr> <tr> <td style="text-align: center;">03.</td> <td>Grinding Without Goggles</td> <td style="text-align: center;">50/-</td> </tr> </tbody> </table>		SN	Violation of Safety Norms	Fine (in Euro)	01	Not Wearing Safety Helmet	50/-	02.	Not wearing Safety Belt	100/-	03.	Grinding Without Goggles	50/-
SN	Violation of Safety Norms	Fine (in Euro)												
01	Not Wearing Safety Helmet	50/-												
02.	Not wearing Safety Belt	100/-												
03.	Grinding Without Goggles	50/-												

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter-IX:HSE & OHSAS

	04.	Not using 24 V Supply For Internal Work	500/-
	05.	Electrical Plugs Not used for hand Machine	100/-
	06.	Not Slinging property	200/-
	07.	Using Damaged Sling	200/-
	08.	Lifting Cylinders Without Cage	500/-
	09.	Not Using Proper Welding Cable With Lot of Joints And Not Insulated Property.	200/-
	10.	Not Removing Small Scrap From Platforms	200/-
	11.	Gas Cutting Without Taking Proper Precaution or Not Using Sheet Below Gas Cutting	200/-
	12.	Not Maintaining Electric Winches Which are Operated Dangerously	500/-
	13.	Improper Earthing Of Electrical T&P	500/-
	14.	Accident Resulting in Partial Loss in Earning Capacity	25,000/- per victim
	15.	Fatal Accident/Accidents Resulting in total loss in Earning Capacity	1,00,000/ - per victim
	<p><i>Fine to be re-calculated by considering Rs. 50 as 2 Euros.</i> Any other non-conformity noticed not listed above will also be fined as deemed fit by BHEL. The decision of BHEL engineer is final on the above. The amount will be deducted from running bills of the contractor. The amount collected above will be utilized for giving award to the employees who could avoid accident by following safety rules. Also the amount will be spent for purchasing the safety appliances and supporting the safety activity at site.</p>		
9.61	<p><u>CITATION:</u>-If safety record of the contractor in execution of the awarded job is to the satisfaction of safety department of BHEL, issue of an appropriate certificate to recognize the safety performance of the contractor may be considered by BHEL after completion of the job</p>		
9.62	<p><u>MEMORANDUM OF UNDERSTANDING</u> After Award Of Work, Contractors Are Required To Enter Into A Memorandum Of Understanding As Given Below:</p> <p style="text-align: center;"><u>Memorandum of Understanding</u></p> <p>➤ BHEL, Power Sector _____ Region is committed to Health, Safety and Environment Policy (EHS Policy).</p>		

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter-IX:HSE & OHSAS

- M/s _____ do hereby also commit to the same EHS Policy while executing the Contract Number _____
- M/s _____ shall ensure that safe work practices not limited to the above are followed by all construction workers and supervisors. Spirit and content therein shall be reached to all workers and supervisors for compliance.
- BHEL will be carrying out EHS audits twice a year and M/s _____ shall ensure to close any non-conformity observed/reported within fifteen days.

Signed by authorized representative of M/s -----

Name :

Place & Date:

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter-X: RA Bill Payments

10.0	RA Bill Payments
10.1	The contractor shall submit his monthly RA bills with all the details required by BHEL on specified date every month covering progress of work in all respects and areas for the previous calendar month.
10.2	Mode of payment and measurement of work completed shall be as per relevant clauses of General Conditions of Contract
10.3	Release of payment in each running bill including PVC Bills will be restricted to 95% of the value of work admitted as per stages of progressive pro rata payments.
10.4	The 5% thus remaining shall be treated as 'Retention Amount' and shall be released as per terms specified in the General Conditions of Contract.
10.5	The payment for running bills will normally be released within 30 days of submission of running bill complete in all respects with all documents. It is the responsibility of the contractor to make his own arrangements for making timely payments towards labour wages, statutory payments, outstanding dues etc and other dues in the meanwhile.
10.6	BHEL shall release payment through Electronic Fund Transfer (EFT)/RTGS. In order to implement this system, Contractor to furnish details pertaining to his Bank Accounts where proceeds will be transferred through BHEL's banker, as per prescribed formats: Note: BHEL may also choose to release payment by other alternative modes as applicable
10.7	Paying Authority shall be the Construction Manager of the Site. Any change in the paying Authority shall be intimated to the Contactor accordingly.

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter-XI : Performance Monitoring

11.0	Performance Monitoring										
11.1	Performance of the contractor is monitored through various reports/reviews and shall be jointly evaluated every quarter as per prescribed formats. Based on the net weighted score obtained, Contractors shall be rated 'Good' or 'Satisfactory' or 'Unsatisfactory'										
11.2	Annual performance (Financial Year wise) and Over all Performance (for the Contract) shall be based on the averages of Quarterly net weighted scores.										
11.3	<p>In case Annual/Quarterly performance is found 'Unsatisfactory', BHEL reserves the right to put on hold such Contractors as given below:</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 10%;">Sl No</th> <th style="width: 60%;">Performance status</th> <th style="width: 30%;">Type of suspension</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">1</td> <td>'Unsatisfactory' in the Annual performance in the last Financial Year (if the agency is executing only one job in the Region)</td> <td>Hold for a period of six months for similar Work</td> </tr> <tr> <td style="text-align: center;">2</td> <td>'Unsatisfactory' in the Annual performance in the last Financial Year or in the 'Overall' Performances, for 2 or more Works/Contracts being executed by the Contractor in the Region</td> <td>Hold for a period of six months for similar Works for which performance is 'Unsatisfactory'.</td> </tr> </tbody> </table> <p>Note: If there is any conflict between the "Overall" performance and the latest "Annual" performance, then the 'Overall' performance shall prevail. However, BHEL reserves the right on the decision of 'Hold', in case of consistent 'Annual' improvement notwithstanding the vendors 'Overall' performance being unsatisfactory.</p>		Sl No	Performance status	Type of suspension	1	'Unsatisfactory' in the Annual performance in the last Financial Year (if the agency is executing only one job in the Region)	Hold for a period of six months for similar Work	2	'Unsatisfactory' in the Annual performance in the last Financial Year or in the 'Overall' Performances, for 2 or more Works/Contracts being executed by the Contractor in the Region	Hold for a period of six months for similar Works for which performance is 'Unsatisfactory'.
Sl No	Performance status	Type of suspension									
1	'Unsatisfactory' in the Annual performance in the last Financial Year (if the agency is executing only one job in the Region)	Hold for a period of six months for similar Work									
2	'Unsatisfactory' in the Annual performance in the last Financial Year or in the 'Overall' Performances, for 2 or more Works/Contracts being executed by the Contractor in the Region	Hold for a period of six months for similar Works for which performance is 'Unsatisfactory'.									

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter-XII: Suspension of Business Dealings

12.0	Suspension of Business dealings
12.1	BHEL reserves the right to take action against contractors who fail to perform or indulge in malpractices, by suspending business dealings with them.
12.2	Suspension could be in the form of 'Hold', 'De-listing' or 'Banning' a contractor.
12.3	<p>A bidder may be put on HOLD for a period of 6 months, for future tenders for specific works on the basis of one or more of the following reasons:</p> <ul style="list-style-type: none"> a) Bidder does not honour his own offer or any of its conditions within the validity period. b) Bidder fails to respond against three consecutive enquires of BHEL. c) After placement of order, Bidder fails to execute a contract. d) Bidder fails to settle sundry debt account, for which he is legitimately liable, within one year of its occurrence. e) Bidder's performance rating falls below 60% in specific category (more fully described in chapter 'Performance Monitoring') f) Bidder works are under strike/ lockout for a long period.
12.4	<p>A Bidder may be de-listed from the list of registered Bidders of the region for a period of 1 year on the basis of one or more of the following reasons:-</p> <ul style="list-style-type: none"> a) Bidder tampers with tendering procedure affecting ordering process or commits any misconduct which is contrary to business ethics. b) Bidder has substituted, damaged, failed to return, short returned or unauthorizedly disposed off materials/ documents/ drawings/ tools etc of BHEL. c) Bidder no longer has the technical staff, equipment, financial resources etc. required to execute the orders/ contracts.
12.5	<p>A Bidder can be banned from doing any business with all Units of BHEL for a period of 3 years on the basis of one or more of the following reasons:</p> <ul style="list-style-type: none"> a) Bidder is found to be responsible for submitting fake/ false/ forged documents, certificates, or information prejudicial to BHEL's interest. b) In spite of warnings, the Bidder persistently violates or circumvents the provisions of labour laws/ regulations/ rules and other statutory requirements. c) Bidder is found to be involved in cartel formation

SPECIAL CONDITIONS OF CONTRACT (SCC)
Chapter-XII: Suspension of Business Dealings

	<p>d) The Bidder has indulged in malpractices or misconduct such as bribery, corruption and fraud, pilferage etc which are contrary to business ethics.</p> <p>e) The Bidder is found guilty by any court of law for criminal activity/offences involving moral turpitude in relation to business dealings.</p> <p>f) The Bidder is declared bankrupt, insolvent, has wound up or been dissolved; i.e ceases to exist for all practical purposes.</p> <p>g) Bidder is found to have obtained Official Company information/documentation by questionable means.</p> <p>h) Communication is received from the administrative Ministry of BHEL to ban the Bidder from business dealings.</p>
12.6	Contracts already entered with a contractor before the date of issue of order of 'HOLD' or 'DE-LISTING' shall not be affected.
12.7	All existing contracts with a 'BANNED' contractor shall normally be short closed
12.8	Once the order for suspension is passed, existing offers/new offers of the contractor shall not be entertained
12.9	The above guidelines are not exhaustive but enunciate broad principles governing action against contractors

TENDER - SPECIFICATIONS

VOLUME- IC (GCC)



Bharat Heavy Electricals Limited
(A Govt. Of India Undertaking)
Power Sector – Northern Region,
Plot No. 25 , Sector - 16A ,
Distt. Gautam Budh Nagar, NOIDA – 201 301(INDIA)

General Conditions of Contract

(Common for Power Sector Regions)

2010

TABLE OF CONTENTS

1. **Chapter-1** : General Instructions to Tenderers
 - 1.1. Despatch Instructions
 - 1.2. Submission of Tenders
 - 1.3. Language
 - 1.4. Price Discrepancy
 - 1.5. Qualification of Tenderers
 - 1.6. Evaluation of Bids
 - 1.7. Data to be enclosed
 - 1.8. Authorisation and Attestation
 - 1.9. Earnest Money Deposit
 - 1.10. Security Deposit
 - 1.11. Return of Security Deposit
 - 1.12. Bank Guarantee
 - 1.13. Validity of offer
 - 1.14. Execution of Contract Agreement
 - 1.15. Rejection of Tender and other Conditions

2. **Chapter-2**
 - 2.1. Definitions
 - 2.2. Law Governing Contract and Court Jurisdiction
 - 2.3. Issue of Notice
 - 2.4. Use of land

- 2.5. Commencement of Work
- 2.6. Measurement of Work and Mode of Payment
- 2.7. Rights of BHEL
- 2.8. Responsibilities of Contractor in respect of Local Laws, Employment of Workers etc
- 2.9. Progress Monitoring, Monthly Review and Performance Evaluation
- 2.10. Time of Completion
- 2.11. Extension of Time for Completion
- 2.12. Over Run Compensation
- 2.13. Interest Bearing Recoverable Advances
- 2.14. Quantity Variation
- 2.15. Extra Works
- 2.16. Supplementary Items
- 2.17. Price Variation Clause
- 2.18. Insurance
- 2.19. Strikes & Lockout
- 2.20. Force Majeure
- 2.21. Arbitration and Reconciliation
- 2.22. Retention Amount
- 2.23. Payments
- 2.24. Performance Guarantee for Workmanship
- 2.25. Closing of Contracts
- 2.26. Reverse Auction
- 2.27. Suspension of Business Dealings
- 2.28. Other Issues
- 2.29. Interpretations/Clarifications and Revisions

CHAPTER -1

1. GENERAL INSTRUCTION TO TENDERERS

1.1. DESPATCH INSTRUCTION

- i) The General Conditions of Contract form part of the Tender specifications. **All pages of the tender documents shall be duly signed, stamped and submitted along with the offer in token of complete acceptance thereof.** The information furnished shall be complete by itself. The tenderer is required to furnish all the details and other documents as required in the following pages
- ii) Tenderers are advised to study all the tender documents carefully. Any submission of tender by the tenderer shall be deemed to have been done after careful study and examination of the tender documents and with the full understanding of the implications thereof. Should the tenderers have any doubt about the meaning of any portion of the Tender Specification or find discrepancies or omissions in the drawings or the tender documents issued are incomplete or shall require clarification on any of the technical aspect, the scope of work etc., he shall at once, contact the authority inviting the tender well in time (so as not to affect last date of submission) for clarification before the submission of the tender. Tenderer's request for clarifications shall be with reference to Sections and Clause numbers given in the tender documents. The specifications and terms and conditions shall be deemed to have been accepted by the tenderer in his offer. Non compliance with any of the requirements and instructions of the tender enquiry may result in the rejection of the tender.
- iii) Integrity pact (IP) shall be applicable for all tenders / contracts if indicated in NIT. This integrity pact shall be issued as part of the Tender documents and shall be returned by the bidder along with Techno-commercial bid duly filled, signed and stamped by the authorized signatory who signs the bid. Only those vendors / bidders who have entered into such an IP with BHEL shall be considered qualified to participate in the bidding. Entering into this pact shall be a preliminary qualification.

1.2. SUBMISSION OF TENDERS

- 1.2.1 The tenderers must submit their tenders to Officer inviting tender as per instructions in the NIT
- 1.2.2 Tenders submitted by post shall be sent by 'REGISTERED POST ACKNOWLEDGEMENT DUE / by COURIER' and shall be posted with due allowance for any postal/courier delays. BHEL takes no responsibility for delay, loss or non-receipt of tenders sent by post/courier. **The tenders received after the specified time of their submission are treated as 'Late Tenders' and shall not be considered under any circumstances.** Offers received by Fax/Email/Internet shall be considered as per terms of NIT.
- 1.2.3 Tenders shall be opened by authorised Officer of BHEL at his office at the time and date as specified in the NIT, in the presence of such of those tenderers or their authorised representatives who may be present

1.2.4 Tenderers whose bids are found techno commercially qualified shall be informed the date and time of opening of the Price Bids and such Tenderers may depute their representatives to witness the opening of the price bids. BHEL's decision in this regard shall be final and binding.

1.2.5 Before submission of Offer, the tenderers are advised to inspect the site of work and the environments and be well acquainted with the actual working and other prevalent conditions, facilities available, position of material and labour, means of transport and access to Site, accommodation, etc. No claim will be entertained later on the grounds of lack of knowledge of any of these conditions.

1.3. LANGUAGE

1.3.1 The tenderer shall quote the rates in English language and international numerals. These rates shall be entered in figures as well as in words. For the purpose of the tenders, the metric system of units shall be used.

1.3.2 All entries in the tender shall either be typed or written legibly in ink. Erasing and over-writing is not permitted and may render such tenders liable for rejection. All cancellations and insertions shall be duly attested by the tenderer.

1.4 PRICE DISCREPANCY:

1.4.1 **Conventional (Manual) Price Bid opening** : In the case of price bid opening without resorting to Reverse Auction, if there are differences between the rates given by the tenderer in words and figures or in amount worked out by him, the following procedure for evaluation and award shall be followed:

- i) When there is a difference between the rates in figures and in words, the rates which corresponds to the amounts worked out by the contractor, shall be taken as correct
- ii) When the amount of an item is not worked out by the contractor or it does not correspond with the rate written either in figure or in words, then the rate quoted by the contractor in words shall be taken as correct
- iii) When the rate quoted by the contractor in figures and words tallies but the amount is not worked out correctly, the rate quoted by the contractor shall be taken as correct and not the amount.
- iv) In case of lumpsum price, if there is any difference between the amount in figures and in words, the amount quoted by the bidder in words shall be taken as correct.
- v) In case of omission in quoting any rate for one or more items, the evaluation shall be done considering the highest quoted rate obtained against the respective items by other tenderers for the subject tender. If the tenderer becomes L-1, the notional rates for the omission items shall be the lowest rates quoted for the respective items by the other tenderers against the respective omission items for the subject job and the 'Total quoted price (loaded for omissions)' shall be arrived at. However the overall price remaining the same as quoted originally, the rates for all the items in the 'Total quoted price (loaded for omissions)' shall be reduced item wise in proportion to the ratio of 'Original' total price and the 'Total quoted price (loaded for omissions)'.

1.4.2 **Reverse Auction:** In case of Reverse Auction, the successful bidder shall undertake to execute the work as per overall price offered by him during the Reverse Auction process. In case of omission of rates, the procedure shall be as per 'Guidelines for Reverse Auction' enclosed.

1.5. QUALIFICATION OF TENDERERS

- i) Only tenderers who have previous experience in the work of the nature and description detailed in the Notice Inviting Tender and/or tender specification are expected to quote for this work duly detailing their experience along with offer.

- ii) Offers from tenderers who do not have proven and established experience in the field shall not be considered
- iii) Offers from tenderers who are under suspension (banned) by any Unit/Region/Division of BHEL shall not be considered.
- iv) Offers from tenderers who do not comply with the latest guidelines of Ministry/Commissions of Govt of India shall not be considered.

1.6. EVALUATION OF BIDS

- i) Technical Bids submitted by the tenderer will be opened first and evaluated for fulfilling the Pre Qualification criteria and other conditions in NIT/Tender documents, based on documentary evidences submitted along with the offer
- ii) In case the same qualifying experience is claimed by more than one agency, then the agency who has executed the work as per documentary evidence submitted shall only be qualified. Scope of qualifying work should be totally with the agency who has executed and in case it is only labour+consumables without T&P, then the responsibility of execution is assigned to the first agency and not to the agency who has executed only as labour supply contractor. Further, BHEL reserves the right to ask for further proofs including submission of TDS certificates for the said job
- iii) In case the qualifying experience is claimed by private organizations based on Work Order and completion certificates from another private organization, BHEL reserves the right to ask for further proofs including submission of TDS certificates for the said job
- iv) Assessing Bidder Capacity for executing the current tender shall be as per Notice Inviting Tender
- v) Price Bids of shortlisted bidders shall only be opened either through the conventional price bid opening or through electronic Reverse Auction, at the discretion of BHEL
- vi) Price Bids of unqualified bidders shall not be opened. Reasons for rejection shall be intimated in due course after issue of LOI/LOA to successful bidder and receipt of unqualified acceptance from the successful bidder
- vii) Bidders are advised to also refer to clause no 2.9.4 regarding evaluation of their performance in ongoing projects for the current tender

1.7. DATA TO BE ENCLOSED

Full information shall be given by the tenderer in respect of the following. Non-submission of this information may lead to rejection of the offer.

- i) **INCOME TAX PERMANENT ACCOUNT NUMBER (Not applicable for Foreign Parties)**
Certified copies of Permanent Account Numbers as allotted by Income Tax Department for the Company/Firm/Individual Partners, etc. shall be furnished along with tender.
- ii) **ORGANIZATION CHART**
The organization chart of the tenderer's organization, including the names, addresses and contact information of the Directors/Partners shall be furnished along with the offer.
- iii) An attested copy of the Power of Attorney, in case the tender is signed by an individual other than the sole proprietor
- iv) **IN CASE OF INDIVIDUAL TENDERER:**
His / her full name, address and place & nature of business.
- v) **IN CASE OF PARTNERSHIP FIRM**

The names of all the partners and their addresses, A copy of the partnership deed/instrument of partnership duly certified by the Notary Public shall be enclosed.

vi) **IN CASE OF COMPANIES:**

- a. Date and place of registration including date of commencement certificate in case of Public Companies (certified copies of Memorandum and articles of Association are also to be furnished).
- b. Nature of business carried on by the Company and the provisions of the Memorandum relating thereof.

1.8 AUTHORISATION AND ATTESTATION

Tenders shall be signed by a person duly authorized/empowered to do so. An attested copy of the Power of Attorney, in case the tender is signed by an individual other than the sole proprietor shall be submitted along with the tenders

1.9 EARNEST MONEY DEPOSIT:

1.9.1 1.9.1 Every tender must be accompanied by the prescribed amount of Earnest Money Deposit (EMD) in the manner described herein.

iv) Bidder may opt to deposit "One Time EMD" of Rs. 2.0 lakhs (Rupees Two lakhs only) / Eq. Euros 3000/ SDG (12500) with BHEL:Power Sector Northern Region HQ issuing the tender, which will enable them to participate in all the future tender enquiries in respect of Erection and Commissioning services issued from the respective office. Interested bidders may clearly send their consent for converting the present EMD into a "One Time EMD" in their offer.

Note : The 'One Time EMD' cannot be withdrawn by the tenderers within 3 years from the date of deposit, under any circumstances. The Tenderer who wishes to withdraw after three years will not be allowed to submit 'One Time EMD' again.

v) Bidders who have already deposited such "One Time EMD" of Rs. 2.00 lakh / Eq. Euros 3000/ SDG (12500) are exempted from submission of EMD for this tender. However a copy of 'One Time EMD' certificate issued by BHEL PSNR HQ issuing the tender shall be enclosed along with the offer.

1.10 SECURITY DEPOSIT

1.10.1 Upon acceptance of Tender, the successful Tenderer should deposit the required amount of Security Deposit for satisfactory completion of work, as per the rates given below:

SN	Contract Value	Security Deposit Amount
1	Up to Rs. 10 lakhs	10% of Contract Value
2	Above Rs. 10 lakhs upto Rs.50 lakhs	1 lakh + 7.5% of the Contract Value exceeding Rs. 10 lakhs.
3	Above Rs. 50 lakhs	Rs 4 lakhs + 5% of the Contract Value exceeding Rs. 50 lakhs.

SD is required to be submitted in EUROS

1.10.2 The security Deposit should be furnished before start of the work by the contractor.

1.10.3 Security Deposit may be furnished in any one of the following forms

- i) Cash (as permissible under the Income Tax Act)
- ii) Pay Order / Demand Draft in favour of BHEL.

- iii) Local cheques of scheduled banks, subject to realization.
- iv) Securities available from Post Offices such as National Savings Certificates, Kisan Vikas Patras etc. (Certificates should be held in the name of Contractor furnishing the security and duly pledged in favour of BHEL and discharged on the back).
- v) Bank Guarantee from Scheduled Banks / Public Financial Institutions as defined in the Companies Act. The Bank Guarantee format for Security Deposit shall be in the prescribed formats
- vi) Fixed Deposit Receipt issued by Scheduled Banks / Public Financial Institutions as defined in the Companies Act. The FDR should be in the name of the contractor, A/C BHEL, duly discharged on the back.
- vii) Security deposit can also be recovered at the rate of 10% from the running bills. However in such cases at least 50% of the Security Deposit should be deposited in any form as prescribed before start of the work and the balance 50% may be recovered from the running bills.
- viii) EMD of the successful bidder can be converted and adjusted against the cash portion of Security Deposit excepting for such bidders who have remitted One Time EMD.

NOTE: Acceptance of Security Deposit against Sl. No. (iv) and (vi) above will be subject to hypothecation or endorsement on the documents in favour of BHEL. However, BHEL will not be liable or responsible in any manner for the collection of interest or renewal of the documents or in any other matter connected therewith.

1.10.4 The Security Deposit shall not carry any interest.

1.10.5 In case the value of work exceeds / reduces from the awarded / accepted value, the Security Deposit shall be correspondingly enhanced / reduced as given below:

- i) The enhanced part of the Security Deposit shall be immediately deposited by the Contractor or adjusted against payments due to the Contractor.
- ii) There will be no reduction in Security Deposit value in case of variation in contract value upto the lower limit specified in Quantity variation clause. In case of reduction of contract value beyond the lower limit specified in Quantity Variation clause, then the Security Deposit shall be re adjusted in proportion.
- iii) In case of reduction, the reduced Contract value shall be certified by BHEL Construction Manager after ascertaining / freezing of BOQ / Drawings from the Design / Engineering Centre. The reduced Security Deposit value can only be considered after taking into account the adequacy of the securities held by BHEL to meet the liabilities of the contractor for the contract, and the performance of the contract in general. **In such cases, the revised value of Security Deposit shall be worked out only after execution of not less than the lower limit of the revised scope of work/contract value as per quantity variation clause, and as certified by Construction Manager. This reduction in value of Security Deposit shall not entitle the contractor to any amendment of Contract and shall be operated at the discretion of BHEL**
- iv) Contract value for the purpose of operating the reduced/increased value of Security Deposit due to Quantity Variation, shall be exclusive of Price Variation Clause, Over Run Compensation and Extra works done on manday rates.

1.10.6 The validity of Bank Guarantees towards Security Deposit shall be initially upto the completion period as stipulated in the Letter of Intent/Award + 3 months, and the same shall be kept valid by proper renewal till the acceptance of Final Bills of the Contractor, by BHEL

1.10.7 BHEL reserves the right of forfeiture of Security Deposit in addition to other claims and penalties in the event of the Contractor's failure to fulfill any of the contractual obligations or in the event of

termination of contract as per terms and conditions of contract. BHEL reserves the right to set off the Security Deposit against any claims of other contracts with BHEL.

1.11 RETURN OF SECURITY DEPOSIT

Security Deposit shall be refunded/Bank Guarantee(s) released to the Contractor along with the 'Final Bill' after deducting all expenses / other amounts due to BHEL under the contract / other contracts entered into with them by BHEL.

1.12 BANK GUARANTEES

Where ever Bank Guarantees are to be furnished/submitted by the contractor, the following shall be complied with

- i) Bank Guarantees shall be from Scheduled Banks / Public Financial Institutions as defined in the Companies Act.
- ii) The Bank Guarantees shall be as per prescribed formats.
- iii) It is the responsibility of the bidder to get the Bank Guarantees revalidated/extended for the required period (subject to a minimum period of six months), as per the advice of BHEL Site Engineer / Construction Manager. BHEL shall not be liable for issue of any reminders regarding expiry of the Bank Guarantees.
- iv) In case extension/further extensions of any Bank Guarantees are not required, the bidders shall ensure that the same is explicitly endorsed by the Construction Manager and submitted to the Regional HQ issuing the LOI/LOA.
- v) In case the Bank Guarantees are not extended before the expiry date, BHEL reserves the right to invoke the same by informing the concerned Bank in writing, without any advance notice/communication to the concerned bidder.
- vi) Bidders to note that any corrections to Bank Guarantees shall be done by the issuing Bank, only through an amendment in an appropriate non judicial stamp paper.
- vii) The Original Bank Guarantee shall be sent directly by the Bank to BHEL under Registered Post (Acknowledgement Due), addressed to the Subcontracting Department of the respective Region.

1.13 VALIDITY OF OFFER

The rates in the Tender shall be kept open for acceptance for a minimum period of **SIX MONTHS** from latest due date of offer submission (including extension, if any). In case BHEL (Bharat Heavy Electricals Ltd) calls for negotiations, such negotiations shall not amount to cancellation or withdrawal of the original offer which shall be binding on the tenderers.

1.14 EXECUTION OF CONTRACT AGREEMENT

The successful tenderer's responsibility under this contract commences from the date of issue of the Letter of Intent by Bharat Heavy Electricals Limited. The Tenderer shall submit an unqualified acceptance to the Letter of Intent/Award within the period stipulated therein.

The successful tenderer shall be required to execute an agreement in the prescribed form, with BHEL, within a reasonable time after the acceptance of the Letter of Intent/Award, and in any case before releasing the first running bill. The contract agreement shall be signed by a person duly authorized/empowered by the tenderer. The expenses for preparation of agreement document shall be borne by BHEL.

1.15 REJECTION OF TENDER AND OTHER CONDITIONS

- 1.15.1 The acceptance of tender will rest with BHEL which does not bind itself to accept the lowest tender or any tender and reserves to itself full rights for the following without assigning any reasons whatsoever:-
- a. To reject any or all of the tenders.
 - b. To split up the work amongst two or more tenderers as per NIT
 - c. To award the work in part if specified in NIT
 - d. In case of either of the contingencies stated in (b) and (c) above, the time for completion as stipulated in the tender shall be applicable.
- 1.15.2 A conditional tender, unsolicited tenders, tenders which are incomplete or not in the form specified or defective or have been materially altered or not in accordance with the tender conditions, specifications etc., are liable to be rejected.
- 1.15.3 Tenders are liable to be rejected in case of unsatisfactory performance of the tenderer with BHEL, or tenderer under suspension (hold/banning /delisted) by any unit / region / division of BHEL or tenderers who do not comply with the latest guidelines of Ministry/Commissions of Govt of India. BHEL reserves the right to reject a bidder in case it is observed that they are overloaded and may not be in a position to execute this job as per the required schedule in line with clause no. 9.0 of the 'NIT'. The decision of BHEL will be final in this regard.
- 1.15.4 If a tenderer who is a proprietor expires after the submission of his tender or after the acceptance of his tender, BHEL may at their discretion, cancel such tender. If a partner of a firm expires after the submission of tender or after the acceptance of the tender, BHEL may then cancel such tender at their discretion, unless the firm retains its character.
- 1.15.5 BHEL will not be bound by any Power of Attorney granted by changes in the composition of the firm made subsequent to the execution of the contract. They may, however, recognise such power of Attorney and changes after obtaining proper legal advice, the cost of which will be chargeable to the contractor concerned.
- 1.15.6 If the tenderer deliberately gives wrong information in his tender, BHEL reserves the right to reject such tender at any stage or to cancel the contract if awarded and forfeit the Earnest Money/Security Deposit/any other money due.
- 1.15.7 Canvassing in any form in connection with the tenders submitted by the Tenderer shall make his offer liable to rejection.
- 1.15.8 In case the Proprietor, Partner or Director of the Company/Firm submitting the Tender, has any relative or relation employed in BHEL, the authority inviting the Tender shall be informed of the fact as per specified format, along with the Offer. Failing to do so, BHEL may, at its sole discretion, reject the tender or cancel the contract and forfeit the Earnest Money/Security Deposit.
- 1.15.9 The successful tenderer should not sub-contract part or complete work detailed in the tender

specification undertaken by him without written permission of BHEL's Construction Manager/Site Incharge. The tenderer is solely responsible to BHEL for the work awarded to him.

- 1.15.10 The Tender submitted by a techno commercially qualified tenderer shall become the property of BHEL who shall be under no obligation to return the same to the bidder. However unopened price bids and late tenders shall be returned to the bidders
- 1.15.11 Unsolicited discount received after the due date and time of Bid Submission shall not be considered for evaluation. However, if the party who has submitted the unsolicited discount/rebate becomes the L-1 party, then the awarded price i.e contract value shall be worked out after considering the discount so offered.
- 1.15.12 BHEL shall not be liable for any expenses incurred by the bidder in the preparation of the tender irrespective of whether the tender is accepted or not.

CHAPTER-2

2.1 **DEFINITION:** The following terms shall have the meaning hereby assigned to them except where the context otherwise requires

- i) BHEL shall mean Bharat Heavy Electricals Limited (of the respective Power Sector Region inviting the Tender), a company registered under Indian Companies Act 1956, with its Registered Office at BHEL HOUSE, SIRI FORT, NEW DELHI – 110 049, or its Power Sector Regional Offices or its Authorised Officers or its Site Engineers or other employees authorised to deal with any matters with which these persons are concerned on its behalf.
- ii) “EXECUTIVE DIRECTOR” or ‘GROUP GENERAL MANAGER’ or “GENERAL MANAGER (Incharge)” or “GENERAL MANAGER” shall mean the Officer in Administrative charge of the respective Power Sector Region.
- iii) “COMPETENT AUTHORITY” shall mean Executive Director or Group General Manager or General Manager (Incharge) or General Manager or BHEL Officers who are empowered to act on behalf of the Executive Director or General Manager (Incharge) or General Manager of BHEL.
- iv) “ENGINEER” or “ENGINEER IN CHARGE” shall mean an Officer of BHEL as may be duly appointed and authorized by BHEL to act as “Engineer” on his behalf for the purpose of the Contract, to perform the duty set forth in this General Conditions of Contract and other Contract documents. The term also includes ‘CONSTRUCTION MANAGER’ or ‘SITE INCHARGE’ as well as Officers at Site or at the Headquarters of the respective Power Sector Regions.
- v) “SITE” shall mean the places or place at which the plants/equipments are to be erected and services are to be performed as per the specification of this Tender.
- vi) “CLIENT OF BHEL” or “CUSTOMER” shall mean the project authorities with whom BHEL has entered into a contract for supply of equipments or provision of services.
- vii) “CONTRACTOR” shall mean the successful Bidder/Tenderer who is awarded the Contract and shall include the Contractor’s successors, heirs, executors, administrators and permitted assigns.
- viii) “CONTRACT” or “CONTRACT DOCUMENT” shall mean and include the Agreement of Work Order, the accepted appendices of Rates, Schedules, Quantities if any, General Conditions of Contract, Special Conditions of Contract, Instructions to the Tenderers, Drawings, Technical Specifications, the Special Specifications if any, the Tender documents, subsequent amendments mutually agreed upon and the Letter of Intent/Acceptance issued by BHEL. Any conditions or terms stipulated by the contractor in the tender documents or subsequent letters shall not form part of the contract unless, specifically accepted in writing by BHEL in the Letter of Intent/Award and incorporated in the agreement.
- ix) “GENERAL CONDITIONS OF CONTRACT” shall mean the ‘Instructions to Tenderers’ and ‘General Conditions of Contract’ pertaining to the work for which above tenders have been called for.
- x) “TENDER SPECIFICATION” or “TENDER” or “TENDER DOCUMENTS” shall mean General Conditions, Common Conditions, Special Conditions, Price Bid, Rate Schedule, Technical

	Specifications, Appendices, Annexures, Corrigendums, Amendments, Forms, procedures, Site information, etc and drawings/documents pertaining to the work for which the tenderers are required to submit their offers. Individual specification number will be assigned to each Tender Specification.
xi)	“LETTER OF INTENT” shall mean the intimation by a Letter/Fax/email to the tenderer that the tender has been accepted in accordance with provisions contained in the letter. The responsibility of the contractor commences from the date of issue of this letter and all terms and conditions of the contract are applicable from this date.
xii)	“COMPLETION TIME” shall mean the period by ‘date/month’ specified in the ‘Letter of Intent/Award’ or date mutually agreed upon for handing over of the intended scope of work, the erected equipment/plant which are found acceptable by the Engineer, being of required standard and conforming to the specifications of the Contract.
xiii)	“PLANT” shall mean and connote the entire assembly of the plant and equipments covered by the contract.
xiv)	“EQUIPMENT” shall mean equipment, machineries, materials, structural, electricals and other components of the plant covered by the contract.
xv)	“TESTS” shall mean and include such test or tests to be carried out on the part of the contractor as are prescribed in the contract or considered necessary by BHEL, in order to ascertain the quality, workmanship, performance and efficiency of the contractor or part thereof.
xvi)	“APPROVED”, “DIRECTED” or “INSTRUCTED” shall mean approved, directed or instructed by BHEL.
xvii)	“WORK or CONTRACT WORK” shall mean and include supply of all categories of labour, specified consumables, tools and tackles and Plants required for complete and satisfactory site transportation, handling, stacking, storing, erecting, testing and commissioning of the equipments to the entire satisfaction of BHEL.
xviii)	“SINGULAR AND PLURALS ETC” words carrying singular number shall also include plural and vice versa, where the context so requires. Words imparting the masculine Gender shall be taken to include the feminine Gender and words imparting persons shall include any Company or Associations or Body of Individuals, whether incorporated or not.
xix)	“HEADING” – The heading in these General Conditions are solely for the purpose of facilitating reference and shall not be deemed to be part thereof or be taken as instructions thereof or of the contract.
xx)	“MONTH” shall mean calendar month unless otherwise specified in the Tender.
xxi)	Day’ or ‘Days’ unless herein otherwise expressly defined shall mean calendar day or days of twenty four (24) hours each. A week shall mean continuous period of seven (7) days.
xxii)	“COMMISSIONING” shall mean the synchronisation testing and achieving functional operation of the Equipment with associated system after all initial adjustments, trials, cleaning, re-assembly required at site if any, have been completed and Equipment with associated system is

	ready for taking into service.
xxiii)	“WRITING” shall include any manuscript type written or hand written or printed statement or electronically transmitted messages, under the signature or seal or transmittal of BHEL.
xxiv)	“TEMPORARY WORK” shall mean all temporary works for every kind required in or for the execution, completion, maintenance of the work.
xxv)	‘CONTRACT PRICE’ or ‘CONTRACT VALUE’ shall mean the sum mentioned in the LOI/LOA/Contract Agreement subject to such additions thereto or deductions there from as may be made under provisions hereinafter contained
xxvi)	“COMMENCEMENT DATE” or “START DATE” shall mean the commencement/start of work at Site as per terms defined in the Tenderl
xxvii)	“SHORT CLOSING” or “FORE CLOSING” of Contract shall mean the premature closing of Contract, for reasons not attributable to the contractor and mutually agreed between BHEL and the contractor
xxviii)	“TERMINATION” of Contract shall mean the pre mature closing of contract due to reasons as mentioned in the contract
xxix)	“DE MOBILISATION” shall mean the temporary winding up of Site establishment by Contractor leading to suspension of works temporarily for reasons not attributable to the contractor
xxx)	“RE MOBILISATION” shall mean the resumption of work with all resources required for the work after demobilization.
2.2	<p style="text-align: center;">LAW GOVERNING THE CONTRACT AND COURT JURISDICTION</p> <p>The contract shall be governed by the Law for the time being in force in the Republic of India. The Civil Court having original Civil Jurisdiction at Delhi for PSNR, at Kolkata for PSER, at Nagpur for PSWR and at Chennai for PSSR, shall alone have exclusive jurisdiction in regard to all claims in respect of the Contract. No other Civil Court shall have jurisdiction in case of any dispute, under this contract</p>
2.3	<p style="text-align: center;">ISSUE OF NOTICE</p> <p>2.3.1 <u>Service of notice on contractor</u> Any notice to be given to the Contractor under the terms of the contract shall be served by sending the same by Registered Post / Speed Post to or leaving the same at the Contractor’s last known address of the principal place of business (or in the event of the contractor being a company, to or at its Registered Office). In case of change of address, the notice shall be served at changed address as notified in writing by the Contractor to BHEL. Such posting or leaving of the notice shall be deemed to be good service of such notice and the time mentioned to the condition for doing any act after notice shall be reckoned from the date so mentioned in such notice.</p> <p>2.3.2 <u>Service of notice on BHEL</u> Any notice to be given to BHEL in-charge/Region under the terms of the Contract shall be served by sending the same by post to or leaving the same at BHEL address or changed address as notified in writing by BHEL to the Contractor.</p>
2.4	<p style="text-align: center;">USE OF LAND</p> <p>No land belonging to BHEL or their Customer under temporary possession of BHEL shall be occupied by the contractor without written permission of BHEL.</p>

2.5 COMMENCEMENT OF WORK

- 2.5.1 The contractor shall commence the work as per the time indicated in the Letter of Intent from BHEL and shall proceed with the same with due expedition without delay.
- 2.5.2 If the contractor fails to start the work within stipulated time as per LOI or as intimated by BHEL, then BHEL at its sole discretion will have the right to cancel the contract. The Earnest Money and/or Security Deposit with BHEL will stand forfeited without any further reference to him without prejudice to any and all of BHEL's other rights and remedies in this regard.
- 2.5.3 All the work shall be carried out under the direction and to the satisfaction of BHEL.

2.6 MEASUREMENT OF WORK AND MODE OF PAYMENT:

- 2.6.1 All payments due to the contractors shall be made by e mode only, unless otherwise found operationally difficult for reasons to be recorded in writing.
- 2.6.2 For progress running bill payments: - The Contractor shall present detailed measurement sheets in triplicate, duly indicating all relevant details based on technical documents and connected drawings for work done during the month/period under various categories in line with terms of payment as per contract. The basis of arriving at the quantities, weights shall be relevant documents and drawings released by BHEL. These measurement sheets shall be prepared jointly with BHEL Engineers and signed by both the parties.
- 2.6.3 These measurement sheets will be checked by BHEL Engineer and quantities and percentage eligible for payment under various groups shall be decided by BHEL Engineer. The abstract of quantities and percentage so arrived at based on the terms of payment shall be entered in Measurement Book and signed by both the parties.
- 2.6.4 Based on the above quantities, contractor shall prepare the bills in prescribed format and work out the financial value. These will be entered in Measurement Book and signed by both the parties. Payment shall be made by BHEL after effecting the recoveries due from the contractor.
- 2.6.5 All recoveries due from the contractor for the month/period shall be effected in full from the corresponding running bills unless specific approval from the competent authorities is obtained to the contrary.
- 2.6.6 Measurement shall be restricted to that portion of work for which it is required to ascertain the financial liability of BHEL under this contract.
- 2.6.7 The measurement shall be taken jointly by persons duly authorized on the part of BHEL and by the Contractor.
- 2.6.8 The Contractor shall bear the expenditure involved if any, in making the measurements and testing of materials to be used/used in the work. The contractor shall, without extra charges, provide all the assistance with appliances and other things necessary for measurement.
- 2.6.9 If at any time due to any reason whatsoever, it becomes necessary to re-measure the work done in full or in part, the expenses towards such re measurements shall be borne by the contractor unless such re measurements are warranted solely for reasons not attributable to contractor.

- 2.6.10 Passing of bills covered by such measurements does not amount to acceptance of the completion of the work measured. Any left out work has to be completed, if pointed out at a later date by BHEL.
- 2.6.11 Final measurement bill shall be prepared in the final bill format prescribed for the purpose based on the certificate issued by BHEL Engineer that entire works as stipulated in tender specification has been completed in all respects to the entire satisfaction of BHEL. Contractor shall give unqualified "No Claim" Certificate. All the tools and tackles loaned to him should be returned in satisfactory condition to BHEL. The abstract of final quantities and financial values shall also be entered in the Measurement Books and signed by both parties to the contract. The Final Bill shall be prepared and paid within a reasonable time after completion of work.

2.7 RIGHTS OF BHEL

BHEL reserves the following rights in respect of this contract during the original contract period or its extensions if any, as per the provisions of the contract, without entitling the contractor for any compensation.

- 2.7.1 To withdraw any portion of work and/or to restrict/alter quantum of work as indicated in the contract during the progress of work and get it done through other agencies to suit BHEL's commitment to its customer or in case BHEL decides to advance the date of completion due to other emergent reasons/ BHEL's obligation to its customer.
- 2.7.2 To terminate the contract or get any part of the work done through other agency or deploy BHEL's own/hired/otherwise arranged resources , at the risk and cost of the contractor after due notice of a period of two weeks by BHEL, in the event of:-
- i) Contractor's continued poor progress
 - ii) Withdrawal from or abandonment of the work before completion of the work
 - iii) Contractor's inability to progress the work for completion as stipulated in the contract
 - iv) Poor quality of work
 - v) Corrupt act of Contractor
 - vi) Insolvency of the Contractor
 - vii) Persistent disregard to the instructions of BHEL
 - viii) Assignment, transfer, sub-letting of contract without BHEL's written permission
 - ix) Non fulfillment of any contractual obligations
 - x) In the opinion of BHEL, the contractor is overloaded and is not in a position to execute the job as per required schedule
- 2.7.3 To meet the expenses including BHEL overheads of 30% & liquidated damage/penalties arising out of "Risk & Cost" as explained above under SI.No. 2.7.2. BHEL shall recover the amount from any money due from Contractor, from any money due to the Contractor including Security Deposit or by forfeiting any T&P or material of the contractor under this contract or any other contract of BHEL or by any other means or any combination thereof
- 2.7.4 To terminate the contract or to restrict the quantum of work and pay for the portion of work executed in case BHEL's contract with their customer are terminated for any reason, as per mutual agreement.
- 2.7.5 To effect recovery from any amounts due to the contractor under this or any other contract or in any other form, the moneys BHEL is statutorily forced to pay to anybody, due to contractor's failure

to fulfill any of his obligations. BHEL shall levy overheads of 15% on all such payments.

2.7.6 While every endeavour will be made by BHEL to this end, they cannot guarantee uninterrupted work due to conditions beyond their control. The Contractor will not be normally entitled for any compensation/extra payment on this account unless otherwise specified elsewhere in the contract.

2.7.7 In case the execution of works comes to a complete halt or reaches a stage wherein worthwhile works cannot be executed and there is no possibility of commencement of work for a period of not less than two months, due to reasons not attributable to the contractor and other than Force Majeure conditions, BHEL may consider permitting the contractor to de mobilize forthwith and re mobilize at an agreed future date. Cost of such demobilization/remobilization shall be mutually agreed. ORC in such cases shall not be applicable for the period between the period of demobilization and re mobilisation. The duration of contract/time extension shall accordingly get modified suitably. In case of any conflict, BHEL decision in this regard shall be final and binding on the contractor.

2.7.8 In the unforeseen event of inordinate delay in receipt of materials, drawings, fronts, etc, due to which inordinate discontinuity of work is anticipated, BHEL at its discretion may consider contractor's request to short close the contract, provided that the balance works are minor vis a vis the scope of work envisaged as per the contract. At the point of requesting for short closure, contractor shall establish that he has completed all works possible of completion and he is not able to proceed with the balance works due to constraints beyond his control. In such a case, the estimated value of the unexecuted portion of work as mutually agreed, shall however be reduced from the final contract value. Final Contract value for this purpose shall mean executed contract value plus value of unexecuted portion of work as per rate schedule.

2.7.9 **LIQUIDATED DAMAGES/PENALTY** – If the contractor fails to maintain the required progress of work which results in delay in the completion of the work as per the contractual completion period, BHEL shall have the right to impose Liquidated Damage/Penalty at the rate of 0.5% of the contract value, per week of delay or part thereof subject to a maximum of 10% of the contract value. For this purpose, the period of delay shall be the delay attributable to the Contractor for the completion of work as per contract. Contract Value for this purpose, shall be the final executed value exclusive of ORC, Extra Works executed on Manday rate basis, Supplementary/Additional Items and PVC.

2.8 **RESPONSIBILITIES OF THE CONTRACTOR IN RESPECT OF LOCAL LAWS, EMPLOYMENT OF WORKERS ETC.**

The following are the responsibilities of the contractor in respect of observance of local laws, employment of personnel, payment of taxes etc. The subcontractor shall fully indemnify BHEL against any claims of whatsoever nature arising due to the failure of the contractor in discharging any of his responsibilities hereunder:

2.8.1 As far as possible, Unskilled Workers shall be engaged from the local areas in which the work is being executed.

2.8.2 The contractor at all times during the continuance of this contract shall, in all his dealings with local labour for the time being employed on or in connection with the work, have due regard to all local festivals and religious and other customs.

- 2.8.3 **NOT APPLICABLE**
- 2.8.4 **NOT APPLICABLE**
- 2.8.5 The contractor shall pay all taxes, fees, license charges, deposits, duties, tolls, royalties, commission or other charges which may be leviable on account of his operations in executing the contract.
- 2.8.6 While BHEL would pay the inspection fees and Registration fees of Boiler/Electrical Inspectorate, all other arrangements for site visits periodically by the Inspectorate to site, Inspection certificate etc. will have to be made by contractor. However, BHEL will not make any payment to the Inspectorate in connection with contractor's Welders/Electricians qualification tests etc.
- 2.8.7 Contractor shall be responsible for provision of Health and Sanitary arrangements, Safety precautions etc. as may be required for safe and satisfactory execution of contract.
- 2.8.8 The contractor shall be responsible for proper accommodation including adequate medical facilities for personnel employed by him.
- 2.8.9 The contractor shall be responsible for the proper behavior and observance of all regulations by the staff employed by him.
- 2.8.10 The contractor shall ensure that no damage is caused to any person/property of other parties working at site. If any such damage is caused, it is responsibility of the contractor to make good the losses or compensate for the same.
- 2.8.11 All the properties/equipments/components of BHEL/their Client loaned with or without deposit to the contractor in connection with the contract shall remain properties of BHEL/their Client.
- 2.8.12 The contractor shall use such properties for the purpose of execution of this contract. All such properties/equipments/components shall be deemed to be in good condition when received by the contractor unless he notifies within 48 hours to the contrary. The contractor shall return them in good condition as and when required by BHEL/their Client. In case of non-return, loss, damage, repairs etc, the cost thereof as may be fixed by BHEL Engineer will be recovered from the contractor
- 2.8.13 In case the contractor is required to undertake any work outside the scope of this contract, the rates payable shall be those mutually agreed upon if the item rates are not mentioned in existing contract
- 2.8.14 Any delay in completion of works/or non achievement of periodical targets due to the reasons attributable to the contractor, the same may have to be compensated by the contractor either by increasing manpower and resources or by working extra hours and/or by working more than one shift. All these are to be carried out by the contractor at no extra cost.
- 2.8.15 The contractor shall arrange, coordinate his work in such a manner as to cause no hindrance to other agencies working in the same premises.
- 2.8.16 All safety rules and codes applied by the Client/BHEL at site shall be observed by the contractor without exception. The contractor shall be responsible for the safety of the equipment/material and works to be performed by him and shall maintain all light, fencing guards, slings etc. or other

protection necessary for the purpose. Contractor shall also take such additional precautions as may be indicated from time to time by the Engineer with a view to prevent pilferage, accidents, fire hazards. Due precautions shall be taken against fire hazards and atmospheric conditions. Suitable number of Clerical staff, watch and ward, store keepers to take care of equipment/materials and construction tools and tackles shall be posted at site by the contractor till the completion of work under this contract.

The contractor shall arrange for such safety devices as are necessary for such type of work and carry out the requisite site tests of handling equipment, lifting tools, tackles etc. as per prescribed standards and practices.

Contractor has to ensure the implementation of Health, Safety and Environment (HSE) requirements as per directions given by BHEL/Customer. The contractor has to assist in HSE audit by BHEL/Customer and submit compliance Report. The contractor has to generate and submit record/reports as per HSE plan/activities as per instruction of BHEL/Customer

- 2.8.17 The contractor will be directly responsible for payment of wages to his workmen. A pay roll sheet giving all the payments given to the workers and duly signed by the contractor's representative should be furnished to BHEL site for record purpose, if so called for.
- 2.8.18 In case of any class of work for which there is no such specification as laid down in the contract, such work shall be carried out in accordance with the instructions and requirements of the Engineer.
- 2.8.19 Also, no idle charges will be admissible in the event of any stoppage caused in the work resulting in contractor's labour and Tools & Plants being rendered idle due to any reason at any time.
- 2.8.20 The contractor shall take all reasonable care to protect the materials and work till such time the plant/equipment has been taken over by BHEL or their Client whichever is earlier.
- 2.8.21 The contractor shall not stop the work or abandon the site for whatsoever reason of dispute, excepting force majeure conditions. All such problems/disputes shall be separately discussed and settled without affecting the progress of work. Such stoppage or abandonment shall be treated as breach of contract and dealt with accordingly
- 2.8.22 The contractor shall keep the area of work clean and shall remove the debris etc. While executing day-to-day work. Upon completion of work, the contractor shall remove from the vicinity of work, all scrap, packing materials, rubbish, unused and other materials and deposit them in places specified by the Engineer. The contractor will also demolish all the hutments, sheds, offices, etc. constructed and used by him and shall clean the debris. In the event of his failure to do so, the same will be arranged to be done by the Engineer and the expenses recovered from the contractor.
- 2.8.23 The contractor shall execute the work in the most substantial and workman like manner in the stipulated time. Accuracy of work and timely execution shall be the essence of this contract. The contractor shall be responsible to ensure that the quality, assembly and workmanship conform to the dimensions and clearance given in the drawings and/ or as per the instructions of the Engineer.
- 2.8.24 The Contractor to note that some of BHEL's T&Ps/MMDs may not be insured. The Contractor will

take necessary precautions and due care to protect the same while in his custody from any damage/ loss till the same is handed over back to BHEL. In case the damage / loss is due to carelessness/ negligence on the part of the contractor, the Contractor is liable to get them repair/ replaced immediately and in case of his failure to do so within a reasonable time, BHEL will reserve the right to recover the loss from the contractor.

2.9 PROGRESS MONITORING, MONTHLY REVIEW AND PERFORMANCE EVALUATION

- 2.9.1 A detailed plan/programme for completion of the contractual scope of work as per the time schedule given in the contract shall be jointly agreed between BHEL and Contractor, before commencement of work . The above programme shall be supported by monthwise deployment of resources viz Manpower, T&P, Consumables, etc. Progress will be reviewed periodically (Daily/Weekly/Monthly) vis a vis this jointly agreed programme. The Contractor shall submit periodical progress reports (Daily/Weekly/Monthly) and other reports/information including manpower, consumables, T&P mobilization etc as desired by BHEL.
- 2.9.2 Monthly progress review between BHEL and Contractor shall be based on the agreed programme as above, availability of inputs/fronts etc, and constraints if any, as per prescribed formats. Manpower, T&P and consumable reports as per prescribed formats shall be submitted by contractor every month. Release of RA Bills shall be contingent upon certification by BHEL Site Engineer of the availability of the above prescribed formats duly filled in and signed.
- 2.9.3 The burden of proof that the causes leading to any shortfall is not due to any reasons attributable to the contractor is on the contractor himself. The monthly progress review shall record shortfalls attributable to (i) Contractor, (ii) Force Majeure Conditions, and (iii) BHEL
- 2.9.4 Quarterly 'Evaluation of Contractor Performance' shall be assessed as per prescribed formats and shall form the basis for 'Annual/Overall Performance Evaluation' of the Contractor. These shall also be used for Evaluation of Bids for future tenders.

2.10 TIME OF COMPLETION

- 2.10.1 The time schedule shall be as prescribed in the Contract. The time for completion shall be reckoned from the date of commencement of work at Site as certified by BHEL Engineers
- 2.10.2 The entire work shall be completed by the contractor within the time schedule or within such extended periods of time as may be allowed by BHEL under clause 2.11

2.11 EXTENSION OF TIME FOR COMPLETION

- 2.11.1 If the completion of work as detailed in the scope of work gets delayed beyond the contract period, the contractor shall request for an extension of the contract and BHEL at its discretion may extend the Contract.
- 2.11.2 Based on the monthly reviews jointly signed, the works balance at the end of original contract period less the backlog attributable to the contractor shall be quantified, and the number of months of 'Time extension' required for completion of the same shall be jointly worked out. Within this period of 'Time extension', the contractor is bound to complete the portion of backlog attributable to the contractor. Any further 'Time extension' or 'Time extensions' at the end of the previous extension shall be worked out similarly.
- 2.11.3 However if any 'Time extension' is granted to the contractor to facilitate continuation of work and completion of contract, due to backlog attributable to the contractor alone, then it shall be without prejudice to the rights of BHEL to impose penalty/LD for the delays attributable to the contractor, in addition to any other actions BHEL may wish to take at the risk and cost of contractor.
- 2.11.4 A joint programme shall be drawn for the balance amount of work to be completed during the period of 'Time Extension', along with matching resources (with weightages) to be deployed by the contractor as per specified format. Review of the programme and record of shortfall shall be done

every month of the 'Time extension' period in the same manner as is done for the regular contract period.

2.11.5 During the period of 'Time extension', contractor shall maintain their resources as per mutually agreed program

2.11.6 At the end of total work completion as certified by BHEL Engineer, and upon analysis of the total delay, the portion of time extensions attributable to (i) Contractor, (ii) Force majeure conditions, and (iii) BHEL, shall be worked out and shall be considered to be exhausted in the same order. The total period of time extensions shall be the sum of (i), (ii) and (iii) above and shall be equal to period between the scheduled date of completion and the actual date of completion of contract. LD shall be imposed/levied for the portion of time extensions attributable to contractor and recoverable from the dues payable to the contractor.

2.12 **OVERRUN COMPENSATION**

2.12.1 Over Run Compensation (ORC) is payable by way of rate revisions for periods beyond original contract period subject to the following terms and conditions.

2.12.2 Rates shall be increased by 10% for the first twelve months of one or more extensions beyond original contract period. For the next twelve months of further extensions if any, rates shall be increased as above by 10% over the previous twelve months, and similarly for each subsequent twelve months extension.

2.12.3 The amount of increase payable per month due to rate revisions is subject to a minimum of EURO 1500 per month and a maximum of EURO 15000 per month.

2.12.4 Should there be any 'Time extension' for reasons attributable only to the contractor, then the work shall be executed by the contractor at the rates applicable for the period the work was planned

2.12.5 Payment of ORC shall be regulated as follows:

- i) Contractor is entitled to Over Run Compensation (ORC) only for the portion of backlog attributable to BHEL.
- ii) 50% of the compensation as per clause 2.12.3 is allocated for deployment of resources agreed as per the joint programme drawn vide 2.11.4. Payment shall however be based on the actual deployment of resources for the month as certified by BHEL, as per weightages assigned therein
- iii) 50% of the compensation as per clause 2.12.3, is allocated for achieving of planned progress agreed as per the joint programme drawn vide 2.11.4. Payment shall be on pro rata basis for actual achieved quantities
- iv) Total Over Run Compensation shall be limited to 10% of the executed contract value as certified in Final Bill. For this purpose executed contract value excludes PVC, ORC, Supplementary/Additional Items and Extra Works done on Manday rate basis

2.12.6 Contractor shall not be entitled for any Over Run Compensation (ORC) for the portion of backlog attributable to the contractor. Such works shall be executed at the rates applicable for the period the work was planned

2.13 **INTEREST BEARING RECOVERABLE ADVANCES**

2.13.1 Normally no advance is payable to the contractor. However, advance payment in exceptional circumstances shall be interest bearing and secured through an equivalent Bank Guarantee and shall be limited to a maximum of 5% of contract value.

2.13.2 In exceptional circumstances, with due justification, Competent Authority of BHEL is empowered to approve proposals for payment of additional interim interest bearing advance against matching Bank Guarantee, for resource augmentation towards expediting work for project implementation.

- 2.13.3 Payment and recovery of Interest Bearing Recoverable advance shall be at the sole discretion of BHEL and shall not be a subject matter of arbitration.
- 2.13.4 The rate of interest applicable for the above advances shall be the prime lending rate of State Bank of India prevailing at the time of disbursement of the advance + 2%, and such rate will remain fixed till the total advance amount is recovered
- 2.13.5 Unadjusted amount of advances paid shall not exceed 5% of the total contract value at any point of time. Recovery of advances shall be made progressively from each Running Bill such that the advance amounts paid along with the interest is fully recovered by the time the contractor's billing reaches 80% of contract value.
- 2.13.6 Recovery rate per month shall be the sum of:
- 10% of Running Bill amount
 - Simple interest up to the date of RA Bill on the outstanding Principle amount/amounts
- 2.13.7 Contractor to submit Bank Guarantee as per prescribed formats for each of the advance and shall be valid for at least one year or the recovery duration or the balance contract period which ever is later. In case the recovery of dues does not get completed within the aforesaid BG period, the contractor shall renew the BG or submit fresh BG for the outstanding amount and the remaining recovery period.
- 2.13.8 BHEL is entitled to make recovery of the entire outstanding amount in case the contractor fails to comply with the BG requirement

2.14 **QUANTITY VARIATION**

- 2.14.1 The quoted rates shall remain firm irrespective of any variations in the individual quantities. No compensation becomes payable in case the variation of the final executed contract value is within the limits of Plus (+) or Minus (-) 15% of awarded contract value
- 2.14.2 Compensation due to variation of final executed value in excess of the limits defined in clause above, shall be as follows:
- In case the finally executed contract value reduces below the lower limit of Contract Value due to quantity variation specified above, the contractor will be eligible for compensation @ 15% of the difference between the lower limit of the contract value and the actual executed value.
 - In case the finally executed contract value increases above the upper limit of Contract Value due to quantity variation specified above, there will be no revision in the rates within the contract period.

2.15 **EXTRA WORKS**

- 2.15.1 All rectifications/modifications, revamping, and reworks required for any reasons not due to the fault of the contractor, or needed due to any change in deviation from drawings and design of equipments, operation/maintenance requirements, mismatching, or due to damages in transit, storage and erection/commissioning, and other allied works which are not very specifically indicated in the drawings, but are found essential for satisfactory completion of the work, will be considered as extra works.
- 2.15.2 Extra works arising on account of the contractor's fault, irrespective of time consumed in rectification

of the damage/loss, will have to be carried out by the contractor free of cost. Under such circumstances, any material and consumable required for this purpose will also have to be arranged by the contractor at his cost.

2.15.3 All the extra work should be carried out by a separately identifiable gang, without affecting routine activities. Daily log sheets in the pro-forma prescribed by BHEL should be maintained and shall be signed by the contractor's representative and BHEL engineer. No claim for extra work will be considered /entertained in the absence of the said supporting documents i.e. daily log sheets. Signing of log sheets by BHEL engineer does not necessarily mean the acceptance of such works as extra works.

2.15.4 BHEL retains the right to award or not to award any of the major repair/rework/modification/rectification/fabrication works to the contractor, at their discretion without assigning any reason for the same

2.15.5 After eligibility of extra works is established and finally accepted by BHEL engineer/designer, payment will be released on competent authority's approval at the following rate.

MAN-HOUR RATE FOR ELIGIBLE EXTRA WORKS: Single composite average labour man-hour rate, including overtime if any, supervision, use of tools and tackles and other site expenses and incidentals, consumables for carrying out any major rework/ repairs/ rectification/ modification/ fabrication as certified by site as may arise during the course of erection, testing, commissioning or extra works arising out of transit, storage and erection damages, payment, if found due will be at 2 EURO per man hour .

2.15.6 The above composite labour man hour rate towards extra works shall remain firm and not subject to any variation during execution of the work. PVC will not be applicable for extra works. Rate revision, Over Run Charges/compensation etc will not be applicable due to extra works.

2.15.7 **NOT APPLICABLE**

2.16 **SUPPLEMENTARY ITEMS**

2.16.1 **For NON Civil Works**

Supplementary items are items/works required for completion of entire work but not specified in the scope of work. Subject to certification of such items/works as supplementary items by BHEL Engineer, rates shall be derived on the basis of any one of the following on mutual agreement:

- i) Based on percentage breakup/rates indicated for similar/nearby items
- ii) In case (i) above does not exist, then BHEL/site may derive the percentage breakup/rates to suit the type of work

2.16.2 **NOT APPLICABLE**

2.17 **PRICE VARIATION COMPENSATION- NOT APPLICABLE**

2.18 **INSURANCE**

2.18.1 BHEL/their customer shall arrange for insuring the materials/properties of BHEL/customer covering the risks during transit, storage, erection and commissioning.

2.18.2 It is the sole responsibility of the contractor to insure his materials, equipments, workmen, etc.

against accidents and injury while at work and to pay compensation, if any, to workmen as per Workmen's compensation Act. The work will be carried out in a protected area and all the rules and regulations of the client /BHEL in the area of project which are in force from time to time will have to be followed by the contractor.

2.18.3 If due to negligence and or non-observation of safety and other precautions by the contractors, any accident/injury occurs to the property / manpower belong to third party, the contractor shall have to pay necessary compensation and other expense, if so decided by the appropriate authorities.

2.18.4 The contractor will take necessary precautions and due care to protect the material, while in his custody from any damage/ loss due to theft or otherwise till the same is taken over by BHEL or customer. For lodging / processing of insurance claim the contractor will submit necessary documents. BHEL will recover the loss including the deductible franchise from the contractor, in case the damage / loss is due to carelessness / negligence on the part of the contractor. In case of any theft of material under contractor's custody, matter shall be reported to police by the contractor immediately and copy of FIR and subsequently police investigation report shall be submitted to BHEL for taking up with insurance. However this will not relieve the contractor of his contractual obligation for the material in his custody.

2.19 STRIKES & LOCKOUT

2.19.1 The contractor will be fully responsible for all disputes and other issues connected with his labour. In the event of the contractor's labour resorting to strike or the Contractor resorting to lockout and if the strike or lockout declared is not settled within a period of one month, BHEL shall have the right to get the work executed through any other agencies and the cost so incurred by BHEL shall be deducted from the Contractor's bills.

2.19.2 For all purposes whatsoever, the employees of the contractor shall not be deemed to be in the employment of BHEL

2.20 FORCE MAJEURE

The following shall amount to Force Majeure:-

2.20.1 Acts of God, act of any Government, War, Sabotage, Riots, Civil commotion, Police action, Revolution, Flood, Fire, Cyclones, Earth quake and Epidemic and other similar causes over which the contractor has no control.

2.20.2 If the contractor suffers delay in the due execution of the contractual obligation due to delays caused by force majeure as defined above, the agreed time of completion of the job covered by this contract or the obligations of the contractor shall be extended by a period of time equal to period of delay, provided that on the occurrence of any such contingency, the contractor immediately reports to BHEL in writing the causes of delay and the contractor shall not be eligible for any compensation.

2.21 ARBITRATION & RECONCILIATION

2.21.1 In case amicable settlement is not reached in the event of any dispute or difference arising out of the execution of the Contract or the respective rights and liabilities of the parties or in relation to interpretation of any provision by the Contractor in any manner touching upon the Contract, such dispute or difference shall (except as to any matters, the decision of which is specifically provided for therein) be referred to the sole arbitration of the arbitrator appointed by BHEL/In charge(Region).

The award of the Arbitrator shall be binding upon the parties to the dispute

Subject as aforesaid, the provisions of Arbitration and Reconciliation Act 1996 (India) or statutory modifications or re enactments thereof and the rules made there under and for the time being in force shall apply to the arbitration proceedings under this clause. The venue of the arbitration shall be the place from which the contract is issued or such other place as the Arbitrator at his discretion may determine

2.21.2 In case of Contract with Public Sector Enterprise (PSE) or a Government Department, the following shall be applicable :

In the event of any dispute or difference relating to the interpretation and application of the provisions of the Contract, such dispute or difference shall be referred to by either party to the arbitration of one of the arbitrators in the department of public enterprises. The award of the arbitrator shall be binding upon the parties to the dispute, provided, however, any party aggrieved by such award may make further reference for setting aside or revision of the award to the Law Secretary, Department of Legal Affairs, Ministry of Law and Justice, Government of India. Upon such reference the dispute shall be decided by the Law Secretary or the Special Secretary or Additional Secretary when so authorized by the Law Secretary, whose decision shall bind the parties hereto finally and conclusively.

2.21.3 The cost of arbitration shall be borne equally by the parties.

2.21.4 Work under the contract shall be continued during the arbitration proceedings

2.22 RETENTION AMOUNT

2.22.1 Retention Amount shall be 5% of executed contract value and shall be recovered at the rate of 5% from each Running Bill admitted, including PVC Bills. Retention amount shall always be retained in cash and shall not be released against BG under any circumstance.

2.22.2 Refund of Retention Amount shall be as follows.

- i) 50% of retention amount along with 'Final Bill'
- ii) Balance 50% of retention amount shall be retained towards 'Performance Guarantee for Workmanship' and shall become refundable after expiry of Guarantee period, provided all the defects noticed during the guarantee period have been rectified to the satisfaction of BHEL Site Engineer/BHEL Construction Manager, and after deducting all expenses/other amounts due to BHEL under the contract/other contracts entered into by BHEL with them. Bank Guarantees are not acceptable towards this portion of retention

2.23 PAYMENTS

Payments to Contractors are made in any one of the following forms

2.23.1 Running Account Bills (RA Bills)

- iii) These are for interim payments when the contracts are in progress. The bills for such interim payments are to be prepared by Contractor in prescribed formats (RA Bill forms).
- iv) Payments shall be made according to the extent of work done as per measurements taken up to the end of the calendar month and in line with the terms of payments described in the Tender documents
- v) Recoveries on account of electricity, water, statutory deductions, etc are made as per terms of contract
- vi) Full rates for the work done shall be allowed only if the quantum of work has been done as per the specifications stipulated in the contract. If the work is not executed as per the stipulated specifications, BHEL may ask the contractor to re do the work according to the required specifications, without any extra cost. However, where this is not considered necessary 'OR' where the part work is done due to factors like non-availability of material to be supplied by BHEL 'OR' non availability of fronts 'OR' non availability of drawings, fraction payment against full rate, as is considered reasonable, may be allowed with due regard for the work remaining to be done. BHEL decision in this regard will be final and binding on the contractor.
- vii) In order to facilitate part payment, BHEL Site Engineer at his discretion may further split the contracted rates/percentages to suit site conditions, cash flow requirements according to the progress of work

2.23.2 Final Bill

Final Bill' is used for final payment on closing of Running Account for works or for single payment after completion of works. 'Final Bill' shall be submitted as per prescribed format after completion of works as per scope and upon material reconciliation, along with the following.

- iii) 'No Claim Certificate' by contractor
- iv) Clearance certificates where ever applicable viz Clearance Certificates from Customer, various Statutory Authorities .
- v) Indemnity bond as per prescribed format

BHEL shall settle the final bills after deducting all liabilities of Contractor to BHEL

2.24 PERFORMANCE GUARANTEE FOR WORKMANSHIP

2.24.1 Even though the work will be carried out under the supervision of BHEL Engineers the Contractor will be responsible for the quality of the workmanship and shall guarantee the work done for a period of twelve months from the date of commencement of guarantee period as defined in Special Conditions of Contract, for good workmanship and shall rectify free of cost all defects due to faulty erection detected during the guarantee period. In the event of the Contractor failing to repair the defective works within the time specified by the Engineer, BHEL may proceed to undertake the repairs of such defective works at the Contractor's risk and cost, without prejudice to any other rights and recover the same from the Guarantee money.

2.24.2 BHEL shall release the guarantee money subject to the following

- i) Contractor has submitted 'Final Bill'
- ii) Guarantee period as per contract has expired
- iii) Contractor has furnished 'No Claim Certificate' in specified format
- iv) BHEL Site Engineer/Construction Manager has furnished the 'No Demand Certificate' in specified format
- v) Contractor has carried out the works required to be carried out by him during the period of Guarantee and all expenses incurred by BHEL on carrying out such works is included for

	adjustment from the Guarantee money refundable.
2.25	CLOSING OF CONTRACTS The Contract shall be considered completed and closed upon completion of all contractual obligations and settlement of Final Bill or completion of Guarantee period whichever is later. Upon closing of Contract, BHEL shall issue a completion certificate as per standard format, based on specific request of Contractor.
2.26	REVERSE AUCTION: BHEL reserves the right to go for Reverse Auction for Price Bid Opening by BHEL appointed service provider, instead of opening the submitted sealed price bid in the conventional way. The Business Rules for Reverse Auction shall be as per BHEL guidelines issued from time to time.
2.27	SUSPENSION OF BUSINESS DEALINGS BHEL reserves the right to take action against Contractors who either fail to perform or Tenderers/Contractor who indulge in malpractices, by suspending business dealings with them in line with BHEL guidelines issued from time to time.
2.28	OTHER ISSUES
2.28.1	Value of Non judicial Stamp Paper for Bank Guarantees and for Contract Agreement shall be not less than Rs 100/- unless otherwise required under relevant statutes..
2.28.2	In case of any conflict between the General Conditions of Contract and Special Conditions of Contract, provisions contained in the Special Conditions of Contract shall prevail.
2.28.3	Unless otherwise specified in NIT, offers from consortium/JVs shall not be considered.
2.28.4	BHEL may not insist for signing of Contract Agreements in respect of low value and short time period contracts like providing services for Hot water flushing, Chemical Cleaning, Transportation, etc

TENDER - SPECIFICATIONS

VOLUME- ID (FORMS & PROCEDURES)



Bharat Heavy Electricals Limited
(A Govt. Of India Undertaking)
Power Sector – Northern Region,
Plot No. 25 , Sector - 16A ,
Distt. Gautam Budh Nagar, NOIDA – 201 301(INDIA)

Rev 00
6th JULY
2010

FORMS & PROCEDURES

(Document No. PS:MSX:F&P)

BHARAT HEAVY ELECTRICALS LIMITED



FORMS & PROCEDURES

INDEX

SN	Description	Form No	No. of Pages
1.0	Forms		
1.1	Offer forwarding Letter/Submission of Tender	F-1 (Rev 00)	01
1.2	Declaration by Authorised Signatory	F-2 (Rev 00)	01
1.3	No Deviation Certificate	F-3 (Rev 00)	01
1.4	Declaration confirming knowledge about Site Conditions	F-4 (Rev 00)	01
1.5	Declaration for relation in BHEL	F-5 (Rev 00)	01
1.6	Non Disclosure Certificate	F-6 (Rev 00)	01
1.7	Bank Account Details for E-Payment	F-7 (Rev 00)	01
1.8	Form for seeking clarifications	F-8 (Rev 00)	01
1.9	Capacity Evaluation of Bidder for current Tender	F-9 (Rev 00)	01
1.10	Contract Agreement	F-10 (Rev 00)	04
1.11	Bank Guarantee for Security Deposit	F-11 (Rev 00)	02
1.12	Bank Guarantee for Interest Bearing Refundable Advance	F-12 (Rev 00)	03
1.13	Extension of Validity of Bank Guarantee	F-13 (Rev 00)	01
1.14	Monthly Plan & Review with Contractors	F-14 (Rev 00)	04
1.15	Guidelines for Evaluation of Contractor Performance	F-15 (Rev 00)	##
1.16	Evaluation of Contractor Performance (Quarterly)	F-16 (Rev 00)	04
1.17	Evaluation of Contractor Performance (Annual)	F-17 (Rev 00)	01
1.18	Evaluation of Contractor Performance for the Contract (Overall)	F-18 (Rev 00)	01
1.19	Milestone Completion Certificate	F-19 (Rev 00)	01

FORMS & PROCEDURES

SN	Description	Form No	No. of Pages
1.20	Completion Certificate	F-20 (Rev 00)	01
1.21	Indemnity Bond	F-21 (Rev 00)	02
1.22	Consortium Agreement	F-22 (Rev 00)	03
1.23	Refund of Security Deposit	F-23 (Rev 00)	01
1.24	Refund of Guarantee Money	F-24 (WAM-11)	02
1.25	Power of Attorney for Submission of Tender/Signing Contract Agreement	F-25 (Rev 00)	01
1.26	Analysis of Unit Rates Quoted	F-26 (Rev 00)	01
1.27	RA Bill Format	WAM-6	09
1.28	Final Bill Submission format with No Claim Certificate and No Demand Certificate	WAM-7	12
1.29			
1.30			
2.0	Procedures		
2.1	Procedure and Business Rules for Reverse Auction	As per Company Policy	
2.2	Integrity Pact	As per Company Policy	
3.0	Customer specific procedures		
3.1			

: will be released later

OFFER FORWARDING LETTER / TENDER SUBMISSION LETTER
(To be typed and submitted in the Letter Head of the Company/Firm of Bidder)

Offer Reference No:.....

Date:.....

To,

(Write Name & Address of Officer of BHEL inviting the Tender)

Dear Sir,

Sub : Submission of Offer against Tender Specification No:

I/We hereby offer to carry out the work detailed in the Tender Specification issued by Bharat Heavy Electricals Limited, Power Sector-....., in accordance with the terms and conditions thereof.

I/We have carefully perused the following listed documents connected with the above work and agree to abide by the same.

1. Amendments/Clarifications/Corrigenda/Errata/etc issued in respect of the Tender documents by BHEL
2. Notice Inviting Tender (NIT)
3. Price Bid
4. Technical Conditions of Contract
5. Special Conditions of Contract
6. General Conditions of Contract
7. Forms and Procedures

Should our Offer be accepted by BHEL for Award, I/we further agree to furnish 'Security Deposit' for the work as provided for in the Tender Conditions within the stipulated time as may be indicated by BHEL.

I/We further agree to execute all the works referred to in the said Tender documents upon the terms and conditions contained or referred to therein and as detailed in the appendices annexed thereto.

I/We have deposited/depositing herewith the requisite Earnest Money Deposit (EMD) as per details furnished in the Check List.

Authorised Representative of Bidder

Signature :

Name :

Address :

Place:

Date:

DECLARATION BY AUTHORISED SIGNATORY OF BIDDER

(To be typed and submitted in the Letter Head of the Company/Firm of Bidder)

To,

(Write Name & Address of Officer of BHEL inviting the Tender)

Dear Sir,

Sub : **Declaration by Authorised Signatory**

Ref : 1) NIT/Tender Specification No:,

2) All other pertinent issues till date

I/We, hereby certify that all the information and data furnished by me with regard to the above Tender Specification are true and complete to the best of my knowledge. I have gone through the specifications, conditions, stipulations and all other pertinent issues till date, and agree to comply with the requirements and Intent of the specification.

I further certify that I am authorised to represent on behalf of my Company/Firm for the above mentioned tender and a valid Power of Attorney to this effect is also enclosed.

Yours faithfully,

(Signature, Date & Seal of Authorized
Signatory of the Bidder)

Date:

Enclosed : Power of Attorney

NO DEVIATION CERTIFICATE

(To be typed and submitted in the Letter Head of the Company/Firm of Bidder)

To,

(Write Name & Address of Officer of BHEL inviting the Tender)

Dear Sir,

Sub : **No Deviation Certificate**

Ref : 1) NIT/Tender Specification No:,
2) All other pertinent issues till date

We hereby confirm that we have not changed/ modified/materially altered any of the tender documents as downloaded from the website/ issued by BHEL and in case of such observance at any stage, it shall be treated as null and void.

We also hereby confirm that we have neither set any Terms and Conditions and nor have we taken any deviation from the Tender conditions together with other references applicable for the above referred NIT/Tender Specification.

We further confirm our unqualified acceptance to all Terms and Conditions, unqualified compliance to Tender Conditions, Integrity Pact (if applicable) and acceptance to Reverse Auctioning process.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized representative of the bidder)

DECLARATION CONFIRMING KNOWLEDGE ABOUT SITE CONDITIONS

(To be typed and submitted in the Letter Head of the Company/Firm of Bidder)

To,

(Write Name & Address of Officer of BHEL inviting the Tender)

Dear Sir,

Sub : **Declaration confirming knowledge about Site conditions**

Ref : 1) NIT/Tender Specification No:,

2) All other pertinent issues till date

I/We, _____ hereby declare and confirm that we have visited the Project Site as referred in BHEL Tender Specifications and acquired full knowledge and information about the Site conditions including Wage structure, Industrial Climate, the Law & Order and other conditions prevalent at and around the Site. We further confirm that the above information is true and correct and we shall not raise any claim of any nature due to lack of knowledge of Site conditions.

I/We, hereby offer to carry out work as detailed in above mentioned Tender Specification, in accordance with Terms & Conditions thereof.

Yours faithfully,

(Signature, Date & Seal of Authorized
Representative of the Bidder)

Date :

Place:

DECLARATION FOR RELATION IN BHEL

(To be typed and submitted in the Letter Head of the Company/Firm of Bidder failing which the offer of Bidder is liable to be summarily rejected)

To,

(Write Name & Address of Officer of BHEL inviting the Tender)

Dear Sir,

Sub : **Declaration for relation in BHEL**

Ref : 1) NIT/Tender Specification No:

I/We hereby submit the following information pertaining to relation/relatives of Proprieter/Partner(s)/Director(s) employed in BHEL

Tick(√) any one as applicable:

1. The Proprieter, Partner(s), Director(s) of our Company/Firm DO NOT have any relation or relatives employed in BHEL

OR

2. The Proprieter, Partner(s), or Director(s) of our Company/Firm HAVE relation/relatives employed in BHEL and their particulars are as below:

(i)

(ii)

Signature of the Authorised Signatory

Note:

1. Attach separate sheet, if necessary.
2. If BHEL Management comes to know at a later date that the information furnished by the Bidder is false, BHEL reserves the right to take suitable against the Bidder/Contractor.

NON DISCLOSURE CERTIFICATE

(To be typed and submitted in the Letter Head of the Company/Firm of Bidder)

I/We understand that BHEL PS-NR is committed to Information Security Management System as per their Information Security Policy.

Hence, I/We M/s.....
who are submitting offer for providing services to BHEL PS-NR against Tender Specification No: _____,
hereby undertake to comply with the following in line with Information Security Policy of BHEL PS-NR, NOIDA

- To maintain confidentiality of documents & information which shall be used during the execution of the Contract.
- The documents & information shall not be revealed to or shared with third party which shall not be in the business interest of BHEL PS-NR.

(Signature, date & seal of Authorized Signatory of the bidder)

Date:

BANK ACCOUNT DETAILS FOR E-PAYMENT

(To be given on Letter head of the Company /Firm of Bidder, and **ENDORSED (SIGNED & STAMPED) BY THE BANK** to enable BHEL release payments through Electronic Fund Transfer (EFT/RTGS))

1. Beneficiary Name :
2. Beneficiary Account No. :
3. Bank Name & Branch :
4. City/Place :
5. 9 digit MICR Code of Bank Branch :
6. IFSC Code of Bank Branch :
7. Beneficiary E-mail ID :
(for payment confirmation)

NOTE: In case Bank endorsed certificate regarding above has already been submitted earlier, Kindly submit photocopy of the same

FORMAT FOR SEEKING CLARIFICATION

(To be typed and submitted in the Letter Head of the Company/Firm of Bidder)

To,

(Write Name & Address of Officer of BHEL inviting the Tender)

Dear Sir,

Sub : **Request for Clarification**

Ref : 1) NIT/Tender Specification No:,

2) All other pertinent issues till date

Sl no.	Reference clause of Tender Document	Existing provision	Bidder's query	BHEL's clarification
1				
2				
3				
4				
5				
6				

Yours faithfully,

(Signature, date & seal of Authorized Representative of the Bidder)

CAPACITY EVALUATION OF BIDDERS FOR CURRENT TENDER

SL NO.	DESCRIPTION OF WORK (Similar to Tendered Scope)	WORK ORDER REF & DATE	CONTRACT VALUE (Rs. LACS)	CUSTOMER NAME & ADDRESS	CURRENT STATUS OF THE JOB ALONG WITH LATEST MILE STONE COMPLETED	%AGE OF WORK COMPLETED	VALUE OF BALANCE WORK (Rs. Lacs)
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							

NOTES:

1. BIDDERS ARE REQUIRED TO FURNISH ALL THE JOBS OF SIMILAR NATURE WHICH THEY ARE EXECUTING (IN PROGRESS) AT THE TIME OF SUBMISSION OF TENDER, AS PER ABOVE FORMAT.

2. BIDDERS HEREBY UNDERTAKE THAT THEY HAVE FURNISHED THE DETAILS SOUGHT AS PER POINT NO. 1 IN TOTALITY AND THAT THE DETAILS FURNISHED IS COMPLETE IN ALL RESPECT.

3. BHEL WILL TAKE APPROPRIATE ACTION AS DEEMED FIT , IN CASE, IT IS FOUND AT A LATER DATE THAT THE CONTRACTOR HAD SUPPRESSED THE FACTS AND HAVE NOT FURNISHED THE CORRECT & COMPLETE INFORMATIONS.

DATE :
PLACE:

Signature

Name, Designation & Seal of Bidder

CONTRACT AGREEMENT

Form No: F-10 (Rev 00)

BHARAT HEAVY ELECTRICALS LIMITED
(A Government of India Undertaking)
Power Sector – Northern Region
NOIDA (UP)
INDIA

CONTRACT AGREEMENT

AGREEMENT NO. _____

NAME OF WORK	
NAME OF THE CONTRACTOR WITH FULL ADDRESS	
VALUE OF WORK AWARDED	
LETTER OF INTENT NO.	
TIME ALLOTTED FOR COMPLETING THE WORK (DATE OF COMPLETION)	

SIGNATURE OF CONTRACTOR

(SIGNATURE OF BHEL OFFICER)

CONTRACT AGREEMENT

THIS AGREEMENT MADE THIS _____ DAY OF _____ between BHARAT HEAVY ELECTRICALS LIMITED (A Government of India Enterprise) a Company incorporated under the Companies Act, 1956, having its Registered Office at BHEL House, Siri Fort New Delhi-110049 (herein after called BHEL) of the ONE PART.

AND

M/S _____
_____ (hereinafter called the `Contractor') of the
SECOND PART.

WHEREAS M/s -----state that they
have acquired and possess extensive experience in the field of -----

And Whereas in response to an Invitation to Tender No. ----- issued by BHEL for
execution of ----- the contractor submitted their offer
No.-----dated -----And whereas BHEL has accepted the
offer of the Contractor on terms and conditions specified in the Letter of Intent No.-----
-----dated -----read with the references cited therein.

THIS AGREEMENT WITNESSES AND it is hereby agreed by and between the parties as follows:

1. That the contractor shall execute the work of -----and more particularly described in Tender Specification No -----including Drawings and Specifications (hereinafter called the said works) in accordance with and subject to terms and conditions contained in these presents, instructions to Tenderers, General Conditions of Contract, Special Conditions, Annexures, Letter of Intent dated ----- and such other instructions, Drawings, Specifications given to him from time to time by BHEL.
2. The Contractor is required to furnish to BHEL Security deposit in the form of cash/ approved securities/ Bank Guarantee valid upto ----- for a sum of Rs.----- towards satisfactory performance and completion of the Contract.
3. The Contractor has furnished a Bank Guarantee bearing no.-----dated ----- for a sum of Rs.-----executed by ----- in favour of BHEL towards Security Deposit valid upto -----

OR

The Contractor has furnished to BHEL an initial Security Deposit of Rs.-----in the form of cash / approved Securities/ B.G No.----- dated ----- for Rs.-----executed by ----- in favour of BHEL valid upto ----- and has agreed for recovery of the balance security deposit by BHEL @ 10% of the value of work done from each running bill till the entire Security Deposit is recovered.

OR

The contractor has furnished to BHEL an initial Security Deposit of Rs.----- (Rs.----- vide Bank draft No.-----dated -----and by adjusting EMD of Rs.----- submitted vide Bank draft No.----- dt.-----) and has agreed for recovery of balance Security Deposit by BHEL @ 10% of the value of work done from each running bill till the entire security deposit is recovered.

4. The Contractor hereby agrees to extend the validity of the Bank Guarantee for such further period or periods as may be required by BHEL and if the Contractor fails to obtain such extension(s) from the Bank, the Contractor, shall pay forthwith or accept recovery of Rs.----- from the bills in one installment and the contractor further agrees that failure to extend the validity of the Bank Guarantee or failure to pay the aforesaid amount in the manner specified above shall constitute breach of contract. In addition to above, BHEL shall be entitled to take such action as deemed fit and proper for recovering the said sum of Rs.-----

OR

In case the contractor furnishes the bank guarantee at a later date the contractor hereby agrees to extend the validity of bank guarantee for such further period or periods as may be required by BHEL and if the contractor fails to obtain such extension(s) from the bank, the contractor shall pay forthwith or accept recovery of the amount of bank guarantee given in lieu of security deposit from the bills in one installment and the contractor further agrees that failure to extend the validity of bank guarantee or failure to pay the aforesaid amount in the manner specified above shall constitute breach of contract. In addition to above, BHEL shall be entitled to take such action as deemed fit and proper for recovering the said sum.

5. That in consideration of the payments to be made to the Contractor by BHEL in accordance with this Agreement the Contractor hereby covenants and undertakes with BHEL that they shall execute, construct, complete the works in conformity, in all respects, with the terms and conditions specified in this Agreement and the documents governing the same.
6. That the Contractor shall be deemed to have carefully examined this Agreement and the documents governing the same and also to have satisfied himself as to the nature and character of the Works to be executed by him.
7. That the Contractor shall carry out and complete the execution of the said works to the entire satisfaction of the Engineer or such other officer authorised by BHEL, within the agreed time schedule, the time of completion being the essence of the Contract.
8. That BHEL shall, after proper scrutiny of the bills submitted by the Contractor, pay to him during the progress of the said works such sum as determined by BHEL in accordance with this Agreement.
9. That this Agreement shall be deemed to have come into force from ----- the date on which the letter of intent has been issued to the Contractor.
10. That whenever under this contract or otherwise, any sum of money shall be recoverable from or payable by the Contractor, the same may be deducted in the manner as set out in the General Conditions of Contract or other conditions governing this Agreement.
11. That all charges on account of Octroi, Terminal and other taxes including sales tax or other duties on material obtained for execution of the said works shall be borne and paid by the Contractor.
12. That BHEL shall be entitled to deduct from the Contractor's running bills or otherwise Income Tax under Section 194 (C) of the Income Tax Act, 1961.
13. That BHEL shall be further entitled to recover from the running bills of the Contractor or otherwise such sum as may be determined by BHEL from time to time in respect of

CONTRACT AGREEMENT

Form No: F-10 (Rev 00)

consumables supplied by BHEL, hire charges for tools and plants issued (Where applicable) and any other dues owed by the Contractor.

14. That it is hereby agreed by and between the parties that non- exercise, forbearance or omission of any of the powers conferred on BHEL and /or any of its authorities will not in any manner constitute waiver of the conditions hereto contained in these presents and the liability of the Contractor with respect to compensation payable to BHEL or Contractor's obligations shall remain unaffected.

15. It is clearly understood by and between the parties that in the event of any conflict between the Letter of Intent and other documents governing this Agreement, the provisions in the Letter of Intent shall prevail.

16. The following documents

1. Invitation to Tender No-----
and the documents specified therein.

2. Contractor's Offer No-----
dated-----.

3. _____

4. _____

5. _____

6. Letter of Intent No_____ dated_____.

7. _____

shall also form part of and govern this Agreement.

IN WITNESS HEREOF, the parties hereto have respectively set their signatures in the presence of

WITNESS

1.

2.

(CONTRACTOR)
(to be signed by a person holding
a valid Power of Attorney)

WITNESS

1.

2.

(For and on behalf of BHEL)

BANK GUARANTEE FOR SECURITY DEPOSIT

B.G. NO.

Date

This deed of Guarantee made this ----- day of -----two thousand ---- by <Name and Address of Bank> hereinafter called the "The Guarantor" (which expression shall unless repugnant to the context or meaning thereof be deemed to include its successors and assigns) in favour of M/s Bharat Heavy Electrical Limited (A Govt. of India Undertaking) a company incorporated under the Companies Act, 1956, having its registered office at BHEL House, Siri Fort, Asiad, New Delhi – 110049 through its unit at BHEL, Power Sector Northern Region, Sector-16-A, NOIDA -201301(UP) hereinafter called "The Company" (which expression shall unless repugnant to the context or meaning thereof be deemed to include its successors and assigns)

WHEREAS < Contractor's Name and Address> (hereinafter referred to as the Contractor) have entered into a contract arising out of Letter of Intent no. < LOI REF & Date > (hereinafter referred to as "the contract") for < Name of Work > with the company.

AND WHEREAS the contract inter-alia provides that the contractor shall furnish to the company a sum of Rs.----- (Rupees-----) towards security deposit for due and faithful performance of the contract in the form and manner specified therein.

AND WHEREAS the contractor has approached the Guarantor and in consideration of the arrangement arrived at between the contractor and the Guarantor, the Guarantor has agreed to give the Guarantee as hereinafter mentioned in favour of the company.

The Guarantor do hereby guarantee to the company the due and faithful performance, observance or discharge of the Contract by the contractor and further unconditionally and irrevocably undertake to pay to the Company without demur and merely on a demand, to the extent of Rs.----- (Rupees-----) against any claim by the company on them for any loss, damage, costs, charges and expenses caused to or suffered by the company by reasons of the contractor making any default in the performance, observance or discharge of the terms, conditions, stipulations or undertakings or any of them as contained in the contract.

The decision of the company whether any default has occurred or has been committed by the contractor in the performance, observance or discharge of any of the terms, conditions, stipulations or undertakings or any one of them as contained in the contract and / or as to the extent of loss, damage, costs, charges and expenses caused to or suffered by the company by reason of the contractor making any default in the performance, observance or discharge of any of the terms, conditions, stipulations or undertakings or any one of them shall be conclusive and binding on the Guarantor irrespective of the fact whether the contractor admits or denies the default or questions the correctness of any demand made by the company in any Court, Tribunal or Arbitration proceedings or before any other Authority.

The company shall have the fullest liberty without affecting in any way the liability of the Guarantor under this Guarantee, from time to time to vary any of the terms and conditions of the contract or extend time of performance by the contractor or to postpone for any time and from time to time any of the powers exercisable by it against the contractor and either enforce or forebear from enforcing any of the terms and conditions governing the contract or securities available to the company and the Guarantor shall not be released from its liability under these presents by any exercise by the company of the liberty with reference to the matters aforesaid or by reasons of time being given to the contractor or any other forbearance, act or commission on the part of the company or any indulgence by the company to the contractor or any other matter or thing whatsoever which under the law relating to sureties would, but for this provision have the effect of so releasing the Guarantor from its liability under this guarantee.

The Guarantor further agrees that the Guarantee herein contained shall remain in full force and effect during the period that would be taken for the performance of the contract and its claim satisfied or discharged and till the company certifies that the terms and conditions of the contract have been fully and properly carried out by the contractor and accordingly discharges this Guarantee, subject however, that the company shall have no claim under this Guarantee after -- i.e. (the present date of validity of Bank Guarantee unless the date of validity of this Bank Guarantee is further extended from time to time, as the case may be) unless a notice of the claim under this Guarantee has been served on the Guarantor before the expiry of the said period in which case the same shall be enforceable against the Guarantor notwithstanding the fact that the same is enforced after the expiry of the said period.

BANK GUARANTEE FOR SECURITY DEPOSIT

The Guarantor undertakes not to revoke this Guarantee during the period it is in force except with the previous consent of the Company in writing and agrees that any liquidation or winding up or insolvency or dissolution or any change in the constitution of the contractor or the Guarantor shall not discharge the Guarantor's liability hereunder.

It shall not be necessary for the company to proceed against the contractor before proceeding against the Guarantor and the Guarantee herein contained shall be enforceable against them notwithstanding any security which the Company may have obtained or obtain from the Contractor shall at the time when proceedings are taken against the Guarantor hereunder be outstanding or unrealized.

Notwithstanding anything contained herein before, our liability under the Guarantee is restricted to Rs.----- - (Rupees-----). Our guarantee shall remain in force until -----, i.e. (the present date of validity of Bank Guarantee unless the date of validity of this Bank Guarantee is further extended from time to time) unless a claim or demand under this guarantee is made against us on or before ----- we shall be discharged from our liabilities under this Guarantee thereafter.

Any claim or dispute arising under the terms of this documents shall only be enforced or settled in the courts of at New Delhi/Delhi only.

The Guarantor hereby declares that it has power to execute this guarantee and the executant has full powers to do so on behalf of the Guarantor.

IN WITNESS whereof the ----- (Bank) has hereunto set and subscribed its hand the day, month and year first, above written.

(Name of the Bank)

Signed for and on behalf of the Bank
(Designation of the Authorized Person Signing the Guarantee)

(Signatory No.-----)

DATED:

SEAL

=====

Notes :

1. **Address of Power Sector Regions (inviting the Tender)** is as below:
 - PSNR : Bharat Heavy Electricals Limited, Power Sector Northern Region, HRDI & PSNR Complex, Plot No 25, Sector 16-A, Noida – 201 301 (Uttar Pradesh)
 - PSER : Bharat Heavy Electricals Limited, Power Sector Eastern Region, BHEL Bhawan, Plot No 9/1, DJ Block, Sector-II, Salt lake City, Kolkata – 700 091
 - PSWR: Bharat Heavy Electricals Limited, Power Sector Western Region, Shree Mohini Complex, 345 Kingsway, Nagpur 440 001
 - PSSR: Bharat Heavy Electricals Limited, Power Sector Southern Region, 690, Anna Salai, Nandanam, Chennai 600 035
2. **Name of place (for jurisdiction of Courts)** is as below:
 - PSNR : Delhi
 - PSER : Kolkata
 - PSWR: Nagpur
 - PSSR : Chennai
3. The BG shall be executed on non-judicial stamp papers of adequate value procured in the name of the Bank in the State where the Bank is located.
4. The BG is required to be sent by the executing Bank directly to BHEL at the address where tender is submitted / accepted under sealed cover.

BANK GUARANTEE FOR INTEREST BEARING REFUNDABLE ADVANCE

B.G. No.

Date

This deed of Guarantee made this _____ day of _____ two thousand _____ by < **Name and Address of Bank**> hereinafter called the "The Guarantor" (which expression shall unless repugnant to the context or meaning thereof be deemed to include its successors and assigns) in favour of M/S Bharat Heavy Electricals Limited a Company incorporated under the Companies Act, 1956, having its registered office at BHEL House, Siri Fort, New Delhi - 110049 through its unit at BHEL, POWER SECTOR, Northern Region, Sector-16 A, NOIDA-201301 (UP) hereinafter called "The Company" (which expression shall unless repugnant to the context or meaning thereof be deemed to include its successors and assigns).

WHEREAS M/s. _____ (hereinafter referred to as the Contractor) have entered into a Contract arising out of Letter of Intent no. _____ dtd _____ (hereinafter referred to as "the Contract") for the < **Name of work**> with the Company.

AND WHEREAS the Contract inter-alia provides that the Company will pay to the Contractor interest bearing advance of Rs. _____ (Rupees _____ only) on certain terms and conditions specified in the Contract subject to the Contractor furnishing a Bank Guarantee for Rs. _____ (Rupees _____ only) in favour of the Company.

AND WHEREAS the Company has agreed to accept a Bank Guarantee from a Bank to cover the said advance.

AND WHEREAS the Contractor has approached the Guarantor and in consideration of the arrangement arrived at between the Contractor and the Guarantor, the Guarantor has agreed to give the Guarantee as hereinafter mentioned in favour of the Company.

NOW THIS DEED WITNESSES AS FOLLOWS:-

(1) In consideration of the Company having agreed to advance a sum of Rs. _____ (Rupees _____ only) to the Contractor, the Guarantor do hereby guarantee the due recovery by the Company of the said advance with interest thereon as provided according to the terms and conditions of the Contract. If the said Contractor fails to utilise the said advance for the purpose of the Contract and /or the said advance together with interest as aforesaid is not fully recovered by the Company the Guarantor do hereby unconditionally and irrevocably undertake to pay to the Company without demur and merely on a demand, to the extent of the said sum of Rs. _____ (Rupees _____ only) any claim made by the Company on them for the loss or damage caused to or suffered by the Company by reasons of the Company not being able to recover in full the advance with interest as aforesaid.

BANK GUARANTEE FOR INTEREST BEARING REFUNDABLE ADVANCE

- (2) The decision of the Company whether the Contractor has failed to utilise the said advance or any part thereof for the purpose of the Contract and / or as to the extent of loss or damage caused to or suffered by the Company by reason of the Company not being able to recover in full the said sum of Rs. _____ with interest if any shall be final and binding on the Guarantor, irrespective of the fact whether the Contractor admits or denies the default or questions the correctness of any demand made by the Company in any Court Tribunal or Arbitration proceedings or before any other Authority.
- (3) The Company shall have the fullest liberty without affecting in any way the liability of the Guarantor under this Guarantee, from time to time to vary any of the terms and conditions of the Contract or extend time of performance by the Contractor or to postpone for any time and from time to time any of the powers exercisable by it against the Contractor and either enforce or forbear from enforcing any of the terms and conditions governing the Contract or securities available to the Company and the Guarantor shall not be released from its liability under these presents by any exercise by the Company of the liberty with reference to the matters aforesaid or by reasons of time being given to the Contractor or any other forbearance, act or commission on the part of the Company or any indulgence by the Company to the Contractor or of any other matter or thing whatsoever which under the law relating to sureties would, but for this provision have the effect of so releasing the Guarantor from its liability under this guarantee.
- (4) The Guarantor further agrees that the Guarantee herein contained shall remain in full force and effect during the period till the Company discharges this Guarantee, subject to however, that the Company shall have no claim under this Guarantee after _____ i.e. (the present date of validity of Bank Guarantee unless the date of validity of this Bank Guarantee is further extended from time to time, as the case may be) unless a notice of the claim under this Guarantee has been served on the Guarantor before the expiry of the said period in which case the same shall be enforceable against the Guarantor not withstanding the fact that the same is enforced after the expiry of the said period.
- (5) The Guarantor undertakes not to revoke this Guarantee during the period it is in force except with the previous consent of the Company in writing and agrees that any liquidation or winding up or insolvency or dissolution or any change in the constitution of the Contractor or the Guarantor shall not discharge the Guarantor's liability hereunder.
- (6) It shall not be necessary for the Company to proceed against the Contractor before proceeding against the Guarantor and the Guarantee herein contained shall be enforceable against them notwithstanding any security which the Company may have obtained or obtain from the Contractor shall at the time when proceedings are taken against the Guarantor hereunder be outstanding or unrealised.
- (7) Notwithstanding anything contained herein before, our liability under the Guarantee is restricted to Rs. _____ (Rupees _____). Our guarantee shall remain in force until _____, i.e. the present date of validity of Bank Guarantee unless the date of validity of this Bank Guarantee is further extended from time to time. Unless a claim or demand under this guarantee is made against us on or before-----, we shall be discharged from our liabilities under this Guarantee thereafter.

BANK GUARANTEE FOR INTEREST BEARING REFUNDABLE ADVANCE

- (8) Any claim or dispute arising under the terms of this document shall only be enforced or settled in the courts at New Delhi/Delhi only.
- (9) The Guarantor hereby declares that it has power to execute this Guarantee under its Memorandum and Articles of Association and the executant has full powers to do so on its behalf under the Power of Attorney dated _____ (To be incorporated by the Bank) granted to him by the proper authorities of the Guarantor.

IN WITNESS whereof the _____(Bank) has hereunto set and subscribed its hand the day, month and year first, above written.

(Name of the Bank)

Signed for and on behalf of the Bank
(Designation of the Authorized Person Signing the Guarantee)

(Signatory No.-----)

DATED:

SEAL

Notes :

1. **Address of Power Sector Regions (inviting the Tender)** is as below:
 - PSNR : Bharat Heavy Electricals Limited, Power Sector Northern Region, HRDI & PSNR Complex, Plot No 25, Sector 16-A, Noida-201301 (Uttar Pradesh)
 - PSER : Bharat Heavy Electricals Limited, Power Sector Eastern Region, BHEL Bhawan, Plot No 9/1, DJ Block, Sector-II, Salt lake City, Kolkata – 700 091
 - PSWR: Bharat Heavy Electricals Limited, Power Sector Western Region, Shree Mohini Complex, 345 Kingsway, Nagpur 440 001
 - PSSR: Bharat Heavy Electricals Limited, Power Sector Southern Region, 690, Anna Salai, Nandanam, Chennai 600 035
2. **Name of place (for jurisdiction of Courts)** is as below:
 - PSNR : Delhi
 - PSER : Kolkata
 - PSWR: Nagpur
 - PSSR : Chennai
3. The BG shall be executed on non-judicial stamp papers of adequate value procured in the name of the Bank in the State where the Bank is located.
4. The BG is required to be sent by the executing Bank directly to BHEL at the address where tender is submitted / accepted, under sealed cover.

FORM for EXTENSION OF VALIDITY OF BANK GUARANTEE

- 1. To be typed on non judicial Stamp Papers of value as applicable in the State of India from where the BG has been issued or the State of India where the BG shall be operated
- 2. The non judicial stamp papers shall be purchased in the name of the Party on whose behalf the BG is being issued or the BG issuing Bank

BANK GUARANTEE NO.:

Date:.....

To

(Write Designation and Address of Officer of BHEL inviting the Tender)

Dear Sir

Sub : Validity of Bank Guarantee No:..... Dated for
..... Rs in favour of yourself, expiry date
....., on account of M/s in respect of
Contract Number....., (herein after called the Original bank Guarantee)

At the request of M/s....., we Bank,
having its branch Office at and having Head office
at, do hereby extend our liability under the above mentioned Bank Guarantee
number..... dated for a further period ofMonths/years
from to expire on

Except as provided above, all other terms and conditions of the Original Bank Guarantee No
..... Dated..... shall remain unaltered and binding on us.

Kindly treat this extension as an integral part of the original Bank Guarantee to which it
would be attached.

Yours faithfully

Signature.....
Name & Designation.....
Power of Attorney/Signing Power No
Seal of Bank



MONTHLY PLAN & REVIEW WITH CONTRACTOR

Page 1 of 4

Name of Site		Contract No.	
		Name of Contractor	
Review for the month of		Brief Scope of work	
Date of Review			

PART- A PHYSICAL REVIEW

Sl.No	Description of work	Unit of Measurement	Original Plan (QTY Planned for the month as per joint review of previous month)	Last months shortfall (attributable to Contractor)	Total Planned for the month (including previous month backlog attributable to Contractor)	Achieved	Shortfall attributable to (in Qty)		REMARKS
			(a)	(b)	C=(a)+(b)		BHEL	Contractor	
		UOM	Phy.	Phy	Phy	Phy.	Phy.	Phy.	

Use separate sheets if necessary

BHEL
(Sign with name, designation and date)

CONTRACTOR
(Sign with name, designation and date)



PS- NR

**MONTHLY PLAN & REVIEW WITH
CONTRACTOR**

Page 2 of 4

CONTRACT NO:

CONTRACTOR:

PART – B-1 REVIEW OF DEPLOYMENT OF MAJOR T&Ps

SUPPLIER SCOPE:-

SN.	MAJOR T&P TO BE DEPLOYED AS PER WORK PLANNED FOR THE MONTH	QTY.	DEPLOYMENT STATUS (ACTUAL DEPLOYED)	REMARKS (WORKS EFFECTED DUE TO NON-DEPLOYMENT OF T&Ps)

BHEL SCOPE:-

BHEL
(Sign with name, designation and date)

CONTRACTOR
(Sign with name, designation and date)



PS- NR

**MONTHLY PLAN & REVIEW WITH
CONTRACTOR**

Page 3 of 4

CONTRACT NO:

CONTRACTOR:

PART – B-2 REVIEW OF DEPLOYMENT OF MANPOWER

SUPPLIER SCOPE:-

SNO.	AREA OF WORK	CATEGORY OF LABOUR	NO. OF LABOUR REQUIRED AS PER CATEGORY	DEPLOYED FOR THE PERIOD	REMARKS (WORKS AFFECTED DUE TO NON-AVAILABILITY OF LABOUR)

BHEL
(Sign with name, designation and date)

CONTRACTOR
(Sign with name, designation and date)



PS- NR

MONTHLY PLAN & REVIEW WITH CONTRACTOR

Page 4 of 4

CONTRACT No.:**Date of Report:****PART C1 : PLAN FOR THE NEXT MONTH (PHYSICAL)**

SL NO.	DESCRIPTION OF WORK (Area Wise)	PLANNED MT/ % / QTY (EXCLUDING SHORTFALLS ATTRIBUTABLE TO CONTRACTOR TILL DATE)	T&Ps REQUIRED	MANPOWER REQUIRED	REMARKS

NOTE: USE SEPARATE SHEETS, IF REQUIRED

**PART C2: PLAN FOR THE NEXT MONTH
(OTHERS)**

SL NO.	DESCRIPTION OF WORK (Area Wise)	PLANNED MT/ % / QTY	T&Ps REQUIRED	MANPOWER REQUIRED	REMARKS

NOTE: USE SEPARATE SHEETS, IF REQUIRED

BHEL
(Sign with name, designation and date)

CONTRACTOR
(Sign with name, designation and date)



QUARTERLY EVALUATION OF OF CONTRACTOR PERFORMANCE

Page No 1 Of 4

NOTE: This evaluation should be done **EVERY QUARTER** * by the respective Regions for all Contracts under executions

* : March, June, September & December of every year

A	GENERAL	
1	Reporting Period	Quarter ending : Year :
2	Name of Site	
3	Name of Contractor	
4	Contract Number/LOI Number & Date	
5	Name of Work	
6	Contract Start Date	
	I. As per Contract	
	II. Actual Date of Start	
7	Completion Status (as on date)	
	I. Physical completion in %age	
	II. Running Bill amount paid in %age of Contract Value	
8	Scheduled Completion Time	
9	Actual Date of Completion	
10	Awarded Contract Value	
11	Final contract Value	
BHEL		Contractor
(Signature with Name, Designation & date)		(Signature with Name, Designation & date)



QUARTERLY EVALUATION OF CONTRACTOR PERFORMANCE

Page No 2 Of 4

		MAX SCORE	SCORE OBTAINED
1.0 QUALITY			
1.1	Amenability to Quality System	5	
1.2	Adherence to Quality Standards	5	
1.3	Preventing recurrence of Defects/Complaints	5	
1.4	Finishing and aesthetics	5	
1.5	Housekeeping	5	
1.6	Rating of Quality Officer for Quality Control of Job	5	
2.0 DELIVERY			
2.1	Achievements vis a vis Requirements/Commitments	5	
2.2	Timely Depoyment of Manpower	5	
2.3	Timely Depoyment of T&Ps and MMEs	5	
2.4	Timely arrangement of Consumables	5	
3.0 MANPOWER			
3.1	Experience and Job knowledge of Supervisory personnel	5	
3.2	Aptitude of supervisory Personnel (w.r.t. Attitude, Initiative, Leadership, Cooperativeness, etc.)	5	
3.3	Adequacy of Manpower (Work Force) deployed	5	
3.4	Competence of Manpower (Work Force) deployed	5	
4.0 T&P, IMTEs & CONSUMABLES			
4.1	Adequacy of T&P & MMEs as per Site requirement	5	
4.2	Condition of T&P & MMEs	5	
4.3	Ensuring Fitness & Calibration of T&P & MMEs	5	
4.4	Adequacy of Consumables as per Site requirement	5	
5.0 SITE INFRASTRUCTURE AND SERVICE			
5.1	Site Organization vis a vis Commitment	5	
5.2	Readiness to rectify Defects	5	
5.3	Providing support Documents and Records	5	
5.4	Speed of responce	5	
5.5	Cooperativeness in Delivering and Implementing Improvement Measures	5	
5.6	Approachability of Top Management during critical requirements and its cooperation	5	



QUARTERLY EVALUATION OF CONTRACTOR PERFORMANCE

Page No 3 Of 4

6.0 SITE FINANCE

6.1	Regularity in Payment to Staff and Workers	5	
6.2	Financing Site Operation	5	

7.0 HSE (Health Safety & Environment) & SA (Social Accountability)

7.1	Health & Safety Awareness among Employess	5	
7.2	Rating of Safety Supervisor on HSE Aspects		
7.2.1	Experience and Job knowledge of Safety Supervisor	5	
7.2.2	Rating of safety Supervisor for controlling Safety at Site	5	
7.3	Quality & Usage of Safety gadgets		
7.3.1	Personal Protective Equipments (PPE)	5	
7.3.2	Use of Safety Equipments & Safety in Equipments (Safety Net, Toeguard, Proper earthing, Fire-fighting Equipments etc.)	5	
7.4	Use of Safety Posters	5	
7.5	Compliance to Social Accountablity Norms	5	
7.6	Rating based on feed back of HSE & SA Audits	5	

8.0 OTHERS

8.1	Concern for Employees Welfare and Health (like First Aid)	5	
8.2	Compliance to Statutory Requirements, State and Local Laws/Regulations	5	
8.3	Tendency of taking undue advantage by interpreting Contract Clauses in their favour (Score 5 for no tendency)	5	
8.4	Understanding of Contract (Scope & Contract Clauses)	5	
8.5	Planning of Work Activities(Monthly/Weekly/Daily)	5	
8.6	Submission of Monthly/Weekly/daily Report	5	

BHEL
(Signature with Name, Designation & date)

Contractor
(Signature with Name, Designation & date)



QUARTERLY EVALUATION OF CONTRACTOR PERFORMANCE

SI No	Category	Max Score	Score obtained	Weightage factor	Weighted Score
1	Quality	30		0.4	
2	Delivery	20		0.75	
3	Manpower	20		0.6	
4	T&Ps, MMEs & Consumables	20		0.75	
5	Site Infrastructure & Service	30		0.4	
6	Site Finance	10		1.1	
7	HSE & SA	40		0.35	
8	Others	30		0.3	
9	Total Weighted Score				
10	Any detail which Construction Manager wants to share with Management				
11	<u>Less</u> Score for Accidents attributable to Contractor during the Reporting Period (Major at@3 Minor@1)				
a	Major Accidents-----Fatal,Permanent Disability, Major Damage to Equipment.				(-)
b	Minor Accidents ----- All others				(-)
12	Net Weighted Score (OUT OF 100):				
Overall Performance Evaluation :			Good / Satisfactory / Unsatisfactory		
Net Weighted Score					
80% and Above			- Good		
Between 60% To 80%			-Satisfactory		
60% and Below			-Unsatisfactory		
Dated:			Section Head/ Site Engineer		
Specific Recommendation of Construction Manager:					
			Construction Manager		
FOR SUB CONTRACT DEPTT.					
Dated			Head (S/C)		
GM/SCP					

Note: This summary evaluation sheet is to be sent to Contractor after every Evaluation



**ANNUAL EVALUATION OF CONTRACTOR
PERFORMANCE**
(EVALUATED FINANCIAL YEAR WISE AT HQ)

Page 1 of 1

1. **Contract No.:**
2. **Contractor:**
3. **Name of Site :**
4. **Reporting Period (Financial Year):**

Sl No	QUARTER	Net Weighted score
1	Quarter-I	
2	Quarter-II	
3	Quarter-III	
4	Quarter-IV	
5	Total for the 4 Quarters	
6	Average for the Year (Financial Year)	
7	Annual Evaluation of Contractor Performance (based on net weighted score)	<ul style="list-style-type: none"> ➤ 80% and above : Good ➤ Between 60% to 80% : Satisfactory ➤ 60% and below : Unsatisfactory

Comments if any:

Head/Subcontracts

Date:

General Manager/SCP



**OVERALL PERFORMANCE OF CONTRACTOR FOR THE
CONTRACT**
(EVALUATED CONTRACT WISE AT HQ)

Page 1 of 1

1. Contract No.:

2. Contractor:

3. Name of Site :

4. Reporting period (From : _____ To : _____)

SI No	FINANCIAL YEAR	QUARTER	Net Weighted score
1		Quarter-I	
		Quarter-II	
		Quarter-III	
		Quarter-IV	
2		Quarter-I	
		Quarter-II	
		Quarter-III	
		Quarter-IV	
3		Quarter-I	
		Quarter-II	
		Quarter-III	
		Quarter-IV	
4		Quarter-I	
		Quarter-II	
		Quarter-III	
		Quarter-IV	
5		Total for all the quarters	
6		Average for the all the Quarters (Contract Period)	
7		Overall Performance for the Contract (based on net weighted score)	➤ 80% and above : Good ➤ Between 60% to 80%: Satisfactory ➤ 60% and below : Unsatisfactory

Comments if any:**Head/Subcontracts****Date:****General Manager/SCP**

MILESTONE COMPLETION CERTIFICATE
(issued by BHEL on the specific request of Contractor)

Ref :

Date:

To,

(Name & address of Contractor)

Dear Sir,

References

1. Contract No:
2. Job Description:

This is to hereby confirm that the following Milestone Activity has been achieved in respect of the Contract /Job under reference

SI No	Milestone Activity	Remarks

This certificate is issued as per your request vide letter no
without any prejudice to the rights of BHEL in line with the terms and conditions of the
above referred Contract

Yours faithfully,

For and on behalf of Bharat Heavy Electricals Limited

Construction Manager/Head (Subcontracts)

CONTRACT COMPLETION CERTIFICATE
 (Issued by BHEL/HQ on the specific request of Contractor)

Ref :

Date:

To Whom so ever it may concern

1	DESCRIPTION OF WORK	
2	NAME AND ADDRESS OF THE CONTRACTOR	
3	CONTRACT NO	
4	CONTRACT VALUE	
5	LETTER OF INTENT NO & DATE	
6	CONTRACT PERIOD//CONTRACT DURATION	
7	FINAL EXECUTED VALUE	
8	PERFORMANCE	GOOD SATISFACTORY UNSATISFACTORY

This certificate is issued as per your request vide letter no
 without any prejudice to the rights of BHEL to use this certificate for evaluation of your offers for future tenders

Yours faithfully,

For and on behalf of Bharat Heavy Electricals Limited

Head (Subcontracts)

INDEMNITY BOND

(To be executed on a Non Judicial Stamp Paper of the requisite value as per Stamp Duty prevalent in the respective State)

This Indemnity Bond executed by <name of company> having their Registered Office at <xxxxxxxxxx> in favour of M/s Bharat Heavy Electricals Limited, a Company incorporated under the Companies Act, 1956, having its Registered Office at BHEL House, Siri Fort, Asiad, New Delhi - 110049 through its Unit at Power Sector-Northern Region, Sector-16-A, NOIDA-201301, Uttar Pradesh State (India). (Hereinafter referred to as the Company)

And whereas the Company has entered into a Contract with M/s xxxxxxxxx, the executants of this Deed (hereinafter referred to as the Contractor) as its contractor in respect of the work of "xxxxxxxxxxxxxxxxxxxxxxxxxxxxxx".

AND WHEREAS under the provisions of GCC further stipulates that the Contractor shall indemnify the Company against all claims of whatever nature arising during the course of execution of Contract including defects liability period of <xx Months > i.e till <xx xx xxxx>

Now this deed witness that in case the Company is made liable by any Authority including Court to pay any claim or compensation etc. in respect of all labourers or other matters at any stage under or relating to the Contract with the Contractor , the Contractor hereby covenants and agrees with the Company that they shall indemnify and reimburse the Company to the extent of such payments and for any fee, including litigation charges, lawyers' fees, etc, penalty or damages claimed against the Company by reason of the Contractor falling to comply with Central/States Laws, Rules etc, or his failure to comply with Contract (including all expenses and charges incurred by the Company).

The Contractor further indemnifies the Company for the amount which the Company may be liable to pay by way of penalty for not making deductions from the Bills of the Contractor towards such amount and depositing the same in the Government Treasury.

INDEMNITY BOND

(To be executed on a Non Judicial Stamp Paper of the requisite value as per Stamp Duty prevalent in the respective State)

The Contractor further agree that the Company shall be entitled to with hold and adjust the Security Deposit and/or with hold and adjust payment of Bills of Contractor pertaining to this Contract against any payment which the Company has made or is required to make for which the Contractor is liable under the Contract and that such amount can be withheld, adjusted by the Company till satisfactory and final settlement of all pending matters and the Contractor hereby gives his consent for the same.

The Contractor further agrees that the terms of indemnity shall survive the termination or completion of this contract.

The contractor further agrees that the liability of the contractor shall be extended on actual basis notwithstanding the limitations of liability clause, in respect of :

1. breach of terms of contract by the contractor
2. breach of laws by the contractor
3. breach of Intellectual property rights by the contractor
4. breach of confidentiality by the contractor

Nothing contained in this deed, shall be construed as absolving or limiting the liability of the Contractor under said Contract between the Company and the Contractor. That this Indemnity Bond is irrevocable and the condition of the bond is that the Contractor shall duly and punctually comply with the terms and the conditions of this deed and contractual provisions to the satisfaction of the Company.

In witness where of M/s xxxxxxxxxxxxxx these presents on the day, month and year first, above written at xxxxxxxx by the hand of its signatory Mr. xxxxxxxxxxxx.

Signed for and on behalf of
M/s xxxxxxxxxxxxxxxxxxxx

Witness:

- 1
- 2

TIE-UP/CONSORTIUM AGREEMENT

(To be executed on Rs. 50/- Non – Judicial Stamp Paper)

THIS AGREEMENT is made and executed on this _____ day of _____, by and between (1) M/s _____, (The First Party, i.e, the Bidder) a company incorporated under the Company's Act 1956, having its registered office at _____(herein after called the "Bidder", which expression shall include its' successors, administrators, executors and permitted assigns) and (2) M/s _____, (The Second Party, i.e, the associates), a company incorporated under the Company's Act 1956, having its registered office at _____ (herein after called the " Associates", which expression shall include its' successors, administrators, executors and permitted assigns).

WHEAEAS the Owner, Bharat Heavy Electricals Ltd, a Government of India Undertaking, proposes to issue / issued an NIT (herein after referred to as the said NIT) inviting bids from the individual Bidders for undertaking the work of _____, at _____ (herein after referred to as the said works).

WHEREAS the said NIT enables submission of a bid by a Consortium subject to fulfillment of the stipulations specified in the said NIT.

AND WHEREAS M/s _____ (The First Party, i.e, the Bidder) will submit its proposal in response to the aforesaid invitation to bid by the Owner for _____ as detailed in the Bid doc. no. < TENDER REF----->

AND WHEREAS M/s _____ (The First Party, i.e the Bidder) itself is meeting all the qualifying requirements except the qualifying requirements of _____ (as detailed in the NIT) and in order to fully meet the qualifying requirements of NIT, this tie-up agreement is being entered into with M/s _____ (The Second Party, the Associates) , who fully meet the balance part of the said works (_____).

WHEREAS the First Party and the Second Party are contractors engaged in the business of carrying out various items of works. WHEREAS the two parties have agreed to constitute themselves into a consortium for the purpose of carrying out the said works, and that the consortium will be continued till the completion of the works in all respects.

WHEREAS the parties have agreed to certain terms and conditions in this regard:

TIE-UP/CONSORTIUM AGREEMENT

NOW THEREFORE THIS AGREEMENT WITNESSETH AS FOLLOWS :

1. First and Second parties hereby constitute themselves into a Consortium for the purpose of bidding and undertaking the said works pursuant to the said NIT as hereinafter stated.
2. The First Party will be the leader (Lead Partner) and will be responsible for the entire works.

TIE-UP AGREEMENT

3. The First Party shall undertake the following part(s) of work detailed in the NIT namely _____

4. The Second Party shall undertake the following part(s) of work detailed in the said NIT namely _____

5. The parties hereby declare and confirm that each of them will fulfill the required minimum qualifying requirements as prescribed in the said NIT for the works agreed to be undertaken by them as stated here-in-above.
6. It is also agreed between the parties hereto that all of them shall be individually and severally responsible for the completion of the said works as per the schedule. Further, if the Employer/Owner sustains any loss or damage on account of any breach of the Contracts, we the, Consortium partners individually and severally undertake to promptly indemnify and pay such losses / damages caused to the Employer/Owner on its written demand without any demur, reservation, contest or protest in any manner whatsoever.
7. The parties hereby agree and undertake that they shall provide adequate finances, suitable Tools, Plants, Tractors, Trailers, other transportation equipment, other Tools & Plants, Measuring & Monitoring Equipments (MMEs), Men and Machinery etc. for the proper and effective execution of the works to be undertaken by them as specified here-in-above.
8. It is agreed interse between the parties hereto that all the consequences liabilities etc., arising out of any default in the due execution of the said works shall be borne by the party in default, that is by party in whose area of works default has occurred, provided however, so far as M/s Bharat Heavy Electricals Limited is concerned, all the parties shall be liable jointly and severally.

TIE-UP/CONSORTIUM AGREEMENT

IN WITNESS HEREOF the parties above named have signed this agreement on the day month and year first above written at _____(Place) .

WITNESS For
1. NAME (FIRST PARTY)
2. OFFICIAL ADDRESS

WITNESS For
1. NAME (SECOND PARTY)
2. OFFICIAL ADDRESS

[The successful bidder shall have to execute the " JOINT DEED OF UNDERTAKING " in the format to be made available by BHEL at the time of awarding].

REFUND OF SECURITY DEPOSIT

To,

The Construction Manager
BHEL Site Office

Dear Sir,

Sub : Refund of Security Deposit

Ref : Contract No:

Work:.....

I/We have submitted Final Bill in respect of the above Contract/Work vide our letter no:..... dated In line with Tender conditions (GCC clause no 1.11), kindly arrange to release/refund the Security Deposit along with Final Bill payments.

The details of Security Deposit are as below:

- 1. Cash Portion :
- 2. BG Portion :

Thanking You

Date: _____

Authorised representative of Contractor

To be filled up by BHEL

- 1. Security Deposit to be refunded:
 - a. Cash Portion:
 - b. BG Portion :
- 2. Less
 - a. Amount spent by BHEL on behalf of Contractor:
 - b. Payments made by BHEL on behalf of Contractor:
 - c. Other recoveries for Services etc
 - d. Any other recoveries
 - e. Total of 'a' to 'd':
- 3. Net Amount to be released (1-2) :
- 4. Certified that
 - a. The payment recommended for release is in order and there are no demands other than those included in the claim outstanding from the Contractor
 - b. Contract Guarantee period of Months commenced wef : _____
 - c. All objections raised so far have been settled
 - d. A note for refund of Security Deposit has been made in the Measurement Book

Signature of BHEL Engineer

Construction Manager

Date:-----

REFUND OF GUARANTEE MONEY

**BHARAT HEAVY ELECTRICALS LIMITED
POWER SECTOR, NORTHERN REGION**

Ref No:

Date:

1. Name and Address of Contractor :
2. Contract Agreement/LOI No :
3. Date of Contract Agreement/LOI :
4. Name of the Work undertaken :
5. Date of commencement of the Work :
6. Date of Completion of the Work :
7. Period of Maintenance :
(Guarantee Period)
8. Date on which the Final Bill was paid :
9. Last date of making good the defect :
during Maintenance Period
10. Expenditure incurred by BHEL during :
Maintenance Period, if any, recoverable
11. Date on which Guarantee Money refund:
falls due as per Contract
12. Amount of Guarantee Money to be refunded:
13. Less Amounts recoverable (with details)
 - a. Amount spent by BHEL on maintenance :
 - b. Payments made by BHEL on behalf of Contractor:
 - c. Court dues/penalties/compensation :
 - d. Other recoveries for Services, etc :
 - e. Total of 'a' to 'd' :
14. Net Amount recommended for release (12-13) :

Signature of BHEL Engineer

Date: _____

REFUND OF GUARANTEE MONEY

**BHARAT HEAVY ELECTRICALS LIMITED
POWER SECTOR, NORTHERN REGION**

CERTIFICATE TO BE FURNISHED BY THE CONTRACTOR

I/We have no claim or demand outstanding against BHEL _____, for the work done or for labour or material supplied or any other account arising out of or connected with the Contract Agreement/LOI (No _____ dated _____) and the payment of this bill shall be in full and final settlement of all my/our claims and demands including the 'Deposits' of the Contract Agreement/LOI referred to.

Signature of Contractor

Date:

CERTIFICATE TO BE FURNISHED BY SENIOR ENGINEER/CONSTRUCTION MANAGER

1. Certified that
 - a. The payment recommended for release is in order and there are no demands other than those included in the claim outstanding from the Contractor
 - b. Maintenance period (Contract Guarantee period) is over and the Contractor has carried out the works required to be carried out by him during the period of maintenance (Guarantee) to our satisfaction, and all expenses incurred by the Company on carrying out such works have been included for adjustment
 - c. All objections raised so far have been settled
 - d. A note for refund of Guarantee Amount has been made in the Measurement Book and Contract Agreement/Work Order

Signature of BHEL Engineer

Construction Manager

Date:-----

FOR USE IN ACCOUNTS DEPARTMENT

Passed for Rs _____ (Rupees _____ only)

Accountant

Accounts Officer

ACKNOWLEDGE BY THE CONTRACTOR

Received Rs _____ in full and final settlement of my/our claim

Signature of Contractor

Date:

POWER OF ATTORNEY for SUBMISSION OF TENDER/SIGNING CONTRACT AGREEMENT

(To be typed on non judicial Stamp Papers of appropriate value as applicable and Notarised)

KNOW ALL MEN BY THESE PRESENTS, that I/We do hereby make, nominate, constitute and appoint Mr , whose signature given below herewith to be true and lawful Attorney of M/s..... hereinafter called 'Company', for submitting Tender/entering into Contract and inter alia, sign, execute all papers and to do necessary lawful acts on behalf of Company with M/s Bharat Heavy Electricals Ltd, Power Sector, Northern Region, NOIDA-201301 (UP), in connection with
..... vide Tender Specification No : _____, dated _____.

And the Company do hereby agree to ratify and confirm all acts, deeds, things or proceedings as may be lawfully done by the said attorney and by or on behalf of the company and in the name of the company, by virtue of the powers conferred herein and the same shall be binding on the company and shall have full force and effect.

IN WITNESS WHEREOF the common seal of the company has been hereunto affixed in the manner hereinafter appearing on the document.

Dated at _____, this _____ day of _____

Director/CMD/Partner/Proprietor

Signature of Mr.....(Attorney)

Attested by: Director/CMD/Partner/Proprietor

Witness

Notary Public

ANALYSIS OF UNIT RATES QUOTED

(To be typed and submitted in the Letter Head of the Company/Firm of Bidder)

Offer Reference No:.....

Date:.....

To,

(Write Name & Address of Officer of BHEL inviting the Tender)

Dear Sir,

Sub : Analysis of Unit Rates Quoted

Ref : Tender Specification No:

Analysis of Unit Rates quoted by us in respect of above Tender is as detailed

SN	DESCRIPTION	% OF QUOTED RATE	REMARKS
01	SITE FACILITIES VIZ., ELECTRICITY, WATER OTHER INFRASTRUCTURE.		
02	SALARY AND WAGES + RETRENCHMENT BENEFITS		
03	CONSUMABLES		
04	T&P DEPRECIATION & MAINTENANCE		
05	ESTABLISHMENT & ADMINISTRATIVE EXPENSES		
06	OVERHEADS		
07	PROFIT		
	TOTAL	100%	

Yours faithfully,

(Signature, Date & Seal of Authorized Representative of the Bidder)

BHARAT HEAVY ELECTRICALS LIMITED

DIVISION.....

Running Account Bill

(Para 4.31.1 of Works Accounts Manual)

Name of the Contractor:

Name of the Work:

Sanctioned Estimate:

Code No:

Contract Agreement No :

Dated:

Departmental Bill no:

Division:

Date of written order to commence the work :

Date of commencement of the Work:

Due date of completion as per Agreement:

Date:

Sub-Division:

1. ACCOUNT OF WORK EXECUTED

On account payment for work not previously previously measured**			Item No of	Description of Work	Quantity as per agree- ment	Quantity executed up to date	Rate	Unit	Payment on the basis of actual measure- ment up to date	Quantity since last running account bill	Payment on the basis of actual measurement since last running account bill	Remarks
Total	since last	Total										
As per	running	up to										
Running	account	date										
Account	bill											
bill												
Rs.	Rs.	Rs.					Rs.	P.	Rs.	P.	Rs.	P.
1	2	3	4	5	6	7	8	9	10	11	12	13

* *1. Whenever payment is made on 'on account' basis without actual measurements the amount in whole rupees should be entered in columns 1 to 3 only and not in columns 7 to 12.

2. whenever there is an entry in column 12 on the basis of actual measurement, the whole of the amount previously paid without detailed measurement should be adjusted by a minus entry in column 2 equivalent to the amount shown in column 1, so that the total up to date in column 4 may become nil.

1	2	3	4	5	6	7	8	9	10	11	12	13
---	---	---	---	---	---	---	---	---	----	----	----	----

Total value of work done up to date (A) ...

Deduct value of work shown on the last Running Account Bill (B) ...

Net value of work done since last (C) ...

Rupees (in words)only.

II.MEMORANDUM OF PAYMENTS

		I		II	
		Rs.	P.	Rs.	P.
1.Total value of work actually measured as per Account No. I. Column 10	(A)	
2.Total up to date 'on account' payment for work covered by approximate Or plan measurements as per Account No. I, Column 3	(B)	
3.Total up to date secured advances on security of materials as per column 8 Of the enclosed Account (Form WAM 10)	(C)	
4.Total up to date payments [(A) + (B) + (C)]	(D)	
5.Total amount of payments already made as per Entry (D) of last Running Account Bill No..... Dated.....forwarde to the Accounts Office on	(E)				
6.Balance [(D)-(E)]				
7.Payments now to be made:					
a) by cash/cheque				
b) by deduction for value of materials supplied				
c) by BHEL vide Annexure A attached				
d) by deduction for hire of tools and plant vide Annexure B attached				
e) by deduction for other charges vide Annexure C Attached				
f)by deduction on account of security deposit				
h) by deduction on account of Income Tax			

Note: Amounts relating to items 4 to 6 above should be entered in column II and those relating to item 7 in column I. The amount shown against item 6 and the total of item 7 should agree with each other.

III.CERTIFICATE OF THE ENGINEER IN CHARGE

Form WAM 6 (contd...)

1. The measurements on which the entries in column 7 to 12 of Part I of this Bill (Account of work executed) are based were made by.....and are recorded at pages.....of
(Name and Designation)

Measurement Book No

2. Certified that the methods of measurement are correct and the work has been carried out in accordance with the terms and conditions, schedules, specifications and drawings etc, forming part of the contract agreement, subject to deviations included in the deviation statement (Annexure D).

3. Certified that in addition to and quite apart from the quantities of work actually executed as shown in column 10 of Part I, some work has actually been done in connection with several items and the value of the such work is, in no case, less than 'on account' payments as per column 3 of Part I, made or proposed to be made, for the convenience of the contractor in anticipation of, and subject to the results of, detailed measurement which will be made as soon as possible.

Signature of Contractor
Date:

Signature of Engineer in charge
Designation:
Date:

IV. CERTIFICATE OF THE SENIOR ENGINEER

1. Certified that measurements have been check measured to the prescribed extent byat site and also by the undersigned and the relevant entries have been intialled in the Measurement book. (vide pages.....)
(Name and Designation)

2. Certified that all the measurements recorded in the measurement book have been correctly billed for

3. Certified that all recoberable amounts in respect of materials tools and plant etc, and other charges have been correctly made vide

Annexures A to C attached.

Certified for payment * of Rs.....(Rupees.....only)

To be paid in cash/by cheque in the presence of

ALLOCATION

The expenditure is chargeable as under and to be included in the accounts for.....20.....

Ledger Head	Debit (Gross amount)	Credit (Deductions)
	Rs. P.	Rs. P.
Total		

* Here specify the net amount payable.

Signature of Senior Engineer
Date:

ANNEXURE A

Statement showing details of materials issued to the contractor Shri/M/s.....
 In respect of Contract Agreement NoDated.....

Sl. No.	Stores issue Voucher No. and date	Issue voucher No. and date allotted by stores to the SIV	Description of material issued to the contractor	Quantity issued	Quantity actually incorporated in the work	Whether recoverable from the contractor or supplied free	If recoverable from the contractor				R E M A R K S
							Rate at which recoverable	Amount recoverable	Amount recovered up to previous bill	Balance now recovered	
1	2	3	4	5	6	7	8	9	10	11	12
							Rs. P.	Rs. P.	Rs. P.	Rs. P.	

Total

Signature of contractor
Date:

Signature of Engineer in Charge
Date:

Signature of Senior Engineer
Date:

ANNEXURE B

Statement showing tools and plant issued to the contractor Shri/M/s.....
 In respect of Contract Agreement NoDated.....

Sl. No	Description of tools and plant issued	Period for which Issued	Rate at which recovery Is to be Made		Amount recover-able		Amount recovered upto previous bill		Balance now recovered		Remarks
			Rs.	P.	Rs.	P.	Rs.	P.	Rs.	P.	
1	2	3	4	5	6	7	8				

Total

Signature of contractor
Date:

Signature of Engineer in Charge
Date:

Signature of Senior Engineer
Date:

ANNEXURE D

Name of the Contractor:
Name of the Work:

Contract Agreement No:
Date:

Sl. No.	Description of item	Unit	Quantity as per Agreement	Quantity as executed	Quantity further anticipated	Total quantity anticipated on completion	Rate as per agreement	
							Rs.	P.
1	2	3	4	5	6	7	8	

Rate as executed	Amount as per agreement	Amount as executed	Amount further anticipated	Total amount anticipated on completion	Difference				Reason for the deviation with authority, if any
					Excess		savings		
Rs. P.	Rs. P.	Rs. P.	Rs. P.	Rs. P.	Rs. P.	Rs. P.	Rs. P.		
9	10	11	12	13	14	15	16		

Signature of Engineer in Charge
Date:

Signature of Senior Engineer
Date:

1	2	3	4	5	6	7	8	9	10	11	12	13
---	---	---	---	---	---	---	---	---	----	----	----	----

Total Value of Work Done up to date	(A)	
Deduct Value of work shown on the last running account bill	(B)	
Net value of work done since last running account bill	(C)	

Rupees (In Words).....Only

II MEMORANDUM OF PAYMENT

1	Total Value of work actually measured as per Account no I coloumn 10	(A)	Rs.	P
	Deduct amount of paym,ents already made as per last running account bill No Dated.....			
2	Forwarded to the Accounts Office on	(B)		
3	Payments now to be made { (A) - (B)}	(C)		
4	Deduct ammounts recoverable from the contractor on account of :	Rs		P
	a Material suplied by BHEL vide annexure A attached			
	b Hire of Tools & Plants vide Annexure B attached			
	c Other charges vide Annexure C attached			
	d Income Tax			
	Total deduction			
5	Balance			
6	Refund of 50% of security deposite on completion of work			
7	Net amount to be paid to the Contractor			

III. CERTIFICATE OF THE ENGINEER IN CHARGE

The measurement on which the entries in coulms 7 to 12 of Part I of this bill (Account of work executed) are based were made by

-
- 1 (Name and designation)
 - 2 A statement showing the quantities of stores issued to the contractor (whether free or on recovery basis) and their disposal is attached.

Date:

Signature of Engineer in charge
Designation

IV CERTIFICATE OF THE SENIOR ENGINEER

- 1 Certified that I have personally inspected the work and that the work has been physically completed on the due date in accordance with the terms and
 Certified that the measurements have been check measured to the prescribed extent by
 (Name & designation). And by the the undersigned at site and relevent entries have been initiated in the measurement book (vide
 2 pages.....)
- 3 Certified that the methods of measurement are correct
- 4 Certified that the measurements have been technically checked with reference to contract drawings, deviations etc
- 5 Certified that all the measurements recorded in the measurement book have been correctly billed for at the contract rates or approved rates.
- 6 Certified that all the recoverable amounts in respect of stores, tools and pallant, elwater, electricity charges etc, have been correctly made vide Annexures A
- 7 Certified that the issues of all stores as per statement atyatched (whether charged to the contractor or direct to the work) have been technically checked and

Certified for payment of * Rs (Rupees.....) (Only). To be paid in
 cash/by cheque in the presence of

ALLOCATION

The expenditure as under and to be included in the accounts for19

Ledger Head	Debit (Gross Amount)		Credit (Deduction)	
	Rs.	P	Rs.	P
.....
Total

* Here specify the net amount payable

Signature of Senior Engineer
 Date

V. ENTRIES TO BE MADE IN THE ACCOUNTS OFFICE

Account Bill no..... Dated

Entered in Journal book vide entry No..... Dated.....

Passed for.....Rs.....

Less Deductions.....Rs.....

(Rupees.....Only)

Payable to Shri/M/s..... by cheque/cash

Entered in contractors' Ledger no..... Page

ALLOCATION

Estimate No:

Name of the Work

Code No

Credit
(Deduction)
Rs

Ledger Head

Debit
(Gross Amount)
Rs P

Total

Assistant Accountant Accounts officer

Date: Date: Date:

VI. Received Rs.....(Rupees.....Only) in full and final settlement of all moneys due under this contract and I / we have no further claims of this contract.

Signature of Witness
Address

Revenue Stamp
Signature of Contractor
Date:

VII . ENTRIES TO BE MADE BY TREASURY SECTION

Cash book entry no and date :

Amount Paid Rs.....

Amount unpaid Rs.....

Total Rs.....

Signature of Cashier
Date:

ANNEXURE A
Part I

Statement showing details of material issued to the contractor Shri/M/s..... In respect of Contract Agreement/Work Order No..... Dated

SI No	Stores Issue voucher No and date	Issue voucher No and date allotted by stores to the SIV	description of material issued to the contractor	Quantity issued	Quantity incorporated in the work	Whether recoverable from the contractor or supplied free	Rate at which recoverable		If recoverable from contractor				Remarks		
							Rs	P	Amount Recoverable	upto previous bill	Amount recoverable	Balance Now recovered			
									Rs	P	Rs	P	Rs	P	
1	2	3	4	5	6	7	8	9	10		11				12

Total

Signature of Contractor
Date

Signature of Engineer in charge
Date

Signature of Senior Engineer
Date

ANNEXURE A

Part II

Statement showing details of material issued to the contractor Shri/M/s..... in respect of Contract Agreement/Work Order No..... Datedand not covered by the agreement

SI No	Stores Issue voucher No and date	Issue voucher No and date allotted by stores to the SIV	description of material issued to the contractor	Quantity issued	Quantity actually incorporated in the work	Issue Rate		Amount Recoverable		Amount recoverable upto previous bill		Balance Now recovered		Remarks
						Rs	P	Rs	P	Rs	P	Rs	P	
1	2	3	4	5	6	7	8	9	10	11	11			

Total

Add Departmental Charges

Add Sales Tax (wherever applicable)

Total

Signature of Contractor
Date

Signature of Engineer in charge
Date

Signature of Senior Engineer
Date

ANNEXURE B

Statement showing TOOLS & PLANTS issued to the contractor Shri/M/s..... in respect of Contract Agreement/Work Order No..... Datedand not covered by the agreement

SI No	Description of tools & plants issued	Period for which issued	Rate at which Recivry is to be made	Amount recoverabl e		Amount recoverable upto previous bill		Balance Now recovered		Remarks
				Rs	P	Rs	P	Rs	P	
1	2	3	4	5		6		7		8
				Total						

Signature of Contractor
Date

Signature of Engineer in charge
Date

Signature of Senior Engineer
Date

ANNEXURE C

showing detail of other recoveries to be made from the contractor Shri/M/s.....
 nent/Work Order No..... Dated.....

Sr.No	Particulars	Unit	Quantity	Rate Rs. P.	Amount recoverable Rs. P	Amount recovered upto previous bill Rs. P.	Amount now recovered Rs. P.	Remarks
1	2	3	4	5	6	7	8	9
	1 Water Charges							
	2 Electricity Charges							
	3 Seignorage Charges							
	4 Medical Charges							
	Cost of empty gunny bags and empty containers not 5 returned							
	6							
	7							
	8							
	9							
	10							
Total								

Signature of Contractor
Date

Signature of Engineer Incharge
Date

Signature of Sr. Engineer
Date

**ANNEXURE D -
DEVIATION STATEMENT :**

Name of the Contractor :

Contract Agreement/Work Order No. :

Name of the Work :

Date :

Sl. No.	Description of item	Unit	Quantity as per agreement	Quantity as executed	Rate as per agreement Rs. P.	Rate as executed Rs. P.	Amount as per agreement Rs. P.	Amount as executed Rs. P.	Difference		Reason for the deviation with authority, if any
									Excess	Savings	
1	2	3	4	5	6	7	8	9	10	11	12

Signature of Engineer in Charge

Date :

Signature of Senior Engineer

Date :

ANNEXURE E

Statement showing the consumption of materials issued to the contractor Shri/M/s.....
in respect of Contract Agreement/Work Order No..... Dated.....

Name of the Work :

ON RECOVERY BASIS

Sl. No.	Description of material	Unit	Quantity actually issued	Quantity actually incorporated in the work	Balance	Particulars of disposal of balance	Quantity to be issued as per approved data for work actually done	Variation in consumption (Difference between column 5 and 8)		Rate chargeable for excess/short consumption, if any	Amount recoverable for excess/short consumption, including materials not returned	
								More	Less		Rs. P.	Rs. P.
1	2	3	4	5	6	7	8	9	10	11	12	13
1.	Cement											
2.	Bricks											
3.	Wood.....											
4.	Asbestos Sheet											
5.	Iron Materials											
6.												
7.												
8.												
9.												
10.												

Signature of Contractor

Date :

Signature of Engineer in Charge

Date :

Signature of Senior Engineer

Date :

Note : 1. The quantities shown in columns 4 and 5 above should tally with those shown in columns 5 and 6 respectively of Annexure A (Part I and II).

2. Data statement of theoretical consumption should be attached in support of quantity specified in column 8.

ANNEXURE F

Statement showing detail of materials issued to the contractor Shri/M/s.....

of Contract Agreement/Work Order No.....Dated.....

Name of work;

FREE OF COST

Sr.No	Stores issue voucher No.	Description of material	Unit	Quantity issued	Quantity required as per data	Quantity consumed in the work	Balance(If any)	Nature of disposal for the balance	Rate chargeable for material not returned Rs.P.	Amount recoverable for material not returned Rs. P	Remarks
1	2	3	4	5	6	7	8	9	10	11	12
Total											
Signature of Contractor Date				Signature of Engineer Incharge Date				Signature of Sr. Engineer Date			
Note:Data statement of theoretical consumption should be attached in support of the quantity specified in column 6											