


1470221/2023/PS-PEM-MAX

	<b>PROJECT: 2X 660 MW TALCHER TPP STAGE-III</b> <b>PRE-QUALIFICATION REQUIREMENT- VENTILATION SYSTEM.</b>	PE-PQ-497-554-A002	
		DATE	19.05.2023
		REV NO	00

1.0	The bidder should have designed, supplied, erected and commissioned at least one (1) number Ventilation system including air washer unit having individual fan capacity of 80,000 Cum./Hr. or more. The system should have been in successful operation for at least one (1) year as on 06.06.2022
2.0	The supplier has to submit following supporting documents meeting above mentioned pre-qualifying requirement  Copy of minimum one (1) performance certificate (in English) from end user along with copy of related Purchase Order (PO) or Letter of intent (LOI) or Letter of Award (LOA) or Work Order (WO) in support of PQR clause at S.No.1.0 above.
3.0	Bidder shall submit all necessary data such as type, design, make, capacity, duty conditions, date of commissioning/ operation etc. to substantiate technical parameters specified in PQR, if the same is not mentioned in performance certificate/purchase order.
4.0	Bidder to submit all supporting documents in English. If documents submitted by bidder are in language other than English, a self-attested English translated document should also be submitted.
5.0	Notwithstanding anything stated above, BHEL reserves the right to assess the capabilities and capacity of the bidder to perform the contract, should the circumstances warrant such assessment in the overall interest of BHEL.
6.0	Consideration of offer shall be subject to customer's approval of bidders, if applicable.
7.0	After satisfactory fulfilment of all the above criteria/ requirement, offer shall be considered for further evaluation as per NIT and all the other terms of the tender.
8.0	The bidder shall meet PQR based on its own credentials. Bid from joint venture (JV) company / Consortium bid is not acceptable.