



LIMIT SWITCH CONTACT DEVELOPMENT				
CONTACT	POSITION	HOME	INTER MEDIATE END	FORWARD
LS-1	1-2	X	X	-
LS-2	4-5	-	X	X
	4-6	X	-	-
X CONTACT CLOSED, - CONTACT OPEN				

REV	DATE	ALTERED :	CHD./APPD. :

	JHARKHAND STATE ELECTRICITY BOARD PATRATU T.P.S., 2x110MW, R&M, STAGE IV, UNIT 9 & 10, CUSTOMER No. D113 & D114
DEPT. : C&I CODE : 392	LONG RETRACTABLE BLOWER CONTROL SCHEME DIAGRAM
SHEET NO. 10/24 	DATE 02-01-08 SCALE NTS DRAWING NO. : 3-96-186-90093 REV 00