



Checklist of Documents to be Submitted with Technical Bid

Annexure - IV

Sl. No.	REQUIREMENT	Bidder's Response
1	Self Certification of clause wise compliance of all clauses of NIFPS requirement mentioned in RDSO specification TI/SPC/PSI/TRNPWR/3201 (Annexure-1).	☐ Submitted
2	Type, make and quantity of Fire detector being used (in line with Clause 11.0 of RDSO NIFPS Specification.) to be submitted.	☐ Submitted
3	IP-55 protection certificate of Fire extinguishing cubicle (FEC) (in line with Clause of 11.0 of of RDSO NIFPS Specification) to be submitted.	☐ Submitted
4	Type, make and quantity of the fire survival cable and manufacturer's test certificate of the cable reflecting withstand temperature (in line with Clause 11.0 of RDSO NIFPS Specification) to be submitted.	☐ Submitted
5	Type and make of FRLS cable of 1.5 mm sq. along with cable manufacturer's test certificate (in line with clause 11.0 of Rof RDSO NIFPS Specification.) to be submitted.	☐ Submitted
6	Type test Report of Fire Detectors (in line with Clause 9.0 of RDSO NIFPS Specification) to be submitted.	☐ Submitted
7	The vendor must have facility for conducting factory tests of NIFPS as per Clause 9 (b) / Clause 13 of RDSO NIFPS Specification.	☐ Available
8	Confirmation to conduct all Factory Test in presence of RDSO as per Clause 13.0 of RDSO NIFPS specification.	☐ Agreed
9	Confirmation to conduct Performance Test after complete erection of NIFPS System at site in presence of RDSO as per Clause 9.0 (c) of RDSO NIFPS Specification.	☐ Agreed
10	Detailed drawing of NIFPS as per Clause 10.0 of RDSO NIFPS Specification to be submitted.	☐ Submitted
11	Declaration that make/model of the fire detector supplied with the transformer and which has been tested at third party laboratory are same (as per Clause 13.5 of RDSO Specification).	☐ Submitted
12	Confirmation to perform live demonstration test as per Clause 13.6 of RDSO NIFPS Specification	☐ Agreed
13	Manual of NIFPS (in line with Clause 11.0 of RDSO NIFPS specification) to be submitted.	☐ Submitted
14	The Purity certificate of Nitrogen gas of 99.99% purity (in line with Clause 11.0 of RDSO NIFPS specification) to be submitted.	☐ Submitted
15	Bill of Materials of NIFPS System to be supplied	☐ Submitted

- We agree that our bid is liable to be rejected in case (a) the relevant information is not filled, (b) documentation is incomplete, (c) there are false declarations, and (d) if we do not meet the PQR.
- Type tests for which facilities of testing are not available with the manufacturer shall be carried out at Govt. Lab/NABL. If capacity constraint in Govt. Lab/NABL, type test can also be carried out at accredited Lab by a Govt. controlled accreditation agency which meets the criteria mentioned in RDSO's ISO document No.QO-D-8.1-10 Ver. 1.6 or its latest version.

(Signature of the Supplier with Name, Designation & Seal)