



- PARAMETERS TO BE CONSIDERED :
1. Crane Height should be less than 24 M
  2. Max. Boom Length should atleast 38.3m (40 m Max)
  3. Crane Capacity at the Centre of LP Turbine should be 20 MT (As shown in the fig)
  4. Crane Capacity at the end should be atleast 2 MT
  5. Crane shall be placed and travelled in the Service Bay Only
  6. Crane Boom should be such that it may be dismantled in 3 Parts.

Capacity Required at this Point = 20 MT

CAPACITY REQUIRED AT THIS POINT = 2 MT