



- PARAMETERS TO BE CONSIDERED :
1. Crane Height should be less than 24 M
 2. Max. Boom Length should atleast 3015 m (31 m Max)
 3. Crane Capacity at the Centre of LP Turbine should be 20 MT (As shown in the fig)
 4. Crane Capacity at the end should be atleast 2 MT
 5. Crane shall installed over 4 pedestals as shown in fig.
 6. Crane Boom should be such that it may be dismantled in 3 Parts.

Capacity Required at This Point = 20 MT

CAPACITY REQUIRED AT THIS POINT = 2 MT

Min Required Boom Length : 30151 mm (30m Approx)

4 Nos of Pedestals - For High Lift Arrangement WHICH MAY BE USED FOR INSTALLATION OF FIXED TYPE TOWER CRANE