

 <b>BHARAT HEAVY ELECTRICALS LIMITED</b> <b>TRANSMISSION BUSINESS GROUP</b> <b>ENGINEERING MANAGEMENT, NOIDA, SECTOR-62</b>											
COPYRIGHT AND CONFIDENTIAL The information contained in this document is the property of BHARAT HEAVY ELECTRICALS LIMITED This must not be used directly or indirectly, in any manner detrimental to the interest of the company	BHEL Document No.			Rev	Prepared by		Checked by		Approved by		
	TB-387-316-011			00	Name	NK	SKS		AG		
	Type of Document			TECHNICAL SPECIFICATION		Sign	<i>N. K. Shah</i>		<i>S. K. S.</i>		
	Title			420 kV POST INSULATOR		Date	27.12.21	27.12.21	27.12.21		
				Group		TBEM					
	CUSTOMER:			TELANGANA STATE POWER GENERATION CORPORATION LTD.							
	PROJECT:			5x800 MW YADADRI TPS – 400 kV SWITCHYARD							
	LOI NO:			ED/TPC/SE-III/YADADRI TPS(5X800MW)/D.No. 102/17, Dated: 17/10/2017							
	<b>CONTENTS</b>										
	<b>SECTION</b>		<b>TITLE</b>							<b>PAGE</b>	
1		Scope, Specific Technical Requirements & Quantities							04		
2		Equipment Specification							03		
3		General Technical Requirement							13		
4		Guaranteed Technical Particulars							02		
5		Annexure – A (No deviation certificate)							01		
6		Check List							01		
Rev No.		Date	Altered	Checked	Approved	REVISION DETAILS					
Distribution					To						
					Copies						

**SECTION 1**  
**SCOPE, SPECIFIC TECHNICAL REQUIREMENTS AND QUANTITIES**

## 1.0 SCOPE

This technical specification covers the requirements of design, manufacture, testing at works, packing and dispatch of 420 kV BPI complete with accessories as listed under this specification.

This section covers the specific technical requirements of BPI. This constitutes minimum technical parameters for the above item as specified by the customer (TSGENCO). The offered equipment shall also comply with the General Technical Requirements for the project as detailed under section-3 of this specification.

The specification comprise of following sections:

- Section-1: Scope, Specific Technical Requirements & Quantities
- Section-2: Equipment Specification
- Section-3: General Technical Requirements
- Section-4: Guaranteed Technical Particulars

In case of any conflict between various sections, order of precedence shall be in the same order as listed above.

## 1.1 THE EQUIPMENT IS REQUIRED FOR THE FOLLOWING PROJECT

Name of customer : Telangana State Power Generation Corp. Ltd.  
Name of the project : 400 kV Switchyard at 5X800MW Yadadri TPS  
Consultant : TCE Bangalore  
Refer Section - 3 for Project Details and General Specifications.

## 1.2 SPECIFIC TECHNICAL REQUIREMENTS

SI No.	Particulars	420 kV
01	Rated system voltage / Highest system voltage	400 / 420 kV
02	Type	Cylindrical Solid Core
03	Material	Porcelain
04	Installation	Outdoor
05	Creepage distance (mm)	10500
06	Height (mm)	3650
07	Pitch circle dia (mm)	
	a) Top	127
	b) Bottom	300
08	No. of bolts	
	a) Top	4
	b) Bottom	8
09	Diameter of bolt holes	

	a) Top b) Bottom	M16 M18
10	Total Minimum Cantilever Strength (Bending strength) (Kg)	800
11	Total Minimum Breaking Strength (Kg)	1000
12	Minimum Torsional strength (kN-m)	As per IEC 273 or 600 kg
13	Corona Extinction Voltage (kV rms) (Min.)	320
14	One minute power frequency withstand voltage (kV rms) a) Dry b) Wet	710 680
15	Dry Lightning Impulse withstand voltage (kVp)	±1425
16	Wet Switching Surge Withstand Voltage (kVp)	±1050
17	Max. radio interference voltage (in microvolts) at voltage 305 kV (rms) for 400 kV between phase and ground	500
18	Seismic Acceleration	0.3g

Note: If corona extinction voltage is to be achieved with the help of corona ring or any other similar device, the same shall be deemed to be included in the scope of the vendor.

### 1.3 QUANTITIES

The number of post insulators of each type, to be supplied, is given below. Each supplied post insulator shall be complete with the accessories as stated in this specification.

S. No.	Details	(Main+Spare) Qty
1	SUPPLY- POST INSULATORS : 400KV, 25MM/KV CREEPAGE, 8KN, POST INSULATOR FOR BUS SUPPORT WITH CORONA RING	(529+12)=541 Nos.
2	SUPPLY- POST INSULATORS : 400KV, 25MM/KV CREEPAGE, 8KN, POST INSULATOR FOR ISOLATOR WITHOUT CORONA RING	(513+39)=552 Nos.

NOTE:

1. Post insulators shall be supplied complete with Hot Dip Galvanised Hardware for inter-unit joining and fixing to structure (both top & bottom).
2. Final quantity may vary  $\pm 20\%$ .

### 1.4 TYPE TESTS

Bidder shall submit valid type test reports (as per relevant IEC/IS standard) for the tests carried out after 17.10.2012. The reports should have been conducted on identical or similar equipment/components to those offered. In case type test reports are earlier than 17.10.2012 or the reports of type tests are found to be technically unacceptable, the type test shall be conducted by the vendor without cost and delivery implication to BHEL.

## 1.5 INSPECTION & TESTING

Before being fitted on the equipment, all components shall be subjected to routine tests at the Contractors factory, provided by the relevant IEC/IS standards. A detailed test report proving the successful passing of such tests shall be provided.

Prior to dispatch, the routine & acceptance tests shall be carried out on each item in accordance with the applicable IEC/IS and the material shall be offered for final inspection by BHEL and TSGENCO in accordance with agreed quality plan with 3 weeks advance information. The charges for these shall be deemed to be included in the equipment price.

## 1.6 QUALITY PLAN

The contractor shall carry out contract works in accordance with sound quality management principles which shall include such as controls which are necessary to ensure full compliance to all requirements of the specification & applicable international standards. These quality management requirement shall apply to all activities during design, procurement, manufacturing, inspection, testing, packaging, shipping, inland transportation, storage, site erection & commissioning. Contractor shall submit detailed Quality Plan for BHEL / customer's approval.

## 1.7 TITLE BLOCK

The drawings / documents submitted shall be project and product specific and shall incorporate following details:

- a) Project Name : 400 kV Switchyard at 5X800MW Yadadri TPS
- b) Customer Name : Telangana State Power Generation Corp. Ltd.
- c) Consultant Name : TCE, Bangalore
- d) Contractor : BHEL
- e) Customer LOA no. : ED/TPC/SE-III/YADADRI TPS(5X800MW)/D.No. 102/17, Dated: 17/10/2017

## 1.8. Drawings / Documents

The drawings / documents submitted shall be project and product specific and shall incorporate all project details and title block of the customer as detailed in Section 1, 2 & 3.

The drawings/ documents, as follows shall be used for providing engineering manufacturing clearance of the equipment (400kV Post Insulators) and furthermore, it shall be used for delay analysis, if any from bidder.

The schedule for submission and resubmission shall be in line with details provided in section-3.

1	400kV Post Insulators - Drawings & Guaranteed Technical Particulars
2	400kV Post Insulators - Type Test Reports
3	400kV Post Insulators - Quality Assurance Plan & Inspection Test Schedule

Date of Submission of first lot of drawings/ documents shall be counted only from the date of

submission of reasonably correct drawings/ documents.

The successful bidder shall have to extend all possible supports like timely submission/ re-submission of drawings, visit to end customer to facilitate documents approval without any commercial implications to BHEL. Acceptance of bidder's documents shall be subject to end customer approval.

Soft copies in CD-R of documents shall comprise

- i) Scanned images of all approved documents, including drawings.
- ii) Editable versions (AUTO CAD 2000 or High) of all drawings viz. drawings, GTP, Manufacturing and field quality plan, type test reports, O & M instructions / manuals.

Telangana State Power Generation Corp. Ltd.  
400 kV Switchyard at 5X800 MW Yadadri TPS  
Technical Specification of 420 kV PI

Bharat Heavy Electricals Ltd.  
Doc. No. TB-387-316-011, Rev 00

## SECTION - 2

### EQUIPMENT SPECIFICATION

#### 2.1 GENERAL

This section covers the general technical requirements of Post Insulators.

#### 2.2 APPLICABLE STANDARDS

The Post Insulators shall conform to the following standards, as appropriate:

Sl. No.	Description	Code
01	Fittings for aluminium and steel cored aluminium conductors for overhead power lines	IS: 2121 (1981)
02	Porcelains insulators for overhead power lines with a nominal voltage 100 V	IS: 731 (1991)
03	Insulator fittings for overhead power lines with a nominal voltage greater than 1000 V	IS: 2486 (P1-P4)
04	Dimensions of ball and socket couplings of string insulators unit	IEC-120 (1981)
05	Insulated bushings for alternating voltages above 1000V	IEC-137 (1995)
06	Test on indoor and outdoor post insulators of ceramic material or glass for systems with nominal voltage greater than 1000 V	IEC-168 (1994)
07	Tests on hollow insulators for use in electrical equipment	IEC-233 (1988)
08	Characteristics of indoor and outdoor post insulators for systems with nominal voltages greater than 1000V	IEC-273 (1990)
09	Insulators for overhead lines with nominal voltage above 1000V ceramic or glass insulator units for AC systems characteristics of string insulator units of the cap and pin type	IEC-305 (1995)
10	Locking devices for ball and socket couplings of string insulator units: dimensions and tests	IEC-372 (1984)
11	Insulators for overhead lines with a nominal voltage above 1000 V	IEC-383 (P1&P2 1993)
12	Characteristics of string insulator units of the long rod type	IEC-133 (1980)
13	Dimensions of Clevis and tongue couplings of string insulator units	IEC-171 (1977)
14	Wet process porcelain insulators	ANSI-C29
15	Test methods for electrical power insulators	ANSI-C29.1
16	For insulators, wet process porcelains and toughened glass suspension type	ANSI-C29.2
17	For wet process porcelain insulators apparatus, post type	ANSI-

Telangana State Power Generation Corp. Ltd.  
400 kV Switchyard at 5X800 MW Yadadri TPS  
Technical Specification of 420 kV PI

Bharat Heavy Electricals Ltd.  
Doc. No. TB-387-316-011, Rev 00

		C29.8
18.	Iron and steel hardware	ANSI-0.8
19	Recommendations of the CISPR tolerances of form and of position, part one	CISPR-7B
20	Zinc, coating hot dip on iron and steel hardware	ASTM A-153

### 2.3 CONSTRUCTIONAL FEATURES

- 2.3.1 Post type insulators shall consist of porcelain part permanently secured in a metal base to mount on the supporting structures. They shall be capable of being mounted upright. Type shall be designed to withstand any shocks to which they may be subjected to by the associated equipment. Only solid core insulators will be acceptable.
- 2.3.2 Porcelain used shall be homogeneous free from lamination cavities and other flaws or imperfections that might affect the mechanical or dielectric quality and shall be thoroughly vitrified, tough and impervious to moisture.
- 2.3.3 Glazing of the porcelain shall be of uniform brown in colour, free from blisters, burrs and other similar defects.
- 2.3.4 The insulator shall have alternate long and short sheds with aerodynamic profile. The shed profile shall also meet the requirements of IEC – 815 for the specified pollution level.
- 2.3.5 When operating at normal rated voltage there shall be no electric discharge between conductor and insulators, which would cause corrosion or injury to conductors, or insulator by the formation of substance produced by chemical action.
- 2.3.6 The design of the insulators shall be such that stresses due to expansion and contraction in any part of insulator shall not lead to deterioration.
- 2.3.7 All ferrous parts shall be hot dip galvanized in accordance with the latest edition of IS: 2633, & IS: 4579. The zinc used for galvanizing shall be grading Zn 99.95 as per IS: 209. The zinc coating shall be uniform, adherent smooth, reasonably bright, continuous and free from imperfections such as flux ash, rust stains bulky white deposits and blisters. The metal parts shall not produce any noise-generating corona under the operating conditions.
- 2.3.8 A) Every bolt shall be provided with a steel washer under the nut so that part of the threaded portion of the bolts is within the thickness of the parts bolts is within the thickness of the parts bolted together.
- B) Flat washer shall be circular of a diameter 2.5 times that of bolt and of suitable thickness. Where bolts heads/nuts bear upon the bevelled surfaces they shall be provided with square tapered washers of suitable thickness to afford a seating square with the axis of the bolt.
- C) All bolts and nuts shall be of well formed hexagonal heads forged from the solid and shall be hot dip galvanized. The nuts shall be good fit on the bolts and two clear threads shall show through the nut when it has been finally tightened up.
- 2.3.9 Bidder shall make available data on all the essential features of design including the method of assembly of shells and metals parts, number of shells per insulator. The manner in which mechanical stresses are transmitted through shells to adjacent parts, provision for meeting expansion stresses, are transmitted through shells to adjacent parts, provision for meeting expansion stresses, results of corona and thermal shock tests, recommended working strength and any special design or arrangement employed to increase life under service conditions.

Telangana State Power Generation Corp. Ltd.  
400 kV Switchyard at 5X800 MW Yadadri TPS  
Technical Specification of 420 kV PI

Bharat Heavy Electricals Ltd.  
Doc. No. TB-387-316-011, Rev 00

- 2.3.10 Post insulator stack shall be used to support either the ACSR conductor or tubular Aluminium bus of Outdoor EHV switchyard. Insulators shall be solid core porcelain type and composed of stacked units. Insulators of identical rating shall be interchangeable.
- 2.3.11 Insulator having sufficient cantilever strength shall be of wet process porcelain, brown glazed and free from all blemishes. Metal parts and hardwares shall be hot-dip galvanised.
- 2.3.12 Insulator shall have adequate mechanical strength and rigidity to withstand the duty involved.
- 2.3.13 When operated at maximum system voltage, there shall be no electrical discharge. Corona/grading ring if necessary, shall be provided with the post insulator.
- 2.3.14 Each post insulator will be mounted on steel structure. The insulators shall be provided with necessary nuts, bolts & washers.

## 2.4 TESTS

Bidder to submit all type test/special test report as per relevant IS/IEC clause. In accordance with the stipulations under section –2 the post insulators shall be subject to type, acceptance, sample and routine tests as per IS: 2544 and IEC-168.

- 2.4.1 In addition to acceptance/sample/routine tests as per IS: 2544 and IEC-168, the following tests shall also be carried out.
- a) Ultrasonic test as an acceptance test.
  - b) Soundness test, metallurgical tests and magnetic test on MCI caps and pedestal tests as acceptance test.
  - c) All hot dip galvanized components shall be subject to check for uniformity of thickness and weight of zinc coating on sample basis.
  - d) The bending test shall be carried out at 50% minimum falling loads in four directions as a routine test and at 100% minimum falling loads in four directions as an acceptance test.
  - e) Acceptance norms for visual defects allowed at site and also at works shall be agreed in the quality plan.
- 2.4.2 Type test reports for the following tests shall be submitted.
- a) Power frequency withstand test (dry & wet).
  - b) Lightning impulse test (dry).
  - c) Switching impulse test (wet)
  - d) Measurement of RIV. (Dry).
  - e) Corona extinction voltage test (dry).
  - f) Test for deflection under load.
  - g) Test for mechanical strength.



Project: 5x800 MW YADADRI THERMAL POWER STATION.  
Customer: TELANGANA STATE POWER GENERATION CORPORATION LTD

Section-3: Project Details & General Specifications

Rev. No. 0

## SECTION - 3

### PROJECT DETAILS AND GENERAL SPECIFICATIONS

#### GENERAL TECHNICAL REQUIREMENTS

#### 1.0 PROJECT DETAILS

Customer	:	M/s Telangana State Power Generation Corporation Ltd.
Project Title	:	5x800MW Yadadri Thermal Power Station
Project Location	:	Veerlapalem Village, Damercherla Mandal, Nalgonda District, Telangana
Nearest Railway station	:	Vishnupuram railway station.
Nearest Road Head	:	NH-9 is at 45km North SH-2 is at 7km South
Nearest Airport	:	Hyderabad (about 120 Km) Chief Engineer (O&M), 5X800MW Yadadri Thermal Power
Postal Address	:	Station, TSGENCO, Village - Veerlapalem, Mandal- Dameracheral, Dist. – Nalgonda, Telangana

#### 1.1 SITE CONDITIONS (FOR DESIGN PURPOSES)

##### 1.1.1 SITE CONDITIONS

a).	Average rainfall per year	:	1124 mm
b).	Maximum hourly rainfall intensity	:	102 mm
c).	Altitude	:	1000 m

##### 1.1.2 DESIGN AMBIENT

a).	Minimum Temperature	:	13.5°C
b).	Maximum Temperature	:	45°C
c).	Design Ambient Temperature	:	50 °C

##### 1.1.3 RELATIVE HUMIDITY

a).	Maximum	::	85%
-----	---------	----	-----



Project: 5x800 MW YADADRI THERMAL POWER STATION.  
Customer: TELANGANA STATE POWER GENERATION CORPORATION LTD

Section-3: Project Details & General Specifications

Rev. No. 0

**1.1.4 WIND PRESSURE (AS PER IS:875-1987)**

a). Design wind speed : 44 m/sec.

**1.1.5 SEISMIC FACTORS**

a). Horizontal Seismic Coefficient : As per latest IS : 1893

b). Vertical Seismic Coefficient : As per latest IS : 1893

} **Zone - III**

**1.1.6 ELECTRICAL DATA**

		400 kV System	415V AC System	240V AC System	220 V DC System	48 V DC System
1.	Nominal Voltage	400 kV	415 V	240 V	220 V	48 V
2.	Highest System Voltage	420 kV	457 V	264 V	242 V	55 V
3.	No. of phases	3	3	1	NA	NA
4.	Frequency	50 Hz	50 Hz	50 Hz	NA	NA
5.	Voltage variation	± 5%	± 10 %	± 10 %	+10 % to -15%	± 10 %
6.	Neutral Earthing	Effectively Earthed	Solidly Earthed	Solidly Earthed	-	-
7.	Fault Level	63 kA for 1 sec.	50 kA for 1 sec.	50 kA for 1 sec.	15 kA for 1 sec.	-

**1.1.7 SYSTEM PARAMETERS**

Dry and wet one minute power frequency withstand voltage : 630 kVrms  
Dry impulse withstand voltage positive and negative : 1425 kVpeak  
Minimum Total Creepage : 25 mm/kV

**1.1.8 MINIMUM CLEARENCE (AS PER IS: 10118)**

Phase to phase (PP) : 4200 mm  
Phase to earth (PE) : 3500 mm  
Section clearance : 6500 mm  
Minimum ground clearance from plinth level (Plinth level : 300 mm) : 8000 mm



Project: 5x800 MW YADADRI THERMAL POWER STATION.  
Customer: TELANGANA STATE POWER GENERATION CORPORATION LTD

Section-3: Project Details & General Specifications

Rev. No. 0

Vertical ground clearance to nearest part not at earth  
potential of an insulator supporting live conductor/ equipment 2440 mm

### 1.2 INSTRUCTION TO BIDDERS

The bidders shall submit the technical requirements, data and information as per the technical data sheets, provided in Section-4.

The bidders shall furnish catalogues, engineering data, technical information, design documents, drawings etc fully in conformity with the technical specification. It is recognised that the Manufacturer may have standardised on the use of certain components, materials, processes or procedures different than those specified herein. Alternate proposals offering similar equipment based on the manufacturer's standard practice will also be considered provided such proposals meet the specified designs, standard and performance requirements and are acceptable to the Purchaser. Unless brought out clearly, the Bidder shall be deemed to conform to this specification scrupulously.

### 1.3 STANDARDS

The works covered by the specification shall be designed, engineered, manufactured, built, tested and commissioned in accordance with the Acts, Rules, Laws and Regulations of India.

The equipment to be furnished under this specification shall conform to latest issue (with all amendments) of specified standards.

In addition to meeting the specific requirement called for in Sections 1 and 2 of the Technical Specification, the equipment shall also conform to the general requirement of the applicable standards, which shall form an integral part of the specification. The Bidder shall note that standards mentioned in the specification are not mutually exclusive or complete in themselves, but intended to complement each other. When the specific requirements stipulated in the specifications exceed or differ from those required by the applicable standards, the stipulation of the specification shall take precedence.

Other internationally accepted standards, which ensure equivalent or better performance than that specified in the standards referred, shall also be accepted. The bidder shall submit copies of such standards.

In case governing standard for the equipment is different from IS or IEC, the salient points of difference shall be clearly brought out in the offer along with English language version of standard or relevant extract of the same. The equipment conforming to standards other than IS/IEC shall be subject to Purchaser's / owner's approval. The bidder shall clearly indicate in his bid the specific standards in accordance with which the works will be carried out.



Project: 5x800 MW YADADRI THERMAL POWER STATION.  
Customer: TELANGANA STATE POWER GENERATION CORPORATION LTD

Section-3: Project Details & General Specifications

Rev. No. 0

#### 1.4 TYPE TESTING, INSPECTION, TESTING & INSPECTION CERTIFICATE

All equipment being supplied shall conform to type tests and shall be subject to routine and acceptance tests in accordance with requirements stipulated under respective sections. Purchaser reserves the right to witness any or all the tests. The Manufacturer shall intimate the Purchaser the detailed programme about the tests at least three (3) weeks in advance in case of domestic supplies & six (6) weeks in advance in case of foreign supplies. Purchaser reserves the option for getting any or all the type tests repeated on the equipment. The Manufacturer shall also submit type test procedure for approval of the Purchaser.

In the event of any discrepancy in the test reports i.e. any test report not acceptable due to any design/manufacturing changes (including substitution of components) or due to non-compliance with the requirement stipulated in the technical specification or any/all additional type tests not carried out without any additional cost implication to the Purchaser.

The price of conducting all tests and additional type tests is deemed to be included in Bid price. In case any bidder indicates that he shall not carry out a particular test, his offer shall be considered incomplete and shall be liable to be rejected.

The purchaser intends to repeat the type tests and additional type tests on cables for which test charges shall be payable as per provision of contract.

The Purchaser, his duly authorised representative and/or outside inspection agency acting on behalf of the Purchaser shall have at all reasonable times free access to the Contractors premises or Works and shall have the power, at all reasonable times to inspect and examine the materials and workmanship of the Works during its manufacture or erection if part of the Works is being manufactured or assembled at other premises or works, the Manufacturer shall obtain for the Engineer and for his duly authorized representative permission to inspect as if the works were manufactured or assembled on the Manufacturer's own premises or works. Inspection may be made at any stage of manufacture, dispatch or at site at the option of the Purchaser and the equipment if found unsatisfactory due to bad workmanship or quality, material is liable to be rejected.

The Manufacturer shall give the Purchaser/inspector thirty (30) days written notice of any material being ready for testing. Such tests shall be to the Manufacturer's account except for the expenses of the inspector. Unless witnessing of the tests is virtually waived, the Purchaser/ inspector will attend such tests within thirty (30) days of the date of which the equipment is notified as being ready for test/ inspection, failing which the Manufacturer may proceed with the test which shall be deemed to have been made in the Inspector's presence and the Manufacturer shall forthwith forward duly certified copies of test reports in triplicate to the Inspector.

The Purchaser or Inspector shall, within fifteen (15) days from the date of inspection as defined herein, give notice in writing to the Manufacturer, of any objection to any drawings and all or any equipment and workmanship which in his opinion is not in accordance with the Contract. The



Project: 5x800 MW YADADRI THERMAL POWER STATION.  
Customer: TELANGANA STATE POWER GENERATION CORPORATION LTD

Section-3: Project Details & General Specifications

Rev. No. 0

Manufacturer shall give due consideration to such objections and shall either make the modifications that may be necessary to meet the said objections or shall confirm in writing to the Purchaser/ inspector giving reasons therein, that no modifications are necessary to comply with the Contract.

When the factory tests have been completed at the Manufacturer's works, the Purchaser/ inspector shall issue a certificate to this effect within fifteen (15) days after completion of tests but if the tests are not witnessed by the Purchaser/inspector, the certificate shall be issued within fifteen (15) days of receipt of the Manufacturer's Test certificate by the Engineer/ Inspector. Failure of the Purchaser/inspector to issue such a certificate shall not prevent the Manufacturer from proceeding with the Works. The completion of this test or the issue of the certificate shall not bind the Purchaser to accept the equipment should it, on further tests/ after erection, be found not to comply with the Contract. The equipment shall be dispatched to site only after approval of test reports and issuance of MICC by the Purchaser.

In all cases where the Contract provides for tests whether at the premises or at the works of the Manufacturer or of any Sub-Contractor, the Manufacturer except where otherwise specified shall provide free of charge such items as labour, materials, electricity, fuel, water, stores, apparatus and instruments as may be reasonably demanded by the Purchaser /Inspector or his authorised representative to carry out effectively such tests of the equipment in accordance with the Contract and shall give facilities to the Purchaser Inspector or to his authorised representative to accomplish testing.

The inspection by Purchaser and issue of Inspection Certificate thereon shall in no way limit the liabilities and responsibilities of the Manufacturer in respect of the agreed quality assurance programme forming a part of the Contract.

The Purchaser will have the right of having at his own expenses any other test(s) of reasonable nature carded out at Manufacturer's premises or at site or in any other place in addition of aforesaid type and routine tests, to satisfy that the material comply with the specification.

The Purchaser reserves the right for getting any field tests not specified in respective sections of the technical specification conducted on the completely assembled equipment at site. The testing equipment for these tests shall be provided by the Purchaser.

## **1.5 MATERIAL/WORKMANSHIP**

### **1.5.1 GENERAL REQUIREMENT**

Where the specification does not contain characteristics with reference to workmanship, equipment, materials and components of the covered Equipment it is understood that the same must be new, of highest grade of the best quality of their kind conforming to best engineering practice and suitable for the purposes for which they are intended.



Project: 5x800 MW YADADRI THERMAL POWER STATION.  
Customer: TELANGANA STATE POWER GENERATION CORPORATION LTD

Section-3: Project Details & General Specifications

Rev. No. 0

The design of the Works shall be such that installation, future expansions, replacements and general maintenance may be undertaken with a minimum of time and expenses. Each component shall be designed to be consistent with its duty and suitable factors of safety, subject to mutual agreements and shall be used throughout the design. All joints and fastenings shall be devised, constructed and documented so that the component parts shall be accurately positioned and restrained to fulfil their required function. In general screw threads shall be standard metric threads. The use of other thread forms will only be permitted when prior approval has been obtained from purchaser.

Whenever possible, all similar part of the Works shall be made to gauge and shall also be made interchangeable with similar parts. All spare parts shall be interchangeable with, and shall be made of the same materials and workmanship as the corresponding parts of the Equipment supplied under the Specification. Where feasible, common component units shall be employed in different pieces of equipment in order to minimize spare parts stocking requirements. All equipment of the same type and rating shall be physically and electrically interchangeable.

All materials and equipment shall be installed in strict accordance with the manufacturer's recommendation(s). Only first-class work in accordance with the best modern practices will be accepted. Installation shall be construed as being the erection of equipment at its permanent location. This, unless otherwise specified, shall include unpacking, cleaning and lifting into position, grouting, levelling, aligning, coupling of or bolting down to previously installed equipment bases/foundations, performing the alignment check and final adjustment prior to initial operation, testing and commissioning in accordance with the manufacturer's tolerances /instructions and the Specification. All factory assembled rotating machinery shall be checked for alignment and adjustments made as necessary to re-establish the manufacture's limits. Suitable guards shall be provided for the protection of personal on all exposed rotating and / or moving machine parts and shall be designed for easy installation and removal for maintenance purpose. The spare equipment(s) shall be installed at designated locations and tested for healthiness.

The Contractor shall apply oil and grease of the proper specification to suit the machinery, as is necessary for the installation of the equipment. Lubricants used for installation purposes shall be drained out and the system flushed through where necessary for applying the lubricant required for operation. The Contractor shall apply all operational lubricants to the equipment installed by him.

All oil, grease and other consumables used in the Works/ Equipment shall be purchased in India unless the Contractor has any special requirement for the specific application of a type of oil or grease not available in India. If such is the case, he shall declare in the proposal where such oil or grease is available. He shall help purchaser in establishing equivalent Indian make and Indian Contractor. The same shall be applicable to other consumables too.

#### 1.5.2 PROVISIONS FOR EXPOSURE TO HOT AND HUMID CLIMATE

Outdoor equipment supplied under the specification shall be suitable for service and storage under tropical conditions of high temperature, high humidity, heavy rainfall and environment favourable to



Project: 5x800 MW YADADRI THERMAL POWER STATION.  
Customer: TELANGANA STATE POWER GENERATION CORPORATION LTD

Section-3: Project Details & General Specifications

Rev. No. 0

the growth of fungi and mildew. The indoor equipments located in non-air conditioned areas shall also be of same type.

### 1.6 COLOUR SCHEME AND CODES FOR PIPE SERVICE

The contractor shall propose a colour scheme for those equipment/Items for which the colour scheme has not been specified in the specification for the approval of purchaser. The decision of purchaser shall be final. The scheme shall include:

Finishing colour of Indoor equipment

Finishing colour of Outdoor equipment.

Finish colour of all cubicles.

Finishing colour of various auxiliary system equipment including piping

Finishing colour of various building items.

All steel structures, plates etc. shall be painted with non-corrosive paint on a suitable primer. It may be noted that normally all electrical equipment in switchyard are painted with shade 631 of IS-5. All The indoor cubicles shall be of same colour scheme and for other miscellaneous items, colour scheme will be approved by the purchaser.

### 1.7 PAINTING

- a) All sheet steel work shall be phosphated in accordance with the following procedure and in accordance with IS: 6005 "Code of practice for Phosphating Iron and Steel".
- b) Oil, grease, dirt and swerve shall be thoroughly removed from emulsion by cleaning.
- c) Rust and scale shall be removed by pickling with dilute acid followed by washing with running water, rinsing with slightly alkaline hot water and drying.
- d) After phosphating, thorough rinsing shall be carried out with clean water followed by final rinsing with dilute bichromate solution and over drying.
- e) The phosphate coating shall be sealed by the application of two coats of ready mixed, stoving type zinc chromate primer. The first coat may be "Flash dried" while the second coat shall be stoved.
- f) After application of the primer, two coats of finishing epoxy paint shall be applied, each coat followed by stoving. The panel shall have colour conforming to shade 631 of IS-5 for outside and inside of the panel with black colour for base frame.
- g) Each coat of primer and finishing paint shall be of a slightly different shade to enable inspection of the painting.



Project: 5x800 MW YADADRI THERMAL POWER STATION.  
Customer: TELANGANA STATE POWER GENERATION CORPORATION LTD

Section-3: Project Details & General Specifications

Rev. No. 0

- h) Finished painted appearance of panel shall present an asthetically pleasing appearance free from dents and uneven surface.
- i) A small quantity of finishing paint shall be supplied for minor touching up required at site after the installation of the panels.

### 1.8 PROTECTION

- a) All coated surfaces shall be protected against abrasion, impact, discoloration and any other damages. All exposed threaded portions shall be suitably protected with either a metallic or a non-metallic protecting device. All ends of all valves, pipings and conduit equipment connections shall be properly sealed with suitable devices to protect them from damage.
- b) All equipment accessories and wiring shall have fungus protection, involving special treatment of insulation and metal against fungus, insects and corrosion.
- c) The parts which are likely to get rusted, due to exposure to weather should also be properly treated and protected in a suitable manner.
- d) Screens of corrosion resistant material shall be furnished on all ventilating louvers to prevent entry of insects.

### 1.9 FUNGISTATIC VARNISH

Besides the space heaters, special moisture and fungus resistant varnish shall be applied on the parts, which may be subjected or predisposed to the formation of fungi due to the presence or deposit of nutrient substances. The varnish shall not be applied to any surface of part where the treatment will interface with the operation or performance of the equipment. Such surfaces or parts shall be protected against the application to the varnish.

### 1.10 SURFACE FINISH

All interiors and exteriors of tanks, control cubicles and other metal parts shall be thoroughly cleaned to remove all rust, scales, corrosion, greases or other adhering foreign matter. All steel surfaces in contact with insulating oil as far as accessible shall be painted with not less than two coats of heat resistant, oil insoluble, insulating paints.

All metal surfaces exposed to atmosphere shall be given two primer coats of zinc chromate and two coats of epoxy paint with epoxy base thinner. All metal parts not accessible for painting shall be made of corrosion resisting material. All machine finished or bright surfaces shall be coated with a suitable preventive compound and suitably wrapped or other wise protected. All paints shall be carefully selected to withstand tropical heat and extremes of weather within the limit specified. The paint shall not scale off or wrinkle or be removed by abrasion due to normal handling.



Project: 5x800 MW YADADRI THERMAL POWER STATION.  
Customer: TELANGANA STATE POWER GENERATION CORPORATION LTD

Section-3: Project Details & General Specifications

Rev. No. 0

### 1.11 GALVANIZING

All ferrous parts including all sizes of nuts, bolts, Plain and spring washers, support channels, structures, shall be hot dip galvanised conforming to latest version of IS:2629 or any other equivalent authoritative standard. However, hardware less than M12 size shall be electro-galvanized. Minimum weight of zinc coating shall be 610 gm/sq.mm and minimum thickness of coating shall be 85 microns for all items thicker than 6mm. For items lower than 6 mm thickness, requirement of coating shall be as per relevant ASTM.

### 1.12 AUXILIARY POWER SUPPLY

1.12.1 A.C power supply for auxiliaries will be available at 240 V, 50 C/s 1-phase, 2 wire and 415V, 50 C/s, 3-phase, 4 wire, neutral solidly earthed with variation in frequency of +/-5% and variation in voltage +/-10%

1.12.2 D.C. power supply at 220 V, 2-wire ungrounded will be available 187 V to 242 V.

### 1.13 INSPECTION AND TESTING

All tests and inspection of the equipment specified shall be performed to the extent and in the manner as stipulated in the relevant standards and in this specification. All type tests/routine tests/acceptance tests as specified shall be conducted in the presence of purchaser. Wherever equipment similar to the one being offered has already been type tested within 5 years from the date of opening the bid. Type tests done in an independent government laboratory or in the presence of representative of State Electricity Board or other reputed public undertakings, the type test reports of the same shall be submitted for scrutiny /approval. If these are found suitable and technically acceptable, conducting of type tests shall be waived off. Otherwise the subcontractor will have to carry out the type tests without any extra cost and without any delivery implications.

### 1.14 PACKAGING

Aluminium Tube shall be partially packed with Hessians cloths. Similar items shall be grouped and tied with steel wires/strip for convenient handling during transits.

### MARKINGS

The following details are to be clearly indicated in the material forwarding documents:

- a) Name and address of the consignee.
- b) Purchase order number.
- c) Name of supplier/s.
- d) Description of equipment / material.



Project: 5x800 MW YADADRI THERMAL POWER STATION.  
Customer: TELANGANA STATE POWER GENERATION CORPORATION LTD

Section-3: Project Details & General Specifications

Rev. No. 0

e) Tare weight.

f) Gross weight.

All the equipments shall be suitably protected, coated, covered or boxed and crated to prevent damage or deterioration during transit, handling and storage at Site till the time of erection. On request of the purchaser, the Contractor shall also submit packing details/associated drawing for any equipment material under his scope of supply, to facilitate the purchaser to repack any equipment/material at a later date, in case the need arises, while packing all the materials, the limitation from the point of view of availability of Railway wagon sizes in India should be taken account of. The Contractor shall be responsible for any loss or damage during transportation, handling and storage due to improper packing. Any demurrage wagons and other such charges claimed by the transporters, railways etc. shall be to the account of the Contractor. Purchaser takes no responsibility of the availability of the wagons.

### 1.15 HANDLING, STORING AND INSTALLATION

In accordance with the specific installation instructions as shown on manufacturer's drawings or as directed by the purchaser or his representative, the Contractor shall unload, store, erect, install, wire, test and place into commercial use all the equipment included in the contract. Equipment shall be installed in a neat, workmanlike manner so that it is level, plumb, square and properly aligned and oriented. Commercial use of switchyard equipment means completion of all site tests specified and energisation at rated voltage.

Contractor may engage manufacturer's Engineers to supervise the unloading, transportation to site, storing, testing and commissioning of the various equipment being procured by them separately. Contractor shall unload, transport, store, erect, test and commission the equipment as per instructions of the manufacturer's supervisory Engineer(s) and shall extend full cooperation to them.

In case of any doubt/misunderstanding as to the correct interpretation of manufacturer's drawings or instructions, necessary clarifications shall be obtained from the purchaser.

Contractor shall be held responsible for any damage to the equipment consequent to not following manufacturer's drawings/instructions correctly.

Where assemblies are supplied in more than one section, contractor shall make all necessary mechanical and electrical connections between sections including the connection between buses. Contractor shall also do necessary adjustments/alignments necessary for proper operation of circuit breakers, isolators and their operating mechanisms. All components shall be protected against damage during unloading, transportation, storage, installation, testing and commissioning. Any equipment damaged due to negligence or carelessness or otherwise shall be replaced by the contractor at his own expenses.

Contractor shall be responsible for examining all the shipment immediately of any damage, shortage, discrepancy etc. for the purpose of Purchaser's information only. The Contractor shall submit to the



Project: 5x800 MW YADADRI THERMAL POWER STATION.  
Customer: TELANGANA STATE POWER GENERATION CORPORATION LTD

Section-3: Project Details & General Specifications

Rev. No. 0

purchaser every week a report detailing all the receipts during the weeks. However, the Contractor shall be solely responsible for any shortages or damages in transit, handling and/or in storage and erection of the equipment at Site. Any demurrage, pilferage and other such charges claimed by the transporters, railways etc. shall be to the Contractor' account.

The Contractor shall be fully responsible, for the equipment/material until the same is handed over to the purchaser in an operating condition after commissioning. Contractor shall be responsible for the maintenance to the equipment/material while in storage as well as after erection until taken over by Purchaser, as well as protection of the same against theft, element of such nature, corrosion, damages etc.

The Contractor shall be responsible for making suitable indoor storage facilities, to store all equipments which require indoor storage.

The words erection and installation used in the specification are synonymous. Exposed live parts shall be placed high enough above ground to meet the requirements of electrical and other statutory safety codes.

The minimum phase to earth, phase to phase and section clearance along-with other technical parameters for the various switchyard voltage levels to be maintained shall be strictly as per the approved drawings.

The design and workmanship shall be in accordance with the best engineering practices to ensure satisfactory performance throughout the service life. If at any stage during the execution of the Contract, it is observed that the erected equipment(s) do not meet the above minimum clearances, the Contractor shall immediately proceed to correct the discrepancy at his risks and costs.

#### **1.16 TOOLS AND TACKLES**

The Contractor shall supply with the equipment one complete set of all special tools and tackles for the erection, assembly, dis-assembly and maintenance of the equipment. However, these tools and tackles shall be separately, packed and brought on to Site.

#### **1.14 EQUIPMENT BASES**

A cast iron or welded steel base-plate shall be provided for all rotating equipment, which is to be installed on a concrete base unless otherwise agreed to by the Purchaser. Each base-plate shall support the unit and its drive assembly, shall be of a neat design with pads for anchoring the units shall have a raised lip all around, and shall have threaded drain connections.

#### **1.15 QUALITY**

BHEL quality plan to be followed subject to TBEM / customer's approval.



Project: 5x800 MW YADADRI THERMAL POWER STATION.  
Customer: TELANGANA STATE POWER GENERATION CORPORATION LTD

Section-3: Project Details & General Specifications

Rev. No. 0

## 1.16 DOCUMENTATION

### 1.16.1 DRAWINGS

All drawings shall be prepared in AutoCAD and ultimate documentation would include drawings/documents on CDs. All dimensions and data shall be in SI metric units.

All items of the equipment should be clearly identified by proper part nos. in the contract drawings. Such parts, which are to be dispatched to site from works in dispatchable units and are reassembled at site, should be marked by proper identification marks at works and indicated in the drawings and quantified. The shipping list should be sent along with the general arrangement drawings for engineer's approval. All the items of the shipping list should be identified in the drawing.

The drawing submitted by the supplier shall be reviewed by the purchaser as far as practicable within two weeks of receipt of drawings and shall be modified by the sub-contractor if any modifications and/or corrections are required by the purchaser. The sub-contractor shall incorporate such modifications and / or corrections and submit the final drawings for approval. Any delay arising out of failure of the subcontractor to rectify the drawings shall not alter the contract completion date.

Further work by the subcontractor shall be in strict accordance with these drawings and no deviation shall be allowed without the written approval of the purchaser.

All manufacturing and fabrication work in connection with the equipment prior to the approval of the drawings shall be at supplier's risk.

Approval of drawing or work by the purchaser/consultant shall not relieve the subcontractor of any of his responsibilities and liabilities under the contract.

In case of any modifications that may be necessary during erection or commissioning of the equipment, the subcontractor shall carry out modifications in the original drawing & submit 'As Built drawings' and required no. of prints thereof.

### 1.16.2 INSTRUCTION MANUALS

The supplier shall submit to the purchaser, draft instruction manuals for approval within 30 days of placement of order. The final instruction manuals complete in all respects shall be submitted 60 days before the first shipment of the equipment. The instruction manuals shall contain full details and drawings of all the equipment furnished, the erection procedures, testing, operation & maintenance procedures of the equipment.

If after the commissioning and initial operation of the plant, the instruction manuals require any modification/ addition / changes, the same shall be incorporated and the up- dated final instruction manuals shall be submitted as required.



Project: 5x800 MW YADADRI THERMAL POWER STATION.  
Customer: TELANGANA STATE POWER GENERATION CORPORATION LTD

Section-3: Project Details & General Specifications

Rev. No. 0

### 1.16.3 TITLE BLOCK & DRAWING/ DOCUMENT NUMBERING SCHEME

Title block for drawing / document should be followed as per ANNEXURE-3

### 1.16.4 DOCUMENTATION SCHEDULE AT CONTRACT STAGE

A. <u>For approval</u>	<u>No of Copies</u>
Copies of all drawings with project details, dimension, shipping weights, No. of cases & dimensions, fixing details, tolerance etc.	10
Copies of type test reports.	5
Copies of works quality plan & field quality plan.	5
Copies of installation, operation & maintenance manual.	5
Copies of drawings on floppies/CDs	1 set
B. <u>After approval and for information / distribution</u>	
Copies of all drawings	15
Copies of installation, operation & maintenance manual including Routine test reports	15
Sets of RTF of drawings	2
CDs of Drgs & O&M Manuals.	4
C. <u>As Built Drawings</u>	
Hard copies of Drawings	15
CDs	4

**NOTE:**

1. Any revision of drawings / documents shall be submitted in the same no. of copies submitted first time for approval
2. Final drawings / documents shall be submitted in bound volume with customer and project details etc. written on the top.

**620158(1)/2022/TBG-TB ENGG MSE**

Telangana State Power Generation Corp. Ltd.  
400 kV Switchyard at 5X800MW Yadadri TPS  
Technical Specification of 420 kV PI

Bharat Heavy Electricals Ltd.  
Doc. No. TB-387-316-011, Rev 00

**SECTION – 4****GUARANTEED TECHNICAL PARTICULARS FOR  
POST INSULATOR**

For each type and rating of insulator proposed, the bidder shall provide the following information

Sl. No.	Description	
01.	<b>GENERAL</b>	
i)	Name of Manufacturer	
ii)	Type of insulator unit	
iii)	Applicable standard	
iv)	No. of units per stack	
02.	<b>PHYSICAL &amp; MECHANICAL CHARACTERISTICS</b>	
i)	Largest shell diameter (mm)	
ii)	Mean diameter of stack (mm)	
iii)	Pitch circle diameter (mm) - Top - Bottom	
iv)	Height of unit (mm)	
v)	Height of complete stack (mm)	
vi)	Dry arcing distance of complete stack (mm)	
vii)	No. & dia of bolts for interconnecting units	
viii)	No. & dia of bolts & nuts for structure mounting.	
ix)	Cantilever strength of complete stack i) Upright (kN) ii) Inverted (kN) iii) Horizontal (kN)	
x)	Tensile strength of each unit (kg)	
xi)	Torsional strength of each unit (kg M)	
xii)	Compression strength of each unit (kg)	
xiii)	Total Creepage distance (mm) a) One Unit b) Complete stack	
xiv)	Weight of insulator unit (kg)	
xv)	Weight of complete stack (kg)	
xvi)	Shipping dimensions with packing (L x B x H )	
03.	<b>ELECTRICAL CHARACTERISTICS</b>	

**620158(1)/2022/TBG-TB\_ENGG\_MSE**

Telangana State Power Generation Corp. Ltd.  
400 kV Switchyard at 5X800MW Yadadri TPS  
Technical Specification of 420 kV PI

Bharat Heavy Electricals Ltd.  
Doc. No. TB-387-316-011, Rev 00

i)	Voltage rating of each unit (kV)	
ii)	Highest system voltage (kV)	
iii)	One minute power frequency withstand voltage (kV rms) a) Of one unit - Dry - Wet b) Of complete stack without corona rings - Dry - Wet	
iv)	Power frequency flashover voltage of complete stack (kV rms) - Dry - Wet	
v)	1.2/50 micro sec. Impulse Withstand Voltage (kV peak) a) Of one unit  - Positive polarity - Negative polarity b) Of complete stack without corona rings  - Positive polarity - Negative polarity	
vi)	1.2/50 micro sec. Impulse flashover Voltage of complete stack  Positive polarity Negative polarity	
vii)	Switching Impulse withstand voltage (kV peak)	
viii)	Visual discharge voltage without corona ring (kV rms)	
ix)	Radio Interference Voltage of complete stack at 1 MHz and without corona rings i) Test voltage (kV) ii) Radio Interference Voltage (micro volts)	
x)	Puncture withstand voltage (kV)	

**620158(1)/2022/TBG-TB\_ENGG\_MSE**

Telangana State Power Generation Corp. Ltd.  
400 kV Switchyard at 5X800MW Yadadri TPS  
Technical Specification of 420 kV PI

Bharat Heavy Electricals Ltd.  
Doc. No. TB-387-316-011, Rev 00

**ANNEXURE – A****NO DEVIATION CERTIFICATE**

-----  
It is confirmed that there is no deviation and the offer is in full compliance with the specification. It is also confirmed that there are no deviations in any other form such as comments, variations and or exceptions. Further it is confirmed that at all drawings/ data sheets/ QP/ type tests reports shall be submitted to BHEL for organizing approval of ultimate customer. Also, furnishing of all relevant information/ repetition of type tests (if required for meeting the specification requirement) shall be carried out by us at no extra cost to BHEL and without affecting delivery requirements.  
-----

Signature of the authorized representative of Bidder

Name \_\_\_\_\_

Designation \_\_\_\_\_

Place \_\_\_\_\_

Date \_\_\_\_\_

Company Seal

### SECTION-6

#### Check List

#### 1. TECHNICAL REQUIREMENTS FOR 420kV SOLID CORE POST INSULATOR

Sl. No	Parameter	Data	
1	Type	Solid Core	Yes/No
2	Voltage class (kV)	420	Yes/No
3	Dry and wet one minute power frequency withstand voltage (kVp)	710 & 680	Yes/No
4	Dry lightning impulse withstand voltage (kVp)	±1425	Yes/No
5	Wet switching surge withstand voltage (kVp)	±1050	Yes/No
6	Max. radio interference voltage (in microvolts) at voltage 305 kV (rms) for 400 kV between phase and ground	500	Yes/No
7	Min. Corona extinction voltage (kV rms)	320	Yes/No
8	Total min. cantilever strength (kN)	8	Yes/No
9	Minimum torsional moment	As per IEC 273 or 600 kg	Yes/No
10	Total height of insulator (mm)	3650	Yes/No
11	P.C.D		
	Top (mm)	127	Yes/No
	Bottom (mm)	300	Yes/No
12	No. of bolts		
	Top	4	Yes/No
	Bottom	8	Yes/No
13	Diameter of bolt holes		
	Top ( <b>Tapped hole M16X2X22 DEEP</b> )	M16	Yes/No
	Bottom (mm)	18	Yes/No
14	Pollution level as per IEC-815	Heavy (III) :	Yes/No
15	Min. total creepage distance (mm)	10500	Yes/No
16	Complete with Hot Dip Galvanised Hardware for inter-unit joining and fixing to structure (both top & bottom).		Yes/No

#### 2. TYPE TESTS

Type test reports are not earlier than 17.10.2012  
on similar material

**YES/NO**

If the valid type tests reports are not available with the bidder  
then the tests shall be conducted by the bidder free  
of cost.

**YES/NO**

**TECHNICAL QUALIFYING REQUIREMENT FOR**  
**POST INSULATORS FOR TSGENCO YADADRI SWITCHYARD**

The bidder should have manufactured, type tested (as per IEC/IS or equivalent standard) and supplied 400kV or higher voltage class Post Insulators as on the originally scheduled date of technical bid opening of this tender.

**Remark:**

Document for proof of supplies need to be submitted along with the technical offer

*N. K. Chakrabarti*  
*22.12.2021*

PREPARED BY

*S. K. Jaiswal*  
*27.12.21*

REVIEWED BY

*31.12.21*  
*27/12/21*

APPROVED BY

Availability in GeM for 400kV Post Insulators		
search_type	search_string	Availability
product	400kV Post Insulators with corona ring	Not available
product	400kV Post Insulators without corona ring	Not available

V. K. Chakraborty  
22.12.21

Sanku  
22.12.21



**Report ID:** GEM/GARPTS/211.22021/44X0Q9XMSDN8

**Report Name:** BPI Yadadri

**Generated By:** Neeraj Kumar

**Generated On:** 21/12/2021

**Valid till:** 20/01/2022

### GeM Availability Report and Past Transaction Summary

GeM Availability Report and past transaction summary report is generated based on the search strings/specifications uploaded by the Buyer. The specification/strings may be modified appropriately for searching relevant categories on GeM. Buyer may navigate to the GeM category page to view category specifications and products/services available in the category.

*Order Count and Order Value displayed is on a cumulative basis since GeM inception.*

#### **1. Search String: 400kV Post Insulators with corona ring**

Search type: Product

Search Result: The below categories are suggested as per specification/strings uploaded by the buyer.

Category Name	Catalog Count	Order Count			Order Value (in Lakhs)		
		Direct Purchase	Reverse Auction	Bid	Direct Purchase	Reverse Auction	Bid
Porcelain insulators for overhead power lines with a nominal voltage Greater than 1000 V as per IS: 731	219	197	7	38	189	5	53
Asbestos Cement Pressure Pipe And Joints-IS:1592	64	38	0	11	47	0	37
Network Theorem Kit For Educational Purpose	4,489	8,354	23	174	3,025	24	255
Power Cable For Direct Burial Xlpe Ugac Cable-IS: 10418	18,381	20,317	476	4,594	18,356	4,007	19,866

*Neeraj Kumar*  
22/12/21

*Sanjay*  
22/12/21

PVC Insulated (Heavy Duty) Electric Cables, Aluminium Conductor as per IS:1554 (Part 1)	230	37	1	21	58	3	113
---	-----	----	---	----	----	---	-----

If the above suggested categories doesn't meet your requirement, try searching different string for more results.

**2. Search String: 400kV Post Insulators without corona ring**

Search type: Product

Search Result: Category not available on GeM for the text string uploaded by the buyer.

*Apshah*  
22/12/21

*Saujan*  
22/12/21