

	PROJECT: 4X39 MW UJVNL, CHILLA HEP, PAURI, GARHWAL, RMU HYDRO ELECTRIC PROJECT PRE-QUALIFICATION REQUIREMENT- HVAC SYSTEM.	PE-PQ-464-571-11000-A001	
		DATE	14.05.2025
		REV NO	00

1.0	Bidder should have designed, supplied, erected and commissioned at least one (1) no. Air Conditioning or Ventilation system in industrial / commercial installations, consisting of Single Unitary Air Filtration / Air Washer / Fan Filtration/ Air Handling Unit, With Centrifugal Fan / Axial Fan, of total capacity 50,000 Cu. Mtr. / Hr. at least, along with associated ducting work etc., which are in successful operation for a period of not less than one (1) year as on date of techno commercial bid opening.
2.0	The supplier has to submit following supporting documents meeting above mentioned pre-qualifying requirement. Copy of minimum one (1) performance certificate (in English) from end user along with copy of related Purchase Order (PO) or Letter of Intent (LOI) or letter of Award (LOA) or Work Order (WO) specifying that the product is running successfully for one (1) year from date of commissioning as on date of bid opening in support of PQR clause at S. No. 1.0 above.
3.0	Bidder shall submit design documents to substantiate technical parameters specified in PQR, if the same is not mentioned in performance certificate/ purchase order.
4.0	Bidder to submit all supporting documents in English. If documents submitted by bidder are in language other than English, a self-attested English translated document should also be submitted.
5.0	Notwithstanding anything stated above, CUSTOMER/BHEL reserves the rights to satisfy himself on the proneness of the equipment and capability and capacity of the manufacturers.
6.0	Notwithstanding anything stated above, CUSTOMER/BHEL reserves the right to assess the capabilities and capacity of the Bidder to perform the contract, should the circumstances warrant such assessment in the overall interest of the Employer.
7.0	BHEL shall evaluate and qualify the bidders for this tender based on their performance in previously awarded jobs as per attached Annexure A.
8.0	Consideration of offer shall be subject to customer's approval of bidders, if applicable.
9.0	After satisfactory fulfilment of all the above criteria/ requirement, offer shall be considered for further evaluation as per NIT and all the other terms of the tender.
10.0	The bidder shall meet PQR based on its own credentials. Bid from joint venture (JV) company / Consortium bid is not acceptable.

Prepared By

Reviewed By

Approved By

Assessment of Bidder/ Supplier wrt Performance Feedback from current projects by PS- Regions

Name of Bidder/ Supplier:

Package quoted for:

Reference Project for Performance Assessment:

Date:

Sl. No.	Area of Assessment	Particulars for Evaluation	Maximum marks	Marks awarded
1	Material supply		50	
1a	Package Name	Whether agency has supplied the material within given contractual period with extension. Supply 100% - 40 marks 75% - 30 marks 50% - 20 marks Marks may be given on pro-rate supply basis.	40	
1b		Assessment of Qualitative ability of agency to follow the approved documents/ BHEL procedures / guidelines for material inspections/ inspection call/ MDCC request / Dispatch documentation.	10	
2	Execution Capabilities		50	
2a	Package Name	Whether agency has engaged competent person as site in charge and other supervisors/ manpower to handle site execution.	10	
2b		Vendor involvement/ behaviour/ engagement during E&C at site and initiative to resolve of interface issues.	10	
2c		Quality of erection drawings and BOQ availability.	10	
2d		Agency efforts & inclination on implementation of HSE, Safety and quality during execution of system	10	
2e		Whether agency has made the system ready/ commissioned before corresponding project milestone requirement.	10	
	Grand Total		100	

Note: 1. The feedback to be provided by PS-Regions against the bidder's performance.
2. The average qualifying marks will be 60.

PS-Region Representative

PS-Region (Head/Projects)