

BHEL-PEM-MAUX PRE-QUALIFICATION CRITERIA			
	PROJECT: 2X660MW CSPGCL KORBA WEST TPP PACKAGE: VENTILATION SYSTEM PRE-QUALIFICATION REQUIREMENT (TECHNICAL)	PE-PQ-530-554-A001	
		DATE	05.08.2026
		REV NO	00

Sl. No.	DESCRIPTION
1.0	The Bidder should have designed, supplied, erected, and commissioned at least one (1) number ventilation system including similar air washer unit having individual fan capacity of 80,000 Cum./Hr. or more. The system should have been in successful operation for at least one (1) year as on the date of Techno-Commercial bid opening.
2.0	The supplier has to submit following supporting documents meeting above mentioned prequalifying requirement: Copy of minimum one (1) performance certificate from end user along with copy of related Purchase Order (PO) or Letter of intent (LOI) or Letter of Award (LOA) or Work Order (WO) in support of PQR clause at S. No. 1.0 above.
Notes	
a	BHEL reserves the right to seek approved design documents from bidders to substantiate technical parameters as specified in clause 1 above.
b	Bidder to submit all supporting documents in Hindi and/or English as required. If documents submitted by bidder are in language other than that specified above, a translated copy of the same, in above language(s) shall be submitted by the bidder. In such case, for purposes of interpretation, the translated version shall govern. The translation of the documents shall be carried out by professional translators and the translator shall certify that he is proficient in both languages in order to translate the document and that the translation is complete and accurate. Further, in case the supporting documents are issued outside India, same shall be authenticated by the Indian Consulate located in the Country where the documents have been issued or the Embassy of that Country in India.
c	In case the PO/ LOI /LOA/ WOs is more than ten (10) years old as on date of bid opening, minimum one (1) no. additional Purchase order (for similar jobs) shall be submitted which should not be more than ten (10) years old as on date of bid opening, for establishing continuity in business.
d	Notwithstanding anything stated above, BHEL/End customer/Owner reserves the right for physical assessment of the capabilities and capacity of the bidder to perform the contract, should the circumstances warrant such assessment in the overall interest of BHEL/ End customer/Owner.
e	Consideration of offer shall be subject to End customer/Owner's approval of bidder.
f	After satisfactory fulfilment of all the above criteria/ requirement, offer shall be considered for further evaluation as per NIT and all other terms of the tender.
g	The bidder shall meet PQR based on its own credentials. Bid from joint venture (JV) company / Consortium bid is not acceptable.