

**NLC TAMILNADU POWER LIMITED**

**NTPL 2X500 MW COAL FIRED UNITS AT TUTICORIN  
FLUE GAS DESULPHURISATION (FGD) SYSTEM PACKAGE**

**TECHNICAL SPECIFICATION  
FOR  
MISCELLANEOUS PUMPS (HORIZONTAL)**

**Specification No. : PE-TS-483-100-N001 (REV. 01)**



**BHARAT HEAVY ELECTRICALS LIMITED  
POWER SECTOR  
PROJECT ENGINEERING MANAGEMENT  
PPEI BUILDING, SECTOR 16 A  
NOIDA - 201301**

672753/2022/PS-PEM-MISE

	<b>TECHNICAL SPECIFICATION MISCELLANEOUS PUMPS</b>	SPEC. NO.: <b>PE-TS-483-100-N001</b>
		SECTION:
		SUB-SECTION:
		REV. NO. <b>01</b> DATE    03.02.2022
		SHEET    1      OF    1

**SPECIFIC TECHNICAL REQUIREMENTS**

**INDEX**

**THIS TECHNICAL SPECIFICATION CONSISTS OF FOLLOWING SECTIONS:**

**CONTENTS**

<b>SECTION</b>	<b>TITLE</b>
I	Specific Technical Requirements
IA	Specific Technical Requirements (Mechanical)
IB	Specific Technical Requirements (Electrical)
IC	Specific Technical Requirements (C&I)
ID	Data Sheet – A
II	Standard Technical Specifications
IIA	Standard Technical Specifications (Mechanical)
IIB	Standard Technical Specifications (Electrical)
III	Documents to be submitted by Bidder
IIIA	Guarantee Schedule (To be submitted along with the Bid by all Bidders)
IIIB	Compliance Certificate (To be submitted along with the Bid by all Bidders)
IIIC	Deviation schedule (To be submitted along with the Bid by all Bidders)
IIID	Data Sheet – B and Other documents (To be submitted by successful Bidder after award of Contract)


**Notes:**

**1) For detailed list of documents to be submitted by bidder in their technical offer, please refer cl. no. 15.00.00 of Section-IIA.**

**2) For detailed list of documents to be submitted by vendor after award of contract, please refer Datasheet-C of Section-IIA.**

**3) In case there is conflict in different clauses of specification, most stringent clause (as decided by BHEL / end customer) shall be followed, if no specific deviation is taken by bidder and accepted by BHEL during tender stage in that regard.**


672753/2022/PS-PEM-MSE

	<b>TECHNICAL SPECIFICATION MISCELLANEOUS PUMPS</b>	SPEC. NO.: <b>PE-TS-483-100-N001</b>	
		SECTION:	
		SUB-SECTION:	
		REV. NO. <b>01</b>	DATE 03.02.2022
		SHEET <b>1</b>	OF <b>1</b>

**SPECIFIC TECHNICAL REQUIREMENTS****SECTION - I****SPECIFIC TECHNICAL REQUIREMENTS**

- SUB-SECTION IA** - Specific Technical Requirements (Mech.)  
**SUB-SECTION IB** - Specific Technical Requirements (Electrical)  
~~**SUB-SECTION IC** - Specific Technical Requirements (C & I)~~  
**SUB-SECTION ID** - Datasheet-A


672753/2022/PS-PEM-MSE


	<b>FILE:</b> <b>TECHNICAL SPECIFICATION MISCELLANEOUS PUMPS</b>  <b>SPECIFIC TECHNICAL REQUIREMENTS</b>	SPEC. NO.: <b>PE-TS-483-100-N001</b>	
		SECTION: <b>I</b>	
		SUB-SECTION: <b>IA</b>	
		REV. NO. <b>01</b>	DATE <b>03.02.2022</b>
		SHEET <b>1</b>	OF <b>1</b>

### **SUB-SECTION – IA**

### **SPECIFIC TECHNICAL REQUIREMENTS (MECHANICAL)**



	<b>TECHNICAL SPECIFICATIONS</b>		Specification No. : PE-TS-483-100-N001, Rev.01	
	<b>MISCELLANEOUS PUMPS</b>		SECTION: IA	
	<b>SPECIFIC TECHNICAL REQUIREMENTS</b>		REV. NO. 01	DATE:
<b>1.0 SCOPE</b>				
1.1 This enquiry covers the design, manufacture, assembly, inspection and testing at manufacturer's and/or his sub-contractors works, painting, proper packing to avoid damage of items during transportation & storage at site of Miscellaneous Pumps (along with Motors & mandatory spares as applicable), transportation to site, complete with all other accessories as per the requirements specified in this specification, site services including installation checks of pump motor set & supervision of replacement of gland packing with Mechanical Seal arrangement (if applicable) at site for Miscellaneous Pumps, PG Test at site and any other services, etc. if called for in the succeeding sections of the specification for following project:				
<b>NTPL 2X500 MW COAL FIRED UNITS AT TUTICORIN -FGD PROJECT</b>				
The above project is referred as 'NTPL 2X500 MW TUTICORIN -FGD PROJECT' elsewhere in the Specification for ease of reference.				
1.2 The miscellaneous pumps covered under this specification shall be grouped (Type) as under:				
i. Horizontal Pumps				
<b>NOTE:-</b>				
<b>1. The bidder shall include complete supplies for Pump Type as above in his scope. Part supplies offered for the Pump Type shall disqualify the bidder's offer for that Pump Type.</b>				
<b>2. Pump details shall be as per Data Sheet-A at Section-ID.</b>				
<b>3. If stated specifically in NIT, bidder shall include complete supplies for Project(s)/Group(s) in his scope. Part supplies offered for the Project(s)/Group(s) shall disqualify the bidder's offer for that Project(s)/Group(s).</b>				
1.3 The miscellaneous pumps and drives covered under this specification for project are as per Annexure-1 of this section. HT drives, wherever applicable and irrespective of motor ratings, shall be issued free of cost by BHEL. The details of pumps with HT drives shall be as per Annexure-2 of this section.				
1.4 The Capacity, Head, Materials of construction, Mandatory spares and other particulars of these pumps, are detailed in Data Sheet-A at Section-ID of the specification.				
1.5 For detailed scope of supply & services refer Standard technical Specification for Horizontal Centrifugal pumps specified under Section-II of this specification.				
1.6 Electrical scope between BHEL and Vendor for Miscellaneous pumps and drives of this specification shall be as per Section-IB of this specification.				
LT drives shall be energy efficient as per subsequent clauses mentioned elsewhere in the specification. <b>However wherever IE2 compliant motors are applicable same shall be provided with Premium Efficiency class-IE3 compliance (refer Specific Technical requirements-Electrical Section).</b>				
1.7 <u>DELIVERY &amp; DOCUMENT SUBMISSION SCHEDULE:</u>				
Delivery & Document submission schedule of miscellaneous pumps shall be as per NIT requirement.				
1.8 Evaluation and LD criterion w.r.t. Auxiliary Power is defined at clause 4.0 of Section IIA of this specification. In case bidder quotes Aux. power less than Benchmark Auxiliary Power, then quoted Aux. power shall be replaced with Benchmark Auxiliary Power for both evaluation as well as LD purposes.				
<b>2.0 Horizontal Pumps:</b>				
2.1 Additional Specific requirements for Horizontal pumps shall be as per end customer's specification attached in this section-IA.				
2.2 In case, shaft sleeve is threaded a water slinger shall be provided on the Pump Shaft to avoid ingress of leaked water (if any due to failure of sealing arrangement for shaft sleeve) to Bearing.				
2.3 In case of axial split casing Multistage pumps, minimum factor of safety of '2' times shall be considered for bearing capacity selection and pump design.				
2.4 Deleted				

	<b>TECHNICAL SPECIFICATIONS</b>		Specification No. : PE-TS-483-100-N001, Rev.01	
	<b>MISCELLANEOUS PUMPS</b>		SECTION: IA	
	<b>SPECIFIC TECHNICAL REQUIREMENTS</b>		REV. NO. 01	DATE:

**3.0** Mechanical run test along with Performance test shall be carried out on all pumps to determine the vibration levels, noise levels etc. at Vendor works. **Vibration & Noise level test shall also be conducted by vendor at site for All Pumps and as per approved PG Test Procedure, inline with CI no. 3.04 of Section-1IA of this specification.** However, test value at site shall be used for the acceptance of the equipment. Pump vendor shall bring necessary instruments for conductance of site performance test. If the site performance is found not meeting the requirements in any respect as specified, then the equipment shall be rectified or replaced by the vendor, without any commercial implication to BHEL.

**4.0** Deleted

**5.0 Additional Dispatch Requirements:**

MDCC after final inspection shall be provided to vendor subject to submission of following documents along with meeting the other requirements stated in NIT :-

**5.1** List of items packed in each box with description & quantity.


**5.2** Photograph of each box in open & closed condition.

**5.3** Bidder to include handling instructions on Packed Box of each item & in Engineering drg/doc/O&M Manual and packing to be done in such a way to avoid damage of items in transit and long storage at site and same shall be approved during contract stage by BHEL/Customer


**6.0 Drawing/Document Submission Schedule:**

PACKAGE	BHEL DRG NO	DRG TITLE	Drg Sch for Vendors	Remarks
MISC.PUMPS (HORIZONTAL )	PE-V6-483-100-N001	TDS AND PERFORMACE CURVES-MISC. PUMPS (HORIZONTAL)	As per NIT	
	PE-V6-483-100-N002	GENERAL ARRANGEMENT AND CROSS SECTIONAL-PUMPS (HORIZONTAL)		
	PE-V6-483-100-N003	TDS AND CURVES OF MOTORS FOR MISC. PUMPS (HORIZONTAL)		
	PE-V6-483-100-N004	QP-MISC PUMPS (HORIZONTAL)		
	PE-V6-483-100-N005	QP- MOTORS (HORIZONTAL)		
	PE-V6-483-100-N006	MOTOR TYPE TEST DOC (if applicable) (HORIZONTAL)	As per NIT	
	PE-V6-483-100-N007	O& M MANUAL -HORZ. PUMPS	As per NIT	
	PE-V6-483-100-N008	PG TEST PROCEDURE -HOR. PUMPS (If Applicable)	R-0 within 20 days of Cat-I approval on all Pump & Motor documents (TDS, GA drg & QPs).	


Note: Drawings submitted shall be complete in all respects with revised drawing submitted incorporating all comments. Any incomplete drawing submitted shall be treated as non-submission with delays to bidder's account. For any clarification / discussion required to complete the drawings, the bidder shall himself depute his personnel to BHEL for across the table discussions/ finalizations / submissions of drawings

	<b>TECHNICAL SPECIFICATIONS</b>		Specification No. : PE-TS-483-100-N001, Rev.01	
	<b>MISCELLANEOUS PUMPS</b>		SECTION: IA	
	<b>SPECIFIC TECHNICAL REQUIREMENTS</b>		REV. NO. 01	DATE:
<p>7.0 Following to be complied by the bidder:</p> <p>a. Supplier to submit detailed 'Bill of Material' (BoM) at the time of drawing/document submission after placement of PO. Each item of the BoM to be uniquely identified with item code no. or item serial no.</p> <p>b. Supplier to ensure that all items which will find separate mention in the packing list are covered in this detailed BoM.</p> <p>c. Supplier to give following undertaking in the BoM"  "The BoM provided herewith completes the scope (in content and intent) of material supply under PO no.-----, dated -----</p> <p>.  Any additional material which may become necessary for the intended application of the supplied items(s)/package will be supplied free of cost in most reasonable time."</p>				

672753/2022/PS-PEM-MSE

	<b>TECHNICAL SPECIFICATIONS</b>		Specification No. : PE-TS-483-100-N001, Rev.01	
	<b>MISCELLANEOUS PUMPS</b>		SECTION: IA	
	<b>SPECIFIC TECHNICAL REQUIREMENTS</b>		REV. NO. 01	DATE: 03.02.2022
<b>Annexure-1</b>				
<b>List of Miscellaneous Pumps and drives for :</b>				
<b>NTPL 2X500 MW TUTICORIN -FGD PROJECT</b>				
<b>Sl. No.</b>	<b>Pump Description</b>	<b>Total Qty.</b>	<b>Type of Pumps</b>	
A.	<b>Horizontal Pumps</b>			
1	DMCW PUMPS	3 nos.	Horizontal	
2	ACW PUMPS	3 nos.	Horizontal	

672753/2022/PS-PEM-MSE

	<b>TECHNICAL SPECIFICATIONS</b>		Specification No. : PE-TS-483-100-N001, Rev.01	
	<b>MISCELLANEOUS PUMPS</b>		SECTION: IA	
	<b>SPECIFIC TECHNICAL REQUIREMENTS</b>		REV. NO. 01	DATE:
<b>Annexure-2</b>				
<p><b>Following HT drives for NTPL 2X500 MW TUTICORIN -FGD PROJECT, irrespective of Motor ratings shall be issue free, by BHEL:</b></p>				
<p><b>NIL</b></p>				



## VOLUME : II-H

### SECTION-II

#### HORIZONTAL CENTRIFUGAL PUMPS

##### 1.00.00 INTRODUCTION

1.01.00 This section presents the general guidelines and details of horizontal centrifugal pumps to be procured under the scope of the Flue Gas Desulphurisation Package and shall not be limited to the pumps specified under Clause no. 3.00.00 below. For other horizontal centrifugal pump in the scope of Flue Gas Desulphurisation Package, these general guidelines as specified hereinafter shall be followed.

##### 2.00.00 CODES AND STANDARDS

2.01.00 The design, manufacture and performance of the horizontal centrifugal pumps as specified hereinafter, shall comply with the requirements of the following codes and standards and shall include all the latest amendments subsequent to the year of publication as mentioned below.

2.01.01	IS-6595 Part-2/ 1993	:	Horizontal Centrifugal pumps for clear, cold and fresh water.
2.01.02	IS-5120/1977	:	Technical requirements for Rotodynamic special Purpose pumps.
2.01.03	IS-5639/1970	:	Pumps for handling chemicals & corrosive liquids.
2.01.04	IS-5659/1970	:	Pumps for process water.
2.01.05	IS-6536/1972	:	Pumps for handling volatile liquids.
2.01.06	IS-9137/1978	:	Code for acceptance tests for centrifugal, mixed flow and axial flow pumps - Class 'C'.
2.01.07	ISO 3555/1977 BS 5316/1977 Part 2	:	Acceptance tests for centrifugal, mixed flow and axial flow pumps - Class 'B' tests.
2.01.08	ISO 2548/1973 BS 5316/1976 Part 1	:	- Do - Class 'C' tests.
2.01.09	API-610/1989	:	Centrifugal pumps for general refinery services.





- 2.01.10 Standards of the Hydraulic Institute of USA (1983).
- 2.01.11 PTC 8.2/1965 : Power Test Codes - Centrifugal pumps.
- 2.02.00 In case of any contradiction with the above standards and annexure, the stipulations in the annexure shall prevail and shall be binding to the Contractor.

### 3.00.00 SCOPE OF WORKS

#### 3.01.00 Scope of Supply

The scope of supply under this section shall be as below. Items specifically not mentioned but deemed necessary by the Tenderer for making the system completely reliable and efficient shall also be included.

#### 3.01.01 Equipment for Limestone based FGD system

- i) 4 x 100% Limestone slurry circulation pumps (two (2) for each circulation tank).
- ii) 4 x 100% Limestone slurry distribution pumps (two (2) for each slurry storage tank).
- iii) 2 x 100% Limestone slurry recirculation pumps for each level. Alternatively, one spare spray level with 1 x 100% pump for each level.
- iv) 4 x 100% Gypsum Bleed Pumps (two (2) for each absorber).
- v) 2 x 100% Emergency slurry pumps.
- vi) 4 x 100% Cloth wash pumps (two (2) for each vacuum belt filter)
- vii) 4 x 100% Cake wash pumps (two (2) for each vacuum belt filter)
- viii) 4 x 100% Filtrate Pump (two (2) for each vacuum belt filter)
- ix) 2 x 100% Filtrate Water Pump
- x) 2 x 100% Process Water Pumps.
- xi) 2 x 100% Flue Gas Quenching Water Pumps
- xii) 2 x 100% Mist Eliminator Wash Water Pumps.
- xiii) 2 x 100% Waste water hydro- cyclone feed pumps
- xiv) 2 x 100% Waste water transfer pumps



- xv) 2 x 100% Waste water disposal pumps
- xvi) Any other horizontal centrifugal pump included by the Bidder within the scope of Flue Gas Desulphurisation Package.

### 3.01.02 **Equipment Accessories**

Each pump set shall be supplied with the following accessories as a minimum:

- i) Couplings of approved design to connect pump shaft directly with the motor shaft.
- ii) Sets of base plates, support plates, grounding pads, lifting lugs, eyebolts, nuts etc for each pump and motor set.
- iii) Slip-on type drilled steel flanges of proper rating for both suction and discharge connections of each pump set. All the counter-flanges shall be complete with requisite number of bolts, nuts, gaskets etc.
- iv) Air release cocks and drain plugs for each pump set.
- v) Discharge line pressure gauge and suction line pressure/vacuum gauges complete with isolating cocks for each pump set.
- vi) All internal/integral piping with valves, fittings, and pressure gauges for lubrication, cooling and sealing, wherever applicable, shall be tapped of directly from respective pump discharge.

3.02.00 For details regarding Scope of Services and works Lead Specification Volume-IIA of this specification shall be referred.

### 4.00.00 **PERFORMANCE REQUIREMENT**

4.01.00 Performance requirements for the pumps shall be as guided by Section-I and Section-II of this Volume and by the annexure enclosed with this section.

4.02.00 Pumps shall preferably be designed to have the best efficiency at the specified duty point. The pumps shall be suitable for continuous operation at any point within the "Range of Operation" as stipulated in the annexure attached with this Section.

4.03.00 Pumps shall preferably have a continuously rising head-capacity characteristic from the specified duty point towards shut-off point, the maximum being at shut-off to enable parallel operation.







Under all circumstances, the 'range of operation' of the pumps shall exclude any unstable operating zone of the head - capacity curve.

- 4.04.00 Wherever specified in the annexure attached to this section, pumps of each category shall be suitable for parallel operation. The head vs. capacity, the BHP vs. capacity characteristics etc. shall be identical to ensure equal load sharing and trouble-free operation of any pump when the other pump(s) working in parallel with it trip.
- 4.05.00 The pump set along with the drive motor shall run smooth without undue noise and vibration. Acceptable peak-to-peak vibration limits shall be generally guided by the Hydraulic Institute Standards of USA.
- 5.00.00 **DESIGN AND CONSTRUCTION**
- 5.01.00 **Pump Casing**
- 5.01.01 Pump casing shall be provided with adequate number of vents and priming connections with valves unless the pump is made self-venting and priming. Casing drain, as required, shall be provided complete with drain valves.
- 5.01.02 Pump design must ensure that the nozzles are capable of withstanding external reactions not less than those specified in API-610.
- 5.01.03 In cases where an expansion joint is located at pump discharge, the pump assembly will be subjected to an additional thrust which will be transmitted to the foundation. This additional thrust shall be taken into the consideration of pump design.
- 5.02.00 **Impeller**
- 5.02.01 The rotor assembly shall be dynamically balanced and designed with critical speed substantially above the operating speed.
- 5.03.00 **Wearing Rings**
- 5.03.01 Replaceable type wearing rings shall be furnished to prevent damage to impeller and casing.
- 5.04.00 **Shaft**
- 5.04.01 Shaft size shall be selected considering that the critical speed shall be away from the operating speed as recommended in applicable Code/Standard. The critical speed shall also be at least 10% away from runaway speed.



5.05.00 **Shaft Sleeves**

5.05.01 Renewable type fine finished shaft sleeves shall be provided at the stuffing boxes/mechanical seals. Length of the shaft sleeves must extend beyond the other faces of gland packing or seal end plate so as to distinguish between the leakage past shaft and shaft sleeve and that past the seals/glands.

5.05.02 Shaft sleeves shall be properly fastened to the shaft to prevent any leakage or loosening. Shaft and shaft sleeve assembly should ensure concentric rotation.

5.06.00 **Bearings**

5.06.01 Bearings shall be easily accessible without disturbing the pump assembly. A drain plug shall be provided at the bottom of each bearing housing.

5.06.02 Heavy-duty sleeve/ball/roller type bearings shall be provided to take care of the radial loads.

5.06.03 In case of sleeve type radial bearings; axial thrust shall be absorbed in suitable hydraulic devices and/or thrust bearings.

5.06.04 Bearings and hydraulic devices (if provided for balancing axial thrust) shall be of adequate design for taking the entire pump load arising from all probable conditions of continuous operation, as specified in the annexure. Life of the bearings shall be guided by the design standard of the pump or as specified in annexure. Thrust bearing shall be capable of running continuously at maximum load.

5.06.05 The bearings shall be oil/grease lubricated. Suitable lubricating arrangement for the bearings shall be furnished with the pump complete all accessories like pump, filters, pipings, fittings, valves, interlocking and supervising instruments etc. as necessary and specified in the annexure. The design shall be such that the bearing lubricant does not contaminate the liquid being pumped.

5.07.00 **Stuffing Boxes**

5.07.01 Stuffing box design shall permit replacement of packing without removing any part other than the gland.

5.07.02 Stuffing boxes shall be sealed / cooled by the fluid being pumped/external clear water, as specified in the annexure. All necessary pumps, piping, fittings, valves, instruments etc. as required for safe and trouble-free operation of the pumps and as specified in the annexure shall be included in the scope of supply.





5.08.00      **Mechanical Seals**

5.08.01      Mechanical seals shall be provided if specified in the annexure. The pump supplier shall co-ordinate with the seal maker in establishing the circulation rate for maintaining a stable film at the seal face in the chamber. The seal piping system shall form an integral part of the pump assembly.

5.08.02      When handling liquids near their boiling point, suitable arrangement for external cooling shall be provided so as to prevent flashing at the seal faces.

5.08.03      For the seals under vacuum service, the seal design must ensure sealing against atmospheric pressure, even when the pumps are not operating.

5.09.00      **Drive Unit**

5.09.01      The pumps shall be driven by electric motor or other driving equipment like diesel engine etc. directly coupled or through a gear box/belt drives, as specified in the annexure. A heavy duty coupling along with coupling guard shall be provided between the pump and drive unit (except for belt drives).

5.09.02      Unless otherwise specified in annexure, drive unit power rating shall be the maximum of the following requirements.

- a)      15% margin over the pump shaft input power at the rated duty point.
- b)      5% margin over the maximum pump shaft input power required within the 'Range of Operation'.
- c)      Pump shaft input power required considering the overloading of the pump assuming single pump operation in the event of tripping of one or more of the pumps operating in parallel.

6.00.00      **INSPECTION AND TESTING**

6.01.00      The Contractor shall carry out the following specific tests and inspections to ensure that the equipment furnished lies in strict conformance with the specification and also in accordance with applicable codes/standards and good engineering practice.

- a)      Identification and Testing
  - i)      All materials used for pump construction shall be of tested quality. Material shall be tested as per the relevant standards and test certificates shall be made available to the Owner.



ii) Tests for each pump included under this section shall include but not be limited to the following:

- The entire surface of the impeller castings shall be subjected to Dye Penetration Test as per ASTM Specification no.: E165 65.
- Shaft shall be subjected to Dye Penetration and Ultrasonic Tests
- Wearing rings shall be subjected to Dye Penetration Test.
- Verification of material, witnessing of pouring, casting and inspection of finalized fabricated/cast castings.
- Inspection of finished castings for impeller and verification of materials.
- Inspection of pump shaft and verification of material.
- Witnessing of NDT/review of NDT reports.
- Static balancing test for impeller and dynamic balancing of complete rotating parts as per ISO-1940.
- Complete Inspection of assembled pump.

b) **Hydrostatic Testing**

The pump casing shall be hydrostatically tested at 150% of the shut-off pressure. Pressure shall be maintained for a period of not less than one (1) hour. While arriving at the above values maximum suction pressure shall be taken into account.

c) **Performance Test at Shop**

i) Each pump shall have to be tested to determine the performance curves of the pumps. These tests are to be conducted in presence of Owner's representative as per the requirements of the Standards of Hydraulic Institute of USA (ASME-Power Test Code PTC 8.2/BS-599) or any other equivalent standard but the tolerances on head discharge and power shall be as specified in HIS, USA.



- ii) Performance tests are to be conducted to cover the entire range of operation of the pumps. These shall be carried out to span 130% of rated capacity up to pump shut-off condition. A minimum of five combinations of head and capacity are to be achieved during testing to establish the performance curves, including the design capacity point, shut-off point and the two extremities of the range of operation as specified in the annexure. After completion of performance test, all pumps shall be stripped down for inspection of internals.
- iii) Tests shall be conducted with actual drive motors being furnished.
- iv) NPSH tests are to be conducted on one pump of each type at 3% head drop conditions, if specified in the pump annexure.
- v) Mechanical run test shall be carried out on all pumps to determine the vibration levels, noise levels etc. This test shall be conducted at site also. However, test value at site shall be used for the acceptance of the equipment.

#### 7.00.00 **DRAWING, DATA AND INFORMATION REQUIRED**

7.01.00 The Bidder shall submit the following along with his formal proposal besides the different information required as indicated elsewhere in this section.

##### 7.01.01 **Drawings**

- a) General arrangement drawings showing the principal dimensions, weight and location of the suction and discharge connections of the pumps offered. Details of lubrication and sealing arrangement shall be included.
- b) Typical cross-section drawing showing various components of the pumps offered, materials of construction etc.

##### 7.01.02 **Data and Curves**

- a) Determination of pump total dynamic head and rated capacity as per guidelines specified in Section-I and II of this Volume. Detailed calculations shall be shown by the Bidder.
- b) Anticipated performance curves showing the following characteristics:
  - i) Capacity vs. head.
  - ii) Capacity vs. power.





**Tender Specification  
for  
FGD Package**

**NLC Tamil Nadu Power Ltd.  
2x500 MW Project  
Tuticorin, Tamil Nadu**

- iii) Capacity vs. efficiency.
  - iv) Capacity vs. NPSH required.
  - v) System resistance curves.
- c) Speed vs. torque curve of the pump corresponding to recommended mode of pump starting superimposed on speed vs. torque curves of the drive unit corresponding to 80%, 90%, 100% of the rated voltage (applicable only in the cases of pumps with drive motor power rating of 100 KW and above).
- d) Completely filled-in Technical particulars enclosed under Volume-III of this specification.
- 7.02.00 The successful Bidder shall furnish the following drawings/data for Purchaser/Engineer's approval after award of the Contract.
- 7.02.01 Final versions of all the drawings, documents as specified in Clause no. 7.01.00 above.
- 7.02.02 Pump foundation details along with all design loads, direction and points of application.
- 7.02.03 Test reports, test certificates and other particulars.
- 7.02.04 All other applicable drawings and documents as specified in Volume IIA ('Lead Specification') and Volume IIB of this specification.

672753/2022/PS-PEM-MSE



FILE:  
**TECHNICAL SPECIFICATION  
MISCELLANEOUS PUMPS**  
  
**SPECIFIC TECHNICAL REQUIREMENTS**

SPEC. NO.: <b>PE-TS-483-100-N001</b>	
SECTION: <b>I</b>	
SUB-SECTION: <b>IB</b>	
REV. NO. <b>01</b>	DATE <b>03.02.2022</b>
SHEET <b>1</b>	OF <b>1</b>

**SUB-SECTION – IB**

**SPECIFIC TECHNICAL REQUIREMENTS (ELECTRICAL)**

672753/2022/PS-PEM-MSE:



ELECTRICAL EQUIPMENT SPECIFICATION  
FOR  
MISCELLANEOUS PUMPS  
2X500 MW NTPL TUTICORIN TPS (FGD System Package)

SPECIFICATION NO.

VOLUME NO. : **II-B**SECTION: **I**REV NO. : **00** DATE: 21.07.2021

SHEET: 1 OF 1

### CONTENTS

SECTION	TITLE	NO OF SHEETS
I	SPECIFIC TECHNICAL REQUIREMENTS	3
I	ELECTRICAL SCOPE BETWEEN BHEL & VENDOR	1
I	TECHNICAL SPECIFICATION FOR LV MOTORS	15
I	TECHNICAL SPECIFICATION FOR CABLING	25
I	REFERENCE QUALITY PLAN	11
I	MOTOR DATASHEET-A	1
I	MOTOR DATASHEET-C	2
I	ELECTRICAL LOAD DATA FORMAT (ANNEXURE-II)	1
I	CABLE SCHEDULE FORMAT (ANNEXURE-III)	1
II	GENERAL TECHNICAL REQUIREMENTS FOR LV MOTORS	4

The requirements mentioned in Section-I shall prevail and govern in case of conflict between the same and the corresponding requirements mentioned in the descriptive portion in Section-II.



672753/2022/PS-PEM-MSE



TITLE :  
ELECTRICAL EQUIPMENT SPECIFICATION  
FOR  
MISCELLANEOUS PUMPS  
2X500 MW NTPL TUTICORIN TPS (FGD System Package)

SPECIFICATION NO.
VOLUME NO. : II-B
SECTION : I
REV NO. : 00 DATE : 21.07.2021
SHEET : 1 OF 3

TECHNICAL SPECIFICATION  
FOR  
MISCELLANEOUS PUMPS  
(ELECTRICAL PORTION)



<b>TITLE :</b> <b>ELECTRICAL EQUIPMENT SPECIFICATION</b> <b>FOR</b> <b>MISCELLANEOUS PUMPS</b> <b>2X500 MW NTPL TUTICORIN TPS (FGD System Package)</b>	SPECIFICATION NO.
	VOLUME NO. : <b>II-B</b>
	SECTION : <b>I</b>
	REV NO. : <b>00</b> DATE : 21.07.2021
	SHEET : 2 OF 3

### 1.0 EQUIPMENT & SERVICES TO BE PROVIDED BY BIDDER:

- a) Services and equipment as per “Electrical Scope between BHEL and Vendor”.
- b) Any item/work either supply of equipment or erection material which have not been specifically mentioned but are necessary to complete the work for trouble free and efficient operation of the plant shall be deemed to be included within the scope of this specification. The same shall be provided by the bidder without any extra charge.
- c) Supply of mandatory spares as specified in the specifications of mechanical equipments.
- d) Electrical load requirement for MISCELLANEOUS PUMPS (all AC & DC loads at different voltage levels like 415V AC, 240 V AC, 220 V DC etc).
- e) All equipment shall be suitable for the power supply fault levels and other climatic conditions mentioned in the enclosed project information.
- f) Bidder to furnish list of makes for each equipment at contract stage, which shall be subject to customer/BHEL approval without any commercial and delivery implications to BHEL.
- g) Various drawings, data sheets as per required format, Quality plans, calculations, test reports, test certificates, operation and maintenance manuals etc shall be furnished as specified at contract stage. All documents shall be subject to customer/BHEL approval without any commercial implication to BHEL.
- h) Motor shall meet minimum requirement of motor specification.
- i) Vendor to clearly indicate equipment locations and local routing lengths in their cable listing furnished to BHEL.
- j) Cable BOQ worked out based on routing of cable listing provided by the vendor for “ both end equipment in vendor’s scope”shall be binding to the vendor with +10 % margin to take care of slight variation in routing length & wastages.

### 2.0 EQUIPMENT & SERVICES TO BE PROVIDED BY PURCHASER FOR ELECTRICAL & TERMINAL POINTS:

Refer “Electrical Scope between BHEL and Vendor”.

### 3.0 DOCUMENTS TO BE SUBMITTED ALONG WITH BID

- 3.1 The electrical specification without any deviation from the technical/quality assurance requirements stipulated shall be deemed to be complied by the bidder in case bidder furnishes the overall compliance of package technical specification in the form of compliance certificate/No deviation certificate.
- 3.2 No technical submittal such as copies of data sheets, drawings, write-up, quality plans, type test certificates, technical literature, etc, is required during tender stage. Any such submission even if made, shall not be considered as part of offer.

672753/2022/PS-PEM-MSE



TITLE :  
**ELECTRICAL EQUIPMENT SPECIFICATION**  
**FOR**  
**MISCELLANEOUS PUMPS**  
 2X500 MW NTPL TUTICORIN TPS (FGD System Package)

SPECIFICATION NO.	
VOLUME NO. :	<b>II-B</b>
SECTION :	<b>I</b>
REV NO. :	<b>00</b> DATE : 21.07.2021
SHEET :	3 OF 3

#### 4.0 List of enclosures :

- a) Electrical scope between BHEL & vendor
- b) General Technical requirements for LV Motors.
- c) Customer specification for Motors
- d) Customer cabling spec ( to be referred by vendor for their scope of work (as per
- e) Electrical scope between BHEL & vendor)).
- f) Quality plan for motors
- g) Datasheet A and C for LT Motors (Annexure-I)
- h) Electrical Load data format (Annexure –II)
- i) BHEL cable listing format (Annexure –III)

## STANDARD ELECTRICAL SCOPE BETWEEN BHEL AND VENDOR

## PACKAGE: MISC. PUMP

## PROJECT: 2X500 MW NTPL TUTICORIN FGD

<u>S.NO</u>	<u>DETAILS</u>	<u>SCOPE SUPPLY</u>	<u>SCOPE E&amp;C</u>	<u>REMARKS</u>
1	415 V MCC	BHEL	BHEL	240 V AC (supply feeder)/415 V AC (3 PHASE 4 WIRE) supply shall be provided by BHEL based on load data provided by vendor at contract stage for all equipment supplied by vendor as part of contract. Any other voltage level (AC/DC) required will be derived by the vendor.
2	Local Push Button Station ( for motors)	BHEL	BHEL	Located near the motors.
3	Power cables, control cables and screened control cables	BHEL	BHEL	Incoming cable from BHEL supplied MCC will be informed by BHEL. Screened control cable between DCS & field equipment will also be informed by BHEL. Vendor shall provide lugs & glands accordingly.
4	Cable trays, accessories & cable trays supporting system	BHEL	BHEL	
5	Cable glands and lugs for equipments supplied by Vendor	Vendor	BHEL	1. Double compression Ni-Cr plated brass cable glands 2. Solder less crimping type heavy duty tinned copper lugs for power and control cables.
6	Conduit and conduit accessories for cabling between equipments supplied by vendor	BHEL	BHEL	
7	Equipment grounding & lightning protection	BHEL	BHEL	
8	Below grade grounding	BHEL	BHEL	
9	LT Motors with base plate and foundation hardware	Vendor	BHEL	Makes shall be subject to BHEL approval at contract stage.
10	Mandatory spares	Vendor	-	Vendor to quote as per specification.
11	Recommended O & M spares	Vendor	-	As per specification
12	Any other equipment/material/service required for completeness of system but not specified above (to ensure trouble free and efficient operation of the system).	Vendor	BHEL	
13	Electrical equipment GA drawing	Vendor	-	For necessary interface review.

NOTES:

1. Make of all electrical equipments/items supplied shall be reputed make & shall be subject to approval of BHEL after award of contract.
2. All QPs shall be subject to approval of BHEL after award of contract without any commercial implication.

## A.C. & D.C. MOTORS

### 1.00.00SCOPE

- 1.01.0 This specification covers the general requirements of the electric motors for Limestone based flue gas de-sulphurisation system.
- 1.02.00Motors shall be furnished in accordance with both this general specification and the accompanying driven equipment specification.
- 1.03.00 In case of any discrepancy, the driven equipment specification shall govern.
- 1.04.00 Recommended spare parts for three (3) years operation in addition to mandatory spares

### 2.00.00CODES & STANDARDS

- 2.01.00All motors shall conform to the latest applicable IS, IEC and CBIP Standards/Publications except when otherwise stated herein or in the driven equipment specification.
- 2.02.00 Equipment and materials conforming to any other standard, which ensures equal or better quality may be accepted. In such case, copies of the English version of the standard adopted shall be submitted along with the bid.

### 3.00.00SERVICE CONDITIONS

- 3.01.00The motors shall be installed in hot, humid and tropical atmosphere, highly polluted area.
- 3.02.00 Unless otherwise noted, electrical equipment/system design shall be based on the service conditions and auxiliary power supply given in the annexure to this specification.
- 3.03.00 For motor installed outdoor and exposed to direct sunrays, the effect of solar heat shall be considered in the determination of the design ambient temperature.

### 4.00.00 TYPE AND RATING

#### 4.01.00A.C. Motors

- 4.01.01 Motors shall be general purpose, constant speed, squirrel cage, three/single phase, induction type.
- 4.01.02All motors shall be either totally enclosed fan cooled (TEFC) or totally enclosed tube ventilated (TETV) or closed air circuit air cooled (CACA) or closed air water

cooled (CACW) type. Temperature rise shall be limited to 70 deg C by resistance method for class F insulation.

4.01.03 All motors shall be rated for continuous duty (S1). They shall also be suitable for long period of inactivity.

4.01.04 All LT motor shall conform to minimum efficiency performance standards (MEPS) of IE3 mentioned in IS: 12615. All HT motors shall have efficiency and power factor higher than 90% and 0.83 power factor respectively.

4.01.05 The motor name plate rating at 50<sup>o</sup>C shall have at least 15% margin for LT system and 10% margin for HT system, over the input power requirement of the driven equipment at rated duty point and also covering the maximum load demand of the driven equipment under entire operating range, including voltage and frequency variations, unless stated otherwise in driven equipment specification or in general electrical specification.

4.01.06 The motor characteristics shall match the requirements of the driven equipment so that adequate starting, accelerating, pull up, break down and full load torques are available for the intended service. The direction of rotation of motor and its cooling fan should be properly matched with the driven equipment.

#### **4.02.00 AC motor for VFD application**

4.02.01 Inverter duty motors are designed according to the requirements of IEC/TS- 60034 part 17 & part 25 or NEMA MG-1, Part-30, Part 31 and have performance characteristics match with the driven equipment and variable speed requirement.

4.02.02 Induction motors to be operated in adjustable-speed drive applications should be derated as per NEMA/IEC standard due to the reduction in cooling resulting from any reduction in operating speed and the effect of additional losses introduced by harmonics generated by the control.

4.02.03 Inverter duty motors shall have VPI/improved insulation systems that do not degrade readily due to transient voltage spikes and have an adequate thermal margin.

4.02.04 Inverter duty motors shall be self-ventilated without any auxiliary blower. Force ventilation shall be subject to purchaser approval.

4.02.05 Inverter motor shall be suitable for scalar (open loop) control, without any speed feedback signal, where fast response is not required. Vector (closed loop) control will be used with encoder if specified.

4.02.06 The breakdown torque at any frequency within the defined frequency range shall be not less than 150% of the rated torque at that frequency when rated voltage for that frequency is applied.

4.02.07 The motor should be capable of producing a breakaway torque of at least 140% of rated torque requiring not more than 150% rated current when the voltage

boost is adjusted to develop rated flux in the motor and when the inverter is able to produce the required minimum fundamental frequencies.

4.02.08 The motor shall be provided with insulated bearing on one side.

4.02.09 Normally the maximum safe speed shall be as per IEC/NEMA, however it should be co-ordinated with VSD requirement.

4.02.10 In case of a conflict, the requirement mentioned under clause no. 4.02.00 for motors for VFD application shall supersede the corresponding requirement for standard motors.

#### 4.03.00 D.C. Motors (If applicable)

4.03.01 D.C. motor provided for emergency service shall be shunt wound type. It can also be of compound-wound type with the series field shorted.

4.03.02 Motor shall be sized for operation with fixed resistance starter for maximum reliability. Starter panel complete with all accessories shall be included in the scope of supply.

### 5.00.00 PERFORMANCE

#### 5.01.00 Running Requirements

5.01.01 Motor shall run continuously at rated output over the entire range of voltage and frequency variations as given in the annexure.

5.01.02 The motor shall be capable of operating satisfactorily at full load for 5 minutes without injurious heating with 75% rated voltage at motor terminals. The mill motors shall be suitable for operating at 75% of rated voltage for one (1) minute

#### 5.02.00 Starting Requirements

5.02.01 Motor shall be designed for direct on line starting at full voltage. Starting current shall not exceed 600% of full load current (subject to IS tolerance of 20%) for HT motors rated upto 1000kW. For HT motors above 1000kW upto 3000kW starting current shall not exceed 600% of full load current without any positive tolerance. For HT motors above 3000kW starting current shall not exceed 450% of full load current without any positive tolerance.

For LT motors the starting current shall be as per the limit mentioned in the relevant standard with IE-3 efficiency class. For D.C. Motors the starting current shall be limited to 2 times full load current.

5.02.02 The motor shall be capable of withstanding the stresses imposed if started at 110% rated voltage.

5.02.03 All motors (except mill motors) shall start with rated load and accelerate to full speed with 80% rated voltage at motor terminals. Mill motors shall start with rated load and accelerate to full speed with 85% of rated voltage.

## 2x500 MW NLC Tamil Nadu Power Ltd. Tuticorin, Tamil Nadu

5.02.04 Motor shall be capable of three equally spread starts per hour, two starts in quick succession from cold condition and one restart from hot condition.

### **Cold Motor Starting**

Under specified voltage variations two (2) starts in quick succession and third start five (5) minutes thereafter, all with full load (including loaded equipment) of driven equipment. No additional start shall be made till lapse of further thirty (30) minutes.

### **(b) Hot Motor Starting**

Under specified voltage variations, one (1) immediate and two (2) fifteen (15) minutes interval starts all with full load (including loaded equipment) of driven equipment. No additional start shall be made till lapse of further thirty (30) minutes.

**(c)** Motor shall also be suitable for three (3) equally spread starts per hour when the motor is under normal service condition.

5.02.05 Pump motor subject to reverse rotation shall be designed to withstand the stresses encountered when starting with non-energized shaft rotating at 125% rated speed in reverse direction.

### **5.03.00 Stress During Bus Transfer**

5.03.01 Motors subjected to bus transfer shall be suitable for sudden application of 150% rated voltage during bus transfer, due to the phase difference between the incoming voltage and motor residual voltage.

5.03.02 The motor shall be designed to withstand any torsional and/or high current stresses, which may result, without experiencing any deterioration in the normal life and performance characteristics.

### **5.04.00 Locked Rotor Withstand Time**

5.04.01 For motors with starting time up to 20 secs, starting time at minimum permissible voltage should be less than the locked rotor withstand time under hot condition at highest voltage limit by at least 2.5 secs.

For motors with starting time more than 20 secs. and upto 45 secs, starting time at minimum permissible voltage should be less than the locked rotor withstand time under hot condition at highest voltage limit by at least 5 secs.

For motors with starting time more than 45 secs, starting time at minimum permissible voltage should be less than the locked rotor withstand time under hot condition at highest voltage limit by at least 10% of the starting time.

5.04.02 To prevent unwanted tripping of a high inertia load at start-up, there may be need to shunt out the motor's overload trip device. Speed switches mounted



**2x500 MW NLC Tamil Nadu Power Ltd. Tuticorin, Tamil Nadu**

on the motor shaft may be provided in such case. Heating experienced during start-up must still be considered when sizing the motor.

5.04.03 Hot thermal withstand curve shall have a margin of at least 10% over the full load current of the motor to permit relay setting utilising motor rated capacity.

5.05.00 Torque Requirements

5.05.01 Accelerating torque at any speed with the lowest permissible starting voltage shall be at least 10% motor full load torque.

5.05.02 Pull out torque at rated voltage shall not be less than 205% of full load torque.

**6.00.00 SPECIFIC REQUIREMENTS****6.01.00 Enclosure**

6.01.01 All motor enclosures and terminal boxes shall conform to the degree of protection IP-55 unless otherwise specified. Motor for outdoor or semi-outdoor service shall be of weather-proof construction.

Motors, located inside a building and not directly exposed to coal dust or fly ash, could have screen protected drip proof enclosure conforming to IP-23.

6.01.02 Motor located in hazardous area shall have flameproof enclosure conforming to IS: 2148 /Equiv.

**6.03.00 Cooling**

6.03.01 The motor shall be self ventilated type, either totally enclosed fan cooled (TEFC) or closed air circuit air- cooled (CACA).

6.03.02 For large capacity motors, totally enclosed tube ventilated (TETV) may be considered for acceptance. In case of motors rated 3000kW and above, closed air circuit water cooled (CACW) motors may be offered for consideration before proceeding with design and manufacturing.

**6.04.00 Winding and Insulation**

6.04.01 All insulated winding shall be of copper.

6.04.02 HT and LT motors shall have Class F insulation with winding temperature limited to 120°C. Windings shall be impregnated to make them non-hygroscopic and oil resistant. The lightning impulse and coil inter-turn insulation surge withstand level shall be as per IEC-60034 – Part 15.

**6.05.00 Tropical Protection**

6.05.01 All motors shall have fungus protection involving special treatment of insulation and metal against fungus, insects and corrosion.

6.05.02 All fittings and hardwares shall be corrosion resistant.

**6.06.00 Bearings**

6.06.01 Motor rated above 1000kW shall have insulated bearings to prevent flow of shaft currents.

6.06.02 Vertical shaft motors shall be provided with thrust and guide bearings.

**6.07.00 Noise & Vibration**

6.07.01 The noise level shall not exceed 85 db (A) at 1.0 meters from the motor.

6.07.02 Peak amplitude of vibration shall be limited within the values prescribed in IS: 12075 / IEC 60034-14.

**6.08.00 Motor Terminal Box**

6.08.01 Motor terminal box shall be detachable type, made of cast iron or pressed steel and located in accordance with Indian Standards clearing the motor base-plate / foundation.

6.08.02 Terminal box shall be capable of being turned 360 Deg. in steps of 90 Deg., unless otherwise approved.

6.08.03 The terminal box shall be split type with removable cover with access to connections and shall have the same degree of protection as motor. Terminal box for all LT motors shall be diagonally split type.

6.08.04 The terminal box shall have sufficient space inside for termination / connection of XLPE (11000V/3300V) or XLPE (415V) insulated armoured aluminium cables. Where the specified main cable size demands, adopter / extension box of suitable size shall be provided as a part integral to the motor, for easy termination of the cable.

6.08.05 Terminals shall be stud or lead wire type, substantially constructed and thoroughly insulated from the frame.

6.08.06 The terminals shall be clearly identified by phase markings, with corresponding direction of rotation marked on the non-driving end of the motor.

6.08.07 The terminal box shall be capable of withstanding maximum system fault current for a duration of 0.25 sec.

6.08.08 For 11000V and 3300V motor, the terminal box shall be phase-segregated type. The neutral leads shall be brought out in a separate terminal box (not necessarily phase segregated type) with shorting links for star connection.

6.08.09 Motor terminal box shall be furnished with suitable cable lugs and double compression brass glands to match with cable used.

**2x500 MW NLC Tamil Nadu Power Ltd. Tuticorin, Tamil Nadu**

6.08.10 The gland plate for single core cable shall be non-magnetic type.

6.08.11 Motors rated 1000kW and above shall be provided with neutral current transformers of PS class on each phase in a separate neutral terminal box for differential protection.

**6.09.00 Grounding**

6.09.01 The frame of each motor shall be provided with two separate and distinct grounding pads complete with tapped hole, GI bolts and washer.

6.09.02 The grounding connection shall be suitable for accommodation of ground conductors as follows:

Motor above 90KW	:	50 x 6 mm GS Flat
Motor above 30KW up to 90KW	:	25 x 6 mm GS Flat
Motor above 5KW up to 30KW	:	25 x 3 mm GS Flat
Motor up to 5KW	:	8 SWG GI Wire

6.09.03 The cable terminal box shall have a separate grounding pad.

**6.10.00 Rating Plate**

In addition to the minimum information required by IS, the following information shall be shown on motor rating plate:

- a) Temperature rise in Deg.C under rated condition and method of measurement.
- b) Degree of protection (IP No.).
- c) Bearing identification no. and recommended lubricant.
- d) Location of insulated bearings.

**7.00.00 ACCESSORIES****7.01.00 General**

Accessories shall be furnished, as listed below, or if otherwise required by driven equipment specification or application.

**7.02.00 Space Heater**

7.02.01 Motor of rating 30KW and above shall be provided with space heaters, suitably located for easy removal or replacement.

7.02.02 The space heater shall be rated 240V, 1 phase 50Hz and sized to maintain the motor internal temperature above dew point when the motor is idle.

#### 7.03.00 Temperature Detectors

7.03.01 All 11000V and 3300V motors shall be provided with minimum four (4) numbers simplex or two (2) numbers duplex platinum resistance type winding temperature detectors per phase.

7.03.02 11000V and 3300V motor bearing shall be provided with one (1) duplex or two (2) simplex type temperature detectors.

7.03.03 The temperature detector mentioned above shall be resistance type, 3 wire, platinum wound, 100 Ohms at 0 deg.C.

Leads of all duplex or simplex type motor winding RTDs and motor bearing RTDs shall be wired up to respective switchgear metering & protection compartment. From which one set of RTDs shall be connected to numerical protection relay and another set shall be kept free for DDCMIS connectivity.

#### 7.04.00 Indicator/Switch

7.04.01 Dial type local indicator with alarm contacts shall be provided for the following:

- a) 11000V and 3300V motor bearing temperature.
- b) Hot and cold air temperature of the closed air circuit for CACA and CACW motor.

7.04.02 Flow switches shall be provided for monitoring cooling water flow of CACW motor and oil flow of forced lubrication bearing, if used.

7.04.03 Alarm switch contact rating shall be minimum 0.5A at 220V D.C. and 5A at 240V A.C.

#### 7.05.00 Current Transformer for Differential Protection

7.05.01 Motor above and including 1000KW shall be provided with three differential current transformers (PS class) mounted over the neutral leads within the enclosure. Loose three (3) numbers matching PS class CT shall be supplied for mounting on switchgear.

7.05.02 The arrangement shall be such as to permit easy access for C.T. testing and replacement. Current transformer characteristics shall match with the requirements of differential protection relay.

#### 7.06.00 Accessory Terminal Box

7.06.01 All accessory equipment such as space heater, temperature detector, current transformers etc., shall be wired to and terminated in terminal boxes, separate from and independent of motor (power) terminal box.

## 2x500 MW NLC Tamil Nadu Power Ltd. Tuticorin, Tamil Nadu

7.06.02 Accessory terminal box shall be complete with double compression brass glands and pressure type terminals to suit required cable connections.

### 7.07.00 Drain Plug

Motor shall have drain plugs so located that they shall drain the water, resulting from the condensation or other causes from all pockets of the motor casing.

### 7.08.00 Lifting Provisions

Motor weighing 25 Kg. or more shall be provided with eyebolt or other adequate provision of lifting.

### 7.09.00 Dowel Pins

The motor shall be designed to permit easy access for drilling holes through motor feet or mounting flange for installation of dowel pins after assembling the motor and driven equipment.

### 7.10.00 Painting

Motor including fan shall be painted with corrosion proof paints.

## 8.00.00 TESTS

8.01.00 Upon completion, each motor shall be subject to standard routine tests as per IS. In addition, any special test called for in the driven equipment specification shall be performed.

8.02.00 Unless and otherwise stated, Six (6) copies of routine test certificates shall be submitted for approval prior to the dispatch of the motors from works.

8.03.00 The following type test reports shall be submitted for each type and rating of 11 kV & 3.3 kV motor:

- a) Degree of protection test for the enclosure followed by IR, HV and no load run test.
- b) Fault level withstand test for each type of terminal box.
- c) Lightning impulse withstand test on the sample coil as per IEC 60034, part-15.
- d) Surge withstand test on inter-turn insulation as per clause no. 5.1.2 of IEC 60034, part-15.

### SPARES

Recommended spares for three (3) years operation shall be quoted along with the bid clearly identifying the part numbers with recommended quantities.

**2x500 MW NLC Tamil Nadu Power Ltd. Tuticorin, Tamil Nadu****09.00.00 DRAWINGS, DATA & MANUALS**

Drawings, data & manuals for the motors shall be submitted as indicated below:

**09.01.00 Along with the bid**

- a) List of the motors
- b) Individual motor data sheet as per format of the proposal data sheets.
- c) Scheme & write up on forced lubrication system, if any
- d) Type test report

**09.02.00 After Award of the Contract**

- a) Dimensional General Arrangement drawing
- b) Foundation Plan & Loading
- c) Cable end box details
- d) Space requirement for rotor removal
- e) Thermal withstand curves hot & cold
- f) Starting and speed torque characteristics at 80% & 100% voltage
- g) Complete motor data
- h) Erection & Maintenance Manual
- i) Efficiency curves.
- j) List of motors.
- k) Test reports

## 2x500 MW NLC Tamil Nadu Power Ltd. Tuticorin, Tamil Nadu

### DESIGN DATA

#### 1.0 SERVICE CONDITIONS

Refer Vol-IIA of Specification for FGD package.

#### 2.0 AUXILIARY POWER SUPPLY

Supply	Description	Consumer
H.T. Supply	11000V, 3 $\phi$ , 3W, 50 Hz, non-effectively earthed. Fault level 40kA symm. for 3sec	Motors above 750kW
	3.3kV, 3 $\phi$ , 3W, 50 Hz, non-effectively earthed. Fault level 40kA symm for 3sec	Motors above 160kW up to & including 750kW
L.T. Supply	415V, 3 $\phi$ , 3W, 50 Hz, effectively earthed. Fault level 50kA symm for 1sec	Motors above 200W upto 160 kW
	240V, 1 $\phi$ , 2W, 50 Hz, effectively earthed.	Motors less than 200W, Lighting, space heating, A.C. control & protective devices
D.C. Supply	220V, 2W, unearthed. Fault level 25*kA for 1sec	D.C. alarm, control & protective devices

\* Indicative only; actual value shall be decided by the Bidder, after substantiating the same by calculation.

#### 3.0 RANGE OF VARIATION

##### A.C. Supply

Voltage:  $\pm 10\%$       Frequency:  $\pm 5\%$

Combined Volt & frequency: 10%( absolute sum)

##### D.C. Supply

Voltage: (+10% to -15%)

## 2x500 MW NLC Tamil Nadu Power Ltd. Tuticorin, Tamil Nadu

### SCHEDULE OF PRE-COMMISSIONING TESTS OF ~~TRANSFORMER & ELECTRICAL EQUIPMENT~~

1.	<b>Power Transformer</b>	
	<b>Pre-commissioning Tests</b>	
a.	The following test shall be carried out a site as minimum requirements before energizing of a transformer. All tests which may not have been specifically mentioned here but necessary for commissioning and any tests, which have been specifically asked for by the purchaser shall be done by Bidder at no extra cost:	
b.	IR test on each winding to ground and between windings	
c.	Turns ratio test on each tap	
d.	Polarity and vector group test	
e.	Measurement of winding resistance of HV & LV windings for all taps by Kelvin bridge	
f.	IR, wiring and operational tests on all control devices in control cabinet, oil level indicator, winding and oil temp. indicators, cooling fan etc.	
g.	Checking of earthing with respect to transformer tank (flexible from top cover to tank) other parts, neutral and tank to electrodes of Las (for Las located near to transformer)	
h.	Testing of buchholz relay for alarm and trip conditions	
i.	For bushing CTs, tests applicable shall be as for current transformers.	
j.	Setting of oil/winding temperature indicators, level gauge and checking of alarm/trip circuits.	



9.	<b>AC Motors (including slip rings motor)</b>	
a	IR test of stator and rotor windings.	
b	Heating of both windings upto the permissible temp. limit from heating curve (only for HT motors).	
c	Ensure that checking / testing of associated switchboard, cables, relays / meter interlockings as mentioned in relevant chapters are completed.	
d	Check tightness of cable connection.	
e	Winding resistance measurement of stator and rotor.	
f	Checking continuity of winding.	
g	Check tightness of earth connections.	
h	Check space heaters and carryout heating of winding (if required).	
i.	Check direction of rotation in decoupled condition during kick start.	
j	Measure no load current for all phases.	
k	Measurement of temperature of body during No-load and load conditions.	
l	Check for tripping of motor from local / remote switches and from electrical / technological protection including differential protection.	
m	Checking of vibration (if required)	
n	Checking of noise level (if required).	
o	During load running, measurement of stator and bearing temperatures (if applicable) for every half an hour interval till saturation comes.	
p	Checking tightness of foundation bolts.	

q	Check operation of speed switch (if there).	
r	Check continuity of temp. detectors.	
s	Check alignment, paralleling of shafts, level of lubricating oil etc. as per manufacturer's manual.	
t	Check contact of slip ring brush and measure brush pressure (150-200 gm/sq.cm).	
u	For CACW drive check cooling water and system / piping, availability of pressure cleaning and pressure testing of pipelines etc.	
v	Check for polarisation index of stator windings R10 / R1 by motorised megger. (The value should not be less than 2.0). R60/R10 absorption coefficient shall not be less than 1.5	
w	Dielectric test (only for HT motors).	
X	Measurement of open circuit rotor winding voltage for slip ring motor.	
10	<b>Motors (DC) If required</b>	
a	IR measurement and heating the winding as per heating curve.	
b	Check for earth connection.	
c	Winding resistance for field and armature.	
d.	Check running of drive at minimum and maximum specified voltage.	
e	Check auto start of drive on failure of AC supply (if applicable).	
f	Check operation of overload relay.	

g	Measure vibration.	
h	Check temperature rise on body of drive after required period of continuous running.	
i	Measure load currents and no load currents (if possible).	
j.	Check direction of rotation.	
k.	Check continuity of winding.	
l	Measurement of RPM.	
11	<b>For actuator drives following shall be checked / tested.</b>	
a	Visual and dimensional	
b	Hydraulic pressure for valves	
c	IR and operation of limit switches	
d	Winding resistance	
12	<b>CRANE/HOIST</b>	
a	Check IR of all drives, panels and other equipment	
b	Check & clean surface of shop leads(if there)	
C	Check earthing system and earthing of all metallic part	
d	Measurement of no load and load currents for all drives	
e	Observations on speed of hoisting/lowering for main and aux.hoists & brake.	
f	Measurement of deflection at full load and as per mechanical requirement at overload for main hoist.	
g	Checking for operations of all limit switches	

~~CABLING, GROUNDING AND  
LIGHTNING PROTECTION SYSTEM~~

## **CABLING, GROUNDING AND LIGHTNING PROTECTION SYSTEM**

### **1.00.00 SCOPE OF WORK**

1.01.00 The Scope of Work covers complete and efficient design, engineering, testing at manufacturers works, supply, transportation erection, testing and commissioning of lightning protection system, all cabling and electrical grounding works. The scope shall broadly cover, but not be limited to:

1. Limestone Handling Area
2. Gypsum Handling Area
3. Absorber Area
3. All auxiliary buildings (including electrical rooms of respective buildings) and structures within the FGD package like Limestone preparation building, Absorber pump house, Gypsum De-watering building, FGD Control building, etc. as detailed in the Lead Specification & Plot Plan.
4. Overhead cable trestle and pipe cum cable trestle, if any.
5. All electrical equipment as described in Volumes II-F.

The scope of work shall also include all civil and structural works necessary for successful installation and commercial operation of all electrical equipment to be erected under this specification.

### **2.00.00 SCOPE OF SUPPLY**

2.01.00 The scope of supply shall include but not be limited to the followings:

2.01.01 Timely procurement and transportation to site in properly packed condition of all materials and miscellaneous items required to complete the erection work under this specification.

These materials and miscellaneous items shall include but not be limited to the following:

- a) Galvanized steel pre-fabricated cable trays, coupler plates, nuts, bolts & washers, reducers, covers, wall brackets, hanger clamps, straight run, elbows, bends, etc.

- b) Galvanised steel rigid/flexible conduits and accessories, ferrules, lugs, glands, terminal blocks, galvanised sheet steel junction boxes, cable fixing clamps, nuts & bolts etc. as required.
- c) Cable termination and jointing kits as necessary.
- d) All necessary erection materials, consumables and sundry items including arc welding rods to complete the installation for satisfactory and trouble free operation.
- e) Mild steel rods for grounding conductor, grounding electrode, column & structure grounding, risers etc.,  
Mild steel rod for vertical air terminals,  
Materials for electronic grounding,  
Galvanized steel flats for horizontal air terminals, for down conductors and for large equipment grounding  
Galvanized wire (8SWG) for small equipment grounding.
- f) Any item of works or erection materials which have not been specifically mentioned but are necessary to complete the work involved shall be deemed to be included in the scope of this specification and shall be furnished by the Bidder without any extra charge to the Purchaser.

#### **Scope of Services**

- 2.02.00 The scope of Cabling, Grounding and Lightning Protection Systems includes but is not limited to the following:
- 2.02.01 Furnishing of all erection tools and tackles, testing equipment, implements, supplies, hardware and transport for timely and efficient execution of the erection work. Hydraulic jacks or motorized jacks necessary for lifting of heavy equipment shall be provided by the contractor.
- 2.02.02 Transport vehicles necessary for efficient transportation of equipment from stores to site of erection and excess materials back to stores.
- 2.02.03 A general list of the outdoor and indoor Electrical Equipment with accessories for complete assembly, erection and connection, testing and commissioning, putting into successful and satisfactory commercial operations by the contractor and as applicable in a FGD plant is given below. Since plant configuration varies from project to project, actual equipment and accessories shall also be guided by other specification documents.
  - a) 220/11.5/11.5kV Station Transformer
  - b) HT Aux. Transformers for FGD system
  - c) L.T. Transformers (dry)
  - d) Lighting Transformers

- e) Neutral Grounding Resistor Cubicles
  - f) 3.3Kv & 11kV Busducts
  - g) 415 V Busduct
  - h) 11kV & 3.3kV Switchgears
  - i) 415 V Switchgears, Switchgear cum MCCs.
  - j) Motor Control Centres, A.C./D.C. Distribution boards, Main lighting distribution boards and miscellaneous items.
  - k) Battery and Battery Chargers, Uninterrupted Power Supply Panels
  - l) Electrical Control Desks/Panels, Relay Panels, Data logger Panels etc.
  - m) Miscellaneous Local Panels.
  - n) All electrical equipment and systems integral with mechanical equipment, systems and subsystems.
  - o) Any other equipment, not mentioned herein but required for the completing the Plant shall be deemed included in the scope.
- 2.02.06 Erection work of equipment shall be carried out in a neat and efficient way so as not to impair their normal functioning in any way.
- 2.02.07 Pre-commissioning checks as well as commissioning of different equipment shall be carried out as per guidance of actual manufacturer's supervisor and or as per written instructions in Erection Manuals. In case of any site related problem in commissioning activities, contractor shall seek advice of the OE.
- 2.02.08 All erection work under this specification shall be carried out strictly in accordance with the approved drawings.
- 2.02.09 Erection work shall also be performed with respect to the following items:
- a) Cable trays and accessories
  - a) Power cables
  - b) Cables laid directly buried in ground
  - c) Control, instrument and special cables
- 2.03.00 All materials and accessories to be supplied by the Bidder shall be brand new ones of reputed make.
- 2.04.00 Necessary drawings, data sheets and Technical leaflets on each piece of material.
- 3.00.00 GENERAL REQUIREMENTS**

**3.01.00 Codes and Standards**

3.01.01 All cable and materials shall be designed, manufactured and tested in accordance with the latest applicable Indian Standards (IS) and IEC except where modified and/or supplemented by this specification.

3.01.02 Cable and material conforming to any other standard, which ensures equal or better quality, may be accepted. In such case, copies of the English version of the standard adopted shall be submitted along with the bid.

3.01.03 The electrical installation shall meet the requirements of Indian Electricity Rules as amended up to date and relevant IS Code of Practice. In addition, other rules and regulations applicable to the work shall be followed.

**3.02.00 Erection Schedule**

3.02.01 The entire erection work shall be carried out in a phased manner. A schedule of the work showing the sequence of erection shall be submitted by the tenderer for this purpose.

3.02.02 The erection schedule, as approved by the Owner's Engineer shall be strictly followed by the Bidder. If, for any reason beyond the control of the Bidder, the work is held-up then the Bidder shall bring it to the notice of the Owner's Engineer without any delay.

**4.00.00 DESIGN CRITERIA****4.01.00 Grounding System**

4.01.01 The main objectives of grounding system are to:

- a) Provide safety to personnel from contact of dangerous potential caused by ground fault.
- b) Ensure sufficient grounding current for effective relaying.
- c) Stabilize circuit potential with respect to ground.
- d) The grounding system shall be designed in compliance with the IEEE-80/ IEEE- 665 considering fault current of 50kA for 1 sec. and shall be subject to approval of the Owner.
- e) Major items of equipment, such as switchgear, transformer, motor, relay panels and control panels etc shall have integral ground buses or connection points which shall be connected to the underground grid.
- f) Electronic panels and equipment, where required, shall be grounded utilizing an insulated ground wire connected in accordance with the manufacturer's recommendations. Where practical, electronics ground loops shall be avoided. Where this is not practical, isolation



- 4.02.04 For metal structures which are electrically continuous down to the ground level, no lightning protection is required except adequate grounding connections.
- 4.02.05 **System Design**
- a) Air termination network with down conductors and earthing electrodes shall be provided on the basis of IS Code of Practice.
  - b) Horizontal air termination shall be so laid out that no part of the roof shall be more than 9 meters from the nearest conductor.
  - c) Shielding angle for one vertical air termination shall be 45 degrees. For more than one rod, shielding angle between the rods shall be taken as 60 Degrees.
  - d) Down conductors shall run along the outer surfaces of the building and shall have a test joint about 1500 mm above ground.
  - e) An earth electrode shall be provided at the connection point of the down conductor with the station ground.
  - f) Galvanised steel rods and flats shall be generally used for air termination and connections. All connections shall be welded type.
  - g) All other ancillary items in connection with the work described above shall be furnished to complete the work irrespective of whether such items may have been specifically mentioned or not.
- 4.02.06 All materials and accessories to be supplied by the Bidder shall be brand new ones of reputed make.
- 4.03.00 **Cabling System**
- 4.03.01 Erection of cabling work shall be carried out in such a way as to provide a reliable and assured electric power supply system to all FGD auxiliaries.
- 4.03.02 Cable routing shall be done on unit basis as far as possible.
- 4.03.03 Cables shall generally be laid on cable trays overhead supported from building steel/structures. Cables shall be run in concrete trenches in those electrical rooms at ground level, which are without any spreader room below.
- 4.03.04 For inter plant connections, the cables shall be routed through an overhead cable bridge pipe cum cable bridge. For isolated but long outdoor cable route with very few cables of 3/4 nos., the cables may be directly buried subject to Owner's approval.
- 4.03.05 For underground crossing of railways, road etc. additional protection shall be provided in form of hume pipe or concrete encased rigid steel conduits (duct bank).

- 4.03.06 A.C. and D.C. circuit shall not be run in same cable. Further, separately fused circuit shall run in separate cables.
- 4.03.07 Cables for redundant equipment system shall be run in separate trays, as far as possible.
- 4.03.08 Erection of cabling work shall be executed keeping in view all necessities and requirements.
- 4.03.09 Suitable embedded steel inserts shall be provided on wall/floor/ ceiling surfaces for welding of cable tray bracket in order to make the cable tray system withstand horizontal/vertical accelerations due to seismic forces for indoor trays and also wind load for outdoor trays in addition to normal tray cable loadings.
- 4.03.10 All erection work to be carried out under this specification shall conform to the notes and details given in Annexure-A to this specification.

## **5.00.00 SPECIFIC REQUIREMENTS - SUPPLY**

### **5.01.00 Equipment and Material**

- 5.01.01 Equipment and material shall comply with description, rating, type and size as detailed in this specification, drawings and annexures.
- 5.01.02 Equipment and materials furnished shall be complete and operative in all details.
- 5.01.03 All accessories, fittings, supports, hangers, anchor bolts etc. which form part of the equipment or which are necessary for safe and satisfactory installation and operation of the equipment shall be furnished.
- 5.01.04 All parts shall be made accurately to standard gauges so as to facilitate replacement and repair. All corresponding parts of similar equipment shall be interchangeable.

### **5.03.00 Conduits and Accessories**

- 5.03.01 The contractor shall provide and install all conduits, mild steel pipes, flexible conduits, rigid PVC pipes, etc. complete with accessories like tees, bends, adopters, locknuts, pull boxes, conduit plugs, caps, etc as required for the cabling work. Conduits shall be furnished in standard length of 5 metres, threaded at both ends.
- 5.03.02 Conduits diameter upto and including 25mm size shall be of 16 SWG and conduits above 25 mm diameter shall be of 14 SWG. Minimum diameter of conduits shall be 20 mm.
- 5.02.03 Conduits shall be made of hot-dip galvanized steel with an organic corrosion resistant ID coating. In chemical handling areas, battery room, etc., the

exterior surface shall be further coated with chromate and polymer for better resistance to corrosion. Conduits, fittings & accessories shall have ISI mark.

- 5.02.04 For sizes above 63 mm, hot dip galvanized - both on inside and outside - steel pipes with necessary fittings & accessories shall be provided and installed by the contractor. The pipes and fittings shall be of heavy duty class with relevant ISI mark.
- 5.02.05 Flexible conduits complying to relevant IS and made with bright, cold-rolled, annealed and electro-galvanized mild steel strips shall be used between embedded conduits/pipes and the motor terminals. It shall also be used between fixed conduit and any equipment with vibration or equipment requiring regular removal.
- 5.02.06 Non-metallic conduits made of HDPE outer jacket with friction-reducing permanent internal lining shall generally be used for control & instrumentation cables in some areas where cable trays do not exist and where the runs are straight ones Necessary fittings & accessories as may be required for the installation shall also be provided.
- 5.03.00 **Junction Boxes**
- 5.03.01 Technical requirement for both non-metallic type and galvanized steel Junction Boxes are given below. Unless the choice is specifically mentioned in the General / Lead Electrical Specification or elsewhere in the tender document, galvanized steel Junction Boxes shall be offered.
- 5.03.02 Non-metallic Junction Boxes
- a) Material of the Junction Boxes shall be halogen-free and silicon-free, glass fibre-reinforced polycarbonate for outdoor use and/or for cable sizes more than 50 sq.mm. Material shall be ABS/ polycarbonate for indoor use and/or for cable sizes upto 50 sq. mm. Junction boxes for use with fire-survival cables shall be of Duro-plast / powder-coated metal.
  - b) Material of all non-metallic junction boxes shall be fire retardant and self-extinguishing in accordance with UL 94 V0. It should be tested at Glow Wire test for 960° C.
  - c) Boxes shall be suitable for continuous operation at an ambient temperature range of -10° C to +80° C.
  - d) The impact strength of polycarbonate enclosures/boards i.e. the degree of protection against mechanical shock load shall be in accordance with EN 50298-98 for IK 08 (5 Joule).
  - e) Degree of protection shall be IP 66 to EN 60529. Junction boxes shall have integrally embedded gaskets made of Polyurethane.
  - f) Allowing a minimum of 20% spare terminals after complete termination, the terminal board for control and instrumentation JBs shall have 6 / 12 / 24 / 36 / 48 ways.
  - g) Doors shall have stainless steel quick fastening screws.

- h) The boxes shall be complete with all brackets/fasteners as required for installation on walls, columns and structure.

5.03.03 **Steel Junction Boxes**

- a. Junction boxes with IP 55 degree of protection, shall comprise of a rectangular parallelepiped case constructed from cold rolled sheet steel of minimum thickness 2mm. Top of the box shall be arranged to slope towards the rear of the box. Gland plate shall be 3mm thick sheet steel with neoprene/synthetic rubber gaskets. All junction boxes shall be of adequate strength and rigidity, hot dip galvanized as per relevant IS, and suitable for mounting on wall, column, structures etc. The boxes shall be complete with M8 earthing stud and all brackets/fasteners as required for installation.
- b) No. of Ways:6 / 12 / 24 / 36 / 48 with 20% spare terminals after termination.
- c) Outdoor JBs shall be similar but with a canopy at the top.
- d) Doors shall be hinged and lockable and shall be made of the same material as the case. The doors shall have industrial heavy-duty hinges. The doors shall be easily but firmly lockable with quick release fastener.

5.03.04 **The junction boxes shall have the following indelible markings:**

- Circuit nos. on top by white-stenciled paint at site.
- Circuit nos. with ferrules (inside) as per approved drawing.
- Danger sign in case of 415 V circuit.

5.04.00 **Terminals**

5.04.01 Multiway terminal blocks of approved type, complete with screws, nuts; washers and marking strips shall be furnished for connection of incoming/outgoing wires.

5.04.02 Each control cable terminal shall be suitable for connection of 2 nos. 2.5 sq.mm. stranded copper conductors without any damage to the conductor or looseness of conductors.

5.05.00 **Cable Termination & Straight Through Joints**

5.05.01 Bidder shall supply cable termination and jointing kits in requisite quantity for H.T. Power Cables, L.T. Power, Control Cables, Instrumentation Cables, etc. along with all accessories & consumables required for making termination and joints complete. Those shall be of proven design and make which have already been extensively used and type tested.

- 5.05.02 Components shall be pre-moulded type, taped type or heat-shrinkable type. 11kV, 6.6kV and 3.3kV grade joints and terminations shall be type tested as per IS: 13573.
- 5.05.03 Kits shall be complete with the aluminium solderless crimping type cable lugs and ferrule as per DIN standard.

5.06.00 **Cable Glands**

Cable shall be terminated using double compression type cable glands. Cable glands shall conform to BS 6121 or to EN 50262. Ingress Protection rating for cable glands with seal, when offered conforming to EN 50262, shall be minimum IP 66 in line with BS. Cable glands shall be made of tinned brass gland, double compression type complete with necessary armour clamp and tapered washer, etc. Rubber components shall be of neoprene or better synthetic material and of tested quality. Cable glands shall match with the sizes of different H.V./L.V./Control cables supplied/erected.

5.07.00 **Cable Lugs**

All cable lugs shall be Cd plated copper. Cable lugs shall be suitable for termination of different cross-sections of H.V./L.V./Control/Instrumentation cables and shall be of following types :

- i) Aluminium tubular terminal end for solderless crimping to aluminium conductors.
- ii) Copper tubular terminal end for solderless crimping to copper conductors.  
Solderless crimping of terminals shall be done by using corrosion inhibiting compound. The cable lugs shall suit the type of terminals provided on the equipment. Lugs for control/instrumentation cables shall be PVC insulated/sleeved type.
- iii) Cable lugs for control cable termination shall be insulated. These lugs shall be pin type/flat type/ring type/U type to suit the terminals provided in the panels.

5.08.00 **Cable Clamps and Straps**

- 5.08.01 Trefoil clamps for single core cables shall be pressure die-cast aluminium or fibre glass or nylon with necessary G I fasteners. Trefoil clamps shall have adequate mechanical strength to forces generated by peak value of maximum system short circuit current.
- 5.08.02 Cable clamps required for multicore cables on vertical run shall be made up of 25x3mm size aluminium strip. For clamping the multicore cables, self-

locking, de-interlocking type fire-resistant nylon clamps/straps of sufficient strength shall be used.

5.09.00 **Consumables and Hardware**

5.09.01 The Bidder shall furnish all erection materials, hardware and consumables required to complete the installation.

5.09.02 The materials shall include but not be limited to the following :

Consumables : Welding rods & gas, oil and grease, cleaning fluids, paints, electrical tape, soldering materials etc.

Hardware : Bolts, nuts, washers, screws, brackets, supports, clamps, hangers, saddles, cleats, sills, shims etc.

5.09.03 Supply of cement, sand, stone etc. required for the execution of the contract shall be the responsibility of the Bidder.

5.10.00 **Testing Equipment**

5.10.01 The major testing equipment that are required to be arranged by the Bidder for site testing are listed below:

a) **Insulation Tests**

i) Power operated Meggar - 1 KV and 10 KV grade

ii) Hand operated Meggar - 1 KV grade

b) Hand driven earth Resistance Meggar, range 0-1/3/30 ohms.

c) High potential testing set - roller mounted type

d) Tong testers of suitable ranges.

e) Contact resistance measuring set for micro-ohms.

f) Torque wrench of various sizes.

g) Multi meters, test lamp, field telephone with buzzer set, different gauges etc.

5.10.02 The list of equipment is indicative only. Any other test equipments required shall be arranged by the Bidder.

6.00.00 **METHODS AND WORKMANSHIP**

6.01.00 All work shall be installed in a first class, neat workmanlike manner by mechanics/electricians skilled in the trade involved.

6.02.00 The erection work shall be supervised by competent supervisors holding relevant supervisory license from the Government.

6.03.00 All details on installation shall be electrically and mechanically correct.

- 6.04.00 The installation shall be carried out in such a manner as to preserve access to other equipment installed.
- 7.00.00 INSTALLATION**
- 7.01.01 Installation work shall be carried out in accordance with good engineering practices and also as per manufacturer's instructions/ recommendations where the same are available.
- 7.01.02 Equipment shall be installed in a neat workmanlike manner so that it is level, plumb, square and properly aligned and oriented.
- 7.01.03 Cable installation work shall mean erection of cable trays/racks, supports, hangers, junction boxes, conduits, laying of cables either in ground or on trays inside trenches tunnels/overhead trays in conduits etc. dressing and clamping, jointing and termination inclusive of supply of necessary jointing/termination kits, lugs, glands, ferrules, tapes etc. and other accessories, grounding of cable armour. In case of direct laying in ground, all excavation work, necessary back-filling, supply of bricks and protective concrete slabs, removal of excess earth shall be part of the installation work.
- 7.01.04 Grounding installation work shall mean erection, jointing/brazing/welding, connection and painting, testing of ground conductors including supply of necessary steel/copper.
- 7.01.05 Lightning protection system installation work shall mean erection, jointing, welding, connection and painting, testing of air termination network, down conductors, shielding masts, connection to ground grid, electrodes, risers, horizontal conductors etc. of lightning protection system.
- 7.02.00 Cable Trays**
- 7.02.01 Pre-fabricated cable trays and accessories shall be assembled & erected at site. Adequate spaces shall be provided to facilitate installation of cable system and to allow routine inspection and modification after installation.
- 7.02.02 Cable trays either inside concrete trenches or inside buildings and racks inside cable shafts shall be aligned and leveled properly. All tray runs shall be installed parallel to the trench/building walls and floors except otherwise noted in the approved drawings.
- 7.02.03 As far as practicable, cable trays shall be supported from one side only in order to facilitate installation and maintenance of cables from the other side.
- 7.02.04 The cable trays shall be supported in general at a span of not exceeding 1.5 metres horizontally and 1.0 metre vertically.
- 7.02.05 Sufficient spacing not less than 250 mm shall be provided between trays and maintained to permit adequate access, for installing & maintaining the cables..



## 2x500 MW NLC Tamil Nadu Power Ltd. Tuticorin, Tamil Nadu

- 7.02.06 Complete cable tray support structure after installation shall be inspected/ tested for welding strength, straightness, accuracy, use of proper sizes and compliance to drawings.
- 7.02.07 Complete cable tray and accessory installation work shall be inspected/ tested for proper alignment, leveling, use of proper accessories, high quality workmanship etc.
- 7.02.08 The Bidder shall remove the RCC/steel trench covers whenever required and shall again place the same in their positions after the erection work in the particular area is completed or when further work is not likely to be taken up for some time.
- 7.02.09 Whenever any pipe/conduit/cable tray emerges out or enters into a building care should be taken to ensure that no water enters into the building.
- 7.02.10 Cable trays in areas subject to excessive coal dust, oil spillage, mechanical damage or accessible to personal contact shall be provided with raised sheet metal tray covers, installed on upper tray in horizontal run and front in vertical run.
- 7.02.11 Cable trays/racks shall be so arranged that they do not obstruct or impair clearances of passage way.
- 7.02.12 Cable tray/conduit system shall be so designed as to accommodate maximum pulling tension and minimum bending radius of cable.
- 7.02.13 Cable tray/conduit system shall be constructed to prevent drainage of water into equipment or building.
- 7.02.14 Cable tray/conduit system shall be electrically continuous and grounded.
- 7.02.15 Different voltage grade cables shall be laid in separate trays when trays are run in tier formation. Power cables shall normally be on top trays and control/instrumentation cable on bottom trays.
- 7.02.16 Trenches
- i) PCC flooring of built up trenches shall be sloped for effective drainage with sump pits and sump pumps.
  - ii) No subzero level cable vault/trenches shall be provided below control building/switchgear rooms in FGD areas.
- 7.03.00 **Cable and Conduits**
- 7.03.01 The Bidder shall install, terminate and connect up all cable and conduits as per drawings and cable schedules.



- 7.03.02 The drawings shall be strictly followed except where obvious interference occurs. In such cases, the routing shall be changed as directed and/or approved by the Engineer.
- 7.03.03 Approximate lengths of cable and conduit runs shall be shown by the Bidder in the cable schedule for guidance only. Before commencement of work the Bidder shall take actual measurements and prepare his own cable-cutting schedule to reduce wastage to a minimum.
- 7.03.04 The Bidder shall also maintain and submit when requested, a record of cable insulation value when drawn from store, after laying, before and after termination/jointing.
- 7.03.05 Where direct heat radiation exists, heat isolating barriers, shall be adopted for cabling system.
- 7.03.06 Cabling/wiring in offices, laboratories, control rooms etc. shall be taken through concealed G.I. or rigid PVC pipes as directed by the Owner's Engineer.
- 7.03.07 At certain places where hazardous fumes/gasses may cause fire to the cables, cable trenches after installation of cables shall be sand filled.
- 7.04.00 **Conduit and Accessories**
- 7.04.01 Conduit/pipes shall be used only in short lengths in certain areas where required and/or as directed by the Engineer.
- 7.04.02 The Bidder shall furnish all conduits complete with accessories as required.
- 7.04.03 Conduits shall be flexible type in general. However, rigid type steel conduit if required shall also be supplied by the Bidder.
- 7.04.04 Except for inside an enclosure wherever the cable enters or leaves the conduit, the conduit end shall be sealed by suitable sealing compound, having fire withstand capability.
- 7.04.05 The entire metallic conduit system, when embedded or exposed shall be electrically continuous and grounded.
- 7.04.06 Where it is possible for water or other liquids to enter conduits, sloping of conduit runs and drainage of flow points shall be considered.
- 7.04.07 Pull boxes shall be installed between termination points where required to facilitate cable pulling, but at a maximum interval of 30 meters.
- 7.04.08 Conduits shall be firmly fastened within 900 mm of each junction box/pull box/cabinet/fitting etc. Conduits shall be supported at least every 2000 mm.
- 7.05.00 **Cables: Storage and Handling**

- 7.05.01 Cable drums shall be stored on hard and well-drained surface so that they may not sink. In no case shall the drum be stored on the flat, i.e., with flange horizontal.
- 7.05.02 Rolling of drums shall be avoided as far as practicable, for short distance, the drums may be rolled provided they are rolled slowly and in proper direction as marked on the drum.
- 7.05.03 In absence of any indication, the drums may be rolled in the same direction as it was rolled during taking up the cable.
- 7.05.04 For unreeling the cable, the drum shall be mounted on jacks or on cable wheel. The spindle shall be strong enough to carry the weight without bending.
- 7.05.05 The drum shall be rolled on the spindle slowly so that the cable should come out over the drum and not below the drum.
- 7.05.06 While laying cable, cable rollers shall be used at an interval of 2000 mm. The cables shall be pushed over the roller by a gang of people positioned in between rollers over a suitable distance. Care shall be taken so that kinks and twists or any mechanical damage does not occur in cables. Only approved cable pulling grips or other devices shall be used. Cables shall not be dragged on ground or along structure while laying out from cable drums.
- 7.05.07 Cable shall not be pulled from the end without having intermediate pushing arrangement. Bending radius of the cable during installation shall not be less than what is specified by the manufacturer.
- 7.05.08 Empty cable drums shall be returned to the Owner.
- 7.06.00 **Cable Laying**
- 7.06.01 Cable shall generally be installed in ladder type prefabricated trays except for some short run in rigid/flexible conduit for protection or crossings.
- 7.06.02 Cables laid on trays and risers shall be neatly dressed and clamped with self-locking type fire resistant nylon ties at an interval of 750 mm for horizontal and vertical runs, in case of both power, control and instrumentation cables.
- 7.06.03 All single core power cables for 3 Ph. AC circuits shall be laid in trefoil formation and suitably clamped with self-locking type fire resistant nylon ties at an interval of 750mm.
- 7.06.04 L.T. multicore power cables with cross-sectional area of 95 sq.mm and above and all H.T. multicore power cables and shall be clamped individually by self-locking type fire resistant nylon ties.
- 7.06.05 L.T. power cables of cross sectional area less than 95 sq.mm and all control and Instrumentation cables shall be clamped in bunches with self-locking type fire resistant nylon ties. The number of cable in one bunch shall not exceed eight (8).

- 7.06.05 Prior to laying of cables inside the indoor and outdoor trenches, the Bidder shall properly clean the trenches.
- 7.06.06 In outdoor areas, buried cables shall be laid and covered with sand/riddled earth and protected from damage by bricks at sides and precast slab at top.
- 7.06.07 When buried cables cross road/railway track, adequate protection shall be provided in the form of hume/ galvanised iron pipes laid at a minimum depth of 1 meter below ground.
- 7.06.08 After completion of installation and prior to connection, all power cables shall be subjected to a high potential test.
- 7.07.00 **Cable Fire Sealing**
- 7.07.01 Cable/cable tray openings in walls and floors or through pipe sleeves from one area to another or from one elevation to another within the unit shall be sealed by a fire proof sealing system (FPSS) of minimum 2 Hrs rating. The FPSS shall effectively prevent the spread of fire from the flaming to non-flaming side of a fire.
- 7.07.02 Wherever the cables/cable trays pass through walls/floors, fire proof cable penetration seals rated for two hour shall be provided. This shall be by suitable block system using individual blocks with suitable framework or by silicon RTV foaming system. In case foaming system is offered, damming board, if used, shall not be considered for fire rating criteria. Any of the system offered shall be of proven type as per BS: 476 (Part-20) or equivalent standard.
- In order to prevent fire propagation through cable penetrations, after laying, dressing & clamping of cables, all the openings shall be properly sealed by using Fire Stop Mortar Seal and Fire Retardant Cable coating compound. Also the cable runs both before and after the fire scale shall be suitably sprayed with anti-fire propagation liquid.
- 7.08.00 **Cable Laying in Trenches**
- 7.08.01 RCC cable trenches with removable covers shall be provided by the Contractor. Cables shall be laid in 3 or 4 tiers in these trenches RCC covers of trenches in process area shall be effectively sealed to avoid ingress of chemicals etc. Removal of concrete covers for purposes of cable laying and reinstating them in their proper positions after the cables are laid shall be done by the Contractor at no extra cost.
- 7.08.02 For cable trays are laid in trench in more than two tiers a space of minimum 600 mm shall be available for maintenance. In case two or more tiers of cable trays are running parallel along both sides of trench walls there shall be space of minimum 600 mm between them.

- 7.08.03 Cables shall be handled carefully during installation to prevent mechanical injury to the cables. Ends of cable leaving trenches shall be coiled and provided with a protective pipe or cover till such times the final termination to the equipment is completed.
- 7.08.04 Prior to laying of cables inside both indoor and outdoor trenches, the Contractor shall properly clean inside of those trenches.
- 7.08.05 When cables are laid in multiple tiers, spacing between individual tiers shall be as approved by Site Engineer.
- 7.08.06 As each row of cables is laid in place every cable shall be given on insulation test in the presence of Site Engineer. Any cable, which proves defective, shall be replaced before the next groups of cables are laid.
- 7.08.07 All wall openings/pipe sleeves shall be effectively sealed after installation of cables to avoid seepage of water inside building/lined trench.
- 7.08.08 Where cables rise from trenches to motor, control station, lighting panels etc., they shall be taken in G.I. Pipes for mechanical protection up to a minimum of 150mm above grade.
- 7.08.09 Cable ends shall be carefully pulled through the conduit, to prevent damage to these cables. Where required, approved cable lubricant shall be used for this purpose. Where cable enters conduit the cable should be bent in large radius. Radius shall not be less than the recommended bending radius of the cables specified by the manufacturer.
- 7.08.10 Following guide of the pipe fill shall be used for sizing the pipe size:-
- a) 1 cable in pipe - 53% full
  - b) 2 cables in pipe - 51% full
  - c) 3 or more cables - 40% full
- 7.08.11 After the cables are installed and all testing is complete, conduit ends above grade shall be plugged with a suitable weatherproof plastic compound/'PUTTI' for sealing purpose. Alternatively G.I. Lids or PVC bushes shall be employed for sealing purposes. The cost for the same shall be deemed to have been included in the installation of G.I. pipe and no separate payment shall be allowed.
- 7.08.12 Where cables pass through foundation walls or other underground structures, the necessary ducts or openings shall be provided in advance for the same. However, should it become necessary to cut holes in existing foundations or structures, the electrical Contractor shall determine their location and obtain approval of the Site Engineer before cutting is done.
- 7.09.00 **Cable Tags & Markers**

- 7.09.01 Each cable and conduit run shall be tagged with numbers that appear in the cable and conduit schedules. Cables and conduits shall be tagged at their entrance, bends, every 30.0M and exit from any equipment, junction box. When a cable/conduit passes through a wall, tags shall be fitted on both sides of the wall.
- 7.09.02 The tags shall be of aluminium with the number punched on it and securely attached to the cable by not less than two turns of 16 SWG G.I. wire. For single core cable the wire shall be of non-magnetic material.
- 7.09.03 Location of cable joints, if any, shall be clearly indicated with cable marker with an additional inscription 'cable-joint'.
- 7.09.04 Contractor shall furnish and install all tags and markers stated above.
- 7.09.05 For buried cable, the marker shall project 150 mm above ground and shall be spaced at an interval of 30 meters and at every change of direction.
- 7.10.00 Cable Termination and Connection**
- 7.10.01 Termination and connection of cables shall be done strictly in accordance with manufacturer's instruction, drawings and/or as directed by the Engineer.
- 7.10.02 Work shall include all clamping, fitting, fixing, soldering, tapping, compound filling, cable jointing, crimping, shorting and grounding as required for the complete job. All equipment required for all such operations shall be of Contractor's procurement. Furnishing of all consumable materials such as soldering material, electrical tape, sealing material as well as cable jointing kits shall be included in the offer.
- 7.10.03 Cable joint kits for all cables shall be supplied by Contractor under this specification. Responsibility for proper termination shall lie on the contractor. Guarantee for termination shall also have to be given by Contractor.
- 7.10.04 The equipment will be generally provided with blank bottom plates for cable/conduit entry and cable end box for power cables.
- 7.10.05 The bidder shall perform all drilling, cutting on the blank plate and any minor modification work required to complete the job.
- 7.10.06 If the cable end box or terminal enclosure provided on the equipment is found unsuitable and requires major modification, the same shall be carried out by the contractor.
- 7.10.07 Control/instrumentation cable cores entering control panel/ switchgear/ MCC, etc. shall be neatly bunched and served with PVC perforated tape to keep it in position at the terminal block.
- 7.10.08 The bidder shall put ferrules on all control cable cores in all junction boxes and at all terminations. The ferrules shall carry terminal numbers as per drawings. All ferrules shall be coloured, plastic & interlocked type.

- 7.10.09 Spare cores shall be similarly ferruled, crimped with lug and taped on the ends. Spare cores shall be ferruled with individual cable number.
- 7.10.10 Termination and connection shall be carried out in such a manner as to avoid strain on the terminals.
- 7.10.11 All cable entry points shall be properly sealed and made vermin and dust proof. Unusual opening, if any, shall be effectively closed. Sealing work shall be carried out with approved sealing compound having fire withstand capability for at least three hours.
- 7.10.12 Strips and special tools like manually or pneumatically driven gun/pistol for termi point/equivalent connection shall be supplied by the Contractor.
- 7.11.00 **Cable Joints**
- 7.11.01 Cable shall be installed without joints as far as practicable.
- 7.11.02 If however jointing becomes necessary, it shall be made only by qualified cable joiner and strictly in accordance with manufacturer's recommendation.
- 7.12.00 **Grounding**
- 7.12.01 The Bidder shall carry out the interconnection among various peripheral earthing grids/mats, steel structures, lightning protection system as well as grounding of all electrical equipment, etc. The grounding work shall be carried out as per provisions of I.E. rules Indian standards and enclosed grounding and lightning protection notes and details.
- 7.12.02 Grounding shall be done by conductors of adequate sizes (size shall be selected by the bidder with supporting calculation, if not specified) and the same shall be connected to the risers of main ground mat.
- 7.12.03 For fabricated cable trays, a separate ground conductor (50x6 mm G.S. flat) shall run along the entire length of each route of cable tray being suitably clamped on the cable tray. Individual cable trays of each section shall be connected to above ground conductor through 50x6 mm G.S. flat to maintain continuity of ground path.
- 7.12.04 All ground conductor connections shall be made by electric arc welding/ brazing unless otherwise specified. Ground connections shall be made from nearest available station ground grid risers. The rods/connection shall be coated with cold galvanizing /weather resistance anti corrosive paints.
- 7.12.05 All ground conductors shall be painted black for easy identification.
- 7.12.06 Equipment ground connections, after being checked and tested by the Engineer, shall be coated with anti-corrosive paint.

7.17.02 Upon completion of work, the Bidder shall remove all rubbish, tools, scaffoldings, temporary structures and surplus materials etc. to leave the premises clean and fit for use.

## **8.00.00 TESTS**

### **8.01.00 Shop Tests**

8.01.01 All equipment shall be completely assembled, wired, adjusted and routine tested as per relevant Indian Standards at manufacturer's works.

8.01.02 Tests on panels/junction boxes shall include:

- a) Wiring continuity tests.
- b) High voltage and insulation tests.
- c) Operational tests.

### **8.02.00 Site Tests**

8.02.01 Bidder shall thoroughly test and meggar all cables, wires and equipment to prove the same are free from ground and short circuit.

8.02.02 If any ground or short circuit is found, the fault shall be rectified or the cable and/or equipment replaced.

8.02.03 All power cables after installation and prior to connections shall be subjected to High Potential tests. Also the insulation resistance values shall be measured both before and after Hipot test for comparison. The leakage current shall also be measured during the Hipot test at site.

Cable cores shall be tested for:

- a) Physical damage
- b) Continuity
- c) Correctness of connections as per relevant wiring diagram
- d) Insulation resistance to earth
- e) Insulation resistance between conductors
- f) Proper earth connections of cable glands, cable boxes, cable armour, screens etc.

8.02.04 All equipment shall be demonstrated to operate in accordance with the requirements of this specification.

### **8.03.00 Test Certificates**



8.03.01 Type test certificate on any equipment, if so desired by the Owner, shall be furnished. Otherwise the equipment shall have to be type tested, free of charge, to prove the design.

**9.00.00 DRAWINGS, DATA & MANUALS**

**9.01.00 To be submitted with the Bid**

9.01.01 Make, type and catalogue number of different electrical items and accessories along with technical leaflets, data sheets etc.

9.01.02 Typical General arrangement drawings showing constructional features, fixing arrangement of pre-fabricated cable trays.

9.01.03 Bill of Materials for cable trays and accessories, conduits & accessories.

9.01.04 Layout of Grounding system and lightning protection system showing connection and other details along with backup design calculations and detailed write up.

9.01.05 Bill of materials for grounding and lightning protection system.

9.01.06 Drawing showing details of equipment grounding.

**9.02.00 To be submitted after Award of Contract**

9.02.01 Make, type and catalogue number of cable termination kits, joints and accessories.

9.02.02 Detail dimensional drawings showing constructional features, grounding, fixing arrangement etc.

9.02.03 Bill of Materials for Pre-fabricated cable tray and accessories, Conduits & accessories.

9.02.04 Dimensional G.A. drawings and data sheets for different equipment and items supplied under this specification.

9.02.05 Layout drawing of Grounding system and Lightning protection system showing connection details along with backup design calculation and detailed write up.

9.02.06 Bill of material for grounding system and lightning protection system.

9.02.07 Drawing showing details of equipment grounding system.



**NOTES AND DETAILS  
FOR  
CABLING SYSTEM**

**1.00.00 GENERAL**

1.01.00 These notes and details shall be read and construed in conjunction with Specification and the drawings meant for cable tray details and supporting arrangements in Trench, Racks etc., enclosed elsewhere. In case of conflict between these notes and drawings, the latter shall prevail.

1.02.00 The Cabling System installation work shall conform to the requirements of the latest revisions of the following standards/codes

- a) Indian Electricity Rules, 1956, with up to date amendment.
- b) I.S. Code of Practice

**2.00.00 CABLE ROUTING/LAYING**

2.01.01 Cables shall generally be laid on ladder type cable trays either in trenches or overhead supported from building steel/structures except in some cases cables may have to be laid underground and for short runs in conduits for protection or crossing.

2.01.02 For interplant connections, the cables may be routed through an overhead cable bridge or cable trenches/tunnels selection being dependent on site constraints. Directly buried cable shall be avoided as far as possible. Owner's prior approval shall be taken for exceptional cases, where buried cables cannot be avoided.

2.01.03 For underground crossing of railways, roads etc. hume pipes shall be used and shall be laid at a depth of minimum 1000 mm such that cables shall not be damaged.

2.01.04 The cable racks in dust prone areas shall be supported from available structure in vertical configuration with suitable cover to avoid deposition of lignite dust as far as practicable.

2.01.05 Different voltage grade cables shall be laid in separate trays when trays are arranged in tiers. Power cables shall be on top trays and Control/Instrumentation cables on bottom trays, and it is recommended that trays for cables of different voltage levels be stacked in descending order with higher voltage level above.

2.01.06 Cables for redundant equipment/system shall be run in separate trays in separate route.

- 2.01.07 Cables from two different services viz. supply from station board and supply from unit board shall be fully segregated to prevent simultaneous damage due to fire in one of the services.
- 2.01.08 Low level signal cables and other special Instrumentation and Control cables shall run in separate trays. In general, a minimum of 1500 mm clearance shall be maintained between these cables and noise generating equipment (large motors, generators, transformers etc.).
- 2.01.09 The cable spreaders of each unit shall be compartmentalized by provision of fire proof partition wall.
- 2.01.10 The floor of the cable spreader rooms shall have to be made water proof so that water does not percolate to lower levels in the event of fire fighting operations. Adequate arrangement for efficient drainage of water shall be provided. The cable raceways should also be suitably curved to avoid water entry through this place.
- 2.02.00 **Cable Trays/Supports**
- 2.02.01 Cable trays and covers shall be pre-fabricated type, constructed from minimum 14 SWG sheet steel for trays and 16 SWG for covers and hot-dip galvanized after fabrication.
- 2.02.02 Cable tray supports shall be cantilever type for each installation. All supports and hardware shall be hot-dip galvanized. Support shall be fixed with bolts and no welding shall be done on the galvanized parts.
- 2.02.03 Standard cable tray width shall be 600 mm. However, trays with 450, and 300, 150 mm width may be used in some places considering the requirement and space restrictions. For instrumentation and control purpose, some perforated type cable trays of width 150 and/or 100mm may be used particularly in low space area and 600, 450, 300 mm perforated trays may be used depending on site requirement.
- 2.02.04 Cable trays shall be ladder type with 250 mm rung spacing, 100 mm depth and rung width not less than 50 mm.
- 2.02.05 All weld for cable tray supports shall have a minimum throat thickness of 6 mm.
- 2.02.06 Cable trays in areas subjected to excessive lignite dust, or mechanical damage shall have hot-dip galvanised sheet metal tray cover installed on front tray in vertical run and inverted 'V' type on upper tray in horizontal run.
- Where covers are used on trays containing power cables, consideration should be given to ventilation requirements. Areas where corrosive chemicals are likely to be handled, cable tray and covers shall be epoxy painted.
- 2.03.00 **Conduits**

- 2.03.01 Conduits shall be rigid steel coated type; minimum size of conduit shall be limited to 19mm.
- 2.03.02 Steel conduits with interior coating of silicon epoxy ester for ease of wire pulling shall be seamed by welding and flo-coat metal conduit/hot-dip galvanized. These shall be supplied in standard length of 5M with minimum wall thickness as specified in IS: 9537 Part-II. In chemical handling areas, Battery room etc., the exterior surface shall be further coated with chromate and polymer for better resistance to corrosion.
- 2.03.03 Conduit runs shall be supported at an interval of 750 mm for vertical run and 1000 mm for horizontal run.
- 2.03.04 Conduits shall be sized so that conduit fill (ratio of total cable area to conduit area) shall not exceed the following:
- |                   |   |     |
|-------------------|---|-----|
| One Cable         | : | 53% |
| Two Cable         | : | 31% |
| Three Cables & Up | : | 40% |
- 2.03.05 Conduit runs shall be provided with necessary bends as required.
- 2.04.00 **Installation**
- 2.04.01 The Bidder shall install, terminate and connect up all cables and conduits with supporting arrangements as per drawings, cable schedules and interconnection chart/drawings.
- 2.04.02 The HV power cables of 11 KV/3.3 KV shall be laid in trays or racks as follows:
- a) In single layer only.
  - b) 3 core cables to be laid giving one diameter gap of the largest diameter adjacent cable.
  - c) Single core cables to be laid in trefoil formation with a spacing equal to diameter of the trefoils.
- 2.04.03 1100V grade power cables shall be laid in single layer in trays.
- 2.04.04 1100V grade power cable shall be laid giving one diameter gap of the largest diameter adjacent cable.
- 2.04.05 Control and Instrumentation cables can be laid up to a maximum of three layers in each tray.
- 2.04.06 The trays shall be run with a vertical spacing of 300 mm for overhead cable trays as well as inside cable trenches. A minimum of 225 mm clearance shall be provided between the top of tray and beams, cold piping, 500 mm clearance for hot piping/object to facilitate installation of cables in tray.

- 2.04.07 Adequate pull boxes shall be provided in conduit run to facilitate cable pulling in long runs and also to ensure that there shall be no more than 270 Deg. bends between pull points.
- 2.04.08 Cable tray/conduit system shall be installed to accommodate cable manufacturer's recommended maximum pulling tension and minimum bending radius.
- 2.04.09 All openings in the floor and wall for cable access shall be sealed after installation of the cable system with non-inflammable materials, as follows:
- i) Fire stop/Penetration seal shall be installed in the cable spreaders and cable raceways.
  - ii) Similarly in the trenches fire stop/penetration seals shall be provided at suitable interval to avoid spread of fire.
  - iii) For all H.V., L.V., Relay and Control panels, Control desk, instrumentation panels, battery charger, D.C. Dist. boards and other miscellaneous panels, fire-stops should be provided below base plate.
- 2.04.10 All floor/wall openings for cable entry to the electrical equipment and accessories shall be sealed with non-inflammable materials, after completion of cable installation. Thickness of such materials shall be equal to the thickness of floor/wall unless specified otherwise.
- 2.04.11 The portion of galvanized steel, which, if required, undergoes any welding at site shall be coated with two (2) coats of cold galvanizing anti-corrosive paint after welding.
- 2.04.12 The cables shall be coated with fire protection coating as specified elsewhere.
- 2.05.00 **Identification**
- 2.05.01 The complete cabling system shall be properly identified. Methods for identification of cabling system shall be furnished to the successful tenderer and the Bidder shall strictly adhere to the said methods.
- 2.05.02 Each cable and conduit run shall be tagged with numbers that appear in the cable and conduit schedule.
- 2.05.03 Location of cables laid directly underground shall be clearly indicated with cable marker made of galvanized iron plate, projected above ground level.
- 2.05.04 Cable tags shall be provided on all cables at each end (just before entering the equipment enclosure), on both sides of a wall or floor crossing, on each duct/conduit entry, at each bend and at every thirty (30) metres in cable tray/trench runs. Cable tags shall also be provided inside the switchgear, MCC, control & relay panels etc. wherever required for cable identification, such as where a number of cables enter together through a gland plate.

672753/2022/PS-PEM-MSE :



**ELECTRICAL EQUIPMENT SPECIFICATION  
FOR  
MISCELLANEOUS PUMPS  
2x500 MW NLC Tamil Nadu Power Ltd.**

SPECIFICATION NO.

VOLUME NO. : **II-B**

SECTION :

REV NO. **00** : DATE : 21.07.2021

SHEET : 1 OF 1

**DATASHEET-A**

ANNEXURE-I

- |      |                                                                  |                                          |                                                                                      |
|------|------------------------------------------------------------------|------------------------------------------|--------------------------------------------------------------------------------------|
| 1.0  | Design ambient temperature                                       | :                                        | 50 °C                                                                                |
| 2.0  | Maximum acceptable kW rating of LV motor                         | :                                        | 160 KW *                                                                             |
| 3.0  | Installation (Indoors/ Outdoors)                                 | :                                        | As required                                                                          |
| 4.0  | Details of supply system                                         |                                          |                                                                                      |
|      | a)                                                               | Rated voltage (with variation)           | : 415V ± 10%                                                                         |
|      | b)                                                               | Rated frequency (with variation)         | : 50 Hz + 5 % to - 5%                                                                |
|      | c)                                                               | Combined voltage & freq. variation       | : 10% (sum of absolute values)                                                       |
|      | d)                                                               | System fault level at rated voltage      | : 50 kA for 1 sec                                                                    |
|      | e)                                                               | Short time rating for terminal boxes     |                                                                                      |
|      |                                                                  | o Above 90 kW (Breaker Controlled)       | : 50 KA for 0.25 sec.                                                                |
|      |                                                                  | o 90 kW and below (Contactor Controlled) | : 50 KA protected by HRC fuse                                                        |
|      | f)                                                               | LV System grounding                      | : Solidly                                                                            |
| 5.0  | Winding & Insulation                                             | :                                        | Class F with temp rise limited to class B                                            |
| 6.0  | Minimum voltage for starting<br>(As percentage of rated voltage) | :                                        | 80%                                                                                  |
| 7.0  | Power cables data                                                | :                                        | Shall be given during detailed engg.                                                 |
| 8.0  | Earth Conductor Size & Material                                  | :                                        | Shall be given during detailed engg.                                                 |
| 9.0  | Space heater supply (for motors >=30kw)                          | :                                        | 240 V, 1ϕ, 50 Hz                                                                     |
| 10.0 | Rating up to which Single phase motor                            | :                                        | Acceptable below 0.2 kW                                                              |
| 11.0 | Locked rotor current                                             |                                          |                                                                                      |
|      | a)                                                               | Limit as percentage of FLC               | : As per IS 12615                                                                    |
| 12.0 | Makes                                                            | :                                        | BHEL/ Customer approval (Package owner to take care)                                 |
| 13.0 | Paint shade                                                      | :                                        | Blue (RAL 5015) – Corrosion proof                                                    |
| 14.0 | Degree Of protection for motor/ terminal box                     | :                                        | Degree of protection for various enclosures as per IEC60034-05 shall be as follows:- |
|      | i)                                                               | Indoor motors - IP 23                    |                                                                                      |
|      | ii)                                                              | Outdoor motors - IP 55                   |                                                                                      |
|      | iii)                                                             | Cable box-indoor area - IP 23            |                                                                                      |
|      | iv)                                                              | Cable Box-Outdoor area - IP 55           |                                                                                      |

**\* LT motors of continuous duty shall be energy efficient IE3 class conforming to IS-12615**

15.0 TESTING REQUIREMENTS: IN LINE WITH SPECIFICATION

672753/2022/PS-PEM-MSE



FILE:  
**TECHNICAL SPECIFICATION  
MISCELLANEOUS PUMPS**  
**SPECIFIC TECHNICAL REQUIREMENTS**

SPEC. NO.: <b>PE-TS-483-100-N001</b>		
SECTION: <b>I</b>		
SUB-SECTION: <b>ID</b>		
REV. NO. <b>01</b>	DATE	<b>03.02.2022</b>
SHEET <b>1</b>	OF	<b>1</b>

**SUB-SECTION – IC**  
**SPECIFIC TECHNICAL REQUIREMENTS (C&I)**

672753/2022/PS-PEM-MSE



FILE:  
**TECHNICAL SPECIFICATION  
MISCELLANEOUS PUMPS**  
  
**SPECIFIC TECHNICAL REQUIREMENTS**

SPEC. NO.: <b>PE-TS-483-100-N001</b>		
SECTION: <b>I</b>		
SUB-SECTION: <b>ID</b>		
REV. NO. <b>01</b>	DATE	<b>03.02.2022</b>
SHEET <b>1</b>	OF	<b>1</b>

**SUB-SECTION – ID**  
**DATASHEET-A**

672753/2022/PS-PEM-MSE

DATA SHEET - A

SPECIFICATION NO.:  
PE-TS-483-100-N001, REV-01

MISCELLANEOUS PUMPS (HORIZONTAL)		SECTION : I D	
		REV: 01, DATED 03.02.2022	
PROJECT		NTPL 2X500 MW TUTICORIN -FGD PROJECT	
Sl. No.	DESCRIPTION	DMCW PUMPS	ACW PUMPS
		HORIZONTAL PUMPS	HORIZONTAL PUMPS
<b>1.0</b>	<b>SERVICE</b>		
1.1	Total number of Pumps for Project	3	3
1.2	Number of working(W) & Standby(S) pumps	2W+1S	2W+1S
1.3	Liquid Handled (refer water analysis enclosed herein)	pH corrected DM Water	Desalinated water
1.4	Location (Indoor / Outdoor)	Outdoor	Outdoor
1.5	Duty	Continuous	Continuous
1.6	No. of pumps working in parallel	2	2
1.7	Specific gravity	1	1
1.8	System design pressure (kg/sq. cm), g	10	7.5
<b>2.0</b>	<b>DESIGN PARAMETERS</b>		
2.1	Design/Rated capacity each, M <sup>3</sup> /hr	73	73
2.2	Total dynamic head (MWC) at Rated capacity	76	28
2.3	Suction Pressure(MWC)	8	Flooded suction
2.4	Design Temperature (°C)	60	60
2.5	Maximum permissible speed of pump (RPM)	1500	1500
2.6	Max. limit on shut off head Corresponding to pump TDH (MWC) at 51.5 Hz	Not to exceed 90 MWC	Not to exceed 40 MWC
2.7	Operating range	-----30-130% of design duty point flow-----	
2.8	Motor rating	Continuous Motor rating (at 50 deg. C ambient) shall be maximum of following: 1) 15% margin over the pump shaft input power at the rated duty point. 2) 5% margin over the maximum pump shaft input power over the entire characteristic curve of pump. 3) Pump shaft input pwer required considering the overloading of the pump assuming the single pump operation, in the event of tripping of one or more of the pump(s) operating in parallel.	
2.9	Permissible tolerance in rated capacity & TDH	no negative tolerance	
2.10	Permissible tolerance in efficiency at rated capacity(%)	no negative tolerance	
2.11	Performance/Design Standard	HIS	
<b>3.0</b>	<b>CONSTRUCTION FEATURES</b>		
3.1	Pump type	Horizontal centrifugal type	Horizontal centrifugal type
3.2	Impeller type	Closed	Closed
3.3	Casing type	To be decided by bidder	To be decided by bidder
3.4	Coupling type	Flexible Spacer type	Flexible Spacer type
3.5	Sealing arrangement	Gland packing initially & Mechanical seal finally after commissioning	Gland Packing
3.6	Type of Lubrication	Grease / Self Liquid	Grease / Self Liquid
3.7	Pump characteristics	Non Overloading type & stable	Non Overloading type & stable



672753/2022/PS-PEM-MSE

DATA SHEET - A

SPECIFICATION NO.:  
PE-TS-483-100-N001, REV-01

MISCELLANEOUS PUMPS (HORIZONTAL)		SECTION : I D	
		REV: 01, DATED 03.02.2022	
PROJECT		NTPL 2X500 MW TUTICORIN -FGD PROJECT	
Sl. No.	DESCRIPTION	DMCW PUMPS	ACW PUMPS
3.8	Drain Connection with Valve, Vent with 3-way Isolating Valve, lifting lugs, priming connection with 3-way SS Isolating Valve, coupling guard, Positioning dowels, Companion flanges with nuts, bolts & gaskets, Gland Sealing and Cooling Arrangement, Bearing Lubrication and Cooling Arrangement, Eye-bolts, Lifting Tackle etc.	Required	Required
<b>4.0</b>	<b>MATERIALS OF CONSTRUCTION</b>		
4.1	Casing	2% Ni Cl to IS: 210 Gr FG-260	2% Ni Cl to IS: 210 Gr FG-260
4.2	Impeller	ASTM – A351 – CF8M	ASTM – A351 – CF8M
4.3	Shaft	SS AISI-410/EN-8	SS AISI-410/EN-8
4.4	Shaft Sleeves	Hardened Stainless steel	Hardened Stainless steel
4.5	Diffuser	Fabricated CS as per IS 2062	Fabricated CS as per IS 2062
4.6	Impeller Wearing rings	SS 316	SS 316
4.7	All Fasteners	SS 304	SS 304
4.8	Gland	2% Ni Cl to IS: 210 Gr FG-260	2% Ni Cl to IS: 210 Gr FG-260
4.9	Lantern Ring	SS 316	SS 316
4.10	Mechanical seal	Manufacturer standard	NA
4.11	Gland Packing	Teflon Impregnated (Asbestos Free)	Teflon Impregnated (Asbestos Free)
4.12	Base Plate	MS fabricated IS-2062 (min. thk.-10 mm) Epoxy Coated	
4.13	Stuffing Box	2% Ni Cl to IS: 210 Gr FG-260	2% Ni Cl to IS: 210 Gr FG-260
4.14	Casing Wearing rings (If applicable)	SS 316	SS 316
4.15	Coupling	CI	CI
4.16	Connecting Pipe material (for deciding counterflange material)	Carbon Steel to IS 1239 (Heavy Grade) / IS:2062 GR. E 250B, Plates rolled & welded as per IS 3589.	Carbon Steel to IS 1239 (Heavy Grade) / IS:2062 GR. E 250B, Plates rolled & welded as per IS 3589.
<b>5.0</b>	<b>MANDATORY SPARES FOR PUMP-MOTOR SET</b>		
5.1	Impeller	1 No.	1 No.
5.2	Casing	1 No.	1 No.
5.3	Shaft	1 No.	1 No.
5.4	Shaft Sleeves (DE & NDE)	1 Set	1 Set
5.5	Impeller / Casing Liner	1 No.	1 No.
5.6	Seals	1 Set	1 Set
5.7	Pump & Motor bearings	2 Sets	2 Sets
5.8	Gear Box	1 No.	1 No.
5.9	Pump- Motor coupling	1 No.	1 No.

672753/2022/PS-PEM-MSE	DATA SHEET - A		SPECIFICATION NO.: PE-TS-483-100-N001, REV-01
	MISCELLANEOUS PUMPS (HORIZONTAL)		SECTION : I D
			REV: 01, DATED 03.02.2022
	PROJECT	NTPL 2X500 MW TUTICORIN -FGD PROJECT	
Sl. No.	DESCRIPTION	DMCW PUMPS	ACW PUMPS
	<p><b>Mandatory Spare Note:</b></p> <p>1. One(1) set consists of quantity required for complete replacement for one(1) Pump of each type/size. Also the 'set' would include all components/hardware required to replace the item.</p> <p>2. In case spares indicated in the list are not applicable to the particular design offered by the bidder, the bidder should offer spares applicable to offered design or suitable alternative spare item subject to BHEL/End customer approval within the quoted price in price schedule, with quantities as specified in the Datasheet A.</p>		
6.0	<b>BID EVALUATION RATE</b>		
6.1	Bid evaluation rate	Rs. 4.065 Lacs/KW	Rs. 4.065 Lacs/KW
6.2	Maximum permissible efficiency for Bid evaluation		
6.2.1	Pump Efficiency	62	78
6.2.2	Motor Efficiency	92.9	90.1
Notes :			
1	Material of construction for other components not specified above shall be similarly selected in line with the above for the duty intended and subject to approval.		
2	For items stated as not applicable by bidder, shall have to be supplied without any cost implication to BHEL in the event they are found to be applicable during detail engineering stage.		
3	For all HT motor driven pumps (wherever applicable), bidder shall provide flat surface with dimensions 60 MM x60 MM on bearing Housing for mounting vibration measuring block and a key slots of dimensions 30MM (L) X 15 MM (W) X 3 MM (D) on each pump shaft or some other suitable location which shall be confirmed during detail engineering by BHEL for Phase Marker.		
4	Wherever SS material is coming in contact with non SS material, suitable isolation (rubber etc.) shall be provided to avoid galvanic corrosion.		




TABLE-II

## TREATED WATER/ FGD PROCESS WATER QUALITY

Sr. Number	Item	Unit	Value
1.	<u>TDS of permeate from Desalination RO System</u>	ppm	<500
2.	Total Suspended solids	ppm	Nil
3.	Iron as Fe	ppm as Fe	<0.1
4.	Reactive Silica as SiO <sub>2</sub>	ppm as SiO <sub>2</sub>	<1.0
5.	Chloride as Cl	ppm as Cl	<200
6.	Sodium	ppm as Na	<150
7.	pH at 25 deg C	---	6.0-7.0


672753/2022/PS-PEM-MISC

	<b>TECHNICAL SPECIFICATION MISCELLANEOUS PUMPS</b>	SPEC. NO.: <b>PE-TS-483-100-N001</b>	
		SECTION: <b>II</b>	
		SUB-SECTION: <b>IIA</b>	
		REV. NO. <b>01</b>	DATE <b>03.02.2022</b>
		SHEET <b>1</b>	OF <b>1</b>
<b>SPECIFIC TECHNICAL REQUIREMENTS</b>			

## SUB-SECTION - IIA

### STANDARD TECHNICAL SPECIFICATION (MECHANICAL)

- STANDARD TECHNICAL SPECIFICATION FOR MISC. PUMPS (HORIZONTAL) INCLUDING DATASHEET-C
- STANDARD QUALITY PLANS


	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06	
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS</b>	<b>VOLUME:</b>	
		<b>SECTION:</b> IIA	
		<b>REV. NO.</b> 04	<b>DATE:</b> 01/07/2016
		<b>SHEET</b> 1 of 16	


### 1.00.00 GENERAL INFORMATION


- 1.01.0 The general guidelines as illustrated in the subsequent clauses of this section shall be applicable for horizontal centrifugal pumps to be procured under the scope of this package.
- 1.02.0 It is not the intent to specify herein all the details of design and manufacture. However, the equipment shall conform in all respects to high standards of design, engineering and workmanship, and shall be capable of performing the required duties in a manner acceptable to Engineer/Owner who will interpret the meaning of drawings and specifications and shall be entitled to reject any component or material, which in his judgement is not in full accordance herewith.
- 1.03.0 The omission of specific reference to any component/accessory necessary for the proper performance of Miscellaneous Pumps and drives shall not relieve the bidder of the responsibility of providing such facilities to complete the supply of equipment at quoted prices.
- 1.04.0 BHEL's / Customer's representative shall be given full access to the shop in which the equipment are being manufactured or tested and all test records shall be made available to him.
- 1.05.0 The equipment covered under this specification shall not be dispatched unless the same have been finally inspected, accepted and shipping release issued by BHEL/Customer.

### 2.00.00 CODES AND STANDARDS


- 2.01.00 In addition to the requirements spelt out elsewhere in the specification, the equipment to be provided under this section shall specifically conform to the following codes, standards, specifications and regulations, as applicable, including all the latest amendments subsequent to the year of publication as mentioned below.
- 2.01.01 IS-1520/1980: Horizontal Centrifugal pumps for clear, cold and fresh water.
- 2.01.02 IS-5120/1977: Technical requirements for Rotodynamic special Purpose pumps.
- 2.01.03 IS-5639/1970: Pumps for handling chemicals & corrosive liquids.
- 2.01.04 IS-5659/1970: Pumps for process water.
- 2.01.05 IS-6536/1972: Pumps for handling volatile liquids.
- 2.01.06 IS-9137/1978: Code for acceptance tests for centrifugal, mixed flow and axial flow pumps- Class 'C'.


	<b>TITLE:</b>		<b>SPECIFICATION NO.</b> PES-179-06
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS</b>		<b>VOLUME:</b>
			<b>SECTION:</b> IIA
	<b>REV. NO.</b> 04	<b>DATE:</b> 01/07/2016	
	<b>SHEET</b> 2 of 16		
2.01.07	ISO 3555/1977: BS 5316/1977 Part 2	Acceptance test for centrifugal, mixed flow and axial flow pumps - Class 'B' tests.	
2.01.08	ISO 2548/1973: BS 5316/1976 Part 1	- Do - Class 'C' tests.	
2.01.09	API-610/1989:	Centrifugal pumps for general refinery services.	
2.01.10	HIS	Hydraulic Institute Standards, USA	
2.01.11	PTC 8.2/1965:	Power Test Codes - Centrifugal pumps.	
2.01.12	ASTM-1-165-55	Standard Methods for Liquid Penetration Inspection.	
2.02.00	In case of any contradiction with the above standards and annexure, the stipulations in the annexure shall prevail and shall be binding on the bidder.		
<b>3.00.00</b>	<b>SCOPE OF SUPPLY &amp; SERVICES:</b>		
3.01.00	The miscellaneous pumps and drives scope shall be as specified in Data Sheet A /Section IA.		
3.02.00	The Capacity, Head, Materials of construction and other particulars of pumps are detailed in Data Sheet A of the specification.		
3.03.00	Accessories:		
	All the pumps under this specification shall be complete with following standard/special accessories.		
3.03.01	Standard accessories:		
	a) LT Electric drives/motors (as applicable) with cable gland and lugs at motor end. (The bare HT drive motors and LT motors not in bidder's scope of supply, wherever required supplied as free issue by BHEL refer Cl. 5.08.00).		
	b) Pump motor coupling along with coupling guard.		
	c) Common base plate for pumps and motor.		
	d) Self contained lubrication system along with all internal piping, valves, fittings, specialties etc. as required.		


	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS</b>	<b>VOLUME:</b>
		<b>SECTION:</b> IIA
		<b>REV. NO.</b> 04 <b>DATE:</b> 01/07/2016
	<b>SHEET</b> 3 of 16	
	<p>e) Counter flanges for suction/ discharge nozzles along with fixing nuts, bolts and gaskets.</p> <p>f) Anchor bolts, nuts, seating steel works, shims etc. as necessary for mounting the pump-motor unit on civil foundations.</p> <p>g) Suitable vent (with valves)/ lifting/ handling attachments for the pump/ motor/ accessories.</p> <p>h) Suitable drain connections with isolating valves as applicable.</p> <p>i) Supply of first fill of lubricants with toping requirements for one year of operation after commissioning and handing over of equipment.</p> <p>j) Set of “Special” Tools &amp; Tackles for Pumps and motors, if any.</p> <p>k) Erection and commissioning spares, “on as required” basis.</p> <p>l) Bidder shall provide various drawings, data, calculations, test reports/ certificates, operation and maintenance manuals, As-built drawings, etc. as specified and as necessary.</p> <p>m) Mandatory spares as specified in respective Data Sheet-A of this section.</p>	
3.04.00	Services included in Bidder’s Scope:	
3.04.01	The pumps shall be guaranteed to meet the performance requirements specified vide Data Sheet -A and also for trouble free operation after commissioning. Schedule of performance guarantees (Section-IIIA) duly filled and signed shall be furnished with the bid.	
3.04.02	Pumps with Mechanical seal shall be supplied with gland packing arrangement initially to site and gland packing arrangement shall be replaced by vendor with mechanical seal arrangement at site after commissioning of the pumps with gland packing. However Mechanical seal shall be dispatched along with main supply for this purpose. Shaft sleeve and any other item required for satisfactory operation of Mechanical seal after replacement at site shall be provided by the pump supplier without any cost implication to BHEL.	
3.04.03	The pumps erected by the purchaser shall be checked by the bidder for correctness of their installation, alignment, etc. at site prior to their commissioning.	
3.04.04	After commissioning of pumps at site, site performance test for Noise, vibration and parallel running of pumps of all pumps for each unit/project shall be conducted by pump vendor at project site to ensure that the pumps meet the specified requirements. Pump vendor shall bring necessary instruments for conductance of site performance test.	


	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06	
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS</b>	<b>VOLUME:</b>	
		<b>SECTION:</b> IIA	
		<b>REV. NO.</b> 04	<b>DATE:</b> 01/07/2016
		<b>SHEET</b> 4 of 16	
<p>If the site performance is found not meeting the requirements in any respect as specified, then the equipment shall be rectified or replaced by the vendor, without any commercial implication to BHEL</p> <p><b>Note: Applicability of conducting PG test at site by vendor as per above clause shall be applicable if indicated in Section-1A.</b></p> <p>If conductance of PG test of pumps at site for Noise, vibration and parallel running of pumps of all pumps for each unit/project is not in bidders scope and same is conducted by BHEL/ customer. In such cases also, if the site performance is found not meeting the requirements in any respect as specified, then the equipment shall be rectified or replaced by the vendor, without any commercial implication to BHEL.</p> <p>3.04.05 Performance Guarantees for pumps shall stand valid till the satisfactory completion of performance testing by BHEL and its acceptance by purchaser / customer.</p> <p>3.05.00 Works excluded from Bidder's Scope:</p> <ul style="list-style-type: none"> <li>a) All HT motors and those LT Motors which are specifically excluded.</li> <li>b) Civil foundation</li> <li>c) Suction/ discharge pipe works</li> <li>d) MCC/ Switchgear/Power supply</li> <li>e) Power and Control Cables, unless specifically specified in Electrical/ Systems portion of the specification.</li> <li>f) Erection of equipments.</li> </ul> <p><b>4.00.00 BID EVALUATION CRITERIA &amp; LIQUIDATED DAMAGES FOR SHORTFALL:</b></p> <p>4.01.00 The bids received shall be evaluated for power consumption at inlet to the motors, in respect of pumps specified in Data Sheet-A (working pump only viz. not the standby), for the purpose of price comparisons as briefed below:</p> <p>The bid evaluation shall be done at the rate as specified in Data Sheet A per one (1) KW Power consumption, per working pump as follows.</p> $KW = \frac{Q \times H \times S}{P \times M \times 367.2}$ <p>Where Q = Rated capacity M<sup>3</sup>/hr  H = Rated TDH, MWC  P = Pump Efficiency  M = Motor Efficiency.  S = Specific Gravity of fluid handled</p> <p>4.02.00 The efficiencies for pumps and motors for arriving at benchmark power for Bid Evaluation shall be as indicated in Data Sheet A for various pumps.</p>			



	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06	
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS</b>	<b>VOLUME:</b>	
		<b>SECTION:</b> IIA	
		<b>REV. NO.</b> 04	<b>DATE:</b> 01/07/2016
		<b>SHEET</b> 5 of 16	
<p>No advantage shall be given to the bidder for Aux. Power quoted lower than the Bench mark values calculated with KW calculation formula at Cl. 4.01.00 <i>above, considering the bid evaluation efficiencies for pump and motor as indicated in Data Sheet-A.</i> However the bids shall be evaluated as above if the Aux. Power quoted are higher than Bench mark values.</p> <p>NOTE:</p> <ol style="list-style-type: none"> <li>Efficiencies for HT motors and LT motors not in bidder's scope, for bid evaluation purpose shall be taken based on the maximum value as furnished in Data Sheet A.</li> <li>During contract stage the Guaranteed power consumption of Pumps with BHEL supplied drives (HT/LT) for successful bidder shall be reworked by BHEL as below:</li> </ol> <p>Revised guarantee power consumption shall be as per KW calculation formula at Cl. 4.01.00 <i>above, where P = pump efficiency guaranteed by bidder and M = motor efficiency as per approved datasheet of the supplied HT/LT motor.</i></p> <p><b>4.03.00</b> Liquidated damages for shortfall in Guaranteed KW</p> <p>The above guaranteed power consumption shall be demonstrated by the successful bidder during performance testing at works/ site.</p> <p>For pumps with BHEL supplied drives, the power consumption shall be compared with the reworked guarantee power consumption, defined as per note no. 2 of Cl. 4.02.00 above for the purpose of shortfall.</p> <p>The liquated damages @ twice the bid evaluation rate as above per KW per working pump shall be levied in the event of failure of bidder to demonstrate the guaranteed power consumption.</p> <p><b>5.00.00 TECHNICAL REQUIREMENTS:</b></p> <p><b>5.01.00</b> The pumps shall meet the technical requirements of Section-I as well as Section-II. In the event of any contradiction of Section-II with Section-I, the Section-I will prevail.</p> <p><b>5.02.00</b> The pumps shall be Electric motor driven.</p> <p><b>5.03.00</b> The Pumps shall conform to HIS. It is bare minimum requirement, however, any other equivalent or stringent standard is also acceptable, if, all the requirements of HIS are also met.</p> <p><b>5.04.00</b> The horizontal pumps shall be Horizontal split casing type with speeds not exceeding 1500 RPM or as indicated in Data Sheet-A.</p> <p><b>5.05.00</b> No negative tolerance shall be permitted in rated capacity &amp; TDH.</p> <p><b>5.06.00</b> No negative tolerance shall be permitted in efficiency at rated capacity.</p>			

	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06	
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS</b>	<b>VOLUME:</b>	
		<b>SECTION:</b> IIA	
		<b>REV. NO.</b> 04	<b>DATE:</b> 01/07/2016
		<b>SHEET</b> 6 of 16	
5.07.00	<p>The shut off head of pumps shall be more than pump rated TDH and percentage variation may vary depending on the specific speed of the pump as under:</p> <ol style="list-style-type: none"> <li>i. 10-15% for pumps of specific speed up to 1000 US units,</li> <li>ii. 15-20% for pumps of specific speed in the range of 1000 to 2000 US units,</li> <li>iii. 20-40% for pumps of specific speed in the range of 2000 to 4000 US units,</li> <li>iv. Above 50% for pumps of specific speed in the range of 4000 to 7000 US units.</li> </ol>		
5.08.00	<p>All HT motors and those LT motors which are not in bidder's scope of supply: bare motors only, shall be supplied as free issue by BHEL through BHEL, based on ratings and TS (Torque - Speed) curve selected and furnished by the bidders along with their un-priced bid. The responsibility for satisfactory operation for combined performance of pumps &amp; motors shall rest with the bidder only as if, the drive motors also have been supplied by the bidder.</p> <p>Couplings, base plate, foundation bolts, any other fittings, etc. as required shall be supplied by the bidders only. BHEL shall supply one number of each type of drive motors (where drive motor is not in bidder's scope of supply) for shop testing of pumps with job motors. All other motors shall be dispatched by BHEL directly to project sites.</p>		
5.09.00	<p>For all HT motor driven pumps, BHEL has envisaged vibration-monitoring system in their own scope. The bidder shall make provisions for mounting following on the pump/ pump shaft:</p> <ul style="list-style-type: none"> <li>• Purchaser's probes in both DE/NDE bearings of pumps</li> <li>• Key slots on pump shaft and flat surface on bearing housing for mounting vibration measuring block with dimensions as specified in Data Sheet A.</li> <li>• Other components as finalized during detailing.</li> <li>• For mounting of above on the HT motors &amp; specifically excluded LT motors, same shall be taken care by BHEL.</li> </ul>		
5.10.00	<p>The pumps shall be capable of developing the required total head at rated capacity for continuous operation. The pumps shall operate satisfactorily at any point on the Q-H characteristic curve over a range of 0% to 130% capacity and shall be suitable for continuous operation between 30% to 130% capacity.</p>		
5.11.00	<p>Selection of the pumps shall be such that the design point shall be met even with negative manufacturing tolerance.</p>		
5.12.00	<p>The total head capacity curve shall be continuously rising towards the shut off, the pumps shall preferably be non-overloading type and stable.</p>		
5.13.00	<p>The pumps shall be capable of running over the entire range of NPSH conditions required without any noise, vibration or cavitations.</p> <p>The prevailing suction pressures for various pumps are indicated in Data Sheet-A for suitable mechanical design of pumps.</p>		

	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06	
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS</b>	<b>VOLUME:</b>	
		<b>SECTION:</b> IIA	
		<b>REV. NO.</b> 04	<b>DATE:</b> 01/07/2016
		<b>SHEET</b> 7 of 16	
5.14.00	The pumps shall be of stiff shaft design. The minimum internal clearances should be sufficiently more than the maximum static deflection of the shaft. Shaft size selected must take into consideration the critical speed as specified in API-610.		
5.15.00	Pumps and motors shall run smooth without undue noise and vibration.  The vibration shall be within vibration norms for testing as per American National Standard for 'Rotodynamics Pump' for Vibration Measurement and allowable values, Doc. ANSI/ HIS 9.6.4-2009. The applicable vibration limits for each pump, shall be indicated in the Technical Data sheet to be furnished by the successful bidder after award of LOI/ PO.  The noise level shall be limited to 85 dB at distance of 1.0M.		
5.16.00	Pumps of a particular category shall be identical and shall be suitable for parallel operation with equal load division. Components of identical pumps shall be interchangeable.		
5.17.00	After installation, the guaranteed values of noise, vibration and parallel operation of pumps shall be tested and verified. If the site performance is found not meeting the requirements in any respect as specified, then the equipment shall be rectified or replaced by the vendor, at his own cost.		
5.18.00	High reliability of the pumps is an essential requirement and therefore it gets weightage over its efficiency. It is therefore essential that the bidder choose a standard proven model from the range of pumps manufactured.		
5.19.00	The offered pumps shall be of proven design meeting the experience-qualifying requirement of their operation at two sites for a minimum period of one year or as specified in technical PQR. Any deviation to this criterion shall be suitably highlighted in the deviations schedule.		
5.20.00	The bearings shall be self-water lubricated, no external water supply shall be available. The cooling/ lubrication water for bearings, etc. shall be tapped from the pump discharge and supplied thru' bidder's integral pipe work.  If water handled by pump is dirty/ not suitable for lubrication/ cooling, the bidder shall provide requisite strainer/ filters, tanks, motorized valves, etc. after the tap off for the required service, the arrangement provided shall be subject to Purchaser's approval.		
<b>6.00.00</b>	<b>MANDATORY SPARES:</b>		
6.01.00	Bidder to provide the Mandatory spares listed vide Data Sheet-A. Unit price of mandatory spares shall be furnished in price Schedule.		
6.02.00	Bidder shall include the cost of Mandatory Spares, unless specified otherwise in Sec-IA of the specification or NIT.		

	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS</b>	<b>VOLUME:</b>
		<b>SECTION:</b> IIA
		<b>REV. NO.</b> 04 <b>DATE:</b> 01/07/2016
		<b>SHEET</b> 8 of 16

**7.00.00 OTHER REQUIREMENTS:**

7.01.00 The quality of water handled by various pumps shall be as per Data Sheet-A.


7.02.00 The materials of construction for various components specified are the minimum requirements and materials of construction for other components not specified shall be similarly selected by the bidder for the intended duty.


7.03.00 The makes of various bought out items of bidder (i.e. motor, bearings, mechanical seal etc.) shall be subject to purchaser's approval in the event of order.

7.04.00 Painting for Pumps


- a) The surface of SS, Gun metal, brass, bronze and non-metallic component shall not be applied with any painting.
- b) The Steel surface to be applied with painting shall be thoroughly cleaned before applying painting by brushing, shop blasting etc. as per the agreed procedure.
- c) For all the steel surfaces inside the (indoor installation) building, a coat of red oxide primes of min. thickness DFT of 50 microns followed up with under coat of Synthetic Enamel paint of min. thickness DFT of 50 microns shall be applied. The top coat shall consist of two coats each of min. thickness DFT of 50 microns of synthetic enamel paint and thus total DFT shall be min. 200 microns.
- d) For all the steel surfaces exposed to (outdoor installation) atmosphere, a coat of chlorinated rubber based zinc phosphate primer of min. thickness DFT of 50 microns followed up with under coat of chlorinated rubber paint of min. thickness DFT of 50 microns shall be applied. Then, intermediate coat consisting of one coat of chlorinated rubber based paint pigmented with Titanium di-oxide with min. thickness DFT of 50 microns and top coat shall consist of two coats each of min. thickness DFT of 50 microns of chlorinated rubber paint shall be provided. Total DFT of paint system shall be min. 200 microns.


7.05.00 **It is mandatory for the bidder to submit along with the bid, the deviations if any – whether major or minor in the schedule of deviations only. In the absence of deviations listed in the “Schedule of deviations, the offer shall be deemed to be full conformity with the specification, “not-withstanding” anything else stated elsewhere in bidder’s offer. The implied/indirect deviations shall not be binding on the purchaser.**

	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06	
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS</b>	<b>VOLUME:</b>	
		<b>SECTION:</b> IIA	
		<b>REV. NO.</b> 04	<b>DATE:</b> 01/07/2016
		<b>SHEET</b> 9 of 16	
8.00.00	<b>PERFORMANCE REQUIREMENTS</b>		
8.01.00	Performance requirements for the pumps shall be as guided in Data sheet - A enclosed with Section-I.		
8.02.00	Pump(s) shall preferably be designed to have the best efficiency at flow within $\pm 10\%$ of the specified duty point flow. The pumps shall be suitable for continuous operation at any point within the "Range of Operation" as stipulated in the Data Sheet - A attached with Section-I.		
8.03.00	Pump(s) shall preferably have a continuously rising head-capacity characteristics from the specified duty point towards shut-off point, the maximum being at shut-off to enable parallel operation.  Under all circumstances, the 'range of operation' of the pumps shall exclude any unstable operating zone of the head-capacity curve.		
8.04.00	Wherever specified in the Data Sheet - A, pumps of each category shall be suitable for parallel operation. The head vs. capacity, the BHP vs. capacity characteristics etc. shall be identical to ensure equal load sharing and trouble-free operation of any pump when the other pump(s) working in parallel with it trip.		
8.05.00	The pump set along with drive motor shall run smooth without undue noise and vibration. Acceptable vibration limits shall be guided by the HIS of USA. Refer clause 5.15.00 above for permissible limits.		
9.00.00	<b>DESIGN AND CONSTRUCTION</b>		
9.01.00	<b>Pump Casing</b>		
9.01.01	Pump casing shall be provided with adequate number of vents and priming connections with valves unless the pump is made self-venting and priming. Casing drain, as required, shall be provided complete with drain valves. It shall be provided with a connection for suction and discharge pressure gauge as standard feature.		
9.01.02	Pump design must ensure that the nozzles are capable of withstanding external reactions not less than those specified in API-610.		
9.01.03	In case where an expansion joint is located at pump discharge, the pump assembly will be subjected to an additional thrust which will be transmitted to the foundation. This additional thrust shall be taken into the consideration of pump design.		
9.02.00	<b>Impeller</b>		
9.02.01	The Impeller assembly shall be dynamically balanced and designed with critical speed substantially above the operating speed.		


	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS</b>	<b>VOLUME:</b>
		<b>SECTION:</b> IIA
		<b>REV. NO.</b> 04 <b>DATE:</b> 01/07/2016
	<b>SHEET</b> 10 of 16	
9.03.00	<b>Wearing Rings</b>	
9.03.01	Replaceable type wearing rings shall be furnished to prevent damage to impeller and casing.	
9.04.00	<b>Shaft</b>	
9.04.01	Shaft size shall be selected considering that the critical speed shall be away from the operating speed as recommended in applicable Code/Standard. The critical speed shall be at least 30% higher than the rated speed.	
9.05.00	<b>Shaft Sleeves</b>	
9.05.01	Renewable type fine finished shaft sleeves shall be provided at the stuffing boxes/mechanical seals. Length of the shaft sleeves must extend beyond the other faces of gland packing or seal end plate so as to distinguish between the leakage past Shaft and shaft sleeve and that past the seals/glands.	
9.05.02	Shaft sleeves shall be properly fastened to the shaft to prevent any leakage or loosening. Shaft sleeve assembly should ensure concentric rotation.	
9.06.00	<b>Bearings</b>	
9.06.01	Bearings shall be easily accessible without disturbing the pump assembly. A drain shall be provided at the bottom of each bearing housing.	
9.06.02	Heavy-duty sleeve/ball/roller type bearings shall be provided to take care of the radial loads.	
9.06.03	In case of sleeve type radial, axial thrust shall be absorbed in suitable hydraulic devices and/or thrust bearings.	
9.06.04	Bearings and hydraulic devices (if provided for balancing axial thrust) shall be of adequate design for taking the entire pump load arising from all probable conditions of continuous operation. Life of the bearings shall be guided by the design standard of the pump. Antifriction bearings of standard type, if provided, shall be selected for a minimum life 20,000 hrs. of continuous operation at maximum axial and radial loads at rated speed. Thrust bearing shall be capable of running continuously at maximum load.	
9.06.05	The bearing shall be oil/grease lubricated. Suitable lubricating arrangement for the bearings shall be furnished with the pump complete with all accessories like pump, filters, piping, fittings, valves, interlocking and supervising instruments etc. as necessary. The design shall be such that the bearing lubricant does not contaminate the liquid being pumped.	
9.06.06	Bearing housing for HT motor driven pumps shall have provision for mounting temperature measuring device.	





	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS</b>	<b>VOLUME:</b>
		<b>SECTION:</b> IIA
		<b>REV. NO.</b> 04 <b>DATE:</b> 01/07/2016
	<b>SHEET</b> 11 of 16	
9.06.07	Bearings of reputed makes are to be provided, same shall be indicated in Technical Data sheet to be furnished by the successful bidder after award of LOI/ PO, subject to acceptance of BHEL/ end customer, without any price implication to BHEL.	
9.07.00	<b>Stuffing Boxes</b>	
9.07.01	Stuffing box design shall permit replacement of packing without removing any part other than the gland.	
9.07.02	Stuffing boxes shall be sealed/cooled by the fluid being pumped/external clear water, as specified in the Annexure. All necessary pumps, piping, fittings, valves, instruments etc. as required for safe and trouble-free operation of the pumps and as specified in the Annexure shall be included in the scope of supply.	
9.08.00	<b>Mechanical Seals</b>	
9.08.01	Mechanical seals (cartridge type) shall be provided if specified in the Data Sheet-A of this section. The pump supplier shall co-ordinate with the seal maker in establishing the direct circulation rate for maintaining a stable film at the seal in the chamber. The seal piping system shall form an integral part of the pump assembly.	
9.08.02	When handling liquids near boiling point, suitable arrangement for external cooling shall be provided so as to prevent flashing at the seal faces.	
9.08.03	For the seals under vacuum service, the seal design must ensure sealing against atmospheric pressure, even when the pumps are not operating.	
9.08.04	Pumps with Mechanical seal shall be supplied with gland packing arrangement initially to site and gland packing arrangement shall be replaced by vendor with mechanical seal arrangement at site after commissioning of the pumps with gland packing. However Mechanical seal shall be dispatched along with main supply for this purpose. The special tools (if any) required for above shall be arranged by bidder.	
9.08.05	Mechanical seals of reputed makes are to be provided, same shall be indicated in Technical Data sheet to be furnished by the successful bidder after award of LOI/ PO, subject to acceptance of BHEL/ end customer, without any price implication to BHEL.	
9.09.00	<b>Drive Unit</b>	
9.09.01	The pumps shall be driven by electric motor directly coupled as specified in the Data Sheet-A of this section. A heavy duty coupling along with coupling guard shall be provided between the pump and drive unit.	
9.09.02	Unless otherwise specified in Data Sheet-A of this section, drive unit power rating shall be the maximum of the following requirements.	

	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS</b>	<b>VOLUME:</b>
		<b>SECTION:</b> IIA
		<b>REV. NO.</b> 04 <b>DATE:</b> 01/07/2016
	<b>SHEET</b> 12 of 16	
	<p>a) 16% margin over the pump shaft input power at the rated duty point.</p> <p>b) 10% margin over the maximum pump shaft input power required within the 'Range of Operation'.</p> <p>c) Pump shaft input power required considering the overloading of the pump assuming single pump operation in the event of tripping of one or more of the pumps operating in parallel.</p>	
9.10.00	<b>Coupling for pump &amp; Motor Shaft</b>	
9.10.01	The pump and motor shafts shall be connected with adequately sized flexible coupling of proven design with spacer to facilitate dismantling of the pump without disturbing the motor. Necessary coupling guard shall be provided.	
9.10.02	No. of coupling holes for joining coupling hubs shall be even in number and preferably in multiples of four.	
10.00.00	<b>INSPECTION AND TESTING</b>	
10.01.00	The Quality Plans enclosed in the specification are for bidder's guidance only. The bidder shall comply with these and other minimum requirements specified in the specification and shall furnish his own quality plan in the event of order based on the guidance given as above, for approval by BHEL/Customer.	
10.02.00	The Bidder shall carry out the following specific tests inspections to ensure that the equipment furnished lies in strict conformance with the specification and also in accordance with applicable codes/standards and good engineering practice.	
	<p>a) <b>Identification and Testing</b></p> <p>i) All materials used for pump construction shall be of tested quality. Material shall be tested as per the relevant standard and test certificates shall be made available to the Owner.</p> <p>ii) 100% PMI (Process Material Identification) inspection for material grade of pump casing, shaft and impeller shall be done by vendor &amp; certification shall be submitted for review of BHEL. Further BHEL reserves the right to conduct random &amp; independent PMI inspection on pump casing, shaft and impeller to ascertain the grade of material during inspection at vendor works.</p> <p>iii) Tests for each pump included under this section shall include but not be limited to the following:</p>	



	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06	
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS</b>	<b>VOLUME:</b>	
		<b>SECTION:</b> IIA	
		<b>REV. NO.</b> 04	<b>DATE:</b> 01/07/2016
		<b>SHEET</b> 13 of 16	
<p>- The entire surface of the impeller / casing / diffuser castings shall be subjected to Dye Penetration Test as per ASTM Specification no.:1-165-65.</p> <p>- Shaft coupling &amp; other active components shall be subjected to Dye Penetration and Ultrasonic Tests.</p> <p>- Wearing rings, shaft sleeves shall be subjected to Dye Penetration Test.</p> <p>- Fabricated components of pumps shall be subjected to Dye Penetration test on weld.</p> <p>- Verification of material, witnessing of pouring, casting and inspection of finished fabricated/castings.</p> <p>- Inspection of finished castings for impeller and verification of materials.</p> <p>- Inspection of pump shaft and verification of material.</p> <p>- Witnessing of NDT/review of NDT reports.</p> <p>- Static balancing test for impeller and dynamic balancing of complete rotating parts as per ISO- 1940 to grade 6.3 or better.</p> <p>- Complete Inspection of assembled pump.</p> <p><b>b) Hydraulic Testing</b></p> <p>The pump casing shall be hydrostatically tested at maximum of the following:</p> <ol style="list-style-type: none"> <li>i. 2 times the TDH (Total Dynamic Head) at rated capacity (or)</li> <li>ii. 1.5 times the shut-off pressure (or)</li> <li>iii. System Design pressure indicated in Data Sheet-A of Section-I.</li> </ol> <p>The HT pressure shall be maintained for a period of not less than 30 minutes. During testing there should not be any pressure drop &amp; leakage.</p> <p><b>c) Performance Test at Shop</b></p> <ol style="list-style-type: none"> <li>i) Each pump shall have to be tested to determine the performance curves of the pumps. These tests are to be conducted in presence of Owner's representative as per the requirements of the Standards of Hydraulic Institute of USA (ASME-Power Test Code PTC 8.2/BS-599) or any other equivalent standard.</li> <li>ii) Performance tests are to be conducted to cover the entire range of operation of the pumps at rated speed. These shall be carried out to span 130% of rated capacity up to pump shut-off condition. A minimum of five combinations of</li> </ol>			

	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS</b>	<b>VOLUME:</b>
		<b>SECTION:</b> IIA
		<b>REV. NO.</b> 04 <b>DATE:</b> 01/07/2016
		<b>SHEET</b> 14 of 16
<p>head and capacity are to be achieved during testing to establish the performance curves, including the design capacity point, shut-off point and the two extremities of the range of operation as specified in the annexure. After completion of performance test, all pumps shall be stripped down for inspection of internals.</p> <p>iii) Tests shall be conducted with actual drive motors being furnished.</p> <p>iv) NPSH tests are to be conducted for each type at 3% head drop conditions, if specified in the pump approved QP.</p> <p>v) All rotating components of the pumps shall be subjected to static and dynamic balancing tests. The assembled rotor will be subjected to dynamic balancing tests.</p> <p>vi) Mechanical run test shall be carried out on all pumps to determine the vibration levels, noise levels etc. This test shall be conducted at site also. However, test value at site shall be used for the acceptance of the equipment.</p> <p>10.03.00 Inspection of Mandatory/ Recommended spares shall be in line with approved QP for main supply.</p> <p><b>11.00.00 DRAWINGS/ DOCUMENTS DISTRIBUTION SCHEDULE</b></p> <p>11.01.00 After award of LOI, the successful bidder shall submit drawings/documents as per Data Sheet-C.</p> <p>11.02.00 The no. of drawings/documents to be submitted shall be as per Data Sheet-C.</p> <p>12.00.00 The various Sections-I's &amp; II's along with Data Sheets attached in this specification together with the specification for Miscellaneous Pumps shall be complied with by the bidders.</p> <p>13.00.00 Bidder to submit all drawing/ documents in soft as well as hard copy in the event of order as per schedule indicated in section-IA.</p> <p>Within one (1) week of receipt of BHEL comments a technical representative from Bidder's works shall come for meeting with BHEL along with revised documents to resolve all issues and incorporate all comments in the soft copy here only for further submission to customer.</p> <p>Further on receipt of customer's comments on the documents a technical representative from Bidder's works shall come for meeting with Customer to resolve all issues and incorporate all comments in the soft copy here only and further resubmission of same to Customer. The representative shall be available here till Category-I approval of all the drawings and documents.</p>		

	<b>TITLE:</b>  <b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS</b>	<b>SPECIFICATION NO.</b> PES-179-06	
		<b>VOLUME:</b>	
		<b>SECTION:</b> IIA	
		<b>REV. NO.</b> 04	<b>DATE:</b> 01/07/2016
		<b>SHEET</b> 15 of 16	


14.00.00 Guarantee for all pumps shall at least remain valid for 18 months from the Unit commissioning date or as specified in NIT.

**15.00.00 The following documents only shall be furnished by the bidder with his offer:**

- a) Compliance certificate duly signed and stamped (enclosed at Section-IIIB).
- b) GA drawings of pumps and motors with following: (shall be only for reference purpose, same shall not be reviewed/commented by purchaser at this stage and shall be subject to approval only during contract).
  - Civil static & dynamic loads.
  - Foundation details.
- c) Guarantee Schedule duly signed and stamped (enclosed at Section-IIIA).
- d) Technical deviation schedule (if reqd.) (enclosed at Section-IIIC).
- e) Data for drive Motor (HT/LT- which is not in bidder's scope of supply - as applicable): Load torque speed curves of the pumps, selected motor rating, rpm,  $GD^2$  of driven equipment.
- f) Unpriced copy of the price bid shall be furnished along with the technical bid.

**Apart from above no other Drgs./Docs./Data sheets etc. are required to be submitted at bid stage and even if furnished shall not be taken cognizance of.**

**In case of any deviation from this technical specification, the same shall be indicated in the schedule of deviations as per Section-IIIC or NIT. In the absence of duly filled schedules it will be assumed that the bid strictly conforms to the specification.**

	<b>TITLE:</b>	<b>SPECIFICATION NO.</b> PES-179-06		
	<b>STANDARD TECHNICAL SPECIFICATION HORIZONTAL PUMPS</b>		<b>VOLUME:</b>	
			<b>SECTION:</b> IIA	
	<b>REV. NO.</b> 04	<b>DATE:</b> 01/07/2016		
	<b>SHEET</b> 16 of 16			

**DATA SHEET – C****Drawings / documents distribution schedule to be followed by successful Bidder:**

- 1.0** Drawings/documents submission schedule, shall be as per Section-IA.  
The successful bidder shall submit at least following drawings/ documents:
- 1.1** Fully dimensioned outline general arrangement drawings of the pump and motor assembly. This drawing should include foundation base plate/sole plate details as applicable, civil foundation, anchor bolt details, loading data (Static and Dynamic), points of connections of external piping, cables and mounting of devices furnished by the supplier and details for Gap between Coupling Shafts, Float & details for axial/radial tolerance allowed etc. which are required for erecting agency during erection of pump.
- 1.2** Cross sectional drawing of the equipment showing the details of assembly of components and their material of construction with standard applicable codes.
- 1.3** Technical datasheet as per Datasheet-B (Section-IIID) including characteristic curves of pumps showing the following:
- a) Flow Vs Head
  - b) Flow Vs Power
  - c) Flow Vs Efficiency
  - d) Flow Vs NPSHR/ minimum submergence
- 1.4** QAP for pump and QAP for motors (if applicable).
- 1.5** GA, Datasheet, Curves etc. for drive motor (as applicable).
- 1.6** Operation and maintenance manual.
- 1.7** Lubrication arrangement drawings for external lubrication (if applicable).
- 1.8** PG test procedure as per clause 3.04.04 (if applicable).
- 1.9** Motor type test document (if applicable).
- 2.0** Within the stipulated time period as per vendor's drawings/ documents schedule as per NIT, the O&M Manual comprising of minimum following shall be submitted:
- a) Drawings of components & details as deemed necessary.
  - b) Instruction manual for erection, operation & maintenance.
  - c) Storage instruction.
- 3.0** Before dispatch of the equipment the bidder shall furnish the following.
- a) Material test certificates.
  - b) Shop test reports & certificates.
  - c) Fulfilment of packing instructions as indicated in Section-IA of this specification.
- 4.0** Distribution of drawings / documents for all projects:


The no. of copies of drawing/ documents to be submitted by the successful bidder, after the award of the contract shall be as per Section-IA or as specified in NIT.

MANUFACTURER/ BIDDER/ SUPPLIER NAME & ADDRESS		QUALITY PLAN				SPEC. NO. PE-TS-XXX-100-N1001		DATE	
CUSTOMER:		PROJECT:				OF NO.: PE-OP-999-100-N1004		DATE	
ITEM: MISC. PUMPS (HORIZONTAL/VERTICAL)		SYSTEM: CW/ACW/DMC/W/PLANT/COMMON				PO NO.:		DATE	
TYPE OF CHECK		QUANTUM OF CHECK		REFERENCE DOCUMENTS		ACCEPTANCE NORMS		REMARKS	
CLASS		TYPE OF CHECK		APPROVED CS DRAWING/DATA SHEET		8		AGENCY	
CHARACTERISTIC		MECHANICAL AND CHEM. ANALYSIS		APPROVED CS DRAWING/DATA SHEET		7		M C N	
COMPONENT & OPERATION		MECHANICAL AND CHEM. ANALYSIS		APPROVED CS DRAWING/DATA SHEET		6		9 10 11	
3		LAB. TEST		100%		5		FORMAT OF RECORD	
2		1. MECHANICAL & CHEMICAL ANALYSIS.		1/CAST OR 1/BARS		4		P V	
1		2. MEASUREMENT		100%		3		P V	
RAW MATERIALS		3. ULTRA SONIC TEST		100%		2		P V	
CASINGS (INCLUDING BOWLS/DIFFUSERS, STAGE BODIES, DISCH HEAD (IF CAST), ETC. - (AS APPLICABLE) AND IMPELLER		VERIFICATION OF SPRT CHART		ALL BATCHES		1		P V	
STUFFING BOX, SUCTION BELL, WEARING RINGS, NECK RINGS, SHAFT SLEEVES		LAB. TEST		ONE SAMPLE/ HT BATCH		0		P V	
1.1		1. MECH & CHEM. TEST		1/BATCH 100%		0		P V	
2. DIMENSIONS		2. MEASUREMENT		100%		0		P V	
3. INTERNAL DEFECTS FOR 40MM & ABOVE DIA SHAFTS		3. VISUAL EXAM		100%		0		P V	
1.2		1. MECH & CHEM. TEST		1/BATCH 100%		0		P V	
2. DIMENSIONS		2. MEASUREMENT		100%		0		P V	
3. SURFACE FINISH		3. VISUAL EXAM		100%		0		P V	
1.3		1. MECH & CHEM. TEST		1/BATCH 100%		0		P V	
2. DIMENSIONS		2. MEASUREMENT		100%		0		P V	
3. INTERNAL DEFECTS FOR 40MM & ABOVE DIA SHAFTS		3. VISUAL EXAM		100%		0		P V	
1.4		1. MECH & CHEM. TEST		1/BATCH 100%		0		P V	
2. DIMENSIONS		2. MEASUREMENT		100%		0		P V	
3. SURFACE FINISH		3. VISUAL EXAM		100%		0		P V	
1.5		1. MECH & CHEM. TEST		1/BATCH 100%		0		P V	
2. DIMENSIONS		2. MEASUREMENT		100%		0		P V	
3. SURFACE FINISH		3. VISUAL EXAM		100%		0		P V	
BIDDER/SUPPLIER		SIGN & DATE		NAME		SEAL		REMARKS	
BHEL		03/01/20		MOHIT KUMAR		[Seal]		CORRELATION REQUIRED IDENTIFICATION AS PER TC	
ENGINEERING		03/02/20		RITESH KUMAR JAISWAL		[Seal]		CORRELATED SR/HT CHARTS	
SIGN & DATE		03/02/20		[Signature]		[Seal]		LAB. REPORT	
NAME		TANUJ MATTA		A JAY JAIN		[Seal]		LAB. REPORT	
Checked by:		[Signature]		[Signature]		[Seal]		MFR T.C OR LAB. REPORT	
Reviewed by:		[Signature]		[Signature]		[Seal]		CORRELATED SR/HT CHARTS	
Doc No.:		[Blank]		[Blank]		[Blank]		LAB. REPORT	
FOR CUSTOMER REVIEW & APPROVAL		[Blank]		[Blank]		[Blank]		MFR T.C OR LAB. REPORT	








MANUFACTURER/ BIDDER/ SUPPLIER NAME & ADDRESS		QUALITY PLAN									
		CUSTOMER:		SPEC. NO.: PE-TS-XXX-100-N001		DATE:					
		PROJECT:		QP NO.: PE-QP-999-100-N004		DATE:					
		ITEM: MISC. PUMPS (HORIZONTAL/VERTICAL)		SYSTEM: CW/ACWDM(CW/PLANT/COMMON)		PO NO.:		DATE:			
S. No.	COMPONENT & OPERATION	CHARACTERISTIC	CLASS	TYPE OF CHECK	QUANTUM OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY	REMARKS	
1			4	5	M/C/N	7	8	9	M C N	11	
2.7.7	BUTT WELDS	INTERNAL DEFECT	MA	UT/RT	100%	ASME SEC. V	ASME-VIII.DIV I	IR	P W V	WITNESSING OF U.T	
2.7.8	DISCHARGE HEAD, COLUMN PIPE, DISCHARGE PIPE, ETC.	1. LEAK TIGHTNESS 2. DIMENSION	CR	1. HYDROTEST 2. MEASUREMENT	100%	APPROVED DATA SHEET/ APPROVED OP APPROVED GA- CS DRG/MFR DRG.	1. NO LEAKAGE 2. MFR. DRAWING	IR	P W V		
3.0	SUB-ASSEMBLY CONTROL										
3.1	ROTOR ASSEMBLY	ECCENTRICITY	MA	MEASUREMENT	100%	APPROVED GA DRG/ MFR.DRAWING	APPROVED GA DRG/ MFR.DRAWING	IR/LOG BOOK	P V V		
3.2	ROTOR ASSEMBLY RESIDUAL UNBALANCE	STATIC & DYNAMIC	CR	STATIC & DYNAMIC BALANCING	100%	ISO 1940	ISO1940 G:6.3	BALANCING CERTIFICATE	P W V	WITNESSING ONLY FOR SIZE GREATER THAN 10KW	
3.3	COMPLETE PUMP ASSEMBLY	COMPLETENESS, CORRECTNESS, CLEANLINESS, CLEARANCES, FREQUENCIES, ALIGNMENT	MA	VISUAL EXAM MEASUREMENT	100%	APPROVED DRG & MFG STANDARDS	APPROVED DRG & MFG STANDARDS	I.R. & CHECK LISTS	P V V		
ENGINEER'S SIGN & DATE		BIDDER/ SUPPLIER		CUSTOMER REVIEW & APPROVAL							
Prepared by:	Sign & Date	Name	Sign & Date	Name	Sign & Date	Name	Doc No:	Sign & Date	Name	Seal	
Reviewed by:	03/02/2020	TANUJ MATTA	03/02/20	MOCHIT KUMAR	Seal						
	03/02/20	JAY JAIN	03/02/20	RITESH KUMAR JAISWAL							



MANUFACTURER/ BIDDER/ SUPPLIER NAME & ADDRESS		QUALITY PLAN				SPEC NO.: PE-TS-XXX-1000-1001		DATE			
		CUSTOMER:				QP NO.: PE-QP-099-100-N104		DATE			
		PROJECT:				PO NO.		DATE			
		ITEM: MISC. PUMPS (HORIZONTAL/VERTICAL)				SYSTEM: CUMMINS/PLANT/COMMON		SECTION: SHEET 5 OF 6			
S. No.	COMPONENT & OPERATION	CHARACTERISTIC	CLASS	TYPE OF CHECK	QUANTUM OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY	REMARKS	
			4	5	6	7	8	9	M C N		
FINAL INSPECTION, TESTS & PACKING DESPATCH CONTROL											
4.1	PUMP WITH JOB/SHOP MOTOR ASSEMBLED ON INDIVIDUAL BASE FRAME	1. Q.V.S HEAD 2. Q.V.S POWER 3. Q.V.S PUMP EFF. 4. VIBRATION 5. NOISE 6. BEARING TEMP. 7. LEAKAGES	CR	PERFORMANCE TEST	100%	APPD. PERFORMANCE TEST PROCEDURE/ APPD. DATA SHEET/APPD. CURVES FOR VIBRATIONS - AS PER ANSII/HS 9.6.4-2009 (VALUES AS PER APPROVED DATA SHEET) FOR BEARING TEMP. - BEARING HOUSING SHOULD NOT BE UNTOUCHABLY HOT. FOR LEAKAGE - MINOR LEAKAGE (DROPPY) IN CASE OF GLAND PACKING ARRANGEMENT.	APPD. PERFORMANCE TEST PROCEDURE/ APPD. DATA SHEET/APPD. CURVES	IR, PERFORM TEST RECORD. PLOTTED CURVES	✓ P W	W	* MINIMUM 7 POINTS FROM SHUT-OFF TO MAX. OPERATING FLOW COVERING ENTIRE OPERATION RANGE OF PUMP SHALL BE TAKEN. * CUSTOMER HOLD POINT
4.2	STRIP DOWN AFTER PERFORMANCE TEST	NPSH REQUIRED	CR	NPSH TEST	1/MODEL	APPD. PERFORMANCE TEST PROCEDURE/ APPD. DATA SHEET/APPD. CURVES	IR, NPSH TEST RECORD. PLOTTED CURVES	✓ P W	W	IF SPECIFIED or INSISTED BY CUSTOMER.	
4.3	COMPLETE PUMP WITH UNIT MOTOR BASE FRAME COUNTER FLANGES ETC INCLUDING ALL ACCESSORIES AS PER SECTION C OF SPECN.	COMPLETENESS, CLEANLINESS, OVERALL DIMENSIONS ORIENTATION, WORKMANSHIP AND FINISH	MA	VISUAL EXAM AFTER STRIPPING	1/MODEL	NO UNDUJE WEAR TEAR & RUBBING ON IMPELLER & WEAR RING	INSP. REPORT	✓ P W	W	WITNESS REQUIRED ONLY WHEN ABNORMAL SOUND OBSERVED DURING PERFORMING TEST.	
						APPD. G.A DRAWING		APPD. G.A DRAWING			
BHEL											
SIGN & DATE				SIGN & DATE				SIGN & DATE			
Name				Name				Name			
Prepared by: <i>[Signature]</i> 03/02/2020				Checked by: TANUJ MATTA				Reviewed by: MOHIT KUMAR			
Reviewed by: <i>[Signature]</i> 03/02/2020				Reviewed by: AJAY JAIN				Reviewed by: RITESH KUMAR JASWAL			
FOR CUSTOMER REVIEW & APPROVAL											
Doc No:				Sign & Date				Name			
Reviewed by:				Reviewed by:				Reviewed by:			
Approved by:				Approved by:				Approved by:			

QUALITY PLAN		MANUFACTURER/ BIDDER/ SUPPLIER NAME & ADDRESS		CUSTOMER:		SPEC NO. PE-TS-XXX-100-N001		DATE			
				PROJECT :		QP NO. PE-QP-999-100-N004		DATE			
				ITEM: MISC PUMPS (HORIZONTAL/VERTICAL)		PO NO.		DATE			
				SYSTEM: CW/AC/WDMC/W/PLANT/COMMON		SECTION:		SHEET 6 OF 6			
S. No.	COMPONENT & OPERATION	CHARACTERISTIC	CLASS	TYPE OF CHECK	QUANTUM OF CHECK	REFERENCE DOCUMENTS	ACCEPTANCE NORMS	FORMAT OF RECORD			REMARKS
								M	C	N	
1			4	5	M/C/N	7	8	9	10	11	
4.4	PAINTING	1. SURFACE FINISH, DFT, MARKINGS ETC.	MA	VISUAL EXAM MEASUREMENT AESTHETIC	100%	APPD.DRG.	APPD.DOCS	✓	✓	✓	
4.5	PACKING, MARKING	SOUNDNESS OF PACKING	MI	VISUAL AESTHETIC	100%	TECHNICAL SPECIFICATION/ MFG. STANDARD	TECHNICAL SPECIFICATION/ MFG. STANDARD	✓	✓	✓	PHOTOGRAPHS OF PACKED MATERIAL TO BE VERIFIED BY BHEL BEFORE ISSUING MDCC

**NOTES:**

- AS CAST HEAT MARKS SHALL BE PROVIDED ON CI CASTING LIKE TOP & BOTTOM CASING.
- HYDRO TEST PRESSURE SHALL BE AT LEAST 2(TWO) TIMES THE DUTY POINT (OR) 1.5 TIMES OF SHUT OFF HEAD (OR) SYSTEM DESIGN PRESSURE, WHICHEVER IS HIGHER.
- THIS QAP IS ALSO APPLICABLE FOR SPARES.
- NO WELD REPAIRS PERMISSIBLE ON CI CASTING.
- MATERIAL SHALL BE AS PER APPROVED CROSS SECTION DRG. / DATA SHEET.
- STRIP TEST- INCREASE OF ABNORMAL NOISE OBSERVED DURING PERF. TEST, THOSE PUMP WILL BE STRIPPED DOWN FOR VISUAL INSPECTION OF IMPELLER & WEAR SHALL BE OFFERED FOR VISUAL INSPECTION FOR WEAR/RUBBING MARKS.
- PUMPS WITH MECHANICAL SEAL ARRANGEMENT TO BE TESTED AND SUPPLIED WITH GLAND PACKING ARRANGEMENT. HOWEVER MANUFACTURER TO ENSURE DIMENTIONAL MATCHING OF MECHANICAL SEAL WITH PUMP GA DRAWING.
- BHEL RESERVES THE RIGHT FOR CONDUCTING REPEAT TEST IF REQUIRED.
- PMI (POSITIVE MATERIAL IDENTIFICATION) INSPECTION WITNESS BY "C"/"N" FOR MATERIAL GRADE OF PUMP CASING/BOWL ASSEMBLY, SHAFT, SHAFT SLEEVE, IMPELLER AND COLUMN PIPE (FOR VERTICAL PUMPS) ON RANDOM SAMPLE BASIS. HOWEVER, VENDOR TO CONDUCT 100% PMI AND PROVIDE PMI CERTIFICATES FOR REVIEW BY "C"/"N" DURING INSPECTION AT VENDOR WORKS.

**LEGEND :** - \* RECORDS, IDENTIFIED WITH "TICK"(✓) SHALL BE ESSENTIALLY INCLUDED BY SUPPLIER IN QA DOCUMENTATION  
 \*\* M: SUPPLIER/MANUFACTURER/SUB-SUPPLIER, C: MAIN SUPPLIER/BHEL/THIRD PARTY INSPECTION AGENCY, N: CUSTOMER  
 P- PERFORM, W- WITNESS, V-VERIFICATION, AS APPROPRIATE  
 MA- MAJOR, MI- MINOR, CR- CRITICAL, MTC- Mill Test Certificate, TC- Test Certificate, IGC- Inter- Granular Corrosion.  
 GA-GENERAL ARRANGEMENT DRAWING, CS-CROSS-SECTIONAL DRAWING

BHEL		BIDDER/SUPPLIER		FOR CUSTOMER REVIEW & APPROVAL	
ENGINEERING:		QUALITY		Doc No:	
Sign & Date	Name	Sign & Date	Name	Sign & Date	Name
	TANUJ MATTA		MOHIT KUMAR		
	AJAY JAIN		RITESH KUMAR		

672753/2022/PS-PEM-MIS

	<b>TECHNICAL SPECIFICATION MISCELLANEOUS PUMPS</b>	SPEC. NO.: <b>PE-TS-483-100-N001</b>	
		SECTION: <b>II</b>	
		SUB-SECTION: <b>IIB</b>	
		REV. NO. <b>01</b>	DATE <b>03.02.2022</b>
		SHEET <b>1</b>	OF <b>1</b>
<b>STANDARD TECHNICAL REQUIREMENTS</b>			

### **SUB-SECTION - IIB**

### **STANDARD TECHNICAL SPECIFICATION (ELECTRICAL)**

672753/2022/PS/PEM-MSE

TITLE :

**GENERAL TECHNICAL REQUIREMENTS****FOR****LV MOTORS**


SPECIFICATION NO.

PE-SS-999-506-E101

VOLUME NO. : **II-B**SECTION : **D**REV NO. : **00** DATE : 29/08/2005

SHEET : 1 OF 1

**GENERAL TECHNICAL REQUIREMENTS****FOR****LV MOTORS****SPECIFICATION NO.: PE-SS-999-506-E101 Rev 00**

	TITLE : <b>GENERAL TECHNICAL REQUIREMENTS</b>  <b>FOR</b>  <b>LV MOTORS</b>	SPECIFICATION NO. PE-SS-999-506-E101
		VOLUME NO. : <b>II-B</b>
		SECTION : <b>D</b>
		REV NO. : <b>00</b> DATE : 29/08/2005
		SHEET : 1 OF 4

**1.0 INTENT OF SPECIFIATION**

The specification covers the design, materials, constructional features, manufacture, inspection and testing at manufacturer's work, and packing of Low voltage (LV) squirrel cage induction motors along with all accessories for driving auxiliaries in thermal power station.

Motors having a voltage rating of below 1000V are referred to as low voltage (LV) motors.

**2.0 CODES AND STANDARDS**

Motors shall fully comply with latest edition, including all amendments and revision, of following codes and standards:

- IS:325                      Three phase Induction motors
- IS : 900                    Code of practice for installation and maintenance of induction motors
- IS: 996                     Single phase small AC and universal motors
- IS: 4722                    Rotating Electrical machines
- IS: 4691                    Degree of Protection provided by enclosures for rotating electrical machines
- IS: 4728                    Terminal marking and direction of rotation rotating electrical machines
- IS: 1231                    Dimensions of three phase foot mounted induction motors
- IS: 8789                    Values of performance characteristics for three phase induction motors
- IS: 13555                  Guide for selection and application of 3-phase A.C. induction motors for different types of driven equipment
  
- IS: 2148                    Flame proof enclosures for electrical appliance
- IS: 5571                    Guide for selection of electrical equipment for hazardous areas
- IS: 12824                  Type of duty and classes of rating assigned
- IS: 12802                  Temperature rise measurement for rotating electrical machines
- IS: 12065                  Permissible limits of noise level for rotating electrical machines
- IS: 12075                  Mechanical vibration of rotating electrical machines

In case of imported motors, motors as per IEC-34 shall also be acceptable.

**3.0 DESIGN REQUIREMENTS**

3.1 Motors and accessories shall be designed to operate satisfactorily under conditions specified in data sheet-A and Project Information, including voltage & frequency variation of supply system as defined in Data sheet-A

3.2 Motors shall be continuously rated at the design ambient temperature specified in Data Sheet-A and other site conditions specified under Project Information  
 Motor ratings shall have at least a 15% margin over the continuous maximum demand of the driven equipment, under entire operating range including voltage & frequency variation specified above.

**3.3 Starting Requirements**

3.3.1 Motor characteristics such as speed, starting torque, break away torque and starting time shall be properly co-ordinated with the requirements of driven equipment. The accelerating torque at any speed with the minimum starting voltage shall be at least 10% higher than that of the driven equipment.

3.3.2 Motors shall be capable of starting and accelerating the load with direct on line starting without exceeding acceptable winding temperature.

	TITLE : <b>GENERAL TECHNICAL REQUIREMENTS</b>	SPECIFICATION NO. PE-SS-999-506-E101
	<b>FOR</b>	VOLUME NO. : <b>II-B</b>
	<b>LV MOTORS</b>	SECTION : <b>D</b>
		REV NO. : <b>00</b> DATE : 29/08/2005
		SHEET : 2 OF 4

The limiting value of voltage at rated frequency under which a motor will successfully start and accelerate to rated speed with load shall be taken to be a constant value as per Data Sheet - A during the starting period of motors.

3.3.3 The following frequency of starts shall apply

- i) Two starts in succession with the motor being initially at a temperature not exceeding the rated load temperature.
- ii) Three equally spread starts in an hour the motor being initially at a temperature not exceeding the rated load operating temperature. (not to be repeated in the second successive hour)
- iii) Motors for coal conveyor and coal crusher application shall be suitable for three consecutive hot starts followed by one hour interval with maximum twenty starts per day and shall be suitable for minimum 20,000 starts during the life time of the motor

3.4 **Running Requirements**

3.4.1 Motors shall run satisfactorily at a supply voltage of 75% of rated voltage for 5 minutes with full load without injurious heating to the motor.

3.4.2 Motor shall not stall due to voltage dip in the system causing momentary drop in voltage upto 70% of the rated voltage for duration of 2 secs.

3.5 **Stress During bus Transfer**

3.5.1 Motors shall withstand the voltage, heavy inrush transient current, mechanical and torque stress developed due to the application of 150% of the rated voltage for at least 1 sec. caused due to vector difference between the motor residual voltage and the incoming supply voltage during occasional auto bus transfer.

3.5.2 Motor and driven equipment shafts shall be adequately sized to satisfactorily withstand transient torque under above condition.

3.6 Maximum noise level measured at distance of 1.0 metres from the outline of motor shall not exceed the values specified in IS 12065.

3.7 The max. vibration velocity or double amplitude of motors vibration as measured at motor bearings shall be within the limits specified in IS: 12075.


4.0 **CONSTRUCTIONAL FEATURES**

4.1 Indoor motors shall conform to degree of protection IP: 54 as per IS: 4691. Outdoor or semi-indoor motors shall conform to degree of protection IP: 55 as per IS: 4691 and shall be of weather-proof construction. Outdoor motors shall be installed under a suitable canopy


4.2 Motors upto 160KW shall have Totally Enclosed Fan Cooled (TEFC) enclosures, the method of cooling conforming to IC-0141 or IC-0151 of IS: 6362.

Motors rated above 160 KW shall be Closed Air Circuit Air (CACA) cooled

4.3 Motors shall be designed with cooling fans suitable for both directions of rotation.


	TITLE :	SPECIFICATION NO.
	GENERAL TECHNICAL REQUIREMENTS	PE-SS-999-506-E101
	FOR	VOLUME NO. : II-B
	LV MOTORS	SECTION : D
		REV NO. : 00 DATE : 29/08/2005
	SHEET : 3 OF 4	

- 4.4. Motors shall not be provided with any electric or pneumatic operated external fan for cooling the motors.
- 4.5. Frames shall be designed to avoid collection of moisture and all enclosures shall be provided with facility for drainage at the lowest point.
- 4.6. In case Class 'F' insulation is provided for LV motors, temperature rise shall be limited to the limits applicable to Class 'B' insulation.  
In case of continuous operation at extreme voltage limits the temperature limits specified in table-1 of IS:325 shall not exceed by more than 10°C.
- 4.7. **Terminals and Terminal Boxes**
- 4.7.1 Terminals, terminal leads, terminal boxes, windings tails and associated equipment shall be suitable for connection to a supply system having a short circuit level, specified in the Data Sheet-A.  
  
Unless otherwise stated in Data Sheet-A, motors of rating 110 kW and above will be controlled by circuit breaker and below 110 kW by switch fuse-contactor. The terminal box of motors shall be designed for the fault current mentioned in data sheet "A".
- 4.7.2 unless otherwise specified or approved, phase terminal boxes of horizontal motors shall be positioned on the left hand side of the motor when viewed from the non-driving end.
- 4.7.3 Connections shall be such that when the supply leads R, Y & B are connected to motor terminals A B & C or U, V & W respectively, motor shall rotate in an anticlockwise direction when viewed from the non-driving end. Where such motors require clockwise rotation, the supply leads R, Y, B will be connected to motor terminals A, C, B or U W & V respectively.
- 4.7.4 Permanently attached diagram and instruction plate made preferably of stainless steel shall be mounted inside terminal box cover giving the connection diagram for the desired direction of rotation and reverse rotation.
- 4.7.5 Motor terminals and terminal leads shall be fully insulated with no bar live parts. Adequate space shall be available inside the terminal box so that no difficulty is encountered for terminating the cable specified in Data Sheet-A.
- 4.7.6 Degree of protection for terminal boxes shall be IP 55 as per IS 4691.
- 4.7.7 Separate terminal boxes shall be provided for space heaters.. If this is not possible in case of LV motors, the space heater terminals shall be adequately segregated from the main terminals in the main terminal box. Detachable gland plates with double compression brass glands shall be provided in terminal boxes.
- 4.7.8. Phase terminal boxes shall be suitable for 360 degree of rotation in steps of 90 degree for LV motors.
- 4.7.9 Cable glands and cable lugs as per cable sizes specified in Data Sheet-A shall be included. Cable lugs shall be of tinned Copper, crimping type.
- 4.8 Two separate earthing terminals suitable for connecting G.I. or MS strip grounding conductor of size given in Data Sheet-A shall be provided on opposite sides of motor frame. Each terminal box shall have a grounding terminal.
- 4.9 **General**

	TITLE :	SPECIFICATION NO.
	GENERAL TECHNICAL REQUIREMENTS	PE-SS-999-506-E101
	FOR	VOLUME NO. : II-B
	LV MOTORS	SECTION : D
		REV NO. : 00 DATE : 29/08/2005
		SHEET : 4 OF 4

- 4.9.1 Motors provided for similar drives shall be interchangeable.
- 4.9.2 Suitable foundation bolts are to be supplied alongwith the motors.
- 4.9.3 Motors shall be provided with eye bolts, or other means to facilitate safe lifting if the weight is 20Kgs. and above.
- 4.9.4 Necessary fitments and accessories shall be provided on motors in accordance with the latest Indian Electricity rules 1956.
- 4.9.5 All motors rated above 30 kW shall be provided with space heaters to maintain the motor internal air temperature above the dew point. Unless otherwise specified, space heaters shall be suitable for a supply of 240V AC, single phase, 50 Hz.
- 4.9.6 Name plate with all particulars as per IS: 325 shall be provided
- 4.9.7 Unless otherwise specified, the colour of finish shall be grey to Shade No. 631 and 632 as per IS:5 for motors installed indoor and outdoor respectively. The paint shall be epoxy based and shall be suitable for withstanding specified site conditions.
- 5.0 INSPECTION AND TESTING**
- 5.1 All materials, components and equipments covered under this specification shall be procured, manufactured, as per the BHEL standard quality plan No. PED-506-00-Q-006/0 and PED-506-00-Q-007/2 enclosed with this specification and which shall be complied.
- 5.2 LV motors of type-tested design shall be provided. Valid type test reports not more than 5 year shall be furnished. In the absence of these, type tests shall have to be conducted by manufacturer without any commercial implication to purchaser.
- 5.3 All motors shall be subjected to routine tests as per IS: 325 and as per BHEL standard quality plan.
- 5.4 Motors shall also be subjected to additional tests, if any, as mentioned in Data Sheet A.
- 6.0 DRAWINGS TO BE SUBMITTED AFTER AWARD OF CONTRACT**
- a) OGA drawing showing the position of terminal boxes, earthing connections etc.
- b) Arrangement drawing of terminal boxes.
- c) Characteristic curves:  
(To be given for motor above 55 kW unless otherwise specified in Data Sheet).
- i) Current vs. time at rated voltage and minimum starting voltage.
- ii) Speed vs. time at rated voltage and minimum starting voltage.
- iii) Torque vs. speed at rated voltage and minimum voltage.  
For the motors with solid coupling the above curves i), ii), iii) to be furnished for the motors coupled with driven equipment. In case motor is coupled with mechanical equipment by fluid coupling, the above curves shall be furnished with and without coupling.
- iv) Thermal withstand curve under hot and cold conditions at rated voltage and max. permissible voltage.




		<b>STANDARD QUALITY PLAN</b>				SPEC. NO.:		DATE:	
		CUSTOMER :				QP NO.: PE-QP-999-Q-006, REV-02		DATE: 17.04.2020	
		PROJECT:				PO NO.:		DATE:	
		ITEM: AC ELECT. MOTORS UPTO 55KW (LV (415V))				SYSTEM: II		SECTION: II	

S. NO.	COMPONENT & OPERATIONS	CHARACTERISTICS	CLASS	TYPE OF CHECK	QUANTUM OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY	REMARKS
1	2	3	4	5	6	7	8	9	**	
					M C/ N			D	M C N	
		1.WORKMANSHIP	MA	VISUAL	100%	MFG. SPEC.	MFG. SPEC.	LOG BOOK	P -	-
		2.DIMENSIONS	MA	VISUAL	100%	MFG. DRG./ MFG. SPEC.	MFG. DRG./ MFG. SPEC.	LOG BOOK	P -	-
1.0	ASSEMBLY	3.CORRECTNESS COMPLETENESS TERMINATIONS/ MARKING/ COLOUR CODE	MA	VISUAL	100%	MFG.SPEC./	MFG.SPEC.	LOG BOOK	P -	-

2.0	PAINTING	1.SHADE	MA	VISUAL	SAMPLE	MFG. SPEC/ APPROVED DATASHEET	MFG. SPEC/ APPROVED DATASHEET	LOG BOOK	✓ P	V -
-----	----------	---------	----	--------	--------	-------------------------------------	-------------------------------------	----------	-----	-----

3.0	TESTS	1.ROUTINE TEST INCLUDING SPECIAL TEST	MA	VISUAL	100%	IS-325 / IS-12615 / APPROVED DATA SHEET	IS-325 / IS-12615 / APPROVED DATA SHEET	TEST/ INSPN. REPORT	✓ P	V -	* NOTE -1
		2.OVERALL DIMENSIONS & ORIENTATION	MA	MEASUREMENT & VISUAL	100%	APPROVED DRG/ DATA SHEET	APPROVED DRG/ DATA SHEET	TEST/ INSPN. REPORT	✓ P	V -	* NOTE -1 & NOTE-2

<b>BHEL</b>				<b>BIDDER/SUPPLIER</b>				<b>FOR CUSTOMER REVIEW &amp; APPROVAL</b>					
ENGINEERING		QUALITY		Sign & Date		Sign & Date		Doc No.:		Name		Seal	
Prepared by:	HEMA KUSHWAHA	Checked by:	KUNAL GANDHI	Sign & Date	Seal	Reviewed by:		Sign & Date		Name		Seal	
Reviewed by:	PRAVEEN DUTTA	Reviewed by:	RITESH KUMAR JAISWAL			Approved by:							

	<b>MANUFACTURER/ BIDDER/ SUPPLIER NAME &amp; ADDRESS</b>		<b>STANDARD QUALITY PLAN</b>				<b>SPEC. NO.:</b>	<b>DATE:</b>
	<b>CUSTOMER :</b>						<b>QP NO.:</b> PE-QP-999-Q-006, REV-02	<b>DATE:</b> 17.04.2020
	<b>PROJECT:</b>						<b>PO NO.:</b>	<b>DATE:</b>
	<b>ITEM: AC ELECT. MOTORS UPTO 55KW (LV (415V))</b>		<b>SYSTEM:</b>				<b>SECTION: II</b>	<b>SHEET 2 of 2</b>


	3.NAMEPLATE DETAILS	MA	VISUAL	100% -	IS-325 / IS-12615 / APPROVED DATA SHEET	SAME AS COL. 7	TEST/ INSPN. REPORT	✓	P	V	-
4.0	PACKING SURFACE FINISH & COMPLETENESS	MA	VISUAL	100%	AS PER MFG. STANDARD / (#)	AS PER MFG. STANDARD / (#)	INSPC. REPORT	✓	P	W	-

**NOTES:**





1. Routine tests on 100% motors shall be done by the vendor. However, BHEL/ Customer shall witness routine tests on random samples. The sampling plan shall be mutually agreed upon.
2. For exhaust/ventilation fan motors of rating up to 1.5 KW, only routine test certificates shall be furnished for scrutiny.
3. In case test certificates for these tests on similar type, size and design of motor from independent laboratory are available, the same is valid for 5 years.
4. BHEL reserves the right to perform repeat test, if required.
5. After packing and prior to issue MDCC, photographs of items to be despatched shall be sent to BHEL for review.
6. In case of any changes in QP commented by customer at contract stage, same shall be carried out by bidder without any implication to BHEL/ Customer.
7. Project specific QP to be developed based on customer requirement.
8. For export job, BHEL technical specification for seaworthy packing to be followed.
9. Packing shall be suitable for storage at site in tropical climate conditions.
10. Latest revision/ year of issue of all the standards (IS/ ASME/ IEC etc.) indicated in QP shall be referred.

**LEGENDS:**  
 \*RECORDS, IDENTIFIED WITH "TICK"(√) SHALL BE ESSENTIALLY INCLUDED BY SUPPLIER IN QA DOCUMENTATION,  
 \*\* M: SUPPLIER/MANUFACTURER/ SUB-SUPPLIER, B: MAIN SUPPLIER/ BHEL/ THIRD PARTY INSPECTION AGENCY, C: CUSTOMER,  
 P: PERFORM, W: WITNESS, V: VERIFICATION, AS APPROPRIATE  
 MA: MAJOR, MI: MINOR, CR: CRITICAL  
 D: DOCUMENTATION

<b>BHEL</b>				<b>BIDDER/SUPPLIER</b>				<b>FOR CUSTOMER REVIEW &amp; APPROVAL</b>							
<b>ENGINEERING</b>		<b>QUALITY</b>		<b>Sign &amp; Date</b>		<b>Sign &amp; Date</b>		<b>Doc No.:</b>		<b>Sign &amp; Date</b>		<b>Name</b>		<b>Seal</b>	
Prepared by:	HEMA KUSHWAHA	Checked by:	KUNAL GANDHI	Sign:		Sign:		Reviewed by:		Reviewed by:		Reviewed by:			
Reviewed by:	PRAVEEN DUTTA	Reviewed by:	RITESH KUMAR JAISWAL	Seal:		Seal:		Approved by:		Approved by:		Approved by:			


 <b>MANUFACTURER/ BIDDER/ SUPPLIER NAME &amp; ADDRESS</b>		<b>STANDARD QUALITY PLAN</b>	
		<b>CUSTOMER :</b> PE-QP-899-Q-007, REV-04 <b>DATE:</b> 17.04.2020	
		<b>PROJECT:</b>	
		<b>ITEM:</b> AC ELECT. MOTORS 55 KW & ABOVE (LV (415V)) <b>SYSTEM:</b>	
		<b>SPEC. NO :</b>	<b>SECTION: II</b>
		<b>OP NO:</b>	<b>SHEET 1 OF 9</b>

SI No.	Component & Operations	Characteristics	Class	Type of Check	Quantum Of check		Reference Document	Acceptance NORMS	FORMAT OF RECORD	AGENCY					
					M	C/N				D	M	C	N		
1	1.0 RAW MATERIAL & BOUGHT OUT CONTROL		4	5			7	8							
1.1	SHEET STEEL, PLATES, SECTION, EYEBOLTS	1.SURFACE CONDITION	MA	VISUAL	100%	-	-	FREE FROM BLINKS, CRACKS, DIPS, WELLS ETC	LOG BOOK		P	-	-		
		2.DIMENSIONS	MA	MEASUREMENT	SAMPLE	-	MANUFACTURER'S DRG./SPEC	MANUFACTURER'S DRG./SPEC	LOG BOOK		P	-	-		
		3.PROOF LOAD TEST (EYE BOLT)	MA	MECH. TEST	SAMPLE	-	MANUFACTURER'S DRG./SPEC	MANUFACTURER'S DRG./SPEC	TEST REPORT		P/V	-	-		
1.2	HARDWARES	1.SURFACE CONDITION	MA	VISUAL	100%	-	-	FREE FROM CRACKS, UNEVENNESS ETC.	TEST REPORT		P	-	-		
		2.PROPERTY CLASS	MA	VISUAL	SAMPLES	-	MANUFACTURER'S DRG./SPEC	MANUFACTURER'S DRG./SPEC	TC		P/V	-	-		PROPERTY CLASS MARKING SHALL BE CHECKED BY THE VENDOR
1.3	CASTING	1.SURFACE CONDITION	MA	VISUAL	100%	-	MANUFACTURER'S DRG./SPEC	FREE FROM CRACKS, DIPS, LOW HOLES ETC.	LOG BOOK		P/V	-	-		
		2.CHEM. & PHY. PROP.	MA	CHEM & MECH TEST	1/HEAT NO.	-	MANUFACTURER'S DRG./SPEC	MANUFACTURER'S DRG./SPEC	TC		P/V	-	-		HEAT NO. SHALL BE VERIFIED
		3.DIMENSIONS	MA	MEASUREMENT	100%	-	MANUFACTURER'S DRG.	MANUFACTURER'S DRG.	LOG BOOK		P/V	-	-		
1.4	PAIN & VARNISH	1.MAKE SHADE. SHELF LIFE & TYPE	MA	VISUAL	100% CONTINUOUS	-	MANUFACTURER'S DRG./SPEC	MANUFACTURER'S DRG./SPEC	LOG BOOK		P/V	-	-		

ENGINEERING		QUALITY	
Sign & Date	Name	Sign & Date	Name
 HEMA KUSHWAHA <small>MANUFACTURER/ BIDDER/ SUPPLIER</small>	HEMA KUSHWAHA	 RITESH JAINSWAL <small>QUALITY CONTROL</small>	KUNAL GANDHI
 PRAVEEN DUTTA <small>MANUFACTURER/ BIDDER/ SUPPLIER</small>	PRAVEEN DUTTA	 R K JAINSWAL <small>QUALITY CONTROL</small>	R K JAINSWAL

BIDDER/ SUPPLIER	
Sign & Date	
Seal	


FOR CUSTOMER REVIEW & APPROVAL	
Doc No.	
Sign & Date	Name
Seal	
Reviewed by:	
Approved by:	

	<b>STANDARD QUALITY PLAN</b>	<b>SPEC. NO. :</b>	
<b>MANUFACTURER/ BIDDER/ SUPPLIER NAME &amp; ADDRESS</b>		<b>CUSTOMER :</b>	GP NO.: PE-QP-989-Q-007, REV/04
		<b>PROJECT:</b>	DATE:17.04.2020
		<b>SYSTEM:</b>	SHEET 2 OF 9
		<b>ITEM:</b> AC ELECT. MOTORS 55 KW & ABOVE (LV (415V))	

Sl No.	Component & Operations	Characteristics	Class	Type of Check	Quantum Of check		Reference Document	Acceptance NORMIS	FORMAT OF RECORD	AGENCY										
					M	C/N				D	M	C	N							
1	SHAFT (FORGED OR ROLLED)	1. SURFACE COND. 2. CHEM. & PHYSICAL PROPERTIES 3. DIMENSIONS 4. INTERNAL FLAWS	MA	5	100%		7	8	LOG BOOK											
1.5			MA	VISUAL				FREE FROM VISUAL DEFECTS												
1.6	SPACE HEATERS, CONNECTORS, TERMINAL BLOCKS, CABLES, CABLE LUGS, CARBON BRUSH TEMP. DETECTORS, RTD, BTD'S	1. MAKE & RATING 2. PHYSICAL COND. 3. DIMENSIONS (WHEREVER APPLICABLE) 4. PERFORMANCE/ CALIBRATION	MA	5	100%		MANUFACTURER'S DRG./ SPEC.	MANUFACTURERS DRG./ STD.	TC											
			CR	ULTRASONIC TEST	100%		MANUFACTURER'S DRG./ SPEC.	MANUFACTURERS DRG.	LOG BOOK											
			MA	VISUAL	100%		ASTM-A388	MANUFACTURERS DRG./ STD.	INSPECTION REPORT											
			MA	VISUAL	100%		MANUFACTURER'S DRG./ STD.	MANUFACTURERS DRG./ STD.	INSPECTION REPORT											
			MA	MEASUREMENT	SAMPLE		MANUFACTURER'S DRG./ STD.	MANUFACTURERS DRG./ STD.	INSPECTION REPORT											
			MA	TEST	100%		MANUFACTURER'S DRG./ STD.	MANUFACTURERS DRG./ STD.	TEST REPORT											

BIDDER/ SUPPLIER	
Sign & Date	
Seal	

FOR CUSTOMER REVIEW & APPROVAL	
Doc No:	
Sign & Date	Seal
Reviewed by:	
Approved by:	

ENGINEERING		QUALITY	
Sign & Date	Name	Sign & Date	Name
HEMA KUSHWAHA	HEMA KHUSHWAHA		KUNAL GANDHI
Prepared by:	Checked by:	Reviewed by:	
PRAVEEN DUTTA	PRAVEEN DUTTA	RITESH JAIN	R. K. JAISWAL

**DUTTA**

MANUFACTURER'S SIGNATURE

MANUFACTURER'S NAME

MANUFACTURER'S ADDRESS

MANUFACTURER'S PHONE NO.

MANUFACTURER'S FAX NO.

MANUFACTURER'S E-MAIL ADDRESS

MANUFACTURER'S WEBSITE

MANUFACTURER'S CONTACT PERSON

MANUFACTURER'S CONTACT PERSON PHONE NO.

MANUFACTURER'S CONTACT PERSON E-MAIL ADDRESS

MANUFACTURER'S CONTACT PERSON WEBSITE

MANUFACTURER'S CONTACT PERSON ADDRESS

MANUFACTURER'S CONTACT PERSON CITY

MANUFACTURER'S CONTACT PERSON STATE

MANUFACTURER'S CONTACT PERSON COUNTRY

MANUFACTURER'S CONTACT PERSON ZIP CODE

MANUFACTURER'S CONTACT PERSON FAX NO.

MANUFACTURER'S CONTACT PERSON E-MAIL ADDRESS

MANUFACTURER'S CONTACT PERSON WEBSITE


MANUFACTURER'S CONTACT PERSON ADDRESS

MANUFACTURER'S CONTACT PERSON CITY

MANUFACTURER'S CONTACT PERSON STATE

MANUFACTURER'S CONTACT PERSON COUNTRY


MANUFACTURER'S CONTACT PERSON ZIP CODE


 <b>MANUFACTURER/ BIDDER/ SUPPLIER NAME &amp; ADDRESS</b>	<b>STANDARD QUALITY PLAN</b>		<b>SPEC. NO. :</b>	<b>DATE: 17.04.2020</b>
	<b>CUSTOMER :</b>		QP NO.: PE-QP-999-3-007, REV.04	
	<b>PROJECT:</b>		<b>PO NO.:</b>	
	<b>ITEM: AC ELECT. MOTORS 55 KW &amp; ABOVE (LV (415V))</b>		<b>SYSTEM: II</b>	
				<b>SHEET 3 OF 9</b>

SI No.	Component & Operations	Characteristics	Class	Type of Check	Quantum Of check		Reference Document	Acceptance NORMS	FORMAT OF RECORD	AGENCY					
					M	C/N				D	M	C	N		
1			4	5		M	7	8	9						
1.7	OTHER INSULATING MATERIALS LIKE SLEEVES, BINDINGS CORDS, PAPERS, PRESS BOARDS ETC.	1. SURFACE COND, ETC. 2. DIMENSION (BORE DIA, WALL THICKNESS, BDV AS RECEIVED, BDV AFTER FOLDING AT 180°)	MA	VISUAL	100%	-	-	NO VISUAL DEFECTS	TEST REPORT	P/V	-	-	-		
1.8	SHEET STAMPING (PUNCHED)	1. SURFACE COND. 2. DIMENSIONS INCLUDING BURS HEIGHT 3. ACCEPTANCE TESTS	MA	VISUAL	SAMPLE	-	MANUFACTURER'S STD.	MANUFACTURERS STD.	LOG BOOK & SUPPLIER'S TC	P/V	-	-	-		
1.9	CONDUCTORS	1. SURFACE FINISH 2. ELECT, PROP. & MECH. TESTS	MA	MEASUREMENT	SAMPLE	-	MANUFACTURER'S DRG.	MANUFACTURERS DRG.	LOG BOOK	P	-	-	-		
			MA	ELECT. & MECH TESTS	SAMPLE	-	MANUFACTURER'S DRG./ STD.	MANUFACTURER'S DRG./ STD.	LOG BOOK	P/V	-	-	-		
			MA	VISUAL	100%	-	-	FREE FROM VISUAL DEFECTS	LOG BOOK	*P/V	-	-	-		* MOTOR MANUFACTURER TO CONDUCT VISUAL CHECK FOR SURFACE FINISH ON PAPERWORKS AND MAINTAIN RECORD FOR VERIFICATION BY
			MA	ELECT. & MECH. TEST	SAMPLES	-	MANUFACTURER'S DRG./ SPEC.	MANUFACTURERS / SPEC.	TC & VENDOR'S TEST REPORTS	P/V	-	-	-		



<b>BIDDER/ SUPPLIER</b>	
Sign & Date	
Seal	

<b>FOR CUSTOMER REVIEW &amp; APPROVAL</b>	
Doc No:	
Sign & Date	Seal
Reviewed by:	
Approved by:	

<b>BHEL</b>		<b>QUALITY</b>	
Sign & Date	Name	Sign & Date	Name
HEMA KUSHWAHA	HEMA KHUSHWAHA		KUNAL GANDHI
Prepared by: PRAVEEN DUTTA	Checked by:	Reviewed by: R K JAISWAL	Reviewed by:


	<b>MANUFACTURER/ BIDDER/ SUPPLIER NAME &amp; ADDRESS</b>		<b>STANDARD QUALITY PLAN</b>		<b>SPEC. NO. :</b>	
			<b>CUSTOMER :</b>		<b>GP NO. : PE-QP-999-Q-007 , REV/04</b>	
			<b>PROJECT :</b>		<b>DATE:17.04.2020</b>	
			<b>ITEM: AC ELECT. MOTORS 55 KW &amp; ABOVE (LV (415V))</b>		<b>SECTION: II</b>	
				<b>SYSTEM:</b>		<b>SHEET 4 OF 9</b>

SI No.	Component & Operations	Characteristics	Class	Type of Check	Quantum Of check		Reference Document	Acceptance NORMS	FORMAT OF RECORD	AGENCY				
					M	C/N				D	M	C	N	
1			4	5	6	7	8	9						
1.10	BEARINGS	3.DIMENSIONS 1.MAKE & TYPE 2.DIMENSIONS 3.SURFACE FINISH	MA	MEASUREMENT VISUAL MEASUREMENT VISUAL	SAMPLES 100% SAMPLE 100%	MANUFACTURER'S DRG./ SPEC. MANUFACTURER'S DRG./ APPROVED DATASHEET APPROVED DATASHEET	MANUFACTURERS / SPEC. MANUFACTURERS DRG./ APPROVED DATASHEET APPROVED DATASHEET/ DRAWINGS MANUALS CATALOGUES FREE FROM VISUAL DEFECTS	LOG BOOK LOG BOOK LOG BOOK LOG BOOK	P/V P/V P/V P/V					
1.11	SUJ RING (WHEREVER APPLICABLE)	1.SURFACE COND. 2.DIMENSIONS 3.TEMP WITH STAND CAPACITY	MA	VISUAL MEASUREMENT ELECT.TEST	100% SAMPLE SAMPLE	- MANUFACTURER'S DRG MANUFACTURERS STD./APPROVED DATASHEET	FREE FROM VISUAL DEFECTS FREE FROM VISUAL DEFECTS MANUFACTURERS DRG	LOG BOOK LOG BOOK LOG BOOK	P P P/V					
1.12	OIL SEALS & GASKETS	1.MATERIAL OF GASKET 2.SURFACE COND. 3.DIMENSIONS	MA	-O-O- VISUAL VISUAL MEASUREMENT	100% 100% 100% SAMPLE	MANUFACTURER'S STD./APPROVED DATASHEET MANUFACTURERS DRG/SPECS MANUFACTURERS DRG	MANUFACTURERS STD./APPROVED DATASHEET MANUFACTURERS STD./APPROVED DATASHEET FREE FROM VISUAL DEFECTS MANUFACTURERS DRG	LOG BOOK LOG BOOK LOG BOOK LOG BOOK	P/V P/V P P					





ENGINEERING				QUALITY			
Sign & Date	Name	Sign & Date	Name				
 HEMA KUSHWAHA	HEMA KHUSHWAHA	 RITESH KUMAR	KUNAL GANDHI				
Prepared by: PRAVEEN DUTTA		Checked by:	R K JAISWAL				
Reviewed by:		Reviewed by:					

BIDDER/ SUPPLIER	
Sign & Date	
Seal	

FOR CUSTOMER REVIEW & APPROVAL			
Doc No.		Sign & Date	Seal
Reviewed by:		Name	
Approved by:			


	<b>STANDARD QUALITY PLAN</b>		<b>SPEC. NO. :</b>
	<b>CUSTOMER :</b>		QP NO.: PE-QIP-999-Q-007, REV-04
	<b>PROJECT:</b>		DATE: 17.04.2020
	<b>ITEM: AC ELECT. MOTORS 55 KW &amp; ABOVE (LV (415V))</b>		<b>SECTION: II</b>
<b>MANUFACTURER/ BIDDER/ SUPPLIER NAME &amp; ADDRESS</b>			<b>SYSTEM: II</b>
			<b>SHEET 5 OF 9</b>

SI No.	Component & Operations	Characteristics	Class	Type of Check	Quantum Of check	Reference Document	Acceptance NORMS	FORMAT OF RECORD	AGENCY
1			4	5	6	7	8	9	
					M			D	M C N
2.0	IN PROCESS								
2.1	STATOR FRAME WELDING (IN CASE OF FABRICATED STATOR)	1.WORKMANSHIP & CLEANNESS 2.DIMENSIONS	MA	VISUAL MEASUREMENT	100% 100%	MANUFACTURER'S DRG	GOOD FINISH MANUFACTURER'S DRG	LOG BOOK LOG BOOK	PIW P
2.2	MACHINING	1.FINISH 2.DIMENSIONS 3.SHAFT SURFACE FLOWS	MA	VISUAL MEASUREMENT PT	100% 100% 100%	-DO- MANUFACTURER'S DRG MANUFACTURER'S STD./APPROVED DATASHEET.	GOOD FINISH MANUFACTURER'S DRG MANUFACTURER'S DRG	LOG BOOK LOG BOOK LOG BOOK	P P P
2.3	PAINTING	1.SURFACE PREPARATION 2.PAINT THICKNESS (BOTH PRIMER & FINISH COAT) 3.SHADE 4.ADHESSION	MA	VISUAL MEASUREMENT BYELOCOMETER VISUAL CROSS CUTTING & TAPE TEST	100% SAMPLE SAMPLE SAMPLE	MANUFACTURER'S STD./APPROVED DATASHEET MANUFACTURER'S STD./APPROVED DATASHEET MANUFACTURER'S STD./APPROVED DATASHEET	MANUFACTURER'S STD./APPROVED DATASHEET. ASTM E165 MANUFACTURER'S STD./APPROVED DATASHEET	LOG BOOK LOG BOOK LOG BOOK	✓ P P P


ENGINEERING			QUALITY		
Sign & Date	Name		Sign & Date	Name	
	HEMA KUSHWAHA	Checked by:		KUNAL GANDHI	
	PRAVEEN DUTTA	Reviewed by:		R. K. JAISWAL	

BIDDER/ SUPPLIER	
Sign & Date	
Seal	

FOR CUSTOMER REVIEW & APPROVAL		
Doc No.		
Sign & Date	Name	Seal
Reviewed by:		
Approved by:		

	<b>STANDARD QUALITY PLAN</b>	<b>SPEC. NO. :</b>
<b>MANUFACTURER/ BIDDER/ SUPPLIER NAME &amp; ADDRESS</b>	<b>CUSTOMER :</b>	<b>GP NO.:</b> PE-QP-989-Q-007, REV/04
<b>PROJECT:</b>	<b>SYSTEM:</b>	<b>DATE:</b> 17.04.2020
<b>ITEM: AC ELECT. MOTORS 55 KW &amp; ABOVE (LV (415V))</b>	<b>SECTION: II</b>	<b>SHEET 6 OF 9</b>


SI No.	Component & Operations	Characteristics	Class	Type of Check	Quantum Of check		Reference Document	Acceptance NORMS	FORMAT OF RECORD	AGENCY				
					M	C/N				D	M	C	N	
1			4	5	6	7	8	9	*	**				
2.4	SHEET STACKING	1.COMPLETENESS 2.COMPRESSION & TIGHTENING	MA	MEASUREMENT	SAMPLE	MANUFACTURER'S STD,	MANUFACTURERS STD,	LOG BOOK		P				
2.5	WINDING	1.COMPLETENESS 2.CLEANLINESS 3.IR-HVR 4.RESISTANCE 5.INTERTURN INSULATION	CR	MEASUREMENT VISUAL VISUAL ELECT. TEST ELECT. TEST ELECT. TEST	100% 100% 100% 100% 100%	MANUFACTURER'S STD, MANUFACTURER'S STD, MANUFACTURER'S STD/APPROVED DATASHEET	MANUFACTURERS STD, MANUFACTURERS STD, MANUFACTURERS STD/APPROVED DATASHEET	LOG BOOK LOG BOOK LOG BOOK		P P P				
2.6	IMPREGNATION	1.VISCOSITY 2.TEMP. PRESSURE VACUUM 3.NO. OF DIPS	MA	PHY. TEST PROCESS CHECK PROCESS CHECK	AT STARTING CONTINUOUS CONTINUOUS	MANUFACTURER'S STANDARD MANUFACTURER'S STANDARD MANUFACTURER'S STANDARD	MANUFACTURERS STANDARD MANUFACTURERS STANDARD MANUFACTURERS STANDARD	LOG BOOK LOG BOOK LOG BOOK		P P P				THREE DIPS TO BE GIVEN

<b>ENGINEERING</b>		<b>BHEL</b>		<b>QUALITY</b>	
Sign & Date	Name	Sign & Date	Name	Sign & Date	Name
HEMA KUSHWAHA	HEMA KHUSHWAHA		KUNAL GANDHI		
Prepared by:		Checked by:		Reviewed by:	
PRAVEEN DUTTA		PRAVEEN DUTTA		RITESH KUMAR JAIN	





**FOR CUSTOMER REVIEW & APPROVAL**

Doc No.	Sign & Date	Name	Seal
Reviewed by:			
Approved by:			



	<b>MANUFACTURER/ BIDDER/ SUPPLIER NAME &amp; ADDRESS</b>		<b>STANDARD QUALITY PLAN</b>		<b>SPEC. NO. :</b>	
	CUSTOMER :		GP NO.: PE-QP-99-Q-007, REV/04		DATE:17.04.2020	
	PROJECT:		ITEM: AC ELECT. MOTORS 55 KW & ABOVE (LV (415V))		SYSTEM: II	
	SECTION: II		SHEET 7 OF 9			


SI No.	Component & Operations	Characteristics	Class	Type of Check	Quantum Of check		Reference Document	Acceptance NORMS	FORMAT OF RECORD	AGENCY				
					M	C/N				D	M	C	N	
1			4	5	6	7	8	9	*	**				
2.7	COMPLETE STATOR ASSEMBLY	4.DURATION 1.COMPACTNESS & CLEANLINESS	MA	PROCESS CHECK VISUAL	CONTINUOUS	MANUFACTURER'S STANDARD	MANUFACTURER'S STANDARD	LOG BOOK	✓	P	V	-		
2.8	BRAZING/COMPRESSION JOINT	1.COMPLETENESS 2.SOUNDNESS	CR	VISUAL	100%	MANUFACTURER'S STANDARD	MANUFACTURER'S STANDARD	LOG BOOK		P	-	-		
2.9	COMPLETE ROTOR ASSEMBLY	3.HV 1.RESIDUAL UNBALANCE	CR	MALLET TEST & UT ELECT. TEST DYN.BALANCE	100%	MANUFACTURER'S STANDARD	MANUFACTURER'S STANDARD	TEST/INSP. REPORT	✓	P	-	-		
2.10	ASSEMBLY	2.SOUNDNESS OF THE CASTING 1.ALIGNMENT 2.WORKMANSHIP 3.AXIAL PLAY 4.DIMENSIONS 5.CORRECTNESS, COMPLETENESS, TERMINATIONS/ COLOUR CODE 6. RTD, BTD & SPACE HEATER MOUNTING.	CR	ELECT. CHECKER (TEST) MEAS. VISUAL MEAS. MEAS. VISUAL	100%	MANUFACTURER'S SPEC./ ISO 1840	MANUFACTURER'S SPEC.	TEST/INSP. REPORT	✓	P	-	-		
			MA	MEAS.	100%	MANUFACTURER'S SPEC.	MANUFACTURER'S SPEC.	LOG BOOK		P	-	-		
			MA	MEAS.	100%	MANUFACTURER'S SPEC.	MANUFACTURER'S SPEC.	LOG BOOK		P	-	-		
			MA	MEAS.	100%	MANUFACTURER'S DRG/ MANUFACTURER'S SPEC.	MANUFACTURER'S SPEC.	LOG BOOK	✓	P	V	-		
			MA	MEAS.	100%	MANUFACTURER'S SPEC.	MANUFACTURER'S SPEC.	LOG BOOK		P	-	-		
			MA	VISUAL	100%	MANUFACTURER'S SPEC.	MANUFACTURER'S SPEC.	LOG BOOK	✓	P	-	-		

ENGINEERING			QUALITY		
Sign & Date	Name		Sign & Date	Name	
 HEMA KUSHWAHA	HEMA KHUSHWAHA	Checked by:	 RITESH KUMAR	KUNAL GANDHI	
 PRAVEEN DUTTA	PRAVEEN DUTTA	Reviewed by:	 R K JAISWAL	R K JAISWAL	

<b>BIDDER/ SUPPLIER</b>	
Sign & Date	
Seal	

<b>FOR CUSTOMER REVIEW &amp; APPROVAL</b>	
Doc No:	
Sign & Date	Seal
Reviewed by:	
Approved by:	





	<b>MANUFACTURER/ BIDDER/ SUPPLIER NAME &amp; ADDRESS</b>	<b>STANDARD QUALITY PLAN</b>	<b>SPEC. NO :</b>
		<b>CUSTOMER :</b>	QP NO.: PE-OP-999-007, REV:04
		<b>PROJECT:</b>	DATE:17.04.2020
		<b>ITEM: AC ELECT. MOTORS 55 KW &amp; ABOVE (LV (415V))</b>	<b>SECTION: II</b>
		<b>SYSTEM:</b>	<b>SHEET 9 OF 9</b>

SI No.	Component & Operations	Characteristics	Class	Type of Check	Quantum Of check	Reference Document	Acceptance NORMS	FORMAT OF RECORD	AGENCY
1	2	3	4	5	6	7	8	9	
	PACKING	SURFACE FINISH & COMPLETENESS	MA	VISUAL	100%	AS PER MANUFACT. STANDARD / (#)	AS PER MANUFACT. STANDARD / (#)	INSPC. REPORT	
					M			D	M C N
					C/N			✓	P W -
					100%				

- NOTES:**
- 1 DEPENDING UPON THE SIZE AND CRITICALLY, WITNESSING BY BHEL SHALL BE DECIDED.
  - 2 ROUTINE TESTS ON 100% MOTORS SHALL BE DONE BY THE VENDOR, HOWEVER, BHEL/CUSTOMER SHALL WITNESS ROUTINE TESTS ON RANDOM SAMPLES. THE SAMPLING PLAN SHALL BE MUTUALLY AGREED UPON.
  - 3 IN CASE TEST CERTIFICATES FOR THESE TESTS ON SIMILAR TYPE, SIZE AND DESIGN OF MOTOR FROM INDEPENDENT LABORATORY ARE AVAILABLE, THE SAME IS VALID FOR 5 YEARS.
  - 4 BHEL RESERVES THE RIGHT TO PERFORM REPEAT TEST, IF REQUIRED.
  - 5 AFTER PACKING AND PRIOR TO ISSUE MDCC, PHOTOGRAPHS OF ITEMS TO BE DESPATCHED SHALL BE SENT TO BHEL PURCHASE GROUP FOR REVIEW.
  - 6 IN CASE , ANY CHANGES IN QP COMMENTED BY CUSTOMER AT CONTRACT STAGE SHALL BE CARRIED OUT BY BIDDER WITHOUT ANY IMPLICATION TO BHEL/ CUSTOMER.
  - 7 PROJECT SPECIFIC QP TO BE DEVELOPED BASED ON CUSTOMER REQUIREMENT.
  - 8 FOR EXPORT JOB, BHEL TECHNICAL SPECIFICATION FOR SEAWORTHY PACKING TO BE FOLLOWED.
  - 9 PACKING SHALL BE SUITABLE FOR STORAGE AT SITE IN TROPICAL CLIMATE CONDITIONS.
  - 10 LATEST REVISION/ YEAR OF ISSUE OF ALL THE STANDARDS (ISI/ ASME/ IEC ETC.) INDICATED IN QP SHALL BE REFERRED.


**LEGENDS:**  
 \*RECORDS, IDENTIFIED WITH "TICK"(✓) SHALL BE ESSENTIALLY INCLUDED BY SUPPLIER IN QA DOCUMENTATION.  
 \*\* M: SUPPLIER/ MANUFACTURER/ SUB-SUPPLIER; B: MAIN SUPPLIER/ BHEL/ THIRD PARTY INSPECTION AGENCY; C: CUSTOMER,  
 P: PERFORM; W: WITNESS; V: VERIFICATION, AS APPROPRIATE  
 MA: MAJOR; MI: MINOR; CR: CRITICAL  
 D: DOCUMENT

BHEL		QUALITY	
ENGINEERING		Sign & Date	Name
Prepared by: HEMA KHUSHWAHA	Checked by: HEMA KHUSHWAHA		KUNAL GANDHI
Reviewed by: PRAVEEN DUTTA	Reviewed by: PRAVEEN DUTTA		R K JAISWAL

BIDDER/ SUPPLIER	
Sign & Date	
Seal	

FOR CUSTOMER REVIEW & APPROVAL	
Doc No:	
Reviewed by:	Sign & Date
Approved by:	Name
	Seal

672753/2022/PS-PEM-MIS

	<b>TECHNICAL SPECIFICATION MISCELLANEOUS PUMPS</b>	SPEC. NO.: <b>PE-TS-483-100-N001</b>	
		SECTION: <b>III</b>	
		SUB-SECTION:	
		REV. NO. <b>01</b>	DATE <b>03.02.2022</b>
		SHEET <b>1</b>	OF <b>1</b>
<b>STANDARD TECHNICAL REQUIREMENTS</b>			

### **SECTION III**


**DOCUMENTS TO BE SUBMITTED BY BIDDER**

672753/2022/PS-PEM-MIS

	<b>TECHNICAL SPECIFICATION MISCELLANEOUS PUMPS</b>	SPEC. NO.: <b>PE-TS-483-100-N001</b>	
		SECTION: <b>IIIA</b>	
		SUB-SECTION:	
		REV. NO. <b>01</b>	DATE <b>03.02.2022</b>
		SHEET <b>1</b>	OF <b>1</b>
<b>STANDARD TECHNICAL REQUIREMENTS</b>			

### **SECTION IIIA**

**GUARANTEE SCHEDULE  
(TO BE SUBMITTED ALONG WITH THE BID BY ALL BIDDERS)**

		SPECIFICATION NO.: PE-TS-483-100-N001, Rev-01	
677153/02/PS-PEM-MSE		VOLUME: --	SECTION: IIIA Sheet 1 of 1
SCHEDULE OF PERFORMANCE GUARANTEES NTPL 2X500 MW TUTICORIN -FGD PROJECT		REV. NO. 01	DATE: 03.02.2022

**Following parameters are guaranteed for following pumps**

Sl. No.	Pump Description	Guaranteed Capacity	Guaranteed TDH	Guaranteed Pump Eff.	Guaranteed Motor Eff.	Guaranteed Power consumption at inlet to motor terminals	Motor Rating	Motor GD <sup>2</sup> Value for HT motor only	Pump RPM	T/S Curve attached for HT motor
	<b>Horizontal pumps</b>	(M3/Hr)	(MWC)	%	%	(KW)	(KW)			
1	#DMCW PUMPS	73	76							
2	#ACW PUMPS	73	28							


Note: 1 # Bid evaluation and LD is applicable for these pumps only as per clause 4.00.00 of Section-IIA, Data Sheet-A of Section-ID and clause 1.8 of Section IA of Technical Specification for pumps.

We the undersigned hereby undertake to meet the performance guarantees as listed in the table above on the conditions as elsewhere specified. Any variation of the specified conditions during official tests will be taken in account by the customer

PARTICULARS OF BIDDER/ AUTHORISED REPRESENTATIVE

NAME	DESIGNATION	SIGNATURE	DATE	COMPANY SEAL
------	-------------	-----------	------	--------------

672753/2022/PS-PEM-MIS

	<b>TECHNICAL SPECIFICATION MISCELLANEOUS PUMPS</b>	SPEC. NO.: <b>PE-TS-483-100-N001</b>	
		SECTION: <b>IIIB</b>	
		SUB-SECTION:	
		REV. NO. <b>01</b>	DATE <b>03.02.2022</b>
		SHEET <b>1</b>	OF <b>1</b>
<b>STANDARD TECHNICAL REQUIREMENTS</b>			

## SECTION IIIB

**COMPLIANCE CERTIFICATE  
(TO BE SUBMITTED ALONG WITH THE BID BY ALL BIDDERS)**

672750007/PS-PEM/MSE



TECHNICAL SPECIFICATIONS MISCELLANEOUS PUMPS	SPECIFICATION NO.:	PE-TS-483-100-N001, Rev.01		
NTPL 2X500 MW TUTICORIN-FGD PROJECT	VOLUME:	--	SECTION:	IIIB
COMPLIANCE CERTIFICATE	REV. NO.	01	DATE:	03.02.2022

The bidder shall confirm compliance with following by signing/ stamping this compliance certificate and furnish same with the offer.

- a) The scope of supply, technical details, construction features, design parameters etc. shall be as per technical specification & there are no exclusions/ deviations with regard to same.
- b) QP/ test procedures shall be submitted in the event of order based on the guidelines given in the specification & QP enclosed therein.  
  
QP will be subject to BHEL/ CONSULTANT/ CUSTOMER approval in the event of order & customer hold points for inspection/ testing shall be marked in the QP at the contract stage. Inspection/ testing shall be witnessed as per same apart from review of various test certificates/ Inspection records etc.
- c) All drawings/data – sheets etc. to be submitted during contract shall be subject to BHEL/ CONSULTANT/ CUSTOMER approval.
- d) There are no other deviation with respect to specification other than those furnished in the 'Schedule of Deviations'.
- e) Bidder shall include the cost of Mandatory Spares, unless specified otherwise in Sec-IA of the specification or NIT.  
  
Any mandatory spares stated as not applicable, shall have to be supplied without any cost implication to BHEL in the event they are found to be applicable during detail engineering stage.
- f) The offered materials should be either equivalent or superior to those specified. Also for components where material is not specified it shall be suitable for intended duty. All materials shall be subject to approval in the event of order.
- g) Prices for recommended spares (if any) for 3 years operation shall be furnished separately & not included in the base price.
- h) The commissioning spares (if any) are supplied on 'As Required Basis' & prices for same included in the base price (If bidders reply to this is "No commissioning spares are required" and if some spares are actually required during commissioning same shall be supplied by bidder without any cost to BHEL).
- i) All sub vendors shall be as per BHEL/CONSULTANT/CUSTOMER approved list.
- j) Tests for noise, vibration, parallel running etc. for pumps shall be conducted at site by Pump Vendor/BHEL as per cl. no. 3.04.00 of Section-IIA and if the site performance is found not meeting the requirements in any respect as specified, than the equipment shall be rectified or replaced by the vendor, at his own cost.
- k) Any special tools & tackles, if required, shall be in bidder's scope.
- l) All models offered have been supplied by bidder in the past and are meeting the experience qualifying criteria of BHEL/CONSULTANT/CUSTOMER (viz. offered model is successfully operating in two separate stations for at least one year or as specified in technical PQR). Any deviation to this criteria shall be suitably highlighted in deviation schedule.
- m) All selected motor ratings have minimum margins as per Datasheet A, Section ID.

We the undersigned hereby undertake to meet the compliance requirements as listed above on the conditions as elsewhere specified.

PARTICULARS OF BIDDER/ AUTHORISED REPRESENTATIVE

NAME	DESIGNATION	SIGNATURE	DATE	COMPANY SEAL
------	-------------	-----------	------	--------------



672753/2022/PS-PEM-MIS

	<b>TECHNICAL SPECIFICATION MISCELLANEOUS PUMPS</b>	SPEC. NO.: <b>PE-TS-483-100-N001</b>	
		SECTION: <b>IIIC</b>	
		SUB-SECTION:	
		REV. NO. <b>01</b>	DATE <b>03.02.2022</b>
		SHEET <b>1</b>	OF <b>1</b>
<b>STANDARD TECHNICAL REQUIREMENTS</b>			

## SECTION IIIC

### DEVIATION SCHEDULE

**(TO BE SUBMITTED ALONG WITH THE BID BY ALL BIDDERS AS PER NIT  
FORMAT)**

672753/2022/PS-PEM-MIS

	<b>TECHNICAL SPECIFICATION MISCELLANEOUS PUMPS</b>	SPEC. NO.: <b>PE-TS-483-100-N001</b>	
		SECTION: <b>IIID</b>	
		SUB-SECTION:	
		REV. NO. <b>01</b>	DATE <b>03.02.2022</b>
		SHEET <b>1</b>	OF <b>1</b>
<b>STANDARD TECHNICAL REQUIREMENTS</b>			

### **SECTION IIID**


**DATA SHEET – B FOR PUMPS (FORMAT ATTACHED)**

**ELECTRICAL LOAD DATA (FORMAT ATTACHED)**

**CABLE SCHEDULE (FORMAT ATTACHED)**

**MOTOR DATASHEET (FORMAT ATTACHED)**


**(TO BE SUBMITTED BY SUCCESSFUL BIDDER AFTER AWARD OF  
CONTRACT)**

		PROJECT:	
MISE		MISCELLANEOUS PUMPS	
		DATASHEET - B	
SL.	DESCRIPTION	UOM	PUMP DATA
<b>1.0</b>	<b>GENERAL</b>		
1.1	Designation of the Pump		
1.2	Manufacturer		
1.3	Model No.		
1.4	No. of pumps	Nos.	
1.5	System Design Pressure	Kg/cm <sup>2</sup>	
1.6	Specific Gravity of fluid to be handled	-	
<b>2.0</b>	<b>PERFORMANCE PARAMETERS</b>		
2.1	Performance standard		
2.2	Rated capacity. (No negative tolerance)	M <sup>3</sup> /hr	
2.3	Total Dynamic Head (TDH) at rated capacity (No negative tolerance)	MWC	
2.4	Shut off head	MWC	
2.5	Range of Operation of the Pump		
	a) Min.Flow	M <sup>3</sup> /hr	
	b) Max.Flow	M <sup>3</sup> /hr	
2.6	The pumps offered have continuously rising head capacity curves from the duty point towards shut off point.		
2.7	The pumps offered have stable rising H-Q curves within the "Range of Operation"		
2.8	Pump rated speed	RPM	
2.9	Vibration measurements (2.9.2 is applicable in addition to 2.9.1 for Pumps with speed less than 600 RPM )		
2.9.1	Max.value of vibration on any pump /motor bearing w.r.t. velocity (Vrms) as per ANSI/ HIS 9.6.4 for speed > 600 RPM		
	a) Guaranteed at manufacturer's works	mm/s	
	b) Guaranteed at site	mm/s	
2.9.2	Max.value of vibration on any pump /motor bearing w.r.t. peak to peak amplitude as per ANSI/ HIS 9.6.4 for speed <= 600 RPM		
	a) Guaranteed at manufacturer's works	microns	
	b) Guaranteed at site	microns	
2.10	Max. noise Level (Guaranteed at site)	dB	
2.11	Guaranteed Pump efficiency at rated head & rated capacity without -ve tolerance	%	
2.12	Power consumption		
	a) Guaranteed pump input power at duty point	KW	
	b) Guaranteed max. Pump input power within range of operation.	KW	
	c) Max. pump input power at shut off	KW	
	d) Guranteed power at motor input	KW	
2.13	NPSH required at rated capacity	MWC	
<b>3.0</b>	<b>DESIGN &amp; CONSTRUCTION FEATURES</b>		
3.1	Type of pump casing		
3.2	Pump duty		
3.3	Type of Impeller		
3.4	Location		
3.5	Pump suitable for parallel operation		
3.6	Torque speed curve of the pump & drive motor furnished for pumps with drive motor rating of 100 KW and above.		
3.7	Pump number of stages		

672753/2022/PS

PROJECT:			
MISCELLANEOUS PUMPS			
DATASHEET - B			
SL.	DESCRIPTION	UOM	PUMP DATA
3.8	Specific speed $N = \frac{\text{RPM} \times (\text{Flow in USGPM})^{1/2}}{(\text{Head in Ft.})^{3/4}}$		
3.9	Minimum suction head required in MLC for pump operation at maximum discharge point within the 'Range of Operation' specified (NPSHR at max. flow).		
3.10	Whether pump is suitable/designed so that pump internals can be attended without disturbing suction and discharge piping.		
3.11	Type of coupling between pump & motor		
3.12	Bearing (DE & NDE)		
	a) Type and manufacturer		
	b) Bearing no.		
	c) Type of lubrication		
	d) Design life (Hrs.)		
3.13	Shaft Sealing arrangement		
	a) Type and manufacturer		
	b) Sealing liquid		
	c) Requirement of external water if any		
	i) Quality		
	ii) Quantity/ Pump	M <sup>3</sup> /hr	
3.14	In case separate oil/grease/water pump or any such equipment required for bearing lubrication/stuffing box gland sealing, furnish full technical details of these equipment and their drive.		
<b>4.0</b>	<b>MATERIAL OF CONSTRUCTION (Indicate applicable code/ standard)</b>		
4.1	Casing		
4.2	Impeller		
4.3	Shaft		
4.4	Shaft sleeves		
4.5	Wear ring		
4.6	fasteners		
4.7	Gland		
4.8	Lantern ring		
4.9	Mechanical seals (faces)/ Gland packing		
4.10	Base plate		
<b>5.0</b>	<b>CONNECTIONS AND OTHER DIMENSIONAL DETAILS</b>		
5.1	Impeller diameter	mm	
<b>6.0</b>	<b>DRIVE DATA</b>		
6.1	Drive unit output at 50°C ambient condition	KW/ P	
<b>7.0</b>	<b>INSPECTION &amp; TESTING</b>		
7.1	Material test		
7.2	Hydrostatic test pressure	Kg/cm <sup>2</sup>	
7.3	Hydrostatic test duration	Min.	
7.4	Performance test on pump at shop		
7.5	Dyanamic balance test		
<b>8.0</b>	<b>WEIGHT AND LOADING DATA</b>		
8.1	Weight of the pump & drive assembly	Kg	
8.2	Weight of the heaviest piece to be handled	Kg	

672753/2022/PS

		PROJECT: MISCELLANEOUS PUMPS DATASHEET - B	
SL.	DESCRIPTION	UOM	PUMP DATA
8.3	Size of base plate (length x width)	mm	
<b>9.0</b>	<b>ADDITIONAL INFORMATION FOR VERTICAL PUMPS</b>		
9.1	Type of pump		
9.2	No. of stages for Vertical Turbine Pump	Nos.	
9.3	Bowl Head	MLC	
9.4	Bowl Efficiency	%	
9.5	Setting Length	m	
9.6	Column pipe OD X Thickness	mm X mm	
9.7	No of column pieces	Nos.	
9.8	No of intermediate shafts	Nos.	
9.9	No of bearings	Nos.	
9.10	Type & make of Bearing		
9.11	Sealing/lubrication arrangement of bearings		
9.12	Capacity of overhead forced lubrication tank	m <sup>3</sup>	
9.13	Nos of forced lubrication pumps	Nos.	
9.14	Capacity of forced lubrication pumps	m <sup>3</sup> /Hr	
9.15	TDH of forced lubrication pumps	MLC	





672753/2022/PS-PEM-MSE


	TITLE	<p style="text-align: center;"><b>MOTORS</b></p> <p style="text-align: center;"><b>DATA SHEET – C</b></p> <p style="text-align: center;">2x500 MW NLC Tamil Nadu Power Ltd.</p>	SPECIFICATION NO.
			VOLUME II B
			SECTION D
			REV NO. 00 DATE 21.07.2021
			SHEET 1 OF 2

S. No.	Description	Data to be filled by successful bidder
<b>A.</b>	<b>General</b>	
1	Manufacturer & country of origin	
2	Motor type	
3	Type of starting	
4	Name of the equipment driven by motor & Quantity	
5	Maximum Power requirement of driven equipment	
6	Rated speed of Driven Equipment	
7	Design ambient temperature	
<b>B.</b>	<b>Design and Performance Data</b>	
1	Frame size & type designation	
2	Type of duty	
3	Rated Voltage	
4	Permissible variation for	
5	a) Voltage	
6	b) Frequency	
7	c) Combined voltage & frequency	
8	Rated output at design ambient temp (by resistance method)	
9	Synchronous speed & Rated slip	
10	Minimum permissible starting voltage	
11	Starting time in sec with mechanism coupled	
12	a) At rated voltage	
13	b) At min starting voltage	
14	Locked rotor current as percentage of FLC (including IS tolerance)	
15	Torque	
	a) Starting	
	b) Maximum	
16	Permissible temp rise at rated output over ambient temp & method	
17	Noise level at 1.0 m (dB)	
18	Amplitude of vibration	
19	Efficiency & P.F. at rated voltage & frequency	
	a) At 100% load	
	c) At 75% load	

NAME OF VENDOR			SEAL	REV.	
NAME	SIGNATURE	DATE			



672753/2022/PS-PEM-MSE

	TITLE	<b>MOTORS</b> <b>DATA SHEET – C</b>  2x500 MW NLC Tamil Nadu Power Ltd.	SPECIFICATION NO.
	VOLUME	II B	
	SECTION	D	
	REV NO. 00	DATE 21.07.2021	
	SHEET	2 OF 2	

S. No.	Description	Data to be filled by successful bidder
	c) At starting	
<b>C.</b>	<b>Constructional Features</b>	
1	Method of connection of motor driven equipment	
2	Applicable Standard	
3	DOP of Enclosure	
4	Method of cooling	
5	Class of insulation	
6	Main terminal box	
	a) Type	
	b) Power Cable details (Conductor, size, armour/unarmour)	
	c) Cable Gland & lugs details (Size, type & material)	
	d) Permissible Fault level ( kArms & duration in sec)	
7	Space heater details (Voltage & watts)	
8	Flame proof motor details (if applicable)	
	a) Enclosure	
	b) suitability for hazardous area	
	i Zone	O / I / II
	ii Group	IIA / IIB / IIC
9	No. of Stator winding	
10	Winding connection	
11	Kind of rotor winding	
12	Kind of bearings	
13	Direction of rotation when viewed from NDE	
14	Paint Shade & type	
15	Net weight of motor	
16	Outline mounting drawing No (To be enclosed as annexure)	
<b>D.</b>	<b>Characteristic curves/ drawings</b> (To be enclosed for motors of rating $\geq 55$ KW)	
	a) Torque speed characteristic	
	b) Thermal withstand characteristic	
	c) Current vs time	
	d) Speed vs time	

NAME OF VENDOR			SEAL	REV.	
NAME	SIGNATURE	DATE			