
	PROJECT: 2X660 MW DVC RAGHUNATHPUR TPS PH-II SG ISLAND PACKAGE TECHNICAL PREQUALIFYING REQUIREMENT FOR WIND TUNNEL STUDY OF CHIMNEY	DOCUMENT NO. PE-TS-528-600-C031
		REV.NO. 0
		DATE 16-04-2025
		Page 1 of 3

**TECHNICAL PREQUALIFYING REQUIREMENT OF BIDDERS
FOR
WIND TUNNEL STUDY OF CHIMNEY**

DOCUMENT NO. PE-TS-528-600-C031




BHARAT HEAVY ELECTRICALS LIMITED
Power Sector, Project Engineering Management
BHEL Sadan, Plot No. 25, Sector 16A, Noida (U.P.)-201301

	PROJECT: 2X660 MW DVC RAGHUNATHPUR TPS PH-II SG ISLAND PACKAGE TECHNICAL PREQUALIFYING REQUIREMENT FOR WIND TUNNEL STUDY OF CHIMNEY	DOCUMENT NO. PE-TS-528-600-C031
		REV.NO. 0
		DATE 16-04-2025
		Page 2 of 3

Project Title	:	2X660 MW DVC RAGHUNATHPUR TPS PH-II SG ISLAND PACKAGE	
Job No.	:	528	
Document No.	:	PE-TS-528-600-C031	
Building / System	:	CHIMNEY	Sheet
Subject	:	TECHNICAL PREQUALIFYING REQUIREMENT OF BIDDERS FOR WIND TUNNEL STUDY OF CHIMNEY	

Rev. No.	Particulars	Prepared By	Checked By	Approved By	Remarks
0	Name	MTA	LP /TMSR	SP	
	Sign				
	Date	16.04.2025	16.04.2025	16.04.2025	

	PROJECT: 2X660 MW DVC RAGHUNATHPUR TPS PH-II SG ISLAND PACKAGE TECHNICAL PREQUALIFYING REQUIREMENT FOR WIND TUNNEL STUDY OF CHIMNEY	DOCUMENT NO. PE-TS-528-600-C031
		REV.NO. 0
		DATE 16-04-2025
		Page 3 of 3

TECHNICAL PREQUALIFYING REQUIREMENT FOR WIND **TUNNEL STUDY OF CHIMNEY**


1. Bidder should have successfully executed Wind Tunnel model and testing on aero-elastic model of a structure, of minimum height 100m, for any one of the following in the last seven years from the latest date of bid submission
 - a) One (1) work of value not less than 10,00,000 Rs (ten lac rupees) Ex-works price.

OR

 - b) Two (2) works each of value not less than 6,25,000 Rs (six lac twenty-five thousand rupees) Ex-works price.

OR

 - c) Three (3) works each of value not less than 5,00,000 Rs (five lakh rupees) Ex-works price.
2. Bidder should have their own Wind tunnel testing facility which shall be suitable for testing on model having a scale not less than 1:250.

	PROJECT: 2X660 MW DVC RAGHUNATHPUR TPS PH-II SG ISLAND PACKAGE TECHNICAL SPECIFICATIONS FOR WIND TUNNEL TEST OF RCC CHIMNEY	SPECIFICATION NO. PE-TS-528-620-C001	
		SECTION	C
		REV.NO.	0 DATE: 16-04-2025
		Page 1 of 3	


2X660 MW DVC RAGHUNATHPUR TPS PH-II SG ISLAND PACKAGE

TECHNICAL SPECIFICATIONS FOR WIND TUNNEL TEST OF RCC CHIMNEY

DOCUMENT NO. PE-TS-528-620-C001
(REVISION 00)



BHARAT HEAVY ELECTRICALS LIMITED
Power Sector, Project Engineering Management
BHEL Sadan, Plot No. 25, Sector 16A, Noida (U.P.)-201301

	PROJECT: 2X660 MW DVC RAGHUNATHPUR TPS PH-II SG ISLAND PACKAGE TECHNICAL SPECIFICATIONS FOR WIND TUNNEL TEST OF RCC CHIMNEY	SPECIFICATION NO. PE-TS-528-620-C001	
		SECTION	C
		REV.NO.	0
		DATE:	16-04-2025
		Page 2 of 3	

SECTION 'C'

SPECIFIC TECHNICAL REQUIREMENTS

1. General Requirement

- 1.01. Bidder shall conduct wind tunnel study with a scaled down model of chimney in an established wind tunnel to study the along and across behaviour of the subject chimney under wind loading for the cases as mentioned in Table-1.

Table-1


<u>Sl. No.</u>	<u>Cases</u>
1	STAND ALONE CHIMNEY, WITHOUT FLUE LINER
2	STAND ALONE CHIMNEY, WITH FLUE LINER
3	INTERFERENCE CASE WITH ADJACENT STRUCTURES, WITHOUT FLUE LINER
4	INTERFERENCE CASE WITH ADJACENT STRUCTURES, WITH FLUE LINER


- 1.02. Subject project consists of “one no. twin flue” or “two nos. single flue” RCC chimney of maximum height up to 275m. In case of “two nos. single flue” RCC chimney, selection of one target chimney for wind tunnel test shall be decided by bidder as per their expertise, considering plant layout and wind rose diagram etc.
- 1.03. For every case of wind tunnel study, following parameters shall be derived and furnished in a detailed report.
- Natural frequency
 - Bending Moment (at minimum four elevations)
 - Shear Force (at minimum four elevations)
 - Deflection (at peak)
- 1.04. Dimensional analysis of subject chimney vis a vis the model, shall be conducted to find the various dimensional parameters.

This dimensional analysis shall be furnished in the detailed study report.

2. Wind Loading:

Wind loading will be in accordance with Indian Standard Code IS: 875 (Part 3) for a basic wind speed of 47 m/sec (K1-1.07, Terrain Cat-2). Across-wind loads due to vortex shedding shall be considered in study as per velocity range defined in IS 4998-2015.

	PROJECT: 2X660 MW DVC RAGHUNATHPUR TPS PH-II SG ISLAND PACKAGE TECHNICAL SPECIFICATIONS FOR WIND TUNNEL TEST OF RCC CHIMNEY	SPECIFICATION NO. PE-TS-528-620-C001	
		SECTION	C
		REV.NO.	0 DATE: 16-04-2025
		Page 3 of 3	
<p>3. Material of construction</p> <p>The bidder shall prepare an aero-elastic model of the chimney with fibre reinforced plastic or any other suitable material reflecting dynamic properties of subject chimney, whose properties may be dimensionally correlated with the grade of concrete of the subject chimney.</p> <p>4. Bidder shall simulate the subject terrain in the wind tunnel, as per that given in IS 875 Part (III).</p> <p>5. Aero elastic model of chimney along with rigid model of all major structures (for interference case only) which are within the distance of "20 times the diameter of the chimney at the 2/3 height of the chimney" all around shall be considered in the study.</p> <p>6. The bidder shall simulate inside the wind tunnel actual prototype flow conditions for the study. The scale of the model shall be such that the boundary conditions (side wall and roof) in the wind tunnel shall not alter the targeted flow conditions. However, the scale of the model shall not be less than 1:250</p> <p>7. Report</p> <p>After conducting the wind tunnel test, Bidder shall submit the detailed study report (in soft copy) for review of BHEL/Customer. Final detailed study report after incorporation of BHEL/Customer observations shall be submitted by the bidder (in soft copy and 3 hard copies).</p>			


	PROJECT: 2X660 MW KORADI TPS U#11&12 CHIMNEY TECHNICAL PREQUALIFYING REQUIREMENT FOR WIND TUNNEL STUDY OF CHIMNEY	DOCUMENT NO. PE-TS-527-600-C031
		REV.NO. 0
		DATE 28-04-2025
		Page 1 of 3

**TECHNICAL PREQUALIFYING REQUIREMENT OF BIDDERS
FOR
WIND TUNNEL STUDY OF CHIMNEY**

DOCUMENT NO. PE-TS-527-600-C031




BHARAT HEAVY ELECTRICALS LIMITED
Power Sector, Project Engineering Management
BHEL Sadan, Plot No. 25, Sector 16A, Noida (U.P.)-201301

	PROJECT: 2X660 MW KORADI TPS U#11&12 CHIMNEY TECHNICAL PREQUALIFYING REQUIREMENT FOR WIND TUNNEL STUDY OF CHIMNEY	DOCUMENT NO. PE-TS-527-600-C031
		REV.NO. 0
		DATE 28-04-2025
		Page 2 of 3

Project Title	:	2X660 MW KORADI TPS U#11&12 CHIMNEY	
Job No.	:	527	
Document No.	:	PE-TS-527-600-C031	
Building / System	:	CHIMNEY	Sheet
Subject	:	TECHNICAL PREQUALIFYING REQUIREMENT OF BIDDERS FOR WIND TUNNEL STUDY OF CHIMNEY	

Rev. No.	Particulars	Prepared By	Checked By	Approved By	Remarks
0	Name	MTA	LP /TMSR	SP	
	Sign				
	Date	28.04.2025	28.04.2025	28.04.2025	

	PROJECT: 2X660 MW KORADI TPS U#11&12 CHIMNEY TECHNICAL PREQUALIFYING REQUIREMENT FOR WIND TUNNEL STUDY OF CHIMNEY	DOCUMENT NO. PE-TS-527-600-C031
		REV.NO. 0
		DATE 28-04-2025
		Page 3 of 3

TECHNICAL PREQUALIFYING REQUIREMENT FOR WIND TUNNEL STUDY OF CHIMNEY


1. Bidder should have successfully executed Wind Tunnel model and testing on aero-elastic model of a structure, of minimum height 100m, for any one of the following in the last seven years from the latest date of bid submission
 - a) One (1) work of value not less than 10,00,000 Rs (ten lac rupees) Ex-works price.

OR

 - b) Two (2) works each of value not less than 6,25,000 Rs (six lac twenty-five thousand rupees) Ex-works price.

OR

 - c) Three (3) works each of value not less than 5,00,000 Rs (five lakh rupees) Ex-works price.
2. Bidder should have their own Wind tunnel testing facility which shall be suitable for testing on model having a scale not less than 1:250.

	PROJECT: 2X660 MW KORADI TPS U#11&12 CHIMNEY TECHNICAL SPECIFICATIONS FOR WIND TUNNEL TEST OF RCC CHIMNEY	SPECIFICATION NO. PE-TS-527-620-C001	
		SECTION	C
		REV.NO.	0 DATE: 28-04-2025
		Page 1 of 3	


2X660 MW KORADI TPS U#11&12 CHIMNEY

TECHNICAL SPECIFICATIONS FOR WIND TUNNEL TEST OF RCC CHIMNEY

DOCUMENT NO. PE-TS-527-620-C001
(REVISION 00)



BHARAT HEAVY ELECTRICALS LIMITED
Power Sector, Project Engineering Management
BHEL Sadan, Plot No. 25, Sector 16A, Noida (U.P.)-201301

	PROJECT: 2X660 MW KORADI TPS U#11&12 CHIMNEY TECHNICAL SPECIFICATIONS FOR WIND TUNNEL TEST OF RCC CHIMNEY	SPECIFICATION NO. PE-TS-527-620-C001	
		SECTION	C
		REV.NO.	0 DATE: 28-04-2025
		Page 2 of 3	

SECTION 'C'

SPECIFIC TECHNICAL REQUIREMENTS

1. General Requirement

- 1.01. Bidder shall conduct wind tunnel study with a scaled down model of chimney in an established wind tunnel to study the along and across behaviour of the subject chimney under wind loading for the cases as mentioned in Table-1.

Table-1


<u>Sl. No.</u>	<u>Cases</u>
1	STAND ALONE CHIMNEY, WITHOUT FLUE LINER
2	STAND ALONE CHIMNEY, WITH FLUE LINER
3	INTERFERENCE CASE WITH ADJACENT STRUCTURES, WITHOUT FLUE LINER
4	INTERFERENCE CASE WITH ADJACENT STRUCTURES, WITH FLUE LINER

- 1.02. Subject project consists of “one no. twin flue” or “two nos. single flue” RCC chimney of maximum height up to 275m. In case of “two nos. single flue” RCC chimney, selection of one target chimney for wind tunnel test shall be decided by bidder as per their expertise, considering plant layout and wind rose diagram etc.
- 1.03. For every case of wind tunnel study, following parameters shall be derived and furnished in a detailed report.
- Natural frequency
 - Bending Moment (at minimum four elevations)
 - Shear Force (at minimum four elevations)
 - Deflection (at peak)
- 1.04. Dimensional analysis of subject chimney vis a vis the model, shall be conducted to find the various dimensional parameters.

This dimensional analysis shall be furnished in the detailed study report.

2. Wind Loading:

Wind loading will be in accordance with Indian Standard Code IS: 875 (Part 3) for a basic wind speed of 44 m/sec (K1-1.07, Terrain Cat-2). Across-wind loads due to vortex shedding shall be considered in study as per velocity range defined in IS 4998-2015.

	PROJECT: 2X660 MW KORADI TPS U#11&12 CHIMNEY TECHNICAL SPECIFICATIONS FOR WIND TUNNEL TEST OF RCC CHIMNEY	SPECIFICATION NO. PE-TS-527-620-C001	
		SECTION C	
		REV.NO. 0	DATE: 28-04-2025
		Page 3 of 3	

3. Material of construction

The bidder shall prepare an aero-elastic model of the chimney with fibre reinforced plastic or any other suitable material reflecting dynamic properties of subject chimney, whose properties may be dimensionally correlated with the grade of concrete of the subject chimney.

4. Bidder shall simulate the subject terrain in the wind tunnel, as per that given in IS 875 Part (III).

5. Aero elastic model of chimney along with rigid model of all major structures (for interference case only) which are within the distance of "20 times the diameter of the chimney at the 2/3 height of the chimney" all around shall be considered in the study.

6. The bidder shall simulate inside the wind tunnel actual prototype flow conditions for the study. The scale of the model shall be such that the boundary conditions (side wall and roof) in the wind tunnel shall not alter the targeted flow conditions. However, the scale of the model shall not be less than 1:250

7. Report

After conducting the wind tunnel test, Bidder shall submit the detailed study report (in soft copy) for review of BHEL/Customer. Final detailed study report after incorporation of BHEL/Customer observations shall be submitted by the bidder (in soft copy and 3 hard copies).