

985830/2022/PS-PEM-MAX



## TECHNICAL REQUIREMENTS



- 2.02.10 At all intersection joints, it is Contractor's responsibility to design and provide suitable reinforcements as per the applicable codes and standards.
- 2.02.11 For large size pipes/ducts, at high point and bends/change of direction of flow, air release valves shall be provided as dictated by the system requirement and operation philosophy & tripping conditions of pumping system. Sizing criteria for air release valves shall be generally on the basis of valve size to pipe diameter ratio of 1:8. Requirement shall be decided as per relevant code.
- Transient analysis /surge analysis where ever specified and required shall be conducted in order to determine the location , number and size of the Air-Release valve on certain long distance/high volume piping systems, if applicable within the scope of work of the package.
- 2.03.00 **Material**
- 2.03.01 Alternate materials offered by Bidder against those specified. shall either be equal to or superior to those specified, The responsibility for establishing equality or superiority of the alternate materials offered rests entirely with the Bidder and any standard code required for establishing the same shall be in English language.
- 2.03.02 No extra credit would be given to offers containing materials superior to those specified. Likewise no extra credit would be given to offers containing pipe thickness more than specified.
- 2.03.03 All materials shall be new and procured directly from the manufacturers. Materials procured from traders or stockists are not acceptable.
- 2.03.04 All materials shall be certified by proper material test certificates. All material test certificates shall carry proper heat number or other acceptable references to enable identification of the certificate that certifies the material.
- 2.03.05 Material of construction for pipes carrying various fluids shall be as follows:

SI N	Type of Fluid	Material
1.	i) Ordinary Water (Raw Water, Clarified Water, etc.) ii) Equipment cooling water including Both primary & secondary circuit (DMCW pH-corrected & ACW drain water)	IS-2062 Gr.-E-250B/ASTM A-36/ASTM A-53 type 'E'Gr.B/IS-3589 Gr. 410 /IS-1239 Heavy.
2.	i) Demineralised water, ii)Alkaline solution (ECW system chemical dosing)	Stainless Steel to ASTM A312, Gr. 304 welded for sizes 65 mm NB and above. Stainless steel to ASTM A312, Gr. 304 sch.40s seamless for sizes 50mm and below
3.	i) Drinking (potable) water ii)Compressed air (Instrument & service air)	ASTM A-53 type E Gr. B galvanized/ IS 1239 Gr heavy galvanized/IS 3589 Gr 410 galvanized. Galvanized shall be to IS- 4736 or equivalent.
4.	(Condensate) spill water	ASTM A 106 Gr. B
5.	Effluents from Neutralization pit	MSRL

KHURJA SUPER THERMAL POWER PROJECT  
(2X660 MW)  
TURBINE GENERATOR AND ASSOCIATED  
PACKAGES

TECHNICAL SPECIFICATION  
SECTION – VI, PART-B  
BID DOC. NO.:  
THDC/RKSH/CC-9915-371

SUB-SECTION- A6  
(LOW PRESSURE  
PIPING)

PAGE 4 OF 21

985830/2022/PS-PEM-MAX



## TECHNICAL REQUIREMENTS



CLAUSE NO.			
2.03.06	In water lines, pipes upto 150mm Nb shall conform to ANSI B36.10/ASTM-A-53, Type-E Gr.B /IS:1239 Gr. Heavy and minimum selected thickness shall not be less than IS:1239 Grade Heavy except for demineralised water, drinking water and condensate spill lines.		
2.03.07	Pipes of above 150mm Nb shall be to AWWA-C200/ANSI B 36.10/ASTM A-53/IS 3589 Gr.410. Pipe to be fabricated by the bidder shall be rolled and butt welded from plates conforming to ASTM A-53 type 'E' Gr. B/IS 2062 Gr.E-250B/ASTM-A-36. However, larger pipes, i.e. 1000mm Nb and above shall be made from plates conforming to ASTM A 36/IS 2062 Gr.E-250B and shall meet the requirements of AWWA-M-11 (for deflection & buckling criteria considering water filled pipe as well as vacuum condition that may prevail during transient/surge conditions, truck-load, rail-load and weight density for compacted soil or any other load as the case may be).		
2.03.08	In demineralised water service, the pipes upto 50 Nb shall be of stainless steel ASTM A 312, Gr. 304 sch. 40 Seamless. The size for these pipes shall be to ANSI B 36.19. These shall be socket welded. The material for pipe from 65mm NB upto and including 400 NB shall be to ASTM A 312, Gr. 304 (welded). In no case the thickness of fittings shall be less than parent pipe thickness.  Bidder/Contractor shall note that pipes offered as per a particular code shall conform to that code in all respects i.e. Dimension, tolerances, manufacturing methods, material, heat treatment, testing requirements, etc. unless otherwise mentioned elsewhere in the specification.		
2.03.09	Instrument air, Plant (service) air lines and Drinking water lines shall be to ASTM A 53 type E grade B/ANSI B 36. 10/IS 3589, Gr. 410 / IS: 1239 Heavy (in case thickness calculated is more than gr. Heavy, ANSI B 36.10 Schedule numbers shall be followed) and galvanized to IS 4736 or any equivalent internationally reputed standard. The material of the pipes shall be to ASTM A 53 type 'E' Gr. B / IS: 3589, Gr. 410 / IS: 1239 Gr. Heavy. The fittings shall be of either same as parent material or malleable iron to IS-1879 (galvanized).		
2.03.10	Spiral welded pipes as per API-5L/IS-3589 are also acceptable for pipe of size above 150 NB. However minimum thickness of the pipes shall be as elaborated in above clauses.		
2.03.11	Condensate lines shall be to ASTM A 106 Gr. B and dimension to ANSI B 36.10 schedule "standard" as minimum to be maintained.		
2.03.12	If carbon steel plates of thickness more than 12 mm are used for manufacture of pipes, fittings and other appurtenances, then the same shall be control-cooled or normalized as the case may be following the guidelines of the governing code.		
2.04.00	<b>Field routed pipes:</b>		
2.04.01	Pipe lines of NB 50 size and below are regarded as field run piping. It is Bidder's responsibility to plan suitable layouts for these system insitu. Bidder shall prepare drawings indicating the layout of field run pipe work. These drawings shall be approved by Project Manager to the installation of the field run pipe work. Based on these approved layouts the Bidder shall prepare the BOQ of field run-pipes and submit to Employer for approval.		
2.05.00	<b>Slope/Drains and Vents</b>		
2.05.01	Suitable slope shall be provided for all pipelines towards drain points. It is Bidder responsibility to identify the requirements of drains and vents, and supply the necessary pipe work, valves, fittings, hangers and supports etc. As per the system requirement low points in the pipelines shall be provided with suitable draining arrangement and high points shall be provided with vent connections where air or gas pockets may occur. Vent for use during hydrostatic test shall be plugged after the completion of the test. Vent shall not be less than 15mm size. Drains shall be provided at low points and at pockets in piping such that complete drainage of all systems is possible. Drain shall not be less than 15mm for line size		
KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES	TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371	SUB-SECTION- A6 (LOW PRESSURE PIPING)	PAGE 5 OF 21

985830/2022/PS-PEM-MAX



## TECHNICAL REQUIREMENTS



CLAUSE NO.			
	up to 150mm, not less than 20mm up to 300mm and not less than 25mm for 350mm to 600mm pipes and not less than 50mm for 600mm and above pipes.		
2.05.02	Air piping shall be sloped so that any part of the system can be drained through the shut-off drain valve or drain plugs.		
2.06.00	<b>Pipe Joints</b>		
	In general all water lines 65mm NB and above, are to be joined generally by butt welding except the locations where valves/fittings are to be installed with flanged connections and 50mm and below by socket welding unless mentioned otherwise specifically. All air lines shall be of screwed connection and rubber lined pipes of flanged connections.		
2.06.01	<b>Screwed Joints</b>		
	(a) Threading of pipes shall be carried out after bending, heat treatment etc. If not possible, threading may be done prior to these operations but proper care should be taken to protect them from damage. Threads shall be to ANSI B 2.1 (taper) NPT/ ANSI B1.20.1 (taper) NPT / IS: 554 unless specified otherwise.		
	(b) Galvanized pipe shall generally be joined by screwing into sockets. The exposed threaded portion on the outside of the pipes shall be given a zinc silicate coating. Galvanized pipes shall not be field joined by welding for protection of Galvanising Zinc layer. Screwed ends of GI pipes shall be thoroughly cleaned and painted with a mixture of red and white lead before jointing. For galvanized pipe sizes above 150 mm NB, screw & socket jointing as per ASTM-A-865 shall be employed for both pipe-to-pipe and pipe-to-fitting jointing. For pipe to fitting connection since no direct threading can be done on the fittings (supplied as per ASTM-A-234 Gr. WPB and ANSI B-16.9) necessary straight pipe lengths acting as match pieces shall be welded to the fitting at both ends and subsequently the free ends of the straight lengths shall be threaded as per ASTM A-865 for jointing with main pipe. Once welding of fittings with match pieces and threading of free ends of match pieces are over, the entire fabricated piece shall be galvanized, or in case match pipes and fittings are already galvanized before the above mentioned fabrication then suitable application of Zinc-Silicate paste adequately at the welded surface (both in side & out side) after welding with zinc rich electrode, along with the nascent threaded metal portions at both free ends given the same application of Zinc Silicate paste. Alternatively flanged jointing may be employed for pipe sizes 100 NB and above. However, the bidder shall ensure the galvanized pipe joints do not fail during hydro test.		
	(c) Teflon tapes shall be used to seal out screwed joints and shall be applied to the male threads only. Threaded parts shall be wiped clean of oil or grease with appropriate solvent if necessary and allowing proper time for drying before applying the sealant. Pipe ends shall be reamed and all chips shall be removed. Screwed flanges shall be attached by screwing the pipe through the flange and the pipe and flange shall be refaced accurately.		
	(d) For pipe sizes from 350 mm NB to 550 mm NB (including 350 NB & 550 NB) the GI pipes shall be of flanged connection. However, the pipes after welding of flanges shall be completely galvanized. Any site welding done on galvanized pipes shall be done with zinc-rich special electrodes and the welded surfaces whether inside or outside shall be coated with zinc-silicate paste. Seal welding of flanges with zinc-rich electrode will be permitted only when any flange is leak-prone during hydro testing.		
	(e) For pipe sizes 600 mm NB and above, the GI pipes shall be of welded connection (with zinc-rich special electrodes) followed by application of zinc silicate coating at welded surfaces both inside and outside the pipe, except for the last blank/blind flange, or, equipment connection where application of zinc-silicate paste after welding cannot be done due to inaccessibility of the inside welded surface and where		
KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES	TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371	SUB-SECTION- A6 (LOW PRESSURE PIPING)	PAGE 6 OF 21

985830/2022/PS-PEM-MAX



## TECHNICAL REQUIREMENTS



CLAUSE NO.	TECHNICAL REQUIREMENTS		
	galvanic protection has been impaired due to welding of pipe-to-pipe joint. Thus the last erection joint shall be flanged joint.		
2.06.02	<p><b>Welded Joints</b></p> <p>(a) For making up welded joints (butt weld or socket weld) the welding shall be performed by manual shielded metal arc process in accordance with the requirements specified elsewhere in the spec. Any welder employed for carrying butt welding shall be qualified as per ASME section IX for the type of joints he is going to weld. Jointing by butt weld, or socket weld shall depend upon the respective piping material specifications.</p>		
2.06.03	<p><b>Flanged Joints</b></p> <p>(a) Flanged connections for pipes are to be kept to the minimum and used only for connections to vessel, equipments, flanged valves and other fittings like strainer/traps/orifices etc. for ease of connection and maintenance etc. Rubber lined pipes shall be flange joined only.</p> <p>(b) All flanged valves intended for installation on steel piping system, shall have their flanges drilled to ANSI B 16.5 (or equivalent) and according to the pressure class stated in their respective piping material specification.</p> <p>(c) Drilling on flanges of flanged valves must correspond to the drilling of flanges on the piping system on which the valves are installed.</p>		
2.07.00	<p><b>Bends/elbows/mitre bends/ Tees/ Reducers &amp; other fittings</b></p>		
2.07.01	<p>For pipe fittings such as elbows (long radius), reducers, tees, etc. the material shall be to ASTM-A-234 Gr. WPB/ASTM-105 up to 300 NB. For pipe fittings above 300 NB, the fittings may be fabricated conforming to parent pipe material. Provision of compensation pads shall be kept as per ANSI B 31.1. The fitting shall conform to the dimensional standard of ANSI B-16.9/ 16.11. Further branching in pipes for sizes 65nb and above is also acceptable (ANSI B 31.1).</p> <p>However, for pipes up to 150 NB, pipe fittings may be supplied with material and dimension conforming to IS 1239 in case parent pipes also conform to IS 1239.</p>		
2.07.02	<p>For pipe size 350Nb and above mitre bends may be used for all pipes except rubber lined pipes. However, mitre bends are also acceptable for rubber lined pipes above 1200 NB. The bend radius shall be 1½ times the nominal pipe diameter. 90 deg. bends (mitre) shall be in 4 pieces (3 cuts) and 45 deg. mitre bends shall be in 3 pieces 22½ deg. Fabrication of mitre bends shall be as detailed in BS 2633/BS534.</p>		
2.07.03	<p>For pipes, above 1200 NB, reducer and tees shall be to dimensional standard of AWWA-C-208.</p>		
2.07.04	<p>Stainless steel fittings shall conform to either ASTM-A-182 Gr. 304 or ASTM-A-403 Grade WP. 304 Class-S, for sizes upto and including 50 mm NB, i.e. the fittings shall be of seamless construction. However, for stainless fittings above 50 mm NB, the same shall conform to ASTM-A-403 Gr. WP 304 Class W i.e. the fittings shall be of welded construction strictly in accordance with ASTM-A-403.</p>		
2.07.07	<p>In no case, the thickness of fittings shall be less than the thickness of parent pipe, irrespective of material of construction.</p>		
2.08.00	<p><b>Flanges</b></p>		
2.08.01	<p>Flanges shall be slip on type or weld neck type. Welding of flanges in tension is not permitted.</p>		
<p><b>KHURJA SUPER THERMAL POWER PROJECT</b> (2X660 MW) <b>TURBINE GENERATOR AND ASSOCIATED</b> <b>PACKAGES</b></p>	<p><b>TECHNICAL SPECIFICATION</b> <b>SECTION – VI, PART-B</b> <b>BID DOC. NO.:</b> <b>THDC/RKSH/CC-9915-371</b></p>	<p><b>SUB-SECTION- A6</b> <b>(LOW PRESSURE</b> <b>PIPING)</b></p>	<p><b>PAGE 7 OF 21</b></p>

985830/2022/PS-PEM-MAX



## TECHNICAL REQUIREMENTS



CLAUSE NO.	
2.08.02	All flanges and-flanged drilling shall be to ANSI B 16.5 / BS EN-1092 / AWWA C - 207 of relevant pressure/temperature class. Flanges shall be fabricated from steel plates conforming to ASTM A 105/IS 2062 Gr. E-250B. However stainless steel flanges shall be fabricated from SS plates to ASTM-A-240, Gr. 304 or equivalent.
2.09.00	<p><b>Specific technical requirement of laying buried pipe with anti-corrosive treatment</b></p> <p>The pipe in general shall be laid with the top of the pipe minimum 1.0 (one) meter below finished general ground level.</p>
2.09.01	<p><b>Trenching</b></p> <p>(a) The trench shall be cut true to the line and level and shall follow the gradient of the pipeline. The width of the trench shall be sufficient to give free working space on each side of the pipe. Trenches shall conform to IS 5822 or any international standard.</p>
2.09.02	<p><b>Preparation and cleaning of piping</b></p> <p>(a) The pipeline shall be thoroughly cleaned of all rust, grease, dirt, weld scales and weld burrs etc. moisture or other foreign matter by power cleaning method such as sand or grit blasting, power tool cleaning, etc. Grease or heavy oil shall be removed by washing with a volatile solvent such as gasoline. Certain inaccessible portions of the pipeline (which otherwise not possible to be cleaned by power cleaning methods) may be scrubbed manually with a stiff wire brush and scrapped where necessary with specific permission of the Project Manager.</p> <p>(b) On the internal surface for pipes 1000 Nb and above, a coat of primer followed by a hot coal-tar enamel or coal tar epoxy painting (cold) shall be applied.</p>
2.09.03	<p><b>Coating and wrapping/ Anti corrosive Protection Coal tar tape</b></p> <p>a. Buried piping shall be coated and wrapped, as per specification, after completion of welded and/or flanged connections, and after completion and approval of Hydro testing. Materials to be used for coating and wrapping of underground pipelines are:</p> <ol style="list-style-type: none"> <li>(1) Coating primer (coal tar primer)</li> <li>(2) Coating enamel (coal tar enamel)</li> <li>(3) Wrapping materials.</li> </ol> <p>All primer/coating/wrapping materials and methods of application shall conform to IS: 10221 except asphalt/bitumen material. Materials (primer/coating/wrapping) as per AWWA-C-203 are also acceptable.</p> <p>Protective coating shall consist of coal tar primer, coal tar enamel coating, glass fiber, tissue inner wrap followed by glass fiber or coal tar impregnated Kraft outer wrap or finish coat.</p> <p>Number of coats and wraps, minimum thickness for each layer of application shall be as per IS-10221. Number of. Coats and wraps shall be decided based on soil corrosivity/resistivity as indicated in IS-10221. Soil data-for this purpose shall be made available.</p> <p>Total thickness of completed coating and wrapping shall not be less than 4.0 mm.</p>

KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES	TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371	SUB-SECTION- A6 (LOW PRESSURE PIPING)	PAGE 8 OF 21
--	---	---	--------------

985830/2022/PS-PEM-MAX



## TECHNICAL REQUIREMENTS



CLAUSE NO.				
	b.	Alternatively, the anti-corrosive protection for buried pipes can consist of anti-corrosive protection Coal-tar tapes. Material and application of tapes shall conform to IS 15337 or equivalent. These-tapes shall be applied hot over the cold coal tar primer in steps of 2mm thickness so as to cover the spiral edges of the first tape by the application of second tape. The total thickness of the finished protective coating shall be 4.0 mm minimum.		
2.09.04	<b>Trench bed preparation and back filling</b>			
	Prior to lowering and laying pipe in any excavated trench, the bottom of the trench may require to be back filled and compacted (or as the case may be) to provide an acceptable bed for placing the pipe. Bed preparation in general shall be as per IS: 5822.			
2.09.05	<b>Laying of galvanized steel (GI) pipes</b>			
	All the joints shall be screwed with socket or flanged. Screwed ends of GI pipes shall be thoroughly cleaned and painted with a mixture of red and white lead before jointing Threaded portion on either side of the socket joint shall be applied with Zinc silicate paste.			
	All the provisions for trenching' bed preparation' laying the pipe application of primer' coating' wrapping with tapes and back filling etc. as indicated for "laying of buried piping" and " anti corrosive protection for buried piping" are applicable for buried galvanized steel (GI) pipes also.			
2.10.00	<b>Cleaning and flushing</b>			
2.10.01	All piping shall be cleaned by the Bidder before and after erection to remove grease, dirt, dust, scale and welding slag.			
2.10.02	Before erection all pipe work, assemblies, sub-assemblies, fittings, and components, etc. shall be thoroughly cleaned internally and externally by blast cleaning or by power driven wire brushes and followed by air-blowing . However for pipe sizes below 100nb the pipes may be cleaned internally by compressed air blowing as an alternative to internal blast cleaning. The brushes shall be of the same or similar material as the metal being cleaned. Cleaning of Galvanized pipes shall be done by air blowing only.			
2.10.03	After erection, all water lines shall be mass flushed with water. The cleaning velocities in water lines shall be 1.2-1.5 times the operating velocities in the pipelines.			
2.10.04	All compressed air pipe work shall be cleaned by blowing compressed air.			
2.11.00	<b>Specification for hangers and supports</b>			
2.11.01	All supports and parts shall conform to the requirement of power piping code ANSI B 31.1 or approved equivalent.			
2.11.02	The maximum spans of the supports of straight length shall not exceed the recommended values indicated in ANSI B 31.1.			
2.11.03	At all sliding surfaces of supports suitable arrangement is to be provided to minimize sliding friction.			
2.12.00	<b>Design/Construction/Material Particulars of Gate/ Globe /Check /Butterfly / Ball / Air release /Float valves / Moisture Traps.</b>			
2.12.01	<b>GENERAL</b>			
KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES		TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371	SUB-SECTION- A6 (LOW PRESSURE PIPING)	PAGE 9 OF 21

985830/2022/PS-PEM-MAX



## TECHNICAL REQUIREMENTS



CLAUSE NO.	TECHNICAL REQUIREMENTS		
	<p>(a) All valves shall have indicators or direction clearly marked on the hand-wheel so that the valves opening/closing can be readily determined.</p> <p>(b) Special attention shall be given to operating mechanism for large size valves with a view to obtaining quick and easy operation ensuring that a minimum of maintenance is required.</p> <p>(c) The valves coming in vacuum lines shall be of extended gland type and/or water sealed.</p> <p>(d) The actuator-operated valves shall be designed on the basis of the following:</p> <ol style="list-style-type: none"> <li>(1) The internal parts shall be suitable to support the pressure caused by the actuators;</li> <li>(2) The valve-actuator unit shall be suitably stiff so as not to cause vibrations, misalignments, etc.</li> <li>(3) All actuator-operated valves shall be provided with hand operated gearing mechanism also.</li> <li>(4) All actuators operated valves shall open/ close fully within time required by the process.</li> </ol> <p>(e) Valves coming under the purview of IBR shall meet IBR requirements.</p> <p>(f) All valves shall be provided with embossed name plate giving details such as tag number, type, size etc.</p> <p>(g) Wherever required valves shall be provided with chain operator, extension spindles and floor stands or any other arrangement approved by employer so that they can be operated with ease from the nearest operating floor. Wherever necessary for safety purpose locking device shall be provided. Further, necessary small platforms for facilitating easy valve operation shall be provided by the contractor wherever necessary in consultation with project manager within the bid price at no extra cost to employer</p> <p><b>2.12.02 VALVE BODY MATERIAL</b></p> <p>Valve body material for various services shall be as follows:</p> <p>Valve body material for water application like Secondary circuit auxiliary cooling water of ECW system, Raw water, Ash water make-up, service water, clarified water, DM cooling water (pH corrected) , drinking water etc. shall be cast iron for sizes 65NB and above; gun-metal for sizes 50 Nb and below.</p> <p>For compressed air application, valve body material shall be cast carbon steel or forged carbon steel for sizes 65 mm NB &amp; above and Gun metal for sizes 50 NB and below.</p> <p>DM water: SS body and disc along with SS internals. However for butterfly valves, Cast Iron /Ductile Iron/SG iron/carbon steel body and disc with elastomer lining are also acceptable.</p> <p>Condensate: Cast Carbon Steel / Forged Carbon Steel.</p> <p><b>2.12.03</b></p> <p>The design, material, construction, manufacture, inspection, testing and performance of valves shall comply with all currently applicable statutes, regulations and safety codes in the locality where the valves will be installed. The valves shall conform to the latest editions of</p>		
<p><b>KHURJA SUPER THERMAL POWER PROJECT</b> (2X660 MW) <b>TURBINE GENERATOR AND ASSOCIATED PACKAGES</b></p>	<p><b>TECHNICAL SPECIFICATION SECTION – VI, PART-B</b> <b>BID DOC. NO.:</b> <b>THDC/RKSH/CC-9915-371</b></p>	<p><b>SUB-SECTION- A6</b> <b>(LOW PRESSURE PIPING)</b></p>	<p><b>PAGE 10 OF 21</b></p>

985830/2022/PS-PEM-MAX





## TECHNICAL REQUIREMENTS



CLAUSE NO.																																	
	<p>applicable codes and standards as mentioned elsewhere. Nothing in this specification shall be construed to relieve the Bidder of his responsibility. Valves in general shall conform to the requirements of the following standards.</p> <p><b>Standards and Codes</b></p> <table border="0"> <tr> <td data-bbox="341 376 512 405">AWWA-C-504</td> <td data-bbox="730 376 1102 405">Rubber seated butterfly valves.</td> </tr> <tr> <td data-bbox="341 454 549 483">BS-5155/EN-593</td> <td data-bbox="730 454 1453 528">Cast iron and steel body butterfly valves for general purpose.</td> </tr> <tr> <td data-bbox="341 566 416 595">IS-778</td> <td data-bbox="730 566 1453 640">Gun-metal gate, globe and check valves for general purpose.</td> </tr> <tr> <td data-bbox="341 656 448 685">BS-5154</td> <td data-bbox="730 656 1453 730">Copper alloy globe/globe stop and check and gate valves for general purpose.</td> </tr> <tr> <td data-bbox="341 723 424 752">IS-780</td> <td data-bbox="730 723 1401 752">Sluice valves for water works purpose (50-300 mm size)</td> </tr> <tr> <td data-bbox="341 779 440 808">IS-2906</td> <td data-bbox="730 779 1445 808">Sluice valves for water works purpose (350-1200 mm size)</td> </tr> <tr> <td data-bbox="341 835 440 864">IS-5150</td> <td data-bbox="730 835 1453 909">Cast iron wedge and double disc gate for general purpose.</td> </tr> <tr> <td data-bbox="341 936 448 965">BS-5152</td> <td data-bbox="746 936 1209 965">Specification for cast iron globe valves.</td> </tr> <tr> <td data-bbox="341 992 448 1021">BS-5153</td> <td data-bbox="746 992 1262 1021">Cast iron check valves for general purpose.</td> </tr> <tr> <td data-bbox="341 1048 440 1077">IS-5312</td> <td data-bbox="754 1048 1278 1077">Swing check type reflux (non-return) valves.</td> </tr> <tr> <td data-bbox="341 1115 507 1144">ANSI B 16.34</td> <td data-bbox="762 1115 1002 1144">Standard for valves.</td> </tr> <tr> <td data-bbox="341 1171 440 1200">API-594</td> <td data-bbox="762 1171 1142 1200">Standard for Dual-check valves.</td> </tr> <tr> <td data-bbox="341 1227 440 1256">API-600</td> <td data-bbox="770 1227 983 1256">Steel gate valves.</td> </tr> <tr> <td data-bbox="341 1283 512 1312">ANSI-B-16.10</td> <td data-bbox="762 1283 1350 1312">Valves face to face and other relevant dimension.</td> </tr> <tr> <td data-bbox="341 1339 440 1368">API-598</td> <td data-bbox="762 1339 1031 1368">Valves inspection test.</td> </tr> </table> <p><b>2.12.04 End Connections</b></p> <p>The end connections, shall comply with the following:</p> <p>Socket welding (SW) - ANSI B 16.11</p> <p>Butt Welding (BW) - ANSI B 16.25.</p> <p>Threaded (SC) - ANSI B 2.1</p> <p>Flanged (FL) - ANSI B 16.5&amp; AWWA-C-207 (steel flanges), ANSI B 16.1 (Cast Iron flanges).</p> <p><b>2.13.00 Gate/Globe/Check Valves</b></p> <p>(a) All cast iron body valves (gate, globe and non-return) shall have flanged end connections; (screwed ends for Ductile D.2NI body valves are not acceptable).</p> <p>(b) All steel and stainless steel body valves of sizes 65 mm and above shall have flanged or butt welding ends. Valves of sizes below 65mm shall have flanged or</p>			AWWA-C-504	Rubber seated butterfly valves.	BS-5155/EN-593	Cast iron and steel body butterfly valves for general purpose.	IS-778	Gun-metal gate, globe and check valves for general purpose.	BS-5154	Copper alloy globe/globe stop and check and gate valves for general purpose.	IS-780	Sluice valves for water works purpose (50-300 mm size)	IS-2906	Sluice valves for water works purpose (350-1200 mm size)	IS-5150	Cast iron wedge and double disc gate for general purpose.	BS-5152	Specification for cast iron globe valves.	BS-5153	Cast iron check valves for general purpose.	IS-5312	Swing check type reflux (non-return) valves.	ANSI B 16.34	Standard for valves.	API-594	Standard for Dual-check valves.	API-600	Steel gate valves.	ANSI-B-16.10	Valves face to face and other relevant dimension.	API-598	Valves inspection test.
AWWA-C-504	Rubber seated butterfly valves.																																
BS-5155/EN-593	Cast iron and steel body butterfly valves for general purpose.																																
IS-778	Gun-metal gate, globe and check valves for general purpose.																																
BS-5154	Copper alloy globe/globe stop and check and gate valves for general purpose.																																
IS-780	Sluice valves for water works purpose (50-300 mm size)																																
IS-2906	Sluice valves for water works purpose (350-1200 mm size)																																
IS-5150	Cast iron wedge and double disc gate for general purpose.																																
BS-5152	Specification for cast iron globe valves.																																
BS-5153	Cast iron check valves for general purpose.																																
IS-5312	Swing check type reflux (non-return) valves.																																
ANSI B 16.34	Standard for valves.																																
API-594	Standard for Dual-check valves.																																
API-600	Steel gate valves.																																
ANSI-B-16.10	Valves face to face and other relevant dimension.																																
API-598	Valves inspection test.																																
<p><b>KHURJA SUPER THERMAL POWER PROJECT</b> (2X660 MW) <b>TURBINE GENERATOR AND ASSOCIATED PACKAGES</b></p>	<p><b>TECHNICAL SPECIFICATION</b> <b>SECTION – VI, PART-B</b> <b>BID DOC. NO.:</b> <b>THDC/RKSH/CC-9915-371</b></p>	<p><b>SUB-SECTION- A6</b> <b>(LOW PRESSURE</b> <b>PIPING)</b></p>	<p><b>PAGE 11 OF</b> <b>21</b></p>																														

985830/2022/PS-PEM-MAX

CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 		
	<p>socket welded ends. Compatibility of welding between valve body material and connecting pipe material is a pre-requisite in case of butt-welded joints.</p> <p>(c) All gun metal body valves shall have screwed ends.</p> <p>(d) All flanged end valves/specialties. shall be furnished along with matching counter flanges, fasteners, gaskets etc. as required to complete the joints.</p> <p>(e) Gate/sluice valves shall be used for isolation of flow. All gate valves shall be of the full-way type, and when in the full open position the bore of the valve shall not be constricted by any part of the gate.</p> <p>Gate valves shall be of the solid/elastic or articulated wedge disc. Gate valves shall be provided with the following accessories in addition to other standard items:</p> <ol style="list-style-type: none"> <li>(1) Hand wheel</li> <li>(2) Position indicator (for above 50 mm NB valve size)</li> <li>(3) Draining arrangement wherever required.</li> </ol> <p>(f) Globe valves shall be used for regulation purposes. They shall be provided with hand wheel, position indicator, draining arrangement (wherever required) and arrow indicating flow direction. Preferably, the valves shall be of the vertical stem type. Globe valves shall preferably have radiused or spherical seating and discs shall be free to revolve on the spindle.</p> <p>The pressure shall preferably be under the disc of the valve. However, globe valves, with pressure over the disc shall also be accepted provided (i) no possibility exists that flow from above the disc can remove either the disc from stem or component from disc (ii) manual globe valves can easily be operated by hand. If the fluid load on the top of the disc is higher than 40-60 KN, bypass valve shall be provided which permits the downstream system to be pressurized before the globe valve is opened.</p> <p>(g) Check valves shall be used for non-return service. They shall be swing. check type or double door (Dual plate)check type with a permanent arrow inscription on the valve body indicating the fluid flow direction. In long distance pipes lines with possibility of surge-occurrence, dual plate check valves are preferable for its spring controlled opening /closing of flaps/doors against flow reversals. However, dual plate check valves shall not be used for sizes more than 600mm NB.</p> <p>(h) For bore greater than 2" the valves must be swing check type or dual plate check type suitable for installation in all positions (vertical and horizontal);</p> <p>(i) For bore smaller than or equal to 2" the valves must be of the piston type to be installed, in horizontal position.</p> <p>(j) All gate and globe valves shall be provided with back seating arrangement to enable on line changing of gland packing. The valves shall be preferably outside screw &amp; yoke type.</p> <p>(k) All gate and globe valves shall be rising stem type and shall have limit switches for full OPEN and full CLOSED indication wherever required. This will include motor-operated valves also wherever required. In such cases the limit switches shall form an integral part of the valve. Stop-gap arrangement in this respect is not acceptable.</p> <p>(l) All valves except those with rising stems shall be provided with continuous mechanical position indicators; rising stem valves shall have only visual indication through plastic/metallic stem cover for sizes above 50 mm nominal bore.</p>		
<b>KHURJA SUPER THERMAL POWER PROJECT</b> (2X660 MW) <b>TURBINE GENERATOR AND ASSOCIATED PACKAGES</b>	<b>TECHNICAL SPECIFICATION</b> <b>SECTION – VI, PART-B</b> <b>BID DOC. NO.:</b> <b>THDC/RKSH/CC-9915-371</b>	<b>SUB-SECTION- A6</b> <b>(LOW PRESSURE PIPING)</b>	<b>PAGE 12 OF 21</b>

985830/2022/PS-PEM-MAX



## TECHNICAL REQUIREMENTS



CLAUSE NO.	TECHNICAL REQUIREMENTS			
2.13.01	<p>(m) For CI gate, globe and check valves wherever thickness of body/bonnet is not mentioned in the valves standards, thickness mentioned in IS- 1538 for fitting shall be applicable.</p>	<b>MATERIAL OF CONSTRUCTION (GATE/GLOBE/CHECK VALVE)</b>		
	(a) The materials shall generally comply with the following:	(1) <b>Cast Steel Valves</b>		
	Body & bonnet	ASTM A 216 Gr. WCB/ ASTM A 105		
	Disc for non-return Valves	ASTM A 216 Gr. WCB/ ASTM A 105		
	Trim.	ASTM A 182 Gr. F6 or Equivalent		
	(2) <b>Stainless steel valves</b>			
	Body & Bonnet	SS 304		
	Disc	-do-		
	Trim.	SS 316		
	(3) <b>Cast iron valves</b>			
	Body & bonnet	BS 1452 Gr. 14/ IS-210 Gr. FG 260		
	Seating surfaces and rings	13% chromium steel/ 13% Chrome overlay		
	Disc for non-return valves	BS 1452 Gr. 14/IS-210 Gr FG 260		
	Hinge pin for non-return valves	AISI 316		
	Stem for gate globe valves	13% chromium steel or Equivalent		
	Back seat	13 % chromium steel / 13% Chrome overlay		
	(4) <b>Gun Metal valves</b>			
	Body and bonnet	IS 318 Gr. 2/ Equivalent Standard		
	Trim.	-do-		
	(b) Cast iron body valves shall have high alloy steel stem and seat.			
	(c) Material for counter flanges shall be the same as for the piping.			
	(d) Forged carbon steel valves are also acceptable in place of Gun metal valves.			
KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES	TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371	SUB-SECTION- A6 (LOW PRESSURE PIPING)	PAGE 13 OF 21	



985830/2022/PS-PEM-MAX



## TECHNICAL REQUIREMENTS



CLAUSE NO.			
	Shaft  Seat ring  Seal  <b>(b) Stainless Steel Butterfly Valves</b>  Body & Disc  Shaft  Seat Rings  <b>(c) Carbon steel Butterfly Valves</b>  Body & Disc  Shaft  Disc & Seat Rings  <b>(d) Elastomer lined Butterfly Valves</b>  Body & Disc  Shaft	BS 970 431 S: 291 / EN 57, or AISI-410 or AWWA-permitted shaft material equivalent to EN-57/AISI-410 or better.  18-8 Stainless steel  Nitrile Rubber  SS 304  SS 316  EPT/BUNA-N/Neoprene  ASTM A 216, Gr. WCB  SS 304  EPT/BUNA-N/Neoprene  ASTM A48, Gr. 40 / IS: 210. Gr. FG-260 / SG Iron (ductile iron) IS 1865 Gr 400-15 or BSEN 1563, Gr EN GJS-400-15 / ASTM A 216, Gr. WCB with elastomer lining.  SS 316	
2.15.03	<b>Proof of Design Test (Type Test) for Butterfly Valves</b>		
2.16.00	<b>Float operated valves</b>		
	<b>(a)</b> Valve shall automatically control the rate of filling and will shut off when a predetermined level is reached and close to prevent over flow on pre-set maximum water level. Valve shall also open and close in direct proportion to rise or fall of water level.  <b>(b)</b> DESIGN AND CONSTRUCTION FEATURES	The following design and construction feature of the valve shall be the minimum acceptable.	
KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES	<b>TECHNICAL SPECIFICATION            SECTION – VI, PART-B            BID DOC. NO.:</b> <b>THDC/RKSH/CC-9915-371</b>	<b>SUB-SECTION- A6            (LOW PRESSURE            PIPING)</b>	<b>PAGE 15 OF            21</b>

985830/2022/PS-PEM-MAX



## TECHNICAL REQUIREMENTS



CLAUSE NO.	TECHNICAL REQUIREMENTS		
	<p>(c) Valves shall be right-angled or globe pattern.</p> <p>(d) Valves shall be balance piston type with float ball.</p> <p>(e) Leather liner shall not be provided.</p> <p>(f) The body and cover material shall be cast iron conforming to ASTM-A 126 Grade 'B' or IS: 210 Grade 200 or equivalent, and Float shall be of copper with epoxy painting of two (2) coats.</p> <p>(g) Valves shall be suitable for flow velocities of 2 to 2.5m/sec.</p> <p>(h) The valves shall have flanged connections.</p>		
2.17.00	<b>Tanks and Accessories</b>		
2.17.01	The designer and manufacturer of storage tanks shall comply with and obtain approval of all currently applicable statutory regulations and safety codes in the locality where the equipment will be installed. The tanks shall conform to IS 803/IS804/IS 805/ IS 2825/ API 650/ IS 4049/ IS 4682 (part-I) and IS 4864 to 4870/ ASME B & PV code Sec.-VIII as the case may be.		
2.17.02	<p><b>DESIGN AND CONSTRUCTION</b></p> <p>(a) Design of all vertical atmospheric storage tanks containing water, acid, alkali and other chemical shall conform to IS:803 &amp; API 650.</p> <p>(b) Design of all horizontal atmospheric storage tanks containing water, acid, alkali and other chemicals shall generally conform to IS:2825 as regards to fabrication and general construction taking care of combined bending, shear &amp; hoop stresses developed due to supporting arrangement.</p> <p>(c) Tank shall be made from mild steel plates to BS 4360/IS-2062 Gr.E-250B (or equivalent) for ordinary wafer application when it is not corrosive in nature.</p> <p>(f) Tank shall be provided with suitable supporting joints. All vessels shall be provided with lifting lugs, eye bolts etc. for effective handling during erection.</p> <p>(j) Tanks shall be provided with float operated level indicators/level gauges/level transmitters and level switches, as required, with complete assembly. Suitable flanged pads for level switches mounting shall also be provided. The level indicator can be top or side mounted as the case may be.</p> <p>(k) In addition to inlet and outlet nozzles, the tanks shall be provided with vents, overflow, drain nozzles complete for various connections on tanks. Overflow lines from storage tanks is to be routed to the nearest surface drains. For tanks containing dm water, alkaline water or power cycle water the vent to atmosphere shall be through carbon-di-oxide absorber vessel suitably mounted on the tank. CO2 absorber vessel shall be provided with the initial fill of chemicals.</p> <p>(l) Tanks shall have suitable stairs/ladders on inside and outside of the tanks, manholes/inspection covers as required and also platform suitably located.</p> <p>(m) Tank supporting arrangement as approved by Employer shall be provided with all plates/angles/joints/flats and supporting attachment including lugs, saddles, legs etc.</p> <p>(o) Tank fabrication drg. and design calculations shall be approved by the Project Manager.</p>		
KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES	TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371	SUB-SECTION- A6 (LOW PRESSURE PIPING)	PAGE 16 OF 21

985830/2022/PS-PEM-MAX





## TECHNICAL REQUIREMENTS



CLAUSE NO.		
2.17.03	<p><b>Corrosion protection</b></p> <p>(a) A corrosion allowance, applicable to surface in contact with corrosive media, when required after thorough cleaning by blast cleaning preceded by wire brushing shall be taken into consideration.</p> <p>(b) Manholes shall be provided for easy access into the vessels. The size shall be minimum 500 mm and will be with cover plate, nuts bolts, etc. to ensure leak tightness at the test pressure.</p> <p>(c) Each tank shall be provided with drilled cleats welded to the tank for electrical grounding. Material of cleats shall be same as that of the shell.</p>	
	<p>-----</p> <p><b>Sl. No. Description</b></p> <p>-----</p>	<p><b>Tech. Particulars</b></p> <p>-----</p>
	<b>DRINKING WATER TANK</b>	
	a) Quantity	One per each Unit
	b) Liquid to be handled	Drinking Water
	c) Size and Min. Plate Thickness	5m long x 2.5m wide x 2.5m high; Plate Thk. (min.) 8mm Overall Cap.= 31.25 M <sup>3</sup> (Effective cap.: 25M <sup>3</sup> ).
	d) Type	Pressed steel rectangular tank Closed top/ welded construction
	e) Design pressure	Atmospheric
	f) Tank Standard	BS-1564/IS-804 (Latest Edition)
	g) Material of Construction	Plates to ASTM-A-36/IS-2062 Gr.B
	h) Flange Material Standard	ASTM-A-105/IS-2062-Gr. B
	i) Accessories	
	(i) Vent, Overflow, drain piping & valve	To be provided
	(ii) Manhole	To be provided
	(iii) Stair/Platform	To be provided
	(iv) Supporting structure	To be provided
	(v) Internal ladder	To be provided
	(vi) Level indicator	To be provided
	(vii) Root valve for level transmitter	To be provided
	j) Protection of Internal surface	Two coats of food grade epoxy paint

<b>KHURJA SUPER THERMAL POWER PROJECT</b> (2X660 MW) <b>TURBINE GENERATOR AND ASSOCIATED PACKAGES</b>	<b>TECHNICAL SPECIFICATION</b> <b>SECTION – VI, PART-B</b> <b>BID DOC. NO.:</b> <b>THDC/RKSH/CC-9915-371</b>	<b>SUB-SECTION- A6</b> <b>(LOW PRESSURE PIPING)</b>	<b>PAGE 17 OF</b> <b>21</b>
---	---	--	--------------------------------

985830/2022/PS-PEM-MAX

CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b>	
	k) Protection of external surface	Two coats of EPOXY based paint preceded by one(1) coat of primer. (minimum DFT 100 micron)
	l) Location	On Power House roof.
.....		
	<b>1.00 CONDENSATE STORAGE TANKS</b>	
1.01	Number required	one for each unit
1.02	Capacity of each tank (Effective)	350 Cu.m ( for 660MW units),
1.03	Size (Dia & Height)/Plate Thickness	8.6mX7.2m minimum, Shell & Roof plate Thickness 8mm and Base plate thickness 10mm
1.04	Type and pressure class	Vertical, cylindrical, atmospheric
1.05	Material of construction	MS- (IS-2062 Gr.B or equivalent) as per specified code, 8mm thickness (minimum)
1.06	Location	Outdoor
1.07	Overflow, drain, vent and Sample connection(piping &valve)	required
1.08	Level Indicator	
	a) Number	One for each tank
	b) Type	Mechanical float type with dial type indicator (Guide wire, Float and Housing of Stainless steel - 316 Gr. construction)
1.09	Manhole (minimum 500mm size)	Two (2)-one on shell and the other on roof
1.10	Special Fittings	
	a) Hydraulic Seal of Overflow/Drain	Required

985830/2022/PS-PEM-MAX



## TECHNICAL REQUIREMENTS



CLAUSE NO.	TECHNICAL REQUIREMENTS		
	b)	Additional nozzle Connection	number and size to be indicated to successful Bidder
	c)	Nozzle connection for Instrument/spare	Three (3) nos. for each tank
	d)	CO2 Absorber for vent (not to be kept on roof of tank, but to be kept on ground level)	required
	e)	Outside stair case (spiral)	required
	f)	Inside Ladder	Required
	g)	Draw off sump	required
	h)	Root valve for level Transmitter	Root valves for two (2) nos. level transmitter for each tank Required
2.18.00	<b>RUBBER EXPANSION JOINTS</b>		
2.18.01	All parts of expansion joints shall be suitably designed for all stresses that may occur during continuous operation and for any additional stresses that may occur during installation and also during transient condition.		
2.18.02	The expansion joints shall be single bellow rubber expansion joints. The arches of the expansion joints shall be filled with soft rubber.		
2.18.03	The tube (i.e. inner cover) and the cover (outer) shall be made of natural or synthetic rubber of adequate hardness. The shore hardness shall not be less than 60 deg. A for outer and 50 deg. A for inner cover.		
2.18.04	The carcass between the tube and the cover shall be made of high quality cotton duck, preferably, square woven to provide equal strength in both directions of the weave. The fabric plies shall be impregnated with age resistant rubber or synthetic compound and laminated into a unit.		
2.18.05	Reinforcement, consisting of solid metal rings embedded in carcass shall be provided.		
2.18.06	Expansion joints shall be complete with stretcher bolt assembly. The expansion joints shall be suitable to absorb piping movements and accommodate mismatch between pipe lines.		
2.18.07	The expansion joints shall be of heavy duty construction made of high grade abrasion-resistant natural or synthetic rubber compound. The basic fabric for the 'duck' shall be either a superior quality braided cotton or synthetic fibre having maximum flexibility and non-set characteristic.		
2.18.08	The expansion joints shall be adequately reinforced, with solid steel rings, to meet the service conditions under which they are to operate.		
2.18.09	All expansion joints shall be provided with stainless steel retaining rings for DM water application and IS 2062 Gr E-250B galvanized steel retaining rings for ordinary water for use on the inner face of the rubber flanges, to prevent any possibility of damage to the rubber		
KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES	TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371	SUB-SECTION- A6 (LOW PRESSURE PIPING)	PAGE 19 OF 21

985830/2022/PS-PEM-MAX



## TECHNICAL REQUIREMENTS



CLAUSE NO.	
2.18.10	when the bolts are tightened. These rings shall be split and beveled type for easy installation and replacement and shall be drilled to match the drilling on the end rubber flanges and shall be in two or more pieces.
2.18.10	The expansion joints shall have integral fabric reinforced full-face rubber flanges. The bolt on one flange shall have no eccentricity in relation to the corresponding bolt hole on the flange on the other face. The end rubber flanges shall be drilled to suit the companion pipe flanges. The flanges shall be as per ANSI B 16.5. For higher sizes, not covered under ANSI B 16.5, the same shall be as per AWWA.
2.18.11	All exposed surfaces of the expansion joint shall be given a 3 mm thick coating of neoprene. This surface shall be reasonably uniform and free from any blisters, porosity and other surface defects.
2.18.12	Each control unit shall consist of two (2) numbers of triangular stretcher bolt plates, a stretcher bolt with washers, nuts, and lock nuts. Each plate shall be drilled with three holes, two for fixing the plate on to the companion steel flange and the third for fixing the stretcher bolt.
2.18.13	Each joint shall have a permanently attached brass or stainless steel metal tag indicating the tag numbers and other salient design features.
2.18.14	Bidder to note that any metallic part which comes in contact with DM /corrosive water shall be of Stainless Steel material.
2.18.15	<p><b>Life cycle test for RE Joints of Condenser CW Inlet Outlet lines:</b></p> <p>Life cycle test certificates shall be furnished by the bidder for each type and size of RE joints supplied by the Bidder, in the absence of which actual Life cycle test shall be conducted on one rubber expansion joint of each type and size .</p>
2.19.00	<b>STRAINERS</b>
2.19.01	<p><b>Simplex type</b></p> <p>The strainers shall be basket type and of simplex construction. The strainer shall be provided with plugged drain/blow off and vent connections. The free area of the strainer element shall be at least four (4) times the internal area of the connecting pipe lines. The strainer element shall be 20 mesh. Pressure drop across the strainers in new condition shall not exceed 1.5 MCW at full flow. Wire mesh of the strainers shall be suitably reinforced, to avoid buckling under operation. Strainer shall have screwed blow off connection fitted with a removable plug. The material of construction of various parts shall be as follows:</p>
	<p>(a) Body IS: 318, Gr. 2 up to 50 mm Nb, and IS: 210 Gr. FG 260 above 50 mm Nb. (For DM water/ -Body: AISI 316 or equivalent)</p>
	<p>(b) Strainer Element Stainless steel (AISI 316)</p>
	<p>(c) End connection Screwed upto 50 mm Nb, and Flanged above 50 mm Nb</p>
2.19.02	<p><b>Duplex type</b></p> <p>(a) The strainers shall be basket type and of duplex construction. The strainer shall be provided with plugged drain/blow off and vent connections. The free area of the strainer element shall be at least four (4) times the internal area of the connecting</p>

KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES	TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371	SUB-SECTION- A6 (LOW PRESSURE PIPING)	PAGE 20 OF 21
--	---	---	------------------



985830/2022/PS-PEM-MAX







## TECHNICAL REQUIREMENTS





CLAUSE NO.	TECHNICAL REQUIREMENTS		
	<p>pipe. The mesh of strainer element shall be commensurate with the actual service required. Pressure drop across the strainer in new condition shall not exceed 4.0 MWC at full flow.</p> <p>(b) Wire mesh (if applicable) of the strainers shall be suitably reinforced. The material of construction of various parts shall be as follows.</p> <p>Body                    IS: 318, Gr. 2 up to 50 mm Nb, and IS:210, Gr. FG 260 or ASTM-A-515 Gr. 75/IS-2062 Gr. E-250B and internally epoxy-painted above 50 mm NB.</p> <p>Strainer element        Stainless steel (AISI 316)</p> <p>End connection         Screwed up to 50mm Nb, and Flanged above 50 mm Nb. Gasket shall be of full face type</p> <p>(c) The strainer will have a permanent stainless steel tag fixed on the strainer body indicating the strainer tag number and service and other salient data.</p> <p>(d) The size of the strainer and the flow direction will be indicated on the strainer body casting.</p> <p>(e) Thickness of the strainer element should be designed to withstand the pressure developed within the strainer due to 100% clogged condition exerting shut-off pressure on the element.</p> <p><b>Note:</b> <b>Bidder to refer Specific Technical Requirements/ Sub Section IA/ Data Sheet-A for minimum technical requirements of the piping, fittings, valves, strainers etc. However, bidder to refer this chapter for other technical requirements of the piping, fittings, valves, strainers etc..</b></p>		
KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES	TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371	SUB-SECTION- A6 (LOW PRESSURE PIPING)	PAGE 21 OF 21



<p>CLAUSE NO.</p>	 <p style="text-align: center;"><b>TECHNICAL REQUIREMENTS</b></p> 		
	<p style="text-align: center;"><b>GENERAL SPECIFICATION FOR HORIZONTAL PUMPS</b></p> <p>(1) <b>SCOPE</b></p> <p>This specification covers the design, material, construction features, manufacture, inspection, testing the performance at the Vendor's/Sub-Vendor's Works and delivery to site of Horizontal Centrifugal Pumps.</p> <p>(2) <b>CODES AND STANDARDS</b></p> <p>The design, material, construction, manufacture inspection and performance testing of Horizontal Centrifugal Pumps shall comply with all currently applicable statutes, regulations and safety codes in the locality where the Equipment will be installed. Nothing in these specifications shall be construed to relieve the Vendor of this responsibility. The Equipment supplied shall comply with the latest applicable Indian Standards listed below. Other National Standards are acceptable, if they are established to be equal or superior to the Indian Standards.</p> <p>(3) <b>LIST OF APPLICABLE STANDARDS</b></p> <p>IS : 1520 : Horizontal Centrifugal Pumps for clear cold fresh water</p> <p>IS : 5120 : Technical requirements of rotodynamic special purpose pumps</p> <p>API : 610 : Centrifugal pumps for general refinery service.</p> <p>IS : 5639 : Pumps Handling Chemicals &amp; corrosion liquids</p> <p>IS : 5659 : Pumps for process water</p> <p>HIS : Hydraulic Institute Standards, USA</p> <p>ASTM-1-165-65: Standards Methods for Liquid Penetration Inspection.</p> <p>In case of any contradiction with aforesaid standards and the stipulations as per the technical specifications as specified hereinafter the stipulations of the technical specifications shall prevail.</p> <p>(4) <b>DESIGN REQUIREMENTS</b></p> <p>(a) The Pump shall be capable of developing the required total head at rated capacity for continuous operation. Also the pumps shall be capable of being operated to give satisfactory performance at any point on the HQ characteristics curve. The operating range of the pump shall be 40% to 120% of the duty point unless otherwise mentioned elsewhere. The maximum efficiency of pump shall preferably be within <math>\pm 10\%</math> of the rated design flow as indicated in data sheets.</p> <p>(b) The total head capacity curve shall be continuously rising from the operating point towards shut – off without any zone of instability with the highest head at shut-off condition. Shut-off head shall be more than the rated design head and the percentage variation may vary depending on the specific speed of the pumps (i.e) 10-15% for</p>		
<p><b>KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES</b></p>	<p><b>TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371</b></p>	<p><b>SUB-SECTION- A-4 EQUIPMENT COOLING WATER SYSTEM</b></p>	<p><b>PAGE 13 OF 20</b></p>



CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 									
	<p>pumps of specific speed upto 1000 US units, about 15 to 20% for specific speed in the range of 1000 to 2000 US units, about 20% to 40% for specific speed of 2000 to 4000 US units and above 50% for specific speed of 4000 to 7000 US Units</p> <p>(c) Pumps of a particular category shall be identical and shall be suitable for parallel operation with equal load division. The head Vs capacity and BHP Vs capacity characteristics should match to ensure even load sharing and trouble free operation throughout the range. Components of identical pumps shall be interchangeable.</p> <p>(d) Pumps shall run smoothly without undue noise and vibration. Peak to peak vibration limits shall be restricted to the following values during operation:</p> <table border="1" data-bbox="446 535 1380 693"> <thead> <tr> <th><u>Speed</u></th> <th><u>Antifriction Bearing</u></th> <th><u>Sleeve Bearing</u></th> </tr> </thead> <tbody> <tr> <td>1500 rpm and below</td> <td>75.0 micron</td> <td>75.0 micron</td> </tr> <tr> <td>3000 rpm</td> <td>50.0 micron</td> <td>65.0 micron</td> </tr> </tbody> </table> <p>The noise level shall not exceed 85 dBA overall sound pressure level reference 0.0002 microbar (the standard pressure reference for air sound measurement) at a distance of 1 M from the equipment surface.</p> <p>(e) The pumps shall be capable of starting with discharge valve fully open and close condition. Motors shall be selected to suit to the above requirements.</p> <p>(f) Pumps shall be so designed that pump impellers and other accessories of the pumps are not damaged due to flow reversal.</p> <p>(g) The Contractor under this specification shall assume full responsibility in the operation of pump and motor as a unit.</p> <p>(5) <b>DESIGN CONSTRUCTION</b></p> <p>(a) Design and construction of various components of the pumps shall conform to the following general specifications. For material of construction of the components, data sheets shall be referred to.</p> <p>(b) Pump Casing</p> <p>Pump casing shall have axially or radially split type construction as specified. The casing shall be designed to withstand the maximum shut-off pressure developed by the pump at the pumping temperature.</p> <p>Pump casing shall be provided with a vent connection and piping with fittings &amp; valves. Casing drain as required shall be provided complete with drain valves, piping and plugs. It shall be provided with a connection for suction and discharge pressure gauge as standard feature. It shall be structurally sound to provide housing for the pump assembly and shall be designed hydraulically to minimum radial load at part load operation.</p> <p>(c) Impeller</p> <p>Impeller shall be closed, semi-closed or open type as specified elsewhere and designed in conformance with the detailed analysis of the liquid being handled.</p>	<u>Speed</u>	<u>Antifriction Bearing</u>	<u>Sleeve Bearing</u>	1500 rpm and below	75.0 micron	75.0 micron	3000 rpm	50.0 micron	65.0 micron
<u>Speed</u>	<u>Antifriction Bearing</u>	<u>Sleeve Bearing</u>								
1500 rpm and below	75.0 micron	75.0 micron								
3000 rpm	50.0 micron	65.0 micron								
<p><b>KHURJA SUPER THERMAL POWER PROJECT</b> (2X660 MW) <b>TURBINE GENERATOR AND ASSOCIATED PACKAGES</b></p>	<p><b>TECHNICAL SPECIFICATION SECTION – VI, PART-B</b> <b>BID DOC. NO.:</b> <b>THDC/RKSH/CC-9915-371</b></p>	<p><b>SUB-SECTION- A-4</b> <b>EQUIPMENT COOLING WATER SYSTEM</b></p>	<p><b>PAGE</b> <b>14 OF 20</b></p>							



CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 		
	<p>The impeller shall be secured to the shaft, and shall be retained against circumferential movement by keying, pinning or lock rings. On pumps with overhung shaft, impellers shall be secured to the shaft by a lockout or cap screw which tightness in the direction of normal rotation.</p> <p>(d) Impeller/Casing Wearing Rings</p> <p>Replaceable type wearing rings shall be provided at suitable locations of pumps as per manufacturer's standard practice. Suitable method of locking the wearing ring shall be used.</p> <p>(e) Shaft</p> <p>The critical speed shall be well away from the operating speed and in no case less than 130% of the rated speed.</p> <p>The shaft shall be ground and polished to final dimensions and shall be adequately sized to withstand all stresses from rotor weight, hydraulic loads, vibration and torques coming in during operation.</p> <p>(f) Shaft Sleeves</p> <p>Renewable type fine finished shaft sleeves shall be provided at the stuffing boxes/mechanical seals. Length of the shaft sleeves must extend beyond the outer faces of gland packing of seal end plates so as to distinguish between the leakage between shaft and shaft sleeve and that past the seals/gland.</p> <p>Shaft sleeves shall be fastened to the shaft to prevent any leakage or loosening. Shaft and shaft sleeve assembly should ensure concentric rotation.</p> <p>(g) Bearings</p> <p>Heavy duty bearings, adequately designed for the type of service specified in the enclosed pump data sheet and for long, trouble free operation shall be furnished.</p> <p>The bearings offered shall be capable of taking both the radial and axial thrust coming into play during operation. In case, sleeve bearings are offered additional thrust bearings shall be provided. Antifriction bearings of standard type, if provided, shall be selected for a minimum life 20,000 hrs. of continuous operation at maximum axial and radial loads and rated speed.</p> <p>Proper lubricating arrangement for the bearings shall be provided. The design shall be such that the bearing lubricating element does not contaminate the liquid pumped. Where there is a possibility of liquid entering the bearings suitable arrangement in the form of deflectors or any other suitable arrangement must be provided ahead of bearings assembly.</p> <p>Bearings shall be easily accessible without disturbing the pump assembly. A drain plug shall be provided at the bottom of each bearings housing.</p> <p>(h) Stuffing Boxes</p> <p>Stuffing boxes of packed ring construction type shall be provided wherever specified. Packed ring stuffing boxes shall be properly lubricated and sealed as per service requirements and manufacturer's standards. If external gland sealing is required, it</p>		
<p><b>KHURJA SUPER THERMAL POWER PROJECT</b> (2X660 MW) <b>TURBINE GENERATOR AND ASSOCIATED PACKAGES</b></p>	<p><b>TECHNICAL SPECIFICATION SECTION – VI, PART-B</b> <b>BID DOC. NO.:</b> <b>THDC/RKSH/CC-9915-371</b></p>	<p><b>SUB-SECTION- A-4</b> <b>EQUIPMENT COOLING WATER SYSTEM</b></p>	<p><b>PAGE</b> <b>15 OF 20</b></p>

CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 		
	<p>shall be done from the pump discharge. The Bidder shall provide the necessary piping valves, fittings etc. for the gland sealing connection.</p> <p>(i) Mechanical Seals</p> <p>Wherever specified in pump data sheet, mechanical seals shall be provided. Unless otherwise recommended by the tenderer, mechanical seals shall be of single type with either sliding gasket or bellows between the axially moving face and shaft sleeves or any other suitable type. The sealing faces should be highly lapped surfaces of materials known for their low frictional coefficient and resistance to corrosion against the liquid being pumped.</p> <p>(j) The pump supplier shall coordinate with the seal maker in establishing the seal chamber of circulation rate for maintaining a stable film at the seal face. The seal piping system shall form an integral part of the pump assembly. For the seals under vacuum service, the seal design must ensure sealing against atmospheric pressure even when the pumps are not operating. Necessary provision for seal water supply along with complete piping fittings and valves as required shall form integral part of pump supply.</p> <p>(k) Pump Shaft Motor Shaft Coupling</p> <p>The pump and motor shafts shall be connected with an adequately sized flexible coupling of proven design with a spacer to facilitate dismantling of the pump without disturbing the motor. Necessary coupling guards shall also be provided.</p> <p>(l) Base Plate</p> <p>A common base plate mounting both for the pump and motor shall be furnished. The base plate shall be fabricated steel and of rigid construction, suitably ribbed and reinforced. Base plate and pump supports shall be so constructed and the piping unit so mounted as to minimise misalignment caused by mechanical forces such as normal piping strain, internal differential thermal expansion and hydraulic piping thrust. Suitable drain troughs and drip lip shall be provided.</p> <p>(m) Assembly and Dismantling</p> <p>Assembly and dismantling of each pump with drive motor shall be possible without disturbing the grouting base plate or alignment.</p> <p>(n) Drive Motor (Prime Mover)</p> <p>Continuous Motor rating (at 50 0 C ambient) shall be at least ten percent (10%) above the maximum load demand of the pump in the entire operating range to take care of the system frequency variation and in no case less than the maximum power requirement at any condition of the entire characteristic curve of the pump. The KW rating of the drive unit shall be based on continuously driving the connected equipment for the conditions specified. However, in cases where parallel operation of the pumps are specified, the actual motor rating is to be selected by the Bidder considering overloading of the pumps in the event of tripping of operating pump(s).</p> <p><b>Note:</b>  <b>Bidder to refer Specific Technical Requirements/ Sub Section IA/ Data Sheet-A for minimum technical requirements of the horizontal pumps. However, bidder to refer this chapter for other technical requirements of the pumps.</b></p>		
KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES	TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371	SUB-SECTION- A-4 EQUIPMENT COOLING WATER SYSTEM	PAGE 16 OF 20

985830/2022/PS-PEM-MAX

CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 		
1.00.00 1.01.00 2.00.00 2.01.00 3.00.00 4.00.00 5.00.00	<p style="text-align: center;"><b>SUBMERSIBLE PUMPS</b></p> <p><b>SCOPE</b></p> <p>This specification covers general requirements in respect of design, material, manufacture, construction, testing &amp; inspection at Vendor's / sub-vendor's delivery to site, of submersible pumps.</p> <p><b>CODES AND STANDARD</b></p> <p>The design manufacture and performance of submersible pumps shall be comply with all currently applicable statues, regulation, and safely codes in the locality where the Equipment will be installed. The Equipment shall also conform to the latest applicable Indian standards listed below other Nation Standards are acceptable, if they are established to be equal or superior to the listed standards. Nothing in these specifications shall be construed to relieve the contractor of this responsibility.</p> <p><b>List of Applicable Indian Standards</b></p> <p>IS:8034            -            Submersible pumps for clear cold fresh water</p> <p>IS:5120            -            Technical requirement of Rotodynamic Special Purpose pumps.</p> <p>In case of any contradiction with aforesaid standards and the stipulations as per technical specification as specified hereinafter the stipulation of the technical specification shall prevail.</p> <p><b>DESIGN AND PERFORMANCE REQUIREMENTS</b></p> <p>a) The pump shall be of single stage mono - block type with non-clog design.</p> <p>b)        Components of Identical pumps shall be interchangeable.</p> <p>c)        Pumps shall have a continuously rising head characteristics.</p> <p><b>MOTOR RATING</b></p> <p>Continuous motor rating (at 50 deg. C ambient) for pumps shall be atleast ten percent (10%) above the maximum load demand of the driven equipment in the complete operating range to take care of the system frequency variations.</p> <p><b>FEATURES OF CONSTRUCTION</b></p> <p>a)        Pumps shall be of Submersible, wet pit type.</p> <p>b)        Pumps shall be able to pass through solids upto 40 mm and capable of handling waste water which may contain, sludge, plastic solids etc.</p> <p>c)        Coupling device shall ensure leak proof joint between the pump and discharge elbow. This shall also enable pump to be removed from the sumps without the necessity of dismantling any nuts, bolts etc.</p>		
<b>KHURJA SUPER THERMAL POWER PROJECT</b> (2X660 MW) <b>TURBINE GENERATOR AND ASSOCIATED PACKAGES</b>	<b>TECHNICAL SPECIFICATION</b> <b>SECTION – VI, PART-B</b> <b>BID DOC. NO.:</b> <b>THDC/RKSH/CC-9915-371</b>	<b>SUB-SECTION- A-4</b> <b>EQUIPMENT COOLING WATER</b> <b>SYSTEM</b>	<b>PAGE</b> <b>17 OF 20</b>

CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 		
6.00.00	<p>d) Pumps shall be portable type and capable of using in any sump as and when required. Pump shall be provided with required stool, flexible, hoses chain connection etc. for easy installation, removal and maintenance. Adequate length of chain required for lowering the pump into the sump and flexible type discharge pipe shall be provided.</p> <p>e) Impeller</p> <p>Impeller type shall be open/semi-closed type/closed as indicated elsewhere. Enclosed impellers shall be equipped with seal rings on their hubs. In case of open impeller, the pump shall be design to take care of the additional thrust produced.</p> <p><b>MOTOR</b></p> <p>i) Motor shall be coupled directly to the impeller shaft.</p> <p>ii) The motor shall be suitable for operation when submersed in water. The housing shall have required degree of protection.</p> <p>iii) Necessary arrangement to be made to make cable entry absolutely water tight, with cores cast in insulation along with cable gland 'O' ring seat.</p> <p>iv) Built in temperature sensors are to be provided to enable tipping of motor if temperature rises above the design temperature limit. These sensors are to be used directly in the circuiting of control panel. The control circuit should trip the motor if the temperature rises beyond safe limits.</p> <p>v) Moisture sensors are to be embedded in motor chamber to trip the motor in case of moisture entry in motor due to failure of pump mechanical seal.</p> <p>vi) Motor shall be oil filled/oil lubricated or water filled type. Pressure equalizing diaphragm and sand guards with seal shall be provided to prevent the water and sand entering the motor.</p> <p>vii) Power supply to the motor and control connections shall be preferably combined in one cable and shall be flexible copper conductor PVC insulated, armoured and overall hard grade PVC sheathed, and suitable for under water service. The cable gland shall be properly sealed to prevent entry of pumped liquid the motor. Length of the cable shall be of suitable for site conditions. The cable shall be terminated on the control panel with necessary facility to terminate with the power receptacle.</p> <p>viii) For pumps which are specified under portable application, Cable shall be suitable for continuous winding/un winding duty on a cable reeling drum and shall be installed on a trolley mounted on wheels. Associated control panel is also to be mounted on the trolley.</p> <p>ix) Water level controller shall be provided which should be with two level controls, high to start and low to stop.</p>		
7.00.00	<p><b>Equipment Data Sheet</b></p> <p>Type of pump : Submersible type fixed inside pits/ sump with guides /lifting chains</p> <p>Type of Working Fluid : Drains with particle size upto 40 mm</p>		
<p><b>KHURJA SUPER THERMAL POWER PROJECT</b> (2X660 MW) <b>TURBINE GENERATOR AND ASSOCIATED PACKAGES</b></p>	<p><b>TECHNICAL SPECIFICATION SECTION – VI, PART-B</b> <b>BID DOC. NO.:</b> <b>THDC/RKSH/CC-9915-371</b></p>	<p><b>SUB-SECTION- A-4</b> <b>EQUIPMENT COOLING WATER SYSTEM</b></p>	<p><b>PAGE</b> <b>18 OF 20</b></p>

CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 		
	<p>Type of impeller : Open</p> <p>Type of lubrication : Self / Grease / Oil</p> <p>Speed : Preferrably 1500 rom (maximum)</p> <p><b>Material of Construction</b></p> <p>a) Casing : 2% Nickel Cast Iron, IS:210 Grade FG 260;</p> <p>b) Impeller : SS-316 / CF8M</p> <p>c) Shaft : SS- 410</p> <p>d) Bolts &amp; nuts : SS-316</p> <p>e) Accessories : Suction Strainer, Pump stand, Adaptors for discharge flange, Level measuring devices/ Controllers, Lifting hook &amp; chain Handle to agitate debris etc, Discharge hose connected with piping upto the drains etc.</p> <p>f) The discharge, suction /column pipes shall be heavy grade Carbon steel externally lined with epoxy or galvanised.</p> <p><b>Note:</b>  <b>Bidder to refer Specific Technical Requirements/ Sub Section IA/ Data Sheet-A for minimum technical requirements of the Submersible pumps. However, bidder to refer this chapter for other technical requirements of the pumps.</b></p>		
<p><b>KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES</b></p>	<p><b>TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371</b></p>	<p><b>SUB-SECTION- A-4 EQUIPMENT COOLING WATER SYSTEM</b></p>	<p><b>PAGE 19 OF 20</b></p>

985836/2022/PS-PEM-MAX



TITLE:

2X660 MW THDC KHURJA STPP- CW  
SYSTEM CIVIL WORKS

SPECIFICATION NO. PE-TS-492-673-A001

TECHNICAL SPECIFICATION FOR SEWAGE  
TREATMENT PLANT

SECTION -II

SUB SECTION -IIB

REV. NO. 00

DATE :

## SUBSECTION-IIB

### GENERAL TECHNICAL REQUIREMENT (ELECTRICAL)

985830/2022/PS-PEM-MAX



TITLE :

GENERAL TECHNICAL REQUIREMENTS

FOR

LV MOTORS

SPECIFICATION NO.

PE-SS-999-506-E101

VOLUME NO. : II-B

SECTION : D

REV NO. : 00 DATE : 29/08/2005

SHEET : 1 OF 1

## GENERAL TECHNICAL REQUIREMENTS

FOR

LV MOTORS

SPECIFICATION NO.: PE-SS-999-506-E101 Rev 00



GENERAL TECHNICAL REQUIREMENTS

FOR

LV MOTORS

SPECIFICATION NO.

PE-SS-999-506-E101

VOLUME NO. : II-B

SECTION : D

REV NO. : 00 DATE : 29/08/2005

SHEET : 1 OF 4

### 1.0 INTENT OF SPECIFICATION

The specification covers the design, materials, constructional features, manufacture, inspection and testing at manufacturer's work, and packing of Low voltage (LV) squirrel cage induction motors along with all accessories for driving auxiliaries in thermal power station.

Motors having a voltage rating of below 1000V are referred to as low voltage (LV) motors.

### 2.0 CODES AND STANDARDS

Motors shall fully comply with latest edition, including all amendments and revision, of following codes and standards:

IS:325	Three phase Induction motors
IS : 900	Code of practice for installation and maintenance of induction motors
IS: 996	Single phase small AC and universal motors
IS: 4722	Rotating Electrical machines
IS: 4691	Degree of Protection provided by enclosures for rotating electrical machines
IS: 4728	Terminal marking and direction of rotation rotating electrical machines
IS: 1231	Dimensions of three phase foot mounted induction motors
IS: 8789	Values of performance characteristics for three phase induction motors
IS: 13555	Guide for selection and application of 3-phase A.C. induction motors for different types of driven equipment
IS: 2148	Flame proof enclosures for electrical appliance
IS: 5571	Guide for selection of electrical equipment for hazardous areas
IS: 12824	Type of duty and classes of rating assigned
IS: 12802	Temperature rise measurement for rotating electrical machines
IS: 12065	Permissible limits of noise level for rotating electrical machines
IS: 12075	Mechanical vibration of rotating electrical machines

In case of imported motors, motors as per IEC-34 shall also be acceptable.

### 3.0 DESIGN REQUIREMENTS

3.1 Motors and accessories shall be designed to operate satisfactorily under conditions specified in data sheet-A and Project Information, including voltage & frequency variation of supply system as defined in Data sheet-A

3.2 Motors shall be continuously rated at the design ambient temperature specified in Data Sheet-A and other site conditions specified under Project Information  
Motor ratings shall have at least a 15% margin over the continuous maximum demand of the driven equipment, under entire operating range including voltage & frequency variation specified above.

#### 3.3 Starting Requirements

3.3.1 Motor characteristics such as speed, starting torque, break away torque and starting time shall be properly co-ordinated with the requirements of driven equipment. The accelerating torque at any speed with the minimum starting voltage shall be at least 10% higher than that of the driven equipment.

3.3.2 Motors shall be capable of starting and accelerating the load with direct on line starting without exceeding acceptable winding temperature.



GENERAL TECHNICAL REQUIREMENTS  
FOR  
LV MOTORS

SPECIFICATION NO. PE-SS-999-506-E101
VOLUME NO. : II-B
SECTION : D
REV NO. : 00 DATE : 29/08/2005
SHEET : 2 OF 4

The limiting value of voltage at rated frequency under which a motor will successfully start and accelerate to rated speed with load shall be taken to be a constant value as per Data Sheet - A during the starting period of motors.

3.3.3 The following frequency of starts shall apply

- i) Two starts in succession with the motor being initially at a temperature not exceeding the rated load temperature.
- ii) Three equally spread starts in an hour the motor being initially at a temperature not exceeding the rated load operating temperature. (not to be repeated in the second successive hour)
- iii) Motors for coal conveyor and coal crusher application shall be suitable for three consecutive hot starts followed by one hour interval with maximum twenty starts per day and shall be suitable for minimum 20,000 starts during the life time of the motor

3.4 **Running Requirements**

3.4.1 Motors shall run satisfactorily at a supply voltage of 75% of rated voltage for 5 minutes with full load without injurious heating to the motor.

3.4.2 Motor shall not stall due to voltage dip in the system causing momentary drop in voltage upto 70% of the rated voltage for duration of 2 secs.

3.5 **Stress During bus Transfer**

3.5.1 Motors shall withstand the voltage, heavy inrush transient current, mechanical and torque stress developed due to the application of 150% of the rated voltage for at least 1 sec. caused due to vector difference between the motor residual voltage and the incoming supply voltage during occasional auto bus transfer.

3.5.2 Motor and driven equipment shafts shall be adequately sized to satisfactorily withstand transient torque under above condition.

3.6 Maximum noise level measured at distance of 1.0 metres from the outline of motor shall not exceed the values specified in IS 12065.

3.7 The max. vibration velocity or double amplitude of motors vibration as measured at motor bearings shall be within the limits specified in IS: 12075.


4.0 **CONSTRUCTIONAL FEATURES**

4.1 Indoor motors shall conform to degree of protection IP: 54 as per IS: 4691. Outdoor or semi-indoor motors shall conform to degree of protection IP: 55 as per IS: 4691 and shall be of weather-proof construction. Outdoor motors shall be installed under a suitable canopy

4.2 Motors upto 160KW shall have Totally Enclosed Fan Cooled (TEFC) enclosures, the method of cooling conforming to IC-0141 or IC-0151 of IS: 6362.

Motors rated above 160 KW shall be Closed Air Circuit Air (CACA) cooled

4.3 Motors shall be designed with cooling fans suitable for both directions of rotation.

	TITLE : <b>GENERAL TECHNICAL REQUIREMENTS</b>  <b>FOR</b>  <b>LV MOTORS</b>	SPECIFICATION NO. PE-SS-999-506-E101
		VOLUME NO. : <b>II-B</b>
		SECTION : <b>D</b>
		REV NO. : <b>00</b> DATE : 29/08/2005
		SHEET : 3 OF 4
4.4.	Motors shall not be provided with any electric or pneumatic operated external fan for cooling the motors.	
4.5	Frames shall be designed to avoid collection of moisture and all enclosures shall be provided with facility for drainage at the lowest point.	
4.6	<p>In case Class 'F' insulation is provided for LV motors, temperature rise shall be limited to the limits applicable to Class 'B' insulation.</p> <p>In case of continuous operation at extreme voltage limits the temperature limits specified in table-1 of IS:325 shall not exceed by more than 10°C.</p>	
4.7	<b>Terminals and Terminal Boxes</b>	
4.7.1	<p>Terminals, terminal leads, terminal boxes, windings tails and associated equipment shall be suitable for connection to a supply system having a short circuit level, specified in the Data Sheet-A.</p> <p>Unless otherwise stated in Data Sheet-A, motors of rating 110 kW and above will be controlled by circuit breaker and below 110 kW by switch fuse-contactor. The terminal box of motors shall be designed for the fault current mentioned in data sheet "A".</p>	
4.7.2	unless otherwise specified or approved, phase terminal boxes of horizontal motors shall be positioned on the left hand side of the motor when viewed from the non-driving end.	
4.7.3	Connections shall be such that when the supply leads R, Y & B are connected to motor terminals A B & C or U, V & W respectively, motor shall rotate in an anticlockwise direction when viewed from the non-driving end. Where such motors require clockwise rotation, the supply leads R, Y, B will be connected to motor terminals A, C, B or U W & V respectively.	
4.7.4	Permanently attached diagram and instruction plate made preferably of stainless steel shall be mounted inside terminal box cover giving the connection diagram for the desired direction of rotation and reverse rotation.	
4.7.5	Motor terminals and terminal leads shall be fully insulated with no bar live parts. Adequate space shall be available inside the terminal box so that no difficulty is encountered for terminating the cable specified in Data Sheet-A.	
4.7.6	Degree of protection for terminal boxes shall be IP 55 as per IS 4691.	
4.7.7	Separate terminal boxes shall be provided for space heaters.. If this is not possible in case of LV motors, the space heater terminals shall be adequately segregated from the main terminals in the main terminal box. Detachable gland plates with double compression brass glands shall be provided in terminal boxes.	
4.7.8.	Phase terminal boxes shall be suitable for 360 degree of rotation in steps of 90 degree for LV motors.	
4.7.9	Cable glands and cable lugs as per cable sizes specified in Data Sheet-A shall be included. Cable lugs shall be of tinned Copper, crimping type.	
4.8	Two separate earthing terminals suitable for connecting G.I. or MS strip grounding conductor of size given in Data Sheet-A shall be provided on opposite sides of motor frame. Each terminal box shall have a grounding terminal.	
4.9	<b>General</b>	




FILE :  
**GENERAL TECHNICAL REQUIREMENTS**  
**FOR**  
**LV MOTORS**

SPECIFICATION NO. PE-SS-999-506-E101
VOLUME NO. : <b>II-B</b>
SECTION : <b>D</b>
REV NO. : <b>00</b> DATE : 29/08/2005
SHEET : 4 OF 4


- 4.9.1 Motors provided for similar drives shall be interchangeable.
- 4.9.2 Suitable foundation bolts are to be supplied alongwith the motors.
- 4.9.3 Motors shall be provided with eye bolts, or other means to facilitate safe lifting if the weight is 20Kgs. and above.
- 4.9.4 Necessary fitments and accessories shall be provided on motors in accordance with the latest Indian Electricity rules 1956.
- 4.9.5 All motors rated above 30 kW shall be provided with space heaters to maintain the motor internal air temperature above the dew point. Unless otherwise specified, space heaters shall be suitable for a supply of 240V AC, single phase, 50 Hz.
- 4.9.6 Name plate with all particulars as per IS: 325 shall be provided
- 4.9.7 Unless otherwise specified, the colour of finish shall be grey to Shade No. 631 and 632 as per IS:5 for motors installed indoor and outdoor respectively. The paint shall be epoxy based and shall be suitable for withstanding specified site conditions.
- 5.0 INSPECTION AND TESTING**
- 5.1 All materials, components and equipments covered under this specification shall be procured, manufactured, as per the BHEL standard quality plan No. PED-506-00-Q-006/0 and PED-506-00-Q-007/2 enclosed with this specification and which shall be complied.
- 5.2 LV motors of type-tested design shall be provided. Valid type test reports not more than 5 year shall be furnished. In the absence of these, type tests shall have to be conducted by manufacturer without any commercial implication to purchaser.
- 5.3 All motors shall be subjected to routine tests as per IS: 325 and as per BHEL standard quality plan.
- 5.4 Motors shall also be subjected to additional tests, if any, as mentioned in Data Sheet A.
- 6.0 DRAWINGS TO BE SUBMITTED AFTER AWARD OF CONTRACT**
- a) OGA drawing showing the position of terminal boxes, earthing connections etc.
- b) Arrangement drawing of terminal boxes.
- c) Characteristic curves:  
*(To be given for motor above 55 kW unless otherwise specified in Data Sheet).*
- i) Current vs. time at rated voltage and minimum starting voltage.
- ii) Speed vs. time at rated voltage and minimum starting voltage.
- iii) Torque vs. speed at rated voltage and minimum voltage.  
 For the motors with solid coupling the above curves i), ii), iii) to be furnished for the motors coupled with driven equipment. In case motor is coupled with mechanical equipment by fluid coupling, the above curves shall be furnished with and without coupling.
- iv) Thermal withstand curve under hot and cold conditions at rated voltage and max. permissible voltage.

985830/2022/PS-PEM-MAX

	<b>LV MOTOR DATA SHEET - C</b>	SPECIFICATION NO.	
		VOLUME	II B
		SECTION D	
		REV NO. 00	DATE
		SHEET 1	OF 2


S. No.	Description	Data to be filled by successful bidder
<b>A.</b>	<b>General</b>	
1	Manufacturer & country of origin	
2	Motor type	
3	Type of starting	
4	Name of the equipment driven by motor & Quantity	
5	Maximum Power requirement of driven equipment	
6	Rated speed of Driven Equipment	
7	Design ambient temperature	
<b>B.</b>	<b>Design and Performance Data</b>	
1	Frame size & type designation	
2	Type of duty	
3	Rated Voltage	
4	Permissible variation for	
5	a) Voltage	
6	b) Frequency	
7	c) Combined voltage & frequency	
8	Rated output at design ambient temp (by resistance method)	
9	Synchronous speed & Rated slip	
10	Minimum permissible starting voltage	
11	Starting time in sec with mechanism coupled	
12	a) At rated voltage	
13	b) At min starting voltage	
14	Locked rotor current as percentage of FLC (including IS tolerance)	
15	Torque	
	a) Starting	
	b) Maximum	
16	Permissible temp rise at rated output over ambient temp & method	
17	Noise level at 1.0 m (dB)	
18	Amplitude of vibration	
19	Efficiency & P.F. at rated voltage & frequency	
	a) At 100% load	
	c) At 75% load	

NAME OF VENDOR			SEAL	REV.	
NAME	SIGNATURE	DATE			

	<b>LV MOTOR</b>  <b>DATA SHEET - C</b>	SPECIFICATION NO.	
		VOLUME	II B
		SECTION D	
		REV NO. 00	DATE
		SHEET 2	OF 2

S. No.	Description	Data to be filled by successful bidder
	c) At starting	
<b>C.</b>	<b>Constructional Features</b>	
1	Method of connection of motor driven equipment	
2	Applicable Standard	
3	DOP of Enclosure	
4	Method of cooling	
5	Class of insulation	
6	Main terminal box	
	a) Type	
	b) Power Cable details (Conductor, size, armour/unarmour)	
	c) Cable Gland & lugs details (Size, type & material)	
	d) Permissible Fault level ( kArms & duration in sec)	
7	Space heater details (Voltage & watts)	
8	Flame proof motor details (if applicable)	
	a) Enclosure	
	b) suitability for hazardous area	
	i Zone	O / I / II
	ii Group	IIA / IIB / IIC
9	No. of Stator winding	
10	Winding connection	
11	Kind of rotor winding	
12	Kind of bearings	
13	Direction of rotation when viewed from NDE	
14	Paint Shade & type	
15	Net weight of motor	
16	Outline mounting drawing No (To be enclosed as annexure)	
<b>D.</b>	<b>Characteristic curves/ drawings</b> (To be enclosed for motors of rating $\geq 55$ KW)	
	a) Torque speed characteristic	
	b) Thermal withstand characteristic	
	c) Current vs time	
	d) Speed vs time	

NAME OF VENDOR			SEAL	REV.	
NAME	SIGNATURE	DATE			

	DOCUMENT TITLE  <b>CONDUITS AND PIPES</b>	SPECIFICATION NO. PES-507-27	
		VOLUME II B	
		SECTION D	
		REVISION 0	DATE: 27/10/2010
		SHEET 2	OF 6

### 1.0 GENERAL

1.1 This specification covers the manufacture, inspection & testing at vendor's works and delivery to site of conduits, pipes and their fittings for electrical installation.

### 2.0 CODES AND STANDARDS

2.1 The material, constructional features and various processes involved in manufacture shall comply with currently applicable Indian Standards.

2.2 The following Indian Standards shall be applicable, in general. However if Data Sheet A specifies conformance to other international standards, the equivalent IEC/BS/other standards shall be considered.


- |                        |   |
|------------------------|---|
| a) IS:9537 (All Parts) | Conduits for electrical installation.   |
| b) IS:3480             | Flexible steel conduits for electrical wiring.  |
| c) IS:6946             | Flexible non-metallic conduits for electrical installation.   |
| d) IS:1239             | Mild steel tubes, tubulars and other wrought steel fittings.<br>(for size above 63mm dia of rigid conduits) |
| e) IS:2667             | Fittings for rigid steel conduits for electrical wiring.  |
| f) IS:3837             | Accessories for rigid steel conduits for electrical wiring.   |
| g) IS:3419             | Fittings for rigid non-metallic conduits.   |
| h) IS:6005             | Code of practice for phosphating iron & steel.  |
| i) IS:2629             | Recommended practice for hot dip galvanizing on iron and steel.   |
| j) IS:4759             | Specification for hot dip zinc coatings on structural steel and allied products.                            |
| k) IS:6745             | Methods for determination of mass of zinc coating on zinc coated iron and steel articles.                   |

### 3.0 DESIGN REQUIREMENTS AND CONSTRUCTIONAL FEATURES


The conduit and conduit accessories shall include conduit plugs & caps, gaskets and box cover etc in addition to any specific requirement given in Data Sheet A. The diameter of conduits and accessories shall be uniform throughout the length.

#### 3.1 Rigid Conduits and Fittings

3.1.1 Rigid conduits shall generally conform to the requirements of IS:9537 (Part I & Part II). However conduits above 63mm diameter shall conform to the requirements of IS:1239. Unless specified otherwise in Data Sheet A, all conduits and pipes shall be of medium duty.

	DOCUMENT TITLE  <b>CONDUITS AND PIPES</b>	SPECIFICATION NO. PES-507-27	
		VOLUME II B	
		SECTION D	
		REVISION 0	DATE: 27/10/2010
		SHEET 3	OF 6

- 3.1.2 The rigid conduits shall be hot dip galvanized inside and outside. Weight of zinc shall be as per IS:4759. Conduits shall be thoroughly cleaned and pretreated, conforming to IS:6005.
- 3.1.3 Conduits shall be supplied in approximate length as specified below
- a) Rigid Conduits 5 metres
  - b) Flexible Conduits 10 - 30 metres
- 3.1.4 Each end of conduit length shall be threaded. The ends of conduits shall be sealed with protective caps to prevent damage to threaded portions and entrance of moisture and foreign material.
- 3.1.5 The inside surface of all conduits shall be smooth and suitable for pulling insulated cables and wires without damage.
- 3.1.6 Conduit fittings shall be made out of tube or cast to the shape as to match with corresponding conduit sizes and meet their purpose without any special adjustment.
- 3.1.7 All fittings shall be screwed type and hot dip galvanized inside and outside.
- 3.2 Flexible Metallic Conduits and Fittings
- 3.2.1 Flexible metallic conduits shall generally conform to the requirements of IS:3480.
- 3.2.2 Flexible conduits shall be made of strip steel which shall be of cold rolled mild steel. The strip shall be of uniform width and thickness throughout.
- 3.2.3 The strip shall be electro galvanized to a minimum thickness of 25 microns as specified in IS:3480. The surface of the strip shall be thoroughly cleaned before application of protective coating. Pretreatment, before galvanization, shall conform to IS:6005.
- 3.2.4 The strip for making flexible conduit shall be wound tightly and so overlapped in subsequent helicals that no openings are seen in normal position.
- 3.2.5 Flexible conduits shall be lead coated for application in high temperature zones, if specifically mentioned in Data Sheet A.
- 3.2.6 The conduit shall have uniform diameter throughout its length. The internal surface of all conduits shall be smooth and suitable for pulling insulated cables and wires without damage.
- 3.3 PVC Conduits
- 3.3.1 PVC conduits shall generally conform to the requirements of IS:9537(Part I & Part III).
- 4.0 INSPECTION
- 4.1 The following stages of manufacture shall be stage inspected by Purchaser or his duly authorized representative.
- 4.1.1 Inspection of manufacturing processes such as shearing, punching, bending, welding, galvanizing etc.
  - 4.1.2 Inspection of packing material and procedure.

	DOCUMENT TITLE  <b>CONDUITS AND PIPES</b>	SPECIFICATION NO. PES-507-27	
		VOLUME II B	
		SECTION D	
		REVISION 0	DATE: 27/10/2010
		SHEET 4	OF 6

4.1.3 Inspection of finished product.

4.2 The inspection will be carried out as per agreed quality plan.

## 5.0 TESTING

### 5.1 Rigid Conduits


- a) Acceptance Tests - as per IS:9537 Part 1 & 2 upto 63mm OD  
- as per IS:1239 above 63mm OD
- i) Dimension checks
- ii) Bending test (below 32mm OD)
- iii) Compression test
- b) Special Tests (as acceptance test) as applicable to galvanizing.

### 5.2 Flexible Steel Conduits

- a) Acceptance Tests - as per IS:3480
- i) Dimension checks
- ii) Linear breaking test
- iii) Test for flexibility
- iv) Bend fracture test
- v) crushing test
- b) Special Tests (as acceptance test) as applicable to galvanizing.

### 5.3 PVC Conduits

- a) Type Tests - as per IS : 9537 (Part 1 & 3)
- i) Dimension checks
- ii) Bending test
- iii) Compression test
- iv) Impact test
- v) Collapse test
- vi) Resistance test
- vii) Resistance to burning

	DOCUMENT TITLE  <b>CONDUITS AND PIPES</b>	SPECIFICATION NO. PES-507-27	
		VOLUME II B	
		SECTION D	
		REVISION 0	DATE: 27/10/2010
		SHEET 5	OF 6

viii) Electrical Characteristics

b) Acceptance tests - as per IS:9537 (Part 1 & 3)

i) Dimension checks

ii) Bending test

iii) Compression test

iv) Collapse test

v) Resistance to burning

vi) Electrical characteristics

5.4 Sampling for the tests shall be done as per applicable standards mentioned above.

5.5 The testing shall be carried out as per agreed quality plan.

#### 6.0 PACKING

6.1 The material shall be packed as per manufacturer's standard. Packing procedure shall be to the purchaser's approval.

#### 7.0 DRAWING, DATA AND DOCUMENTS REQUIRED

7.1 The following information shall be furnished within two weeks of award of contract, for purchaser's approval.

a) Manufacturing drawings/details.

b) Recommended Field quality plan covering site handling, storing, laying etc.

c) Final quality plan.

7.3 The following information shall be furnished after testing and inspection

Type Test, routine test and special test certificates in bound volume in requisite number.





## **SUB-SECTION – B-5**



# **CABLING EARTHING LIGHTNING AND PROTECTION**



**KHURJA SUPER THERMAL POWER PROJECT  
(2X660 MW)  
TURBINE GENERATOR AND ASSOCIATED PACKAGES  
BID DOC. NO.: THDC/RKSH/CC-9915-371**



**SEPARATOR**



CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 																																									
<b>1.00.00</b>	<b>CODES AND STANDARDS</b>																																									
1.01.00	<p>All standards, specifications and codes of practice referred to herein shall be the latest editions including all applicable official amendments and revisions as on date of opening of bid. In case of conflict between this specification and those (IS codes, standards, etc.) referred to herein, the former shall prevail. All work shall be carried out as per the following standards/ codes as applicable .</p> <table border="0"> <tr> <td data-bbox="391 422 695 453">IS:513</td> <td data-bbox="699 422 1437 453">Cold rolled low carbon steel sheets and strips.</td> </tr> <tr> <td data-bbox="391 478 695 510">IS:802</td> <td data-bbox="699 478 1437 531">Code of practice for the use of Structural Steel in Overhead Transmission Line Towers.</td> </tr> <tr> <td data-bbox="391 562 695 594">IS:1079</td> <td data-bbox="699 562 1437 594">Hot Rolled carbon steel sheet &amp; strips</td> </tr> <tr> <td data-bbox="391 619 695 651">IS:1239</td> <td data-bbox="699 619 1437 651">Mild steel tubes, tubulars and other wrought steel fittings</td> </tr> <tr> <td data-bbox="391 676 695 707">IS:1255</td> <td data-bbox="699 676 1437 728">Code of practice for installation and maintenance of power cables upto and including 33 KV rating</td> </tr> <tr> <td data-bbox="391 760 695 791">IS:1367 Part-13</td> <td data-bbox="699 760 1437 812">Technical supply conditions for threaded Steel fasteners. (Hot dip galvanized coatings on threaded fasteners).</td> </tr> <tr> <td data-bbox="391 844 695 875">IS:2147</td> <td data-bbox="699 844 1437 896">Degree of protection provided by enclosures for low voltage switchgear and control gear</td> </tr> <tr> <td data-bbox="391 928 695 959">IEC:62305</td> <td data-bbox="699 928 1437 980">Code of Practice for the protection of building and allied structures against lightning.</td> </tr> <tr> <td data-bbox="391 1012 695 1043">IS:2309</td> <td data-bbox="699 1012 1437 1064">Code of Practice for the protection of building and allied structures against lightning.</td> </tr> <tr> <td data-bbox="391 1096 695 1127">IS:2629</td> <td data-bbox="699 1096 1437 1127">Recommended practice for hot dip galvanising of iron &amp; steel</td> </tr> <tr> <td data-bbox="391 1159 695 1190">IS:2633</td> <td data-bbox="699 1159 1437 1190">Method for testing uniformity of coating on zinc coated articles.</td> </tr> <tr> <td data-bbox="391 1222 695 1253">IS:3043</td> <td data-bbox="699 1222 1437 1253">Code of practice for Earthing</td> </tr> <tr> <td data-bbox="391 1285 695 1316">IS:3063</td> <td data-bbox="699 1285 1437 1316">Fasteners single coil rectangular section spring washers.</td> </tr> <tr> <td data-bbox="391 1348 695 1379">IS:6745</td> <td data-bbox="699 1348 1437 1400">Methods for determination of mass of zinc coating on zinc coated iron &amp; steel articles.</td> </tr> <tr> <td data-bbox="391 1432 695 1463">IS:8308</td> <td data-bbox="699 1432 1437 1484">Compression type tubular in- line connectors for aluminium conductors of insulated cables</td> </tr> <tr> <td data-bbox="391 1516 695 1547">IS:8309</td> <td data-bbox="699 1516 1437 1568">Compression type tubular terminal ends for aluminium conductors of insulated cables.</td> </tr> <tr> <td data-bbox="391 1600 695 1631">IS:9537</td> <td data-bbox="699 1600 1437 1631">Conduits for electrical installation.</td> </tr> <tr> <td data-bbox="391 1663 695 1694">IS:9595</td> <td data-bbox="699 1663 1437 1715">Metal - arc welding of carbon and carbon manganese steels - recommendations.</td> </tr> <tr> <td data-bbox="391 1747 695 1778">IS:13573</td> <td data-bbox="699 1747 1437 1778">Joints and terminations for polymeric cables.</td> </tr> <tr> <td data-bbox="391 1810 695 1841">BS:476</td> <td data-bbox="699 1810 1437 1841">Fire tests on building materials and structures</td> </tr> </table>		IS:513	Cold rolled low carbon steel sheets and strips.	IS:802	Code of practice for the use of Structural Steel in Overhead Transmission Line Towers.	IS:1079	Hot Rolled carbon steel sheet & strips	IS:1239	Mild steel tubes, tubulars and other wrought steel fittings	IS:1255	Code of practice for installation and maintenance of power cables upto and including 33 KV rating	IS:1367 Part-13	Technical supply conditions for threaded Steel fasteners. (Hot dip galvanized coatings on threaded fasteners).	IS:2147	Degree of protection provided by enclosures for low voltage switchgear and control gear	IEC:62305	Code of Practice for the protection of building and allied structures against lightning.	IS:2309	Code of Practice for the protection of building and allied structures against lightning.	IS:2629	Recommended practice for hot dip galvanising of iron & steel	IS:2633	Method for testing uniformity of coating on zinc coated articles.	IS:3043	Code of practice for Earthing	IS:3063	Fasteners single coil rectangular section spring washers.	IS:6745	Methods for determination of mass of zinc coating on zinc coated iron & steel articles.	IS:8308	Compression type tubular in- line connectors for aluminium conductors of insulated cables	IS:8309	Compression type tubular terminal ends for aluminium conductors of insulated cables.	IS:9537	Conduits for electrical installation.	IS:9595	Metal - arc welding of carbon and carbon manganese steels - recommendations.	IS:13573	Joints and terminations for polymeric cables.	BS:476	Fire tests on building materials and structures
IS:513	Cold rolled low carbon steel sheets and strips.																																									
IS:802	Code of practice for the use of Structural Steel in Overhead Transmission Line Towers.																																									
IS:1079	Hot Rolled carbon steel sheet & strips																																									
IS:1239	Mild steel tubes, tubulars and other wrought steel fittings																																									
IS:1255	Code of practice for installation and maintenance of power cables upto and including 33 KV rating																																									
IS:1367 Part-13	Technical supply conditions for threaded Steel fasteners. (Hot dip galvanized coatings on threaded fasteners).																																									
IS:2147	Degree of protection provided by enclosures for low voltage switchgear and control gear																																									
IEC:62305	Code of Practice for the protection of building and allied structures against lightning.																																									
IS:2309	Code of Practice for the protection of building and allied structures against lightning.																																									
IS:2629	Recommended practice for hot dip galvanising of iron & steel																																									
IS:2633	Method for testing uniformity of coating on zinc coated articles.																																									
IS:3043	Code of practice for Earthing																																									
IS:3063	Fasteners single coil rectangular section spring washers.																																									
IS:6745	Methods for determination of mass of zinc coating on zinc coated iron & steel articles.																																									
IS:8308	Compression type tubular in- line connectors for aluminium conductors of insulated cables																																									
IS:8309	Compression type tubular terminal ends for aluminium conductors of insulated cables.																																									
IS:9537	Conduits for electrical installation.																																									
IS:9595	Metal - arc welding of carbon and carbon manganese steels - recommendations.																																									
IS:13573	Joints and terminations for polymeric cables.																																									
BS:476	Fire tests on building materials and structures																																									



| **KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES** | **TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371** | **SUB-SECTION-B-05 CABLING, EARTHING & LIGHTNING PROTECTION** | **PAGE 1 OF 23** |



CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 		
1.02.00	IEEE:80 IEEE:142 DIN 46267 (Part-II) DIN 46329 BS:6121	IEEE guide for safety in AC substation grounding Grounding of Industrial & commercial power systems Non tension proof compression joints for Aluminium conductors. Cable lugs for compression connections, ring type ,for Aluminium conductors Specification for mechanical Cable glands for elastomers and plastic insulated cables. Indian Electricity Act. Indian Electricity Rules. Equipment complying with other internationally accepted standards such as IEC, BS, DIN, USA, VDE, NEMA etc. will also be considered if they ensure performance and constructional features equivalent or superior to standards listed above. In such a case, the Bidder shall clearly indicate the standard(s) adopted, furnish a copy in English of the latest revision of the standards alongwith copies of all official amendments and revisions in force as on date of opening of bid and shall clearly bring out the salient features for comparison.	
<b>2.00.00</b>	<b>DESIGN AND CONSTRUCTIONAL FEATURE</b>		
2.01.00	<b>Inter Plant Cabling</b>		
2.01.01	Interplant cabling for main routes shall be laid along overhead trestles/duct banks. Cables from main plant to switchyard control room shall be laid in overhead trestles or duct bank. In case of Duct banks, pull-pits shall be filled with sand and provided with a PCC covering. Directly buried cables, if essential, shall not have concentration of more than 4 cables in one route. All HT, LT and Control cables shall be armored.		
2.01.02	<b>Transformer yard</b> In transformer yard cables shall be laid in <u>overhead trestle</u> . The main cable routes coming out from Main plant building and crossing the Transformer yard shall be laid in overhead trestles. In transformer yard, trestle height for rail/road crossing shall be suitable for movement of Generator Transformer with bushing.		
2.01.03	<b>Trenches</b> PCC flooring of built up trenches shall be sloped for effective drainage with sump pits and sump pumps.		
2.01.04	No sub zero level cable vault/trenches shall be provided below control building/switchgear rooms in main plant.		
2.01.05	<b>Cable Vault</b> The cable vault/ / cable spreader room space below the HT / LT switchgear room, Control Rooms, unit control equipment room, Programmer room, UPS, Charger & Battery Rooms, Boiler MCC room shall have <b>800 mm wide</b> and 2.1 m high movement passage all around the cable trays in the cable vault/ cable spreader room for easy laying/maintenance of cables Cable vaults shall be provided with adequate drainage facilities for drainage of fire water.		
<b>KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES</b>	<b>TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371</b>	<b>SUB-SECTION-B-05 CABLING, EARTHING &amp; LIGHTNING PROTECTION</b>	<b>PAGE 2 OF 23</b>



CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 		
	<p>Each cable vault should have at least two doors.</p> <p>Exit signs shall be provided near doors for personnel escape in case of emergency</p>		
2.01.06	<p><b>Boiler Area</b></p> <p>Two separate cable routes one on each side shall be provided for each boiler unit. Cables for on set of auxiliaries such as ID, FD, PA fan &amp; half of the coal mills shall be routed in one route &amp; for other set of auxiliaries through other route.</p> <p>Cable trays in boiler &amp; ESP area shall be supported from the boiler and ESP structures. The same shall be coordinated with SG/ESP contractor.</p> <p>Cable trays in these areas shall be in vertical formation to avoid dust accumulation. No cable trenches shall be provided in boiler/ESP area.</p>		
2.01.07	<p><b>Turbine Hall Area</b></p> <p>a) Two separate cable routes shall be provided for cable routing of working and standby drives or different set/group (say 50% capacity) of auxiliaries.</p>		
2.01.08	<p><b>OffSite Area</b></p> <p>In offsite pumphouses, overhead cable tray arrangement shall be followed. However cable trenches may be considered below switchgear/mcc.</p> <p>Trestle In fuel oil pump house, overhead cable tray arrangement shall be provided. RCC trenches provided in MCC room shall be separated from fuel oil area to avoid oil accumulation.</p>		
2.01.09	<p>The cable slits to be used for motor/equipment power/control supply shall be sand filled &amp; covered with PCC after cabling.</p>		
2.01.10	<p>Sizing criteria, derating factors for the cables shall be met as per respective chapters. However for the power cables, the minimum conductor size shall be 6 sq.mm. for aluminium conductor and 2.5 sq.mm. for copper conductor cable.</p>		
2.01.11	<p>Conscious exceptions to the above guidelines may be accepted under special conditions but suitable measures should be taken at such location to:</p> <ul style="list-style-type: none"> <li>• Meet all safety requirements</li> <li>• Safeguard against fire hazards, mechanical damage, flooding of water, oil accumulation, electrical faults/interferences, etc</li> </ul>		
3.00.00	<p><b>EQUIPMENT DESCRIPTION</b></p>		
3.01.00	<p><b>Cable trays, Fittings &amp; Accessories</b></p>		
3.01.01	<p>Cable trays shall be ladder/perforated type as specified complete with matching fittings (like brackets, elbows, bends, reducers, tees, crosses, etc.) accessories (like side coupler plates, etc. and hardware (like bolts, nuts, washers, G.I. strap, hook etc.) as required. Cable tray shall be ladder type for power &amp; control cables and perforated for instrumentation cables.</p>		
3.01.02	<p>Cable trays, fittings and accessories shall be fabricated out of rolled mild steel sheets free from flaws such as laminations, rolling marks, pitting etc. These (including hardware) shall be hot dip galvanized as per Clause No. 3.13.00 of this chapter.</p>		
<p><b>KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES</b></p>	<p><b>TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371</b></p>	<p><b>SUB-SECTION-B-05 CABLING, EARTHING &amp; LIGHTNING PROTECTION</b></p>	<p><b>PAGE 3 OF 23</b></p>



CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 		
3.01.03	Cable trays shall have standard width of 150 mm, 300 mm & 600 mm and standard lengths of 2.5 metre. Thickness of mild steel sheets used for fabrication of cable trays and fittings shall be 2 mm. The thickness of side coupler plates shall be 3 mm.		
3.01.04	Cable troughs shall be required for branching out few cables from main cable route. These shall be U-shaped, fabricated of mild steel sheets of thickness 2 mm and shall be hot dip galvanised as per Clause No. 3.13.00 of this chapter. Troughs shall be standard width of 50 mm & 75 mm with depth of 25 mm.		
3.01.05	The tolerance for cable tray and accessories shall be as per IS 2102 (Part-1). Tolerance Class: - Coarse		
3.02.00	<b>Support System for Cable Trays</b>		
3.02.01	Cable tray support system shall be pre-fabricated out of single sheet as per enclosed tender drawings.		
3.02.02	<p>Support system for cable trays shall essentially comprise of the two components i.e. main support channel and cantilever arms. The main support channel shall be of two types : (i) C1:- having provision of supporting cable trays on one side and (ii) C2:-having provision of supporting cable trays on both sides. The support system shall be the type described hereunder</p> <ol style="list-style-type: none"> <li>Cable supporting steel work for cable racks/cables shall comprise of various channel sections, cantilever arms, various brackets, clamps, floor plates, all hardwares such as lock washers, hexagon nuts, hexagon head bolt, support hooks, stud nuts, hexagon head screw, channel nut, channel nut with springs, fixing studs, etc.</li> <li>The system shall be designed such that it allows easy assembly at site by using bolting. All cable supporting steel work, hardwares fittings and accessories shall be prefabricated factory galvanised.</li> <li>The main support and cantilever arms shall be fixed at site using necessary brackets, clamps, fittings, bolts, nuts and other hardware etc. to form various arrangements required to support the cable trays. Welding of the components shall not be allowed. However, welding of the bracket (to which the main support channel is bolted) to the overhead beams, structural steel, insert plates or reinforcement bars will be permitted. Any cutting or welding of the galvanised surface shall be brushed and red lead primer, oil primer &amp; aluminium paint shall be applied</li> <li>All steel components, accessories, fittings and hardware shall be hot dip galvanised after completing welding, cutting, drilling and other machining operation.</li> <li>The typical arrangement of flexible support system is shown in the enclosed drawings and described briefly below:  The main support channel and cantilever arms shall be fabricated out of 2.5 thick rolled steel sheet conforming to IS 1079.</li> <li>Cantilever arms of 320 mm, 620mm and 750 mm in length are required, and shall be as shown in the enclosed drawing. The arm portion shall be suitable for assembling the complete arm assembly on to component constructed of standard channel section. The back plate shall allow sufficient clearance for fixing bolt to be tightened with tray in position.</li> <li>Support system shall be able to withstand</li> </ol>		
<b>KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES</b>	<b>TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371</b>	<b>SUB-SECTION-B-05 CABLING, EARTHING &amp; LIGHTNING PROTECTION</b>	<b>PAGE 4 OF 23</b>



CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 		
3.02.03	<ul style="list-style-type: none"> <li>• weight of the cable trays</li> <li>• weight of the cables (75 Kg/Metre run of each cable tray)</li> <li>• Concentrated load of 75 Kg between every support span.</li> <li>• Factor of safety of minimum 1.5 shall be considered.</li> </ul>		
3.02.04	<p>The size of structural steel members or thickness of sheet steel of main support channel and cantilever arms and other accessories as indicated above or in the enclosed drawings are indicative only. Nevertheless, the support system shall be designed by the bidder to fully meet the requirements of type tests as specified. In case the system fails in the tests, the components design modification shall be done by the Bidder without any additional cost to the Employer. The bidder shall submit the detailed drawings of the system offered by him alongwith the bid.</p>		
3.02.04	<p>Four legged structure shall be provided wherever there is change in elevation and change in direction</p>		
3.03.04	<p>FOR COAL, LIMESTONE AND GYPSUM HANDLING PLANT THE FOLLOWING SHALL ALSO BE APPLICABLE:</p> <p>a) All overhead cable routes shall be along the route of the conveyor gallery on separate supporting structures and cables shall be laid in vertical trays. The bottom of the steel shall be such that the existing facilities, movement of trucks/human beings etc. does not get affected. The cable trestle shall have a minimum 600mm clear walk way and shall have maintenance platforms as required. The bottom of the steel supporting structure shall be generally at 3.0M above the grade level except for rail/road crossings where it shall be at 8.0M above grade level. Tap offs from the overhead cable trestle can be through shallow trenches with prior approval of the Employer. Directly buried cable, if essential, shall not have concentration of more than 4 cables on one route.</p> <p>b) Cable trenches shall be provided only in Switchgear/MCC rooms.</p> <p>c) Cables shall not be routed through the conveyor galleries except for the equipment located in the conveyor galleries for a particular conveyor i.e. protection switches, receptacles etc.</p> <p>d) Cables for PCS and BSS shall be routed along the conveyors through GI conduits.</p>		
3.04.00	<p><b>Pipes, Fittings &amp; Accessories</b></p>		
3.03.01	<p>Pipes offered shall be complete with fittings and accessories (like tees, elbows, bends, check nuts, bushings, reducers, enlargers, coupling caps, nipples etc.) The size of the pipe shall be selected on the basis of maximum 40% fill criteria</p>		
3.03.02	<p>GI Pipes shall be of medium duty as per IS: 1239</p>		
3.03.03	<p>Duct banks shall be PVC conduits encased in PCC (10% spare of each size, subject to minimum one) with suitable water-proof manholes and with proper sealing arrangement consisting of fire retardant sealing compound.</p>		
3.03.04	<p>Hume pipes shall be NP3 type as per IS 458.</p>		
3.03.05	<p>TERNE Coated Flexible Steel Conduits shall be water proof and rust proof made of heat resistant lead coated steel. Conduit diameter shall be uniform throughout its length. Internal surface of the conduit shall be free from burrs and sharp edges. Conduits shall be complete</p>		
<p><b>KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES</b></p>	<p><b>TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371</b></p>	<p><b>SUB-SECTION-B-05 CABLING, EARTHING &amp; LIGHTNING PROTECTION</b></p>	<p><b>PAGE 5 OF 23</b></p>



CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 		
3.03.06	with necessary accessories for proper termination of the conduit with junction boxes and lighting fixtures.		
3.04.00	<b>Junction Boxes</b>		
3.04.01	<p>Junction box shall be made of Fire retardant material. Material of JB shall be Thermoplastic or thermosetting or FRP type. The box shall be provided with the terminal blocks, mounting bracket and screws etc. The cable entry shall be through galvanized steel conduits of suitable diameter. The JB shall have suitable for installing glands of suitable size on the bottom of the box. The JB shall be suitable for surface mounting on ceiling/structures. The JB shall be of grey color RAL 7035. All the metal parts shall be corrosion protected. Junction box surface should be such that it is free from crazings, blisterings, wrinkling, colour blots/striations. There should not be any mending or repair of surface. JB's will be provided with captive screws so that screws don't fall off when cover is opened. JB's mounting brackets should be of powder coated MS. Type test reports for the following tests shall be furnished:-</p> <p>(a) Impact resistance for impact energy of 2 Joules (IK07) as per BS EN50102</p> <p>(b) Thermal ageing at 70deg C for 96 hours as per IEC60068-2-2Bb.</p> <p>(c) Class of protection shall be IP 55.</p> <p>(d) HV test.</p>		
3.04.02	Terminal blocks shall be 1100V grade, of suitable current rating, made up of unbreakable polyamide 6.6 grade. The terminals shall be screw type or screw-less (spring loaded) / cage clamp type with lugs. Marking on terminal strips shall correspond to the terminal numbering in wiring diagrams. All metal parts shall be of non-ferrous material. In case of screw type terminals the screw shall be captive, preferably with screw locking design. All terminal blocks shall be suitable for terminating on each side the required cables/wire size. All internal wiring shall be of cu. Conductor PVC wire.		
3.05.00	<b>Terminations &amp; Straight Through Joints</b>		
3.05.01	<p>Termination and jointing kits for 33kV, 11 kV, 6.6 KV and 3.3 kV grade XLPE insulated cables shall be of proven design and make which have already been extensively used and type tested. Termination kits and jointing kits shall be Pre-moulded type or heat shrinkable type. Further Cold shrinkable type termination and jointing kits are also acceptable. The Cold shrinkable type kits shall be type tested as per relevant standards. Calculation to withstand the required fault level shall also be furnished in case of cold shrinkable type kits. 33 kV, 11 kV, 6.6 KV and 3.3kV grade joints and terminations shall be type tested and Type test reports as per IS:13573 Part-II and IEC60502 shall be furnished. Also, heat shrink material shall comply with requirements of ESI 09-13 (external tests). Critical components used in cable accessories shall be of tested and proven quality as per relevant product specification/ESI specification. Cable joints and terminations should be with FRLS properties as per IEC 60754-1&amp;2. Kit contents shall be supplied from the same source as were used for type testing. The kit shall be complete with the tinned copper solderless crimping type cable lugs &amp; ferrule or mechanical connectors (wherein bolts are tightened that shear off at an appropriate torque) as per DIN standard suitable for aluminium compacted conductor cables. (Tender drg. no 0000-211-POE –A-51-RA of cable lug attached at the end of this chapter)..</p>		
3.05.02	Straight through joint and termination shall be capable of withstanding the fault level of 21 KA for 0.12 Sec. with dynamic peak of 52 KA for 33 KV system & of 40 kA for 0.12 sec with a dynamic peak of 100 kA for 11 kV, 6.6 KV & 3.3 KV system. Straight through joints shall		
<b>KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES</b>	<b>TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371</b>	<b>SUB-SECTION-B-05 CABLING, EARTHING &amp; LIGHTNING PROTECTION</b>	<b>PAGE 6 OF 23</b>



CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 		
	<p>have provisions for shield connection and earthing wherever required and complete with all accessories and consumables suitable for storage without deterioration at a temperature of 50 deg. C with shelf life of more than five years. 1.1 kV grade straight through joints shall also be of proven design</p>		
3.05.03	1.1 KV grade Straight Through Joint shall be of proven design.		
3.06.00	<b>Cable glands</b>		
3.06.01	<p>Cable shall be terminated using double compression type cable glands. Testing requirements of Cable glands shall conform to BS:6121 and gland shall be of robust construction capable of clamping cable and cable armour (for armoured cables) firmly without injury to insulation. Cable glands shall be made of heavy duty brass machine finished and nickel chrome plated. Thickness of plating shall not be less than 10 micron. All washers and hardware shall also be made of brass with nickel chrome plating Rubber components shall be of neoprene or better synthetic material and of tested quality. Cable glands shall be suitable for the sizes of cable supplied/erected.</p>		
3.07.00	<b>Cable lugs/ferrules</b>		
3.07.01	<p>Cable lugs/ferrules for power cables shall be tinned copper solderless crimping type suitable for aluminium compacted conductor cables. Cable lugs and ferrules for control cables shall be tinned copper type. The cable lugs for control cables shall be provided with insulating sleeve and shall suit the type of terminals provided on the equipments. Cable lugs and ferrule shall conform to DIN standards.</p>		
3.08.00	<b>Trefoil clamps</b>		
3.08.01	<p>Trefoil clamps for single core cables shall be pressure die cast aluminum or fibre glass or nylon and shall include necessary fixing accessories like G.I. nuts, bolts, washers, etc. Trefoil clamps shall have adequate mechanical strength, when installed at 1 mtr intervals, to withstand the forces generated by the peak value of maximum system short circuit current.</p>		
3.09.00	<b>Cable Clamps &amp; Ties</b>		
3.09.01	<p>The cable clamps/ties required to clamp multicore cables shall be of SS-316 material, 12mm wide, polyester coated ladder lock type. The clamps/ties shall have self locking arrangement &amp; shall have sufficient strength. The cable clamps/ties shall be supplied in finished individual pieces of suitable length to meet the site requirements.</p>		
3.10.00	<b>Receptacles</b>		
3.10.01	<p>Receptacles boxes shall be fabricated out of MS sheet of 2mm thickness and hot dipped gavanised or of die-cast aluminium alloy of thickness not less than 2.5 mm. The boxes shall be provided with two nos. earthing terminals, gasket to achieve IP55 degree of protection, terminal blocks for loop-in loop-out for cable of specified sizes, mounting brackets suitable for surface mounting on wall/column/structure, gland plate etc. The ON-OFF switch shall be rotary type heavy duty, double break, AC23 category, suitable for AC supply. Plug and Socket shall be shrouded Die-cast aluminium. Socket shall be provided with lid safety cover. Robust mechanical interlock shall be provided such that the switch can be put ON only when the plug is fully engaged and plug can be withdrawn only when the switch is in OFF position. Also cover can be opened only when the switch is in OFF position. Wiring shall be carried out with 1100 V grade PVC insulated stranded aluminium/copper wire of adequate size. The Terminal blocks shall be of 1100 V grade. The Terminal blocks shall be of 1100 V grade made up of unbreakable polyimide 6.6 grade with adequate current rating and size. The welding receptacles shall be provided with RCCB/RCD of 30mA sensitivity having facility for manual testing/checking of operation of RCCB/RCD</p>		
<b>KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES</b>	<b>TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371</b>	<b>SUB-SECTION-B-05 CABLING, EARTHING &amp; LIGHTNING PROTECTION</b>	<b>PAGE 7 OF 23</b>



CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 		
3.12.00	<b>Cable Drum Lifting Jack</b> The jack for cable drum lifting shall be of screw type with 10 ton capacity. The cable drum jacks shall be manufactured from fabricated steel. The spindles supplied with the cable drum jack shall be manufactured using BSEN-24 grade steel bar with locking collars. Jack nests shall be of SG cast steel. Cable drum jack supplied shall have undergone load testing and reports for the same shall be submitted. At least Two Nos. of jacks shall be supplied for NTPC use. Contractor has to make arrangements for his own jacks for cable reeling/unreeling under his scope of installation.		
3.13.00	<b>Galvanising</b>		
3.13.01	Galvanising of steel components and accessories shall conform to IS:2629 , IS4759 & IS:2633. Additionally galvanising shall be uniform, clean smooth, continuous and free from acid spots.		
3.13.02	The amount of zinc deposit over threaded portion of bolts, nuts, screws and washers shall be as per IS:1367 . The removal of extra zinc on threaded portion of components shall be carefully done to ensure that the threads shall have the required zinc coating on them as specified		
3.14.00	<b>Welding</b>		
3.14.01	The welding shall be carried out in accordance with IS:9595. All welding procedures and welders qualification shall also be followed strictly in line with IS:9595		
4.00.00	<b>INSTALLATION</b>		
4.01.00	<b>Cable tray and Support System Installation</b>		
4.01.01	Cables shall run in cable trays mounted horizontally or vertically on cable tray support system which in turn shall be supported from floor, ceiling, overhead structures, trestles, pipe racks, trenches or other building structures.		
4.01.02	Horizontally running cable trays shall be clamped by bolting to cantilever arms and vertically running cable trays shall be bolted to main support channel by suitable bracket/clamps on both top and bottom side rails at an interval of 2000 mm in general. For vertical cable risers/shafts cable trays shall be supported at an interval of 1000mm in general. Fixing of cable trays to cantilever arms or main support channel by welding shall not be accepted. Cable tray installation shall generally be carried out as per the approved guidelines/ drawings. Vendor shall design the support system along with tray, spacing etc in line with tray loadings/drawings.		
4.01.03	The cantilever arms shall be positioned on the main support channel with a minimum vertical spacing of 300 mm unless otherwise indicated.		
4.01.04	The contractor shall fix the brackets/ clamps/ insert plates using anchor fasteners. Minimum size of anchor fasteners shall be M 8 X 50 and material shall be stainless steel grade 316 or better. Anchor fastener shall be fixed as recommended by manufacturer and as approved by site engineer. For brick wall suitable anchor fasteners shall be used as per the recommendations of manufacturer. Make of anchor fasteners subject to QA approval and the same shall be finalized at pre-award stage.		
4.01.05	All cable way sections shall have identification, designations as per cable way layout drawings and painted/stenciled at each end of cable way and where there is a branch connection to another cable way. Minimum height of letter shall be not less than 75 mm. For long lengths of trays, the identification shall be painted at every 10 meter. Risers shall additionally be painted/stenciled with identification numbers at every floor.		
<b>KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES</b>	<b>TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371</b>	<b>SUB-SECTION-B-05 CABLING, EARTHING &amp; LIGHTNING PROTECTION</b>	<b>PAGE 8 OF 23</b>



CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 											
4.01.06	<p>In certain cases it may be necessary to site fabricate portions of trays, supports and other non standard bends where the normal prefabricated trays, supports and accessories may not be suitable. Fabricated sections of trays, supports and accessories to make the installation complete at site shall be neat in appearance and shall match with the prefabricated sections in the dimensions. They shall be applied with one coat of red lead primer, one coat of oil primer followed by two finishing coats of aluminium paint.</p>											
4.02.00	<p><b>Conduits/Pipes/Ducts Installation</b></p>											
4.02.01	<p>The Contractor shall ensure for properly embedding conduit pipe sleeves wherever necessary for cabling work. All openings in the floor/roof/wall / cable tunnel/cable trenches made for conduit installation shall be sealed and made water proof by the Contractor.</p>											
4.02.02	<p>GI pull wire of adequate size shall be laid in all conduits before installation. Metallic conduit runs at termination shall have two lock nuts wherever required for junction boxes etc.</p>											
4.02.03	<p>Conduit runs/sleeves shall be provided with PVC bushings having round edge at each end. All conduits/pipes shall have their ends closed by caps until cables are pulled. After cables are pulled, the ends of conduits/pipes shall be sealed with Glass wool/Cement Mortar/Putty to prevent entrance of moisture and foreign material</p>											
4.02.04	<p>Exposed conduit/pipe shall be adequately supported by racks, clamps, straps or by other approved means. Conduits /pipe support shall be installed square and true to line and grade with an average spacing between the supports as given below, unless specified otherwise</p> <table border="1" data-bbox="391 905 1437 1192"> <thead> <tr> <th data-bbox="391 905 841 936"><b>Conduit /pipe size (dia).</b></th> <th data-bbox="841 905 1437 936"><b>Spacing</b></th> </tr> </thead> <tbody> <tr> <td data-bbox="391 961 841 993">Upto 40 mm</td> <td data-bbox="841 961 1437 993">1 M</td> </tr> <tr> <td data-bbox="391 1018 841 1050">50 mm</td> <td data-bbox="841 1018 1437 1050">2.0 M</td> </tr> <tr> <td data-bbox="391 1075 841 1106">65-85 mm</td> <td data-bbox="841 1075 1437 1106">2.5 M</td> </tr> <tr> <td data-bbox="391 1131 841 1163">100 mm and above</td> <td data-bbox="841 1131 1437 1163">3.0 M</td> </tr> </tbody> </table>		<b>Conduit /pipe size (dia).</b>	<b>Spacing</b>	Upto 40 mm	1 M	50 mm	2.0 M	65-85 mm	2.5 M	100 mm and above	3.0 M
<b>Conduit /pipe size (dia).</b>	<b>Spacing</b>											
Upto 40 mm	1 M											
50 mm	2.0 M											
65-85 mm	2.5 M											
100 mm and above	3.0 M											
4.02.05	<p>For bending of conduits, bending machine shall be arranged at site by the contractor to facilitate cold bending. The bends formed shall be smooth.</p>											
4.03.00	<p><b>Junction Boxes Installation</b></p>											
4.03.01	<p>Junction boxes shall be mounted at a height of 1200mm above floor level or as specified in the drawings and shall be adequately supported/mounted on masonry wall by means of anchor fasteners/ expandable bolts or shall be mounted on an angle, plate or other structural supports fixed to floor, wall, ceiling or equipment foundations.</p>											
4.04.00	<p><b>Cable Installation</b></p>											
4.04.01	<p>Cable installation shall be carried out as per IS:1255 and other applicable standards.</p>											
4.04.02	<p>For Cable unloading, pulling etc following guidelines shall be followed in general:</p> <p>a) Cable drums shall be unloaded, handled and stored in an approved manner on hard and well drained surface so that they may not sink. In no case shall be drum be stored flat i.e. with flange horizontal. Rolling of drums shall be avoided as far as possible. For short distances, the drums may be rolled provided they are rolled slowly and in proper direction as marked on the drum. In absence of any indication, the drums may be rolled in the same direction as it was rolled during taking up the cables. For unreeling the cable, the drum shall be mounted on suitable jacks or on</p>											
<p><b>KHURJA SUPER THERMAL POWER PROJECT</b> (2X660 MW) <b>TURBINE GENERATOR AND ASSOCIATED PACKAGES</b></p>	<p><b>TECHNICAL SPECIFICATION</b> SECTION – VI, PART-B <b>BID DOC. NO.:</b> THDC/RKSH/CC-9915-371</p>	<p><b>SUB-SECTION-B-05</b> <b>CABLING, EARTHING &amp;</b> <b>LIGHTNING PROTECTION</b></p>	<p><b>PAGE</b> <b>9 OF 23</b></p>									



CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 		
	<p>cable wheels and shall be rolled slowly so that cable comes out over the drum and not from below. All possible care shall be taken during unreeling and laying to avoid damage due to twist, kink or sharp bends. Cable ends shall be provided with sealed plastic caps to prevent damage and ingress of moisture.</p> <p>b) While laying cable, ground rollers shall be used at every 2 meter interval to avoid cable touching ground. The cables shall be pushed over the rollers by a gang of people positioned in between the rollers. Cables shall not be pulled from the end without having intermediate pushing arrangements. Pulling tension shall not exceed the values recommended by cable manufacturer. Selection of cable drums for each run shall be so planned so as to avoid using straight through joints. Care should be taken while laying the cables so as to avoid damage to cables. If any particular cable is damaged, the same shall be repaired or changed to the satisfaction of Project Manager.</p> <p>4.04.03 Cables shall be laid on cable trays strictly in line with cable schedule . Where specific cable layouts are not shown on drawings, Contractor shall route these as directed by the Project Manager</p> <p>4.04.04 Power and control cables shall be laid on separate tiers inline with the approved guidelines/drawings. The laying of different voltage grade cables shall be on different tiers according to the voltage grade of the cables. In horizontal tray stacks, H.T. cables shall be laid on top most tier and cables of subsequent lower voltage grades on lower tiers of trays. Single core cable in trefoil formation shall be laid with a distance of four times the diameter of cable between trefoil center lines and clamped at every-one metre. All multicore cables shall be laid in touching formation. Power and control cables shall be secured fixed to trays/support with cable clamps/ties with self locking arrangement. For horizontal trays arrangements, multicore power cables and control cables shall be secured at every five meter interval. For vertical tray arrangement, individual multicore power cables and control cables shall be secured at every one meter. After completion of cable laying work in the particular vertical tray, all the control cables shall be binded to trays/supports by cable clamps/ties with self locking arrangement at every five meter interval and at every bend. Fibre Optical cable shall be laid in trenches/trays or as decided by Employer.</p> <p>4.04.05 Bending radii for cables shall be as per manufacturer's recommendations and IS:1255.</p> <p>4.04.06 Where cables cross roads/rail tracks, the cables shall be laid in hume pipe/ HDPE pipe.</p> <p>4.04.07 No joints shall be allowed in trip circuits, protection circuits and CT/PT circuits. Also joints in critical equipment in main plant area shall not be permitted. Vendor shall identify and accordingly procure the cable drum length.</p> <p>4.04.08 In each cable run some extra length shall be kept at suitable point to enable one LT/two HT straight through joints to made, should the cable develop fault at a later stage. Control cable termination inside equipment enclosure shall have sufficient lengths so that shifting of termination in terminal blocks can be done without requiring any splicing.</p> <p>4.04.09 Wherever few cables are branching out from main trunk route troughs shall be used.</p> <p>4.04.10 Wind loading shall be considered for designing support as well Cable trays wherever required.</p> <p>4.04.11 Where there is a considerable risk of steam, hot oil or mechanical damage cable routes shall be protected by barriers or enclosures.</p> <p>4.04.12 The installation work shall be carried out in a neat workman like manner &amp; areas of work shall be cleaned of all scraps, water, etc. after the completion of work in each area every</p>		
<b>KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES</b>	<b>TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371</b>	<b>SUB-SECTION-B-05 CABLING, EARTHING &amp; LIGHTNING PROTECTION</b>	<b>PAGE 10 OF 23</b>



CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 											
4.04.13	<p>day. Contractor shall replace RCC/Steel trench covers after the Installation work in that particular area is completed or when further work is not likely to be taken up for some time.</p> <p><b>Separation</b></p> <p>At least 300mm clearance shall be provided between:</p> <ul style="list-style-type: none"> <li>- HT power &amp; LT power cables,</li> <li>- LT power &amp; LT control/instrumentation cables,</li> </ul>											
4.04.14	<p><b>Segregation</b></p> <ol style="list-style-type: none"> <li>1) Segregation means physical isolation to prevent fire jumping.</li> <li>2) All cables associated with the unit shall be segregated from cables of other units.</li> <li>3) Interplant cables of station auxiliaries and unit critical drives shall be segregated in such a way that not more than half of the drives are lost in case of single incident of fire. Power and control cables for AC drives and corresponding emergency AC or DC drives shall be laid in segregated routes. Cable routes for one set of auxiliaries of same unit shall be segregated from the other set.</li> <li>4) In switchyard, control cables of each bay shall be laid on separate racks/trays.</li> </ol>											
4.04.15	<p>Minimum number of spare cores required to be left for interconnection in control cables shall be as follows:</p> <p>Minimum number of spare cores required to be left for interconnection in control cables shall be as follows:</p> <table border="1" data-bbox="391 1045 1437 1276"> <thead> <tr> <th>No. of cores in cable</th> <th>No. of spare cores</th> </tr> </thead> <tbody> <tr> <td>2C,3C</td> <td>NIL</td> </tr> <tr> <td>5C</td> <td>1</td> </tr> <tr> <td>7C-10C</td> <td>2</td> </tr> <tr> <td>14C and above</td> <td>3</td> </tr> </tbody> </table>		No. of cores in cable	No. of spare cores	2C,3C	NIL	5C	1	7C-10C	2	14C and above	3
No. of cores in cable	No. of spare cores											
2C,3C	NIL											
5C	1											
7C-10C	2											
14C and above	3											
4.04.16	<p><b>Directly Buried Cables</b></p> <ol style="list-style-type: none"> <li>a) Cable trenches shall be constructed for directly buried cables. Construction of cable trench for cables shall include excavation, preparation of sieved sand bedding, riddled soil cover, supply and installation of brick or concrete protective covers, back filling and compacting, supply and installation of route markers and joint markers. Laying of cables and providing protective covering shall be as per IS:1255 and the enclosed drawings showing cabling details.</li> <li>b) RCC cable route and RCC joint markers shall be provided wherever required. The voltage grade of the higher voltage cables in route shall be engraved on the marker. Location of underground cable joints shall be indicated with cable marker with an additional inscription "Cable Joint". The marker shall project 150 mm above ground and shall be spaced at an interval of 30 meters and at every change in direction. They shall be located on both sides of road crossings and drain crossings. Top of cable marker/joint marker shall be sloped to avoid accumulation of water/dust on marker.</li> </ol>											
<b>KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES</b>	<b>TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371</b>	<b>SUB-SECTION-B-05 CABLING, EARTHING &amp; LIGHTNING PROTECTION</b>	<b>PAGE 11 OF 23</b>									



CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 		
4.04.17	<p>Cable tags shall be provided on all cables at each end (just before entering the equipment enclosure), on both sides of a wall or floor crossing, on each duct/conduit entry, and at every 20 meters in cable tray/trench runs. Cable tags shall also be provided inside the switchgear, motor control centers, control and relay panels etc. where a number of cables enter together through a gland plate. Cable tag shall be of rectangular shape for power cables and control cables. Cable tag shall be of 2 mm thick aluminum with number punched on it and securely attached to the cable by not less than two turns of 20 SWG GI wire conforming to IS:280. Alternatively, the Contractor may also provide cable tags made of nylon, cable marking ties with cable number heat stamped on the cable tags. The cable tag requirements mentioned above shall prevail over Tag requirements mentioned elsewhere in this document for HT power, LT power &amp; control cables.</p>		
4.04.18	<p>While crossing the floors, unarmoured cables shall be protected in conduits upto a height of 500 mm from floor level if not laid in tray.</p>		
4.05.00	<p><b>Cable Terminations &amp; Connections</b></p>		
4.05.01	<p>The termination and connection of cables shall be done strictly in accordance with cable termination kit manufacturer" instructions, drawings and/or as directed by Project Manager. Cable jointer shall be qualified to carryout satisfactory cable jointing/termination. Contractor shall furnish for review documentary evidence/experience reports of the jointers to be deployed at site.</p>		
4.05.02	<p>Work shall include all clamps, fittings etc. and clamping, fitting, fixing, plumbing, soldering, drilling, cutting, taping, preparation of cable end, crimping of lug, insulated sleeving over control cable lugs, heat shrinking (where applicable), connecting to cable terminal, shorting and grounding as required to complete the job to the satisfaction of the Project Manager.</p>		
4.05.03	<p>The equipment will be generally provided with undrilled gland plates for cables/conduit entry. The Contractor shall be responsible for punching of gland plates, painting and touching up. Holes shall not be made by gas cutting. The holes shall be true in shape. All cable entry points shall be sealed and made vermin and dust proof. Unused openings shall be effectively sealed by 2mm thick aluminium sheets.</p>		
4.05.04	<p>Control cable cores entering control panel/switchgear/MCC/miscellaneous panels shall be neatly bunched, clamped and tied with self locking type nylon cable ties with de interlocking facility to keep them in position.</p>		
4.05.05	<p>All the cores of the control cable to be terminated shall have identification by providing ferrules at either end of the core, each ferrule shall be indelible, printed single tube ferrule and shall include the complete wire number and TB number as per the drawings. The ferrule shall fit tightly on the core. Spare cores shall have similar ferrules with suffix sp1, sp2, ---etc along with cable numbers and coiled up after end sealing.</p>		
4.05.06	<p>All cable terminations shall be appropriately tightened to ensure secure and reliable connections.</p>		
5.00.00	<p><b>EARTHING SYSTEM</b></p>		
5.01.00	<p>Earthing system shall be in strict accordance with IS:3043 and Indian Electricity Rules/Acts.</p> <p>Earthing system network/earthmat shall be interconnected mesh of mild steel rods buried in ground in the plant. All off-site areas shall be interconnected together by minimum two parallel conductors. The Contractor shall furnish the detailed design and calculations for</p>		
<p><b>KHURJA SUPER THERMAL POWER PROJECT</b> (2X660 MW) <b>TURBINE GENERATOR AND ASSOCIATED PACKAGES</b></p>	<p><b>TECHNICAL SPECIFICATION</b> SECTION – VI, PART-B <b>BID DOC. NO.:</b> THDC/RKSH/CC-9915-371</p>	<p><b>SUB-SECTION-B-05</b> <b>CABLING, EARTHING &amp;</b> <b>LIGHTNING PROTECTION</b></p>	<p><b>PAGE</b> 12 OF 23</p>



CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 																																																	
5.02.00	Employer's approval. Contractor shall obtain all necessary statutory approvals for the system.																																																	
5.03.00	The earth conductors shall be free from pitting, laminations, rust, scale and other electrical, mechanical defects																																																	
5.04.00	<p>The material of the earthing conductors shall be as follows :</p> <table border="0"> <tr> <td style="width: 10%;">1)</td> <td style="width: 40%;">Conductors above ground level and in built up trenches.</td> <td style="width: 10%;">-</td> <td style="width: 30%;">Galvanized steel</td> </tr> <tr> <td>2)</td> <td>Conductors buried in earth</td> <td>-</td> <td>Mild steel</td> </tr> <tr> <td>3)</td> <td>Earth electrodes</td> <td>-</td> <td>Mild steel rod</td> </tr> </table>		1)	Conductors above ground level and in built up trenches.	-	Galvanized steel	2)	Conductors buried in earth	-	Mild steel	3)	Earth electrodes	-	Mild steel rod																																				
1)	Conductors above ground level and in built up trenches.	-	Galvanized steel																																															
2)	Conductors buried in earth	-	Mild steel																																															
3)	Earth electrodes	-	Mild steel rod																																															
5.05.00	<p>The sizes of earthing conductors for various electrical equipments shall be as below:</p> <table border="0"> <thead> <tr> <th style="width: 10%;">Equipment</th> <th style="width: 40%;">Earth conductor buried in earth</th> <th style="width: 10%;"></th> <th style="width: 30%;">Earth conductor above ground level &amp; in built-up trenches</th> </tr> </thead> <tbody> <tr> <td>a) Main earth grid</td> <td>MS rod -Min 40 mm dia. or as per actual calculation whichever is more</td> <td></td> <td>65 x 8mm GS flat</td> </tr> <tr> <td>b) 33kV/11kV/6.6kV/3.3 kV/ switchgear equipment and 415V switchgear</td> <td>---</td> <td></td> <td>65 x 8mm GS flat</td> </tr> <tr> <td>c) 415 V MCC/ Distribution boards / Transformers</td> <td>---</td> <td></td> <td>50 x 6mm GS flat</td> </tr> <tr> <td>d) LT Motors above 125 KW</td> <td>---</td> <td></td> <td>50 x 6mm GS flat</td> </tr> <tr> <td>25 KW to 125 KW</td> <td>---</td> <td></td> <td>25 x 6mm GS flat</td> </tr> <tr> <td>1KW to 25 KW</td> <td>---</td> <td></td> <td>25 x 3mm GS flat</td> </tr> <tr> <td>Fractional House power motor</td> <td>---</td> <td></td> <td>8 SWG GS wire</td> </tr> <tr> <td>e) Control panel &amp; control desk</td> <td>---</td> <td></td> <td>25 x 3 mm GS flat</td> </tr> <tr> <td>f) Push button station / Junction Box</td> <td>---</td> <td></td> <td>8 SWG GI wire</td> </tr> <tr> <td>g) Columns, structures, cable trays and bus ducts enclosures</td> <td>---</td> <td></td> <td>50 x 6mm GS flat</td> </tr> <tr> <td>h) Crane, rails, rail tracks &amp; other non-current carrying metal parts</td> <td></td> <td></td> <td>25 x 6mm GS flat</td> </tr> </tbody> </table> <p>Metallic frame of all electrical equipment shall be earthed by two separate and distinct connections to earthing system, each of 100% capacity, Crane rails, tracks, metal pipes and conduits shall also be effectively earthed at two points. Steel RCC columns, metallic stairs, and rails etc. of the building housing electrical equipment shall be connected to the nearby</p>		Equipment	Earth conductor buried in earth		Earth conductor above ground level & in built-up trenches	a) Main earth grid	MS rod -Min 40 mm dia. or as per actual calculation whichever is more		65 x 8mm GS flat	b) 33kV/11kV/6.6kV/3.3 kV/ switchgear equipment and 415V switchgear	---		65 x 8mm GS flat	c) 415 V MCC/ Distribution boards / Transformers	---		50 x 6mm GS flat	d) LT Motors above 125 KW	---		50 x 6mm GS flat	25 KW to 125 KW	---		25 x 6mm GS flat	1KW to 25 KW	---		25 x 3mm GS flat	Fractional House power motor	---		8 SWG GS wire	e) Control panel & control desk	---		25 x 3 mm GS flat	f) Push button station / Junction Box	---		8 SWG GI wire	g) Columns, structures, cable trays and bus ducts enclosures	---		50 x 6mm GS flat	h) Crane, rails, rail tracks & other non-current carrying metal parts			25 x 6mm GS flat
Equipment	Earth conductor buried in earth		Earth conductor above ground level & in built-up trenches																																															
a) Main earth grid	MS rod -Min 40 mm dia. or as per actual calculation whichever is more		65 x 8mm GS flat																																															
b) 33kV/11kV/6.6kV/3.3 kV/ switchgear equipment and 415V switchgear	---		65 x 8mm GS flat																																															
c) 415 V MCC/ Distribution boards / Transformers	---		50 x 6mm GS flat																																															
d) LT Motors above 125 KW	---		50 x 6mm GS flat																																															
25 KW to 125 KW	---		25 x 6mm GS flat																																															
1KW to 25 KW	---		25 x 3mm GS flat																																															
Fractional House power motor	---		8 SWG GS wire																																															
e) Control panel & control desk	---		25 x 3 mm GS flat																																															
f) Push button station / Junction Box	---		8 SWG GI wire																																															
g) Columns, structures, cable trays and bus ducts enclosures	---		50 x 6mm GS flat																																															
h) Crane, rails, rail tracks & other non-current carrying metal parts			25 x 6mm GS flat																																															
<b>KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES</b>	<b>TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371</b>	<b>SUB-SECTION-B-05 CABLING, EARTHING &amp; LIGHTNING PROTECTION</b>	<b>PAGE 13 OF 23</b>																																															



CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 		
5.06.00	<p>earthing grid conductor by one earthing ensured by bonding the different sections of hand rails and metallic stairs. Metallic sheaths/screens, and armour of multi-core cables shall be earthed at both ends. Metallic Sheaths and armour of single core cables shall be earthed at switchgear end only unless otherwise approved. Every alternate post of the switchyard fence shall be connected to earthing grid by one GS flat and gates by flexible lead to the earthed post. Railway tracks within the plant area shall be bonded across fish plates and connected to earthing grid at several locations. Portable tools, appliances and welding equipment shall be earthed by flexible insulated cable.</p>		
5.06.00	<p>Each continuous laid lengths of cable tray shall be earthed at minimum two places by G.S. flats to earthing system, the distance between earthing points shall not exceed 30 meter. Wherever earth mat is not available, necessary connections shall be done by driving an earth electrode in the ground</p>		
5.07.00	<p>Neutral points of HT transformer shall be earthed through NG resistors. The Contractor shall connect the NGR earthing point to earth electrodes by suitable earth conductors.</p>		
5.08.00	<p>Neutral connections and metallic conduits/pipes shall not be used for the equipment earthing. Lightning protection system down conductors shall not be connected to other earthing conductors above the ground level.</p>		
5.09.00	<p>Connections between earth leads and equipment shall normally be of bolted type. Contact surfaces shall be thoroughly cleaned before connections. Equipment bolted connections after being tested and checked shall be painted with anti corrosive paint/compound.</p>		
5.10.00	<p>Suitable earth risers as approved shall be provided above finished floor/ground level, if the equipment is not available at the time of laying of main earth conductor.</p>		
5.11.00	<p>Connections between equipment earthing leads and between main earthing conductors shall be of welded type. For rust protection the welds should be treated with red lead compound and afterwards thickly coated with bitumen compound. All welded connections shall be made by electric arc welding.</p>		
5.12.00	<p>Resistance of the joint shall not be more than the resistance of the equivalent length of conductors.</p>		
5.13.00	<p>Earthing conductors buried in ground shall be laid minimum 600 mm below grade level unless otherwise indicated in the drawing. Back filling material to be placed over buried conductors shall be free from stones and harmful mixtures. Back filling shall be placed in layers of 150 mm.</p>		
5.14.00	<p>Earthing conductors embedded in the concrete floor of the building shall have approximately 50 mm concrete cover.</p>		
5.15.00	<p>A minimum earth coverage of 300 mm shall be provided between earth conductor and the bottom of trench/foundation/underground pipes at crossings. Earthing conductors crossings the road can be installed in pipes. Wherever earthing conductor crosses or runs at less than 300 mm distance along metallic structures such as gas, water, steam pipe lines, steel reinforcement in concrete, it shall be bonded to the same.</p>		
5.16.00	<p>Earthing conductors along their run on columns, walls, etc. shall be supported by suitable welding / cleating at interval of 1000mm and 750mm respectively.</p>		
5.17.00	<p>Earth pit shall be of treated type &amp; shall be constructed as per IS:3043. Electrodes shall be embedded below permanent moisture level. Minimum spacing between electrodes shall be 600mm. Earth pits shall be treated with salt and charcoal as per IS:3043. Test links shall be</p>		
<b>KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES</b>	<b>TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371</b>	<b>SUB-SECTION-B-05 CABLING, EARTHING &amp; LIGHTNING PROTECTION</b>	<b>PAGE 14 OF 23</b>



CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 																							
5.18.00	<p>provided with bolted arrangement alongwith each earth pit, in order to facilitate measurement of earth resistance as &amp; when required.</p>																							
5.19.00	<p>On completion of installation continuity of earth conductors and efficiency of all bonds and joints shall be checked. Earth resistance at earth terminations shall be measured and recorded. All equipment required for testing shall be furnished by contractor.</p>																							
5.20.00	<p>Earthing conductor shall be buried at least 2000mm outside the fence of electrical installations. Every alternate post of the fences and all gates shall be connected to earthing grid by one lead.</p> <p>Other Requirements of Earthing System:</p> <table border="0" data-bbox="391 548 1437 1318"> <tr> <td>Standard/Code</td> <td>IEEE 80, IS 3043</td> </tr> <tr> <td>Earthing System</td> <td></td> </tr> <tr> <td>Life expectancy</td> <td>40 Years</td> </tr> <tr> <td>System Fault Level</td> <td>As per system requirement (B0)</td> </tr> <tr> <td>Soil resistivity</td> <td>Actual as per site conditions.</td> </tr> <tr> <td>Min. Steel corrosion</td> <td>0.12mm/year</td> </tr> <tr> <td>Depth of burial of main earth conductor</td> <td>600mm below grade level; where it crosses trenches, pipes, ducts, tunnels, rail tracks, etc., it shall be at least 300mm below them.</td> </tr> <tr> <td>Conductor joints</td> <td>By electric arc welding, with resistance of joint not more than that of the conductor.</td> </tr> <tr> <td colspan="2">Welds to be treated with red lead for rust protection and then coated with bitumen compound for corrosion protection.</td> </tr> <tr> <td>Surface resistivity - Gravel</td> <td>3000 ohm-meter</td> </tr> <tr> <td>- Concrete</td> <td>500 ohm-meter</td> </tr> </table>		Standard/Code	IEEE 80, IS 3043	Earthing System		Life expectancy	40 Years	System Fault Level	As per system requirement (B0)	Soil resistivity	Actual as per site conditions.	Min. Steel corrosion	0.12mm/year	Depth of burial of main earth conductor	600mm below grade level; where it crosses trenches, pipes, ducts, tunnels, rail tracks, etc., it shall be at least 300mm below them.	Conductor joints	By electric arc welding, with resistance of joint not more than that of the conductor.	Welds to be treated with red lead for rust protection and then coated with bitumen compound for corrosion protection.		Surface resistivity - Gravel	3000 ohm-meter	- Concrete	500 ohm-meter
Standard/Code	IEEE 80, IS 3043																							
Earthing System																								
Life expectancy	40 Years																							
System Fault Level	As per system requirement (B0)																							
Soil resistivity	Actual as per site conditions.																							
Min. Steel corrosion	0.12mm/year																							
Depth of burial of main earth conductor	600mm below grade level; where it crosses trenches, pipes, ducts, tunnels, rail tracks, etc., it shall be at least 300mm below them.																							
Conductor joints	By electric arc welding, with resistance of joint not more than that of the conductor.																							
Welds to be treated with red lead for rust protection and then coated with bitumen compound for corrosion protection.																								
Surface resistivity - Gravel	3000 ohm-meter																							
- Concrete	500 ohm-meter																							
<b>6.00.00</b>	<b>LIGHTNING PROTECTION SYSTEM</b>																							
6.01.01	Lightning protection system shall be in strict accordance with IEC:62305 .																							
6.01.02	Lightning conductor shall be of 25x6mm GS strip when used above ground level and shall be connected through test link with earth electrode/earthing system																							
6.01.03	Lightning system shall comprise of air terminations, down conductors, test links, earth electrode etc. as per approved drawings.																							
6.02.00	<p><b>Down Conductors</b></p> <ol style="list-style-type: none"> <li>1. Down conductors shall be as short and straight as practicable and shall follow a direct path to earth electrode.</li> <li>2. Each down conductor shall be provided with a test link at 1000 mm above ground level for testing but it shall be in accessible to interference. No connections other than the one direct to an earth electrode shall be made below a test point.</li> </ol>																							
<b>KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES</b>	<b>TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371</b>	<b>SUB-SECTION-B-05 CABLING, EARTHING &amp; LIGHTNING PROTECTION</b>	<b>PAGE 15 OF 23</b>																					



CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 		
	<p>3. All joints in the down conductors shall be welded type.</p> <p>4. Down conductors shall be cleated on outer side of building wall, at 750 mm interval or welded to outside building columns at 1000 mm interval.</p> <p>5. Lightning conductor on roof shall not be directly cleated on surface of roof. Supporting blocks of PCC/insulating compound shall be used for conductor fixing at an interval of 1500 mm.</p> <p>6. All metallic structures within a vicinity of two meters of the conductors shall be bonded to conductors of lightning protection system.</p> <p>7. Lightning conductors shall not pass through or run inside GI Conduits.</p> <p>8. Testing link shall be made of galvanized steel of size 25x 6mm.</p> <p>9. Pulser system for lightning shall not be accepted.</p> <p>10. Hazardous areas handling inflammable/explosive materials and associated storage areas shall be protected by a system of aerial earths.</p>		
<b>7.00.00</b>	<b>TESTS</b>		
7.01.01	All equipment to be supplied shall be of type tested design. During detail engineering, the contractor shall submit for Owner's approval the reports of all the type tests as listed in this specification and carried out within last ten years from the date of bid opening. These reports should be for the test conducted on the equipment similar to those proposed to be supplied under this contract and the test(s) should have been either conducted at an independent laboratory or should have been witnessed by a client.		
7.01.02	However if the contractor is not able to submit report of the type test(s) conducted within last ten years from the date of bid opening, or in the case of type test report(s) are not found to be meeting the specification requirements, the contractor shall conduct all such tests under this contract at no additional cost to the owner either at third party lab or in presence of client/owners representative and submit the reports for approval.		
7.01.03	All acceptance and routine tests as per the specification and relevant standards shall be carried out. Charges for these shall be deemed to be included in the equipment price.		
7.01.04	The type test reports once approved for any projects shall be treated as reference. For subsequent projects of NTPC, an endorsement sheet will be furnished by the manufacturer confirming similarity and "No design Change". Minor changes if any shall be highlighted on the endorsement sheet.		
7.02.00	<b>Type Test reports shall be furnished for the following</b>		
7.02.01	<p>Type tests on Cable Trays support system</p> <p>a) <b>Test 1A:</b></p> <p>On main support channel type-C2 for cantilever arms fixed on one side only. A 3.5 meter length of main support channel shall be fixed vertically at each end to a rigid structure as per the fixing arrangement as shown in the enclosed drawing. Eight (8) nos. 750 mm cantilever arms shall be fixed to the main channel and each arm shall be loaded over the outboard 600 mm with a uniform working load of 100 kg. Subsequently a point load of 100 kg shall be applied on arm 2. A uniform proof load on all the arms equal to twice the working load shall be then be applied. Deflections shall be measured at the points shown in the enclosed drawings and at the following load intervals:</p>		
<b>KHURJA SUPER THERMAL POWER PROJECT</b> <b>(2X660 MW)</b> <b>TURBINE GENERATOR AND ASSOCIATED</b> <b>PACKAGES</b>	<b>TECHNICAL SPECIFICATION</b> <b>SECTION – VI, PART-B</b> <b>BID DOC. NO.:</b> <b>THDC/RKSH/CC-9915-371</b>	<b>SUB-SECTION-B-05</b> <b>CABLING, EARTHING &amp;</b> <b>LIGHTNING PROTECTION</b>	<b>PAGE</b> <b>16 OF 23</b>



CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 		
	<p>i) Working load</p> <p>ii) Working load + point load</p> <p>iii) Off load</p> <p>iv) Proof load + point load</p> <p>v) Off load</p> <p>The deflection measured at working loads shall not exceed 16mm. The permanent deflection after removing the combination of working load and point load shall not exceed 10 mm at the arm tips and 6 mm on the channel. No collapse of the structure shall occur with a combination of proof load and point load applied.</p> <p><b>B) Test 1B:</b></p> <p>Test 1A shall be repeated with Eight Cantilever arms uniformly loaded and with the same point load on arm 2</p> <p><b>Test 2: On Main support channel type -C2 for cantilever arms fixed on both sides</b></p> <p><b>a) Test 2A:</b> A 3.5 m length of main support channel C2 for cantilever arms fixing on both sides shall be fixed at each end to rigid structure as per the fixing arrangement as shown in the enclosed drawing. Six (6), 750 mm cantilever arms shall be attached to each side and each arm uniformly loaded to a working load of 100 kg over the out board 600 mm. A point load of 100 kg shall than be applied to arm 2, followed by a uniform proof load of twice the working load on all the arms; deflection shall be measured at points shown in the enclosed drawings at the following load intervals.</p> <p>i) Working load</p> <p>ii) Working load + Point load</p> <p>iii) Off load</p> <p>iv) Proof load + Point load</p> <p>v) Off load</p> <p>The deflection measured at working loads shall not exceed 16mm. The permanent deflection after removing the combination of working load and point load shall not exceed 10 mm at the arm tips and 6 mm on the channel. No collapse of the structure shall occur with a combination of proof load and point load applied</p> <p><b>b) Test 2 B:</b> The test 2 A shall be repeated with the assembly but with an asymmetrical load on the C2 column and point load applied to arm 8. The 100 kg and 200 kg uniformly distributed loads shall be applied to the upper three arms on one side and the lower three arms on the opposite side.</p> <p><b>Test 3 : Tests on Channel Fixed on Beam/Floor</b></p> <p>A length of main support channel section shall be fixed to steel structure/floor and have loads applied as shown in the drawing enclosed and as detailed below</p>		
<b>KHURJA SUPER THERMAL POWER PROJECT</b> <b>(2X660 MW)</b> <b>TURBINE GENERATOR AND ASSOCIATED</b> <b>PACKAGES</b>	<b>TECHNICAL SPECIFICATION</b> <b>SECTION – VI, PART-B</b> <b>BID DOC. NO.:</b> <b>THDC/RKSH/CC-9915-371</b>	<b>SUB-SECTION-B-05</b> <b>CABLING, EARTHING &amp;</b> <b>LIGHTNING PROTECTION</b>	<b>PAGE</b> <b>17 OF 23</b>



CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 		
	<p>a) <b>Test 3A</b> : A length of steel structure shall be rigidly supported. It should be fitted on a meter length of channel section using beam clamps welded/bolted. A point load of 1200 kg shall be applied to the centre point via two brackets. No distortion or pulling of the components shall take place.</p> <p>b) <b>Test 3B</b>: With the components assembled as in Test 3A, two perpendicular point loads of 600 kg shall be simultaneously applied at positions 150 mm either side of the centre line, no distortion or pulling of the components shall take place.</p> <p>c) <b>Test 3C</b>: With the components assembled as in Test 3A, a perpendicular point load shall be applied at a point 150 mm on one side of the centre line.</p> <p>The load shall be gradually increased to the maximum value that can be applied without causing distortion or pulling of the components. This value shall be recorded.</p> <p><b>Test 4 : Channel Insert Test</b></p> <p>A 2.5 m length of C1 channel fixed to the concrete wall/ steel structure as per actual site installation conditions. 6 nos. of 750 mm cantilever arms shall be attached to C1 channel as shown in enclosed drawing. Each arm uniformly loaded to a working load of 100 kg over the out board 600 mm. A point load of 100 kg shall than be applied to arm 2, followed by a uniform proof load of twice the working load on all the arms; deflection shall be measured at points shown in the enclosed drawings at the following load intervals.</p> <ul style="list-style-type: none"> <li>i) <b>Working Load</b></li> <li>ii) <b>Working Load + Point Load</b></li> <li>iii) <b>Off Load</b></li> <li>iv) <b>Proof Load + Point Load</b></li> <li>v) <b>Off load</b></li> </ul> <p>The deflection measured at working loads shall not exceed 16mm. The permanent deflection after removing the combination of working load and point load shall not exceed 10 mm at the arm tips and 6 mm on the channel. No collapse of the structure shall occur with a combination of proof load and point load applied</p> <p><b>Test 5 : Channel nut slip characteristics (what ever applicable)</b></p> <p><b>Tests 5A1,5A2,5A3</b> : A length of channel C1 section 200mm long shall have fitted bracket with the two bolt fixing as shown in drawing enclosed. With loads applied at the position shown in drawing enclosed nut slip shall be determined with bolt torque of 30NM, 50 NM and 65 NM No fewer than three measurements shall be made for each torque setting.</p> <p>A minimum loading of 720 kg shall be obtained before nut slip with bolt torque of 65 NM.</p> <p><b>Tests 5B1,5B2,5B3</b>: The length of channel C1 section 200 mm long shall have fitted bracket with the one bolt fixing as shown in drawing enclosed. With loads applied at the position shown in drawing, nut slip shall be determined with bolt torques of 30 NM, 50 NM and 65 NM. No fewer than three measurements shall be made for each torque setting.</p> <p>A minimum loading of 350 kg shall be obtained before nut slip with a bolt torque of 65 NM.</p>		
<b>KHURJA SUPER THERMAL POWER PROJECT</b> (2X660 MW) <b>TURBINE GENERATOR AND ASSOCIATED PACKAGES</b>	<b>TECHNICAL SPECIFICATION</b> SECTION – VI, PART-B <b>BID DOC. NO.:</b> <b>THDC/RKSH/CC-9915-371</b>	<b>SUB-SECTION-B-05</b> <b>CABLING, EARTHING &amp;</b> <b>LIGHTNING PROTECTION</b>	<b>PAGE</b> <b>18 OF 23</b>

CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 		
7.02.02	<p><b>Test 6 Weld Integrity Test</b></p> <p>After deflection test as per test 1A, 1B, 2, 3 &amp; 4 weld integrity shall be checked by magnetic particle inspection to detect sub-surface cracks developed, if any.</p> <p>Cable termination kit and straight through joints should have been tested as per IS:13573 for 3.3kV grade &amp; above.</p>		
7.03.00	<p><b>Routine/ Acceptance Tests</b></p>		
7.03.01	<p><b>Routine Tests</b></p> <p>a) Routine tests as per specification and applicable standards shall be carried out on all requirements/items covered in the specification.</p> <p>b) Physical &amp; dimensional check on all equipments as per approved drawings/standards</p> <p>c) HV/IR as applicable.</p> <p>d) Check/measurement of thickness of paint/zinc coating/nickel-chrome plating as per specification &amp; applicable standard.</p>		
7.03.02	<p><b>Acceptance Test</b></p> <p>a) Galvanising Tests as per applicable standards</p> <p>b) Welding checks</p> <p>c) Deflection tests on cable trays:</p> <p>d) One piece each of 2.5m length of cable tray of 300mm &amp; above shall be taken as sample from each offered lot. It shall be supported at both end &amp; loaded with uniform load of 76 kg/meter along the length of cable tray. The maximum deflection at the mid-span of each size shall not exceed 7mm.</p> <p>d) Proof load tests on cable tray support system</p> <p>i) Tests on Main Support Channel shall be done if only C1 Channel are in scope of supply and cantilever arms shall be fitted on one side. This test shall be same as test 4 of type test.</p> <p>ii) Test on Main Support Channel shall be done with C2 channel and cantilever arms fitted on both sides, if C2 channels are in scope of supply. This test shall be same as test 2A of type test. Then test (i) above shall not be done.</p> <p>iii) Nut slip characteristic test (it shall support minimum load of 350kg before nut slips with a bolt torque of 65 NM). This test shall be same as test 5B3 of type test. The procedure for carrying out tests at "d" above shall be as per details given in Type Tests in specification thereafter Die-Penetration test shall be carried out to check weld integrity.</p> <p>d) The above acceptance tests shall be done only on one sample from each offered lot.</p>		
<b>KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES</b>	<b>TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371</b>	<b>SUB-SECTION-B-05 CABLING, EARTHING &amp; LIGHTNING PROTECTION</b>	<b>PAGE 19 OF 23</b>


CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 		
<b>8.00.00</b>	<b>COMMISSIONING</b>		
8.01.01	The Contractor shall carry out the following commissioning tests and checks after installation at site. In addition the Contractor shall carry out all other checks and tests as recommended by the Manufacturers or else required for satisfactory performance..		
8.01.02	<b>Cables</b> <ol style="list-style-type: none"> <li>a) Check for physical damage</li> <li>b) Check for insulation resistance before and after termination/jointing.</li> <li>c) HT cables shall be pressure tested (test voltage as per IS:7098) before commissioning.</li> <li>d) Check of continuity of all cores of the cables.</li> <li>e) Check for correctness of all connections as per relevant wiring diagrams. Any minor modification to the panel wiring like removing/inserting, shorting, change in terminal connections, etc., shall be carried out by the Contractor.</li> <li>f) Check for correct polarity and phasing of cable connections.</li> <li>g) Check for proper earth connections for cable glands, cable boxes, cable armour, screens, etc.</li> <li>h) Check for provision of correct cable tags, core ferrules, tightness of connections.</li> </ol>		
8.02.00	<b>Cable trays / supports and accessories</b> <ol style="list-style-type: none"> <li>1) Check for proper galvanizing/painting and identification number of the cable trays/supports and accessories.</li> <li>2) Check for continuity of cable trays over the entire route.</li> <li>3) Check that all sharp corners, burrs, and waste materials have been removed from the trays supports.</li> <li>4) Check for earth continuity and earth connection of cable trays.</li> </ol>		
8.03.00	<b>Earthing and Lightning protection system</b> <ol style="list-style-type: none"> <li>1) Earth continuity checks.</li> <li>2) Earth resistance of the complete system as well as sub-system.</li> </ol>		
8.04.00	<p>Below Ground Earth Mat:</p> <p>The earthing system for plant shall be designed as per Clause No:- 3.07.00 of Sub Section B-0 of Technical Specification Section-VI, Part-B</p> <p>Grounding for TG and other areas or buildings covered in the specification shall be provided in accordance with IS 3043, IEC 62305, IEEE 80.</p> <p>Earthing system network/earthmat shall be interconnected mesh of mild steel rods buried in ground in the plant. All areas under contractor scope of supply shall be interconnected</p>		
<b>KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES</b>	<b>TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371</b>	<b>SUB-SECTION-B-05 CABLING, EARTHING &amp; LIGHTNING PROTECTION</b>	<b>PAGE 20 OF 23</b>

CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 												
9.00.00	<p>together by minimum two parallel conductors. The Contractor shall furnish the detailed design and calculations for Employer's approval. Contractor shall obtain all necessary statutory approvals for the system. All the columns shall be earthed by nearby risers and earthmat grid spacing shall be maximum 10 X 10 mts.. Minimum two nos of risers shall be provided for each equipment in his scope of area. Separate dedicated riser shall be provided for C&amp;I earthing purpose and also for Lightning down conductor connection purpose. Sufficient nos of risers near the equipment shall be provided as per the system requirement.</p> <p><b>ELECTRICAL LAYOUT PHILOSOPHY:</b></p> <p>While developing the layout the bidder must give due consideration to the following requirements:</p> <p>a) Adequate distance shall be maintained between the transformers. As basic guidelines following norms will be adhered to:</p> <ol style="list-style-type: none"> <li>1) Transformers shall be separated from the adjacent building/structures and from each other by a minimum distance as defined below or by a fire wall of two hours of fire resisting of height at least 600 mm above bushing / pressure relief vent whichever is higher. <table border="0" data-bbox="581 800 1321 1052"> <thead> <tr> <th style="text-align: center;">Oil capacity of individual transformer (in liters)</th> <th style="text-align: center;">Clear separating distance (in meters)</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">5,000 to 10,000</td> <td style="text-align: center;">8.0</td> </tr> <tr> <td style="text-align: center;">10,001 to 20,000</td> <td style="text-align: center;">10.0</td> </tr> <tr> <td style="text-align: center;">20,001 to 30,000</td> <td style="text-align: center;">12.5</td> </tr> <tr> <td style="text-align: center;">Over 30,001</td> <td style="text-align: center;">15.0</td> </tr> </tbody> </table> </li> <li>2) In case of auxiliary transformers having an aggregate oil capacity in excess of 2300 liters but individual oil capacity of less than 5000 liters, the maximum separating distance between transformers and surrounding building shall be at least 6M unless they are separated by fire separating walls or are protected by high velocity spray system.</li> <li>3.) Rail track shall be provided in Transformer yard for movement of each transformer. The rail track in Transformer yard shall be connected with TG area rail track The Foundation top of transformer &amp; rail top shall be at EL +/- 0.0M. Bus duct support or Transformer body shall be at least 8.0M from A-Row of TG building to clear the movement of GT/ Stator/UT/ST/UAT on rail line. Jacking pads shall be provided where the rail track changes the direction. Mooring post shall be provided on rail track for handling the transformers.</li> <li>4) For each transformer a pit shall be provided all around at a distance of 1.5 m (minimum) from transformer outer edge. A sump pit shall be provided for each pit. A common oil retention pit per unit shall be provided to hold oil quantity of the largest transformer (by volume) &amp; 10 minutes of water quantity of HWV spray system for the largest transformer. Sump pit of individual transformer shall be connected to common oil retention pit of that unit.</li> <li>5) Rail track shall be provided for all outdoor transformers up to road for movement of each transformer of size more than or equal to 7.5MVA Transformer. Jacking pads shall be provided where the rail track changes the direction. Jacking pad shall also be provided at the location of installation of transformer and mooring post shall be provided on rail track for handling the transformers.</li> </ol>			Oil capacity of individual transformer (in liters)	Clear separating distance (in meters)	5,000 to 10,000	8.0	10,001 to 20,000	10.0	20,001 to 30,000	12.5	Over 30,001	15.0
Oil capacity of individual transformer (in liters)	Clear separating distance (in meters)												
5,000 to 10,000	8.0												
10,001 to 20,000	10.0												
20,001 to 30,000	12.5												
Over 30,001	15.0												
<b>KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES</b>	<b>TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371</b>	<b>SUB-SECTION-B-05 CABLING, EARTHING &amp; LIGHTNING PROTECTION</b>	<b>PAGE 21 OF 23</b>										


CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 		
	<p>6.) The Transformer fencing shall be at 1.0 M (minimum) distance from the pit wall. The Height of fencing shall be 2.5 M (minimum) and fencing shall have personal entry gate and removable type fencing/gate for transformer withdrawal.</p> <p>7) The transformer firewall, pit sizing and clearances from adjacent building/structures etc. shall be as per IS 1646/CBIP manual on Transformer</p> <p>8) However, for all outdoor transformers of oil capacity less than 2000 litre, a trench of suitable size shall be provided all around at a distance of 1.0 m (minimum) from transformer outer edge. A sump pit shall be provided for each trench.</p> <p>b) Layout requirements for Electrical MCC/switchgear rooms</p> <p>1. Separate Switchgear Rooms shall be provided for each unit. For TG building, all HT boards shall be provided in HT switchgear room at only one floor and all LT boards shall be provided in LT switchgear room only.</p> <p><b>2. The following clearances shall be maintained for HT Switchboard.</b></p> <p><b>a.) Front Clearance</b></p> <p>i) For one Row of Swgr. - 2.0 M (Min)</p> <p>ii) For two Rows of Swgr. - 2.5 M (Min)</p> <p><b>b.) Back Clearance - 1.5 M (Min.)</b></p> <p><b>c.) Side Clearance</b> Min. 800 mm, however provision to be made for any additional panel in future at both ends. Therefore end clearance shall be 800+width of panel (including spare panels/dummy panels etc.)</p> <p><b>3. The following clearances shall be maintained for LT Switchboard.</b></p> <p>a.) Front Clearance</p> <p>i) For one Row of Swgr - 1.5M (Min)</p> <p>ii) For two Rows of Swgr - 1.5/1.75M depending upon the depth of panels etc</p> <p>b.) Back Clearance</p> <p>i) For single front - 1.0M (Min)</p> <p>ii) For double front - 1.5M (Min)</p> <p>c.) Side Clearance</p> <p>Min. 800 mm, however provision to be made for any additional panel in future at both ends. Therefore end clearance shall be 800 mm + width of panel.</p> <p>For offsite areas, HT Switchboard clearances shall be followed wherever both LT &amp; HT switch boards are in the same MCC room.</p> <p>4. Height of HT/LT Switchgear Room and Boiler MCC room</p> <p>i) With Bus Duct - 4.5 m (min)</p> <p>ii) Without Bus Duct - 4.0 m (min)</p>		
<b>KHURJA SUPER THERMAL POWER PROJECT</b> (2X660 MW) <b>TURBINE GENERATOR AND ASSOCIATED PACKAGES</b>	<b>TECHNICAL SPECIFICATION</b> SECTION – VI, PART-B <b>BID DOC. NO.:</b> THDC/RKSH/CC-9915-371	<b>SUB-SECTION-B-05</b> CABLING, EARTHING & LIGHTNING PROTECTION	<b>PAGE</b> 22 OF 23

CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 		
	<p>Further no vertical bracings shall be envisaged in HT/LT switchgear room and associated cable vault area.</p> <p>5. Cable trench/Cable vault</p> <p>For LT switchgear/MCC room at EL 0.0M, minimum 1400 wide x 1400 deep cable trench shall be provided to route the cables. Horizontal cable trays shall be routed in cable trenches.</p> <p>c) Minimum clear working space 1200mm around the equipment</p> <p>e) In buildings having MCC, minimum 2 fire door along with one rolling shutter of adequate size/capacity shall be provided.</p> <p>f) The cable entry and exit from switchgear room shall be from 1.5 mtr (minimum) above FGL.</p>		
<b>KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED PACKAGES</b>	<b>TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915-371</b>	<b>SUB-SECTION-B-05 CABLING, EARTHING &amp; LIGHTNING PROTECTION</b>	<b>PAGE 23 OF 23</b>

This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.



**SINGLE CHANNEL-TYPE C1**




**TWO LENGTHS OF C1 WELDED BACK TO BACK**


**DOUBLE CHANNEL-TYPE C2**

**NOTES.**

1. ALL DIMENSIONS ARE IN mm.
2. MATERIAL :- 2.5mm. THICK MS SHEET.
3. TOLERANCE :-AS PER RELEVANT IS.
4. FINISH :-HOT DIP GALVANISED


RC	FOR TENDER PURPOSE	A3	A3	DM	-	VV	-	-	-	-	AS	05/07/2022
RB	FOR TENDER PURPOSE	DL	DL	SS	-	RA	-	-	-	-	AS	05/07/2022
RA	FOR TENDER PURPOSE	-	-	-	-	-	-	-	-	-	-	07/08/2022
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD	M	E	C	C&C	ARCH	APPD	DATE	
CLEARED BY												
 <b>NTPC LTD.</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION												
PROJECT		STANDARD										
TITLE		C1 & C2 CHANNEL, CABLE TRAY SUPPORT SYSTEM										
SIZE	SCALE	DRG. NO.		0000-211-P0E-A-013						REV. NO.		RC
A4	NTS											

This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.




**TYPICAL DETAILS OF FIXING ACCESSORIES**

- NOTES.  
 1. MATERIAL :- MILD STEEL  
 2. FINISH :-HOT DIP GALVANISED

RC	FOR TENDER PURPOSE	M3	M3	PKR	-	VV	-	-	-	AS	05.07.2000
RB	FOR TENDER PURPOSE	DL	DL	SS	-	RA	-	-	-	AS	05.07.2000
RA	FOR TENDER PURPOSE	-	-	-	-	-	-	-	-	-	07.06.2000
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD	M	E	C	C&I	ARCH	APPD	DATE
CLEARED BY											
 <b>NTPC LTD.</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION											
PROJECT		STANDARD									
TITLE		TYPICAL DETAILS OF CABLE TRAY SUPPORT SYSTEM									
SIZE A4	SCALE NTS	DRG. NO. 0000-211-PDE-A-014							REV. NO. RC		

This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.






NOTE.

1. FINISH :-HOT DIP GALVANISED

RC	FOR TENDER PURPOSE	M3	M3	R4F	-	VV	-	-	-	AS	03/17
RB	FOR TENDER PURPOSE	DL	DL	SS	-	RA	-	-	-	AS	03/17
RA	FOR TENDER PURPOSE	-	-	-	-	-	-	-	-	-	03/17
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD	M	E	C	C&I	ARCH	APPD	DATE
CLEARED BY											
एन टी पी सी <b>NTPC</b>		<b>NTPC LTD.</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION									
PROJECT <b>STANDARD</b>											
TITLE <b>TYPICAL DETAIL OF CABLE TRAY SUPPORT SYSTEM</b>											
SIZE	SCALE	DRG. NO.								REV. NO.	
A4	NTS	0000-211-POE-A-015								RC	



This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.



**ASSEMBLY-1**  
UPPER FIXING C2 CHANNEL




**ASSEMBLY-2**  
UPPER FIXING C1 CHANNEL

**UPPER FIXING FOR CHANNEL VERTICAL SUPPORTS**

- NOTES.  
1. MATERIAL : MS SHEET.  
2. FINISH : HOT DIP GALVANIZED

RC	FOR TENDER PURPOSE	M3	M3	REV.	-	VV	-	-	-	AS	05/08/2022
RB	FOR TENDER PURPOSE	DL	DL	SS	-	RA	-	-	-	AS	05/08/2022
RA	FOR TENDER PURPOSE	-	-	-	-	-	-	-	-	-	05/08/2022
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD.	M	E	C	C&I	ARCH	APPD	DATE
CLEARED BY											
		<b>NTPC LTD.</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION									
PROJECT STANDARD											
TITLE TYPICAL DETAILS OF CABLE TRAY SUPPORT SYSTEM											
SIZE	SCALE	DRG. NO. 0003-211-POE-A-017								REV. NO. RC	
A4	NTS										

This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.




FLOOR FIXING FOR CHANNEL VERTICAL SUPPORTS


- NOTES.  
1. MATERIAL : MS SHEET.  
2. FINISH : HOT DIP GALVANIZED


RC	FOR TENDER PURPOSE	M3	M3	2x8	-	V4	-	-	-	AS	05/07/2022
RB	FOR TENDER PURPOSE	DL	DL	SS	-	RA	-	-	-	AS	05/07/2022
RA	FOR TENDER PURPOSE	-	-	-	-	-	-	-	-	-	07/08/2022
REV. NO.	DESCRIPTION	DRAW	DESIGN	CHK	M	E	C	C&I	ARCH	APPD	DATE
CLEARED BY											
एन टी पी सी <b>NTPC</b>		<b>NTPC LTD.</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION									
PROJECT											
STANDARD											
TITLE											
TYPICAL DETAILS OF CABLE TRAY SUPPORT SYSTEM											
SIZE	SCALE	DRG. NO.							REV. NO.		
A4	NTS	0000-211-POE-A-018							RC		

This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.




- NOTES.  
 1. MATERIAL : MS SHEET.  
 2. FINISH : HOT DIP GALVANIZED

RC	FOR TENDER PURPOSE	B	B	BY	-	W	-	-	-	AS	05.07.2022
RB	FOR TENDER PURPOSE	DL	DL	SS	-	RA	-	-	-	AS	05.07.2022
RA	FOR TENDER PURPOSE	-	-	-	-	-	-	-	-	-	07.01.2022
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD	M	E	C	C&I	ARCH	APPO	DATE
CLEARED BY											
 एन टी सी <b>NTPC</b>		<b>NTPC LTD.</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION									
PROJECT											
STANDARD											
TITLE											
FIXING OF CHANNEL IN TRENCH WALL											
SIZE	SCALE	DRG. NO.								REV. NO.	
A4	NTS	0000-211-POE-A-019								RC	




TRESTLE BRACKET.



FIXING ARRANGEMENT OF TRESTLE BRACKET.

NOTES


- 1) MATERIAL : MILD STEEL.
- 2) FINISH : HOT DIP GALVANISED.

RA	FOR TENDER PURPOSE	MV	RKP	VKM	-	SS	-	-	-	DT	08/10/2008
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD	M	E	C	C&I	ARCH	APPD	DATE
CLEARED BY											
		<b>NTPC LIMITED</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ( FORMERLY NATIONAL THERMAL POWER CORPORATION LTD. ) ENGINEERING DIVISION									
PROJECT						STANDARD					
TITLE    FIXING OF CHANNEL FOR TRESTLE AND TRESTLE BRACKET.											
SIZE	SCALE	DRG. NO.				0000-211-PDE-A-022A				REV. NO.	
A4	NTS									RA	

ISA

TRAY1A-211-022A


This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.



**VERTICAL SUPPORT**

- 1) FOR 1 TO 6 TIER OF 600mm TRAY - C2 CHANNEL
- 2) FOR 1 TO 3 TIER OF 300mm TRAY - C1 CHANNEL
- 3) FOR 4 TO 6 TIER OF 300mm TRAY - C2 CHANNEL
- 4) FOR 1 TO 6 TIER OF 150mm TRAY - C1 CHANNEL

**ARRANGEMENT TYPE-B1**




**NOTES.**

1. ALL DIMENSIONS ARE IN mm.
2. MATERIAL : MS SHEET.
3. FINISH : HOT DIP GALVANIZED
4. IN CASE OF HANGING SUPPORT C2 CHANNEL TO BE USED FOR MAIN SUPPORT

**ARRANGEMENT TYPE-B2**


RC	FOR TENDER PURPOSE	A3	A3	QWL	-	W	-	-	-	AS	05.07.2022
RB	FOR TENDER PURPOSE	DL	DL	SS	-	RA	-	-	-	AS	05.07.2022
RA	FOR TENDER PURPOSE	-	-	-	-	-	-	-	-	-	07.21.2022
REV. NO.	DESCRIPTION	DRAWING	DESIGN	CHKD	M	E	C	C&d	ARCH	APPD	DATE
CLEARED BY											
		<b>NTPC LTD.</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION									
PROJECT		STANDARD									
TITLE		STANDARD CABLE SUPPORT ASSEMBLY									
SIZE	SCALE	DRG. NO.							REV. NO.		
A4	NTS	0000-211-PDE-A-030							RC		

This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.



- VERTICAL SUPPORT**
- 1) FOR 1 TO 6 TIER OF 600mm TRAY - C2 CHANNEL
  - 2) FOR 1 TO 3 TIER OF 300mm TRAY - C1 CHANNEL
  - 3) FOR 4 TO 6 TIER OF 300mm TRAY - C2 CHANNEL
  - 4) FOR 1 TO 6 TIER OF 150mm TRAY - C1 CHANNEL

**ARRANGEMENT TYPE-B1**



- NOTES.**
1. ALL DIMENSIONS ARE IN mm.
  2. MATERIAL : MS SHEET.
  3. FINISH : HOT DIP GALVANIZED
  4. IN CASE OF HANGING SUPPORT C2 CHANNEL TO BE USED FOR MAIN SUPPORT

**ARRANGEMENT TYPE-B2**


RC	FOR TENDER PURPOSE	A3	A3	QWL	-	W	-	-	-	AS	05.07.2022
RB	FOR TENDER PURPOSE	DL	DL	SS	-	RA	-	-	-	AS	05.07.2022
RA	FOR TENDER PURPOSE	-	-	-	-	-	-	-	-	-	07.01.2022
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD	M	E	C	C&d	ARCH	APPD	DATE
CLEARED BY											



**NTPC LTD.**  
( A GOVERNMENT OF INDIA ENTERPRISE )  
ENGINEERING DIVISION


PROJECT		STANDARD									
TITLE		STANDARD CABLE SUPPORT ASSEMBLY									
SIZE	SCALE	DRG. NO.								REV. NO.	
A4	NTS	0000-211-PDE-A-030								RC	

This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.



**VERTICAL SUPPORT**

- 1) FOR 1 TO 6 TIER OF 600mm TRAY - C2 CHANNEL
- 2) FOR 1 TO 3 TIER OF 300mm TRAY - C1 CHANNEL
- 3) FOR 4 TO 6 TIER OF 300mm TRAY - C2 CHANNEL
- 4) FOR 1 TO 6 TIER OF 150mm TRAY - C1 CHANNEL



**ARRANGEMENT TYPE-C1**

**NOTES.**

1. ALL DIMENSIONS ARE IN mm.
2. MATERIAL : MS SHEET.
3. FINISH : HOT DIP GALVANIZED
4. BRACKETS USED FOR FIXING OF C1/C2 CHANNEL SHALL BE ANCHOR BOLTED/WELDED.


RC	FOR TENDER PURPOSE	M	M	RL	-	W	-	-	-	AS	01.07.2022
RB	FOR TENDER PURPOSE	DL	DL	SS	-	RA	-	-	-	AS	01.07.2022
RA	FOR TENDER PURPOSE	-	-	-	-	-	-	-	-	-	07.06.2020
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD	M	E	C	C&d	ARCH	APPD	DATE
CLEARED BY											



**NTPC LTD.**  
( A GOVERNMENT OF INDIA ENTERPRISE )  
ENGINEERING DIVISION


PROJECT		STANDARD									
TITLE		STANDARD CABLE SUPPORT ASSEMBLY									
SIZE	SCALE	DRG. NO.								REV. NO.	
A4	NTS	0000-211-PDE-A-031								RC	

This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.



**VERTICAL SUPPORT**  
1) UPTO 3 TIER - C1 CHANNEL  
2) ABOVE 3 TIER - C2 CHANNEL

**ARRANGEMENT TYPE-D1**




**ARRANGEMENT TYPE-D2**


- NOTES.**  
1. ALL DIMENSIONS ARE IN mm.  
2. MATERIAL : MS SHEET.  
3. FINISH : HOT DIP GALVANIZED  
4. BRACKETS USED FOR FIXING OF C1/C2 CHANNEL SHALL BE ANCHOR BOLTED/WELDED.

RC	FOR TENDER PURPOSE	M3	M3	RA	-	W	-	-	-	AS	05/10
RB	FOR TENDER PURPOSE	DL	DL	SS	-	RA	-	-	-	AS	05/10
RA	FOR TENDER PURPOSE	-	-	-	-	-	-	-	-	-	05/10
REV. NO.	DESCRIPTION	DRAW	DESIGN	CHKD	M	E	C	C&I	ARCH	APPD	DATE
CLEARED BY											
एन टी पी सी <b>NTPC</b>		<b>NTPC LTD.</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION									
PROJECT		STANDARD									
TITLE		STANDARD CABLE SUPPORT ASSEMBLY									
SIZE A4	SCALE NTS	DRG. NO. 0000-211-PDE-A-032							REV. NO. RC		

This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.



(W=WIDTH OF CABLE TRAY)



**VIEW - A**

**ARRANGEMENT TYPE-S1**

**NOTES.**


1. ALL DIMENSIONS ARE IN mm.
2. MATERIAL : MS SHEET.
3. FINISH : HOT DIP GALVANIZED
4. BRACKETS USED FOR FIXING OF C1/C2 CHANNEL SHALL BE ANCHOR BOLTED/WELDED.

RC	FOR TENDER PURPOSE	A2	A3	EXP	-	NY	-	-	-	AS	05.07.20
RB	FOR TENDER PURPOSE	DL	DL	SS	-	RA	-	-	-	AS	05.07.20
RA	FOR TENDER PURPOSE	-	-	-	-	-	-	-	-	-	07.06.2020
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD	M	E	C	C&I	ARCH	APPD	DATE
CLEARED BY											
एन टी पी सी <b>NTPC</b>		<b>NTPC LTD.</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION									
PROJECT		STANDARD									
TITLE		STANDARD CABLE SUPPORT ASSEMBLY									
SIZE A4	SCALE NTS	DRG. NO. 0000-211-PDE-A-033							REV. NO. RC		

This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.

**MAIN SUPPORT**

- 1) FOR 1 TO 5 TIER OF 500mm TRAY - C2 CHANNEL
- 2) FOR 1 TO 3 TIER OF 500mm TRAY - C1 CHANNEL
- 3) FOR 4 TO 5 TIER OF 500mm TRAY - C2 CHANNEL
- 4) FOR 1 TO 5 TIER OF 150mm TRAY - C1 CHANNEL



**ARRANGEMENT TYPE-S2**

**NOTES.**

- 1. ALL DIMENSIONS ARE IN mm.
- 2. MATERIAL : MS SHEET.
- 3. FINISH : HOT DIP GALVANIZED
- 4. BRACKETS USED FOR FIXING OF C1/C2 CHANNEL SHALL BE ANCHOR BOLTED/WELDED.

RC	FOR TENDER PURPOSE	A3	A3	CHK	-	WV	-	-	-	AS	05/07/20
RB	FOR TENDER PURPOSE	DL	DL	SS	-	RA	-	-	-	AS	05/07/20
RA	FOR TENDER PURPOSE	-	-	-	-	-	-	-	-	-	07/08/20
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD	M	E	C	C&d	ARCH	APPD	DATE
CLEARED BY											



**NTPC LTD.**  
( A GOVERNMENT OF INDIA ENTERPRISE )  
ENGINEERING DIVISION

PROJECT		STANDARD	
TITLE		STANDARD CABLE SUPPORT ASSEMBLY	
SIZE A4	SCALE NTS	DRG. NO. 0000-211-POE-A-034	REV. NO. RC


This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.

CHANNELS SUPPORTED BY FLOOR BEAM

MAIN SUPPORT CHANNEL IS SUPPORTED BY BRACKET

C1 CHANNEL PIECES SUPPORTED BY BRACKET.

BRACKET



**ARRANGEMENT TYPE-S3**


**MAIN SUPPORT**

- 1) UPTO 3 TIER - C1 CHANNEL
- 2) ABOVE 3 TIER - C2 CHANNEL

BRACKET

MAIN SUPPORT CHANNEL C1/C2

CANTILEVER ARM



**ARRANGEMENT TYPE-S4**

**NOTES.**

- 1. ALL DIMENSIONS ARE IN mm.
- 2. MATERIAL : MS SHEET.
- 3. FINISH : HOT DIP GALVANIZED
- 4. BRACKETS USED FOR FIXING OF C1/C2 CHANNEL SHALL BE ANCHOR BOLTED/WELDED.


RC	FOR TENDER PURPOSE	M3	M3	REV	-	W	-	-	-	AS	05-07-20
RB	FOR TENDER PURPOSE	DL	DL	SS	-	RA	-	-	-	AS	05-07-20
RA	FOR TENDER PURPOSE	-	-	-	-	-	-	-	-	-	07-01-2008
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD	M	E	C	C&I	ARCH	APPD	DATE
CLEARED BY											




**NTPC LTD.**  
( A GOVERNMENT OF INDIA ENTERPRISE )  
ENGINEERING DIVISION


PROJECT		STANDARD									
TITLE		STANDARD CABLE SUPPORT ASSEMBLY									
SIZE	SCALE	DRG. NO.								REV. NO.	
A4	NTS	0000-211-PDE-A-035								RC	

This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.



RA.	FOR TENDER PURPOSE	13	13	248	-	ⓧ	-	-	-	10/10	
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD.	M	E	C	C&I	ARCH.	APFD.	DATE
CLEARED BY											
		<b>NTPC LTD.</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION									
PROJECT		STANDARD									
TITLE		TYPICAL INTERCONNECTION DETAILS BETWEEN TWO PERPENDICULAR TRESTLES									
SIZE	SCALE	DRG. NO.						REV. NO.			
A4	NTS	DC00-211-POE-A-035A						RA			

This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.




**TESTS 1: MAIN SUPPORT CHANNEL (CANTILEVER ARMS ON ONE SIDE)**

- NOTES.  
 1. ALL DIMENSIONS ARE IN mm.  
 2. BRACKETS USED FOR FIXING OF C1/C2 CHANNEL SHALL BE ANCHOR BOLTED/WELDED.

RC	FOR TENDER PURPOSE	M3	M3	RKH	-	W	-	-	-	AS	05.07.2022
RB	FOR TENDER PURPOSE	RKG	RKG	VKN	-	SS	-	-	-	AS	05.07.2022
RA	FOR TENDER PURPOSE	-	-	-	-	-	-	-	-	-	07.08.2022
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD	M	E	C	C&I	ARCH	APPD	DATE
CLEARED BY											
एन टी पी सी <b>NTPC</b>		<b>NTPC LTD.</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION									
PROJECT		STANDARD									
TITLE		TYPICAL DETAILS OF STRUCTURE FOR TESTING									
SIZE	SCALE	DRG. NO.							REV. NO.		
A4	NTS	0000-211-POE-A-036							RC		

This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.




**TEST 2A : MAIN SUPPORT CHANNEL**  
( CANTILEVER ARMS ON BOTH SIDES )


- NOTES.**
1. ALL DIMENSIONS ARE IN mm.
  2. BRACKETS USED FOR FIXING OF C1/C2 CHANNEL SHALL BE ANCHOR BOLTED/WELDED.

RC	FOR TENDER PURPOSE	M3/M3	RVR	-	V4	-	-	-	AS	05/07/20	
RB	FOR TENDER PURPOSE	RKG/RKG	VKM	-	SS	-	-	-	AS	05/07/20	
RA	FOR TENDER PURPOSE	-	-	-	-	-	-	-	-	07/08/2000	
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD	M	E	C	C&I	ARCH	APPD	DATE
CLEARED BY											
एन टी पी सी <b>NTPC</b>		<b>NTPC LTD.</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION									
PROJECT		STANDARD									
TITLE		TYPICAL DETAILS OF STRUCTURE FOR TESTING									
SIZE	SCALE	DRG. NO.						REV. NO.			
A4	NTS	0000-211-POE-A-037						RC			

This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.



**TEST 2B MAIN SUPPORT CHANNEL**  
(ASYMMETRIC LOADING)




**TEST 3A, 3B & 3C**

- NOTES.
1. ALL DIMENSIONS ARE IN mm.
  2. BRACKETS USED FOR FIXING OF C1/C2 CHANNEL SHALL BE ANCHOR BOLTED/WELDED.

RC	FOR TENDER PURPOSE	B	B	RV	-	NY	-	-	-	AS	05/07/20
RB	FOR TENDER PURPOSE	RK	RK	VKM	-	SS	-	-	-	AS	05/07/20
RA	FOR TENDER PURPOSE	-	-	-	-	-	-	-	-	-	05/07/20
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD	M	E	C	C&I	ARCH	APPD	DATE
CLEARED BY											

 <b>NTPC LTD.</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION			
PROJECT STANDARD			
TITLE TYPICAL DETAILS STRUCTURE FOR TESTING			
SIZE A4	SCALE NTS	DRG. NO. 0000-211-POE-A-038	REV. NO. RC




**NOTES**

ALL DIMENSIONS ARE IN MM (SCALE-NTS)

RB	FOR TENDER PURPOSE	REC	DES	CHK	APP	-	REV	-	-	-	-	-
RA	FOR TENDER PURPOSE ONLY	R	DES	CHK	-	R	-	-	-	-	-	APR 2022
REV. NO.	DESCRIPTION	DRW	DESIGN	CHKD	M	E	C	CHK	ARCH	APPD	DATE	
CLEARED BY												
		<b>NTPC Limited</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION										
PROJECT						STANDARD						
TITLE TYPICAL DETAILS OF STRUCTURE FOR TESTING												
SIZE	SCALE	DRG. NO.						REV. NO.				
A4	NTS	0000-211-P0E-A-030						RB				


CAD FILE NAME : STAND-211-039.DWG

This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.





FRONT VIEW WITH COVER REMOVED

NOTE.  
1. ALL DIMENSIONS ARE IN mm.


RC	FOR TENDER PURPOSE	M3	M3	exp	-	JY	-	-	-	AS	05/07/22
RB	FOR TENDER PURPOSE	RKG	RKG	VKM	-	SS	-	-	-	AS	05/07/22
RA	FOR TENDER PURPOSE	-	-	-	-	-	-	-	-	-	07/08/2020
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD	M	E	C	C&I	ARCH	APPD	DATE
CLEARED BY											
 <b>NTPC LTD.</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION											
PROJECT					STANDARD						
TITLE TYPICAL DRAWING FOR JUNCTION BOX											
SIZE A4	SCALE NTS	DRG. NO. 0000-211-POE-A-040						REV. NO. RC			

This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.




EARTH RISER


NOTE.  
1. ALL DIMENSIONS ARE IN mm.

RC	FOR TENDER PURPOSE	M3	M3	REF	-	WV	-	-	-	-	AS	05.02/20
RB	FOR TENDER PURPOSE	RKG	RKG	VKM	-	SS	-	-	-	-	AS	05.02/20
RA	FOR TENDER PURPOSE	-	-	-	-	-	-	-	-	-	-	07.01.2020
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD	M	E	C	C&I	ARCH	APPD	DATE	
CLEARED BY												
 <b>NTPC LTD.</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION												
PROJECT		STANDARI										
TITLE		EARTHING DETAILS										
SIZE	SCALE	DRG. NO.							REV. NO.			
A4	NTS	0000-211-POE-A-041							RC			


This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.




EQUIPMENT GROUNDING WITH G.S. FLAT





EQUIPMENT GROUNDING WITH G.S. WIRE




MOTOR TERMINAL BOX GROUNDING DETAIL



LAP JOINTS BETWEEN G.S. FLATS



ANGULAR JOINTS BETWEEN G.S. FLATS



SEC. B-B

NOTE.  
1. ALL DIMENSIONS ARE IN mm.




RC	FOR TENDER PURPOSE	A3	A3	RKL	-	NV	-	-	-	AS	05-02-20
RB	FOR TENDER PURPOSE	RKG	RKG	VKM	-	SS	-	-	-	AS	05-02-20
RA	FOR TENDER PURPOSE	-	-	-	-	-	-	-	-	-	07-08-20
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD	M	E	C	C&I	ARCH	APPD	DATE
CLEARED BY											



**NTPC LTD.**  
( A GOVERNMENT OF INDIA ENTERPRISE )  
ENGINEERING DIVISION

PROJECT		STANDARD									
TITLE		EARTHING DETAILS									
SIZE	SCALE	DRG. NO.								REV. NO.	
A4	NTS	0000-211-POE-A-042								RC	


This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.




NOTE.  
1. ALL DIMENSIONS ARE IN mm.

RC	FOR TENDER PURPOSE	M3	M3	REV	-	NY	-	-	-	AS	05/07/20
RB	FOR TENDER PURPOSE	RKG	RKG	VKM	-	SS	-	-	-	AS	05/07/20
RA	FOR TENDER PURPOSE	-	-	-	-	-	-	-	-	-	07/08/20
REV. NO.	DESCRIPTION	DRAW	DESIGN	CHKD	M	E	C	C&I	ARCH	APPD	DATE
CLEARED BY											
		<b>NTPC LTD.</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION									
PROJECT		STANDARD									
TITLE		EARTHING DETAILS									
SIZE	SCALE	DRG. NO.							REV. NO.		
A4	NTS	0000-211-PDE-A-043							RC		

This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.



EARTHING DETAILS MCC AND SWITCHGEAR




SEALING OF UNUSED CABLE OPENING

NOTE.  
1. ALL DIMENSIONS ARE IN mm.


RC	FOR TENDER PURPOSE	M	AS	RVP	-	VV	-	-	-	05.07/22	
RB	FOR TENDER PURPOSE	RKG	RKG	VKM	-	SS	-	-	-	AS	
RA	FOR TENDER PURPOSE	-	-	-	-	-	-	-	-	07.08.2022	
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD	M	E	C	C&I	ARCH	APPD	DATE
					Cleared by						
		<p align="center"><b>NTPC LTD.</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION</p>									
PROJECT		STANDARD									
TITLE		EARTHING DETAILS									
SIZE	SCALE	DRG. NO.				REV. NO.					
A4	NTS	0000-211-POE-A-044				RC					

This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.




EARTHING DETAILS TRANSFORMER

- NOTE.  
 1. ALL DIMENSIONS ARE IN mm.  
 2. THE TRANSFORMER NEUTRAL FOR HT TRANSFORMER SHALL BE EARTHED THROUGH FLATS AS SHOWN (SUPPLIED BY TRANSFORMER SUPPLIER)

RC	FOR TENDER PURPOSE	M	M	RXL	-	W	-	-	-	-	-	-	-	DS-02/10
RB	FOR TENDER PURPOSE	RKG	RKG	VKM	-	SS	-	-	-	-	-	-	-	AS
RA	FOR TENDER PURPOSE	-	-	-	-	-	-	-	-	-	-	-	-	17/01/2022
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD	M	E	C	C&I	ARCH	APPD	DATE	CLEARED BY		
		<p align="center"><b>NTPC LTD.</b>                  ( A GOVERNMENT OF INDIA ENTERPRISE )                  ENGINEERING DIVISION</p>												
PROJECT		STANDARD												
TITLE		EARTHING DETAILS												
SIZE	SCALE	DRG. NO.		0000-211-POE-A-045							REV. NO.			
A4	NTS										RC			


This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.



- NOTE.
1. ALL DIMENSIONS ARE IN mm.
  2. THE TEST LINK SHALL BE OF SAME WIDTH AND THICKNESS AS THE DOWNCOMER. THE NUTS BOLTS AND WASHER TO BE OF GS.
  3. THE DOWN COMER ENTRY AND EXIT POINTS IN TO BOX BE MADE WATER-TIGHT AFTER LAYING OF CONDUCTOR.

RC	FOR TENDER PURPOSE	M3 M3	REL	-	W4	-	-	-	-	05/07/20	
RB	FOR TENDER PURPOSE	RKGRKG	VKN	-	SS	-	-	-	-	AS	
RA	FOR TENDER PURPOSE	-	-	-	-	-	-	-	-	07/08/20	
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD	M	E	C	C&I	ARCH	APPD	DATE
CLEARED BY											
		<b>NTPC LTD.</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION									
PROJECT		STANDARD									
TITLE		LIGHTNING PROTECTION DETAILS.									
SIZE	SCALE	DRG. NO.						REV. NO.			
A4	NTS	0000-211-POE-A-047						RC			


This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.




BLOCK SPACING 1000MM CENTRE TO CENTRE

TYPICAL DETAILS OF CLEATING HORIZONTAL CONDUCTOR OVER WATER PROOFING

NOTE.  
1. ALL DIMENSIONS ARE IN mm.


RC	FDR TENDER PURPOSE	A2	M3	R29	-	VY	-	-	-	AS	05/02/20
RB	FDR TENDER PURPOSE	RKG	RKG	VKM	-	SS	-	-	-	AS	05/02/20
RA	FDR TENDER PURPOSE	-	-	-	-	-	-	-	-	-	07/02/20
REV. NO.	DESCRIPTION	DRWN	DESIGN	CHD	M	E	C	C&I	ARCH	APPD	DATE
CLEARED BY											
		<b>NTPC LTD.</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION									
PROJECT		STANDARD									
TITLE		LIGHTNING PROTECTION DETAILS									
SIZE	SCALE	DRG. NO.							REV. NO.		
A4	NTS	0000-211-POE-A-048							RC		

This drawing covers the design of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.





**GENERAL TECHNICAL PARTICULARS**

1. ALL DIMENSIONS ARE IN MM.
2. TYPE: WALL/COLUMN/PEDESTAL MOUNTING TYPE.
3. SHEET: CRCA SHEET min. 2mm THK.
4. GLAND PLATE SHOULD BE OF 3MM THK ALUMINIUM, REMOVABLE TYPE WITH KNOCKOUT HOLE FOR I/G CABLE-1Cx300SQ.MM AL.-6NOS.  
HOLE FOR O/G CABLE-1Cx185SQ.MM AL.-6NOS.
5. PAINT: PRETREATMENT POWDER COATING
6. SHADE: GREY RAL-9002
7. CABLE ENTRY: BOTTOM
8. BUSBAR: ELECTROLYTIC GRADE TINNED CU. OF Min. 40x10MM
9. IP-55
10. BUS BAR INSULATOR-SMC TYPE
11. BUS BAR ARRANGEMENT: HORIZONTAL
12. BUS BAR SHALL HAVE ONE HOLE DRILLED FOR CABLE CONNECTION OF EACH SIZE MENTIONED AT SL.NO 4 AND SUPPLIED WITH CORRESPONDING SIZE HIGH TENSILE STRENGTH ZINC COATED STEEL BOLTS.

RA	FOR TENDER PURPOSE ONLY	VC	VC	RA	W								
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD	M	E	C	C&I	ARCH	APPD	DATE		
					CLEARED BY								
		<p align="center"><b>NTPC LTD.</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION</p>											
PROJECT		STANDARD											
TITLE		ADAPTOR BOX FOR LT CABLES											
SIZE	SCALE	ORG. NO.		REV. NO.									
AL	NTS	0000-211-POE-A-048A		RA									

This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.





**NOTES:**

1. ALL DIMENSIONS ARE IN mm.
2. ROUTE MARKERS SHALL BE CONSTRUCTED OF CONCRETE WITH CAST IRON PLATE, WITH THE ROUTE INFORMATION ENGRAVED ON IT, BOLTED ON TOP OF THE CONCRETE BLOCK AS SHOWN.
3. CAST IRON PLATE SHALL BE OF Min. 6.0mm THICKNESS.

RC	FOR TENDER PURPOSE	13	13	10/10	-	NS	-	-	-	-	AS	05-07-10
RB	FOR TENDER PURPOSE	RKG	RKG	VKM	-	SS	-	-	-	-	AS	10-11-2005
RA	FOR TENDER PURPOSE	-	-	-	-	-	-	-	-	-	-	17-01-2000
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD	M	E	C	C&I	ARCH	APPD	DATE	
CLEARED BY												
		<b>NTPC LTD.</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION										
PROJECT		STANDARD										
TITLE		BURIED CABLE TRENCH DETAILS FOR LIGHTING										
SIZE	SCALE	DRG. NO.								REV. NO.		
A4	NTS	0000-211-POE-A-049								RC		

This drawing and the design it covers are the property of NTPC LTD. and must not be copied, loaned or exhibited either in part or in whole without written permission. Any contravention is liable for prosecution.



DIRECTLY BURIED CABLES  
IN SINGLE LAYER

DIRECTLY BURIED CABLES  
IN TWO LAYER

LEGEND

- ① — CABLE ROUTE MARKER
- ② — EARTH BACK FILLED & RAMMED
- ③ — PROTECTIVE COVERS
  - a) BRICKS FOR LOW VOLTAGE CABLES
  - b) RCC FOR HIGH VOLTAGE CABLES WITH HOLE AT EACH END TO TIE EACH OTHER WITH G.S. WIRE
- ④ — ARMoured POWER CABLE
- ⑤ — ARMoured CONTROL CABLE
- ⑥ — FINE SAND/RIDDED SOIL COMPACTED

DIMENSION MIN.	1100V GRADE CABLES	FOR 3.3 KV TO 11KV	ABOVE 11KV & UPTO 33KV
D1	750	900	1050
S	= d BETWEEN CABLES OF SAME CLASS = 300MM BETWEEN CABLES OF DEFT CLASS = 400MM BETWEEN 1/C POWER CABLE AND COMMUNICATION CABLE. = 300MM BETWEEN MULTICORE POWER CABLE & COMMUNICATION CABLE.		

d - OVERALL DIAMETER OF THE BIGGER OF THE TWO CABLES.  
D1 - MINIMUM DEPTH OF LAYING FROM GROUND SURFACE TO TOP OF CABLES.

NOTE

1. SINGLE CORE CABLES SHALL BE RUN IN TREFOIL FORMATION AND SHALL BE BOUND BY SELFLOCKING CABLE TIES AT EVERY 750 MM.
2. CABLE IDENTIFICATION TAG SHALL BE TIED AT BOTH ENDS OF THE CABLE.
3. IF THE MINIMUM CLEARANCE AS INDICATED THE ABOVE TABLE FOR CABLES OF DIFFERENT CLASSES ARE NOT FEASIBLE BRICK BARRIERS SHALL BE USED BETWEEN ADJACENT CABLES.
4. G.I/HUME/HDPE. PIPES SHALL BE PROVIDED FOR ROAD CROSSING AT A MINIMUM DEPTH OF 600 FROM THE GRADE LEVEL AS DECIDED BY NTPC.
5. ALL DIMENSIONS ARE IN mm

RC	FOR TENDER PURPOSE	1/3	1/3	RJP	-	WV	-	-	-	AS	05/10
RB	FOR TENDER PURPOSE	RKG	RKG	SG	-	SS	-	-	-	AS	28.11.2006
RA	FOR TENDER PURPOSE	-	-	-	-	-	-	-	-	-	17.01.2000
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD	M	E	C	C&I	ARCH	APPD	DATE
CLEARED BY											



**NTPC LTD.**  
( A GOVERNMENT OF INDIA ENTERPRISE )  
ENGINEERING DIVISION

PROJECT				STANDARD			
TITLE				BURIED CABLES TRENCH FOR HT & LT CABLES			
SIZE	SCALE	DRG. NO.					REV. NO.
A4	NTS	0000-211-POE-A-050					RC



985830/2022/PS-PEM-MAX



TITLE:

2X660 MW THDC KHURJA STPP- CW  
SYSTEM CIVIL WORKS

SPECIFICATION NO. PE-TS-492-673-A001

TECHNICAL SPECIFICATION FOR SEWAGE  
TREATMENT PLANT

SECTION -II



SUB SECTION -IIC

REV. NO. 00

DATE :

## SUBSECTION-IIC

### GENERAL TECHNICAL REQUIREMENT (C&I)

CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 
1.00.00	<b>MEASURING INSTRUMENTS (PRIMARY AND SECONDARY)</b>
1.01.00	<p>Measuring instruments/equipment and subsystems offered by the Bidder shall be from reputed experienced manufacturers of specified type and range of equipment, whose guaranteed and trouble free operation has been proven. Refer Sub-section Basic Design Criteria. Further, all instruments shall be of proven reliability, accuracy, and repeatability requiring a minimum of maintenance and shall comply with the acceptable international standards and shall be subject to Employer's approval.</p>
1.02.00	<p>Every panel-mounted instrument requiring power supply shall be provided with easily replaceable glass cartridge fuses of suitable rating. Every instrument shall be provided with a grounding terminal and shall be suitably connected to the panel grounding bus.</p>
1.03.00	<p>All transmitters, sensors, switches and gauges for parameters like pressure, temperature, level, flow etc. as required for the safe and efficient operation and maintenance as well as for operator and management information (including all computation) of equipment in the system under the scope of specification shall be provided on as required basis with in quoted lump sum price. The Contractor shall furnish all Instrumentation / Control equipment &amp; accessories under this specification as per technical specification, ranges, makes &amp; model as approved by the Employer during detailed engineering.</p>
1.04.00	<p>The necessary root valves, impulse piping, drain cocks, gauge-zeroing cocks, valve manifolds and all the other accessories required for mounting/erection of these local instruments shall be furnished, even if not specifically asked for, on as required basis. The contacts of equipment mounted instruments, sensors, switches etc. for external connection including spare contacts shall be wired out in flexible/rigid conduits, independently to suitably located common junction boxes. The proposal shall include the necessary cables, flexible conduits, junction boxes and accessories for the above purpose. Double root valves shall be provided for all pressure tapping where the pressure exceeds 40 Kg./sq.cm.</p>
1.05.00	<p>All instruments envisaged for sea water applications, shall be provided with wetted parts made of Monel/ Hastelloy C or any other material (if provenness experience of the proposed material for such applications is established by contractor).</p> <p>For Chlorine application: Instruments shall be provided with wetted parts (e.g. diaphragm seal, etc.) made of Hastelloy C. Also, filled liquid shall be Fluorolube oil/ Inert Hydrocarbon / CTFE etc., for these applications.</p> <p>For applications of FECL3 solution: Instruments shall be provided with wetted parts (e.g. diaphragm seal, etc.) made of Tantalum.</p>
1.06.00	<p>For coastal areas, all instruments shall be provided with durable epoxy/ polyurethane coating for housings and all exposed surfaces of the instruments.</p>
1.07.00	<p>The instruments which are proposed to be used for PG test as indicated in the tender P&amp;IDs shall meet the minimum requirements specified in ASME PTC or subsequent clauses in this chapter whichever is better.</p>



13.04.00

**ROTAMETERS**

Sr. No.	Features	Essential / minimum requirements
1.	Type	Variable Area Metal Tube
2.	Fluid media	Water/oil
3.	Tube body	SS316
4.	Material of float	316 SS
5.	Indicator	Linear scale
6.	Accessories	Flange, orifice in case of bypass Rota meter (for line size above 100 mm)
7.	Housing protection class	IP-55
8.	Accuracy	$\pm 2\%$ of measured value.



14.00.00



**NOT USED**



15.00.00

**PROCESS ACTUATED SWITCHES**

FEATURES	ESSENTIAL / MINIMUM REQUIREMENTS
----------	----------------------------------

CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 		
	Pressure/ Draft Switches/ DP Switches	Temperature switches	Level switches
Sensing Element	Piston actuated for high pressure and diaphragm or bellows for low pr./ vacuum	Vapor pressure sensing, liquid filled bellow type with SS bulb and capillary (5 m minimum, to suit application)	Capacitance types, float type, conductivity type, RF type, Ultrasonic type as per suitability to the application. .
Material	316 SS	Bulb 316 SS/ capillary 304 SS	316 SS
End connection	½ inch NPT (F)	½ inch NPT (F)	Manufacturer standard
Over range/ proof pressure	150% of maximum operating pr.	-	150% of maximum operating pr.
Repeatability	+/- 0.5% of full range		
No. of contacts	2 No.+2NC. SPDT snap action dry contact		
Rating of contacts	60 V DC, 6 VA (or more if required by DDCMIS)		
Elect. Connection	Plug in socket.		
Set point adjustment	Provided over full range.		
Dead band adjustment	Adjustable/ fixed as per requirement of application.		
Enclosure	Weather and dust proof as per IP-55, metallic housing.		
Accessories	Siphon, snubber, chemical seal, pulsation dampeners as required by process	Thermo well of 316 SS and packing glands	All mounting accessories
Mounting	Suitable for enclosure/ rack mounting or direct mounting	Suitable for rack mounting or direct mounting	-
Power Supply (wherever required)	As per Contractor's Standard practice.		

CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 
	<p>Notes :-</p> <ol style="list-style-type: none"> <li>1) Where the process fluids are corrosive, viscous, solid bearing or slurry type, diaphragm seals shall be provided. Parts below the diaphragm shall be removable for cleaning. The entire volume above the diaphragm shall be completely filled with an inert liquid suitable for the application.</li> <li>2) Pressure/ Diff pressure switches for very low press/ DP measurements can have sensor material other than SS316 in case of any technical limitation and the offered product is standard product of the manufacture for very low pressure applications.</li> <li>3) Repeatability can be upto +/-1% of full range in case of switches with diaphragm seals or very low pressure/DP range.</li> <li>4) The specifications of switches for air conditioning &amp; ventilation system / process can be as per system manufacturer's standards. The manufacturer shall submit the adequate supporting documents for establishing their standard practice.</li> </ol>

CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 																								
21.00.00	<p><b>Limit switches</b></p> <p>Sewage treatment plant(CW &amp; RW) - The limit switches of manual valves and solenoid operated on-off valves shall be of inductive proximity type and shall be mounted inside the enclosure: pl. refer the minimum specification requirement below .</p> <table border="1" data-bbox="411 1431 1410 1798"> <tr> <td>Operating voltage Range</td> <td>10-40 V DC</td> </tr> <tr> <td>Sensing system</td> <td>Inductive Proximity type , 2 Wire</td> </tr> <tr> <td>Sensor Contact Type</td> <td>NO</td> </tr> <tr> <td>Reverse polarity and short circuit protection</td> <td>Yes</td> </tr> <tr> <td>IP Class-Sensor</td> <td>IP67</td> </tr> <tr> <td>IP Class-Enclosure(Switch box)</td> <td>IP67</td> </tr> <tr> <td>Cable entry-Enclosure(Switch box)</td> <td>2no-1/2" NPT</td> </tr> <tr> <td>Casing material-Sensor</td> <td>Brass /SS</td> </tr> <tr> <td>Enclosure(Switch box) Housing material</td> <td>FRP or SS</td> </tr> <tr> <td>Operating Ambient temp(sensors)</td> <td>-5 to 70 deg C</td> </tr> <tr> <td>Max allowed Voltage Drop across sensor</td> <td>5 V</td> </tr> <tr> <td>Standard applicable</td> <td>EN 60947-5-2 or equivalent.</td> </tr> </table>	Operating voltage Range	10-40 V DC	Sensing system	Inductive Proximity type , 2 Wire	Sensor Contact Type	NO	Reverse polarity and short circuit protection	Yes	IP Class-Sensor	IP67	IP Class-Enclosure(Switch box)	IP67	Cable entry-Enclosure(Switch box)	2no-1/2" NPT	Casing material-Sensor	Brass /SS	Enclosure(Switch box) Housing material	FRP or SS	Operating Ambient temp(sensors)	-5 to 70 deg C	Max allowed Voltage Drop across sensor	5 V	Standard applicable	EN 60947-5-2 or equivalent.
Operating voltage Range	10-40 V DC																								
Sensing system	Inductive Proximity type , 2 Wire																								
Sensor Contact Type	NO																								
Reverse polarity and short circuit protection	Yes																								
IP Class-Sensor	IP67																								
IP Class-Enclosure(Switch box)	IP67																								
Cable entry-Enclosure(Switch box)	2no-1/2" NPT																								
Casing material-Sensor	Brass /SS																								
Enclosure(Switch box) Housing material	FRP or SS																								
Operating Ambient temp(sensors)	-5 to 70 deg C																								
Max allowed Voltage Drop across sensor	5 V																								
Standard applicable	EN 60947-5-2 or equivalent.																								
<b>KHURJA SUPER THERMAL POWER PROJECT (2X660 MW) TURBINE GENERATOR AND ASSOCIATED</b>	<b>TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC. NO.: THDC/RKSH/CC-9915- 274</b>	<b>SUB-SECTION-IIIC-04 MEASURING INSTRUMENTS (PRIMARY &amp; SECONDARY)</b>	<b>PAGE 24 OF 30</b>																						

**SPECIFICATIONS FOR PR. GAUGE, D.P. GAUGE, TEMP. GAUGE AND LEVEL GAUGE.**

SI. No	FEATURES	ESSENTIAL/MINIMUM REQUIREMENTS		
		Pr. Gauge/ DP Gauge/ Draught gauges	Temperature Gauge	Level Gauge
1	Sensing Element and material	Bourdon for high pressure, Diaphragm/Bellow for low pr. Of 316 SS	Mercury in steel for below 450°C and inert gas actuated for above 450°C of SS bulb and capillary.	Tempered * toughened Borosilicate gauge glass steel armoured reflex or transparent type.
2	Body material	Die-cast aluminium	Die-cast aluminium	Forged carbon steel/304 SS
3	Dial size	150mm	150 mm	Tubular covering entire range
4	End connection	1/2 inch NPT (M)	3/4" NPT (M)	Process connection as per ASME PTC and drain/vent 15 NB
5	Accuracy	±1% of span	± 1% of span	± 2%
6	Scale	Linear, 270° arc graduated in metric units	Linear, 270° arc graduated in °C	Linear vertical
7	Range selection	Cover 125% of max. of scale	Cover 125% of max. of scale	Cover 125% of max. of scale
8	Over range test	Test pr. for the assembly shall be 1.5 to the max. Design pr. at 38°C.		
9	Housing	Weather and dust proof as per IP-55	Weather and dust proof as per IP-55	CS/304 SS leak proof
10	Zero/span adjustment	Provided	Provided	--
11	Identification	Engraved with service legend or laminated phenolic name plate		

12	Accessories	Blow out disc, siphon, snubber, pulsation dampener, chemical seal (if required by process) gauge isolation valve	SS Thermowell	Gasket for all KEL-F shield for transparent type vent and drain valves of Steel/SS as per CS/Alloy process Requirement.
13	Material of Bourdon/ movement	316 SS / 304 SS	316 SS / 304 SS	

## Notes:-

\*Bicolour type level gauges will be provided for applications involving steam and water except for condensate and feed water services.

Length of gauge glass shall not be more than 1400 mm. If the vessel is higher, multiple gauge glasses with 50 mm overlapping shall be provided.

Where the process fluids are corrosive, viscous, solid bearing or slurry type, diaphragm seals shall be provided. Parts below the diaphragm shall be removable for cleaning. The entire volume above the diaphragm shall be completely filled with an inert liquid suitable for the application.



**10.00.00**

**FIELD MOUNTED LOCAL JUNCTION BOXES**

- (i) No. of ways            12/24/36/48/64/72/96/128 with 20% spares terminals.
- (ii) Material            and    4mm thick Fiberglass Reinforced Polyester (FRP).  
Thickness
- (iii) Type                    Screwed at all four corners for door. Door gasket shall be of synthetic rubber.



- |        |                                 |   |
|--------|---------------------------------|---|
| (iv)   | Mounting clamps and accessories | Suitable for mounting on walls, columns, structures etc. The brackets, bolts, nuts, screws, glands required for erection shall be of SS, included in Bidders scope of supply. |
| (v)    | Type of terminal blocks         | Rail mounted cage-clamp type suitable for conductor size upto 2.5 mm <sup>2</sup> . A M6 earthing stud shall be provided.   |
| (vi)   | Protection Class                | IP: 55 minimum for indoor & IP-65 minimum for outdoor applications.   |
| (vii)  | Grounding                       | To be provided.   |
| (viii) | Color                           | RAL 7035  |

**Note :** For solenoid valve box, the material for the enclosure shall be of steel plate (SS304) with minimum 2 mm thick frame and minimum 2 mm thick steel (SS-304) sheet. Provision of individual isolation for each solenoid shall be provided inside the box. Minimum 100 mm space between the solenoids shall be ensured for ease of access and maintenance. All other specifications shall be as per above.



**Technical specification (C&I) for  
SEWAGE TREATMENT PLANT**

**2X660 MW STPP, KHURJA – TG PACKAGE**



SECTION D

REV. NO. 00


DATE : 13.07.22

**INSTRUMENT STUB DETAILS  
& HOOK-UP**

**PRESS. MEASUREMENT**



**ELEVATION  
STEAM SERVICE  
PRESSURE CONNECTION ON HORIZONTAL PIPE**



\* USE DOUBLE ISOLATION VALVES FOR PRESSURE EQUAL TO OR EXCEEDING 40 Kg/Cm2.

**ELEVATION  
LIQUID OR STEAM SERVICE  
PRESSURE CONNECTIONS ON VERTICAL PIPES**

**FOR TENDER PURPOSE ONLY**



**NTPC LIMITED**  
( A GOVERNMENT OF INDIA ENTERPRISE )  
ENGINEERING DIVISION



PROJECT										TYPICAL THERMAL POWER PROJECT					
TITLE										INSTRUMENT SOURCE CONNECTION DETAILS					
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD.	M	E	C	C&I	ARCH.	APPD.	DATE	SIZE	SCALE	DRG. NO.	REV. NO.
A	FIRST ISSUE											A4	N.T.S.	0000-999-POI-A-035	A
CLEARED BY										T.G.		21.08.12		Sh-1 Of 14	

This document is the property of NATIONAL THERMAL POWER CORPORATION LTD. No part of this document will be reproduced by any means without the written permission.

PRESSURE MEASUREMENT



(SYSTEM PR.>40Kg/Sq Cm CL 9000)

(SYSTEM PR.>40Kg/Sq Cm CL 6000)



(SYSTEM PR. <40Kg/Sq cm Nb 25 CL 3000)

(SYSTEM PR. <40Kg/Sq cm Nb 15 CL 3000)




NOTES:-

1. MATERIAL OF THE BOSS AND NIPPLE SHALL BE THE SAME AS THE PIPE INTO WHICH IT IS WELDED AND CONFIRM TO ANSI B 16.11.
2. THE LENGTH OF THE NIPPLE SHOULD BE 250mm.
3. THE OTHER END OF THE NIPPLE SHALL BE SOCKET WELDED WITH 1" GLOBE VALVE OF MATERIAL AS PER ANSI B 16.1.
4. TWO ISOLATED VALVES ARE TO BE USED FOR PRESSURE = >40 Kg/Cm2.
5. EDGE HOLE MUST BE CLEAN AND SQUARE OR ROUNDED SLIGHTLY (1/64" RADIUS) FREE FROM BURRS, WIRE EDGES OR OTHER IRREGULARITIES.
6. ORIENTATION OF TAP WILL BE VARY WITH TYPE OF PROCESS FLUID AND NATURE OF RUN OF THE PIPE.
7. ACTIVITIES TO BE COMPLETED AT THE SHOP, WELD THE COUPLING (OR BOSS) ON THE PIPE AND DRILL PRESSURE CONNECTION HOLE (SAME AS I D OF NIPPLE) IN THE PIPE IN ALLIGNMENT WITH HOLE IN THE COUPLING.
8. ALL DIMENSIONS ARE IN mm UNLESS OTHERWISE STATED.


FOR TENDER PURPOSE ONLY

This document is the property of NATIONAL THERMAL POWER CORPORATION LTD. No part of this document will be reproduced by any means without the written permission.

										 <b>NTPC LIMITED</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION					
										PROJECT		TYPICAL THERMAL POWER PROJECT			
										TITLE		INSTRUMENT SOURCE CONNECTION DETAILS			
A	FIRST ISSUE								T.G.						
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD.	M	E	C	C&I	ARCH.	APPD.	DATE	SIZE	SCALE	DRG. NO.	REV. NO.
												A4	N.T.S.	0000-999-POI-A-035	A
CLEARED BY												Sh-2 Of 14			

**PRESS. MEASUREMENT**

This document is the property of NATIONAL THERMAL POWER CORPORATION LTD. No part of this document will be reproduced by any means without the written permission.



**NOTES:-**

1. THIS TYPE OF PRESSURE CONNECTOR SHALL BE PROVIDED FOR PRESSURE MEASUREMENTS IN AIR AND FLUE GAS DUCT/FURNACE.
2. DIMENSIONS ARE INDICATIVE ONLY.

**FOR TENDER PURPOSE ONLY**



**NTPC LIMITED**  
( A GOVERNMENT OF INDIA ENTERPRISE )  
ENGINEERING DIVISION


PROJECT **TYPICAL THERMAL POWER PROJECT**

TITLE **INSTRUMENT SOURCE CONNECTION DETAILS**

REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD.	M	E	C	C&I	ARCH.	APPD.	DATE
A	FIRST ISSUE										31.08.12
CLEARED BY											

SIZE	SCALE	DRG. NO.	REV. NO.
A4	N.T.S.	0000-999-POI-A-035	A


TEMP. MEASUREMENT



NOTES:-

1. THIS TYPE OF THERMOWELL INSTALLATION IS SUITABLE FOR THE PROCESS PIPE OF 2" NPS AND SMALLER.
2. FOR STEAM SERVICE THIS TYPE OF THERMOWELL INSTALLATION 90° BEND MAY BE USED ONLY IN VERTICAL PLANE.
3. THE LENGTH OF THE LARGER PIPE SECTION SHALL BE MINIMUM 150mm (IT MUST BE GREATER THAN THERMOWELL LENGTH).


THERMOWELL SUITABLE FOR THE BOSS



NOTES:-


1. INCLINED INSTALLATION OF THERMOWELL SHALL BE APPLICABLE FOR 4" AND SMALLER LINE SIZE BUT LIMITED TO MIN. 3" LINE SIZE.
2. FOR 2" AND SMALLER LINE SIZE NECESSARY EXPANDER OF MIN. 3" SIZE OF MAIN PIPING SPECIFICATION SHALL BE USED.
3. THIS TYPE OF INSTALLATION IS APPLICABLE FOR HORIZONTAL AND VERTICAL PIPE SECTION.
4. FOR STEAM SERVICES EXPANDER SECTION MAY BE USED ONLY IN VERTICAL RUN.
5. THE EXPANDER SECTION SHALL BE OF ADEQUATE LENGTH (ATLEAST 3-4 TIMES DIA OF THE MAIN PROCESS PIPE AT BOTH SIDE OF THE INSTALLED THERMOWELL).

FOR TENDER PURPOSE ONLY

										 <b>NTPC LIMITED</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION							
										PROJECT				TYPICAL THERMAL POWER PROJECT (SG PACKAGE)			
A										TITLE				INSTRUMENT SOURCE CONNECTION DETAILS			
FIRST ISSUE										DRAWN				DESIGN			
DESCRIPTION										CHKD.				M E C			
REV. NO.										C&I				ARCH. APPD. DATE			
Cleared by										SIZE				SCALE			
										A4				N.T.S.			
										DRG. NO.				0000-999/102-POI-A-035			
														REV. NO. A			
														Sh-4 Of 14			

This document is the property of NATIONAL THERMAL POWER CORPORATION LTD. No part of this document will be reproduced by any means without the written permission.

This document is the property of NATIONAL THERMAL POWER CORPORATION LTD. No part of this document will be reproduced by any means without the written permission.




NOTES:-

1. FLOW INSTALLATION OF THERMOWELL SHALL BE APPLICABLE FOR 4" AND SMALLER LINE SIZE BUT LIMITED TO MINIMUM 3" LINE SIZE.
2. FOR 2" AND SMALLER LINE SIZE NECESSARY EXPANDER OF ELBOW FORM (AS SHOWN) OF MINIMUM 3" SIZE SHALL BE USED.
3. ELBOW EXPANDER SECTION IN HORIZONTAL PLANE MAY BE USED FOR LIQUID SERVICES. ONLY STEAM SERVICES EXPANDER SECTION MAY BE USED IN VERTICAL PLAN.

FOR TENDER PURPOSE ONLY

<div style="display: flex; justify-content: space-around; align-items: center;"> <div style="border: 1px solid black; padding: 2px;"> <p style="font-size: small;">एन टी पी सी <b>NTPC</b></p> </div> <div style="text-align: center;"> <p><b>NTPC LIMITED</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION</p> </div> </div>									
PROJECT					TYPICAL THERMAL POWER PROJECT				
TITLE					INSTRUMENT SOURCE CONNECTION DETAILS				
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD.	M	E	C	C&I	ARCH. APPD. DATE
A	FIRST ISSUE							T.G.	21.08.12
Cleared by									
		SIZE		SCALE		DRG. NO.		REV. NO.	
		A4		N.T.S.		0000-999-POI-A-035		A	
Sh-5 Of 14									

This document is the property of NATIONAL THERMAL POWER CORPORATION LTD. No part of this document will be reproduced by any means without the written permission.



**NOTES:-**

1. THIS TYPE OF TEMPERATURE BOSS SHALL BE USED FOR THE PROCESS PRESS EQUAL/ABOVE 40 Kg/Cm2(g).
2. THE MATERIAL OF THE BOSS SHOULD BE SIMILAR TO THAT OF PIPING MATERIAL OF SPECIFICATION.
3. ALL WELD TO BE TESTED IN ACCORDANCE WITH APPLICABLE CODES BY MANUFACTURER.
4. MATERIAL OF THE THERMOWELL SHALL BE OF 316SS.
5. THERMOWELL SHALL BE DRILLED BARSTOCK TYPE.
6. INTERNAL BORE OF THE THERMOWELL SHOULD BE SELECTED BASED ON THE NORMAL SIZE OF THE SENSING ELEMENT AS PER ASME,PTC-19.3.
7. THE BOTTOM DIAMETER OF THE THERMOWELL TYPICALLY SHOWN HERE SHALL BE SUBJECT TO VARIATION BASED ON THE INTERNAL BORE OF THERMOWELL AND THICKNESS OF THERMOWELL MATERIAL TO WITHSTAND THE PROCESS PRESS.AND TEMP.,AS PER ASME,PTC-19.3.
8. THE TYPE OF TAPERED THERMOWELL SHALL BE USED FOR LIQUID VELOCITIES UP TO 92M.P.S.(300F.T.P.S.).
9. THERMOWELL WITH THE INSULATION LAG EXTENSIONS SHALL BE USED WHEREVER APPLICABLE.
10. ACTIVITIES TO BE COMPLETED AT THE SHOP. WELD THE BOSS ON THE PIPE AND DRILL THE HOLE IN THE PIPE IN ALIGNMENT WITH HOLE IN THE BOSS. PROVIDE INTERNAL THREAD AS PER IS:554 TO MATCH WITH THE THERMOWELL EXTERNAL THREAD.
11. ALL DIMENSIONS ARE IN MM UNLESS OTHERWISE STATED.
12. WILL BE SUITABLE TO MATCH THE STUB DIMENSIONS AS PER RC 1 1/2
13. THE "U" & "L" DIMENSIONS SHALL BE SELECTED BASED ON PARTICULAR APPLICATION AND THE SAME SHALL BE SUBJECT TO OWNER'S APPROVAL DURING DETAILED ENGINEERING.
14. ALL DIMENSIONS ARE INDICATIVE ONLY.

**FOR TENDER PURPOSE ONLY**



**NTPC LIMITED**  
( A GOVERNMENT OF INDIA ENTERPRISE )  
ENGINEERING DIVISION


PROJECT **TYPICAL THERMAL POWER PROJECT**

TITLE **INSTRUMENT SOURCE CONNECTION DETAILS**

A	FIRST ISSUE								T.G.	21.08.12	
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD.	M	E	C	C&I	ARCH.	APPD.	DATE

SIZE	SCALE	DRG. NO.	REV. NO.
A4	N.T.S.	0000-999-POI-A-035	A

This document is the property of NATIONAL THERMAL POWER CORPORATION LTD. No part of this document will be reproduced by any means without the written permission.



**NOTES:-**

1. THIS TYPE OF TEMPERATURE BOSS IS APPLICABLE FOR THE PROCESS PRESSURE/TEMPERATURE BELOW 40 Kg/Cm2(g)/400°C
2. FOR PRESSURE TIGHT JOINTS THE BOSS SHOULD HAVE INTERNAL TAPERED PIPE THREAD Rc 1 AS PER IS:554. THE LENGTH OF THREAD ENGAGEMENT SHOULD BE AS PER ABOVE STANDARD.
3. PIPES HAVING PROBABILITY OF PROLONGED VIBRATION SEAL WELDING MAY BE DONE ALL AROUND AFTER TIGHTENING THERMOWELL WITHIN THE BOSS.
4. SEE NOTES-2 TO 14 OF DRG. NO. 0000-999-POI-A-035, Sh-6 Of 14.

FOR TENDER PURPOSE ONLY



**NTPC LIMITED**  
( A GOVERNMENT OF INDIA ENTERPRISE )  
ENGINEERING DIVISION

PROJECT **TYPICAL THERMAL POWER PROJECT**

TITLE **INSTRUMENT SOURCE CONNECTION DETAILS**


REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD.	M	E	C	C&I	ARCH.	APPD.	DATE
A	FIRST ISSUE										21.08.12
CLEARED BY											

SIZE A4	SCALE N.T.S.	DRG. NO. <b>0000-999-POI-A-035</b>	REV. NO. <b>A</b>
------------	-----------------	------------------------------------	----------------------

Sh-7 Of 14

TEMP. MEASUREMENT

This document is the property of NATIONAL THERMAL POWER CORPORATION LTD. No part of this document will be reproduced by any means without the written permission.



NOTES:—

1. THIS TYPE OF TEMPERATURE CONNECTIONS SHALL BE PROVIDED FOR TEMPERATURE MEASUREMENT IN AIR AND FLUE GAS DUCT.
2. MATERIAL OF THERMOWELL SHALL BE OF 316SS.
3. EXTERNAL CONNECTION SHALL BE OF SLIP ON FLANGED TYPE AND THERMOWELL DESIGN SHALL BE AS PER ASME.PTC-19.3 (REFER NOTES 9&10 OF DRG.NO. 0000-999-POI-A-035, Sh-6 Of 14).
4. BIDDER TO SUPPLY AND INSTALL THE COUNTER FLANGED AND THERMOWELL (ALONG WITH TEMP. ELEMENT).
5. ALL DIMENSIONS ARE INDICATIVE ONLY.


FOR TENDER PURPOSE ONLY



**NTPC LIMITED**  
( A GOVERNMENT OF INDIA ENTERPRISE )  
ENGINEERING DIVISION


PROJECT <b>TYPICAL THERMAL POWER PROJECT</b>											
TITLE <b>INSTRUMENT SOURCE CONNECTION DETAILS</b>											
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD.	M	E	C	C&I	ARCH.	APPR.	DATE
A	FIRST ISSUE										T.G. 21.08.12
SIZE <b>A4</b> SCALE <b>N.T.S.</b> DRG. NO. <b>0000-999-POI-A-035</b> REV. NO. <b>A</b>											
Sh-8 Of 14											

**LEVEL MEASUREMENT**



**NOTES:-**


1. THIS TYPE OF PROCESS CONNECTION SHALL BE USED FOR LEVEL GAUGE AND EXTERNAL CAGE TYPE FLOAT OR DISPLACER OPERATED LEVEL SWITCH.
2. FOR GAUGES 3/4" NIPPLE ALONG WITH 3/4" SW SOURCE VALVE AND FOR SWITCHES 1" NIPPLE ALONG WITH 1" SW SOURCE VALVE SHALL BE PROVIDED AS PROCESS CONNECTION.
3. SOURCE CONNECTION ON VESSEL SHOULD NOT BE LOCATED AT PLACES SUBJECTED TO INTERFACE AND TURBULENCE FROM INLETS AND OUTLETS.
4. IF LOWER CONNECTION IS TAKEN FROM BOTTOM OF THE VESSEL THEN THE NIPPLE MUST BE 100 mm TO 150 mm ABOVE THE BOTTOM OF THE VESSEL.



**NOTES:-**

1. THIS TYPE OF PROCESS CONNECTION SHALL BE PROVIDED FOR TANK LEVEL MEASUREMENT OF VISCOUS OR CORROSIVE LIQUID USING FLUSH DIAPHRAGM/WAFER TYPE LEVEL TRANSMITTER.
2. WELDING OF MATCHING FLANGE TO GATE VALVE SHALL BE DONE BY BIDDER.


**FOR TENDER PURPOSE ONLY**

 <b>NTPC LIMITED</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION										
PROJECT					TYPICAL THERMAL POWER PROJECT					
TITLE					INSTRUMENT SOURCE CONNECTION DETAILS					
A	FIRST ISSUE					T.G.			21.08.12	
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD.	M	E	C	C&I	ARCH. APPD. DATE	
Cleared By										
SIZE	SCALE	DRG. NO.	0000-999-POI-A-035				REV. NO.	A		
A4	N.T.S.					Sh-13 of 14				

This document is the property of NATIONAL THERMAL POWER CORPORATION LTD. No part of this document will be reproduced by any means without the written permission.

LEVEL MEASUREMENT

This document is the property of NATIONAL THERMAL POWER CORPORATION LTD. No part of this document will be reproduced by any means without the written permission.




NOTES:-

1. THIS TYPE OF PROCESS CONNECTION SHALL BE USED FOR DISPLACER TYPE LEVEL TRANSMITTER.
2. SOURCE CONNECTION ON VESSEL SHOULD NOT BE LOCATED AT PLACES SUBJECTED TO INTERFACE AND TURBULENCE FROM INLETS AND OUTLETS.
3. IF LOWER CONNECTION IS TAKEN FROM BOTTOM OF THE VESSEL THEN THE NIPPLE MUST BE 100 mm TO 150 mm ABOVE THE BOTTOM OF THE VESSEL.

FOR TENDER PURPOSE ONLY

<b>NTPC LIMITED</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION									
PROJECT					TYPICAL THERMAL POWER PROJECT				
TITLE					INSTRUMENT SOURCE CONNECTION DETAILS				
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD.	M	E	C	C&I	ARCH. APPD. DATE
A	FIRST ISSUE								T.G. 31.08.12
Cleared by									
		SIZE		SCALE		DRG. NO.		REV. NO.	
		A4		N.T.S.		0000-999-POI-A-035		A	
Sh-14 Of 14									

This document is the property of NATIONAL THERMAL POWER CORPORATION LTD. No part of this document will be reproduced by any means without the written permission.



LIST OF MATERIALS	
ITEM NO.	DESCRIPTION
1.	1/2" / 3/4" / 1" NPS SCH 40/80/160/XXS/P91 (AS PER PROCESS REQUIREMENT) NIPPLE OF MATERIAL SAME AS THAT OF MAIN PIPE.
2.	1/2"/3/4"/1" SW GLOBE VALVE/GATE VALVE
3.	3/4" / 1" x 1/2" SW REDUCING INSERT
4.	1/2" / 3/4" PIPE
5.	1/2" / 3/4" SW EQUAL TEE
6.	1/2" / 3/4" SW GLOBE VALVE.
7.	1/2" / 3/4" NPS SW x 1/2" / 3/4" NPT(M) CARBON/ALLOY STEEL NIPPLE.
8.	1/2" / 3/4" NPT(F) CAP.
9.	1/2" / 3/4" PIPE UNION.
10.	6" SS SYPHON
11.	1/2" BLIND 300lbs RF ANSI FLANGE DRILLED AND TAPED FOR 1" NPT PIPE.
12.	SUITABLE ADAPTER.
13.	1/4" CHROME MOLY STEEL TUBE.
14.	
15.	1"/3/4" SW EQUAL TEE.
16.	DIAPHRAGM(WAFER ELEMENT)
17.	ISOLATION VALVE 316 SS,1/4"SW

**NOTES:-**

1. THE MATERIAL SPECIFICATION AND SCHEDULE NO. OF IMPULSE PIPE & NIPPLE AS LISTED HEREIN SHALL BE AS PER TECHNICAL SPECIFICATIONS.
2. THE MATERIAL SPECIFICATION AND RATING OF FITTINGS AS LISTED SHALL BE AS PER SPECIFICATIONS. WELDED/THREADED FITTINGS SHALL CONFIRM TO ANSI-B.16-11.
3. INSTRUMENTS VALVES BODY STEM MATERIAL AND PRESSURE CLASS SHALL BE AS PER TECHNICAL SPECIFICATIONS.
4. FOR BOILER AIR/FLUE GAS SERVICES SOURCE CONNECTIONS IMPULSE PIPING AND ALL FITTINGS SHALL BE OF 3/4" NB SIZE.
5. GAUGES SHALL NOT BE MOUNTED ON THE PIPE. IT WILL BE MOUNTED ON A CHANNEL OR FRAME OR A RACK.
6. \* SLOPE APPROX. 50 MM / METRE.

**FOR TENDER PURPOSE ONLY**



**NTPC LIMITED**  
( A GOVERNMENT OF INDIA ENTERPRISE )  
ENGINEERING DIVISION


PROJECT: **TYPICAL THERMAL POWER PROJECT**

TITLE: **INSTRUMENT INSTALLATION DIAGRAM (FOR PRESSURE GAUGE)**

A	FIRST ISSUE								T.G.		21.08.12
REV.NO.	DESCRIPTION	DRAWN	DESIGN	CHKD.	M	E	C	C&I	ARCH.	APPD	DATE
		CLEARED BY									


SIZE	SCALE	DRG. NO.	REV. NO.
A3	N.T.S.	0000-999-POI-A-022	A

This document is the property of NATIONAL THERMAL POWER CORPORATION LTD. No part of this document will be reproduced by any means without the written permission.



TRANSMITTER MOUNTED BELOW INSTRUMENT SOURCE POINT      TRANSMITTER MOUNTED ABOVE INSTRUMENT SOURCE POINT

LIQUID PRESSURE MEASUREMENT




TRANSMITTER MOUNTED BELOW INSTRUMENT SOURCE POINT      TRANSMITTER MOUNTED ABOVE INSTRUMENT SOURCE POINT

STEAM PRESSURE MEASUREMENT

LIST OF MATERIALS

ITEM NO.	DESCRIPTION
1.	1/2" / 3/4" / 1" NPS SCH. 80/160/XXXS/PS1 NIPPLE OF MATERIAL SAME AS THAT OF MAIN PIPE.
2.	3/4" / 1" SW GLOBE VALVE
3.	3/4" / 1" TO 1/2" REDUCING INSERT
4.	1/2" NPS PIPE
5.	1/2" SW EQUAL TEE
6.	1/2" SW GLOBE VALVE
7.	1/2" NPS SCH. 80/160 SWx1/2" CS/AS COUPLER
8.	1/2" PIPE UNION
9.	2/3 VALVE MANIFOLD (FOR DETAIL SEE DRAWING NO.0000-102-POI-A-023.
10.	SUITABLE ADAPTER
11.	SS TUBE
12.	1/2" PIPE x 1/2" TUBE UNION
13.	1/2" NPS SCH. 80/160 SWx1/2" NPT(M) CS/AS NIPPLE



VACUUM PRESSURE MEASUREMENT


NOTES:-  
 1. SAME NOTES UNDER DRG. NO. 0000-999-POI-A-023.  
 2. FOR VACUUM APPLICATION OTHER PORT OF TRANSMITTER SHALL BE KEPT OPEN TO ATMOSPHERE.

**FOR TENDER PURPOSE ONLY**

		<b>NTPC LIMITED</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION	
PROJECT		TYPICAL THERMAL POWER PROJECT	
TITLE		INSTRUMENT INSTALLATION DIAGRAM (PRESSURE MEASUREMENT USING PRESS /DP TRANSMITTERS STEAM/LIQUID VACUUM)	
REV. NO.	DESCRIPTION	SIZE	SCALE
A	FIRST ISSUE	A3	N.T.S.
DATE	21.08.12	DRG. NO.	0000-999-POI-A-025
REV. NO.	A		

REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD.	M	E	C	C&I	ARCH.	APPD	DATE
A	FIRST ISSUE										21.08.12
CLEARED BY: _____											

This document is the property of NATIONAL THERMAL POWER CORPORATION, LTD. No part of this document will be reproduced by any means without the written permission.



LIST OF MATERIALS	
ITEM NO.	DESCRIPTION
1.	42x2 TO 3/4" SW REDUCING INSERT.
2.	3/4" SW GLOBE VALVE.
3.	1/2" SW GLOBE VALVE FOR LIQUID APPLICATION & 3/4"/1" IN GAS/AIR APPLICATION
4.	1/2" NPS 40/80/160 (AS PER PROCESS REQUIREMENT) CARBON/ALLOY STEEL PIPE.
5.	1/2" SW EQUAL TEE.
6.	1/2" NPS SW x 1/2" NPT (M) NIPPLE.
7.	1/2" NPT (F) CAP.
8.	1/2" PIPE x 1/2" PIPE UNION.
9.	5 VALVE MANIFOLD (FOR DETAIL REFER DRAWING NO.0000-999-POI-A-026.
10.	3/4" SCH 80 CARBON/ALLOY STEEL PIPE.
11.	3/4"/1/2" SW EQUAL TEE.
12.	3/4"x1/2" TUBE UNION.
13.	1/2" SCREWED GLOBE VALVE.
14.	1/2" NPT (M) PLUG.
15.	3/4" SW GATE VALVE.
16.	3/4" SW EQUAL CROSS.
17.	WAFER ELEMENT FOR USE WITH 3"ANSI R.F. VALVE.
18.	3"BLIND 300lbs R.F. WELD NECK FLANGE DRILLED FOR 1" SCH. 40/80 PIPE.
19.	3" BLIND FLANGE.
20.	1"NPS SCH. 40/80 (AS PER PROCESS REQUIREMENT) CS PIPE.
21.	1" SW EQUAL TEE.
22.	3/4" x 1/2"SW REDUCING INSERT.
23.	3/4" SW x 3/4" NPT (M) CS/AS NIPPLE
24.	3/4" NPT (F) CS/AS CAP.
25.	1/4" NPS ALLOY STEEL PIPE.
26.	1" x 3/4" SW REDUCING INSERT.
27.	3/4" SW x 1/2" PSW BRANCH TEE.
28.	3/4" PIPE UNION
29.	1/2" CLAMP UNION (THREADED) SUITABLE FOR FLEXIBLE CONNECTION OF NYLON REINFORCED PVC TUBE.
30.	SS TUBE
31.	3/4" SW 4 WAY VALVE.
32.	QUICK DISCONNECT FITTINGS.
33.	1/4" SW ISOLATION VALVE 316SS.
34.	1/2" x 1/2" SS PIPE UNION.



NOTES:-  
1. SAME NOTES AS UNDER DRG. NO. 0000-999-POI-A-023.  
**FOR TENDER PURPOSE ONLY**

एन टी पी सी  
**NTPC**



**N T P C LIMITED**  
( A GOVERNMENT OF INDIA ENTERPRISE )  
ENGINEERING DIVISION

PROJECT <b>TYPICAL THERMAL POWER PROJECT</b>															
TITLE <b>INSTRUMENT INSTALLATION DIAGRAM</b>															
DIFF. PRESS. MEASUREMENT (LIQUID, OIL, AIR/GAS SERVICE)															
A	FIRST ISSUE								T.G.	21.08.12					
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD.	M	E	C	C&I	ARCH.	APPD	DATE	SIZE	SCALE	DRG. NO.	REV. NO.
												A3	H.T.S.	0000-999-POI-A-030	A
CLEARED BY															

This document is the property of NATIONAL THERMAL POWER CORPORATION LTD. No part of this document will be reproduced by any means without the written permission.



LIST OF MATERIALS	
ITEM NO.	DESCRIPTION
1.	3/4" x 1" NPS SCH.40/80/160/PP91 (AS PER PROCESS REQUIREMENT) CARBON /ALLOY STEEL PIPE.
2.	3/4" SW GLOBE VALVE.
3.	3/4" SW UNION.
4.	3/4" NPT GLOBE VALVE.
5.	3/4" NPT (M) CAP.
6.	3/4" NPT (F) UNION CONNECTION.
7.	1" SW EQUAL UNION.
8.	1" x 1/2" SW REDUCING INSERT.
9.	1" SW EQUAL TEE.
10.	1/2" SW GLOBE VALVE.
11.	1/2" NPS SWx1/2" NPT(M) CS/AS NIPPLE.
12.	1/2" NPT (F) CAP
13.	3/4"x1/2" NPS SCH.40/80 CS/AS PIPE.
14.	1/2" NPS SCH.80/160 CS/AS NIPPLE.
15.	1" SW GLOBE VALVE.




- NOTES:-**
- FOR LEVEL GAUGE 3/4" AND FOR LEVEL SWITCH 1" PROCESS CONNECTION SHALL BE PROVIDED.
  - NOTES UNDER DRG. NO. 0000-999-POI-A-023 (WHICHEVER ARE RELEVANT).

**FOR TENDER PURPOSE ONLY**

<b>NTPC LIMITED</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION		PROJECT		TYPICAL THERMAL POWER PROJECT	
		TITLE		INSTRUMENT INSTALLATION DIAGRAM (LEVEL GAUGE & SWITCHES)	
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD.	DATE
A	FIRST ISSUE				21.08.12
SIZE	SCALE	DRG. NO.	REV. NO.		
A3	N.T.S.	0000-999-POI-A-031	A		

This document is the property of NATIONAL THERMAL POWER CORPORATION LTD. No part of this document will be reproduced by any means without the written permission.



**LIST OF MATERIALS**

ITEM NO.	DESCRIPTION
1.	1" NPS SCH.40/80/160/XXS/P91 (AS PER PROCESS REQUIREMENT) CARBON /ALLOY STEEL PIPE.
2.	1" SW GLOBE VALVE.
3.	3/4"/1" TO 1/2" REDUCING INSERT.
4.	1/2" NPS SCH.80/160/XXS(AS PER PROCESS REQ.)CS/AS PIPE.
5.	1/2" SW EQUAL TEE.
6.	1/2" SW GLOBE VALVE.
7.	1/2" NPS SWx1/2" NPT(M) CS/AS NIPPLE.
8.	1/2" NPT (F) CAP.
9.	1/2" PIPE UNION.
10.	5-VALVE MANIFOLD (FOR DETAILS REF. DRG. NO.0000-999-POI-A-026.
11.	SUITABLE ADAPTER.
12.	1/2" PIPE x 1/2" TUBE UNION.
13.	S.S. TUBE.

**NOTES:-**

- 1. SAME NOTES AS UNDER DRG. NO.0000-999-POI-A-023. (WHICHEVER ARE RELEVANT).
- \* TO DRAIN HEADER IN LIE/LIR.

**FOR TENDER PURPOSE ONLY**

**TRANSMITTER MOUNTED BELOW INSTRUMENT SOURCE POINT**

**TRANSMITTER MOUNTED ABOVE INSTRUMENT SOURCE POINT**

**LEVEL MEASUREMENT OF CLEAR NON-VISCOUS OR NON-CORROSIVE LIQUID IN CLOSED VESSEL WITH CONDENSABLE ATMOSPHERE USING D/P TRANSMITTER**

CLIENT	<b>THDC INDIA LIMITED</b> ( A JOINT VENTURE OF GOVT. OF INDIA & GOVT. OF UP )														
CONSULTANT	<b>NTPC LIMITED</b> ( A GOVERNMENT OF INDIA ENTERPRISE ) ENGINEERING DIVISION														
PROJECT	TYPICAL THERMAL POWER PROJECT														
TITLE	INSTRUMENT INSTALLATION DIAGRAM (LEVEL MEASUREMENT USING D/P TRANSMITTERS)														
REV. NO.	DESCRIPTION	DRAWN	DESIGN	CHKD.	M	E	C	C&I	ARCH.	APPD	DATE	SIZE	SCALE	DRG. NO.	REV. NO.
A	FIRST ISSUE										26.04.06	A3	N.T.S.	0000-110-POI-A-032	A
CLEARED BY												SH 1 OF 2			



**Technical specification (C&I) for  
SEWAGE TREATMENT PLANT**



**2X660 MW STPP, KHURJA – TG PACKAGE**

SECTION D

REV. NO. 00

DATE : 13.07.22

# TYPE TEST REQUIREMENT

CLAUSE NO.	 <b>TECHNICAL REQUIREMENTS</b> 
<b>1.00.00</b>	<b>TYPE TEST REQUIREMENTS</b>
1.01.00	General Requirements
1.01.01	<p>The Contractor shall furnish the type test reports of all type tests as per relevant standards and codes as well as other specific tests indicated in this specification. If the bidder proposes a different standard/code from that indicated at table 3.00.00, same is acceptable provided the equivalence of the proposed standard is established by the bidder. A list of such tests are given for various equipment in table titled 'TYPE TEST REQUIREMENT FOR C&amp;I SYSTEMS' at the end of this chapter and under the item Special Requirement for Solid State Equipments/Systems. For the balance equipment instrument, type tests may be conducted as per manufactures standard or if required by relevant standard.</p> <p>(a) Out of the tests listed, the Bidder/ sub-vendor/ manufacturer is required to conduct certain type tests specifically for this contract (and witnessed by Employer or his authorized representative) even if the same had been conducted earlier, as clearly indicated subsequently against such tests.</p> <p>(b) For the rest, submission of type test results and certificate shall be acceptable provided.</p> <ol style="list-style-type: none"> <li>i. The same has been carried out by the Bidder/ sub-vendor on exactly the same model /rating of equipment.</li> <li>ii. There has been no change in the components from the offered equipment &amp; tested equipment.</li> <li>iii. The test has been carried out as per the latest standards alongwith amendments as on the date of Bid opening.</li> </ol> <p>(c) In case the approved equipment is different from the one on which the type test had been conducted earlier or any of the above grounds, then the tests have to be repeated and the cost of such tests shall be borne by the Bidder/ sub-vendor within the quoted price and no extra cost will be payable by the Employer on this account.</p>
1.01.02	As mentioned against certain items, the test certificates for some of the items shall be reviewed and approved by the main Bidder or his authorized representative and the balance have to be approved by the Employer.
1.01.03	The schedule of conduction of type tests/ submission of reports shall be submitted and finalized during pre-award discussion.
1.01.04	For the type tests to be conducted, Contractor shall submit detailed test procedure for approval by Employer. This shall clearly specify test setup, instruments to be used, procedure, acceptance norms (wherever applicable), recording of different parameters, interval of recording precautions to be taken etc. for the tests to be carried out.
1.01.05	The Bidder shall indicate in the relevant BPS schedule, the cost of the type test for each item only for which type tests are to be conducted specifically for this project. The cost shall only be payable after conduction of the respective type test in presence of authorize representative of Employer. If a test is waived off, then the cost shall not be payable.



## TECHNICAL REQUIREMENTS



2.00.00

### SPECIAL REQUIREMENT FOR SOLID STATE EQUIPMENTS/ SYSTEMS

2.01.00

The minimum type test reports, over and above the requirements of above clause, which are to be submitted for each of the major C&I systems shall be as indicated below:

- i) Surge Withstand Capability ( SWC) for Solid State Equipments/ Systems

All solid state systems/ equipments shall be able to withstand the electrical noise and surges as encountered in actual service conditions and inherent in a power plant. All the solid state systems/ equipments shall be provided with all required protections that needs the surge withstand capability as defined in ANSI 37.90.1/ IEEE-472. Hence, all front end cards which receive external signals like Analog input & output modules, Binary input & output modules etc. including power supply, data highway, data links shall be provided with protections that meets the surge withstand capability as defined in ANSI 37.90.1/ IEEE-472. Complete details of the features incorporated in electronics systems to meet this requirement, the relevant tests carried out, the test certificates etc. shall be submitted along with the proposal. As an alternative to above, suitable class of EN 61000-4-12 which is equivalent to ANSI 37.90.1/ IEEE-472 may also be adopted for SWC test.

- ii) Dry Heat test as per IEC-68-2-2 or equivalent.  
 iii) Damp Heat test as per IEC-68-2-3 or equivalent.  
 iv) Vibration test as per IEC-68-2-6 or equivalent.  
 v) Electrostatic discharge tests as per EN 61000-4-2 or equivalent.  
 vi) Radio frequency immunity test as per EN 61000-4-6 or equivalent.  
 vii) Electromagnetic Field immunity as per EN 61000-4-3 or equivalent.

Test listed at item no. v, vi, vii, above are applicable for electronic cards only as defined under item (i) above.



## TECHNICAL REQUIREMENTS



3.00.00

## TYPE TEST REQUIREMENT FOR C&amp;I SYSTEMS

Sl. No	Item	Test Requirement	Standard	Test To Be Specifically Conducted	NTPC's Approval Req. On Test Certificate
Col 1	Col 2	Col 3	Col 4	Col 5	Col 6
1	Elect. Metering instruments	As per standard (col 4)	IS-1248	No	No
2	Transducers	As per standard (col 4)	IEC-60688, IS12784	No	No
3	Thermocouple	Degree of protection test	IS-13947	No	No
4	RTD	As per standard (col 4)	IEC-60751	No	No
5	Electronic transmitter	As per standard (col 4)	BS-6447 / IEC-60770	No	No
6	E/P converter	As per standard (col 4)	Mfr. standard	No	No
7	Dust emission monitor	Degree of protection test	IS-13947	No	No
8	Instrumentation Cables Twisted & Shielded*				
	-Conductor	Resistance test	VDE-0815	No	No
		Diameter test	IS-10810	No	No
		Tin Coating test (Persulphate test)	IS-8130	No	No
	-Insulation	Loss of mass	VDE 0472	No	No
		Ageing in air ovens**	VDE 0472	No	No
		Tensile strength and	VDE 0472	No	No



## TECHNICAL REQUIREMENTS



		elongation test before and after ageing**				
		Heat shock	VDE 0472	No		No
		Hot deformation	VDE 0472	No		No
		Shrinkage	VDE 0472	No		No
		Bleeding & blooming	IS-10810	No		No
	-Inner sheath***	Loss of mass	VDE 0472	No		No
		Heat shock	VDE 0472	No		No
		Cold bend/cold impact test	VDE 0472	No		No
		Hot deformation	VDE 0472	No		No
		Shrinkage	VDE 0472	No		No
	-Outer sheath	Loss of mass	VDE 0472	No		No
		Ageing in air ovens**	VDE 0472	No		No
		Tensile strength and elongation test before and after ageing**	VDE 0472	No		No
		Heat shock	VDE 0472	No		No
		Hot deformation	VDE 0472	No		No
		Shrinkage	VDE 0472	No		No
		Bleeding & blooming	IS-10810	No		No
		Colour fastness to water	IS-5831	No		No
		Cold bend/cold impact test	VDE-0472	No		No



## TECHNICAL REQUIREMENTS



	Oxygen index test	ASTMD-2863	No	No
	Smoke Density Test	ASTMD-2843	No	No
	Acid gas generation test	IEC-60754-1	No	No
-fillers	Oxygen index test	ASTMD-2863	No	No
	Acid gas generation test	IEC-60754-1	No	No
-AL-MYLAR shield	Continuity test		No	No
	Shield thickness		No	No
	Overlap test		No	No
-Over all cable	Flammability Test	IEEE 383	No	No
	Swedish Chimney Test	SEN 4241475	No	No
	Noise interference	IEEE Trans-actions	No	No
	Dimensional checks	IS 10810	No	No
	Cross talk	VDE-0472	No	No
	Mutual capacitance	VDE-0472	No	No
	HV test	VDE-0815	No	No
	Drain wire continuity		No	No



## TECHNICAL REQUIREMENTS



\* 1.0 All cables to be supplied shall be of type tested quality. The Contractor shall submit for Owner's approval the reports of all the type tests as listed in this specification and carried out within last Ten years from the date of bid opening. These reports should be for the tests conducted on the equipment similar to those proposed to be supplied under this contract and the test(s) should have been either conducted at an independent laboratory or should have been witnessed by a client.

2.0 In case the Contractor is not able to submit report of the type test(s) conducted within last Ten years from the date of bid opening, or in case the type test report(s) are not found to be meeting the specification requirements, the Contractor shall conduct all such tests either in an independent laboratory or at manufacturer's works in presence of Owner's representative under this contract free of cost to the Owner and submit the reports for approval.

\*\*These tests shall be carried out as per VDE0207 Part 6 & ASTM D-2116 for TEFLON insulated & outer sheathed cables

\*\*\*Applicable for armoured cables only

### 9 DC Power Supply System (Applicable for each model and rating)

1)The Type Test reports for offered rectifier module and the controller module irrespective of the rectifier bank shall be acceptable

Surge Withstand Capability(SWC)	ANSI 37.90.1, No IEEE-472,EN 61000-4-12	No
Dry Heat Test	IEC-68-2-2 or equivalent	No
Damp Heat test	IEC-68-2-3 or equivalent	No
Vibration test	IEC68-2-6 or equivalent	No
Electrostatic discharge test	EN 61000-4-2 or equivalent	No
Radio frequency immunity test	EN-61000-4-3 or equivalent	No
Electromagnetic field immunity	EN 61000-4-3 or equivalent	No
Degree of Protection	IS-13947 or equivalent	No



## TECHNICAL REQUIREMENTS



	10	Battery ##	As per standard (col 4)	IS-10918 (Ni-Cd Batteries)	No	No
				IS-1652 (Lead Acid Plante Batteries)	No	No
	11	NOT APPLICABLE				
	13	Voltage Stabilisers	Over Load Test	Approved procedure	No	No



## TECHNICAL REQUIREMENTS



			Temp rise test without redundant fans	Approved procedure	No	No
15	LIE / LIR		Degree of protection test	of IS-13947	No	No
16	Flue analyzers	gas	Degree of protection test	of IS-13947	No	No
17	Master Clock		Functional test	As per approved procedure	No	No
18	CJC Box		Degree of protection test	Of IS-13947	No	No
19	Junction Box		Degree of protection Test	Of IS-13947	No	No
20	OPC Access Server, Data Exchange Server & Historical Data Access Server	Data Server	OPC Compliance Testing		No	No (Self certification is also acceptable)
21	Conductivity Type Switch	Level	Degree of protection test	of IS-2147	No	No
22	Local Gauges		Degree of protection test	of IS-2147	No	No
23	Process actuated Switches		Degree of protection test	of IS-2147	No	No
24	Control Valves		CV test	ISA 75.02 & 75.11	No	No



## TECHNICAL REQUIREMENTS



4)

26	Flow Orifice Venturi	Nozzle plates,	Calibration	ASME PTC BS 1042	No	No
----	----------------------------	-------------------	-------------	---------------------	----	----

## The contractor shall submit for Employers approval the reports of all the type test as per latest IS-10918 carried out within last ten years from the date of Bid opening and the test(s) should have been either conducted at an independent laboratory or in presence / owners representative. The complete type test reports shall be for any rating of Battery in a particular group based on plate dimensions being manufactured by supplier.

**Note:**

Type Tests are to be conducted only for the items, which are being supplied as a part of this Package.

985836/2022/PS-PEN-MAX



TITLE:

2X660 MW THDC KHURJA STPP- CW  
SYSTEM CIVIL WORKS

SPECIFICATION NO. PE-TS-492-673-A001

TECHNICAL SPECIFICATION FOR SEWAGE  
TREATMENT PLANT

SECTION -III

SUB SECTION

REV. NO. 00

DATE :

## SECTION – III

985836/2022/PS-PEM-MAX



<b>2X660 MW THDC KHURJA STPP- CW SYSTEM CIVIL WORKS</b>	SPECIFICATION NO. PE-TS-492-673-A001	
	SECTION -III	SUB SECTION
<b>TECHNICAL SPECIFICATION FOR SEWAGE TREATMENT PLANT</b>	REV. NO. 00	DATE :


### LIST OF DOCUMENTS TO BE SUBMITTED ALONG WITH BID

#### 1.0 Bidder to furnish following documents/information along with the bid

- Deviation if any strictly in the enclosed Schedule of deviation with cost of withdrawal only with mention of specification clause for which deviation is being asked. (Stamped & Signed). In case of No Technical Deviation, bidder to furnish the same format stating "No Deviation" duly Stamped & Signed.
- Compliance certificate. (Stamped & Signed)
- Schedule of Declaration. (Stamped & Signed)
- Un Price Schedule duly filled in. (Stamped & Signed)

Any other documents submitted by bidder except as asked in the bid's specification shall not be evaluated & considered as null & void.

985836/2022/PS-PEM-MAX


	<b>FILE:</b> <b>2X660 MW THDC KHURJA STPP- CW</b> <b>SYSTEM CIVIL WORKS</b>	SPECIFICATION NO. PE-TS-492-673-A001	
	<b>TECHNICAL SPECIFICATION FOR SEWAGE</b> <b>TREATMENT PLANT</b>	SECTION -III	SUB SECTION
		REV. NO. 00	DATE :

### COMPLIANCE CUM CONFIRMATION CERTIFICATE

The bidder shall confirm compliance with following by signing/ stamping this compliance certificate and furnishing same with the offer:

1. The scope of supply, technical details, construction features, design parameters etc. shall be as per technical specification & there are no exclusions/ deviations with regard to same.
2. QP/ test procedures shall be submitted in the event of order based on the guidelines given in the specification & QP enclosed therein.
3. QP will be subject to BHEL/Customer approval in the event of order & customer hold points for inspection/ testing shall be marked in the QP at the contract stage. Inspection/ testing shall be witnessed as per same apart from review of various test certificates/ Inspection records etc. The charges for 3rd party inspection (Lloyds, TUV or equivalent) for imported components shall be included in the base price of the equipment by the bidder.
4. All drawings/data – sheets etc. to be submitted during contract shall be subject to BHEL/Customer review/ approval. GA drawings, as submitted with offer at tender stage are for reference purpose only and shall be subject to approval during contract stage.
5. There are no other deviations with respect to specification other than those furnished in the 'Schedule of Deviations'.
6. The offered materials shall be either equivalent or superior to those specified. Also for components where material is not specified it shall be suitable for intended duty, materials shall be subject to approval in the event of order.
7. The commissioning spares (if any) are supplied on 'As Required Basis' & prices for same included in the base price (If bidders reply to this is "No commissioning spares are required" and if some spares are actually required during commissioning same shall be supplied by bidder without any cost to BHEL and Customer).
8. All sub vendors shall be subject to BHEL/CUSTOMER approval.
9. Any special tools & tackles, if required, shall be in bidder's scope.
10. Performance guarantee test parameters shall stand valid till the satisfactory completion of Performance guarantee test and its acceptance by BHEL and Customer.

985836/2022/PS-PEN-MAX



**FILE:**  
**2X660 MW THDC KHURJA STPP- CW**  
**SYSTEM CIVIL WORKS**  
**TECHNICAL SPECIFICATION FOR SEWAGE**  
**TREATMENT PLANT**

SPECIFICATION NO. PE-TS-492-673-A001  
 SECTION -III  
 SUB SECTION  
 REV. NO. 00  
 DATE :

**PRE BID CLARIFICATION SCHEDULE**

All clarification from the Technical Specification shall be filled in by the BIDDER clause by clause in this format only.

VOLUME	SECTION	CLAUSE NO.	PAGE NO.	SPECIFICATION REQUIREMENT	CLARIFICATION	REASONS FOR CLARIFICATION

PARTICULARS OF BIDDER / AUTHORISED REPRESENTATIVE				
NAME	DESIGNATION	SIGNATURE	DATE	COMPANY SEAL



<b>FILE:</b> <b>2X660 MW THDC KHURJA STPP- CW</b> <b>SYSTEM CIVIL WORKS</b>		SPECIFICATION NO. PE-TS-492-673-A001	
<b>TECHNICAL SPECIFICATION FOR SEWAGE</b> <b>TREATMENT PLANT</b>		SECTION -III	SUB SECTION
		REV. NO. 00	DATE :

**SCHEDULE OF DECLARATION**

I .....certify that all the technical data and information pertaining to this specification are correct and are true representation of the equipment/system covered by our format proposal number Dated ..... and there is no deviation to the specification.

I hereby certify that I am duly authorized representative of the Bidder's company whose name appears above my signature.

Bidders Company Name .....

Authorized Representative's Signature .....

Name .....

Bidder's Name .....

The bidder hereby agrees to fully comply with the requirements and intent of this specification for the price indicated.

