

	PROJECT: 5X800 MW YADADRI TPS PRE-QUALIFICATION REQUIREMENT- AIR CONDITIONING SYSTEM.	PE-PQ-417-553-A001	
		DATE	03.02.2021
		REV NO	00

1.0	The Bidder should have designed, supplied, erected and commissioned at least one (1) number of Air conditioning system having a total installed capacity of 300TR or more, which included at least one chilling unit with a minimum capacity of 60TR. The system have been in successful operation for at least one (1) year as on date of techno commercial bid opening
2.0	The supplier has to submit following supporting documents meeting above mentioned pre-qualifying requirement Copy of minimum one (1) performance certificate (in English) from end user along with copy of related Purchase Order (PO) or Letter of intent (LOI) or Letter of Award (LOA) or Work Order (WO) in support of PQR clause at S.No.1.0 above.
3.0	Bidder shall submit design documents to substantiate technical parameters specified in PQR, if the same is not mentioned in performance certificate/purchase order.
4.0	Minimum one (1) no. Purchase order shall be submitted which should not be more than seven (7) years old, for establishing continuity in business. This is over and above the requirement of PO mentioned of PQR clause at S. No. 2.0 above.
5.0	Bidder to submit all supporting documents in English. If documents submitted by bidder are in language other than English, a self-attested English translated document should also be submitted.
6.0	Notwithstanding anything stated above, BHEL reserves the right to assess the capabilities and capacity of the bidder to perform the contract, should the circumstances warrant such assessment in the overall interest of BHEL.
7.0	Consideration of offer shall be subject to customer's approval of bidders, if applicable.
8.0	After satisfactory fulfilment of all the above criteria/ requirement, offer shall be considered for further evaluation as per NIT and all the other terms of the tender.