

PQC for PR-0148223031 dated 04.06.2026

Sl.No.	Particulars	Vendor confirmation
1	The vendor should be OEM of this item or authorised dealer / authorised channel partner subject to submission of OEM authorisation and price justification	



**SURESH RAJAN**  
ENGINEER  
PLS (M&E, ELECT & INST)  
SSTP, BHEL  
TRICHY - 620 014

TDC for PR-0148223031 dated 04.06.2026			
PR Item No			Vendor Confirmation
10	Short Description	FLAME RELAY (BURNER SEQUENCE CONTROLLER)	
	Technical Parameters		
	SUPPLY VOLTAGE :	230 VOLTS	
	OPERATING TEMP. :	60 DEG. C (MAXIMUM)	
	PROTECTION CLASS :	IP:54	
	MODEL NO. :	ESTRO-C	
	FLAME CONTROLLING DEVICE :	UV-2 PHOTO TUBE	
	MODELNO.:	ESTRO C2 A-01-10-03-CK-2-/00R-CBBB-0//3-04E- OR <b>successor version ALBEN BC S C//2////////-485ET////////</b>	
MAKE :	ESA PYRONICS (CRESCENT COMBUSTION)		


**SURESH RAJAN**  
 ENGINEER  
 PLS (ELECT & INST)  
 SSTP, BHEL  
 TRICHY - 620 014