

Ash Handling System – Retrofitting of ESP of GSECL Wanakbori TPS Units 4, 5 & 6 (3X210 MW)

Corrigendum to the Technical Specification Ref No: IS-1-19-2019/001

Date: 07th December, 2019

Tender Ref: _____

Bidder to note the following revision in the specification –

Technical specification clause number	Description	Shall be read as -
Clause No. 03.01.09, page no. 5 of 14	“Bidder shall ensure the functionality [wet & dry mode] in the new first field of the ESP as listed in clause no. 02.05.00 of this specification & consider equipment accordingly.”	“Bidder shall ensure the functionality [wet & dry mode] in the new first field of the ESP as listed in clause no. 02.05.00 of this specification & consider equipment accordingly. The fly ash system for the modified ESP shall be able to evacuate the total fly ash generated in one [1] shift in four [4] hours.”
