

Technical Specification

Industrial Pedestal Fan

The Fan should have the following specification:

- 1. Motor Rating: TEFC 3-Phase, 2HP, 1440RPM, 415V, 50HZ, Squirrel Cage Induction Motor complete with DOL starter.
- 2. Impeller: Die Cast Aluminum impeller, Sweep 750 MM approximate.
- 3. Duty Cycle: Continuous duty.
- 4. The air should be adjustable in vertical and horizontal plane by providing tilting head head arrangement. It should be possible with easy turning off knob.
- 5. Fan Guard: To be provided on both sides of fan, chrome plated.
- 6. Mounting Provision: The fan should be mounted on a heavy base and steel supporting column.

Viewed
29/4
Newman
29/4/13
AGM (Shop Tech.)

(VISHAL VERMA)
MGR. LITG/RM

(R. SINGH)
29/4/13
MGR. Shop Tech. RL-1

(W. J. S. Purty)
02.05.2013
S. Mgr (WEX-PLG)

(Nitya Mond)
03/05/2013
AGM/WEX-PLG