

परियोजना इंजीनियरिंग
प्रबंधन
Project Engineering
Management

भारत हेवी इलेक्ट्रिकल्स लिमिटेड
(भारत सरकार का उपक्रम)
Bharat Heavy Electricals Limited
(A Govt. of India Undertaking)

PROJECT: -2X660 MW ENNORE STPP.
PACKAGE:- Distribution Boards
ENQUIRY NO.: E-5947/2018 Dtd. 18.05.2018

Date: 04/06/2018


CORRIGENDUM-02

Ref: 1. BHEL Tender Enquiry No.:-E-5947/2018 Dtd. 18.05.2018

Subject: Due date extension

Due to change in Technical specification clause number 3.7(b.7) page 06 of 16 the last date of submission is extended by 7 days. The change in specification is mentioned in the attachment. Bidders have to note that the due date of submission is extended from existing date 05/06/2018,2:00 PM to 12/06/2018,2:00 PM. Part-I bids shall be opened on 12/06/2018, 3:00 PM (IST).

All other terms and condition shall remain unchanged.


Regards 04/06/18.

Nitin Jindal
Sr. Engineer (PG-II)

**TAMILNADU GENERATION & DISTRIBUTION CORPORATION
LIMITED**

**2 X660 MW ENNORE SEZ SUPER CRITICAL THERMAL
POWER**

AMENDMENT – 01

**TECHNICAL SPECIFICATION
FOR
LIGHTING PANELS**

SPECIFICATION NO : PE-TS-412-558-E005A



**BHARAT HEAVY ELECTRICALS LTD
POWER SECTOR
PROJECT ENGINEERING MANAGEMENT
NOIDA-INDIA**

**TECHNICAL SPECIFICATION LIGHTING PANELS**

SPECIFICATION NO. PE-TS- 412--558-E005A

DATE: 02.06.2018

The following clause in the Technical Specification for **LIGHTING PANELS** (SPECIFICATION NO. PE-TS- 412-558-E005A) shall be read as below:

Technical Specification Reference:	Clause As per technical Specification for LIGHTING PANELS:	The clause to be read as:
CLAUSE no 3.7 (b.7) Page no. 06 of 16	Reactor shall form an integral part of LP.	Reactor may / may not form an integral part of LP. Bidder can quote for combined Lighting panel with ESS or they can quote for separate lighting panel and separate ESS panel(along with necessary interconnection between the two panels).

Ashu Tripathy
2.6.18

Vishayodan
02/6/18

Shruti
02/06/18