

Technical Corrigendum

Tenderdocuments (total 106 pages)					
S. No.	Document Reference	Page	Clause	Tender statement	Shall be read as
1	Variable Frequency Drive (VFD) Electrical Annexure-2	95 of 106	10.01.00	Efficiency (Drive only) shall be minimum 98% for both MV VFD and LV VFD. Overall efficiency shall be minimum 96.5% for LV VFD and minimum 94 % for MV VFD at rated load and speed.	Efficiency of Inverter Panel (excluding Transformer) shall be minimum 98% as per BHEL spec. This is same as customer spec. And overall efficiency of VFD Panel (including Transformer) shall be minimum 96% at 100% motor load.