

CORRIGENDUM

Sl. No.	Section & Clause No.	Description as per specification	Revised description
1	Section 1, clause 1.3.1.b Page 4/107	Both conventional and LED lighting luminaries are mentioned in the specification. However, as conventional luminaries are not available in the market, LED luminaries shall be applicable. Conventional fixtures are mentioned in specification for selection of equivalent LED luminaries and fixtures by bidder. The technical parameter and technical data of LED luminaries are provided in clause 2.3.5 & 2.3.6 of section-2 of specification. Bidder shall comply the same.	Both conventional and LED lighting luminaries are mentioned in the specification. As conventional fixtures are mentioned in customer specification, bidders may quote conventional fixtures if the same can be supplied to meet lux level measurement, spares requirement as mentioned in sheet no. 2 of this corrigendum and lux level measurement at site as per specification & contractual requirement. Both conventional & LED lighting fixtures are mentioned in BOQ Sl. no. 11, 12, 13, 14, 15, 36, 37, 38, 85, 86, 87, 88, 89, 107, 108 & 109 If bidder is not able to supply any conventional fixture as per availability in market, the bidder may offer equivalent LED for the same. The technical parameter and technical data of same shall be as per clause 2.3.5 & 2.3.6 of section-2 of specification. The bidder to offer equivalent LED fixtures as per conventional fixtures specified in technical specification.
2	BOQ. Sl. No. 25 Page 10/107	Supply of Escape lighting luminaire with "EXIT" sign fitted (Type EX) LED type	Supply of Escape lighting luminaire with "EXIT" sign fitted (Type EX)/Equivalent LED fixture
3	BOQ. Sl. No. 39 Page 10/107	Supply of Post Top Lantern fixture LED type 45W	Supply of Post Top Lantern fixture LED type 45W/ 125W HPMV Post Top Lantern fixture
4	BOQ. Sl. No. 96 Page 12/107	ETC of Escape lighting luminaire with "EXIT" sign fitted (Type EX) LED type	ETC of Escape lighting luminaire with "EXIT" sign fitted (Type EX)/ Equivalent LED fixture
5	BOQ. Sl. No. 110 Page 12/107	Civil works & ETC of Post Top Lantern fixture LED type 45W	Civil works & ETC of Post Top Lantern fixture LED type 45W/ 125W HPMV Post Top Lantern fixture
6	Section 2, clause 2.3.4 Page 20/107	Conventional lighting fixtures are mentioned in below table. As conventional light fixtures are not available in the market, bidder to refer the same for required lux level design and equivalent LED fixtures	Conventional lighting fixtures are mentioned in below table. Bidder to refer the same for supply and lux level requirement. In case bidder is offering LED fixtures, bidder to refer the same for required lux level design and equivalent LED fixtures
7	BOQ. Sl. No. 58 to 74 Page 11/107		BOQ. Sl. No. 58 to 74 - Spare items shall be applicable for bidder who are offering LED luminaries. In case, the bidder is offering conventional luminaries, the spare list given on sheet 2 of this corrigendum shall be applicable. Bidder to provide the prices of spares in BOQ sl. no. 58 to 74 only even in case of conventional fixtures are offered. In case conventional luminaries are offered, the total price of all spares of LED luminaries

Handwritten signature
26.11.21

Handwritten signature
San/20

			listed at BOQ Sl. No. 58 to 74 shall be equal to the total price of all spares of conventional luminaries listed below. The unit price of conventional spares to be provided by bidder in his offer.
--	--	--	--

SL. No.	ITEM DESCRIPTION	UNIT	Qty.
1	Spares: High Pressure Mercury Vapour Lamp 125W/Equivalent LED fixture	Nos.	10
2	Spares: High Pressure Sodium Vapour Lamp 150W/Equivalent LED fixture	Nos.	10
3	Spares: High Pressure Sodium Vapour Lamp 250W/Equivalent LED fixture	Nos.	10
4	Spares: High Pressure Sodium Vapour Lamp 400W/Equivalent LED fixture	Nos.	20
5	Spares: Ignitors (Separate type) for High Pressure Sodium Vapour Lamp/Equivalent spare	Nos.	10
6	Spares: Ballast for 1x150W High Pressure Sodium Vapour Lamp/Equivalent spare	Nos.	10
7	Spares: Ballast for 1x250W High Pressure Sodium Vapour Lamp/Equivalent spare	Nos.	10
8	Spares: Capacitor for 1x150W High Pressure Sodium Vapour Lamp/Equivalent spare	Nos.	10
9	Spares: Capacitor for 1x250W High Pressure Sodium Vapour Lamp/Equivalent spare	Nos.	10
10	Spares: Capacitor for 1x400W High Pressure Sodium Vapour Lamp/Equivalent spare	Nos.	10
11	Spares: Fluorescent Lamp 2 X 28W (T5)/Equivalent LED fixture	Nos.	10
12	Spares: Ballast for Fluorescent Lamp 2 X 28W (T5)/Equivalent spare	Nos.	10
13	Spares: Clockswitch type Time Switch	Nos.	10
14	Spares: 1-Pole 20 Amps Miniature Circuit Breakers (M.C.Bs)	Nos.	10
15	Spares: 2-Pole 20 Amps Miniature Circuit Breakers (M.C.Bs)	Nos.	10
16	Spares: 2-Pole 16 Amps Miniature Circuit Breakers (M.C.Bs)	Nos.	10
17	Spares: 5Amp Receptacles	Nos.	10
18	Spares: 15Amp Receptacles	Nos.	10
19	Spares: 63Amp Receptacles	Nos.	10

Handwritten signature
26.11.21

Handwritten signature

CORRIGENDUM-02

Sl. No.	Section & Clause No.	Description as per specification	Revised description
1	BOQ. Sl. No. 54 Page 11/107	Supply of wall mounted DC Distribution panel (for distribution of DC Supply to switchyard equipment) comprising 240V bus, Two (2) No. 63A MCCB as incomer, One (1) No. Bus Coupler and 8 nos 32A two pole MCCB as outgoing feeders	Supply of wall mounted Single front DC Distribution panel (for distribution of DC Supply to switchyard equipment) with stud type lugs comprising 240V bus, Two (2) No. 63A SFU as incomer, One (1) No. Bus Coupler with mechanical interlock and 16 nos 32A two pole SFU as outgoing feeders (8 Nos on each section).
2	General	----	Make of Luminaires/Fixtures shall be subject to TSGENCO approval. The list of Makes shall be submitted by bidders in technical offer. Approval of TSGENCO will be taken during technical evaluation stage before placement of order.

[Signature]

[Signature]