

Technical Corrigendum

Tender documents (total 135 pages)					
S. No.	Document Reference	Page	Clause/SI. No	Tender statement	Shall be read as
1	R.NO. PS/445/3040/ANX10 REV. NO: 00 (Annexure 10)	107 of 135	12	Limiting Dimensions (LxB) of Transformer foundation : 10x10 sq.ft. (Offer/s of Bidder/s offering Transformers beyond the Limiting Dimensions are liable for rejection)	Limiting Dimensions (LxB) of Transformer foundation : 10x10 sq.meter (Offer/s of Bidder/s offering Transformers beyond the Limiting Dimensions are liable for rejection)
2	R.NO. PS/445/3040/ANX11 REV. NO: 00 (Annexure 11)	128 of 135	12	Main Busbars - Electrolytic grade tinned copper	Main Busbars - Aluminium
3	R.NO. P.S NO. : PS/445/3040 REV. NO: 00 Annexure 12	134 of 135	j	Busbar = Electrolytic grade tinned copper	Busbar = Aluminium