

409022/2021/PS-PEM-EL



PRE-QUALIFICATION REQUIREMENTS FOR DISTRIBUTION BOARDS

PE-PQ-999-558-E005

REVISION NO. 01 DATE 26/08/2020

SHEET NO. 1 OF 2

ITEMS : LDBs/ WDBs/ Lighting Panels**SCOPE:** Supply: YES; Erection & Commissioning: NO.

1	Availability of temperature rise and degree of protection test certificates conducted at independent lab or witnessed by third party for LDBs/ WDBs.
2	Vendor should be designer & manufacturer of LDBs/ WDBs.
3	Availability of test reports (witnessed by third party) to establish in-house capability to carry out all Functional tests, HV test, IR measurement as per relevant IS for LDBs/ WDBs.
4	Option -1: Performance certificates for min. 2 years of trouble free operation at minimum 2 different installations/sites for LDBs/ WDBs and lighting panel. Performance certificate should be from end user only. OR Option-2 : Repeat orders received from two different purchasers/end users for LDBs/WDBs and lighting panel during last 5 years provided the gap between award of two PO's is minimum 2 years. OR Option-3 : 1 no. performance certificate (as per Option-1) and 1 no. repeat order (as per Option-2)
5	Capacity of manufacturing 8 nos. LDBs/WDBs, 30 nos. Lighting Panels per month.
6	Manufactured and supplied at least 40 nos. LDB's/ WDBs, 150 nos. lighting panels in one or more orders.
7	(Minimum 2 nos. purchase orders for the LDBs/WDBs) OR (1 nos. purchase order for the LDBs/WDBs & 1 nos. purchase order for the lighting panel) shall be submitted which should not be more than five (5) years old from the date of application for registration or date of techno- commercial bid opening (as applicable) for establishing continuity in business.

Notes:-

- The credentials for LDB/ WDB's should pertain to min. 100A rating and for LP's to min 63A incomer rating.
- In place of LDBs/ WDBs, documents submitted for LT switchgear panels shall also be considered.

Prepared By:

DEVENDRA SINGH

Digitally signed by DEVENDRA SINGH
DN: c=IN, o=BHARAT HEAVY ELECTRICALS LIMITED, ou=BHEL PS PEM Noida, postalCode=201301, st=Uttar Pradesh, 2.5.4.20=711f5c9b9e9b9a4189b26994570e8fbd5e5358f4250f55631a5f658ea9f8ebb9, cn=DEVENDRA SINGH
Date: 2020.08.26 13:37:46 +05'30'

Reviewed By:

PRAVEEN DUTTA

Digitally signed by PRAVEEN DUTTA
DN: c=IN, o=BHARAT HEAVY ELECTRICALS LIMITED, ou=PS PEM, postalCode=201301, st=UTTAR PRADESH, 2.5.4.20=d8948a0c3e2703a98a0aaca2aedd61dd68b0f4c976429c5c374e3b47b930, cn=PRAVEEN DUTTA
Date: 2020.08.26 14:18:49 +05'30'

Approved By:

DEBASISA RATH

Digitally signed by DEBASISA RATH
DN: c=IN, o=BHARAT HEAVY ELECTRICALS LIMITED, ou=BHEL PS PEM Noida, postalCode=201301, st=UTTAR PRADESH, 2.5.4.20=d8948a0c3e2703a98a0aaca2aedd61dd68b0f4c976429c5c374e3b47b930, cn=DEBASISA RATH
Date: 2020.08.27 10:19:52 +05'30'



PRE-QUALIFICATION REQUIREMENTS FOR DISTRIBUTION BOARDS

PE-PQ-999-558-E005

REVISION NO. 01 DATE 26/08/2020

SHEET NO. 2 OF 2

3. In place of Lighting Panels, documents submitted for wall mounted electrical JB's & feeder pillars etc. (with min. rating 63A) shall also be considered.
4. Consideration of offer shall be subject to customer's approval of bidders, if applicable.
5. Bidder to submit all supporting documents in English. If documents submitted by bidder are in language other than English, a self-attested English translated document should also be submitted.
6. Any other project specific requirement shall be as per Annexure-I and bidder shall submit relevant supporting documents.
7. Notwithstanding anything stated above, BHEL reserves the right to assess the capabilities and capacity of the bidder/collaborators to perform the contract, should the circumstances warrant such assessment in the overall interest of BHEL.
8. After satisfactory fulfillment of all the above criteria/ requirement, offer shall be considered for further evaluation as per NIT and all the other terms of the tender.

9. For FGD, Hydro and R & M projects, Clause no. 4, 5 and 6 to be read as below:-

Clause no. 4:

1 no. performance certificates for min. 2 years of trouble free operation for LDB/ WDB and lighting panel. Performance certificate should be from end user only.

OR

1 no. repeat order received from purchaser/end user for LDB/WDB and lighting panel during last 5 years provided the gap between awards of two PO's is minimum 2 years.

Clause no. 5: Capacity of manufacturing 3 nos. LDBs/ WDBs, 10 nos. Lighting Panels per month.

Clause no. 6: Manufactured and supplied at least 10 nos. LDBs/ WDB's, 30 nos. Lighting Panels in one or more orders.

Prepared By:

DEVENDRA SINGH

Digitally signed by DEVENDRA SINGH
DN: c=IN, o=BHARAT HEAVY ELECTRICALS
LIMITED, ou=BHEL PS PEM Noida,
postalCode=201301, st=Uttar Pradesh,
2.5.4.20=7115c9b9e9db4189b26994570e
8fbd5e5358f4250f55631a5f658ea9f8ebb9,
cn=DEVENDRA SINGH
Date: 2020.08.26 13:38:08 +05'30'

Reviewed By:

PRAVEEN DUTTA

Digitally signed by PRAVEEN DUTTA
DN: c=IN, o=BHARAT HEAVY ELECTRICALS LIMITED,
ou=PS PEM, postalCode=201301, st=UTTAR PRADESH,
2.5.4.20=da8948a0c3e2703a98a0aaca2aedd61dd68
dbef4c976429c5c374e3b47b930, cn=PRAVEEN DUTTA
Date: 2020.08.26 14:19:19 +05'30'

Approved By:

DEBASISA RATH

Digitally signed by DEBASISA RATH
DN: c=IN, o=BHARAT HEAVY ELECTRICALS LIMITED,
ou=BHEL PS PEM Noida, postalCode=201301, st=UTTAR
PRADESH,
2.5.4.20=da8948a0c3e2703a98a0aaca2aedd61dd68
dbef4c976429c5c374e3b47b930, cn=DEBASISA RATH
Date: 2020.08.27 10:20:00 +05'30'

BHEL PEM-ELECTRICAL
PRE-QUALIFYING REQUIREMENTS FOR DISTRIBUTION BOARDS
ANNEXURE –I
PROJECT SPECIFIC CRITERIA AGAINST ENQUIRY
PROJECT: 5X800 MW YADRADRI TPS

NIL

Ashim
Kumar Das
[Dealing Engineer]

Digitally signed by Ashim Kumar Das
DN: cn=Ashim Kumar Das,
o=BHEL, ou=PEM,
email=ashimkdas@bhel.in, c=IN
Date: 2021.08.04 18:27:29
+05'30'

ABHISHEK
[Controlling Officer]

Digitally signed by ABHISHEK
DN: cn=ABHISHEK, o=BHEL, ou=PEM,
email=abhishek1@bhel.in, c=IN
Date: 2021.08.04 18:33:06 +05'30'

PRAVEEN
DUTTA
[Section Head]

Digitally signed by PRAVEEN DUTTA
DN: c=IN, o=BHARAT HEAVY ELECTRICALS
LIMITED, ou=PS PEM, postalCode=201301,
st=UTTAR PRADESH,
2.5.4.20=aab948a0c3e2703a98a0aaca2aed651
dd68dbefc976429c5c374e3b47b930,
cn=PRAVEEN DUTTA
Date: 2021.08.05 15:06:18 +05'30'

DEBASISA
RATH
[DH-Electrical]

Digitally signed by DEBASISA RATH
DN: c=IN, o=BHARAT HEAVY ELECTRICALS LIMITED,
ou=BHEL PS PEM North, postalCode=201301,
st=UTTAR PRADESH,
2.5.4.20=a6a61891ac623b359d779ae7860e329ed7
007faa80fcab0a423e15ea76a, ou=DEBASISA RATH
Date: 2021.08.05 15:40:52 +05'30'