

	PRE-QUALIFICATION REQUIREMENTS FOR DC LEAD ACID / Ni-Cd BATTERIES 1X200 MW + 1X210MW GSECL UKAI TG R&M	PE-PQ-499-508-E001
		REVISION NO. 00 DATE 03/09/2025
		SHEET NO. 1 OF 1

ITEM AND TYPE OF BATTERY: DC Lead Acid / Ni-Cd Battery

- (1) Vendor may be considered for evaluation for one or more of the following type of 220V /110V of DC batteries:

Type 1 - Lead Acid (Plante)
Type 2 - Ni Cd (Fibre Plate)
Type 3 - Ni Cd (Positive Pocket Plate)



- (2) Size of battery - 500AH & above

SCOPE: Supply : YES; Erection & Commissioning : NO; Supervision of Erection & Commissioning : YES;

1	Vendor should be designer & manufacturer of the applicable type of Battery.
2	Vendor to furnish published technical catalogue for the applicable type of batteries.
3	Availability of type test certificates conducted at independent Lab or witnessed by third party as per IS/International standards for the applicable type of batteries.
4	In-house capability to carry out all routine and acceptance tests as per IS/International standards for the applicable type of batteries.
5	Option-1: Performance certificate for min. 1 year of trouble-free operation at one (1) industrial installation for the applicable type of batteries. Performance certificate should be from end user only. Performance certificate should not be more than ten (10) years old from the date of application for registration or date of techno- commercial bid opening (as applicable). OR Option-2: Repeat order received from one purchaser/ end user for the applicable type of batteries during last ten (10) years provided the gap between award of two PO's is minimum 2 years.
6	Minimum two (2) nos. purchase orders for the applicable type of batteries shall be submitted which should not be more than five(5) years old from the date of techno- commercial bid opening for establishing continuity in business.

Notes:

1. Consideration of offer shall be subject to customer's approval of bidders, if applicable.
2. Bidder to submit all supporting documents in English. If documents submitted by bidder are in language other than English, a self-attested English translated document should also be submitted.
3. Notwithstanding anything stated above, BHEL reserves the right to assess the capabilities and capacity of the bidder to perform the contract, should the circumstances warrant such assessment in the overall interest of BHEL.
4. After satisfactory fulfillment of all the above criteria/ requirement, offer shall be considered for further evaluation as per NIT and all the other terms of the tender.
5. Attached annexure (Annexure-I) to be filled by the bidder on quality & general terms. Requisite documents (like factory registration certificate, R&D set-up details etc.) asked in Annexure-I, shall also be attached as Annexure-F2.1 to Annexure-F2.17 along with the filled response in Annexure-I.

PREPARED BY  NAME: DEVENDRA SINGH DESIGNATION: MANAGER (E)	CHECKED BY  NAME: PRIYANKA GUPTA DESIGNATION: SR. MANAGER (E)	REVIEWED BY  NAME: PRAVEEN DUTTA DESIGNATION: AGM (E)	APPROVED BY  NAME: DEBASIS RATH DESIGNATION: GM & DH (E)
--	---	--	--