	BHEL: BAP: RANIPET Water Systems Pre-Qualification Requirement (QR) for Pre - Treatment Plant	Ref: PTP: Sagardighi(1x660MW)
		Dt: 15.11.2021
		Rev: 0

## PRE-QUALIFICATION REQUIREMENT

The Qualification requirements for Pre- Treatment Plant (PTP) and accessories are listed below, and bidder should meet the same.




Bidder should have Designed, Manufactured, Supplied and commissioned of at least one number water treatment/ waste water treatment plant each with a total capacity of at least 150 cu.m/hr comprising of clarifiers & sludge sump. The pre-treatment shall be capable of producing outlet quality with suspended solid/ turbidity with less than 15ppm/ NTU. Such Pre-treatment system should have been in successful operation for at least one (1) year as on date of technical bid opening.

Documentary evidence to be submitted by the bidder (in support of meeting Qualification requirement) along with the bid.

1. Performance certificate from the end user for the successful operation of the reference plant for minimum one year as on date of technical bid opening.
2. Purchase Order copy for the reference plant
3. Supporting documents clearly indicating capacity of Pre-Treatment Plant, type of Clarifier and treated water quality (Turbidity, Total suspended solids (TSS), etc.)

### General

1. Bidders who defaulted, in any of the previous tenders floated by BHEL are not permitted to respond. Such offers, if found later, will not be considered for evaluation.
2. After receipt of offers, during scrutiny, if any vendor found to have been banned by BHEL, then their offer will be summarily rejected at any stage.
3. In case BHEL decides, bidder to arrange necessary permission to visit the reference plant furnished by the bidder for meeting the PQR requirements.

Prepared by  D. Balaraju Naik	Checked by  I M Ramalingeswara Rao	Approved by  V N Santhakumar
--	---	---