

1361191/2023/PS-PEM-EL



**PRE-QUALIFICATION REQUIREMENTS FOR
SCREENED CONTROL CABLE
YADADRI TPS 5X800MW**

PE-PQ-417-507-E016

REVISION NO. 00 DATE 11/03/2023

SHEET NO. 1 OF 1

ITEMS : Screened Control Cable**SCOPE :** Supply : YES; Erection & Commissioning : NO;

1.0	Vendor should be a manufacturer of screened/ instrumentation control cables.
2.0	Availability of test reports of tests on FRLS screened control cables to establish in-house Capability to carry out all routine, type acceptance as per relevant IS/ International Standards (except UV radiation & hydrolytic stability Test which can be conducted at Govt. Lab/ Govt. approved Independent lab).
3.0	Capacity of manufacturing 200 km of screened control cables per month.
4.0	Manufactured and supplied at least one (1) km of FRLS cables.
5.0	Manufactured and supplied screened control cables up to 20 pairs.
6.0	Manufactured and supplied at least 800 Km of Screened Control cables in one or more orders and at least 200 Km in one single order.
7.0	Minimum two (2) nos. purchase orders for screened control cables shall be submitted which should not be more than five (5) years old from the date of techno-commercial bid opening for establishing continuity in business.

NOTES:

1. Consideration of offer shall be subject to customer's approval of bidders, if applicable.
2. Bidder to submit all supporting documents in English. If documents submitted by bidder are in language other than English, a self- attested English translated document should also be submitted.
3. Notwithstanding anything stated above, BHEL reserves the right to assess the capabilities and capacity of the bidder to perform the contract, should the circumstances warrant such assessment in the overall interest of BHEL.
4. After satisfactory fulfillment of all the above criteria/requirement, offer shall be considered for further evaluation as per NIT & all the other terms of the tender.

PREPARED BY ABHINAV BANSHIWALA MANAGER	CHECKED BY N.N. JAJWARE SR. MANAGER	REVIEWED BY PRAVEEN DUTTA A.G.M.	APPROVED BY DEBASISA RATH A.G.M.(DH-ELEC)
---	--	---	--