

PROJECT:	NTPC North Karanpura
ITEM:	Supply & Services of ISOLATORS
SUBJECT:	BID SPECIFIC ATC

1.	For any technical clarification , please contact Mr. Akhilesh Kumar, Dy. Manager (TBEM). Contact No. 0120-06748528; e-mail: akhileshk@bhel.in
2.	For any commercial clarification , please contact Mr. Sandeep, Dy. Manager (TBMM). Contact No. 0120-6748540; e-mail: kumar.sandeep@bhel.in
3.	Terms of Payment:
(Supply & Services)	<p>As per GTC of GeM (Payment due date shall be as per GEM) Supply Payment:</p> <p>a) 95% of payment from the date of receipt of complete invoice along with documents in 3 sets (original + 2 copies) as follows:</p> <ul style="list-style-type: none"> • LR / GR duly endorsed by BHEL Site Official. • Material Receipt Certificate issued by BHEL Site Official. • GST Compliant Tax Invoice • Packing List (Case-wise) • Copy of Transit Insurance Certificate from underwriters. • Material Inspection Clearance Certificate (MICC) issued by BHEL Quality Management • Guarantee Certificate • Copy of Performance Bank Guarantee (PBG) • Certificate of acceptance of Type Test Reports issued by BHEL Engineering Management wherever specifically mentioned in the Purchase Order <p>b) 5% of payment days from the date of receipt of complete invoice along with documents in 3 sets (original + 2 copies) as follows:</p> <ul style="list-style-type: none"> • Certificate of successful completion of Supervision of Erection, Testing & Commissioning at Site if it is in the scope of the supplier or Certificate of successful completion of Testing & Commissioning at Site if it is in the scope of the supplier. • Certificate of completion of final documentation as per Purchase Order / Technical Specification issued by BHEL Engineering Management <p><i>Vendor has to submit the duly signed check-list along with Bill.</i></p> <p>For Charges of Services at Site: 100% payment along with applicable GST from the date of receipt of complete GST compliant Tax invoice along with certificate of successful completion of Testing & Commissioning at Site issued by BHEL Site Official / Construction Management in 3 sets (Original + 2 copies).</p> <p>In-case commissioning is delayed beyond reason not attributable to supplier. Supplier may claim the balance 05% of supply portion after 12 months from the date of last delivery or from the date 28.08.2022, whichever is later, upon submission of BG with equivalent amount and the certificate endorsed by BHEL Site In-Charge citing the details that the "delay in commissioning is not attributable to supplier".</p>
4.	Terms of Delivery:
As per GeM. However, unloading at site is in the scope of BHEL. Bidders to quote price accordingly.	
5.	Delivery Time:

PROJECT:	NTPC North Karanpura
ITEM:	Supply & Services of ISOLATORS
SUBJECT:	BID SPECIFIC ATC

29 Weeks (203 days) from the date of PO by BHEL as per Activity schedule (Annexure-A). Early Delivery is acceptable.

Note: In case, BHEL's delivery requirement is not met by vendor(s), then a chance may be given to all such vendors to review their quoted delivery schedule in line with BHEL's delivery requirement. However, if vendor fails to meet the requisite delivery plan, then BHEL reserves the right not to consider the offer of such vendor(s).

6. Prices:

The quoted prices shall be on **Firm basis including packing and forwarding charges**. Price to be quoted as inclusive of GST. i.e. Ex-Works + F&I + GST.

7. Liquidated Damage of delayed Delivery:

As per GeM terms and conditions.

8. Item & BOQ:

BOQ: As per Annexure-1 of Section-1 of Technical specification.

9. Technical Specification:

Technical specification no. **TB-316-369-002 Rev 00**. No permissible Technical Deviation has been envisaged. Bidders to quote as per Technical Specification.

10. Pre-Qualification Requirement:

As specified in Technical Specifications

11. MQP (Manufacturing Quality Plan):

MQP format is indicative only, however inspection shall be carried out as per approved Quality Plan. Supplier has to submit Quality Plan to BHEL for Customer approval.

12. Inspection:

Inspection shall be carried out as per customer as per approved Quality Plan.

13. Destination / Delivery Location:

BHEL C/O GENERAL MANAGER, NTPC North Karanpura, Post Office - Tandwa, Dist.-Chatra, Jharkhand, PIN. 825321, GSTN No.: 20AAACN0255D2ZB,

Site in charge: Prasun Bhattacharjee- Sr Manager- 8790040005- prasun@bhel.in

14. Bill to Address:

Bharat Heavy Electricals Limited-TBG, 10th Floor, Plot No.C-20/1A/1, Joy Tower, Sector-62, Noida-201301, U.P.

GSTN-09AAACB4146P2ZC

15. Guarantee Clause (Defect Liability Period):

The equipment / material supplied and services rendered (if applicable) shall be guaranteed to be free from all defects and faults in design & engineering, material, workmanship & manufacture and in full conformity with the Purchase Order / Contract, Technical Specifications & approved drawings / data sheets, if any, for 18 months from the date of last delivery or 18 months from 28.08.2022 (i.e. date of completion/installations), whichever is later.

Note: In case ordering is delayed beyond 28.08.2022 (i.e. date of completion/installations) then, guarantee clause shall be 18 months from the date of last delivery.

16. Performance Bank Guarantee:

Performance BG to be kept valid till the completion of guarantee period.

"Bidder agrees to submit performance security required for execution of the contract within the time period mentioned. In case of delay in submission of performance security, enhanced performance security which

PROJECT:	NTPC North Karanpura
ITEM:	Supply & Services of ISOLATORS
SUBJECT:	BID SPECIFIC ATC

would include interest (SBI rate + 6%) for the delayed period, shall be submitted by the bidder. Further, if performance security is not submitted till such time the first bill becomes due, the amount of performance security due shall be recovered as per terms and conditions defined in NIT / Contract, from the bills along with due interest.”

17.	Bidders to ensure that Third party / customer issued certificates being submitted as proof of PQR qualification should have verifiable details of document / certificate issuing authority such as name & designation of Issuing Authority and its organization contact number and e-mail Id etc. In case the same found not available, Purchaser has right to reject such document from evaluation.
18.	Acceptance of Offer: Bidder's offer will be technically acceptable subject to final acceptance of vendor by ultimate customer (NTPC) as approved supplier. Price Bid will be opened only for those bidders in respect of which vendor approval is received from NTPC. Necessary credentials/documents to be submitted for approval by Customer as per format.
19.	Deviations: a) Technical Deviation: No Technical Deviation is envisaged. b) Commercial Deviation: No Commercial Deviation is envisaged.
20.	All other terms & conditions shall be as per GTC of GeM

Signature & Seal of supplier

Date

PROJECT:	NTPC North Karanpura
ITEM:	Supply & Services of ISOLATORS
SUBJECT:	BID SPECIFIC ATC

ACTIVITY SCHEDULE

Annexure-A

SL. NO.	ACTIVITY	ACTIVITY TIME IN WEEKS
1.	Submission of documents necessary for getting manufacturing clearance Drawings, data sheets (In scope of vendor)	04
2.	Review and Approval of documents and issue of manufacturing clearance (In scope of BHEL)	06
3.	Manufacturing Time (In scope of vendor)	15
4.	Inspection (In scope of BHEL)	02
5.	Issue of MICC (In scope of BHEL)	01
6.	Dispatch (In scope of vendor)	01
7.	Supervision activity considered from the date of PO/Contract (29 Weeks for supply + 12 Weeks for site readiness + 11 Weeks for services)	52 Weeks

Note – 1 - Supplier to ensure every revised submission incorporating comments within 2 weeks from the date of comments by BHEL.

1. Inspection call to be issued 2 weeks in advance.
2. Supplier must ensure the completeness and correctness of the requisite documents before submission for approval. Delay in approval on account of incomplete / inadequate information shall be the responsibility of supplier.
3. Inspection call should be given in the prescribed format only. Inspection calls not in the prescribed format shall not be entertained.

Signature & Seal of Supplier
Date

PROJECT:	NTPC North Karanpura
ITEM:	Supply & Services of ISOLATORS
SUBJECT:	BID SPECIFIC ATC

Annexure-V

Item/Package Name :	Supply & Supervision of ETC for Isolators
Enquiry No.:	
Project:	NTPC North Karanpura
Type of project	
Percentage of Local Content	<i>(Bidder to enter the applicable % of local content)</i>

Format of Self certification regarding Local Content in line with PPP-MII order, 2017 & its revision dated 04.06.2020.

Date:.....

I _____ S/o, D/o, W/o, _____ Resident of _____ hereby solemnly affirm and declare as under:

That I will agree to abide by the terms and conditions of the Public Procurement (Preference to Make in India) Order, 2017 (*hereinafter PPP-MII order*) of Government of India issued vide Notification No: P-45021/2/2017-BE-II dated 15/06/2017, its revision dated 04/06/2020 and any subsequent modifications/Amendments, if any.

That the information furnished hereinafter is correct to the best of my knowledge and belief and I undertake to produce relevant records before the procuring entity/BHEL or any other Government authority for the purpose of assessing the local content of goods/services/works supplied by me for ***(Enter the name of the Equipment/Item for Project)***.

That the local content for all inputs which constitute the said goods/services/works has been verified by me and I am responsible for the correctness of the claims made therein.

That the goods/services/works supplied by me for ***(Enter the name of the Equipment/Item for Project)*** contains.....% ***(mention the Local content in %age)*** Local Content.

That the value addition for the purpose of meeting the 'Minimum Local Content' has been made by me at ***(Enter the details of the location(s) at which value addition is made)***.

That in the event of the local content of the goods/services/works mentioned herein is found to be incorrect and not meeting the prescribed supplier class categorization criteria as per said order, based on the assessment of procuring agency (ies)/BHEL/Government Authorities for the purpose of assessing the local content, action shall be taken against me in line with the PPP-MII order and provisions of the Integrity pact/ Bidding Documents.

I agree to maintain the following information in the Company's record for a period of 8 years and shall make this available for verification to any statutory authority.

- i. Name and details of the Local Supplier
(Registered Office, Manufacturing unit location, nature of legal entity)
- ii. Date on which this certificate is issued

PROJECT:	NTPC North Karanpura
ITEM:	Supply & Services of ISOLATORS
SUBJECT:	BID SPECIFIC ATC

Annexure-V

- iii. Goods/services/works for which the certificate is produced
- iv. Procuring entity to whom the certificate is furnished
- v. Percentage of local content claimed and whether it meets the Minimum Local Content prescribed
- vi. Name and contact details of the unit of the Local Supplier (s)
- vii. Sale Price of the product
- viii. Ex-Factory Price of the product
- ix. Freight, insurance and handling
- x. Total Bill of Material
- xi. List and total cost value of input used to manufacture the Goods/to provide services/in construction of works
- xii. List and total cost of input which are domestically sourced. Value addition certificates from suppliers, if the input is not in-house to be attached
- xiii. List and cost of inputs which are imported, directly or indirectly

For and on behalf of..... (Name of firm/entity)

Authorized signatory (To be duly authorized by the Board of Directors)

<Insert Name, Designation and Contact No.>

PROJECT:	NTPC North Karanpura
ITEM:	Supply & Services of ISOLATORS
SUBJECT:	BID SPECIFIC ATC

SCHEDULE OF COMMERCIAL DEVIATION

The following are the deviations/ variations exception from the General Terms and Conditions:

SL. NO.	CLAUSE NO. OF TERMS AND CONDITIONS	STATEMENT OF DEVIATION
	NIL DEVIATION	NIL DEVIATION

In case, this schedule is not submitted, it will be presumed that the equipment /material to be supplied under this contract is deemed to be in compliance with the General Terms and Conditions.

If there is NIL deviation, even then the format to be filled as NIL DEVIATION.

Note : 1. Continuation Sheets of like size and format may be used as per the Bidder's Requirement and shall be annexed to this schedule.

2. Deviation mentioned in this schedule shall only be considered.

**This Format is to be submitted in original duly signed by bidder.
Reproduction of the same in any sort is not acceptable.**

Place:	õ õ õ õ õ õ õ	Signature of the authorized representative of
Date :	õ õ õ õ õ õ õ .	Bidder's name
		:õ õ õ õ õ õ õ õ õ õ õ õ õ õ
		Designation:õ õ õ õ õ õ õ õ õ õ õ õ õ õ
		..
		Company
		Seal:õ õ õ õ õ õ õ õ õ õ õ õ õ

PROJECT:	NTPC North Karanpura
ITEM:	Supply & Services of ISOLATORS
SUBJECT:	BID SPECIFIC ATC

UNPRICED BID

Item Number	Item Description	Item Quantity	Unit of Measure	Unit Price (Inclusive of F&I & GST)	GST % Applicable
1	400kV, 3150 A, 50kA/1 sec, 3-ph HCB isolator (mechanically ganged motor operated) with 1 earth switch (motor operated & mechanically ganged) complete with operating mechanism boxes and accessories etc. excluding support insulators, structure and terminal connectors	6	NO	Mention as "Quoted"	Mention GST %
2	220kV, 1600 A, 40kA/1 sec, 3-ph HCB Tandem type isolator (mechanically ganged motor operated) without earth switch complete with operating mechanism boxes and accessories etc. excluding support insulators, structure and terminal connectors	2	NO	Mention as "Quoted"	Mention GST %
3	220kV, 1600 A, 40kA/1 sec, 3-ph HCB isolator (mechanically ganged motor operated) with 1 earth switch (motor operated & mechanically ganged) complete with operating mechanism boxes and accessories etc. excluding support insulators, structure and terminal connectors	1	NO	Mention as "Quoted"	Mention GST %
4	220kV, 1600 A, 40kA/1 sec, 3-ph HCB isolator (mechanically ganged motor operated) with 2 earth switches (motor operated & mechanically ganged) complete with operating mechanism boxes and accessories etc. excluding support insulators, structure and terminal connectors	1	NO	Mention as "Quoted"	Mention GST %
Supervision of ETC					
Item Number	Item Description	Item Quantity	Unit of Measure	Unit Price (Inclusive of GST)	GST % Applicable
5	Supervision of erection, testing and commissioning of 400kV HCB Isolators including alignment check	3	Man-days	Mention as "Quoted"	Mention GST %
6	Supervision of erection, testing and commissioning of 220kV HCB Isolators including alignment check	3	Man-days	Mention as "Quoted"	Mention GST %

Signature & Seal of Supplier
Date:



BHARAT HEAVY ELECTRICALS LIMITED

TRANSMISSION BUSINESS ENGINEERING MANAGEMENT

COPYRIGHT & CONFIDENTIAL. The Information in this document is the property of BHARAT HEAVY ELECTRICALS LIMITED. This must not be used directly or indirectly in any way detrimental to the interest of the company.	BHEL Document No. TB-316-369-002		Rev.		Prepared by	Checked by	Approved by	
			00	Name	AK	VK	VK	
	Type of Document	Technical Specification			Sign	sd	sd	sd
	Title	420 kV & 220kV ISOLATORS/ EARTH SWITCHES			Date	23.08.21	23.08.21	23.08.21
					Group	TBEM		
					W.O. No			
	CUSTOMER	NTPC LTD.						
	CONSULTANT	-						
	PROJECT	400/220kV Switchyard for North Karanpura Super TPP (3x660MW)						
	CONTENTS							
	SN	TITLE					No. of Pages	
	1	Section – 1: Technical Specification					5	
	2	Annexure – I: Bill of Quantity					1	
	3	Section – 2: Equipment Specification					10	
	4	Section – 3: Project details & General Specification					24+2+1+1	
	5	Section – 4: Guaranteed Technical Particulars					1+4	
	6	Section – 5: Quality Plan					1	
	7	Section – 6: Checklist					4	
		<u>NOTE:-</u>						
		Offers submitted without checklist (section-6) shall not be evaluated.						
	Rev No.	Date	Altered	Checked	Approved	REVISION DETAILS		
	Distribution				To			
					Copies			

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-1: Scope, Specific Technical Requirements & Quantities	REV.00

SECTION 1

TECHNICAL SPECIFICATION OF 400kV & 220kV ISOLATORS/ EARTH SWITCHES

1.1 SCOPE

This technical specification covers the requirements of design, manufacture, testing at works, packing and dispatch of 400/220 kV Isolators/ Earth Switches, along with operating mechanism etc. to site.

Refer Section 3 for Project Details.

The Equipment is required for the following projects

Name of Customer : NTPC LTD.

Name of Projects : 400/220kV Switchyard for North Karanpura Super Thermal Power Project (3x660MW)

1.2 SPECIFIC TECHNICAL REQUIREMENTS

Rated voltage kV (rms)	420	220
Rated insulation levels		
Full wave impulse withstand voltage (1.2/50 micro sec.)		
- between line terminals and ground	± 1425 kVp	± 1050 kVp
- between terminals with isolator open	± 1425 kVp Impulse on one terminal and power frequency Voltage of 240kVp of opposite polarity on other terminal	± 1200 kVp
Switching Impulse withstand voltage (250/2500micro sec) dry and wet		
- between line terminal and ground	±1050 kVp	-
-between line terminals with isolator open	±900 kVp impulse on one terminal and 345 kVp power freq. voltage of opposite polarity on other terminal	-
One minute power frequency dry and wet withstand voltage		
- between line terminals and ground	520 kVrms	460 kVrms
- between terminals with isolator open	610 kV rms	530 kVrms
corona extinction voltage (kV rms) with isolator in all positions	320 (Min)	-
Max. radio interference Voltage (micro-volts) for Frequency between 0.5 MHz and 2 MHz	1000 at 266 kV rms	1000 at 156 kV rms
Minimum creepage distance	10500mm (25mm/kV)	6125 (25mm/kV)
Phase to phase spacing (mm)	7000	4500
Rated current at 50 °C Ambient temperature (Amp.)	3150A/ 2000A	2500A/ 1600A
Rated short time withstand Current of isolator and earth switch for 1 Sec.	50 kA	40 kA
Rated dynamic short circuit withstand Current	125 kAp	100 kAp

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)		
CUSTOMER: NTPC LTD.		
Technical Specification of 400kV & 220 kV Isolators		TB-316-369-002
Section-1: Scope, Specific Technical Requirements & Quantities		REV.00

of isolator and earth switch		
Operating mechanism of Isolator	AC/ Universal Motor	AC/ Universal Motor
Operating mechanism of earth switch	AC/ Universal Motor	AC/ Universal Motor
Rated frequency (Hz)	50	50
No.of poles	3	3
Design ambient Temperature (°C)	50	50
Line Charging Breaking Capacity	-	-
Transformer off-load breaking capacity	-	-
Spare way for "Local Mode" and "Remote Mode" of Local/ Remote switch for its use wired till TBs	Required	Required
Electrical Interlocking contactor for Isolator and Earth switch	Required	Required
Type of TBs (<i>For terminating Aux Power, Aux contacts etc</i>)	Stud Type All CT & VT circuits - Min. four 2.5 sq.mm. copper flexible conductor AC & DC power supply -Two 16 sq.mm. Aluminium conductor Other control circuits - Min. two 2.5 sq.mm. copper flexible conductor.	
System neutral earthing	Effectively Earthed	
Seismic acceleration	0.3g horizontal	
Rating of auxiliary contacts	10 A at 220 V DC	
Breaking capacity of auxiliary contacts	2 A DC with circuit Time constant of not less than 20 ms at 220V DC	
Temperature rise over design Ambient temp	As per IEC – 62271-102	
Rated mechanical Terminal load	As per table III of IEC 62271-102.	
Type	Outdoor, HCB motor operated, mechanically ganged	
Min. No. of auxiliary contacts On each isolator	Besides requirement of this spec. The bidder shall wire Up 14 NO +14 NC to TBs for purchaser's future use. 4 Nos MBB (2NO+2NC) shall also be required.	8NO +8NC to TBs for purchaser's future use. 4 Nos MBB (2NO+2NC) shall also be required.
Min. No. of auxiliary contacts On each earthing switch	Besides requirement of this spec. The bidder shall wire Up 12 NO + 12 NC to TBs for purchaser's future use shall be provided.	8NO +8NC to TBs for purchaser's future use.
Operating time	12 sec. or less	
Number of terminals in mechanism box	All contacts and control circuits are to be wired upto mechanism box (plus 20 % or 24 spare terminals whichever is higher, exclusively for employer's use)	
Support Structure Height	Adequate so that lowest part of support insulator of equipment is minimum 2550mm from plinth.	
Temperature Rise	As per table V of IEC 60694 for an ambient temperature of 50 deg C.	
Insulator Data (Not in bidder's scope)		
Type	solid core type	solid core type
Number of units	3	2

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-1: Scope, Specific Technical Requirements & Quantities	REV.00

Height of stack	3650mm	2300mm
Minimum Cantilever strength – Upright	800 Kg	600 Kg
Top PCD	127	127
Bottom PCD	300	254

1.3 QUANTITIES

As per Annexure-1

1.4 Supervision charges for Installation and commissioning

Bidder shall quote lump-sum price for supervision of **installation and commissioning** of one no. of isolator of each voltage & current rating type.

An indicative list of tests to be performed at site is given below. Supplier shall perform any additional test based on specialties of item as per Field QP/ instruction of the equipment manufacturer or Purchaser without extra cost to purchaser.

- a) Insulation resistance of each pole
- b) Manual and electrical operation on interlocks
- c) Insulation resistance of control circuits and motors.
- d) Ground connections
- e) Contact resistance
- f) Proper alignment to minimize the vibration to the extreme possible during operation.
- g) Measurement of operating torque for isolator and Earth switch
- h) Resistance of operating and interlocking coils.

1.5 Spares

All spares supplied under this contract shall be strictly interchangeable with the parts for which they are intended for replacement. The spares shall be treated and packed for long term storage in the climatic conditions prevailing at the site. Small items shall be packed in sealed transparent plastic covers with desiccant bags as necessary.

Each spare part shall be clearly marked and labeled on the outside of the packing together with the description when more than one spare part is packed in single case. A general description of the contents shall be shown on outside of the case and detailed list enclosed. All cases, containers and other packages must be suitably marked and numbered for the purpose of identification.

1.6 Sub-Suppliers

Bidder should consider NTPC approved make of components and fitments. In case the offered make is not approved by BHEL/ NTPC, bidder has to provide alternate make components without any commercial/ time of delivery implication to BHEL.

Few of the approved make of equipments shall be as follows:

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-1: Scope, Specific Technical Requirements & Quantities	REV.00

Item Description	Proposed sub-supplier	Place	Sub-supplier approval status code/category
Cable Lugs	DOWELS	MUMBAI	A
	3D	UMBERGAON	A
	CHETNA	NASIK	A

A – For this item proposed sub-vendor is acceptable to NTPC.

DR – For these items Details required for NTPC review.

Above vendor list is final and no additional vendor approval will be given.

1.7 Qualifying requirements

400kV Disconnectors being offered should be from manufacturer(s) who have manufactured and supplied atleast five (5) nos. of three phase Disconnectors suitable for Air Insulated substation/Switchyard of 400kV or above class which should have been in successful operation for a minimum period of two (2) years prior to the date 28.04.2021.

220 kV Disconnectors being offered should be from manufacturer(s) who have manufactured and supplied at least five (5) nos. of three phase Disconnectors suitable for Air Insulated Substation/Switchyard of 220 kV or above class which should have been in successful operation for a minimum period of two (2) years prior to the date 28.04.2021.

1.8 Type tests

Equipment supplied shall be of type tested design. During detailed engineering, the Bidder shall submit for Owner's approval the reports of all type tests as listed in Section-2 of this specification & carried out within last **ten years** from the date 28.04.2021. These reports should be for the tests conducted on the equipment similar to those proposed to be supplied under this contract and test (s) should have been either conducted at an independent laboratory or should have been witnessed by a client.

However, if bidder is not able to submit report of the type test(s) conducted within last ten years from the date 28.04.2021 or in the case of type test report(s) are not found to be meeting the specification requirements, the bidder shall conduct all such tests under this contract at no additional cost to the owner either at third party lab or in presence of clients/ owners representative and submit the reports for approval.

All acceptance and routine tests as per the specification and relevant standards shall be carried out. Charges for these shall be deemed to be included in the equipment price

The type test reports once approved for any projects shall be treated as reference. For subsequent projects of NTPC, an endorsement sheet will be furnished by the manufacturer confirming similarity and "No design Change". Minor changes if any shall be highlighted on the endorsement sheet.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-1: Scope, Specific Technical Requirements & Quantities	REV.00

1.9 DELETED

Sl. No.	Item	Unit	QTY
A Main Equipments			
1	400kV, 3150 A, 50kA/1 sec, 3-ph HCB isolator (mechanically ganged motor operated) with 1 earth switch (motor operated & mechanically ganged) complete with operating mechanism boxes and accessories etc. excluding support insulators, structure and terminal connectors	Nos.	6
2	220kV, 1600 A, 40kA/1 sec, 3-ph HCB Tandem type isolator (mechanically ganged motor operated) without earth switch complete with operating mechanism boxes and accessories etc. excluding support insulators, structure and terminal connectors	Nos.	2
3	220kV, 1600 A, 40kA/1 sec, 3-ph HCB isolator (mechanically ganged motor operated) with 1 earth switch (motor operated & mechanically ganged) complete with operating mechanism boxes and accessories etc. excluding support insulators, structure and terminal connectors	Nos.	1
4	220kV, 1600 A, 40kA/1 sec, 3-ph HCB isolator (mechanically ganged motor operated) with 2 earth switches (motor operated & mechanically ganged) complete with operating mechanism boxes and accessories etc. excluding support insulators, structure and terminal connectorS	Nos.	1
B Supervision of ETC			
5	Supervision of erection, testing and commissioning of 400kV HCB Isolators including allignment check	Mandays	3
6	Supervision of erection, testing and commissioning of 220kV HCB Isolators including allignment check	Mandays	3

Notes:

- The scope of supply includes hardware and accessories but excludes solid core insulators, structures for mounting the isolators and terminal connectors. The corona rings (if required) are included in scope of supply.
- Erection, testing and commissioning for 1 no. of 400kV & 1 no. of 220kV Isolator with earth switches including alignment check shall be carried out under the supervision of the Isolator manufacturer's representative. The commissioning report shall be prepared and signed by the manufacturer's representative. However required unskilled men power/labour, tools (other than special tools and tackles which shall be in bidder's scope) shall be provided by BHEL.

SECTION 2

EQUIPMENT SPECIFICATION

2.1 GENERAL

This section covers the general technical requirements of Isolator. In case of any discrepancies between the requirements mentioned in this section and those specified in other sections of this specification, this shall prevail after section 1 and shall be treated as binding requirements.

2.2 TECHNICAL REQUIREMENT OF EQUIPMENT

The manufacturer whose Isolators are offered, should have designed, manufactured, tested as per IEC/IS or equivalent standard and supplied the isolator for the specified system voltage and fault level and should meet PQR mentioned under clause No. 1.7 of Section-1.

2.3 APPLICABLE STANDARDS

The Isolator shall conform to the following Indian / International standards:

Three phase induction motors	: IS: 325 - 1978
Alternating current disconnectors and earthing switches	: IS: 9921- 1985
Alternating current disconnectors and earthing switches	: IEC: 62271-102 (2001-12)
High Voltage Switches	: IEC-60265
Schedule of preferred ratings, Manufacturing Specification and Application Guide for High Voltage Air Switches, Bus Supports and Switch accessories	: ANSI-C37.32
Test Code for high voltage air switches	: ANSI-C37.34
Power switching equipment	: NEMA-SG6
Method for testing uniformity of coating of zinc coated articles.	: IS: 2633- 1986
Recommended practice for hotdip galvanizing on iron & steel	: IS: 2629 - 1985
Electric power connectors	: IS: 5561- 1970
Method for determination of mass of zinc coating	: IS: 6745- 1972

on iron and steel articles.

Low voltage switchgear and Controlgear : IS: 13947- 1993
General rules (Part 1)

Dimension for steel plates, sheets, strips and flats : IS: 1730- 1989
for gen engg purposes

Dimension for wrought Al and Al alloy sheet & strip : IS: 2676- 1981

2.4 DESIGN AND CONSTRUCTIONAL FEATURES

2.4.1 General

The equipment shall be three pole type and such units shall be electrically/ mechanically ganged operated to perform the service requirement as specified in section 1.

The design shall be such that changes in mounting and connection can be made at site without excessive labour and with minimum replacement of parts.

All metal parts shall be of non-rusting and non-corroding metal. Current carrying parts shall be from high conductivity electrolytic copper/aluminium. Bolts, screws and pins shall be provided with lock washers. Keys or equivalent locking facilities, if provided on current carrying parts, shall be made of copper silicon alloy or equivalent. The live parts shall be designed to eliminate sharp joints, edges and other corona producing surfaces.

The isolator shall be so constructed that the switch blades will not fall to the closed position if the operating shaft gets disconnected. Isolators and earthing switches including their operating parts shall be such that they can not be dislodged from their open or closed position by gravity, wind pressure, vibrations shocks or accidental touching of the connecting rods of the operating mechanism. The switch shall be designed such that no lubrication of any part is required except at very infrequent intervals.

The insulator of isolator shall conform to the requirements stipulated in section-3 and shall have a min. cantilever strength of 800 kg for 400kV & 600/ 400kg for 220kV. Pressure due to the contact shall not be transferred to the insulators after the main blades full close. The insulators shall be so arranged that leakage current will pass to earth and not between terminals of the same pole or between phases.

Factory adjustment shall be so made that field adjustments will not be required on the isolators and earth switch. When interphase connections are attached to the rotating insulator in the field all phases shall make and break simultaneously.

The isolators shall be provided with high pressure current carrying contacts on the hinge/ jaw ends and all contact surfaces shall be silver plated. The thickness of silver plating should not be less than 25 microns. The contacts shall be accurately machined and self aligned.

The isolator shall be provided with a galvanised steel base provided with holes and designed for mounting on a lattice/pipe support structure. The base shall be rigid and self supporting. The position of movable contact system (main blades) of each of the isolator and earthing switch shall be indicated by a mechanical indicator at the lower end of the vertical rod of shaft for the isolator and earthing switch. The indicator shall be of metal and shall be visible from operating level.

All ferrous parts shall be hot dip galvanised in accordance with relevant standards as detailed in clause 2.3.

2.4.2 Duty Requirement

Isolators and earth switches shall be capable of withstanding the dynamic and thermal effects of the maximum possible short circuit current of the system in their closed position. They shall be constructed such that they do not open under influence of short circuit current and wind pressure together. Further the temperature rise due to this short time current shall not cause any damage to the insulation of current carrying parts. The earth switches wherever provided, shall be constructionally interlocked so that the earth switches can be operated only when the isolator is open and vice versa. The constructional interlocks shall be built in construction of isolator and shall be in addition to the electrical and mechanical interlocks provided in the operating mechanism

In addition to the constructional interlock, isolator and earth switches shall have provision to prevent their electrical and manual operation unless the associated and other interlocking conditions are met. All these interlocks shall be of fail safe type. Suitable individual interlocking coil arrangements shall be provided. The inter-locking coil shall be suitable for continuous operation from DC supply and within a variation range as stipulated in Section 3.

The interlock coil shall be provided with adequate contacts for facilitating permissive logic for 'DC' control scheme of the isolator as well as for AC circuit of the motor to prevent opening of closing of isolators when the interlocking coil is not energized.

The earthing switches shall be capable of discharging trapped charges of the associated Lines. Isolator and Earth switches shall be able to bear on the terminals the total forces including wind loading and electrodynamic forces on the attached conductor without impairing reliability or current carrying capacity.

The isolator shall be capable of making/breaking normal currents when no significant change in voltage occurs across the terminal of each pole of the isolators on account of make/break operation.

All isolators of class 72.5kV above shall be of mechanical endurance class M1as per IEC. All earth switches shall be of class M1 duty. Electrical endurance duty for earth switches shall be E0.

2.4.3 Main Contacts

The isolators and isolator-cum-earthing switches shall have heavy duty accurately machined self-aligning and high pressure current carrying contacts on the hinge/ jaw ends and so designed

that binding cannot occur after remaining closed for prolonged periods of time in a heavily polluted atmosphere. The contacts shall be made of **hard drawn electrolytic copper**. The high pressure type contacts shall wipe the contact surface while opening and closing. The contacts shall be so designed that wiping action shall not cause scouring or abrasion on the contact surfaces. The wiping action shall be sufficient to remove any film of oxide which may be formed during the operation of the switches.

No undue wear or scuffing shall be evident during the mechanical endurance tests. Contacts and spring shall be designed so that readjustments in contact pressure shall not be necessary throughout the life of the isolator or earthswitch. Each contact or pair of contacts shall be independently sprung so that full pressure is maintained on all contacts at all time.

The contacts and other current carrying parts shall be so designed that their temperature rise, under different conditions of operation, shall not exceed the values stipulated in the relevant standards. The temporary rise of temperature due to the passage of rated short circuit current for the specified period shall not cause any annealing or welding of contacts. The surface of the contacts shall be smooth and **silver plated having a thickness of not less than 25microns**.

The fixed contact of centre break isolators shall be provided with springs which ensure that there is always a positive contact with adequate pressure to give enough contact surface for passage of current. The springs provided shall not go out of alignment or get entangled with the moving contact during operation. The springs provided shall be of non ageing type and its strength shall not reduce appreciably during the life span of the isolator. Contact spring shall not carry any current and shall not lose their characteristic due to heating effect.

2.4.4 Blades

The switch blade shall be so assembled that no part of the blade can move relative to the other. Bending and torsional stress shall not exceed $1/3^{rd}$ of the rated strength of the insulator unit. All movable parts which may be in current path shall be shunted by flexible copper conductors. The conductor shall have sufficient length to prevent breaking.

The bolts, pins or springs used in current carrying parts shall also be of stainless steel. All castings and hardware other than those in the current carrying parts shall be of malleable cast iron, hot dip galvanised/electro galvanised, as appropriate.

The live parts shall be designed to eliminate sharp joints, edges and other corona producing surfaces, where applicable. Where this is impracticable, adequate corona shields shall be provided. Corona shields/rings etc. shall be made of aluminium/aluminium alloy.

2.4.5 Earthing Switches

Where specified, the isolators shall be equipped with earthing switches and these shall form an integral part of the isolator and shall be mounted on the base frame of the isolator.

The earthing switches shall have complete operating mechanism and auxiliary contacts having padlock arrangement on both "ON " & "OFF" positions.

The operating mechanism for the earthing switches shall be only locally operated, either electrically or manually.

The earthing blades shall be required to carry peak current and rated short time current as the main blades of the isolators and shall withstand dynamic stresses.

Each earth switch shall be provided with flexible copper braids for connection to ground mat. These braids shall have the same short time current carrying capacity as the earth blades. The transfer of fault current through swivel connection will not be accepted.

The earthing switches shall consist of three earthing links which shall normally reset against the frames when the connected isolator is in the closed position.

The plane of movement and final position of the earth blades shall be such that adequate electrical clearances are obtained from adjacent live parts in the course of its movement between ON and OFF position.

The isolators shall be so designed that addition of earth switches shall be possible at a future date. It should be possible to interchange position of earth switch to either side of the pole at site without disturbing constructional interlock.

The frame of each isolator and earthing switches shall be provided with two reliable earth terminals for connection to earth mat.

The earthing switches shall also comply with the requirement of IEC-1129, 1992 in respect of induced current switching duty as defined for Class B earthing switches.

2.4.6 Bearings

The design and construction of the various bearings shall have all the features required to withstand the specified climatic conditions so as to ensure dependable and effective operation even after long period of inaction of these isolators and switches. All bearings in the current paths shall be shunted by flexible copper conductors of adequate cross section. Bearing housing shall be sturdy and weather proof. All bearings shall be filled & sealed with first filling of lubricants which shall be long lasting in nature. Facilities shall be provided for lubrication of bearings if not sealed for life and if washers do not have facility of greasing.

2.4.7 Operating Mechanism and Control

The isolators and earth switches shall be manually operated or motor operated as specified in Section 1.

The bidder shall offer, motor operated switches having padlock arrangement on both 'ON' and 'OFF' positions.

Isolator shall be electrically/mechanically gang operated for main blades and earth switches (as per section-1). The operating mechanism of the three poles shall be well synchronized and interlocked. ~~It shall also be provided with a pole discrepancy timer and a set of contacts for pole discrepancy remote indication in case of 3 independent operating mechanisms.~~

The design shall be such as to provide maximum reliability under all service conditions. All operating linkages carrying mechanical loads shall be designed for negligible deflection. The length of inter insulator and interpole operating rods shall be capable of adjustments.

The design of linkages & gears shall be such so as to allow one man to operate the handle with ease for isolator & earth switch.

The isolator shall be provided with positive continuous control throughout the entire cycle of operation. The operating pipes and rods shall be sufficiently rigid to maintain positive control under the most adverse conditions and when operated in tension or compression for isolator closing. They shall also be capable of withstanding all torsional and bending stresses due to operation of other poles. The play in the linkages shall not be excessive. Wherever supported the operating rods shall be provided with bearings on either ends. The operating rods/pipes shall be provided with suitable universal couplings to account for any angular misalignment. The design of the linkages & gears shall be such as to allow one man to operate the handle with ease for isolator & earth switch.

All isolator and earth switches shall be provided with manual operating handles enabling one man to open or close the isolator with ease in one movement only while standing on ground level. The operating handle shall be provided with pad locking arrangement and located at around 1meter from the base of isolator support structure.

All rotating parts including rotating insulator shall be supported on double roller or ball bearings. These shall be protected from the weather by means of covers and grease retainers. Bearing pressure shall be kept low to ensure long life and ease of operation. Locking pins wherever used shall be rustproof.

All isolators and earth switches shall be provided with operating handles and double hinged doors with padlocking arrangement for the operating mechanism box.

A mechanical indicator shall be provided at or near the operating mechanism for positive indication of the open and closed position of the switch.

A flexible conductor of adequate size shall be provided for connecting the vertical operating shaft at the lower end to the station ground bus.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)

CUSTOMER: NTPC LTD.

Technical Specification of 400kV & 220 kV Isolators

TB-316-369-002

Section-2: Equipment specification

REV.00

It shall not be possible, after final adjustment has been made for any part of the mechanism to be displaced at any point in the travel sufficient enough to allow improper functioning of the isolator when the isolator is opened or closed at any speed.

Control Cabinets shall be of painted sheet steel and shall be dust, water and vermin proof. Unless otherwise specified, thickness of sheet used shall be at least 2.5 mm.

The enclosure of the control cabinets shall provide a degree of protection of not less than IP 55 as per IS: 2147.

The size of enclosure and the layout of equipment inside shall provide generous clearances. Each cabinet shall be provided with a 15A, 240V ac, 2 pole, 3 pin industrial grade receptacle with switch. For incoming supply, MCB of suitable rating shall be provided. Illumination of each compartment shall be with door operated incandescent lamp. All control switches shall be of rotary switch type.

Each mechanism box shall be provided with two earthing pads to receive 75mmx12mm GS flat. The connection shall be bolted type with two bolts per pad. The hinged door shall be connected to body using flexible wire. The cabinets shall also be provided with danger plate, and internal wiring diagram pasted on inside of the door. The front label shall be on a 3mm thick plastic plate with white letters engraved on black background.

All doors, removable covers and plates shall be gasketed all around with good quality neoprene gaskets.

Cable entry shall be from the bottom. Suitable removable cable gland plate shall be provided on the cabinet for the purpose. **Cable glands shall be provided by BHEL.**

In case of motorised isolator, suitable space heaters shall be mounted in the cabinet to prevent condensation. Heater shall be suitable for 240V, 50 Hz, single phase A.C. supply.

For looping the auxiliary power supply cable, suitable terminals should be provided, for 16/25 sq.mm cables. These terminals are to be separated from the others and fitted with transparent plastic covers and shall have warning labels with red lettering.

The terminal shall be staggered that the connection of external cable to terminal block should be possible without disturbing the rest of the connections. The terminal block arrangements shall be such as to provide maximum accessibility to all conductor terminations and any arrangement preventing ready access to other terminal screws shall not be accepted.

The arrangements shall be such that it is possible so safely connect or disconnect terminals and replace fuse links on live circuits.

A "Local/Remote" selector switch and a set of open/close push buttons shall be provided on the control cabinet of the isolator and earth switch to permit its operation through local or remote push buttons.

Provisions shall be made in the control cabinet to disconnect power supply to prevent local/remote power operation.

Easy access shall be provided for all components on which adjustment or tightening is expected to be done at site, without removal of other components.

Counter balance springs shall be provided for counter balancing the isolators to prevent impact at the end of travel both on opening and closing of the isolator. The spring shall be made of non rusting type alloy.

The fixed contact and its tensioning by spring shall be such that there will be a positive contact with adequate pressure to give enough contact surface for passing the current. The springs provided shall not go out of alignment or get with the moving contact during operation. The springs provided shall be of non - ageing antirust type and its strength shall not reduce appreciably during life span of isolator.

2.4.8 Motor operated mechanism

The motor operated mechanism shall be suitable for operation on 415V, 3 phase and 50Hz power supply/ DC supply.

The motor shall satisfy the requirements specified in IS : 325.

The scheme shall be so designed that during manual operation the motor drive shall be automatically electrically de-coupled.

Suitable reduction gearing shall be provided between the motor and the drive shaft of the isolator. A quick electro mechanical brake shall be fitted on the higher speed shaft.

Limit switches for motor control shall be fitted on the isolator/ earth switch shaft within the cabinet to sense the open and close positions of the isolator and earth switches. The switches shall be snap type and shall have adequate number of NO/NC contacts for use in the indication scheme. The switches shall be adjusted in a manner so that moving contacts reach their final open and close position with proper alignment.

2.4.9 Auxiliary Switch

All contacts shall be kept wired to the terminals in their respective operating mechanism box.

All auxiliary switches shall have a continuous current carrying capacity of at least 10 Amps at the rated control voltage and shall be wired up to the terminals in the operating mechanism box.

Auxiliary switches which are installed on the frame of isolators or earthing switches shall be suitably protected against accidental arcing from the main circuit.

Auxiliary switches shall be mounted in a weather proof housing which shall have provision for entry of conduits of proper sizes, or for fixing of cable glands.

Auxiliary switches which are installed on the frame of the isolators or earthing switches shall be suitably protected against accidental arcing of the main contact.

The breaking capacity of the auxiliary switches shall be adequate for the circuit to be controlled.

The contacts shall be capable of breaking at least 2 Amp in a 230V D.C circuit with a time constant of not less than 20 milliseconds.

Fixing hardware on the auxiliary contacts shall not cause hindrance to the movement of the contact fingers.

Auxiliary Contacts shall be capable of being set such that:

- a) Signaling of the closed position shall not take place unless the contact system has reached such a position that the rated normal and rated short time current can be carried safely.
- b) Signaling of the open position shall not take place unless the contact system has reached such a position of at least 80 percent of the isolating distance.
- c) A simultaneous signaling device for all poles of an isolator shall be arranged in such a way that the signal is given only when all poles of the isolator have a position in accordance with (a) and (b) above.

2.4.10 Base

Each single pole of the isolator shall be provided with a complete galvanised steel base provided with holes and designed for mounting on a supporting structure. The base shall be rigid and self supporting and shall require no guying or cross bracing between phases other than the supporting structures.

The position of movable contact system (main blades) of each of the isolator and earthing switch shall be indicated by a mechanical indicator at the lower end of the vertical rod of shaft for the isolator and earthing switch. The indicator shall be of metal and shall be visible from operating level.

2.4.11 Safety Interlocking

All isolators and isolator-cum-earthing switches shall be suitable for electrical interlocking. In addition to the provision of electrical interlocking, the Isolator and the earthing switch shall also be interlocked through the castle key electro-mechanical interlock. Mechanical interlocks, if applicable, shall be so designed that force cannot be transmitted to points remote from the point at which hand force is applied.

The earth switches wherever provided shall be mechanically and electrically interlocked so that they can be operated only when the isolator is open and vice-versa.

In addition to the constructional interlock, isolator and earth switches shall have provision to prevent their electrical and manual operation unless the associated and other interlocking conditions are met. All these interlocks shall be of fail safe type. Suitable individual interlocking coil arrangements shall be provided. The inter-locking coil shall be suitable for continuous operation from DC supply and within a variation range as stipulated in Section 3.

Constructional interlock of isolator with E/S operating mechanism to be provided in case of manually operated isolators.

The electrical interlocking scheme shall operate on auxiliary supply as given in Section 1 and shall be subject to purchaser's approval at contract stage.

2.4.12 Control Wiring

All the control and secondary circuits and auxiliary contacts of the isolator shall be wired completely and up to the terminal blocks in the operating mechanism box.

The control wiring shall be of adequate cross-section and not less than 2.5mm² copper.

All wires shall have PVC insulation for 1100 Volts and shall be suitable for switch board wiring.

At least 20 per cent terminals with a minimum of 24 Nos. as spare for future use shall be provided over and above the numbers required, in the MOM box.

2.4.13 Galvanising

All ferrous parts, except the operating mechanism box shall be hot dip galvanised as per the relevant Indian standards specified in clause 2.3.

Electro-galvanised hardware may be used only where the hot dip galvanised hardware is not available in the required sizes. Generally, all steel hardware above M10 size should be hot dip galvanised. Hardware should be of GKW or equivalent make. If any other make is used, the same shall be subject to purchaser's approval.

2.5 TESTS

In continuation to the requirements stipulated in Section-1 of this specification, the Isolator alongwith operating mechanism shall conform to the type tests & shall be subjected to routine tests & acceptance tests in accordance with IEC 62271-102. Bidder has to submit valid type test reports conducted within past 10 years for isolator and earthing switches as per IEC:62271-102(2001-12). In case any test report is not acceptable to BHEL/ Customer supplier has to carry out type test without any cost implication to BHEL. Minimum 50Nos Mechanical operation will be carried out on one isolator assembled completely with all accessories as acceptance test. During final testing of isolator sequential closing/opening of earth switch shall also be checked only after Isolator is fully Open/Close. Acceptance test shall be carried out with operating box.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-3: Project Details and General Specification	REV.00

SECTION- 3

PROJECT DETAILS AND GENERAL SPECIFICATIONS

3.0 GENERAL

This section stipulates the General Technical Requirements under the Contract and will form an integral part of the Technical Specification.

The provisions under this section are intended to supplement general requirements for the materials, equipment and services covered under other sections of tender documents and are not exclusive. However in case of conflict between the requirements specified in this section and requirements specified under other sections, the requirements specified under respective sections shall prevail.

3.1 PROJECT DETAILS

	Particular	Details
a)	Customer	NTPC Ltd.
b)	Engineer/Consultant/ Inspector	NTPC Ltd.
c)	Project Title	North Karanpura Super Thermal Power Project (3x660 MW) : 400/220kV Switchyard at NKSTPP end & 220kV Sub-station at Mine end
d)	Project Location	Place: Near Tandwa town District: Hazaribagh & Chatra State: Jharkhand
e)	Latitude & Longitude	400/220kV S/s at NKSTPP: North: 23°50' to 23°52' and East: 84°59' to 85°2' 220kV S/s at Chatti Bariatu & Kerandari-A mine: North: 23°52'35" and East: 85°05'25"
f)	Nearest Railway Station	Khalari Railway Station Ranchi-Garhwa section of Eastern Railways
g)	Distance of project location from the Railway station	40 Km (approx.)
h)	Nearest Major Town	Hazaribagh city
i)	Distance of the town from the project site	50 Km.
j)	Nearest commercial airport	Ranchi
k)	Distance of airport from the project site	150 Km
SITE CONDITIONS (for design purposes)		
a)	Design ambient temperature	50°C
b)	Maximum Relative humidity	95 %
c)	Height above mean sea level	Less than 1000 meters
d)	Pollution Severity	Heavily polluted (With Coal dust & Fly ash) and Highly Corrosive environment.
e)	Criteria for Wind Resistant design of structures and equipment	Standard Applicable - IS 875 (Part 3) 1987
f)	Basic Wind speed "Vb" at ten meters	39 m/ sec

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-3: Project Details and General Specification	REV.00

	above the mean ground level.	
g)	Category of terrain	Cat -2
h)	Risk Coefficient "K1"	1.06

3.1.1 SYSTEM PARAMETERS:

Sl.No.	Parameters	400 kV	220 kV
1	Highest system voltage	420 kV rms	245 kVrms
2	Lightning Impulse voltage	±1425kVp	± 1050kVp
3	Switching impulse voltage	±1050kVp	-
4	Power frequency withstand for 1 min (rms)	630 kV(rms)	460 kV(rms)
5	Max. fault level (1 sec.)	50 kA	40kA
6	Minimum creepage distance	10500 mm	6125mm

3.1.2 AUXILIARY POWER:

Sl.No.	Nominal Connection Voltage	Variations in Voltage	Frequency	Phase	Neutral
1	415V	±10%	50 (+3% -5%)	3Phase , 4 Wire	Solidly Earthed
2	240V	±10%	50 (+3% -5%)	1 phase	Solidly Earthed

Combined variation of voltage and frequency shall be + 10%. Design fault level of 415V system shall be restricted to 50kA rms for 1 second.

The operational limits for variation of DC voltage are (+) 10% to (-) 15%.

3.1.3 The various minimum heights of the switchyard shall be as given below from plinth level:

Voltage	Equipment /1st Level	2nd Level	3rd Level	Peak
220kV	6000mm	12000mm	17000mm	8500mm
400kV	8000mm	16000mm	23000mm	8500mm

The minimum vertical distance from the bottom of the lowest porcelain part of the bushing, porcelain enclosures or support insulators to the bottom of the equipment structure, where it rests on the foundation pad shall be 2550mm.

The minimum height of intermediate gantry tower for 400kV wherever required shall be 25 m and the peak (s) shall be of 8.5 m.

3.1.4 The minimum clearances for 400kV & 220 kV switchyards shall be as given below:

	400kV	220kV
Phase to earth clearance	3500 mm	2100mm
Phase to phase clearance	4000 mm	2100mm
Section clearance	6500 mm	5000mm

3.2 INSTRUCTION TO BIDDERS:

The bidders shall submit the technical requirements, data and information as per the technical data sheets, provided in Section-4.

The bidders shall furnish catalogues, engineering data, technical information, design documents, drawings etc fully in conformity with the technical specification.

It is recognized that the bidders may have standardized on the use of certain components, materials, processes or procedures different than those specified herein. Alternate proposals offering similar

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-3: Project Details and General Specification	REV.00

equipment based on the manufacturer's standard practice will also be considered provided such proposals meet the specified designs, standard and performance requirements and are acceptable to the Purchaser. Unless brought out clearly, the Bidder shall be deemed to conform to this specification scrupulously. All deviations from the specification shall be clearly brought out in the respective schedule of deviations. Any discrepancy between the specification and the catalogues or the bid, if not clearly brought out in the schedule, will not be considered as valid deviation.

Except for lighting fixtures, wherever a material or article is specified or defined by the name of a particular brand, Manufacturer or Vendor, the specific name mentioned shall be understood as establishing type, function and quality and not as limiting competition. For lighting fixtures, makes shall be as defined in Section-Lighting System.

Equipment furnished shall be complete in every respect with all mountings, fittings, fixtures and standard accessories normally provided with such equipment and/ or needed for erection, completion and safe operation of the equipment as required by applicable codes, though they may not have been specifically detailed in the Technical Specifications unless included in the list of exclusions. Materials and components not specifically stated in the specification but which are necessary for commissioning and satisfactory operation of the switchyard unless specifically excluded shall be deemed to be included in the scope of the specification and shall be supplied without any extra cost. All similar standard components/parts of similar standard equipment under supply shall be inter-changeable with one another.

The bidder shall supply type tested (including special tests as per tech. specification) equipment and materials. The test reports shall be furnished by the bidder along with equipment/ material drawings. In the event of any discrepancy in the test reports, (i.e., if any test report is not acceptable due to any design/ manufacturing changes or due to non-compliance with the Technical Specification and/ or applicable standard), the tests shall be carried out without any additional cost implication to the BHEL. BHEL reserves the right to get any or all type/tests conducted/repeated.

3.3 CODES AND STANDARDS

The supplier is required to follow local statutory regulations stipulated in the latest amended Electricity Supply Act 1948 and Indian Electricity Rules 1956 (latest), and other local rules and regulations.

The equipment to be furnished under this specification shall conform to latest issue with all amendments of standards and/ or codes specified under respective section heads. The standards mentioned in the specification are not mutually exclusive or complete in them, but intended to complement each other. The supplier shall also note that list of standards presented in this specification is not complete. Whenever necessary the list standards shall be considered in conjunction with specific IS/IEC. When the specified requirements stipulated in the specifications exceed or differ than those required by the applicable standards, the stipulation of the specification shall take precedence.

Other internationally accepted standards which ensure equivalent or better performance than specified in the standards referred under section shall also be acceptable.

In case governing standards for the equivalent for the equipment is different from IS/ IEC, the salient points of difference shall be clearly brought out in additional information schedule along with English language version of standard of relevant extract of the same. The equipment conforming to standards other than IS/ IEC shall be subject to Purchaser's approval.

The full names of the codes and standards mentioned in abbreviations under various equipment heads are as follows:

BS British Standards
IEC/ CISPR International Electro-technical Commission

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-3: Project Details and General Specification	REV.00

IS	Bureau of Indian Standards
ISO	International Organization for Standards
NEMA	National Electric Manufacturers Association

3.4 SERVICES TO BE PERFORMED BY THE EQUIPMENT BEING FURNISHED

The 400 kV system is being designed to limit the power frequency over voltage of 1.5 p.u. and the switching surge over voltage to 2.5 p.u. In 400 kV system the initial value of temporary over voltage could be 2.0 p.u. for 1-2 cycles. All the equipment/materials covered in this specification shall perform all its function satisfactorily without undue strain, restriking etc. under such over voltage conditions. All equipment shall also perform satisfactorily under various other electrical, electromechanical and meteorological conditions of the site of installation. All equipment shall be able to withstand all external and internal mechanical, thermal and electromechanical forces due to various factors like wind load, temperature variation, ice & snow, (not applicable for this project) short circuit etc for the equipment .

The equipment shall also comply with the following:

- a) All equipments shall be suitable for hot line washing.
- b) To facilitate erection of equipment, all items to be assembled at site shall be "match marked".
- c) Piping, if any, between equipment control cabinet or operating mechanism to marshalling box of the equipment shall bear proper identification to facilitate the connection at site.
- d) All equipment shall be supplied with necessary inter-pole cabling, and its cost shall be included in the cost of equipment.

3.5 ENGINEERING DATA

3.5.1 Drawings

All drawings submitted by the supplier including those submitted at the time of bid shall be in sufficient detail to indicate the type, size, arrangement, material description, Bill of Materials, weight of each component, break-up for packing and shipment, the external connections, fixing arrangement required. The dimensions required for installation and interconnections with other equipment and materials, clearances and spaces required for installation and interconnections between various portions of equipment and any other information specifically requested in the specifications.

Each drawing submitted by the Contractor (including those of sub-vendors) shall bear a title block at the right hand bottom corner with clear mention of the name of the Employer, the system designation, the specifications title, the specification number, the name of the Project, drawing number and revisions. If standard catalogue pages are submitted, the applicable items shall be indicated therein. All titles, noting, markings and writings on the drawing shall be in English. All the dimensions should be in metric units.

After the approval of the drawings, further work by the Contractor shall be in strict accordance with these drawings and no deviation shall be permitted without the written approval of the Purchaser, if so required.

The review of these data by the purchaser will cover only general conformance of the data to the specification and documents, interfaces with the equipment provided under specification, external connections and of the dimensions which might affect plan layout. This review by the purchaser may not indicate a thorough review of the dimensions, quantities and details of the equipment, material, any devices or items indicated or the accuracy of the information submitted. This review and/or approval by the purchaser shall not be considered by the contractor, as limiting any of his responsibilities and liabilities for mistakes and deviations from the requirements, specified under these specifications and documents.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-3: Project Details and General Specification	REV.00

All manufacturing and fabrication work in connection with the equipment prior to the approval of the drawings shall be at the Contractor's risk. The Contractor may make any changes in the design which are necessary to make the equipment conform to the provisions and intent of the Contract and such changes will again be subject to approval by the Purchaser. Approval of Contractor's drawing or work by the Purchaser shall not relieve the contractor of any of his responsibilities and liabilities under the Contract.

All engineering data submitted by the contractor after final process including review and approval by the purchaser shall form part of the contract document and the entire work performed under these specifications shall be performed in strict conformity, unless otherwise expressly requested by the purchaser in writing.

3.5.2 Approval Procedure

The following procedure for submission and review/approval of the drawings, data, reports, information, etc. shall be followed by Contractor:

- a. All data/information furnished by Vendor in the form of drawings, documents, Catalogues or in any other form for NTPC's information/interface and/or review and approval are referred by the general term "drawings".
- b. The 'Master drawings list' indicating titles, Drawing Number, Date of submission and approval etc. shall be finalised mutually between Contractor and Employer before the award of contract. This list shall be updated if required at suitable interval during detailed engineering.
- c. All drawings (including those of subvendor's) shall bear at the right hand bottom corner the 'title plate' with all relevant information duly filled in. The Contractor shall furnish this format to his subvendor along with his purchase order for subvendor's compliance.
- d. Contractor shall submit all the drawings in five (5) copies for review of Employer. Employer shall forward their comments within four (4) weeks of receipt of drawings.
- e. Upon review of each drawings, depending on the correctness and completeness of the drawings, the same will be categorised and approval accorded in one of the following categories:

CATEGORY I	Approved
CATEGORY II	Approved subject to incorporation of comments/modification as noted. Resubmit revised drawing incorporating the comments
CATEGORY III	Not approved. Resubmit revised drawings for Approval after incorporating comments/modifications as noted
CATEGORY IV	For information and records

- f. Contractor shall resubmit the drawings approved under Category II, III within one (1) week of receipt of comments on the drawings, incorporating all comments. Every revision of the drawing shall bear a revision index wherein such revisions shall be highlighted in the form of description or marked up in the drawing identifying the same with relevant revision number enclosed in a triangle (e.g 1.2.3. etc.).
- g. In case Contractor does not agree with any specific comment, he shall furnish the explanation for the same to Employer consideration. In all such cases Contractor shall necessarily enclose explanations along with the revised drawing (taking care of balance comments) to avoid any delay and/or duplication in review work.
- h. It is the responsibility of the Contractor to get all the drawings approved in the Category I or IV (as the case may be) and complete engineering activities within the agreed schedule. Any delay

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-3: Project Details and General Specification	REV.00

arising out of submission and modification of drawings shall not alter the contract completion schedule.

- i. Contractor shall not make any changes in the portion of the drawing other than those commented. If changes are required to be made in the portions already approved, the Contractor shall resubmit the drawings identifying the changes (along with reasons for changes) for Employer's review and approval. **Drawings resubmitted shall show clearly the portions where the same are revised marking the relevant revision numbers and Employer shall review only such revised portion of documents.**
- j. Approval of drawings will not in any way relieve the Contractor of his obligations of furnishing the equipment in accordance with the specification and shall not prevent subsequent rejection if such equipment is later found to be defective.

3.5.3 Erection Drawings.

- a. Contractor shall furnish erection drawings for the guidance or commencement of erection or the first shipment, whichever is earlier. These shall generally comprise of fabrication/assembly drawings, various component/part details drawing, assembly, clearance data requirements, etc. The drawings shall contain details of components/ equipment with identification number, match marks, bill of materials, assembly procedures etc.
- b. For all major equipment apart from above details, assembly sequence and instructions with check-lists shall be furnished in the form of erection manuals.

3.5.4 Instruction Manual

- a. The Contractor shall submit to the Employer preliminary instruction manuals for all the equipments for review. The final instructions manuals incorporating Employer's comments and complete in all respect shall be submitted at least sixty (60) days before the first shipment of the equipment. The instruction manuals shall contain full details and drawings of all the equipments, the transportation, storage, installation, testing, operation and maintenance procedures, etc. separately for each component/equipment along with log record format. These instruction manuals shall be submitted in five (5) copies for approval.
- b. If after commissioning and initial operation of the plant, the instruction manuals require any modifications/additions/changes, the same shall being corporate and the updated final instruction manuals shall be submitted.
- c. The operating and maintenance instructions together with drawings (other than shop drawings) of the equipment, as completed, shall have sufficient details to enable the Employer to maintain, dismantle, reassemble and adjust all parts of the equipment. They shall give a step by step procedure for all operations likely to be carried out during the life of the plant/equipment, including erection, testing, commissioning, operation, maintenance dismantling and repair. Each manual shall also include a complete set of approved drawings together with performance/rating curves of the equipment and test certificates, wherever applicable. The contract shall not be considered completed for purpose of taking over until such instructions and drawings have been supplied to the Employer.
- d. A separate section of the manual shall be for each size/type of equipment and shall contain a detailed description of construction and operation, together will all relevant pamphlets.
- e. The manuals shall include the following
 - a) List of spare parts along with their drawing and catalogues and procedure for ordering spares.
 - b) Lubrication Schedule including charts showing lubrication checking, testing and replacement procedure to be carried daily, weekly, monthly & at longer intervals to ensure trouble free operation.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-3: Project Details and General Specification	REV.00

- f. Where applicable, fault location charts shall be included to facilitate finding the cause of mal-operation or break down.
- g. A collection of the manufacturer's standard leaflets will not accepted to be taken as a compliance of this clause. The manual shall be specifically compiled for the concerned project.

3.5.5 Final Submission of drawings and documents:

The Contractor shall furnish the following after approval of all drawings /documents and test reports:

- a. List of drawings bearing the Employer's and Contractor's drawing number.
- b. Two (2) bound sets alongwith 4 CD-ROMs of all drawing.
- c. All documents/designs in two (2) copies as noted above.
- d. Contractor shall also furnish six (6) bound sets of all as-built drawings including the list of all as-built drawings bearing drawing numbers. The Contractor shall also furnish two (2) sets of CD-ROMs/ DVD/Portable hard disk of all as-built drawings as decided by the Employer.
- e. The Contractor shall also furnish four (4) copies of instruction/ operations & maintenance manuals (after approval) for all the equipments.

3.5.6 TEST REPORTS

Two (2) copies of all test reports shall be supplied for approval before shipment of Equipment. The report shall indicate clearly the standard value specified for each test to facilitate checking of the reports. After final approval six (6) bound copies of all type and routine test reports shall be submitted to Employer.

3.6 MATERIAL /WORKMANSHIP

Where the specification does not contain references to workmanship, equipment, materials and components of the covered equipment, it is essential that the same must be new, of highest grade of the best quality of their kind, conforming to best engineering practice and suitable for the purpose for which they are intended and shall ensure satisfactory performance throughout the service life.

In case where the equipment, materials or components are indicated in the specification as "similar" to any special standard the purchaser shall decide upon the question of similarity. When required by the specification or when required by the purchaser the contractor shall submit, for approval, all the information concerning the materials or components to be used in manufacture. Machinery, equipment, materials and components supplied, installed or used without such approval shall run the risk of subsequent rejection, it being understood that the cost as well as the time delay associated with the rejection shall be borne by the Contractor.

The design of the Works shall be such that installation, future expansions, replacements and general maintenance may be undertaken with a minimum of time and expenses. Each component shall be designed to be consistent with its duty and suitable factors of safety subject to mutual agreements. All joints and fastenings shall be devised, constructed and documented so that the component parts shall be accurately positioned and restrained to fulfill their required function. In general, screw threads shall be standard metric threads. The use of other thread forms will only be permitted when prior approval has been obtained from the Purchaser.

Whenever possible, all similar part of the works shall be made to gauge and shall also be made interchangeable with similar parts. All spare parts shall also be interchangeable and shall be made of the same materials and workmanship as the corresponding parts of the equipment supplied under the specification. Where feasible, common component units shall be employed in different pieces of equipment in order to minimize spare parts stocking requirements. All equipment of the same type and rating shall be physically and electrically interchangeable.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-3: Project Details and General Specification	REV.00

The equipment offered in the bid only shall be accepted for supply, with the minimum modifications as agreed/accepted.

3.7 PROVISIONS FOR EXPOSURE TO HOT AND HUMID CLIMATE

Outdoor equipment supplied under the specification shall be suitable for service and storage under tropical conditions of high temperature, high humidity, heavy rainfall and environment favorable to the growth of fungi and mildew. The indoor equipment located in non-air-conditioned areas shall also be of same type.

SPACE HEATERS

The heaters shall be suitable for continuous operation at 230 V as supply voltage. On –off switch and fuse shall be provided.

One or more adequately rated thermostatically connected heaters shall be supplied to prevent condensation in any compartment. The heaters shall be installed in the compartment and electrical connections shall be made sufficiently away from below the heaters to minimize deterioration of supply wire insulation. The heaters shall be suitable to maintain the compartment temperature to prevent condensation.

The heaters shall be suitably designed to prevent any contact between the heater wire and the air and shall consist of coiled resistance wire centered in a metal sheath and completely encased in a highly compacted powder of magnesium oxide or other material having equal heat conducting and electrical insulation properties or they shall consist of resistance wire wound on a ceramic and completely covered with a ceramic material to prevent any contact between the wire and the air. Alternatively, they shall consist of a resistance wire mounted into a tubular ceramic body built into an envelope of stainless steel or the resistance wire is wound on a tubular ceramic body and embedded in vitreous glaze. The surface temperature of the heaters shall be restricted to a value which will not shorten the life of the heater sheaths or that of insulated wire or other component in the compartments.

FUNGI STATIC VARNISH

Besides the space heaters, special moisture and fungus resistance varnish shall be applied on parts which may be subjected or predisposed to the formation of fungi due to the presence or deposit of nutrient substances. The varnish shall not be applied to any surface of part where the treatment will interfere with the operation or performance of the equipment. Such surfaces or parts shall be protected against the application of the varnish.

Ventilation opening

In order to ensure adequate ventilation, compartments shall have ventilation openings provided with fine wire mesh of brass to prevent the entry of insects and to reduce to a minimum the entry of dirt and dust. Outdoor compartment openings shall be provided with shutter type blinds.

Degree of Protection

The enclosure of the Control Cabinets, Junction boxes and Marshalling Boxes, panels etc. to be installed shall provide degree of protection as detailed here under:

- Installed outdoor: IP- 55
- Installed indoor in air conditioned area: IP-31
- Installed in covered area: IP-52
- Installed indoor in non air-conditioned area where possibility of entry of water is limited: IP-41.
- For LT Switchgear (AC & DC distribution Boards) : IP-52

The degree of protection shall be in accordance with IS: 13947 (Part –I) / IEC-947 (Part-I) / IS 12063/IEC 529. Type test report for degree of protection test, on each type of the box shall be submitted for approval.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-3: Project Details and General Specification	REV.00

PRESERVATIVE SHOP COATING

All exposed metallic surfaces subject to corrosion shall be protected by shop application of suitable coatings. All surfaces which will not be easily accessible after the shop assembly, shall be treated beforehand and protected for the life of the equipment. All surfaces shall be thoroughly cleaned of all mill scales, oxides and other coatings and prepared in the shop. The surfaces that are to be finish-painted after installation or require corrosion protection until installation, shall be shop painted as per the requirements covered in the relevant part of the Technical Specification.

Transformers and other electrical equipments, if included shall be shop finished with one or more coats of primer and two coats of high grade resistance enamel. The finished colors shall be as per manufacturer's standards, to be selected and specified by the Employer at a later date.

Shop primer for all steel surfaces which will be exposed to operating temperature below 95 degrees Celsius shall be selected by the Contractor after obtaining specific approval of the Employer regarding the quality of primer proposed to be applied. Special high temperature primer shall be used on surfaces exposed to temperature higher than 95 degrees Celsius and such primer shall also be subject to the approval of the Employer.

3.8 RATING PLATES, NAME PLATES AND LABELS

- 3.8.1 Each equipment shall have permanently attached to it in a conspicuous position, a rating plate of non-corrosive material upon which shall be engraved manufacturer's name, equipment, type or serial number together with details of the ratings, service conditions under which the item of plant in question has been designed to operate, and such diagram plates as may be required by the Employer.
- 3.8.2 Such nameplates or labels shall be of white nonhygroscopic material with engraved black lettering or alternately, in the case of indoor circuit breakers, starters, etc. of transparent plastic material with suitably coloured lettering engraved on the back.
- 3.8.3 The rated current, extended current rating and rated thermal current shall be clearly indicated in the name plate in case of current transformer.
- 3.8.4 Rated voltage, voltage factor and intermediate voltage shall be clearly indicated on the nameplate in case of capacitor voltage transformer.
- 3.8.5 Each switch shall have a clear inscription identifying its function. Switches shall also have a clear inscription of each position indication.
- 3.8.6 All segregated phases of conductors or bus ducts, indoor or outdoor, shall be provided with coloured phase plates to clearly identify the phase of the system.
- 3.8.7 All such plates, instruction plates, etc. shall be bilingual with Hindi inscription first, followed by English. Alternatively, two separate plates one with Hindi and the other with English inscriptions may be provided.

3.9 GALVANISING:

- 3.9.1 The galvanised surface shall consist of a continuous film adhering to the steel. The finished surface shall be clean and smooth, and shall be free from defects like dissolved patches, base, spot, unevenness of coating, spelter which is loosely attached to the steel globules, spiky deposits, blistered surfaces, flaking or peeling off, etc. The presence of any of these defects shall render the material liable to rejection.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-3: Project Details and General Specification	REV.00

- 3.9.2 All exposed ferrous parts shall be hot dip galvanised as per IS:2629 & IS:2633, Galvanising shall be uniform, smooth continuous and free from acid spots. Should the galvanising of the sample be found defective, the entire batch of steel shall have to be re-galvanised at Contractor's cost. The amount of zinc deposit shall be not less than 610 gms. per sq.m. of surface area and in addition, the thickness of zinc at any spot shall not be less than 85 microns. The Employer reserves the right to measure the thickness of zinc deposit by Elkometer or any other instrument acceptable to Employer and reject any component which shows thickness of zinc at any location less than 85 microns. The testing on the galvanised materials shall be carried out as per IS:2633.
- 3.9.3 The amount of zinc deposit over threaded portion of the bolts, nuts and screws shall not be less than 300 gms. per sq. meter of surface area. The amount of zinc deposit on washers shall not be less than 340 gms. per sq. meter of surface area. The threads having extra deposit of zinc shall be removed by die cutting after the completion of galvanising. The removal of extra zinc shall be carefully done so that threads shall have minimum deposits of zinc on them as specified.

3.10 PAINTING

Unless explicitly stated in relevant chapters of the specification, the painting of all electrical equipment shall be as follows:

Epoxy based with suitable additives. The thickness of finish coat shall be minimum 50 microns (minimum total DFT shall be 100 microns). However in case electrostatic process of painting is offered for any electrical equipment, minimum paint thickness of 50 microns shall be acceptable for finish coat. Paint shade shall be as per technical specification.

3.11 QUALITY ASSURANCE PROGRAMME

- 3.11.1 The Contractor shall adopt suitable quality assurance programme to ensure that the equipment and services under the scope of contract whether manufactured or performed within the Contractor's works or at his subcontractor's premises or at the Employer's site or at any other place of work are in accordance with the specifications. Such programmes shall be outlined by the Contractor and shall be finally accepted by the Employer/authorised representative after discussions before the award of the contract. The QA programme shall be generally in line with ISO-9001/IS- 14001.

A quality assurance programme of the contractor shall generally cover the following:

- i. His organisation structure for the management and implementation of the proposed quality assurance programme
- ii. Quality System Manual
- iii. Design Control System
- iv. Documentation Data Control System
- v. Qualification data for Bidder's key Personnel.
- vi. The procedure for purchase of materials, parts, components and selection of subcontractor's services including vendor analysis, source inspection, incoming raw-material inspection, verification of materials purchased etc.
- vii. System for shop manufacturing and site erection controls including process, fabrication and assembly.
- viii. Control of non-conforming items and system for corrective actions and resolution of deviations.
- ix. Inspection and test procedure both for manufacture and field activities.
- x. Control of calibration and testing of measuring testing equipments.
- xi. System for Quality Audits.
- xii. System for identification and appraisal of inspection status.
- xiii. System for authorising release of manufactured product to the Employer.
- xiv. System for handling storage and delivery.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-3: Project Details and General Specification	REV.00

- xv. System for maintenance of records, and
- xvi. Furnishing quality plans for manufacturing and field activities detailing out the specific quality control procedure adopted for controlling the quality characteristics relevant to each item of equipment/component as per format enclosed as Annexure-I.

3.12 GENERAL REQUIREMENTS - QUALITY ASSURANCE

- 3.12.1 All materials, components and equipment covered under this specification shall be procured, manufactured, erected, commissioned and tested at all the stages, as per a comprehensive Quality Assurance Programme. An indicative programme of inspection/tests to be carried out by the contractor for some of the major items is given in the respective technical specification. This is, however, not intended to form a comprehensive programme as it is the contractor's responsibility to draw up and implement such programme duly approved by the Employer. The detailed Quality Plans for manufacturing and field activities should be drawn up by the Bidder and will be submitted to Employer for approval. Schedule of finalisation of such quality plans will be finalised before award.
- 3.12.2 Manufacturing Quality Plan will detail out for all the components and equipment, various tests/inspection, to be carried out as per the requirements of this specification and standards mentioned therein and quality practices and procedures followed by Contractor's/ Sub-contractor's/ sub-supplier's Quality Control Organisation, the relevant reference documents and standards, acceptance norms, inspection documents raised etc., during all stages of materials procurement, manufacture, assembly and final testing/performance testing. The Quality Plan shall be submitted on electronic media e.g. floppy or E-mail in addition to hard copy, for review. Once the same is finalised, hard copies shall be submitted for approval. After approval the same shall be submitted in compiled form on CD ROM.
- 3.12.3 Field Quality Plans will detail out for all the equipment, the quality practices and procedures etc. to be followed by the Contractor's site Quality Control Organisation, during various stages of site activities starting from receipt of materials/equipment at site.
- 3.12.4 The Bidder shall also furnish copies of the reference documents/plant standards/acceptance norms/tests and inspection procedure etc., as referred in Quality Plans along with Quality Plans. These Quality Plans and reference documents/standards etc. will be subject to Employer's approval without which manufacturer shall not proceed.
- 3.12.5 These approved documents shall form a part of the contract. In these approved Quality Plans, Employer shall identify customer hold points (CHP), i.e. test/checks which shall be carried out in presence of the Employer's Project Manager or his authorised representative and beyond which the work will not proceed without consent of Employer/Authorised representative in writing. All deviations to this specification, approved quality plans and applicable standards must be documented and referred to Employer along with technical justification for approval and dispositioning.
- 3.12.6 No material shall be despatched from the manufacturer's works before the same is accepted subsequent to pre-despatch final inspection including verification of records of all previous tests/inspections by Employer's Project Manager/Authorised representative and duly authorised for despatch by issuance of MDCC.
- 3.12.7 All material used for equipment manufacture including casting and forging etc. shall be of tested quality as per relevant codes/standards. Details of results of the tests conducted to determine the mechanical properties, chemical analysis and details of heat treatment procedure recommended and actually followed shall be recorded on certificates and time temperature chart. Tests shall be carried out as per applicable material standards and/or agreed details.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-3: Project Details and General Specification	REV.00

- 3.12.8 All welding and brazing shall be carried out as per procedure drawn and qualified in accordance with requirements of ASME Section IX/BS-4870 or other International equivalent standard acceptable to the Employer.
- 3.12.9 All welding/brazing procedures shall be submitted to the Employer or its authorised representative for approval prior to carrying out the welding/brazing.
- 3.12.10 All brazers, welders and welding operators employed on any part of the contract either in Contractor's/his sub-contractor's works or at site or elsewhere shall be qualified as per ASME Section-IX or BS-4871 or other equivalent International Standards acceptable to the Employer.
- 3.12.11 Test results or qualification tests and specimen testing shall be furnished to the Employer for approval. However, where required by the Employer, tests shall be conducted in presence of Employer/authorised representative.
- 3.12.12 For all pressure parts and high pressure piping welding, the latest applicable requirements of the IBR (Indian Boiler Regulations) shall also be essentially complied with. Similarly, any other statutory requirements for the equipments/systems shall also be complied with. On all back-gauged welds MPI/LPI shall be carried before seal welding.
- 3.12.13 All the heat treatment results shall be recorded on time temperature charts and verified with recommended regimes.
- 3.12.14 No welding shall be carried out on cast iron components for repair.
- 3.12.15 Unless otherwise proven and specifically agreed with the Employer, welding of dissimilar materials and high alloy materials shall be carried out at shop only.
- 3.12.16 All non-destructive examination shall be performed in accordance with written procedures as per International Standards. The NDT operator shall be qualified as per SNT-TC-IA (of the American Society of non-destructive examination). NDT shall be recorded in a report which includes details of methods and equipment used, result/evaluation, job data and identification of personnel employed and details of co-relation of the test report with the job.

In general all plates of thickness greater than 40mm & for pressure parts plates of thickness equal to or greater than 25mm shall be ultrasonically tested otherwise as specified in respective equipment specification. All bar stock/Forging of diameter equal to or greater than 50mm shall be ultrasonically tested.

The Contractor shall list out all major items/ equipment/ components to be manufactured in house as well as procured from sub-contractors (BOI). All the subcontractor proposed by the Contractor for procurement of major bought out items including castings, forging, semi-finished and finished components/equipment etc., list of which shall be drawn up by the Contractor and finalised with the Employer, shall be subject to Employer's approval. The contractor's proposal shall include vendor's facilities established at the respective works, the process capability, process stabilization, QC systems followed, experience list, etc. along with his own technical evaluation for identified subcontractors enclosed and shall be submitted to the Employer for approval within the period agreed at the time of pre-awards discussion and identified in "DR" category prior to any procurement. Such vendor approval shall not relieve the contractor from any obligation, duty or responsibility under the contract.

- 3.12.17 For components/equipment procured by the contractors for the purpose of the contract, after obtaining the written approval of the Employer, the contractor's purchase specifications and inquiries shall call for quality plans to be submitted by the suppliers. The quality plans called for from the subcontractor shall set out, during the various stages of manufacture and installation, the quality practices and procedures followed by the vendor's quality control

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-3: Project Details and General Specification	REV.00

organisation, the relevant reference documents/standards used, acceptance level, inspection of documentation raised, etc.

- 3.12.18 Employer reserves the right to carry out quality audit and quality surveillance of the systems and procedures of the Contractor's or their sub vendor's quality management and control activities. The contractor shall provide all necessary assistance to enable the Employer carry out such audit and surveillance.
- 3.12.19 The contractor shall carry out an inspection and testing programme during manufacture in his work and that of his sub-contractors and at site to ensure the mechanical accuracy of components, compliance with drawings, conformance to functional and performance requirements, identity and acceptability of all materials parts and equipment. Contractor shall carry out all tests/inspection required to establish that the items/equipments conform to requirements of the specification and the relevant codes/standards specified in the specification, in addition to carrying out tests as per the approved quality plan.
- 3.12.20 Quality audit/surveillance/approval of the results of the tests and inspection will not, however, prejudice the right of the Employer to reject the equipment if it does not comply with the specification when erected or does not give complete satisfaction in service and the above shall in no way limit the liabilities and responsibilities of the Contractor in ensuring complete conformance of the materials/equipment supplied to relevant specification, standard, data sheets, drawings, etc.
- 3.12.21 For all spares and replacement items, the quality requirements as agreed for the main equipment supply shall be applicable.
- 3.12.22 Repair/rectification procedures to be adopted to make the job acceptable shall be subject to the approval of the Employer/ authorised representative.

3.12.23 Environmental Stress Screening

All solid state electronic system / equipment / sub assembly shall be free from infant mortile components. For establishing the compliance to this requirement, the contractor / sub – contractor should meet the following.

1. The Contractor / Sub – contractor shall furnish the established procedure being followed for eliminating infant mortile components. The procedure followed by the Contractor / Sub – contractor should be substantiated along with the statistical figures to validate the procedure being followed. The necessary details as required under this clause shall be furnished at the stage of QP finalization.

Or

In case the Contractor / Sub – contractor do not have any established procedure to eliminate infant mortile components then two or 10% whichever is less, most densely populated Panels shall be tested for Elevated Temperature Cycle Test as per the following procedure.

Elevated Temperature Test Cycle

During the elevated temperature test which shall be for 48 hours, the ambient temperature shall be maintained at 50° C. The equipment shall be interconnected with devices and kept under energized conditions so as to repeatedly perform all operations it is expected to perform in actual service with load on various components being equal to those which will be experienced in actual service.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-3: Project Details and General Specification	REV.00

During the elevated temperature test the cubicle doors shall be closed (or shall be in the position same as they are supposed to be in the field) and inside temperature in the zone of highest heat dissipating components / modules shall be monitored. The temperature rise inside the cubicle should not exceed 10° C above the ambient temperature at 50° C.

In case of any failure during the test cycle, the further course of action should be mutually discussed for demonstrating the intent of the above requirement.

Burn In Test Cycle

The test shall be conducted on all the panels fully assembled and wired including the panels having undergone the above mentioned elevated temperature test.

The period of Burn in Test Cycle shall be 120 hrs and process shall be similar to the elevated temperature test as above except that the temperature shall be reduced to the ambient temperature prevalent at that time.

During the above tests, the process I/O and other load on the system shall be simulated by simulated inputs and in the case of control systems, the process which is to be controlled shall also be simulated. Testing of individual components or modules shall not be acceptable.

During the Burn in Test the cubicle doors shall be closed (or shall be in the position same as they are supposed to be in the field) and inside temperature in the zone of highest heat dissipating components / modules shall be monitored. The temperature rise inside the cubicle should not exceed 10° C above the ambient temperature.

The Contractor / Sub-contractor shall carry out routine test on 100% item at contractor / sub-contractor's works. The quantum of check / test for routine & acceptance test by employer shall be generally as per criteria / sampling plan defined in referred standards. Wherever standards have not been mentioned quantum of check / test for routine / acceptance test shall be as agreed during detailed engineering stage.

3.13 QUALITY ASSURANCE DOCUMENTS

The Contractor shall be required to submit two hard copies and two sets on CDROM of the following Quality Assurance Documents as identified in respective quality plan with tick (✓) mark.

Each QA Documentation shall have a project specific Cover Sheet bearing name & identification number of equipment and including an index of its contents with page control on each document.

The QA Documentation file shall be progressively completed by the Supplier's sub-supplier to allow regular reviews by all parties during the manufacturing.

The final quality document will be compiled and issued at the final assembly place of equipment before dispatch. However CD-Rom may be issued not later than three weeks.

3.13.1 Typical contents of Quality Assurance Document are as below:-

- i) Quality Plan,
- ii) Material mill test reports on components as specified by the specification and approved Quality Plans.
- iii) Manufacturer / works test reports/results for testing required as per applicable codes and standard referred in the specification and approved Quality Plans.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-3: Project Details and General Specification	REV.00

- iv) Non-destructive examination results /reports including radiography interpretation reports. Sketches/drawings used for indicating the method of traceability of the radiographs to the location on the equipment.
 - v) Heat Treatment Certificate/Record (Time- temperature Chart)
 - vi) All the accepted Non-conformance Reports (Major/Minor) / deviation, including complete technical details / repair procedure).
 - vii) CHP / Inspection reports duly signed by the Inspector of the Employer and Contractor for the agreed Customer Hold Points.
 - viii) Certificate of Conformance (COC) whoever applicable.
 - ix) MDCC
- 3.13.2 Similarly, the contractor shall be required to submit two hard copies and two sets on CD ROM of Quality Assurance Documents (in line with above) pertaining to field activities as per Approved Field Quality Plans and other agreed manuals/ procedures, prior to commissioning of individual system.
- 3.13.3 Before dispatch/ commissioning of any equipment, the Supplier shall make sure that the corresponding quality document or in the case of protracted phased deliveries, the applicable section of the quality document file is completed. The supplier will then notify the Inspector regarding the readiness of the quality document (or applicable section) for review.
- i) If the result of the review carried out by the Inspector of the Quality document (or applicable section) is satisfactory. The Inspector shall stamp the quality document (or applicable section) for release.
 - ii) If the quality document is unsatisfactory, the Supplier shall endeavour to correct the incompleteness, thus allowing finalizing the quality document (or applicable section) by time compatible with the requirements as per contract documents. When it is done, the quality document (or applicable section) is stamped by the Inspector.
 - i) If a decision is made for dispatch, whereas all outstanding actions cannot be readily cleared for the release of the quality document by that time, the supplier shall immediately, upon shipment of the equipment, send a copy of the quality document Review Status signed by the Supplier Representative to the Inspector and notify of the committed date for the completion of all outstanding actions & submission. The Inspector shall stamp the quality document for applicable section when it is effectively completed. The submission of QA documentation package shall not be later than 3 weeks after the dispatch of equipment.

3.14 TRANSMISSION OF QUALITY DOCUMENTS

As a general rule, two hard copies of the quality document and Two CD ROMs shall be issued to the Employer after the delivery date for the corresponding equipment. One set of quality document shall be forwarded to Corporate Quality Assurance Department and other set to respective Site.

For the particular case of phased deliveries, the complete quality document to the Employer shall be issued not later than 1 month after the date of the last delivery similarly as stated above.

3.15 INSPECTION, TESTING & INSPECTION CERTIFICATE

- 3.15.1 The word 'Inspector' shall mean the Project Manager and/or his authorised representative and/or an outside inspection agency acting on behalf of the Employer to inspect and examine the materials and workmanship of the works during its manufacture or erection.
- 3.15.2 The Project Manager or his duly authorised representative and/or an outside inspection agency acting on behalf of the Employer shall have access at all reasonable times to inspect

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-3: Project Details and General Specification	REV.00

and examine the materials and workmanship of the works during its manufacture or erection and if part of the works is being manufactured or assembled on other premises or works, the Contractor shall obtain for the Project Manager and for his duly authorised representative permission to inspect as if the works were manufactured or assembled on the Contractor's own premises or works.

- 3.15.3 The Contractor shall give the Project Manager/Inspector fifteen (15) days written notice of any material being ready for testing. Such tests shall be to the Contractor's account except for the expenses of the Inspector's. The Project Manager/Inspector, unless the witnessing of the tests is virtually waived, will attend such tests within fifteen (15) days of the date on which the equipment is noticed as being ready for test/inspection failing which the contractor may proceed with test which shall be deemed to have been made in the inspector's presence and he shall forthwith forward to the inspector duly certified copies of test reports in two (2) copies.
- 3.15.4 The Project Manager or Inspector shall within fifteen (15) days from the date of inspection as defined herein give notice in writing to the Contractor, or any objection to any drawings and all or any equipment and workmanship which is in his opinion not in accordance with the contract. The Contractor shall give due consideration to such objections and shall either make modifications that may be necessary to meet the said objections or shall inform in writing to the Project Manager/Inspector giving reasons therein, that no modifications are necessary to comply with the contract.
- 3.15.5 When the factory tests have been completed at the Contractor's or subcontractor's works, the Project Manager /Inspector shall issue a certificate to this effect fifteen (15) days after completion of tests but if the tests are not witnessed by the Project Manager /Inspectors, the certificate shall be issued within fifteen (15) days of the receipt of the Contractor's test certificate by the Project Manager /Inspector. Project Manager /Inspector to issue such a certificate shall not prevent the Contractor from proceeding with the works. The completion of these tests or the issue of the certificates shall not bind the Employer to accept the equipment should it, on further tests after erection be found not to comply with the contract.
- 3.15.6 In all cases where the contract provides for tests whether at the premises or works of the Contractor or any sub-contractor, the Contractor, except where otherwise specified shall provide free of charge such items as labour, material, electricity, fuel, water, stores, apparatus and instruments as may be reasonably demanded by the Project Manager /Inspector or his authorised representatives to carry out effectively such tests on the equipment in accordance with the Contractor and shall give facilities to the Project Manager/Inspector or to his authorised representative to accomplish testing.
- 3.15.7 The inspection by Project Manager / Inspector and issue of Inspection Certificate thereon shall in no way limit the liabilities and responsibilities of the Contractor in respect of the agreed Quality Assurance Programme forming a part of the contract.
- 3.15.8 To facilitate advance planning of inspection in addition to giving inspection notice, the Contractor shall furnish quarterly inspection programme indicating schedule dates of inspection at Customer Hold Point and final inspection stages. Updated quarterly inspection plans will be made for each three consecutive months and shall be furnished before beginning of each calendar month.
- 3.15.9 All inspection, measuring and test equipments used by contractor shall be calibrated periodically depending on its use and criticality of the test/measurement to be done. The Contractor shall maintain all the relevant records of periodic calibration and instrument identification, and shall produce the same for inspection by NTPC. Wherever asked specifically, the contractor shall re-calibrate the measuring/test equipments in the presence of Project Manager / Inspector.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-3: Project Details and General Specification	REV.00

3.16 PACKAGING & TRANSPORTATION

Items shall be packed & dispatched separately to respective sites i.e. to 400/220kV S/s at NKSTPP end & to 220kV S/s at Chatti Bariatu & Kerandari-A mine end.

3.16.1 Packing, Marking and shipping

The packing and shipping shall be carried out in accordance with the standard practice of Contractor and with the following additional requirements:

- a) The equipment shall be prepared in such a manner as to protect the equipment from damage or deterioration during shipping or storage. The shipments can be exposed to heavy rains, hot sun, high humidity and sudden extreme changes of temperature. The equipment shall be packed and shipped so as to protect it from all such conditions and any other abnormal conditions, generally expected during shipping & storage.
- b) The metallic containers, if any, shall be considered as the property of the Contractor and he will be allowed to remove them from site once the contents are unpacked, inspected, documented and placed in temporary storage or in final position.
- c) The equipment shall be shipped in such a manner as to facilitate unloading, handling and storage enroute and at the site. The Contractor shall provide lifting lugs and special lifting devices for proper handling and erection.
- d) The Contractor shall be liable for any damage or loss resulting due to careless, improper, poor or insufficient packing and handling.
- e) Spare parts and spare equipment shall be packed separately in containers adequate for long term storage, plainly marked "Spare Parts Only". They shall be crated individually or in kits to be used in one single renewal or overhaul operation. Other spare part kits shall not be disturbed when using one set or kit.
- f) The Contractor shall at all times protect and preserve from damage, loss, corrosion and all other forms of damage, all parts of the works.

3.16.2 Transportation

- a) The Contractor shall make a careful examination of access rail/roadways to the site in order to confirm the practical maximum transport weight and dimensions as well as a careful examination of the ports of disembarkation particularly with respect to the capacity of the cranes installed and access roads.
- b) All instruments and computer/microprocessor based equipment imported into India from overseas for the purpose of this contract shall be air freighted to the nearest possible point and further by rail/road taking due precautions as per manufacturer's recommendations. Employer shall have the right to decide the items that should be air freighted and Employer's decision shall be binding on Contractor.

3.16.3 Insurance

- a) The Contractor shall insure all shipments and works at his own expense for not less than the full replacement cost plus any additional cost for accelerated manufacturing of the replacement parts.
- b) Loss or the damage to equipment during shipping or transportation to the site(s) or otherwise

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-3: Project Details and General Specification	REV.00

shall not constitute groups for claims for extension in time or for extra payment.

3.17 CLAMPS AND CONNECTORS INCLUDING TERMINAL CONNECTORS

- 3.17.1 The material of clamps and connectors shall be Aluminium alloy casting conforming to designation A6 of IS:617 for connecting to equipment terminals and conductors of aluminium. In case the terminals are of copper, the same clamps/connectors shall be used with 2mm thick bimetallic liner.
- 3.17.2 The material of clamps and connectors shall be Galvanised mild steel for connecting to shield wire.
- 3.17.3 Bolts, nuts and plain washers shall be hot dip galvanised mild steel for sizes M12 and above. For sizes below M12, they shall be electro-galvanised mild steel. The spring washers shall be electro-galvanised mild steel.
- 3.17.4 All castings shall be free from blow holes, surface blisters, cracks and cavities. All sharp edges and corners shall be rounded off to meet specified corona and radio interference requirements.
- 3.17.5 They shall have same current rating as that of the connected equipment. All current carrying parts shall be at least 10 mm thick. The connectors shall be manufactured to have minimum contact resistance.
- 3.17.6 Flexible connectors, braids or laminated strips shall be made up of copper/aluminium.
- 3.17.7 Current rating and size of terminal/conductor for which connector is suitable shall be put on a suitable sticker on each component which should last atleast till erection time.

3.18 BUSHINGS, HOLLOW COLUMN INSULATORS, SUPPORT INSULATORS, AND DISC INSULATORS

- 3.18.1 Bushings shall be manufactured and tested in accordance with IS: 2099 & IEC: 137 while hollow column insulators shall be manufactured and tested in accordance with IEC 233/IS 5284. The support insulators shall be manufactured and tested as per IS: / IEC 168/IEC 273. The insulators shall also conform to IEC 815 as applicable. Support insulators/ bushings/ hollow column insulators shall be designed to have ample insulation, mechanical strength and rigidity for the conditions under which they will be used.
- 3.18.2 Porcelain used shall be homogenous, free from laminations, cavities and other flaws or imperfections that might affect the mechanical or dielectric quality and shall be thoroughly vitrified, tough and impervious to moisture. Hollow porcelain should be in one integral piece in green & fired stage.
- 3.18.3 Glazing of the porcelain shall be uniform brown in colour, free from blisters, burns and other similar defects.
- 3.18.4 When operating at normal rated voltage there shall be no electric discharge between conductor and insulators which would cause corrosion or injury to conductors or when operating at normal rated voltage.
- 3.18.5 The design of the insulator shall be such that stresses due to expansion and contraction in any part of the insulator shall be lead to deterioration. All ferrous parts shall be hot dip galvanised.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-3: Project Details and General Specification	REV.00

- 3.18.6 Bushing porcelain shall be robust and capable of withstanding the internal pressures likely to occur in service. The design and location of clamps, the shape and the strength of the porcelain flange securing the bushing to the tank shall be such that there is no risk of fracture. All portions of the assembled porcelain enclosures and supports other than gaskets, which may in any way be exposed to the atmosphere shall be composed of completely non hygroscopic material such as metal or glazed porcelain.
- 3.18.7 All iron parts shall be hot dip galvanised and all joints shall be air tight. Surface of joints shall be trued, porcelain parts by grinding and metal parts by machining. Insulator/ bushing design shall be such as to ensure a uniform compressive pressure on the joints.
- 3.18.8 Insulator shall also meet requirement of IEC - 815 as applicable, having alternate long & short sheds.

3.19 CONTROL CABINETS, JUNCTION BOXES, TERMINAL BOXES & MARSHALLING BOXES FOR OUTDOOR EQUIPMENT.

- 3.19.1 All types of control cabinets, junction boxes, marshaling boxes, lighting panels, terminal boxes, operating mechanism boxes, Kiosks etc. shall generally conform to IS:5039, IS:8623 and IEC:439 as applicable.

- 3.19.2 **Mechanism Box/ Control Cabinet/ Kiosks:** A sheet steel (atleast 2.5 mm thick), dust and vermin proof M.Box/CCC/CMB shall be provided with proper lighting and thermostatically controlled space heaters. The degree of protection shall be IP 55. One dummy terminal block in between each trip wire terminal shall be provided. At least 20% spare terminals shall be provided on each panel. The gasket used shall be of neoprene rubber.

Painting of boxes shall be as follows,

- External surface : Chemical resistant epoxy zinc phosphate primer, MIO (Micaceous iron oxide) as intermediate paint followed by polyurethane finish paint (**RAL 5012 Blue**)
- Internal surface : Chemical resistant epoxy zinc phosphate primer followed by chemical & heat resistant **epoxy enamel white paint**.

- 3.19.3 **Junction Boxes:** The junction boxes shall be made of minimum 2 mm thick sheet steel. Gland plates shall be removable type and made of 3 mm thick sheet steel. The boxes shall be provided with detachable cover or hinged door with captive screws. Top of the box shall be arranged to slope towards the rear of the box. The box shall be **hot dip galvanised** and shall be provided with suitable neoprene gaskets to achieve requisite degree of protection. Adequate spacing shall be provided to terminate the external cables. The boxes shall be suitable for mounting on various types of steel structures. The terminal blocks provided shall be of 650 V grade, rated for 10 A for control cables. Suitable numbering for terminal blocks shall be done. In case of junction box for power cable, the box shall be rated for maximum current carrying capacity. Terminal blocks shall be of one piece, Klippon RSF-1 or ELMEX CSLT-1 type with insulating barriers.
- 3.19.4 The cabinets/boxes/kiosks/panels shall be free standing or wall mounting or pedestal mounting type. They shall have hinged doors with padlocking arrangement. All doors, removable covers and plates shall be gasketed all around with neoprene gaskets.
- 3.19.5 The degree of protection of of all the outdoor boxes shall not be less than IP 55 as per IS 2147.
- 3.19.6 The cable entry shall be from bottom, for which removable gasketed cable gland plates shall be provided.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-3: Project Details and General Specification	REV.00

- 3.19.7 Suitable 240V, single phase, 50Hz ac heaters with thermostats controlled by switch and fuse shall be provided to maintain inside temperature 10deg. above the ambient.
- 3.19.8 The size of enclosure and the layout of equipment inside shall provide generous clearances. Each cabinet/box/kiosk/panel shall be provided with a 15A, 240V ac, 2 pole, 3 pin industrial grade receptacle with switch. For incoming supply, MCB of suitable rating shall be provided. Illumination of each compartment shall be with door operated incandescent lamp. All control switches shall be of rotary switch type.
- 3.19.9 Each cabinet/box/kiosk/panel shall be provided with two earthing pads to receive 75mmx12mm GS flat. The connection shall be bolted type with two bolts per pad. The hinged door shall be connected to body using flexible wire. The cabinets/boxes/kiosks/panels shall also be provided with danger plate, and internal wiring diagram pasted on inside of the door. The front label shall be on a 3mm thick plastic plate with white letters engraved on black background

3.20 TERMINAL BLOCKS

- 3.20.1 They shall be non-disconnecting stud type of extensible design equivalent to Elmex type CAT-M4.
- 3.20.2 The terminal blocks shall be of 650 V grade, and rated to continuously carry maximum expected current. The conducting part shall be tinned or silver plated.
- 3.20.3 They shall be of moulded, non-inflammable thermosetting plastic. The material shall not deteriorate with varied conditions of temperature and humidity. The terminal blocks shall be fully enclosed with removable covers of transparent, non deteriorating plastic material. Insulating barriers shall be provided between the terminal blocks so that the barriers do not hinder the wiring operation without removing the barriers.
- 3.20.4 The terminals shall be provided with marking tags for wiring identification.
- 3.20.5 Unless otherwise required (expected current rating) or specified, terminal blocks shall be suitable for connecting the following conductors on each side:
All CT & VT circuits - Min. four 2.5 sq.mm. copper flexible conductor
AC & DC power supply -Two 16 sq.mm. Aluminium conductor
Other control circuits - Min. two 2.5 sq.mm. copper flexible conductor.
- 3.20.6 The terminal blocks for CT and VT secondary leads shall be provided with test links and isolating facilities. CT secondary leads shall also be provided with short circuiting and earthing facilities.

3.21 Wiring

- 3.21.1 All wiring shall be carried out with 1100 V grade stranded copper wires. The minimum size of the stranded conductor used for internal wiring shall be as follows:
a) All circuits except CT circuits 2.5 sq.mm
b) CT circuits 4 sq. mm (minimum number of strands shall be 3 per conductor).
- 3.21.2 All internal wiring shall be securely supported, neatly arranged readily accessible and connected to equipment terminals and terminal blocks.
- 3.21.3 Wire terminations shall be made with solderless crimping type of tinned copper lugs which firmly grip the conductor and insulation. Insulated sleeves shall be provided at all the wire terminations. Engraved core identification plastic ferrules marked to correspond with the wiring diagram shall be fitted at both ends of each wire. Ferrules shall fit tightly on the wires

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-3: Project Details and General Specification	REV.00

shall not fall off when the wires and shall not fall off when the wire is disconnected from terminal blocks.

- 3.21.4 All wires directly connected to trip circuit breaker shall be distinguished by the addition of a red coloured unlettered ferrule. Number 6 & 9 shall not be included for ferrules purposes.
- 3.21.5 All terminals including spare terminals of auxiliary equipment shall be wired upto terminal blocks. Each equipment shall have its own central control cabinet in which all contacts including spare contacts from all poles shall be wired out. Interpole cabling for all equipment's shall be carried out by the Contractor.

3.22 CABLE GLANDS AND LUGS

- 3.22.1 Cable glands shall be Double compression type, tinned/Nicked plated (coating thickness not less than 20 microns in case of tin and 10 to 15 microns in case of nickel) brass cable glands for all power and control cables. They shall provide dust and weather proof terminations. They shall comprise of heavy duty brass casting, machine finished and tinned to avoid corrosion and oxidation. Rubber components used in cable glands shall be neoprene and off tested quality. Required number of packing glands to close unused openings in gland plates shall also be provided.
- 3.22.2 The cable glands shall be tested as per BS:6121. The cable glands shall also be duly tested for dust proof and weather proof termination.
- 3.22.3 Cables lugs for power cables shall be tinned copper solder less crimping type conforming to IS:8309 and 8394 suitable for aluminum or copper conductor (as applicable). Cable lugs and ferrules for control cables shall be tinned copper type. The cable lugs for control cables shall be provided with insulating sleeve and shall suit the type of terminals provided on the equipments. The cable lugs shall suit the type of terminals provided. The cable lugs shall be of Dowell make or equivalent.

3.4 CONDUITS, PIPES AND ACCESSORIES

- 3.4.1 The bidder shall supply and install all rigid conduits, mild steel pipes, flexible conduits, hume pipes, etc. including all necessary sundry materials, such as tees, elbows, check nuts, bushing reduces, enlargers, wooden plugs, coupling caps, nipples, gland sealing fittings, pull boxes, etc.
- 3.4.2 Rigid conduits shall be flow-coat metal conduits of Nagarjuna Coated Tubes or equivalent make. The outer surface of the conduits shall be coated with hot-dip zinc and chromate conversion coatings. The inner surface shall have silicone epoxy ester coating for easy cable pulling. Mild steel pipes shall be hot-dip galvanised. All rigid conduits/ pipes shall be of a reputed make.
- 3.4.3 Flexible conduits shall be heat-resistant lead coated steel, water-leak, fire and rust proof, and be of PLICA make or equivalent.

3.5 MOTOR CONTROL CENTRE

- 3.5.1 The 415 Volt motor control centres (if provided separately) shall conform to the requirements for boxes/cabinets/kiosks. They shall be fixed type, shall be fully sectionalised and shall be equipped with load break switches. Motor feeders shall be provided with isolating switch fuse unit and Contractor with thermal overload relay and single phase protection. The motor Contractor shall have one normally open auxiliary contact for alarm purposes. The motor control circuit shall be independent from all other control circuits.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-3: Project Details and General Specification	REV.00

3.5.2 Isolating Switches

The incoming power supply isolating switch operation handle shall be interlocked with the control cabinet door as to prevent opening of door when main switch is closed. Device for by passing the door interlock shall also be provided. Switch handle shall have provision for locking in both fully open and fully closed positions.

3.5.3 Fuses

All fuses shall be of the HRC cartridge type, conforming to IS: 2208 and suitable to mount on plug-in type of fuse bases. Fuses shall be provided with visible operation indicators to show that they have operated. All accessible live connections shall be adequately shrouded, and it shall be possible to change fuses with the circuit alive, without danger of contact with live conductor. Insulated fuse pulling handle shall be supplied with each control cabinet.

3.6 MOTORS

3.6.1 Motors shall be “Squirrel Cage” three phase induction motors of sufficient size capable of satisfactory operation for the application and duty as required for the driven equipment and shall conform to type tests and shall be subjected to routine tests as per applicable standards.

3.6.2 Enclosures

- a) For motors to be installed outdoor, the motor enclosure shall have degree of protection IP: 55. For motors to be installed indoor, i.e. inside a box, the motor enclosure shall be dust proof equivalent to IP: 54.
- b) Two independent earthing points shall be provided on opposite sides of the motor for bolted connection of earthing conductor.
- c) Motors shall have drain plugs so located that they will drain water resulting condensation or other causes from all pockets in the motor casing.

3.6.3 Operational Features :

- a) Continuous motor ratings (name plate rating) shall be at least suitable for the driven equipment at design duty operating point of driven equipment that will arise in service.
- b) Motors shall be capable of giving rated output without reduction in the expected life span when operated continuously in the given system.

3.6.4 Starting Requirements

- a) All induction motors shall be suitable for full voltage direct on-line starting. These shall be capable of starting and accelerating to the rated speed alongwith the driven equipment without exceeding the acceptable winding temperature even when the supply voltage drops.
- b) Motors shall be capable of withstanding the electrodynamic stresses and heating imposed if it is started at a voltage of 110% of the rated value.
- c) The locked rotor current shall not exceed six(6) times the rated full load current for all motors subject to tolerance given in IS:325.
- d) Motors when started with driven equipment imposing full starting torque and supply voltage conditions specified shall be capable of withstanding at least two successive starts from cold condition at room temperature and one start from hot condition without injurious heating of winding. The motors shall also be suitable for three equally spread starts per hour under the above referred supply condition.
- e) The locked rotor withstand time under hot condition at 110% of rated voltage shall be more than starting time with the driven equipment of minimum permissible voltage by a least two seconds or 15% of the accelerating time whichever is greater. In case it is not possible to meet the above requirement, the Contractor shall offer centrifugal type speed switch mounted on the motor shaft which shall remain closed for speeds lower

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-3: Project Details and General Specification	REV.00

than 20% and open for speeds above 20% of the rated. The speed switch shall be capable of withstanding 120% of the rated speed in either directions of rotation.

- 3.6.5 The maximum permissible temperature rise over the ambient temperature shall be within the limits specified in IS: 325 (for 3 phase induction motors) after adjustment due to increased ambient temperature specified.
- 3.6.6 The double amplitude of motor vibration shall be within the limits specified in IS:729. Vibration shall also be within the limits specified by the relevant standard for the driven equipment when measured at the motor bearings.
- 3.6.7 All the induction motors shall be capable of running at 80% of rated voltage for a period of 5 minutes.

3.7 AUXILIARY SWITCH

The auxiliary switch shall conform of following type tests:

- Electrical endurance test - A minimum of 1000 operations for 2A. D.C. with a time constant greater than or equal to 20 milliseconds with a subsequent examination of mV drop/ visual defects/ temperature rise test.
- Mechanical endurance test - A minimum of 5000 operations with a subsequent checking of contact pressure test/ visual examination
- Heat run test on contacts
- IR/HV test, etc.

3.8 LAMPS AND SOCKETS

3.8.1 Lamps:

All incandescent lamps shall use a socket base as per IS-1258, except in the case of signal lamps.

3.8.2 Sockets

All sockets (convenience outlets) shall be suitable to accept both 5 Amp & 15 Amp pin round Standard Indian plugs. They shall be switched sockets with shutters.

3.8.3 Hand Lamp:

A 240 Volts, single Phase, 50 Hz AC plug point shall be provided in the interior of each cubicle with ON-OFF Switch for connection of hand lamps.

3.9 SWITCHES & FUSES:

Each control panel shall be provided with necessary arrangements for receiving, distributing, isolating and fusing of DC and AC supplies for various control, signaling, lighting and space heater circuits. The incoming and sub-circuits shall be separately provided with switch-fuse units. Selection of the main and sub-circuit fuse ratings shall be such as to ensure selective clearance of sub-circuit faults. Potential circuits for relaying and metering shall be protected by HRC fuses.

All fuses shall be of HRC cartridge type conforming to IS 9228 mounted on plug-in type fuse bases. Miniature circuit breakers with thermal Protection and alarm contacts will also be accepted. All accessible live connection to fuse bases shall be adequately shrouded. Fuses shall have operation indicators for indicating blown fuse condition. Fuse carrier base shall have imprints of the fuse rating and voltage.

All control switches shall be of rotary type. Toggle/piano switches shall not be accepted.

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-3: Project Details and General Specification	REV.00

3.10 TYPE, ROUTINE & ACCEPTANCE TESTS:

All equipments to be supplied shall be of type tested design. During contract stage, bidder shall submit for Owner's approval the reports of all the type tests listed in this specification and carried out within last ten years from the date **28.04.2021**. These reports should be for the test conducted on the equipment similar to those proposed to be supplied under this contract and the tests should have been either conducted at an independent laboratory or should have been witnessed by a client.

However if contractor is not able to submit report of the type tests conducted within ten years from the date **28.04.2021** or in the case of type test reports are not found to be meeting the specification requirements, the bidder shall conduct all such tests under this contract at no additional cost to the owner either at third party lab or in presence of client/ owners representative and submit the reports for approval.


All acceptance and routine tests as per the specification and relevant standards shall be carried out. Charges for these shall be deemed to be included in the equipment price.


3.11 CORONA AND RIV TESTS AND SEISMIC WITHSTAND TEST:


- a) The corona (for 400kV only) and RIV tests shall confirm to the requirements as per Annexure A.
- b) The seismic withstand test for 400kV shall conform to requirements as per Annexure B.

3.12 Enclosures:

1. ANNEXURE- A - CORONA AND RADIO INTERFERENCE VOLTAGE (RIV) TEST
2. ANNEXURE- B - SEISMIC WITHSTAND TEST
3. ANNEXURE- I – MQP (NTPC format)

CLAUSE NO.	<div style="text-align: center;">TECHNICAL REQUIREMENTS</div> 		
	Annexure – A		
	CORONA AND RADIO INTERFERENCE VOLTAGE (RIV) TEST		
1.0	General Unless otherwise stipulated, all equipment together with its associated connectors where applicable shall be tested for external corona both by observing the voltage level for the extinction of visible corona under falling power frequency voltage and measurement of radio interference voltage (RIV).		
2.0	Test Levels The test voltage levels for measurement of external RIV and for corona extinction voltage are listed under the relevant clauses of the specification.		
3.0	Test Methods for RIV:		
3.1	RIV tests shall be made according to measuring circuit as per International Special – committee on Radio Interference (CISPR) Publication 16 -1 (1993) Part – I. The measuring circuit shall preferably be tuned to frequency with 10 % of 0.5 MHz but other frequencies in the range of 0.5 MHz to 2 MHz may be used, the measuring frequency being recorded. The result shall be in microvolts.		
3.2	Alternatively, RIV tests shall be in accordance with NEMA standard Publication No. 107 – 1964 except otherwise noted herein.		
3.3	In measurement of RIV temporary additional external corona shielding may be provided. In measurement of RIV only standard fittings of identical type supplied with the equipment and a simulation of the connections as used in the actual installation will be permitted in the vicinity within 3.5 meters of terminals.		
3.4	Ambient noise shall be measured before and after each series of tests to ensure that there is no variation in ambient noise level. If variation is present, the lowest ambient noise level will form basis for the measurements. RIV levels shall be measured at increasing and decreasing voltages of 85% , 100%, 115% and 130% for the specified RIV test voltage for all equipment unless otherwise specified. The specified RIV test voltage for 420 KV is listed in the detailed specification together with maximum permissible RIV level in microvolts.		
3.5	The metering instruments shall be as per CISPR recommendations or equivalent device so long as it has been used by other testing authorities.		
3.6	The RIV measurement may be made with a noise meter. A calibration procedure of the frequency to which noise meter shall be tuned shall establish the ratio of voltage at the high voltage terminal to the voltage read by the noise meter.		
4.0	Test Methods for visible Corona The purpose of this test is to determine the corona extinction voltage of the apparatus, connectors etc. The test shall be carried out in the same manner as RIV test described above with the exception that RIV measurements are not required during test and a search technique shall be used near the onset and extinction voltage, when the test voltage is raised and lowered to determine their precise values. The test voltage shall be raised to		
NORTH KARANPURA STPP (3 X 660 MW) EPC PACKAGE	TECHNICAL SPECIFICATIONS SECTION VI, PART-B BID DOC. NO.:CS-4410-001-2	SUB SECTION B-14 SWITCHYARD	Page 6 of 102


CLAUSE NO.	TECHNICAL REQUIREMENTS 		
	<p>130 % of RIV test voltage and maintained there for five minutes. In case corona inception does not take place at 130 %, the voltage level shall be raised till inception of corona or rated voltage whichever is lower. The voltage will then be decreased slowly until all visible corona disappears. The test procedure shall be repeated at least 4 times with corona inception and extinction voltage recorded each time. The corona extinction voltage for purposes of determining compliance with the specification shall be the lowest of the four values at which the visible corona (negative or positive polarity) disappears.</p>		
NORTH KARANPURA STPP (3 X 660 MW) EPC PACKAGE	TECHNICAL SPECIFICATIONS SECTION VI, PART-B BID DOC. NO.:CS-4410-001-2	SUB SECTION B-14 SWITCHYARD	Page 7 of 102

CLAUSE NO.	TECHNICAL REQUIREMENTS 		
	<p style="text-align: right;">Annexure – B</p> <p>SEISMIC WITHSTAND TEST</p> <p>The seismic withstand test on the complete equipment (except BPI) shall be carried out along with supporting structure.</p> <p>The bidder shall arrange to transport the structure from his contractor's premises / owner's sites for purpose of seismic withstand test only.</p> <p>The seismic level specified shall be applied at the base of the structure. The accelerometers shall be provided at the terminal pad of the equipment and at any other point as agreed by the owner. The seismic test shall be carried out in all possible combinations of the equipment. The seismic test procedure shall be furnished for approval of the purchaser.</p>		
NORTH KARANPURA STPP (3 X 660 MW) EPC PACKAGE	TECHNICAL SPECIFICATIONS SECTION VI, PART-B BID DOC. NO.:CS-4410-001-2	SUB SECTION B-14 SWITCHYARD	Page 8 of 102

ANNEXURE-I

MFGR.'s LOGO	MANUFACTURER'S NAME AND ADDRESS	MANUFACTURING QUALITY PLAN		PROJECT :
		ITEM :	QP NO.:	PACKAGE :
		SUB-SYSTEM:	REV.NO.:	CONTRACT NO. :
			DATE:	MAIN-SUPPLIER:
			PAGE: OF....	

SL. NO	COMPONENT & OPERATIONS	CHARACTERISTICS	CLASS	TYPE OF CHECK	QUANTUM OF CHECK		REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD		AGENCY			REMARKS
					M	C/N				D*	M	C	N	
1. 2.		3.	4.	5.	6.		7.	8.	9.	D*	**	10.		11.

		LEGEND: * RECORDS, IDENTIFIED WITH "TICK" (√) SHALL BE ESSENTIALLY INCLUDED BY SUPPLIER IN QA DOCUMENTATION. ** M: MANUFACTURER/SUB-SUPPLIER C: MAIN SUPPLIER, N: NTPC P: PERFORM W: WITNESS AND V: VERIFICATION. AS APPROPRIATE, CHP: NTPC SHALL IDENTIFY IN COLUMN "N" AS "W"			DOC. NO.:		REV..... CAT.....	
MANUFACTURER/ SUB-SUPPLIER	MAIN-SUPPLIER		FOR NTPC USE					
SIGNATURE					REVIEWED BY	APPROVED BY	APPROVAL SEAL	

FORMAT NO.: QS-01-QAI-P-09/F1-R1

1/1

ENGG. DIV./QA&I

NORTH KARANPURA STPP (3X660 MW) EPC PACKAGE	TECHNICAL SPECIFICATION SECTION – VI, PART-C BID DOC. NO.:CS-4410-001-2	GENERAL TECHNICAL REQUIREMENT	PAGE 78 OF 100
---	---	-------------------------------	----------------


PROJECT 400/220kV Switchyard for North Karanpura Super TPP (3x660MW) CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators Section-4: Guaranteed Technical Particulars	TB-316-369-002 REV.00


SECTION - 4


GUARANTEED TECHNICAL PARTICULARS FOR ISOLATORS


(To be furnished during detailed engineering)

- NTPC datasheet for Isolators (4 pages)
- NTPC datasheet for control cabinets (1 page)

CLAUSE NO.	Bidder's Name		
3.	<p>c) Closing time of</p> <p> i) Isolator (sec)</p> <p> ii) Earth switch (sec)</p> <p>Dielectric with-stand capacity of Completely assembled Isolator and earth switch</p> <p>a) One minute power frequency withstand test voltage (kV) rms</p> <p> i) against ground (kV peak)</p> <p> - dry (kV rms)</p> <p> - Wet (kV rms)</p> <p>b) 1.2/50 micro second impulse withstand test voltage</p> <p> i) against ground (kV peak)</p> <p> ii) across open contacts (kV peak)</p> <p>c) 250/2500 micro second switching surge withstand test voltage (dry & wet)</p> <p> i) against ground (kV peak)</p> <p> ii) across open contacts (kV peak)</p> <p>d) Corona extinction voltage (kV rms)</p> <p>e) Radio interference level at $1.1 \times U_m/\sqrt{3}$ (in micro volts) for frequency between 0.5 MHz to 2.0 MHz</p> <p>f) Total creepage distance to ground (mm)</p>		
NORTH KARANPURA STPP (3X660 MW) EPC PACKAGE	TECHNICAL DATA SHEETS SECTION – VI, PART-G BID DOC.NO.:CS-4410-001-2	DB12B: ISOLATOR	PAGE 2 OF 4

CLAUSE NO.	Bidder's Name			
4.	Operating Mechanism		
	a) Type and rating (KW) of motor		
	b) Rated voltage of motor		
4.1	Interlockings		
	a) Whether mechanical/ constructional interlock between Isolator and Earth switch provided	Yes/No	
	b) Whether interlock coil is continuously rated		
5	Constructional Features			
	a) Main contacts		
	i) Type of contacts		
	ii) Contact area (cm ²)		
	iii) Material of contacts		
	iv) Contact pressure (Kg/cm ²)		
	v) Maximum current density under normal current carrying capacity (Amp/cm ²)		
	vi) Thickness of silver plating		
	b) Auxiliary contacts on Isolator		
	i) Total number		
	i) NO		
	iii) NC		
iv) Adjustable			
v) Make before break			
NORTH KARANPURA STPP (3X660 MW) EPC PACKAGE		TECHNICAL DATA SHEETS SECTION – VI, PART-G BID DOC.NO.:CS-4410-001-2	DB12B: ISOLATOR	PAGE 3 OF 4

CLAUSE NO.	Bidder's Name		
	<p>vi) Rated voltage (volts)</p> <p>vii) Rated continuous current (Amps)</p> <p>i) Rated DC breaking current with 20 ms time constant (A)</p> <p>c) Auxiliary contacts on earth switch</p> <p>i) Total number</p> <p>i) NO</p> <p>iii) NC</p> <p>iv) Adjustable</p> <p>v) Rated Voltage (volts)</p> <p>vi) Rated continuous current (Amps)</p> <p>vii) Rated DC breaking current with 20 ms time constant (A)</p> <p>e) Whether details of constructional interlock enclosed Yes/No</p>		
<p>NORTH KARANPURA STPP (3X660 MW) EPC PACKAGE</p>	<p>TECHNICAL DATA SHEETS SECTION – VI, PART-G BID DOC.NO.:CS-4410-001-2</p>	<p>DB12B: ISOLATOR</p>	<p>PAGE 4 OF 4</p>

CLAUSE NO.	Bidder's Name		
A.	DB:12G		
	EHV SWITCHYARD AUXILIARY ITEMS		
	CONTROL CABINETS		
	(Bidder shall furnish this data for each equipment marshalling box/operating mechanism box separately i.e.Bay Marshalling Box, cabinets of breakers, disconnecting switches, instrument transformers, lighting panels, etc.)		
	1. Manufacturer's Name and country of origin	
	2. Design ambient air temperature (°C)	
	3. Standards Applicable	
	4. Thickness of sheet steel (mm) and whether cold rolled or hot rolled	
	5. Degree of protection provided	
	6. Shede of finish paint as per RAL a) Outside b) Inside	
B.	TERMINAL CLAMPS AND CONNECTORS, AND SPACERS		
	(Bidder shall furnish this data for Terminal clamps and connector separately for each type and equipment)		
	1. Manufacturer's Name and address	
	2. Applicable Standards	
C.	INSULATOR HARDWARE		
	(Bidder shall furnish this data separately for each type and rating)		
	1. Manufacturer	
NORTH KARANPURA STPP (3X660 MW) EPC PACKAGE	TECHNICAL DATA SHEETS SECTION – VI, PART-G BID DOC.NO.:CS-4410-001-2	DB12G:AUXILIARY ITEMS	PAGE 1 OF 2

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-5: Quality Plan	REV.00

SECTION - 5

QUALITY PLAN

Supplier shall follow valid approved Quality Plan of NTPC.

-X-

SECTION 6

TECHNICAL CHECK LIST FOR ISOLATORS / EARTHING SWITCHES

(INFORMATION TO BE FURNISHED WITH OFFER)

BIDDERS ARE INSTRUCTED TO

- WRITE 'YES' UNDER CLOUMN 'Confirmation', IF THE INFORMATION / SCHEDULE IS FURNISHED / ENCLOSED WITH THE OFFER, **OR**
- WRITE 'NO' UNDER CLOUMN 'Confirmation', IF THE INFORMATION / SCHEDULE IS NOT FURNISHED / ENCLOSED WITH THE OFFER, **OR**
- WRITE 'NOT APPLICABLE (NA)' UNDER CLOUMN 'Confirmation', IF THE INFORMATION / QUERY / SCHEDULE IS NOT RELEVANT TO THEM, **AND**
- **RETURN THIS CHECKLIST AS THE PART OF THE OFFER DULY SIGNED BY THEM.**

SN.	Parameters	Specified Requirement		Confirmation
		400kV	220kV	
1.	Rated Voltage (KV)	400kV	220kV	
2.	Type of Isolator	Outdoor and HCB	Outdoor and HCB	
3.	Standard applicable for isolators and earthing switches	IEC:62271-102 (2001-12), IS:9921- 1985		
4.	Rated Current Under site conditions (A) at 50° C ambient-	3150A	1600A	
5.	Rated short time withstand Current of Isolator and Earth switch for 1 Sec	50kA	40kA	
6.	Rated dynamic short circuit withstand Current of Isolator and Earth switch	125kAp	100kAp	
7.	Rated frequency (Hz)	50		
8.	Number of poles	3		
9.	Phase to phase spacing(mm)	7000	4500	
10.	Whether all 3 poles are ganged	Mechanically	Mechanically	
11.	Opening time of isolator and earth switch (Sec.)	Less than 12		
12.	Closing time of isolator (Sec.)	Less than 12		
13.	Temperature rise over 50° C ambient temperature corresponding to maximum continuous current (°C)	As per IEC-62271-102 or table-IV of IS: 9921-II		
14.	Seismic Acceleration	0.3 g		
15.	Dielectric withstand capacity of completely assembled isolator/isolator and earth switch			

SN.	Parameters	Specified Requirement		Confirmation
15.1	One minute dry power freq. Withstand test voltage(KV rms)			
	i. against ground (KV rms)	520	460	
	ii. Across isolating distance (KV rms.)	610	530	
15.2	1.2/50 micro's impulse withstand test voltage			
	i. Against ground (KVP)	±1425	±1050	
	ii. Across isolating distance (KVP) -	±1425(240)	±1200	
15.3	250/2500 micro sec. switching surge withstand test voltage (dry & wet)			
	i. Against ground (KVP) -	±1050	-	
	ii. Across isolating distance (KVP)	±900+345	-	
16.	Corona extinction voltage (KV rms) -	320	-	
17.	Radio interference level at 1.1 Ur/_/3 (in micro volts at 1.0 MHz)-	1000	1000	
18.	Total creepage distance to ground (mm) – (25 mm/kV)	10500	6125	
19.	Operating Mechanism for Isolator	Motor	Motor	
20.	Operating Mechanism for Earth Switches	Motor	Motor	
21.	Whether constructional interlock between Isolator & Earth switch provided	YES		
22.	Whether interlock between Isolator & Earth switch provided	Mechanical & Electrical		
23.	Arrangement provided to prevent electrical or manual operation unless interlock conditions are satisfied	YES		
24.	Rated Mechanical Terminal Load	As per Table -III of IEC-62271-102		
25.	Whether interlock coil is continuously rated	YES		
26.	Rated DC control voltage and variation allowed	220V DC		
27.	Material of contacts	Hard drawn electrolytic copper		
28.	Thickness of silver plating of contacts	25 micron		

SN.	Parameters	Specified Requirement		Confirmation
29.	Number of auxiliary contacts on isolator/pole for Owner's use	14NO + 14 NC + 4MBB	8NO + 8 NC + 4MBB	
30.	Number of auxiliary contacts on earth switch/pole for Owner's use	12 NO + 12NC	8NO + 8 NC	
31.	Rating of Auxiliary contacts	10 A at 220 V DC		
32.	Rated DC breaking current of Auxiliary contacts with 20 ms time constant (A)	2 A		
33.	Material of Current carrying parts	High conductivity electrolytic copper/ Aluminium		
34.	Height from mounting plane to top of terminal stud (operating rod length to be calculated accordingly)	8000	6000	
35.	All valid Type test reports(as per IEC) not older than 10 years, available	Yes, available		
36.	If valid Type test reports (as per IEC) are not available, bidder shall conduct the tests without any price & delivery implication.	Yes, confirm		
CONTROL CABINETS				
37.	Application	Outdoor		
38.	Material of control cabinet sheet	Painted sheet steel		
39.	Thickness of sheet (mm)	2.5		
40.	Degree of protection provided	IP55		
41.	Standard applicable for control cabinet	IS-5093/IS-8623, IEC-439		
42.	Colour shade of finish paint of outside of control cabinet as per IS : 5	RAL 5012 (Blue)		
43.	Colour shade of finish paint of inside of control cabinet as per IS : 5	Epoxy enamel white paint		
44.	Size of Conductor used in MOM box Control Wiring AC/DC Power supply	4 & 2.5 sq.mm 16 sq. mm		
45.	20 % Spare Terminal Blocks or 24 nos. whichever is higher provided in control cabinet	YES		
46.	Confirm to follow the BHEL/Customer SMQP	Confirmed		
47.	Following accessories not limited			

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW)	
CUSTOMER: NTPC LTD.	
Technical Specification of 400kV & 220 kV Isolators	TB-316-369-002
Section-6: Check List for 400kV & 220kV Isolator	REV.00

SN.	Parameters	Specified Requirement	Confirmation
	<i>to this is included in scope or not:</i>		
A	Hardware for Structure (BHEL supply) to Base Channel (vendor supply)*	YES	
B	Hardware for Base Channel (vendor supply) to Bottom of Post Insulator (BHEL supply)	YES	
C	Hardware for Top BPI (BHEL supply) to Male/Female Member	YES	
D	Hardware for Structure (BHEL supply) to MOM Box	YES	
E	Hardware for Structure (BHEL supply) to Earth Switch MOM	YES	
F	Terminal Connectors	NO	
G	Support Insulators	NO	
H	Support Structure	NO	

**** - length of bolts shall be decided on the basis of 15mm thickness of top plate of mounting structure.**

Date:

Place: (Signature of the authorized representative of Bidder / Firm / Company)

Phone:

Name:

Fax:

Designation:

E-mail:

Company Seal:

Mobile:

Website:

439999/2021/TBG-TBG ENGG

PROJECT: 400/220kV Switchyard for North Karanpura Super TPP (3x660MW) CUSTOMER: NTPC LTD.
--

Technical Specification of 400kV & 220 kV Isolators Section-1: Scope, Specific Technical Requirements & Quantities

TB-316-369-002 REV.01

Annexure-QR**TECHNICAL QUALIFYING REQUIREMENT**

400kV Disconnectors being offered should be from manufacturer(s) who have manufactured and supplied atleast five (5) nos. of three phase Disconnectors suitable for Air Insulated substation/Switchyard of 400kV or above class which should have been in successful operation for a minimum period of two (2) years prior to the date 24.04.2021.


Documents to be submitted for Technical Requirements:

- Purchase Order copy defining the scope & value/ Material Receipt Certificate at site.
- Proof of successful operation/ performance certificate issued by end user.

Prepared By



Akhilesh Kumar

Dy. Manager/TBEM

Reviewed By


Vivek Kapil

SDGM/TBEM

Approved By


Aruna Gulati

AGM/TBEM