

Technical Specifications

* [As per GeM Category Specification](#)

Specification	Specification Name	Bid Requirement (Allowed Values)
Certifications and Standards	ISI Marked	Yes Or higher
	Conformity to Standard	IS 5610:1983 or Latest
Packaging Guidelines	Packaging Size	61.0
	Packaging Type	Recyclable Steel Cylinder
Test Reports	Copies of test reports to be submitted to the Buyer on Demand	Yes Or higher
	Availability of Test Report from Central Govt/NABL/ILAC accredited lab to prove conformity to specification	Yes Or higher

Additional Specification Parameters - Refrigeration Gas Chlorodifluoro Methane Type CFM 22 (R-22) As Per IS 5610/1983 (3 pieces)

Specification Parameter Name	Bid Requirement (Allowed Values)
Scope of Supply	Supply of R22 gas filled new refrigerant cylinders for refrigeration applications.
R22 gas Qty. to be filled in each cylinder	61 kg
Supply Condition	Cylinder to be supplied along with cylinder cap and factory sealed

* Bidders offering must also comply with the additional specification parameters mentioned above.