

TECHNICAL CORRIGENDUM - 1

(NIC tender id: 2023_BHEL_22744_1 for Anchor Fastners to SJVNL dated 07/03/2023

Arun-3 Nepal project)

SL	DESCRIPTION	CORRIGENDUM
1	Section-1, 2.1 Strength level & Technical requirement - Equivalent to fischer FWA hot dip galvanized steel with A2-clip	Section-1, 2.1 revised as follow Strength level & Technical requirement - Equivalent to fischer FWA hot dip galvanized / Electroplated steel with A2-clip
2	Section-1, 2.1 Nominal length (mm) 180 & 100	Section-1, 2.1 revised as follow Nominal length (mm) 180 & 100 minimum

TECHNICAL CLARIFICATION - 1**dated 07/03/2023**

SL	DESCRIPTION	REMARKS
1	As per your BOQ of Fischer FWA (Hot Dip Galvanised with A2 Clip), We have Confirmed with Fischer Building Materials Pvt Ltd that company can provide only Electroplated material.	Please refer technical corrigendum-1
2	JNM brand introduced by us, in that brand we can provide you Mechanical Anchor Hot Dip Galvanised with A2 Clip.	Please refer Section-1, 2.1 Fisher/Hilti/ or Equivalent makes are accepted. The technical acceptance shall be reviewed based on bid document during technical evaluation.
3	Provide drawing / standard details of wedge anchor bolt M16x180mm & M16x100mm Provide dimension standard details of Nut & washer & also provide material Grade required of wedge Anchor Bolt, Nut & Washer.	Please refer standard dimensions & parameters adopted by Fisher/Hilti for given specification