

BUYERS SPECIFIC ADDITIONAL TERMS & CONDITIONS**ITEM NAME:** Seal Steam Valve along with spars

PROJECTS- Raigarh Unit-1 & 2 (Ph-II), Raipur Unit-1 & 2 (Ph-2), Mirzapur Unit-1 & 2 (PH-1), Kawai Unit-1 & 2 (PH -II), Kawai Unit-1 & 2 (Ph-III) & Mahan Unit-1 & 2 (PH-III)

1. SCOPE OF ENQUIRY:

E-bids on GeM portal are invited from bidders for the supply of Seal Steam Valve for Raigarh Unit-1 & 2 (Ph-II), Raipur Unit-1 & 2 (Ph-2), Mirzapur Unit-1 & 2 (PH-1), Kawai Unit-1 & 2 (PH -II), Kawai Unit-1 & 2 (Ph-III) & Mahan Unit-1 & 2 (PH-III) as per requirement mentioned below:

ITEM-NO	MATERIAL CODE & ITEM DESCRIPTION	QTY.	UNIT	DATE FOR SUPPLY COMPLETION	PROJECT
1	W90313239401 DRG: 21323952100 REV:00 SEAL STEAM SUPPLY VALVE WITH PNEUMATIC ACTUATOR	12 Set	12	05-12-2025	Raigarh Unit-1
				05-04-2026	Raigarh Unit-2
				31-07-2026	Raipur Unit-1
				31-01-2027	Raipur Unit-2
				31-01-2027	Mirzapur Unit-1
				30-07-2027	Mirzapur Unit-2
				30-07-2027	Kawai PH-II Unit-1
				30-01-2028	Kawai PH-II Unit-2
				30-10-2027	Kawai PH-III Unit-1
				30-04-2028	Kawai PH-III Unit-2
				31-08-2027	Mahan PH-III Unit-1
				29-02-2028	Mahan PH-III Unit-2
2	W99313239655 DRG: 31323952110 REV:00 SPARES:SEAL STEAM SUPPLY VALVE	5 Set	5	05-06-2026	Raigarh Unit-1
				31-03-2027	Raipur Unit-1
				30-09-2027	Mirzapur Unit-1
				30-07-2028	Kawai PH-II Unit-1
				30-10-2028	Kawai PH-III Unit-1
3	W99318102097 DRG: ADDENDUM NO.- 41810250001 REV:00 POSITIONER WITH POSITION TRANSMITTER FOR SEAL STEAM VALVE AS PER ADDENDUM NO.- 41810250001.	5 No.	5	05-06-2026	Raigarh Unit-1
				31-03-2027	Raipur Unit-1
				30-09-2027	Mirzapur Unit-1
				30-07-2028	Kawai PH-II Unit-1
				30-10-2028	Kawai PH-III Unit-1

2. Project Detail with consignee address:

[A] Project Name	2X800 MW RAIGARH TPP (PH-II) PROJECT
Consignee Address	Adani Power Limited Village: Chhote Bhandar PO: Bade Bhandar Tehsil: Pussore Raigarh 496100
[B] Project Name	2X800 MW APL Raipur (Ph-II)
Consignee Address	Adani Power Limited Village: Raikheda Block: Tilda, Raipur 493225 Chhattisgarh
[C] Project Name	2X800 MW Mirzapur PH-I
Consignee Address	Mirzapur Thermal Energy (UP) Private Limited Village: Dadri Khurd; PO: Darhi Ram Tehsil: Sadar, District: Mirzapur 231 304 Uttar Pradesh
[D] Project Name	2X800 MW KAWAI PH-II
Consignee Address	Adani Power limited, Kawai, 2 x 800 MW(Phase-II) Thermal Power project, Village - Kawai, Tehsil - Atru, Baran -District, Rajasthan Pin-325219
[E] Project Name	2X800 MW KAWAI PH-III
Consignee Address	Adani Power limited, Kawai, 2 x 800 MW(Phase-III) Thermal Power project, Village - Kawai, Tehsil - Atru, Baran -District, Rajasthan PIN-325219
[F] Project Name	2X800 MW Mahan TPP (PH-III)
Consignee Address	Mahan Energen Limited 2x800 MW (Phase-III) Mahan Ultra Supercritical Thermal Power Project, Village: Bandhoura, Karsualal Tehsil: Waidhan, District-Singrauli, Pin - 486886, Madhya Pradesh

3.BUYERS SPECIFIC ADDITIONAL TERMS & CONDITIONS IN ADDITION TO GTC

Sl. No.	Terms	Description	Supplier confirmation
1.	Documents Checklist:	Please submit signed and stamped copy of your offer on each page along with following documents; • Buyer Specific T&C. • Technical PQR & its supportive document. • Technical drawing & purchase specification. • Certificate/self-certification for minimum local content as per PPP-MII order. • Replica of price bid schedule without prices with part-I offer.	
2.	Special Instruction of Technical requirement	• PLEASE ENSURE TO SUBMIT PRICE OFFER AGAINST EACH ITEM MENTIONED IN THE BHEL DRAWING NO. 31323900001 FOR OUR FUTURE REFERENCE AND ORDERING (IF REQUIRED). PLEASE ALSO CONFIRM THAT YOUR PRICES OF THESE ITEMS SHALL BE VALID TILL ENTIRE GUARANTEE PERIOD. • AT THE TIME OF OFFER, ALL THE VENDORS TO ENSURE TO FURNISH DULY FILLED CHECK LIST FOR SEAL STEAM VALVE (AS PER ANNEXURE-B) TO CONFIRM BHEL SPECIFICATION REQUIREMENTS. • AT THE TIME OF OFFER ALL THE VENDORS TO ENSURE TO FURNISH DULY FILLED ANNEXURE- C AND SUBMIT ALL THE DOCUMENTS ACCORDINGLY • ADDITIONAL SPECIFICATION FOR SMART TYPE POSITIONER AS PER DOCUMENT NO. 41810250001 REV 05 DATED -28/02/2025 SHALL BE COMPLIED BY ALL THE VENDORS. • VENDOR TO SUBMIT PACKING LIST OF ITEMS FOR BHEL REVIEW AFTER PLACEMENT OF P.O. AND BEFORE DISPATCH. • MANDATORY SPARES SHALL BE PACKED IN A SEPERATE GREEN COLOR BOX WITH "MANDATORY SPARES FOR SEAL STEAM VALVE" LABLLED ON IT. • THE VENDOR TO PROVIDE 3D MODELS FOR THE SUPPLIED EQUIPMENT ASSEMBLIES (HAVING ALL THE COMPONENTS INCLUDED) COMPLETE WITH ALL CONNECTION POINTS/ INTERFACES FOR THE PURPOSE OF 3D POWER PLANT LAYOUT TO BE DONE BY BHEL AS PER CUSTOMER SPECIFICATION REQUIREMENTS. THE FILE FORMAT OF 3D MODELS SHALL BE INFORMED BY BHEL AND THE SAME SHALL BE SUBJECT TO CUSTOMER APPROVAL. • IN CASE OF ANY CONFLICT BETWEEN STIPULATIONS IN VARIOUS PORTIONS OF THE SPECIFICATIONS, MOST STRINGENT STIPULATION WOULD BE APPLICABLE FOR IMPLEMENTATION BY THE VENDOR WITHOUT ANY EXTRA COST TO THE BHEL. • SPECIAL TOOLS AND TACKLES/ EQUIPMENT FOR THE OPERATION, MAINTENANCE, INSPECTION AND REPAIR OF THE EQUIPMENT SHALL BE SUPPLIED BY THE VENDOR WHICH SHALL BE NEW AND UNUSED. THE SPECIAL TOOLS AND TACKLES/ EQUIPMENT SHALL BE DELIVERED BY THE VENDOR IN LOCKABLE STEEL BOXES AND SHALL BE MARKED FOR IDENTIFICATION PURPOSES ANONGWITH CORRESPONDING TOOL CHART. • ALL THE SPARES MUST BE PACKED IN SEALED TRANSPARENT PLASTIC BAGS AND CLEARLY MARKED OR LABELLED ON THE OUTSIDE OF THE PACKING WITH ITS DESCRIPTION AND ASSEMBLY PART NUMBERS CORRELATED WITH BHEL APPROVED DRAWING AND BILL OF MATERIALS (BOMs). • THE VENDOR TO READ CLAUSE NO. 1.8 OF BHEL SPECIFICATION	

		21323952100 SH02 AS FOLLOWS- - VALVE MUST BE DESIGNED KEEPING IN VIEW OF THE RESPECTIVE SITE DATA AS PER: • ANNEXURE-F_ RAIPUR(PH-II) TPP • ANNEXURE-F_ MIRZAPUR(PH-I) TPP • ANNEXURE-F_ KAWAI (PH-II & PH-III) TPP • D. ANNEXURE-F_ MAHAN (PH-III) TPP	
3.	Compliance of GTC on GeM	General Terms and Conditions on GeM 4.0 (Version 1.22) Dtd -28/02/2025 or it's latest revision of GeM portal shall be applicable against this enquiry. Kindly confirm to compliance the same for this tender.	
4.	Pre-Qualification Requirements	The Pre-Qualification Requirements have been compiled. All the bidders should ensure submission of complete details and documents as called for in these requirements. The Offers submitted by the bidders would be scrutinized with respect to Pre-Qualification Requirements first. Techno-Commercial offer of only those bidders shall be evaluated who meet the Pre-Qualification Requirements.	
5.	Customer approval requirement	Bidders are requested to submit their credentials along with offer (Credentials should include BHEL P.O.s on vendor for the same rating or higher rating turbines, Experience of vendor with state utilities and major PSU like NTPC, End User Certificate wherever available), in order to take up with end customer for approval Supplier to submit following credentials for arranging Customer approval: - • Company Profile • List of Order Executed/ on hand for Power Sector/Gov. organization of same /similar items • Copy of Major Supply Orders • Performance Certificates for Satisfactory working of System/ Equipment from end users Item. The offer of only those bidders, who meet Pre-qualification requirement (PQR), Technical requirement and approved by the End Customer, will be considered for price-bid opening & RA for the requirement against this enquiry.	
6.	Make in India Clause	"For this procurement, the local content to categorize a supplier as a Class-I Local Supplier / Class-II Local Supplier/ Non-Local Supplier and purchase preference to Class-I Local Supplier, is as defined in Public Procurement (Preference to Make in India), Order-2017 Ref. No. P-45021/2/2017-PP (BE-II) dtd. 04/06/2020 issued by DPIIT. In case of subsequent orders issued, by the nodal ministry, changing the definition of local content for the items of this NIT, but before opening of Part-II bids against this NIT As per Make in India Order, only Class-1 and Class-2 local supplies are eligible to bid in this tender enquiry. For this eligibility criteria, bidders are required to submit certificate of Minimum local content as specified in attached Make In India Declaration format.	
7.	Compliance of Rule 144 (xi) of GFR 2017	Compliance of Restrictions under Rule 144 (xi) of GFR 2017 shall be as per GeM.	
8.	Bid validity/ Validity of offer	Please note that validity of the offer shall be 180 days from the date opening of Techno-Commercial bid (Part-I bid) on GeM portal. Offer of bidder's having validity less than 180 days shall liable to reject. Please confirm. The required validity is considering that offer is complete & clear w.r.t. PQR and all techno-commercial conditions. Vendors need to extend their offer validity for the time taken by them in responding BHEL's comments/clarification sought during techno-commercial scrutiny of the offer. In case regret by any bidder for such validity	

		extension, their offer shall liable to be reject. Please confirm.									
9.	Loading and unloading	Vendor’s scope will not cover Loading & Unloading at Final destination of delivery. Unloading at final destination (i.e. BHEL site) is in BHEL ‘scope. Loading and unloading at other intermediate places due to any permitted transshipment will be the responsibility of the vendor. Kindly note									
10.	Prices/Basis of Quotation	The offered prices of the items shall remain firm and fixed till the execution of the contract, kindly confirm.									
		Kindly confirm that your quote prices are inclusive of P&F, Freight & GST for Total quantity on GeM portal.									
		Transit Insurance would be arranged by BHEL. Please quote your prices accordingly.									
		The prices are to be quoted on Ex-Works with freight Pre-paid up to project destination basis. The goods must be dispatched through any Bank approved transporters having their branch at Haridwar. The names and addresses of transporters approved by IBA as well as BHEL are posted at our website www.bhelhwr.co.in. Please note that, if you dispatch the material by any BHEL un-approved transporter then you will necessarily be required to furnish the MRC (Material Receipt Certificate) from respective Project Site for processing of your invoice. No demurrage charges would be borne by BHEL.									
11.	Special Instructions:	a. ADADNI projects: • Please inform 8 digit HSN code for Seal Steam Valve along with spares. • 08 DIGIT GST HSN CODE to be provided & mentioned in your invoice & packing list. • Invoice, GR/LR, packing list, Test certificate are required in original for billing to end user. • Loose items one marker board needs to be send for each bundle for fixing RFID tag at site. • Material for unit-1, unit-2, commissioning spares and mandatory spares needs to be packed in separate boxes and same is required to be marked on the box & packing list. • Vendor to ensure submission billing documents in the same month of material despatch. If vendor fail to provide the despatch documents in the same month GST Penalty shall be applicable and bear by vendor as per GST rule.									
12.	Evaluation criteria	Evaluation shall be done on total landed cost up to BHEL Project Sites considering all material codes together.									
13.	Evaluation Currency	The evaluation currency for this tender shall be INR.									
14.	Payment terms:	For Material portion: The payment shall be done after receipt of Material at BHEL respective project site, within no. of days as defined in the below table from the date of receipt of Material at site i.e. MRC date). <table><tr><td>Type of Bidder</td><td>Payment Terms (Number of Days)</td></tr><tr><td>Micro & Small Enterprises (MSEs)</td><td>45 days</td></tr><tr><td>Medium Enterprises</td><td>60 days</td></tr><tr><td>Non MSME</td><td>90 days</td></tr></table> The Payment terms are subject to receipt of non-discrepant document from supplier.	Type of Bidder	Payment Terms (Number of Days)	Micro & Small Enterprises (MSEs)	45 days	Medium Enterprises	60 days	Non MSME	90 days	
Type of Bidder	Payment Terms (Number of Days)										
Micro & Small Enterprises (MSEs)	45 days										
Medium Enterprises	60 days										
Non MSME	90 days										
15.	GeM charges	GeM charges if any shall be either side only i.e. buyer’s GeM charges shall be in buyer’s account and seller’s GeM charges shall be on seller’s account. Please confirm.									
16.	Contract execution	Bidder’s are advised to read GeM related query & clarification carefully on GeM portal. Order shall be executed through GeM.									

17.	Reverse Auction (E-bidding)	BHEL shall be resorting to Reverse Auction (RA) on GEM portal as per GEM functionalities for this tender. RA shall be conducted among the techno-commercially qualified bidders.	
18.	Quantity Variation	BHEL reserves the right to cancel tender or reject any or all the quotations without assigning any reasons thereof. BHEL also reserves the right to Increase or decrease the tendered quantities or quantity of individual material code may be dropped as a whole also. Vendors should be prepared to accept order for reduced Quantity without any extra charges. Vendor should also be prepared for giving discount in case of Increase in Quantity. Vendor has to take manufacturing clearance from BHEL before starting manufacturing of material. In case ordered quantity is reduced at the time of manufacturing clearance, then payment shall be made accordingly as per decreased quantity. Kindly confirm.	
19.	Delivery Period	Please note that BHEL's Delivery requirements are mentioned in point no 1 of above. Early delivery w.r.t. above lot delivery will be accepted only after written confirmation from BHEL. BHEL reserve right to reject early delivery request of bidders / suppliers. Delivery period indicated in GeM bid is only indicative and final delivery of tender shall be taken as mentioned above. Accordingly bidders to confirm the above deliveries or quote their best possible delivery in no of months / weeks from the date of placement of Purchase order, including all activities like document approval, inspection by TPI time etc.	
20.	Technical Document/ Drawing approval conditions	Drawings/Data sheets/documents/QAP etc. as called for in the specifications shall be submitted by Vendor for BHEL/ Customer approval within 30 days of purchase order. BHEL shall approve these drawings/data sheets/ documents / QAP etc. within 30 days of receipt. Any comments on the documents shall be given by BHEL within 7 days of submission and vendor shall submit revised document / reply to comments, within 7 days of BHEL comments. However, total time for Document submission and approval shall not exceed 30 days for respective party. Delivery is from the date of PO, accordingly, delay in submission / revision of the documents by the vendor will automatically account for to vendor. In case of delay on account of BHEL in comments / approval of the documents, the delivery shall be re-scheduled by the no of days taken by BHEL in excess to 30 days. For delay analysis cumulative no of days (including time taken in comments), shall be considered for delivery extension.	
21.	Liquidated Damages (LD) for late delivery	Liquidated Damages shall be lot wise as per clause no. 15 (iii) of General terms and conditions on GeM 4.0 (Version 1.22) as under: kindly confirm. "If the Seller/Service Provider fails to deliver any or all of the Goods/Services within the original/re-fixed delivery period(s) specified in the contract, the Buyer will be entitled to deduct/recover the Liquidated Damages for the delay, unless covered under Force Majeure conditions aforesaid, @ 0.5% of the contract value of delayed quantity per week or part of the week of delayed period as pre-estimated damages not exceeding 10% of the contract value of delayed quantity without any controversy/dispute of any sort whatsoever". The date of LR would be treated as the date of delivery for penalty purposes.	
22.	MDCC clause	Please note that, material shall be dispatched only after issue of Material dispatch clearance certificate (MDCC) from end customer. For issue of MDCC, vendors are required to submit all test certificates (TC) and inspection report of third party (IR) to BHEL. After review & acceptance of the quality document, BHEL will forward the same to end customer for issuance of MDCC. MDCC shall be issued within 7 days of receipt of complete quality documents / TCs,. In case of delay in issuance of MDCC, only delivery shall be extended by no of days taken	

		by BHEL in excess to 7 days and all other terms and conditions of PO shall remains same & binding. In case any material is dispatched without MDCC and any loss is incurred by Supplier/Vendor for any reason whatsoever, BHEL shall not be responsible in any manner to compensate the supplier in this regard. Kindly confirm.	
23.	BREACH OF CONTRACT, REMEDIES AND TERMINATION:	The following shall amount to breach of contract: I. Non-supply of material/ non-completion of work by the Supplier/Vendor within scheduled delivery/ completion period as per contract or as extended from time to time. II. The Supplier/Vendor fails to perform as per the activity schedule and there are sufficient reasons even before expiry of the delivery/ completion period to justify that supplies shall be inordinately delayed beyond contractual delivery/ completion period. III. The Supplier/Vendor delivers equipment/ material not of the contracted quality. IV. The Supplier/Vendor fails to replace the defective equipment/ material/ component as per guarantee clause. V. Withdrawal from or abandonment of the work by the Supplier/Vendor before completion as per contract. VI. Assignment, transfer, subletting of Contract by the Supplier/Vendor without BHEL's written permission resulting in termination of Contract or part thereof by BHEL. VII. Non-compliance to any contractual condition or any other default attributable to Supplier/Vendor. VIII. Any other reason(s) attributable to Vendor towards failure of performance of contract. In case of breach of contract, BHEL shall have the right to terminate the Purchase Order/ Contract either in whole or in part thereof without any compensation to the Supplier/Vendor. IX. Any of the declarations furnished by the contractor at the time of bidding and/ or entering into the contract for supply are found untruthful and such declarations were of a nature that could have resulted in non-award of contract to the contractor or could expose BHEL and/ or Owner to adverse consequences, financial or otherwise. X. Supplier/Vendor is convicted of any offence involving corrupt business practices, antinational activities or any such offence that compromises the business ethics of BHEL, in violation of the Integrity Pact entered into with BHEL has the potential to harm the overall business of BHEL/ Owner. Note-Once BHEL considers that a breach of contract has occurred on the part of Supplier/Vendor, BHEL shall notify the Supplier/Vendor by way of notice in this regard. Contractor shall be given an opportunity to rectify the reasons causing the breach of contract within a period of 14 days. In case the contractor fails to remedy the breach, as mentioned in the notice, to the satisfaction of BHEL, BHEL shall have the right to take recourse to any of the remedial actions available to it under the relevant provisions of contract. Remedies in case of Breach of Contract. i) Wherein the period as stipulated in the notice issued under above clause has expired and Supplier/Vendor has failed to remedy the breach, BHEL will have the right to terminate the contract on the ground of "Breach of Contract" without any further notice to contractor. ii) Upon termination of contract, BHEL shall be entitled to recover an amount equivalent to 10% of the Contract Value for the damages on account of breach of contract committed by the Supplier/Vendor. This amount shall be recovered by way	

		of encashing the security instruments like performance bank guarantee etc available with BHEL against the said contract. In case the value of the security instruments available is less than 10% of the contract value, the balance amount shall be recovered from other financial remedies (i.e. available bills of the Supplier/Vendor, retention amount, from the money due to the Supplier/Vendor etc. with BHEL) or the other legal remedies shall be pursued. iii) wherever the value of security instruments like performance bank guarantee available with BHEL against the said contract is 10% of the contract value or more, such security instruments to the extent of 10% contract value will be encashed. In case no security instruments are available or the value of the security instruments available is less than 10% of the contract value, the 10% of the contract value or the balance amount, as the case may be, will be recovered in all or any of the following manners: iv) In case the amount recovered under sub clause (a) above is not sufficient to fulfil the amount recoverable then; a demand notice to deposit the balance amount within 30 days shall be issued to Supplier/Vendor. v) If Supplier/Vendor fails to deposit the balance amount within the period as prescribed in demand notice, following action shall be taken for recovery of the balance amount: a) from dues available in the form of Bills payable to defaulted Supplier/Vendor against the same contract. b) If it is not possible to recover the dues available from the same contract or dues are insufficient to meet the recoverable amount, balance amount shall be recovered from any money(s) payable to Supplier/Vendor under any contract with other Units of BHEL including recovery from security deposits or any other deposit available in the form of security instruments of any kind against Security deposit or EMD. vi) In-case recoveries are not possible with any of the above available options, Legal action shall be initiated for recovery against defaulted supplier/Vendor. vii) It is an agreed term of contract that this amount shall be a genuine pre-estimate of damages that BHEL would incur in completion of balance contractual obligation of the contract through any other agency and BHEL will not be required to furnish any other evidence to the Supplier/Vendor for the purpose of estimation of damages. viii) In addition to the above, imposition of liquidated damages, debarment, termination, de-scoping, short-closure, etc., shall be applied as per provisions of the contract. Note: 1) The defaulting Supplier/Vendor shall not be eligible for participation in any of the future enquiries floated by BHEL to complete the balance work. The defaulting contractor shall mean and include: (a) In case defaulted Supplier/Vendor is the Sole Proprietorship Firm, any Sole Proprietorship Firm owned by same Sole Proprietor. (b) In case defaulted Supplier/Vendor is The Partnership Firm, any firm comprising of same partners/ some of the same partners ; or sole proprietorship firm owned by any partner(s) as a sole proprietor.	
24.	Suspension of Business Dealings with Suppliers / Contractors:	The offers of the bidders who are under suspension as also the offers of the bidders, who engage the services of the banned firms / principal / agents, shall be rejected. The list of banned firms is available on BHEL web site www.bhel.com. If any bidder / supplier / contractor during pre-tendering / tendering / post tendering / award / execution / post-execution stage indulges in any act, including but not limited to, mal-practices, cheating, bribery, fraud or and other misconduct or formation of cartel so as to influence the bidding process or influence the price or tampers the tendering process or acts or omits in any manner which tantamount to an offence punishable under any provision of the Indian Penal Code, 1860(Bhartiya Nyaya Samhita 2023) or any other law in force in India, or does anything which is actionable under the Guidelines for Suspension of Business dealings, action may be taken against	

		such bidder / supplier / contractor as per extant guidelines of the company available on www.bhel.com and / or under applicable legal provisions. Guidelines for suspension of business dealings is available in the webpage: http://www.bhel.com/vender_registration/vender.php .	
25.	Settlement of Dispute, CONCILIATION & ARBITRATION: :	Settlement of Dispute If any dispute or difference of any kind whatsoever shall arise between BHEL and the Supplier/Vendor, arising out of the contract for the performance of the work whether during the progress of contract termination, abandonment or breach of the contract, it shall in the first place referred to Designated Officer / IEM for amicable resolution by the parties. Designated Officer / IEM who within 60 days after being requested shall give written notice of his decision to the contractor. Save as hereinafter provided, such decision in respect of every matter so referred shall forthwith be given effect to by the Supplier/Vendor who shall proceed with the work with all due diligence, whether he or BHEL desires to resolve the dispute as hereinafter provided or not. If after the Designated Engineer has given written notice of this decision to the party and no intention to pursue the dispute has been communicated to him by the affected party within 30 days from the receipt of such notice, the said decision shall become final and binding on the parties. In the event the Supplier/Vendor being dissatisfied with any such decision or if amicable settlement cannot be reached then all such disputed issues shall be resolved through conciliation in terms of the BHEL Conciliation Scheme 2018 as per 'CONCILIATION' Clause. CONCILIATION: Any dispute, difference or controversy of whatever nature howsoever arising under or out of or in relation to this Agreement (including its interpretation) between the Parties, and so notified in writing by either Party to the other Party (the "Dispute") shall, in the first instance, be attempted to be resolved amicably in accordance with the conciliation procedure as per BHEL Conciliation Scheme 2018. The proceedings of Conciliation shall broadly be governed by Part-III of the Arbitration and Conciliation Act 1996 or any statutory modification thereof and as provided in - "Procedure for conduct of conciliation proceedings" (as available in www.bhel.com). Note: Ministry of Finance has issued OM reference No. 1/2/24 dated 03.06.2024 regarding "Guidelines for Arbitration and Mediation in Contracts of Domestic Public Procurement. In the said OM it has been recommended that Government departments/ Entities/agencies are to encourage mediation under the Mediation Act. 2023. The said Act has not yet been notified by the Government. Therefore, the clause "Settlement of Disputes" shall be modified accordingly as and when the Mediation Act 2023 gets notified. ARBITRATION: Except as provided elsewhere in this Contract, in case Parties are unable to reach amicable settlement (whether by Conciliation to be conducted as provided herein above or otherwise) in respect of any dispute or difference; arising out of the formation, breach, termination, validity or execution of the Contract; or, the respective rights and liabilities of the Parties; or, in relation to interpretation of any provision of the Contract; or. in any manner touching upon the Contract (hereinafter referred to as the 'Dispute'), then, either Party may, refer the disputes to Arbitral Institution and such dispute to be adjudicated by Sole Arbitrator appointed in accordance with the Rules of said Arbitral Institution. A party willing to commence arbitration proceeding shall invoke Arbitration Clause by giving notice to the other party in terms of section 21 of the Arbitration & Conciliation Act, 1996 (hereinafter referred to as the 'Notice') before referring the matter to arbitral institution. The Notice shall be addressed to the Head of the Region, Power Sector/ Unit, BHEL, executing the Contract and shall contain the particulars of all claims to be referred to arbitration with sufficient detail and shall also indicate the monetary amount of such claim including interest, if any.	

		After expiry of 30 days from the date of receipt of aforesaid notice, the party invoking the Arbitration shall submit that dispute to the Arbitral Institutions (shall be identified by the contract issuing agency) and that dispute shall be adjudicated in accordance with their respective Arbitration Rules. The matter shall be adjudicated by a Sole Arbitrator who shall necessarily be a Retd Judge having considerable experience in commercial matters to be appointed/nominated by the respective institution. The cost/expenses pertaining to the said Arbitration shall also be governed in accordance with the Rules of the respective Arbitral Institution. The decision of the party invoking the Arbitration for reference of dispute to a specific Arbitral institution for adjudication of that dispute shall be final and binding on both the parties and shall not be subject to any change thereafter. The institution once selected at the time of invocation of dispute shall remain unchanged. The fee and expenses shall be borne by the parties as per the Arbitral Institutional rules. The Arbitration proceedings shall be in English language and the seat and venue of Arbitration shall be at the court(s) of Haridwar. Subject to the above, the provisions of Arbitration & Conciliation Act 1996 and any amendment thereof shall be applicable. All matters relating to this Contract and arising out of invocation of Arbitration clause are subject to the exclusive jurisdiction of the Court(s) situated at Haridwar , shall have exclusive jurisdiction. Notwithstanding any reference to the Designated Engineer or Conciliation or Arbitration herein, a. the parties shall continue to perform their respective obligations under the Contract unless they otherwise agree. Settlement of Dispute clause cannot be invoked by the Contractor, if the Contract has been mutually closed or 'No Demand Certificate' has been furnished by the Contractor or any Settlement Agreement has been signed between the Employer and the Contractor. It is agreed that Mechanism of resolution of disputes through arbitration shall be available only in the cases where the value of the dispute is less than Rs. 10 Crores. In case the disputed amount Claim, Counter claim including interest is Rs. 10 crores and above, the parties shall be within their rights to take recourse to remedies other than Arbitration, as may be available to them under the applicable laws after prior intimation to the other party. Subject to the aforesaid conditions, provisions of the Arbitration and Conciliation Act, 1996 and any statutory modifications or re-enactment thereof as amended from time to time, shall apply to the arbitration proceedings under this clause. In case, multiple arbitrations are invoked (whether sub-judice or arbitral award passed) by any party to under this contract, then the cumulative value of claims (including interest claimed or awarded) in all such arbitrations shall be taken in account while arriving at the total claim in dispute for the subject contract for the purpose of clause mentioned above. Disputes having cumulative value of less than 10 crores shall be resolved through arbitration and any additional dispute shall be adjudicated by the court of competent jurisdiction.	
26.	Action against Bidders / vendor / supplier / contractor in case of default:	In order to protect the commercial interests of BHEL, BHEL shall take action against supplies / contractors by way of suspension of business dealings, who either fail to perform or are in default without any reasonable cause, cause loss of business/ money/ reputation, indulge in malpractices, cheating, bribery, fraud or any other misconduct or formation of cartels so as to influence the bidding process or influence the price etc. Suspension of Business Dealings could be in the form of "Hold" or "Banning" a supplier/ contractor or a bidder and shall be as per "Guidelines for Suspension of Business Dealings with Suppliers/ Contractors" available at BHEL's website	

		"https://www.bhel.com/guidelines-suspension-business-dealings-supplierscontractors"																			
27.	MICRO AND SMALL ENTERPRISES (MSE):	Any Bidder falling under MSE category shall furnish the following details & submit documentary evidence/ Govt. Certificate etc. in support of the same along with their techno-commercial offer. <table><tr><td>Type under MSE</td><td>SC/ST owned</td><td>Women owned</td><td colspan="2">Others (excluding SC/ ST & Women Owned)</td></tr><tr><td>Micro</td><td></td><td></td><td colspan="2"></td></tr><tr><td>Small</td><td></td><td></td><td colspan="2"></td></tr></table> Note: If the bidder does not furnish the above, offer shall be processed construing that the bidder is not falling under MSE category. a) MSE suppliers can avail the intended benefits in respect of the procurements related to the Goods and Services only (Definition of Goods and Services as enumerated by Govt. of India vide Office Memorandum F. No. 21(8)/2011-MA dtd. 09/11/2016 office of AS & DC, MSME) only if they submit along with the offer, attested copies of either Udyam Registration. Date to be reckoned for determining the deemed validity will be the last date of Technical Bid submission. Non-submission of supporting document in GeM portal will lead to consideration of their bids at par with other bidders. No benefits shall be applicable for this enquiry if the above required documents are not uploaded at the time of bid submission. Documents submitted by the bidder shall be verified by BHEL for rendering the applicable benefits.				Type under MSE	SC/ST owned	Women owned	Others (excluding SC/ ST & Women Owned)		Micro					Small					
Type under MSE	SC/ST owned	Women owned	Others (excluding SC/ ST & Women Owned)																		
Micro																					
Small																					
28.	JURISDICTION:	This contract shall be governed by the Law for the time being in force in the Republic of India. Subject to clause(s) mentioned above of this contract, the Civil Court having original Civil Jurisdiction at Haridwar shall alone have exclusive jurisdiction in regard to all matters in respect of the Contract.																			
29.	Force Majeure	"Force Majeure" shall mean circumstance which is: a) beyond control of either of the parties to contract, b) either of the parties could not reasonably have provided against the event before entering into the contract, c) having arisen, either of the parties could not reasonably have avoided or overcome, and d) is not substantially attributable to either of the parties And Prevents the performance of the contract, Such circumstances include but shall not be limited to: i) War, hostilities , invasion, act of foreign enemies. ii) Rebellion, terrorism, revolution, insurrection, military or usurped power, or civil war. iii) Riot, commotion or disorder by persons other than the contractor's personnel and other employees of the contractor and sub-contractors. iv) Strike or lockout not solely involving the contractor's personnel and other employees of the contractor and sub-contractors. v) Encountering munitions of war, explosive materials, ionizing radiation or contamination by radio-activity, except as may be attributable to the contractor's use of such munitions, explosives, radiation or radio-activity. vi) Natural catastrophes such as earthquake, tsunami, volcanic activity, hurricane or typhoon, flood, fire, cyclones etc. vii) Epidemic, pandemic etc. The following events are explicitly excluded from Force Majeure and are solely the responsibilities of the non-performing party: a) any strike, work-to-rule action, goslow or similar labour difficulty (b) late delivery of equipment or material (unless caused by Force Majeure event) and (c) economic hardship. If either party is prevented, hindered or delayed from or in performing any of its obligations under the Contract by an event of Force Majeure, then it shall notify the other in writing of the occurrence of such event and the circumstances thereof within 15 (fifteen) days after the occurrence of such event. The party who has given such notice shall be excused from the performance or punctual performance of its obligations under the Contract for so long as the relevant event of Force Majeure continues and to the extent that such party's performance is prevented, hindered or delayed. The Time for Completion shall be extended by a																			

		period of time equal to period of delay caused due to such Force Majeure event. Delay or non-performance by either party hereto caused by the occurrence of any event of Force Majeure shall not i) Constitute a default or breach of the Contract. ii) Give rise to any claim for damages or additional cost expense occasioned thereby, if and to the extent that such delay or non-performance is caused by the occurrence of an event of Force Majeure. BHEL at its discretion may consider short closure of contract after 1 year of imposition of Force Majeure in line with extant guidelines. In any case, Supplier/Vendor cannot consider deemed short-closure after 1 year of imposition of Force Majeure	
30.	Cartel Formation	The Bidder declares that they will not enter into any illegal or undisclosed agreement or understanding, whether formal or informal with other Bidder(s). This applies in particular to prices, specifications, certifications, subsidiary contracts, submission or non-submission of bids or any other actions to restrict competitiveness or to introduce cartelization in the bidding process. In case, the Bidder is found having indulged in above activities, suitable action shall be taken by BHEL as per extant policies/guidelines.	
31.	Order of Precedence:	In the event of any ambiguity or conflict between the Tender Documents, the order of precedence shall be in the order below: - Amendments/Clarifications/Corrigenda/Errata etc. issued in respect of the tender documents by BHEL. - Buyer Added Bid Specific ATC - GeM Bid Technical Conditions of Contract (TCC) - GeM GTC	
32.	Conflict of interest:	A bidder shall not have conflict of interest with other bidders. Such conflict of interest can lead to anti-competitive practices to the detriment of Procuring Entity's interests. The bidder found to have a conflict of interest shall be disqualified. A bidder may be considered to have a conflict of interest with one or more parties in this bidding process, if: - they have controlling partner (s) in common; or - they receive or have received any direct or indirect subsidy/financial stake from any of them; or - they have the same legal representative/agent for purposes of this bid; or - they have relationship with each other, directly or through common third parties, that puts them in a position to have access to information about or influence on the bid of another Bidder; or - Bidder participates in more than one bid in this bidding process. Participation by a Bidder in more than one Bid will result in the disqualification of all bids in which the parties are involved. However, this does not limit the inclusion of the components/sub-assembly/ Assemblies from. one bidding manufacturer in more than one bid; or - In cases of agents quoting in offshore procurements, on behalf of their principal manufacturers, one agent cannot represent two manufacturers or quote on their behalf in a particular tender enquiry. One manufacturer can also authorize only one agent/dealer. There can be only one bid from the following: 1. The principal manufacturer directly or through one Indian agent on his behalf; and 2. Indian/foreign agent on behalf of only one principal· or - A Bidder or any of its affiliates participated as a consultant in the preparation of the design or technical specifications of the contract that is the subject of the Bid· or - In case of a holding company having more than one independently manufacturing units, or more than one unit having common business ownership/management, only one unit should quote. Similar restrictions would apply to closely related sister companies. Bidders must proactively declare such sister/ common business/ management units in same/ similar line of business.	
33.	Guarantee clause	Kindly confirm that Guarantee shall be provided for a period of “24 months from the date of dispatch or 18 months from the date of commissioning, whichever is earlier”. In case of any failure or trouble reported from site, the supplier should	

		depute their representative immediately to attend the problem and replace the defective component/part if required, without any additional cost to BHEL.	
		Supplier shall be responsible for free replacement of defective equipment / material at our site	
		Please note that offers with guarantee period lesser than above mentioned guarantee period may result in rejection of the offer.	
34.	Order Acceptance:	Ink signed order acceptance shall be furnished within 15 days of order placement. In case, order acceptance do not received within 15 days of order placement, PO deemed to be accepted by you.	
35.	Beneficiary of PO	Kindly confirm on whom the PO will be placed in the event of ordering.	
36.	Dispatch documents	Following dispatch documents to be provided immediately after directly dispatch to BHEL Project site for billing purpose: • Guarantee/Warrantee Certificates • E- Invoice and commercial invoice • GeM invoice • Original consignee copies of GR/LR/RR (Material shall be dispatched on door delivery basis without consignee copy) • Packing list • Original GST compliance certificate • E-way bill • MRC/POD/Receipted LR/RR/GR copy (as per proof of delivery of material at BHEL Project site)	
37.	Additional Conditions for Assessment	BHEL reserves the right to consider / Not-consider the offers based on the evaluation of documents submitted for the Pre-Qualification Criteria (PQR). BHEL also reserves the right to have on-site assessment of the facilities at supplier's works during the bid evaluation.	
38.	O&M Manuals	Kindly confirm that in the event of ordering, 22 Sets hard copies (Paper based) and 6 SetS (in CD ROM) of O & M manual shall be furnished containing all drawings and datasheet, catalogues of all instruments and instructions for storage, erection & commissioning, operation and maintenance after approval. Please submit same to BHEL Haridwar after despatch of material. Kindly confirm that in the event of ordering, 3 Sets hard copies (Paper based) and 1 SetS (in CD ROM) of O & M manual would be kept inside the dispatch box of Oil Purification Unit & the same shall also be mentioned in your Shipping/Packing List.	
39.	Quality Requirement	Vendor to confirm and endorse BHEL SQP QA_BI_QP_111_REV04. Vendor to confirm that inspection shall be done by BHEL nominated inspection agency M/s TUV as per BHEL SQP QA_BI_QP_111_REV04. For Spares: • Vendor to confirm that Testing/Witnessing/certification will be done as per approved quality plan of main item. • Vendor to confirm that If item does not appear in approved quality plan then Certificate of compliance will be provided. • Vendor to confirm that interchangeability certificate will be provided for spares.	

		All the vendors to confirm that paint material shall be procured from following manufacturer: - • Asian Paints India Ltd. • Shalimar Paints • Jotun • Akzonobel • Berger Paints • Good Lass Nerolac Paints • Bombay Paints • Jenson & Nicholson	
		The Charges for Pre-Inspection would be borne by BHEL. However at least 15 days' notice is to be provided for arranging Pre-Inspection.	
40.	Bidder Contact details	Please provide Contact details of your representative for techno-commercial clarifications: Mobile no. & Email id (minimum 2 person)	

SPECIAL NOTE FOR BIDDERS:

- In the event of our customer order covering this tender being cancelled /placed on hold /otherwise modified, BHEL would be constrained to accordingly cancel / hold / modify the tender at any stage of execution.
- BHEL may negotiate the L1 rate, if not meeting our budget / estimated cost. BHEL may re-float the tender opened, if L1 price is not acceptable to BHEL even after negotiation.
- Any change in applicable rates of Tax or any other statutory levies (Direct / Indirect) or any new introduction of any levy by means of statute and its corresponding liability for the deliveries beyond the agreed delivery date for reasons not attributable to BHEL will be to vendors account. BHEL will not reimburse the same and any subsequent claim in this respect will be summarily rejected.
- BHEL reserves its right to reject an offer due to unsatisfactory past performance by the respective Vendor in the execution of any contract to any BHEL project / Unit.
- The offers of the bidders who are under suspension and also the offers of the bidders, who engage the services of the banned firms /principal/agents, shall be rejected. The list of banned firms is available on BHEL web site www.bhel.com.
- Recovery / deduction as applicable as per Direct and Indirect taxes as notified by Govt. Of India from time to time will be made and information/certificate for such deduction/recoveries shall be provided by BHEL to the vendor.
- If the delivery of supply as detailed above gets delayed beyond the delivery period, the Supplier/Vendor shall request for a delivery extension and BHEL at its discretion may extend the Contract. However, if any 'Delivery extension' is granted to the Supplier/Vendor for completion of supply, due to backlog attributable to the Supplier/Vendor, then it shall be without prejudice to the rights of BHEL to impose LD for the delays attributable to the Supplier/Vendor.
- In case BHEL increase the quantity during currency of the contract in line with quantity variation clause of GeM bid, delivery extension on pro-rata basis shall be given for supply of these additional quantity.

Following documents are an integral part of this Tender Enquiry and endorsed copies of these documents (duly signed and stamped on each page, as a token of acceptance) are to be submitted/uploaded along with offer on GeM portal against this bid.

- Please submit replica of Price schedule (without prices) showing "quoted" in place of price along with techno-commercial bid (Part-I).
- Please submit signed & Stamped copy (each page) of duly filled of confirmation column of "Buyers Specific Additional Terms & Conditions (ATC)" and its clause wise supporting documents where required.
- Please submit signed & stamped copy (each page) for qualifying PQR with proper filled information and related supporting documents as mentioned in PQR.
- Please submit signed & stamped copy (each page) of BHEL SQP QA_BI_QP_111_REV04.
- Please submit certificate of Minimum local content as specified in the Make In India Certificate of the tender

COPYRIGHT AND CONFIDENTIAL

THE INFORMATION ON THIS DOCUMENT IS THE PROPERTY OF BHARAT HEAVY ELECTRICALS LIMITED. IT MUST NOT BE USED DIRECTLY OR INDIRECTLY IN ANY WAY DETERIMENTAL TO THE INTEREST OF THE COMPANY.

21323913000
Ref.Drawing No

Sign & Date

Inventory No.

10000-68281-8
DRAWING No.

FIRST ANGLE PROJECTION

(ALL DIMENSIONS ARE IN mm)

FORM DG 38(B)

TABLE-1 SPARES FOR SEAL STEAM SUPPLY VALVE

S.NO.	ITEM DESCRIPTION	QTY.	
01	COMPLETE SET OF INTERNALS (EXCEPT OUTER BODY& BONNET ALONG WITH ACTUATOR)	1 SET	
02	GUIDE BUSHINGS	1 SET	
03	PLUG AND STEM ASSEMBLY	1 SET	
04	CAGE	1 NO	
05	SET OF O RINGS	1 SET	
06	SEALING RINGS	1 SET	
07	SET OF GASKETS	1 SET	
09	BONNET SEAL	1 SET	
10	SET OF PACKING	1 SET	
11	SEAT RING	1 NO	
12	GLAND PACKING	1 SET	
13	RETAINER RING	1 NO	

TABLE-2 SPARES FOR SEAL STEAM SUPPLY VALVE ACTUATOR

S.NO.	ITEM DESCRIPTION	QTY.	
01	COMPLETE ACTUATOR ASSEMBLY ALONG WITH ACCESSORIES	1 SET	
02	POSITIONER ALONG WITH POSITION TRANSMITTER	1 NO	
03	ACTUATOR DIAPHRAGM	1 NO	
04	ACTUATOR STEM	1 NO	
05	SEALS/GASKETS	1 SET	
06	O RINGS	1 SET	
07	AIR LOCK RELAY	1 NO	
08	VOLUME BOOSTER	1 NO	
09	AIR FILTER & RELIEF VALVE	1 NO	
10	AIR SET	1 NO	
11	PILOT RELAY	1 NO	

TECHNICAL REQUIREMENTS :-

- INTERCHANGEABILITY OF THE MENTIONED ITEMS ARE FOR REPLACEMENT WITH THEIR PARTS FOR WHICH SUPPLY IS TO BE MADE AGAINST MAIN OFFER
- ALL THE SPARES MUST BE PACKED IN SEALED TRANSPARENT PLASTIC BAGS AND CLEARLY MARKED OR LABELLED ON THE OUTSIDE OF THE PACKING WITH ITS DESCRIPTION & ASSEMBLY PART NUMBERS.
- QUALITY CHECKS & TESTING NORMS/REQUIREMENTS AS PER AGREED QUALITY PLAN (QP) SHALL ALSO BE APPLICABLE FOR ALL THE SPARES AS LISTED.
- ALL THE RELEVANT ASSEMBLY DRGS. SHALL BE FURNISHED BY THE VENDOR MARKING ALL THE OFFERED ITEMS.

GMS No./		C B O M		STATUS OF DRG
AGREED DEPT	NAME	SIGN	DATE	
CIE	SASWATI	-SD-	03.01.16	

TYPE OF PRODUCT
OR
NAME OF CUSTOMER/PROJECT

STEAM TURBINE



BHARAT HEAVY ELECTRICALS LTD.
RANIPUR, HARDWAR

	NAME	SIGN	DATE	NO. OF VAR — 73 74
DRN	HARENDRA	SD/-	01.01.16	
CHD	AKS/NN	SD/-	02.01.16	
APPD	P.K.BANSAL	SD/-	03.01.16	

DEPT STE		SCALE NTS	WEIGHT (KG) —	REF. TO ASSY. DRG.	ITEM No. —	NO. OF ITEMS — 75 77
CODE 4011						

TITLE :
 OPTIONAL SPARES —
SEAL STEAM VALVE

CARD CODE	DRAWING NO. 3-13239-00001	— 22 23 24
-----------	------------------------------	---------------

SHEET No. 1 No. OF SHEETS 1

SIZE A3

SPARES APPLICABLE FOR SEAL STEAM VALVE WITH PNEUMATIC ACTUATOR

NOTES: –

1. ALL THE MANDATORY SPARES SPECIFIED ABOVE SHALL BE MANUFACTURED EXACTLY SAME AS AGAINST MAIN SUPPLY.
2. AGAINST ITEM AT SERIAL NO.12 OF ABOVE TABLE PNEUMATIC ACTUATOR WITHOUT ACCESSORIES IS REQUIRED.
3. INTERCHANGEABILITY OF THE MENTIONED ITEMS ARE FOR REPLACEMENT WITH THEIR PARTS FOR WHICH SUPPLY IS TO BE MADE AGAINST MAIN OFFER.
4. ALL THE SPARES MUST BE PACKED IN SEALED TRANSPARENT PLASTIC BAGS AND CLEARLY MARKED OR LABELLED ON THE OUTSIDE OF THE PACKING WITH ITS DESCRIPTION & ASSEMBLY PART NUMBERS.
5. QUALITY CHECKS & TESTING NORMS/REQUIREMENTS AS PER AGREED QUALITY PLAN (QP) SHALL ALSO BE APPLICABLE FOR ALL THE SPARES AS LISTED.
6. IF ANY ITEM IS NOT APPLICABLE THAN EQUIVALENT ITEM TO BE SUPPLIED BY THE VENDOR.
7. ALL MANDATORY SPARES ARE TO BE PACKED IN GREEN COLOUR BOX WITH " MANDATORY SPARES FOR SEAL STEAM VALVE" LABELED ON IT.

MAT. CODE: W99313239655

SIZE A3

PQR FOR SEAL STEAM VALVE FOR 660 MW/800 MW PROJECTS

Clause No.	Pre-qualification requirements	Vender's response
1	The vendor should have experience of designing, manufacturing & supply of control valve that has been used in steam applications of Steam turbines of rating 500 MW or above as per following details: 1.1 Design pressure: 21 bar or above 1.2 Design temperature: 500 deg C or above 1.3 Valve size: 3" or above 1.4 Working medium: steam 1.5 ANSI class of the supplied valves shall be ASME 600 or higher. 1.6 Operating time for full control stroke shall < 3 seconds 1.7 Valve leakage class: Class IV or higher as per ANSI FCI 70-2. 1.8 Actuators of the valve shall be pneumatically operated 1.9 The vendor shall have experience of SMART type positioner.	<u>Yes/No</u>
2	The vendor should have experience of supplying the valve satisfying all the conditions referred at point no. 1 above for at least one steam turbine power plant of rating 500 MW or above, which has been commissioned at least one year as on date of issuance of enquiry. The vendor to submit experience details as per Annexure-A along with relevant documents of supplied valve & its actuator along with accessories like datasheets & drawings etc. to support their claim.	<u>Yes/No</u>

Note: -

- Against vendor's replies, BHEL reserves the right to ask for more information/documents/clarifications. Vendor's offer shall not be considered if vendor fails to furnish the document/information/clarifications as mentioned above or vendor doesn't meet the above acceptance criteria.

	STE-TG	CIE
Prepared by	<i>[Signature]</i>	<i>[Signature]</i>
Checked by	<i>[Signature]</i>	<i>[Signature]</i>
Approved by	<i>[Signature]</i>	<i>[Signature]</i>


ANNEXURE-A

Experience details for seal steam valve:

SL. No.	Description	Applicable data	
		As per BHEL requirement	As per vendor's experience
1.	Name of power station and its location		
2.	Client name and its address, Fax no. & contact No.		
3.	Name and designation of the responsible person in client's organization /Power plant		
4.	Capacity in MW of unit	500 MW or above	
5.	P.O. no. and date		
6.	Date of commissioning of above project		
7.	Manufactured by		
8.	Evidence of supplying the valve for above mentioned project viz. PO copy/end user certificate (shall not be more than 7 years old as on date of issuance of enquiry)		
9.	Design parameters		
	Design pressure	21 bar (a) or above	
	Design temperature	500 deg C or above	
10.	Size of the valve	≥ 3"	
11.	Operating time of actuators(open/close)	< 3 sec	
12.	Leakage class	Class IV or higher as per ANSI FCI 70-2	
13.	Valve class	ASME 600 or higher	
14.	Type of actuator	Pneumatically actuated	
15.	Working medium	Steam	
16.	Valve type	Control valve	
17.	Type of body	Globe	
18.	Positioner Type	SMART type	


MANUFACTURER'S NAME AND ADDRESS			STANDARD QUALITY PLAN				TO BE FILLED BY BHEL		TO BE FILLED BY BHEL					
BHEL	VENDOR'S NAME	ITEM	SEAL STEAM SUPPLY VALVE WITH PNEUMATIC ACTUATOR	QP NO.	QA_BI_QP_111, REV04									
				DATED	31.01.2025									
		DRG. NO.	AS PER PO											
		SPEC.	AS PER PO											
		REV	AS PER PO		Page 1 of 4									
SL. NO.	COMPONENT & OPERATIONS	CHARACTERISTICS		CLASS	TYPE OF CHECK	QUANTUM OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORDS		AGENCY			REMARKS
									M	B	N			
1	2	3		4	5	6	7	8	9	D	10			11

1.	Body / Bonnet	Mechanical Properties	CR	Physical Test	100%	BHEL APPROVED DATA SHEET/DRAWING	BHEL APPROVED DATA SHEET/DRAWING	TC	√	P	V		
		Chemical Analysis	CR	Chemical Testing	100%	BHEL APPROVED DATA SHEET/DRAWING	BHEL APPROVED DATA SHEET/DRAWING	TC	√	P	V		
		Heat Treatment	CR	Time & Temp.	100%	BHEL APPROVED DATA SHEET/DRAWING	BHEL APPROVED DATA SHEET/DRAWING	TC	√	P	V		
		Internal Soundness	CR	Radiography & UT	100%	BHEL APPROVED DATA SHEET/DRAWING	BHEL APPROVED DATA SHEET/DRAWING	IR	√	P	V		
		Hydraulic Test	CR	Hydraulic Test	100%	BHEL APPROVED DATA SHEET/DRAWING	No Leakage	IR	√	P	V		
2.	Trim (Plug, Seat, Stem)	Mechanical Properties	MA	Physical Test	100%	BHEL APPROVED DATA SHEET/DRAWING	BHEL APPROVED DATA SHEET/DRAWING	TC	√	P	V		
		Chemical Analysis	MA	Chemical Testing	100%	BHEL APPROVED DATA SHEET/DRAWING	BHEL APPROVED DATA SHEET/DRAWING	TC	√	P	V		

MANUFACTURER/SUBCONTRACTOR	 Digitally signed by Preeti Kumar Ranjan Date: 2025.01.31 11:32:06 +05'30'	LEGEND: ! RECORDS IDENTIFIED WITH 'TICK' SHALL BE ESSENTIALLY INCLUDED BY CONTRACTOR IN QA DOCUMENTATION. M: MANUFACTURER / SUBCONTRACTOR B: BHEL / NOM. INSPECTION AGENCY N: CUSTOMER INDICATE 'P' PERFORM 'W' WITNESS AND 'V' VERIFICATION	FOR CUSTOMER USE	APPROVED BY
		ALL 'W' INDICATED IN COLUMN 'N' SHALL BE 'CHP' OF CUSTOMER		


MANUFACTURER'S NAME AND ADDRESS			STANDARD QUALITY PLAN					TO BE FILLED BY BHEL		TO BE FILLED BY BHEL				
BHEL	VENDOR'S NAME	ITEM	SEAL STEAM SUPPLY VALVE WITH PNEUMATIC ACTUATOR		QP NO.	QA_BI_QP_111, REV04								
				DATED	31.01.2025									
		DRG. NO.		AS PER PO										
		SPEC.		AS PER PO										
		REV	AS PER PO			Page 2 of 4								
SL. NO.	COMPONENT & OPERATIONS	CHARACTERISTICS		CLASS	TYPE OF CHECK	QUANTUM OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORDS		AGENCY			REMARKS
											M	B	N	
1	2	3		4	5	6	7	8	9	D	10			11

3.	Studs and Nuts	Mechanical Properties	CR	Physical Test	One Per Lot	BHEL APPROVED DATA SHEET/DRAWING	BHEL APPROVED DATA SHEET/DRAWING	COC	√	P	V		
		Chemical Analysis	CR	Chemical Testing	One Per Lot	BHEL APPROVED DATA SHEET/DRAWING	BHEL APPROVED DATA SHEET/DRAWING	COC	√	P	V		
4.	Packing and Other Internal Parts	Material & Functional Tests	MA	As required by relevant Standard	Sample	BHEL APPROVED DATA SHEET/DRAWING	BHEL APPROVED DATA SHEET/DRAWING	COC	√	P	V		
	Actuator	Model	MA	Verify	Sample	BHEL APPROVED DATA SHEET/DRAWING	BHEL APPROVED DATA SHEET/DRAWING	COC	√	P	V		
		Functional Test	MA	Leakage	Sample	BHEL APPROVED DATA SHEET/DRAWING	BHEL APPROVED DATA SHEET/DRAWING	COC	√	P	V		
	Positioner	Model	MA	Verify	Sample	BHEL APPROVED DATA SHEET/DRAWING	BHEL APPROVED DATA SHEET/DRAWING	COC	√	P	V		

MANUFACTURER/SUBCONTRACTOR	 Digitally signed by Priti Kumar Ranjan Date: 2025.01.31 11:31:52 +05'30'	LEGEND:	FOR CUSTOMER USE	APPROVED BY
		! RECORDS IDENTIFIED WITH 'TICK' SHALL BE ESSENTIALLY INCLUDED BY CONTRACTOR IN QA DOCUMENTATION.		
		M: MANUFACTURER / SUBCONTRACTOR B: BHEL / NOM. INSPECTION AGENCY N: CUSTOMER INDICATE 'P' PERFORM 'W' WITNESS AND 'V' VERIFICATION ALL 'W' INDICATED IN COLUMN 'N' SHALL BE 'CHP' OF CUSTOMER		

MANUFACTURER'S NAME AND ADDRESS			STANDARD QUALITY PLAN				TO BE FILLED BY BHEL		TO BE FILLED BY BHEL			
BHEL	VENDOR'S NAME	ITEM	SEAL STEAM SUPPLY VALVE WITH PNEUMATIC ACTUATOR	QP NO.	QA_BI_QP_111, REV04							
				DATED	31.01.2025							
		DRG. NO.	AS PER PO									
		SPEC.	AS PER PO									
		REV	AS PER PO		Page 3 of 4							
SL. NO.	COMPONENT & OPERATIONS	CHARACTERISTICS	CLASS	TYPE OF CHECK	QUANTUM OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORDS	AGENCY			REMARKS
									M	B	N	
1	2	3	4	5	6	7	8	9	D	10		11


		Functional Test	MA	Testing With Valve	Sample	BHEL APPROVED DATA SHEET/DRAWING	BHEL APPROVED DATA SHEET/DRAWING	COC	√	P	V		
5.	Complete Valve	Hydraulic Test	CR	Hydraulic Test	100%	BHEL APPROVED DATA SHEET/DRAWING	BHEL APPROVED DATA SHEET/DRAWING	TC	√	P	W		
		Seat Leakage Test	CR	Leak test	100%	BHEL APPROVED DATA SHEET/DRAWING	BHEL APPROVED DATA SHEET/DRAWING	TC	√	P	W		
		Packing Tightness / Gasket Leakage	CR	Leak test	100%	BHEL APPROVED DATA SHEET/DRAWING	BHEL APPROVED DATA SHEET/DRAWING	TC	√	P	W		
		Operating Test (Opening & closing Time)	CR	Performance	100%	BHEL APPROVED DATA SHEET/DRAWING	BHEL APPROVED DATA SHEET/DRAWING	TC	√	P	W		

MANUFACTURER/SUBCONTRACTOR	 Digitally signed by Priti Kumar Ranjan Date: 2025.01.31 11:31:39 +05'30'	LEGEND:	FOR CUSTOMER USE	APPROVED BY
		! RECORDS IDENTIFIED WITH 'TICK' SHALL BE ESSENTIALLY INCLUDED BY CONTRACTOR IN QA DOCUMENTATION.		
		M: MANUFACTURER / SUBCONTRACTOR B: BHEL / NOM. INSPECTION AGENCY N: CUSTOMER INDICATE 'P' PERFORM 'W' WITNESS AND 'V' VERIFICATION ALL 'W' INDICATED IN COLUMN 'N' SHALL BE 'CHP' OF CUSTOMER		

MANUFACTURER'S NAME AND ADDRESS			STANDARD QUALITY PLAN				TO BE FILLED BY BHEL		TO BE FILLED BY BHEL					
BHEL	VENDOR'S NAME	ITEM	SEAL STEAM SUPPLY VALVE WITH PNEUMATIC ACTUATOR	QP NO.	QA_BI_QP_111, REV04									
				DATED	31.01.2025									
		DRG. NO.	AS PER PO											
		SPEC.	AS PER PO											
		REV	AS PER PO		Page 4 of 4									
SL. NO.	COMPONENT & OPERATIONS	CHARACTERISTICS		CLASS	TYPE OF CHECK	QUANTUM OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORDS		AGENCY			REMARKS
										M	B	N		
1	2	3		4	5	6	7	8	9	D	10			11

		Flow Capacity Test	CR	Valve Full Capacity	One Per Type	BHEL APPROVED DATA SHEET/DRAWING	BHEL APPROVED DATA SHEET/DRAWING	TC	√	P	V		BHEL Approved CV Test Report
Final Inspection													
6.	Painting	Color & Thickness	MA	Coating Thickness	100%	BHEL APPROVED DATA SHEET/DRAWING	BHEL APPROVED DATA SHEET/DRAWING	TC	√	P	V		
7.	Overall Dimensions	Overall Dimensions Inspection	MA	End to End dimensions	100%	BHEL APPROVED DATA SHEET/DRAWING	BHEL APPROVED DATA SHEET/DRAWING	TC	√	P	V		
8.	Complete Valve S/A & Packing	Verification	MA	Verification	100%	BHEL APPROVED DATA SHEET/DRAWING	BHEL APPROVED DATA SHEET/DRAWING	IR	√	P	-		

- Note:
1. Test certificates shall be submitted clause wise mentioning respective clause on each page.
 2. Valve shall be offered for witnessing in unpainted condition.

MANUFACTURER/SUBCONTRACTOR		LEGEND:	FOR CUSTOMER USE	APPROVED BY
		! RECORDS IDENTIFIED WITH 'TICK' SHALL BE ESSENTIALLY INCLUDED BY CONTRACTOR IN QA DOCUMENTATION.		
		M: MANUFACTURER / SUBCONTRACTOR B: BHEL / NOM. INSPECTION AGENCY N: CUSTOMER INDICATE 'P' PERFORM 'W' WITNESS AND 'V' VERIFICATION ALL 'W' INDICATED IN COLUMN 'N' SHALL BE 'CHP' OF CUSTOMER		

COPYRIGHT AND CONFIDENTIAL
THE INFORMATION ON THIS DOCUMENT IS THE PROPERTY OF BHARAT HEAVY ELECTRICALS LIMITED. IT MUST NOT BE USED DIRECTLY OR INDIRECTLY IN ANY WAY DETERMENTAL TO THE INTEREST OF THE COMPANY.

DPPPG 70100744_A, DPPPG 70096691_A
Ref.Drawing No> 2-13239-39000

Sign & Date
Inventory No

001239-52100-2

DRAWING No.

7

6

5

4

3

2

1

TABLE-1: VALVE DATA:-

OPERATING PARAMETERS	OPERATING CONDITION		
	CASE-1	CASE-2	CASE-3
INLET PRESSURE bar(a)	18	16	13
INLET TEMPERATURE (°C)	240	290	320
FLOW RATE (Kg/sec.)	1.13		
OUTLET PRESSURE bar(a)	1.048		
FLUID	STEAM		
DESIGN PRESSURE bar(a)	21 bar(abs)		
DESIGN TEMPERATURE (°C)	550		

FIG.1: SCHEMATIC DIAGRAM FOR SEAL STEAM SUPPLY VALVE

TABLE-2: ACTUATOR DATA:-

TYPE	ELECTRO-PNEUMATIC
INPUT SIGNAL	4 TO 20 mA.
OPERATING TIME FOR FULL CONTROL STROKE	<3 sec.
ΔP ACTUATOR	2 bar
TYPE OF DRIVE	DIAPHRAGM
FAILURE MODE	STAYPUT
PRESSURE OF CONTROL AIR SUPPLY AHEAD OF ACTUATOR (MAX/MIN.)	10/5 bar(g)
PNEUMATIC CONNECTION	3/4" BUTT WELDED
POSITIONER	I/P - POSITIONER (SMART TYPE)
ELECTRONIC POSITION FEEDBACK TRANSMITTER FOR BHEL USE	2 WIRE TYPE 4~20 mA OUTPUT, 24 V DC

TABLE-3: END CONNECTION DETAIL (REFER SH.2, T.R. 1.3):-

END CONNECTION	NOMINAL DIA.	SIZE			TYPE OF CONNECTION	WELD FIG./ FORM
		OUTER DIA.(mm)	WALL THICKNESS(mm)			
INLET	3"	88.9	5.49	FOR ALL PROJECTS	BUTT WELDED	FIG.4 AS PER ASME B16.25
OUTLET	10"	273.1	6.35	FOR OTHER PROJECTS	BUTT WELDED	FIG.4 AS PER ASME B16.25
			7.80	FOR MAITREE & ONWARDS PROJECTS		

TABLE-4:

ITEM DESCRIPTION
1. CONTROL VALVE FUNCTION: AIR TO OPEN SPRING TO CLOSE.
2. PNEUMATIC ACTUATOR: SPRING-DIAPHRAGM TYPE
3. I/P-POSITIONER
4. AIR VOLUME BOOSTER
5. BLOCKING VALVE
6. FILTER AND REDUCING STATION
7. STOP VALVE
8. 1/2" PIPE CONNECTOR

FIG.2: PROPOSED ARRANGEMENT OF SEAL STEAM SUPPLY VALVE (REFER SH.2,T.R. 1.3)

MAT. CODE : W90313239401

TABLE-5: REVISIONS

REV	DATE	ALTERED	REV	DATE	ALTERED
01	01.03.25	H.SINGH -SD- CHECKED L.P.SINGH -SD-	02	24.06.24	H.SINGH -SD- CHECKED L.P.SINGH -SD-

TABLE-6: CHANGES

CHANGES MADE ONLY IN DRG. SHEET NO.2 AS PER C/R NO. SSTEHS_000304.	CHANGES MADE ONLY IN DRG. SHEET NO.2 AS PER C/A NO. STE-24-F0144.

TABLE-7: STATUS OF DRG

AGREED DEPT	NAME	SIGN	DATE
CIE	MUDIT	-SD-	29.11.23

TABLE-8: TYPE OF PRODUCT OR NAME OF CUSTOMER/PROJECT

TYPE OF PRODUCT OR NAME OF CUSTOMER/PROJECT
STEAM TURBINE

TABLE-9: DEPT STE

DEPT	STE
4011	

TABLE-10: SCALE NTS

SCALE	NTS

TABLE-11: WEIGHT (KG)

WEIGHT (KG)
-

TABLE-12: REF. TO ASSY. DRG.

REF. TO ASSY. DRG.
-

TABLE-13: ITEM No.

ITEM No.
-

TABLE-14: NO. OF ITEMS

NO. OF ITEMS
75

TABLE-15: DRAWING NO.

DRAWING NO.
2-13239-52100

TABLE-16: SHEET No. 01

SHEET No. 01

TABLE-17: No. OF SHEETS 02

No. OF SHEETS 02

TABLE-18: CARD CODE

CARD CODE
7

TABLE-19: TITLE : SEAL STEAM VALVE WITH PNEU. ACTUATOR

TITLE : SEAL STEAM VALVE WITH PNEU. ACTUATOR

TABLE-20: SIZE A2

SIZE A2

PROJECT: 250 /500/660/700/800 MW PROJECT

DATE: 28.02.2025, REV05

ITEM: SMART POSITIONER FOR SEAL STEAM & LEAK STEAM CONTROL VALVE

ADDENDUM TO DRAWING NO:

APPLICATION: STEAM TURBINE

ADDITIONAL SPECIFICATION:

1.0 **SCOPE:** This specification is intended to cover the requirements of Smart positioner for Pneumatic actuator of control valve.

2.0 **ELECTRICAL:**

- 2.1 Input signal shall be 4-20 mA from control system with Hart signal super- imposed.
- 2.2 Power supply: loop powered.
- 2.3 Valve position sensing to be provided, non-contact type, 4-20 mA for control system.

3.0 **ENVIRONEMENT:**

- 3.1 Operating temp shall be 0 to 70 degree C.
- 3.2 Humidity: 0-95%
- 3.3 Protection class shall be IP-65 minimum.

4.0. **SOFTWARE CONFIGURATION DIAGNOSTIC:**

- 4.1 Windows 2000/NT based software. Software shall meet the requirement for configuration, diagnostics, calibration and testing of the actuator. However, Software package for advanced diagnostic features is not required.
- 4.2 It shall be SMART and should have advanced diagnostic features like Travel Counter on line partial closure test, valve signature analysis, step response test, valve friction/jamming detection. The Positioner shall be advanced diagnostic compatible.
- 4.3 Factory valve signature tests reports (PR vs valve travel and Travel vs IP signal shall be provided.

5.0 **CONFIGURATION/OPERATING MODES:**

- 5.1 Calibration: Remote calibration, auto & manual calibration shall be possible.
- 5.2 Operating range: Full range & split range signal range.
- 5.3 Valve action: Direct & reverse valve action.
- 5.4 Flow characterization possible to fit valve linear, equal percentage.

6.0 FAIL SAFE

6.1 In case control signal 4 – 20 mA DC fails, (Pneumatic supply in OK condition, the valve will move to the default Fail safe position (Fail Close --- for Leak as well as seal steam valves).

In case Pneumatic signal fails, control signal (4 – 20 mA DC) in OK condition, then Air inside the Actuator will be Locked by Air Lock Relay, thus Fail Lock condition will be achieved i.e. Last Position hold prior to Failure of Air supply.

7.0 PERFORMANCE:

7.1 Characteristic deviation shall be $\leq 0.5\%$ of SPAN.

7.2 Ambient temp. effect shall be $\leq 0.01\%$ Deg. C or better.

8.0 ACCESSORIES:

8.1 In built operator panel display with push buttons for configuration and display on the positioner itself (password/hardware Lock).

8.2 Air filter regulator to be provided.

8.3 Press Gauge Block for supply & output pressure, filter regulator other accessories shall be provided as on required basis for making system complete.

8.4 Junction Box to be provided. Junction Box Specification -18 Ways, ½” NPT 3 Nos. Cable entry. Weather Proof IP 65 Min.

8.5 Cable glands to be provided. Cable gland specification-Double Compression SS 304(Weather Proof IP 65)

8.6 Position transmitter whether integral part of positioner or not: To be specified by vendor.

9.0 DOCUMENTS TO BE PROVIDED:

9.1 Datasheet including positioner model and make, Hook –up diagram to be complete input/output signals duly terminated onto JB.

10.0 PACKING:

10.1 The positioner shall be loosely supplied in the main package with proper identification along with all fittings for mounting on the main valve and cables for termination to the Junction Box.

10.2 The Packing should be seaworthy (with silica gel) to avoid ingress of Moisture.

- 10.3 The positioner shall be packed in separate wooden box/compartment to avoid breakage.
- 10.4 Proper Labeling such as item name “Positioner”, “P.O.” etc. shall be clearly indicated on the wooden Box for identification in case of misplacement.
- 10.5 Two sets of Mounting and Calibration Instruction manual shall be sent along with the positioner.
- 10.6 O&M manual for mounting and calibration of positioner shall be submitted along with the offer.

Prepared:
(Mudit Jain) Sd/-
(CIE)

Checked:
(Saswati) Sd./-
(CIE)

Approved:
(Vinod Kumar) Sd./-
(CIE)

PROJECT INFORMATION - SITE DESIGN DATA – APL-KAWAI, PHASE-II

1. Project Information - Site Specific Design Details:

Project	Adani Power Rajasthan Limited (APRL), 2x800 MW Phase-II & 2x800 MW Phase-III Ultra Supercritical Thermal Power Projects
Existing Unit	2x660 MW Supercritical Thermal Power Plant
Site Location	Village - Kawai, Tehsil - Atru, Baran - District in Rajasthan
Eastern Longitude	76°43' 52" E
Northern Latitude	24°46' 40" N
Nearest Railway Station	Salpura at 0.2 km, Kota - Bina Line
Nearest Villages	Kawai
Nearest Town	Baran - 30 km
Nearest City	Kota at a distance of 130 Km
Nearest Port	Mundra
Nearest Airport	Kota at a distance of 120 km & Jaipur at 370 km
Access Road	NH-90 Near Site
Altitude	308.5 m above MSL
Seismic Data:	
(a) Seismic intensity	As per IS 1893, Part 1 & 4
(b) Zone	Zone-II as per IS 1893 latest edition
(c) Importance factor	1.75 as per IS: 1893-part IV latest edition
Wind Data:	
Basic wind speed	47 m/s as per IS 875 (Part-III) - latest edition K1 Factor – 1.07, K2 Factor – Shall be as per IS-875 Part III latest edition based on the height of the structure for Terrain Category 2 K3 Factor – 1, K4 Factor – 1
Wind Direction	Predominantly South-East
Ambient Air Temperature:	
(a) Dry bulb	27°C (Guarantee)
(b) Annual Mean Dry bulb	33.3°C
(c) Maximum Dry bulb	48.5°C
(d) Minimum Dry bulb	1.7°C
(e) Maximum Dry bulb (Design)	50°C
Relative Humidity:	
(a) Average	60% (Guarantee)
(b) Max. (Mean value of Summer month)	90%

PROJECT INFORMATION - SITE DESIGN DATA – APL-KAWAI, PHASE-II

(c) Min. (Mean value of Summer month)	18%
Rain Fall:	
Average Annual rain fall	761.4 mm
Auxiliary power supply:	
Power Evacuation	400 kV ($\pm 5\%$), 3 phase, 3 wire 50 Hz, effectively earthed.
Generation Voltage	27kV, 3 phase, 50 Hz, NGTR earthed
Plant HT Auxiliary Supply	11kV ($\pm 10\%$) & 6.6k V ($\pm 10\%$), 3-phase, 3W, 50 Hz, earthed through resistance.
Plant LT Auxiliary Supply	415V ($\pm 10\%$), 3 phase, 4 wire, solidly earthed.
Plant LT Emergency Supply	415V ($\pm 10\%$), 3 phase, 4 wire ungrounded.
Plant DC Supply	220V (+10% to -15%), DC 2 wire unearthed.
Plant UPS Supply	230V ($\pm 10\%$), 1 phase, 2 wires 50 Hz, A.C.
Panel lighting and space heaters	240V, 1-phase, 2wires 50 Hz, A.C. with one point earthed.
Metering, control & protection	220V DC control supply for Protection, Control Supply for Breaker feeders & Numerical relay. 110V AC supply for contactor-controlled feeder in LT Switchgear.
For motors rated above 2000 kW	11KV, 3 phase, 3 wire, 50 Hz earthed through resistance
For motors rated above 200kW & up to 2000kW	6.6kV, 3 phase, 3 wire, 50Hz earthed through resistance
For motors rated above 0.2kW up to 200 kW	415V AC, 3-phase, 4-wire, 50 Hz effectively earthed
For motors rated up to 0.2 kW	240V, 1 phase, 50 Hz, effectively earthed.
DC motor starters, DC solenoids, DC alarm	220V DC, 2 wire, unearthed DC
Frequency	50 Hz (+3% to -5%)
Fault Level	For 400KV- 63 kA (1 Sec.) For 11kV – 50kA (1 sec) For 6.6kV- 50 kA (1 Sec.) For 415V- 50 kA (1 Sec.) For 220V- 25 kA (1 Sec.)
Design Ambient Temperature of electrical equipment	50° C
Relative Humidity for design of Electrical equipment	90%

	2x800 MW BANDHAURA ULTRA SUPERCRITICAL THERMAL POWER PROJECT	MAH1-E-BTG-TGP-TM-S-I-001
Adani Power Limited	Technical Specification for Steam Turbine Generator (STG) & Auxiliaries	Page 1 of 3

VOL II

TECHNICAL SPECIFICATION

SECTION 6

SITE CONDITIONS

6.0 SITE CONDITIONS

6.1.0 Location and Infrastructure

2 x 800 MW coal based Ultra Super Critical Thermal Power Station (USCTPP) is being set up by **Adani Power Ltd.** at Bandhaura village, Singrauli District, Madhya Pradesh, India.

The site is well connected by the National / State Highways; State Highway (SH-14) is passing about 16 km from the site.

Bandhaura is well connected with Road as well as Rail network from all the major towns Waidhan and Singrauli in Madhya Pradesh

The Nearest Airport is at Varanasi at a distance of 280 km from the project site. The nearest railway station Singrauli station is located at 52 km from project site. The nearest seaport is at Dhamra at a distance of 770 km from project site.

6.2.0 Basic Plant Data

GEOLOGICAL CONDITIONS

Soil Data

Layer 1 - At project site sandy Clay soil strata is available having N values 8 to 16; average soil layer thickness 5m.

Layer 2 – Browning stiff Clay having N value 19 to 24; having soil layer thickness 5 to 10m.

Layer 3 – Poorly graded sand having N value 10 to 43; strata thickness from 10 to 15m.

Layer 4 – compacted sand having N value > 100; layer thickness 15 to 18m,

Subsequently sandy stone encounters.

Seismic intensity

Seismic Zone IV

Seismic Intensity: As per IS: 1893

Zone: IV

Importance Factor: 1.75

Zone Factor: (Moderate)

METEOROLOGICAL CONDITIONS

Ambient Air Temperature

Highest monthly mean of daily maximum temperature: 42 °C

Highest monthly mean of daily minimum temperature Min. 3.3 °C

Highest ambient temperature: 48.8 °C

Lowest ambient temperature: 1 °C

Relative Humidity

Maximum Humidity: 85%

Minimum Humidity: 20%

Average relative humidity: 66% during morning hours and 49% during evening hour

Rainfall

The annual average rain fall: 1132.7 mm.

Wind

Basic wind Speed experienced: 47 m/s as per IS 875 part 3:1987

Wind loads to be considered for design of structures shall be based on the design wind speeds arrived at. Based on IS: 875 (Part -3) or the actual observed wind speeds furnished above, whichever is more critical. The parameters for calculation of design wind speed as per IS: 875 (Part -3) -1987 are as follows:

Basic wind speed	47 /sec
Risk coefficient (K1 factor):	1.07 for plant structures 1.00 For non-plant structures
Terrain category (K2 factor):	Category 1
Topography factor (K3 factor):	1.0

PROJECT INFORMATION - SITE DESIGN DATA – MIRZAPUR

1. Project Information - Site Specific Design Details:

Project	2x800 MW Ultra Super-Critical Thermal Power Project
Site Location	Village – Dadri Khurd, Taluka – Mirzapur Sadar, Dist. – Mirzapur, Uttar Pradesh.
Eastern Longitude	82039'50.425" E to 82041'03.72" E
Northern Latitude	24058'41.645" N to 25000'16.88" N
Nearest Railway Station	Lusa Railway Station (on Mirzapur-Singrauli Line), approx. 24 km from Site.
Nearest City	Mirzapur, approx. 25 km by SH-5
Nearest Sea Port (By Rail Route)	Haldia Port, approx. 813 km from Site Distance from Dhamra Port is 870 km
Nearest Airport	Varanasi Airport, approx. 95 km from Site
Access Road	SH – 5, approx. 1.7 km from Site (on Mirzapur – Robertsganj section) NH-7, approx. 23 km (on Mirzapur - Chunar Section)
Altitude	180 m above MSL
Seismic Data:	
(a) Seismic intensity	As per IS 1893, Part 1 & 4
(b) Zone	Zone-III as per IS 1893 latest edition
(c) Importance factor	1.5 as per IS: 1893-part IV latest edition
Wind Data:	
Basic wind speed	47 m/s as per IS 875 (Part-III) - latest edition
Wind Direction	Southwest to Northeast
Ambient Air Temperature:	
(a) Dry bulb	27°C (Guarantee)
(b) Annual Mean Dry bulb	29°C
(c) Average Minimum Dry bulb	12°C
(d) Average Maximum Dry bulb	42°C
(e) Highest Ambient Dry bulb	48.8°C
Relative Humidity:	
(a) Average	60% (Guarantee)
(b) Max.	88%
(c) Min.	28%
Auxiliary power supply:	
Power Evacuation	400 kV (±5%), 3 phase, 3 wire 50 Hz, effectively earthed.
Generation Voltage	27kV, 3 phase, 50 Hz, NGTR earthed

PROJECT INFORMATION - SITE DESIGN DATA – MIRZAPUR

Plant HT Auxiliary Supply	11kV ($\pm 10\%$) & 6.6k V ($\pm 10\%$), 3-phase, 3W, 50 Hz, earthed through resistance.
Plant LT Auxiliary Supply	415V ($\pm 10\%$), 3 phase, 4 wire, solidly earthed.
Plant LT Emergency Supply	415V ($\pm 10\%$), 3 phase, 4 wire ungrounded.
Plant DC Supply	220V (+10% to -15%), DC 2 wire unearthed.
Plant UPS Supply	230V ($\pm 10\%$), 1 phase, 2 wires 50 Hz, A.C.
Panel lighting and space heaters	240V, 1-phase, 2wires 50 Hz, A.C. with one point earthed.
Metering, control & protection	220V DC control supply for Protection, Control Supply for Breaker feeders & Numerical relay. 110V AC supply for contactor-controlled feeder in LT Switchgear.
For motors rated above 2000 kW	11KV, 3 phase, 3 wire, 50 Hz earthed through resistance
For motors rated above 200kW & up to 2000kW	6.6kV, 3 phase, 3 wire, 50Hz earthed through resistance
For motors rated above 0.2kW up to 200 kW	415V AC, 3-phase, 4-wire, 50 Hz effectively earthed
For motors rated up to 0.2 kW	240V, 1 phase, 50 Hz, effectively earthed.
DC motor starters, DC solenoids, DC alarm	220V DC, 2 wire, unearthed DC
Frequency	50 Hz (+3% to -5%)
Fault Level	For 400KV- 63 kA (1 Sec.) For 11kV – 50kA (1 sec) For 6.6kV- 50 kA (1 Sec.) For 415V- 50 kA (1 Sec.) For 220V- 25 kA (1 Sec.)
Design Ambient Temperature of electrical equipment	50°C
Relative Humidity for design of Electrical equipment	90%

REL & REGL - Site specific design inputs				
S.No.	Parameters	Unit	REL- Raipur 2x800 MW	REGL-Raigarh 2x800 MW
1.	Ambient Temperature (Guarantee of SG)	°C	27	27
	Ambient Temperature (Design of SG)		Refer attached file	Refer attached file
2.	Relative Humidity (Guarantee of SG)	%	60	60
	Relative Humidity (Design of SG)		Refer attached file	Refer attached file
3.	Height above MSL	m	300	215
4.	Seismic Zone		Zone-II as per IS 1893 and Importance factor 1.75 as per IS: 1893 part IV latest edition	Zone-II as per IS 1893 and Importance factor 1.75 as per IS: 1893 part IV latest edition
5.	Wind Data			
5a.	Basic Wind Speed, Vb	m/s	44 m/s as per IS 875 (Part-III) latest edition	39 m/s as per IS 875 (Part-III) - latest edition
5b.	K1 Factor		1.07	1.07
5c.	K2 Factor		Shall be as per IS-875 Part III latest edition based on the height of the structure for Terrain Category 2	Shall be as per IS-875 Part III latest edition based on the height of the structure for Terrain Category 2
5d.	K3 Factor		1	1
5e.	K4 Factor		1	1

Check –List for seal steam supply valve (Material code: W90313239401), Drawing. No. 21323952100, Rev. 00

SL No.	BHEL SPECIFICATION REQUIREMENT	Vendor's confirmation/ Remark	Vendor's document no.
1	Valve body material: ASTM A217WC9		
2	Counter Flange material: ASTM A182 Gr. F22		
3	Valve Class: 600		
4	Valve Characteristics: Equal %		
5	Counter flange End connection details: i. Inlet : 88.9X5.49, Butt welded as per fig.4 of ASME B16.25 ii. Outlet : 273.1X7.80, Butt welded as per fig.4 of ASME B16.25		
6	Controllable range of Cv		
7	Hand wheel for manual operation shall be provided.		
8	Manual vent valve shall be provided.		
9	Following commissioning spares shall be provided: i. Packing & gaskets 1 set. ii. washers for flange: 1 complete set for each flange connection.		
10	Valve shall be IBR approved.		
11	Testing of valve as per cl. no. 2.2 of BHEL specification.		
12	Paint as per cl. no. 4.2 of BHEL specification or equivalent		
13	End connection in actuator for air supply: 3/4" pipe connector (CS, weldable) to be supplied by the vendor		
14	Failure mode: stay put		
15	Cv test report submission after placement of P.O.		
16	Operating time < 3 sec		
17	Weight of complete assembly of valve along with actuator <300 Kg		
18	Valve leakage class-V as per ANSI FCI 70-2		
19	Function of Actuator: Air to open spring to close		
20	Type of actuator: Spring diaphragm		
21	Recommended quality and quantity of air		
22	Required supply air pressure (Max/Min- 10/5 bar g)		
23	Documents submission for BHEL approval within 4 weeks after placement of P.O. as per cl. no. 3.2 of BHEL specification.		
24	O & M Manual: Submission of 25 Hard copies (3 copies along with equipment to the site & remaining 22 to BHEL, Hardwar within 12 weeks of placement of P.O.).		

ANNEXURE-C**Seal steam supply valve- Check List for Documents/Information to be furnished along with the offer**

SL. No.	Document/Information details	Vendor's confirmation/ Remark	Vendor's document no.
1	Data sheet of valve and actuator		
2	Sizing calculation of valve and actuator		
3	General arrangement drawing of valve along with actuator indicating: i. Cross-sectional drg. of valve and pneumatic actuator alongwith BOM. ii. overall dimensions, iii. required maintenance space, iv. details of weld ends, v. overall assembly weight vi. direction of flow		
4	Valve characteristic curve.		
5	List of commissioning spares.		
6	Hook up diagram along with its functional write up		
7	Detailed catalogue mentioning type of position transmitter position controller, volume booster, air lock relay, air filter and regulator		
8	Priced list of optional spare parts as per applicable BHEL drg. No. 31323900001 for future ordering		

non-return valves mounted on vertical pipe, integral bypass shall be used to facilitate draining

Control Valves

Control valves shall be used for HP & IP type depending upon the pressure & temperature rating as classified. The control valve sizing shall be suitable for obtaining rated flow conditions with valve opening at approximately 60 to 70% of total valve stem travel and minimum flow conditions with valve stem travel not less than 10% of total valve stem travel. All the valves shall be capable of handling at least 120% of the required rated flow. Further, the valve stem travel range from minimum flow condition to rated flow condition shall not be less than 50% of the total valve stem travel. The sizing shall be in accordance with the latest edition of ISA on control valves. The valves port outlet velocity shall not exceed 8 m/sec for liquid services, 150 m/sec for steam services and 50% of sonic velocity for flashing services.

Valve body rating shall meet the process pressure and temperature requirement as per ANSI B16.34. All control valves shall have leakage rate as per leakage Class-IV. For cavitation services, valves with anti-cavitation trim shall be provided. Applications like CEP minimum recirculation valve shall have anti-cavitation trim with tight shut-off. The deaerator level control valve shall have characterized trim cages to have a cavitation protection at minimum flow as well as good range ability.

S.No.	Service	Application	Trim material
1	Non-corrosive, non-flashing and non-cavitation service below 275 °C	Auxiliary steam flow to Deaerator, Condensate flow to Deaerator, CRH flow to Deaerator	ASME B 16.34 & SS 304
2	Severe flashing/cavitation services	HP heaters & LP heaters emergency drain, Deaerator overflow drain to hotwell etc.	ASME B 16.34 & Stellite / Hastelloy C
3	Low flashing/cavitation service	HP heater/ LP heater normal drains level control, GSC minimum flow, gland seal steam pressure control valve etc.	ASME B 16.34 & Stellite / Hastelloy B
4	Condensate service below 300 °C	Condensate normal and emergency make-up control, ECW DP control	ASME B 16.34 & SS 316

XXXIII. Noise level

In case the noise level pertaining to equipment covered under the scope exceeds the specified values, as given in relevant clause of General Technical requirement portion of Technical Specification, suitable acoustic enclosures along with all accessories in order to complete the system shall be provided to achieve the specified values. The acoustic enclosures & accessories shall be designed as per internationally accepted standards and shall be subject to Owner's approval. Maximum 85 dB(A) from 1 m away from the equipment.

Acoustic enclosure

XXXIV. INSULATION, CLADDING & PAINTING

	Transducer
Accuracy	+/- 1%
Electrical connection	Plug and socket
Accessories	All mounting hardware required like clamping fixtures, mechanism to remove the transducers online, interconnecting Cables etc. All weather canopy for protection from direct Sunlight and direct rain. Material of all fittings shall be SS316.

6.1.17 Electro Magnetic Flow-Meter

The electromagnetic flow meter shall include flow sensor and flow indicator cum integrator / totalizer and shall include all required accessories for satisfactory operation. The flow meter shall be based on full bore electromagnetic principle and shall be electronic type of proven design, make and model acceptable to the owner.

The flow meter shall meet or exceed the following requirement:

- (a) Output: 4-20 mA DC Isolated output
- (b) Accuracy: $\pm 0.5\%$ of calibrated span or better
- (c) Repeatability: $\pm 0.2\%$ of calibrated span or better
- (d) Power Supply: 240V AC $\pm 10\%$, 50 HZ $\pm 5\%$ / 24 V DC.
- (f) Protection class: IP-67
- (e) Flow tube SS304
- (f) Liner Hard Rubber

The flow meter shall provide local indication for instantaneous flow. It should also be possible to get local display for daily and monthly discharge. The flow meter shall indicate totalizer/ integrator to get the daily and monthly discharge as stated above.

6.2 CONTROL VALVES, ACTUATORS & ACCESSORIES

General Technical Guidelines for the Control Valves shall be as follows:

- a) Bidder shall exercise extreme caution in selecting severe service control valves like BFP recirculation valves, HP & LP bypass valves, superheater & reheater attemperator valves, PRDS valves for Boiler & Turbine, Soot blower steam pressure control valve, control valves whose downstream are connected to condenser and in vacuum such as HP/LP heater emergency level control, GSC minimum flow, gland sealing control, condensate spill to condensate storage tank, Deaerator drain to condenser Hotwell, condenser make up water control valve and CEP minimum flow control valve. For such critical applications, Bidder shall offer valves which are proven for similar application for not less than 2 years of continuous service in power plant environment. All the above valves shall have leakage class equal or better than class-V with metal-to-metal seating. These valves shall be of multi-stage, multi-path trim design to eliminate vibration, erosion, and noise effects. All other control valves shall not be inferior to leakage class IV.
- b) Wherever, steam conditioning calls for Pressure reducing & desuperheating as well, combined PRDS type valves shall be offered.
- c) Bidder shall provide redundant control valves for Main condensate flow control, Superheat attemperation control and Reheat attemperation control as a minimum. For other application, if the availability criteria for the plant cannot be met even with the best established product, redundant control valves shall be provided.

- d) All control valves shall be located near floor or platform for ease of access with adequate clearances for maintenance and lay-down and shall be placed as station with upstream motorized isolating valve, down-stream isolating valve, inching duty motorized bypass valve and manual drain valves as per P&ID. Each redundant control valve shall have its upstream and downstream motorized isolating valves.
- e) For detail technical specification of control valve, kindly refer Mechanical section.

6.2.1 Valve Actuators

Spring diaphragm type actuators shall generally be used. Piston type actuators shall be offered in case of high shut-off pressure & quick response requirement. Bidder shall provide piston type actuators for the following services as a minimum requirement.

- a) Auxiliary Pressure reducing & De-super heating stations (excluding spray valves if spray is considered from condensate discharge).
- b) Superheat and Reheat Spray Control Valves.
- c) Main condensate flow control valve.

The actuator shall be designed for 150% thrust required for the valve (at shut-off pressure) at an airline supply pressure of 5.5 Kg/Sq. cm.

All the actuators shall be supplied mounted on the valve with all the accessories integrally mounted. Diaphragms shall be designed for 200% maximum operating pressure.

Nylon reinforced neoprene shall be used as diaphragm material.

Valve actuators shall be capable of operating at 80 Deg. C ambient, continuously.

Entire actuator assembly shall be painted with corrosion inhibiting paint.

Air connection size shall be 1/4" NPT (F) unless otherwise dictated by process response time. Integral tubing shall be of stainless steel construction.

Bidder shall indicate the stroking time of the valve assemblies with positioner.

All actuators shall be of failsafe design signifying that the spring direction will tend to move the valve (open or close) in a direction safe for the process. "Failure to Open" or "Failure to Close" shall be marked on the actuator.

6.2.2 Valve Positioners

All regulating service valves shall be offered with HART protocol based Smart Electro Pneumatic Positioners to ensure accuracy and repeatability of response. Positioners shall have integral non-contact type position transmitter, input and output gauges, local keypad & display and 4-20 mA DC output for position indication in CCR. Positioners shall be capable of functioning under hot, humid and vibrating conditions. Positioner casings shall be dust tight, corrosion resistant and weatherproof.

In general, positioner shall operate at signal range 4 – 20 mA DC for the full travel of the valve. Split range operation in few cases may be required. Remote calibration from control room shall be possible through HART management station.

6.2.3 Valve Accessories

The accessories of the valves shall include side mounted hand wheels, limit switches, junction boxes, airlock relays etc.. Solenoid valve wherever required shall be furnished.



Annexure - 1

TECHNICAL SPECIFICATION FOR PAINTING & COATING OF EQUIPMENT & STRUCTURES

CONTENTS

1.0 INTRODUCTION

- 1.1 Scope / General
- 1.2 Definitions

2.0 CODES AND STANDARDS

- 2.1 Mandatory Statutory Requirements
- 2.2 Codes and Standards & Regulations
 - 2.2.1 The Society for Protective Coatings (SSPC)
 - 2.2.2 American Society for Testing and Materials (ASTM)
 - 2.2.3 Indian Standards (IS)
 - 2.2.4 British Standard (BS)
 - 2.2.5 International Standard of Organization (ISO)
 - 2.2.6 NACE Standard

3.0 SURFACE PREPARATION

- 3.1 General
- 3.2 Requirements of Blasting
- 3.3 Pre – Blasting Preparation
 - 3.3.1 Rough Edges
 - 3.3.2 Weld Flux and Spetter
 - 3.3.3 Surface Cleaning
 - 3.3.4 Chemical Contamination
 - 3.3.5 Equipment Protection
- 3.4 Blasting Operations
 - 3.4.1 Weather conditions
 - 3.4.2 Preliminary Blasting
 - 3.4.3 Blasting and Painting
 - 3.4.4 Post – Blasting Procedure
- 3.5 Blasting Equipment
 - 3.5.1 Compressed Air
 - 3.5.2 Nozzle
 - 3.5.3 Power Tools
 - 3.5.4 Shot Blasting Equipment
- 3.6 Blasting Abrasive
 - 3.6.1 Abrasive
 - 3.6.2 Shot Blasting Material

4.0 COATING APPLICATION

- 4.1 General Application
 - 4.1.1 Supply and Storage
 - 4.1.2 Pot Life
 - 4.1.3 Mixing
- 4.2 Application Requirements
 - 4.2.1 Cleanliness
 - 4.2.2 Temperature
 - 4.2.3 Weather Conditions
 - 4.2.4 Coats
 - 4.2.5 Brush Application (Stripe Coating)
 - 4.2.6 Finish Coat
 - 4.2.7 Field Welds
 - 4.2.8 Inorganic Zinc Primer
- 4.3 Spray Application
 - 4.3.1 Equipment
 - 4.3.2 Procedures
 - 4.3.3 Airless Spray Equipment
- 4.4 Brush Application
 - 4.4.1 General Requirements
 - 4.4.2 Equipment for Brush Application
 - 4.4.3 Procedure for Brush Application

5.0 REPAIR OF DAMAGED AREAS

- 5.1 Repair Procedure for Coating Damage
 - 5.1.1 Top Coat
 - 5.1.2 Base Coat

6.0 INSPECTION & TESTING

- 6.1 Quality Control
- 6.2 Inspection and Testing Requirements
- 6.3 Role of Vendor Representative
- 6.4 Qualification of supervisors, foremen and QC personnel at The Fabrication Yard
- 6.5 Equipment and Material
- 6.6 Inspection Instruments
 - 6.6.1 Calibration of Equipment
 - 6.6.2 Dry Film Thickness
- 6.7 Repair
- 6.8 Maintenance

7.0 PAINT MATERIALS

7.1 Required Characteristics of Paint Materials

8.0 COATING SYSTEMS

8.1 Scope

8.2 Surface Preparation

8.3 Paint System

8.3.1 For C5-M

8.3.2 For C4

8.3.3 For C3

9.0 COLOUR SCHEDULE

9.1 Equipment and piping standard colour code for mechanical

9.2 Standard colour code for electrical equipment

9.3 Colour coding for identification of pipelines used in thermal power plants

9.4 Colour code for structural steel

10.0 RECOMMENDED LIST OF PAINT MANUFACTURER

11.0 PROCEDURE OF APPROVAL OF NEW COATING MATERIAL

12.0 Annexure- ISO 12944

1.0 INTRODUCTION

1.1 Scope

This specification covers the minimum requirements governing surface preparation, selection, application & inspection of the protective coating system to be used on the interior and exterior exposed surfaces of all types of structural steel placed in thermal power plant to get high durability (above 15 years) in C5-M, C-4 & C-3 environment classified according to ISO 12944- 2.

Individual equipment specifications and /or drawings, when furnished, are to be used with these specifications. If conflict exists, the individual specifications and/or drawings shall govern.

Since maintenance –painting requirements are usually different from that necessary for new construction, salient points for each will likewise be addressed separately.

1.2 Definitions

The following definitions shall apply:

COMPANY shall mean Adani or the designated representative.

CONTRACTOR shall mean the party contracted to perform the work in accordance with the drawings, specifications & work scope.

2.0 CODES AND STANDARDS

2.1 Mandatory Statutory Requirements

This document has been prepared to the International Standards detailed within. The CONTRACTOR shall ensure that the Work is executed in accordance with international standards, Statutory & Regulatory requirements as per system application.

2.2 Codes and Standards & Regulations

The requirements of the latest published versions of the following listed Codes, Recommended Practices. Specifications and standards shall be met

2.2.1 Steel Structure Painting Council (SSPC)

SSPC-PA1 : Shop, Field and Maintenance Painting of Steel.

SSPC-PA2 : Measurement of Dry Coating Thickness with Magnetic Gauges

SSPC-SP1 : Solvent Cleaning

SSSC-SP2 : Hand Tool Cleaning

SSPC-SP3 : Power Tool Cleaning

SSPC-SP5 : White Metal Blast Cleaning

SSPC-SP6	:	Commercial Blast Cleaning
SSPC-SP7	:	Brush –Off Blast Cleaning
SSPC-SP10	:	Near White Blast Cleaning
SSPC-SP11	:	Power Tool Cleaning to bare metal
SSPC-SP12	:	Surface Preparation & cleaning of Steel and Other Hard Material by High and Ultra High Pressure Water Jetting Prior to recoating
SSPC-AB1	:	Mineral and Slag Abrasive
SSPC-SP20	:	Zinc rich coating Type-I (Inorganic) & Type-II (Organic)
SSPC-SP COM:		Surface Preparation and Abrasives Commentary, SSPC Painting Manual, Volume 2, "Systems and Specifications"
SSPC VIS-1	:	Visual Standard for Abrasive Blast Cleaned Steel
SSPC Vol.2	:	SSPC Painting Manual. Other equivalent Swedish, BS standard also applicable.

2.2.2 American Society for Testing and Materials (ASTM)

ASTM D4228:	Standard practice for qualification of coating Applicators for application of coating on steel surfaces.
ASTM B117 :	Salt Spray Test
ASTM G50 :	Standard practice for conducting atmospheric corrosion test
ASTM G53 (Part-B):	Weathering Test
ASTM D520 :	Zinc Dust (Metallic Zinc Powder)
ASTM D523 :	Specification for Gloss
ASTM D1200:	Viscosity
ASTM D1640:	Drying time
ASTM D1653:	Standard test method for evaluation of painted or quoted specimens subject to corrosive environment.
ASTM D2247:	Relative Humidity Test
ASTM D2697:	Volume of Solids
ASTM D4060:	Abrasion Resistance of Coating
ASTM D3359:	Standard test method for measuring adhesion by tape test
ASTM D5894:	Standard test method for evaluating drying or Curing during film. Corrosion resistance under Cyclic condensation/UV

2.2.3 Indian Standards

IS 5	:	Colours for Ready Mixed Paints and Enamels
------	---	--

2.2.4 International Standards Organization

- ISO –8501 : International Standard for Preparation of Surface
- ISO-8502 : Preparation of steel substrates before application of Paints & related products
- ISO-8502 (1 to 10) : Tests for the assessment for surface cleanliness
- ISO –8504 : Preparation of steel substrates before application of Paints and related products-Surface preparation method Part – 1, 2 & 3
- ISO 14713 : Protection against corrosion of iron and steel structure-Zinc and aluminum coating.
- ISO 4624 : Adhesion test of paint
- ISO 12944 : Corrosion protection of steel structure by protective paint system part 1 to 8
- ISO 4628 : Evaluation of degradation of paint coating
- ISO 4628-6 : Paints & varnishes - Evaluation of degradation of paint coatings - Designation of intensity, quantity & size of common types of defect - Part 6: Rating of degree of chalking by type method.

2.2.5 Occupational Safety and Health Act

OSHA : Occupational Safety and Health Act

2.2.6 NACE Standards

- NACE RP0188: Discontinuity (Holiday) Testing of Protective coating
- NACE RP0287: Surface profile Measurement of abrasive blast Cleaned steel surfaces using a replica tape.

2.2.7 RAL COLOUR CHART

3.0 SURFACE PREPARATION

3.1 General

The surface preparation procedures and requirements except for galvanizing and Cadmium plating shall be in accordance with Steel Structural Painting Council SSPC and ISO–8501.

The method of surface preparation used shall be compatible with the priming coat of Paint and be one or a combination of the following:-

1. Solvent Cleaning- SSPC-SP1
2. Hand Tool Cleaning - SSPC-SP2

- 3. Power Tool Cleaning - SSPC-SP3
- 4. Blast Cleaning refer 3.2 as below

All fabrication and assembly shall be completed before surface preparation begins.

Blast and prime of structural items prior to assembly will be permitted. All bolt holes shall be drilled and their edges smoothed prior to blasting.

3.2 Requirements of Blasting

Only dry blasting procedures are allowed. Definitions and requirements for, the various methods of surface cleaning are given below:

- A) White Metal Blast: As per SSPC SP5, & visual reference Sa3 as per ISO 8501-1.
- B) Near-White Blast: As per SSPC SP10, & visual reference Sa2.5 as per ISO 8501-1.
- C) Commercial Blast: As per SSPC SP6, & visual reference Sa2 as per ISO 8501-1.
- D) Brush-off Blast: As per SSPC SP7, & visual reference Sa1 as per ISO 8501-1

3.3 Pre Blasting preparation

3.3.1 Rough Edges

Sharp edges, fillets, corners and welds shall be rounded or smoothened by grinding (minimum radius 2 mm). Hard surface layers (e.g. resulting from flame cutting) shall be removed by grinding prior to blast cleaning.

All surfaces should be washed with clean fresh water prior to blast cleaning.

Any major surface defects, particularly surface laminations or scabs detrimental to the protective coating system shall be removed by suitable dressing. Where such defects have been revealed during blast cleaning, and dressing has been performed, the dressed area shall be re-blasted to the specified standard. Surface pores, cavities etc. shall be removed by suitable dressing or weld repair.

3.3.2 Weld Flux and Spatter

Weld flux, slag spatter, slivers etc. shall be ground smooth before blasting.

Welding surface imperfections shall be removed and surface profile shall be prepared as per ISO 12944-3.

Any surface on which grinding is done shall be spot blast cleaned or power tool cleaned to obtain required anchor pattern.
All welds shall be inspected and if necessary repaired prior to final blast cleaning of the area.

3.3.3 Surface Cleaning

Prior to blasting, all deposits or grease or oil shall be removed from the surface in accordance with SSPC-SP1 Solvent Cleaning using biodegradable water soluble cleaner.

3.3.4 Chemical Contamination

All chemical contamination shall be neutralized and/or flushed off prior to any other surface preparation.

3.4 Blasting Operations

3.4.1 Weather conditions

Blast cleaning shall not be done on any surface that is moist, or that may become moist, before the application of a primer.

Blasting is not permitted when:-

- a) The temperature of steel is less than 3°C above the dew point, as measured by a sling hydrometer,
- b) The relative humidity of the air is more than 60 %.

Relative humidity shall be maintained by an adequately designed Dehumidification system and the record shall be maintained.

3.4.2 Preliminary Blasting

If blasting is performed at night, the surfaces shall be re-blasted the following day to provide the specified surface preparation standard and the anchor profile required for the specified coating system.

3.4.3 Blasting and Painting

Blasting shall not be done adjacent to painting operations or coated surfaces that are not fully dry. Blasting shall overlap previously coated surfaces by at least 150 mm.

Blasting and Painting shall be done in closed chamber only.

The record of atmospheric conditions (Temp, RH, Dew Point) before the blasting & painting shall be maintained.

The use of silica sand is strictly prohibited

3.4.4 Post – Blasting Procedure

The surface to be coated shall be clean, dry, free from oil/grease, and have the specified roughness and cleanliness until the first coat is applied.

Blast cleaned steel surfaces shall not be touched by bare hands. The blast cleaned surface shall be rendered dust free and coated with the specified primer as soon as possible to avoid formation of oxidation on the surface, but in any case, four one from the time of blasting, and at least one hour prior to sundown of the day it is blasted and before any rusting occurs.

Any steel surface not primed within these limits or that is wet shall be reblasted.

No acid washes or other cleaning solutions or solvents shall be used on metal surfaces after they are blasted. This includes washes intended to prevent rusting.

All areas around the intended paint surface shall be cleaned of blast material prior to coating. Drains shall be purged of blast material and flushed.

Biodegradable water – soluble cleaning solution used to clean previously painted surfaces shall not lift softens or otherwise damages the existing coating.

For determination of chloride surface; relevant ISO 8502 part 2 & 5 shall be applicable. Chloride contamination shall be checked using SCM 400 / bresle patches / quanta strips. Maximum permissible limit is 10 micro gram / sq.cm. for external surface & 5 micro gram / sq.cm. for internal of vessels.

3.5 Blasting Equipment

3.5.1 Compressed Air

The air compressor shall be capable of maintaining a minimum of 700kpa (7 kg/cm² or 100 psi) air pressure at each blasting nozzle. The compressed air supply shall be free of water and oil. Adequate separators and traps shall be provided on the equipment, which shall be regularly purged of water and oil to maintain efficiency.

3.5.2 Nozzle

The nozzle shall be a 10 mm (maximum) internal diameter venture style nozzle.

3.5.3 Power Tools

Power tools may be used to obtain a metal surface finish as per SSPC SP11 where blasting is not possible, or on items which might be damaged by blasting.

3.5.4 Shot Blasting Equipment

Shot blasting equipment may be used for specific applications. Shot shall be changed as required to maintain the angular profile requirement.

3.6 Blasting Abrasive

3.6.1 Abrasive

The abrasive shall be as per SSPC-AB-1. The abrasives shall be copper slag, steel balls shall be free of contamination of dust and chlorides to produce the required anchor profile and graded as to be free from clay, silt or other matter likely to become embedded in the steel surface. Abrasives which have a tendency to shatter and adhere or embed in the steel surface shall not be acceptable. Recycled abrasive shall not be used. The use of sand is prohibited.

3.6.2 Shot Blasting Material

Shot blasting material shall pass through a G-16 to G-40 mesh screen. At least 25% to 30% steel grit shall be mixed with the graded shot to remove any rust, scale or other impurities pined into the surface. Shot blasting material is limited to iron, steel or synthetic shot which is applied by compressed air nozzles or centrifugal wheels. Shot blasting material shall be checked at least two times a week for replacement of abraded material.

4.0 COATING APPLICATION

4.1 General Application

All application, inspection and safety procedures shall be carried out in accordance with SSPC Painting Manuals, Vol. 1 Chapter 14.2 and Vol. 2 Chapter 5) and as set out below.

4.1.1 Supply and Storage

All coatings shall be furnished, mixed and applied in accordance with manufacturer's recommendations and as specified here in. Mixing of different

Manufacturer's coatings or applications on the same surface are not permitted.

All coating materials and thinners shall be in original, unopened containers being the manufacturers label batch numbers and instructions. For materials having a limited shelf life, the date of manufacture and the length of life shall be shown. Materials older than their stated shelf life shall not be used.

Materials shall be stored in accordance with the manufacturers Recommendations.

Coating materials that have gelled, other than thixotropic materials or materials that have deteriorated during storage shall not be used.

4.1.2 Pot Life

If the coating requires the addition of a catalyst, the manufacturer's Recommended pot life for the application conditions shall not be exceeded.

When the pot life is reached, the spray pot shall be emptied, cleaned and a new material catalyzed. Manufacturer's recommendations to be followed

4.1.3 Mixing

Mixing and thinning directions as furnished by the manufacturer shall be followed. Only thinners specified by the manufacturer shall be used.

All coating materials shall be stirred with a power mixer use, until the pigments, vehicles and catalysts are thoroughly mixed and then strained while being poured into the spray pot. During application the materials shall be agitated according to the manufacturer's recommendations. Different brands or types of paints shall not be intermixed.

4.2. Cleanliness

All Surfaces shall be clean free from dust and dry. Any blast cleaning dust or grit remaining on the surfaces shall be removed by means of compressed air before priming or application of any coating. Any surface with a rust bloom shall be re-blasted as per ISO: 8504.

4.2.1 Temperature

Coating shall only be applied when the temperature of the steel is at least 3°C above the dew point; ambient air temperature must be within the limits specified by the manufacturer.

4.2.2 Weather Conditions

No coatings shall be applied during fog, mist or rain or when humidity is not greater than 60% or on to wet surfaces. In case the minimum temperature at the fabrication yard is below 5 deg C, the contractor shall propose alternate coating procedure for Company's approval at the binding stage itself.

The company has the right to suspend application of coating when damage to the coating may result from actual or impending weather condition.

4.2.3 Coats

Each coat shall be applied uniformly and completely over the entire surface. Each coat shall be allowed to dry for the time specified by the manufacturer before the application of a succeeding coat. To reduce the possibility of intercoat contamination and to assure proper adhesion between successive coats, all coats shall be applied as soon as possible after the minimum specified drying time of the preceding coat.

4.2.4 Brush Application (Stripe Coating)

A stripe coat shall be applied by brush or roller after the prime coat has been applied. The stripe coat shall be applied to edges, corners, welding seams, bolt holes, back side of piping, stiffeners, vent and drain holes, notches and any other area that is difficult to reach by spray gun.

4.2.5 Finish Coat

An additional layer of finish coat shall be hand brushed at edges, corners, welds and hard-to spray areas to eliminate holidays in the final coats.

4.2.6 Field Welds

No coating shall be applied within 150 mm of edges prepared either for field welds or to surfaces waiting non-destructive testing.

4.2.7 Inorganic Zinc Primer

It is preferred that intermediate/top coat for inorganic zinc primer coats be applied within minimum of seven (7) days after the primer coat.

4.3 Spray Application

4.3.1 Equipment

- (a) All equipment to be used for spray applications shall be inspected and tested before application begins.
- (b) All equipment shall be maintained in good working order and shall be equal to that described in the manufacturer's instructions.
- (c) All equipment shall be thoroughly cleaned before and after each use and before adding new material.
- (d) An adequate moisture trap shall be installed between the air supply and each pressure pot. The trap shall be of the type that will continuously bleed off any water or oil from the air supply.
- (e) Suitable pressure regulators and gauges shall be provided for both the air supply to the pressure pot and the air supply to the spray gun. Spray equipment and operating pressures shall comply with the recommendations of the manufacturer.
- (f) The length of hose between the pressure pot and spray gun shall not exceed 15 m.

4.3.2 Procedures

- (a) Pressure pot, material hose and spray gun shall be kept at the same elevation where possible. When spraying inorganic zinc, the elevation difference shall not exceed 3m.
- (b) The spray gun shall be held at right angles to the surface.
- (c) Each pass with the spray gun shall overlap the previous pass by 50%.
- (d) The spray width shall not exceed 300 mm.
- (e) All runs and sags shall be immediately brushed out or the surface re-coated.
- (f) Large surfaces shall receive two passes (except when applying inorganic zinc) at right angles to each other (crosshatched).

4.3.3 Airless Spray Equipment

- (a) Airless spray equipment may be used for applying inorganic zinc, epoxy or aliphatic polyurethane coatings.
- (b) The manufacturer's recommendations in selection and use of airless spray equipment shall be followed.

4.4 Brush Application

4.4.1 General Requirements

- (a) Coating shall be applied by brush on all areas, which cannot be properly spray coated such as corners, edges, and welds etc.,
- (b) Inorganic zinc primer coatings shall not be applied by brushing, not even for touch – up repairs.

4.4.2 Equipment for Brush Application

Brushes shall be of a style and quality that will permit proper application of coating. Round or oval brushes are most suitable for rivets, bolts, irregular surfaces and rough or pitted steel. Wide flat brushes are suitable for large flat areas. Brush width shall not be greater than 100 mm. No extension handles shall be used on brushes.

4.4.3 Procedure for Brush Application

- (a) Brushing shall be done so that a smooth coat, uniform in thickness, is obtained. There shall be no deep or detrimental brush marks.
- (b) Paint shall be worked into all crevices and corners.
- (c) All runs and sags shall be brushed out to prevent air pockets, solvent bubbles or voids.
- (d) When applying solvent type, coatings, care shall be taken to prevent lifting of previous coats.

4.5 Safety Equipment

Appropriate safety equipment shall be provided for blasters, painters and other workers involved in the preparation and application of coating systems as per recommendation of paint manufacturer. Work areas shall be adequately ventilated.

5.0 REPAIR OF DAMAGED AREAS

All areas of paintwork that are locally damaged during transportation, handling or erection shall be fully repaired to the satisfaction of the company.

Prior to the application of any coat, damage to previous coat(s) shall be touched-up by removing the damaged coatings, preparing the surface and reapplying the protective coat(s).

5.1 Repair Procedure for Damaged coating

Surfaces where coating is damaged after application of the finish coat shall be repaired as follows;

5.1.1 Top Coat

The top coat damaged, but base coat undamaged and the metal substrate is not exposed:

- (a) Damaged coating shall be removed with a hand file and abraded back to the sound coating using emery paper or a fine grinder.
- (b) The damaged area shall be wiped with a suitable solvent to remove debris. The periphery of repair area shall be feathered back for a minimum distance of 25 mm into the adjacent undamaged coating by light abrasion or grinding to produce a smooth chamfered surface profile.
- (c) Apply a new topcoat as specified.

5.1.2 Base Coat

Coating damaged to base metal

- a) The damaged area greater than 0.2m² in area, the surface of exposed metal shall be prepared to the original specified standard prior to repairing by power tool cleaning as per SSPC-SP3 or spot blasting to SSPC-SP5 and applying primer, intermediate coat and final coat as specified. Alternatively, high solid surface tolerant epoxy coating such may be used in place of primer & intermediate coats, followed by specified topcoat.
- b) The damaged areas less than 0.2 m² in area may be repaired as per manufacturer's recommendation or by preparing the surface of exposed metal by power tool cleaning as per SSPC-SP11 to the original specified standard.

A primer, intermediate and final coat shall be applied as specified. Alternatively, high solid surface tolerant epoxy coating such may be used in place of primer & intermediate coats, followed by specified topcoat. Brush application is acceptable. Even appearance and smooth feathering into surrounding coating in addition to correct dry film thickness and holidays must be achieved. Coating and surrounding repaired areas shall not be damaged and complete tie-in of the coating with surrounding areas shall be obtained. Zinc based products shall not be applied without Blast Cleaning to Sa 2 ½, instead Surface tolerant epoxy such at 100 microns shall be used as a primer in case blast cleaning is not possible or practical.

6.0 INSPECTION AND TESTING

6.1 Quality Control

Procedures for testing and documenting quality control shall be prepared prior to the initial start up of any work covered by this specification & submitted to company for approval. The procedures shall include methods to assure the specification requirements are met and forms to document environmental conditions, surface temperature, coating applicator, surface(s) being coated, coating applied and status of required examinations and tests.

Testing and inspection shall be carried out in accordance with Table-6.2. Surfaces shall be accessible until final inspection is carried out.

6.2 Inspection and testing requirement

Test type	Test Method	Test Frequency	Acceptance criteria	Consequence
Environmental conditions	Ambient and steel Temperature. Relative Humidity. Dew point.	Before start of each shift + minimum twice per Shift.	In accordance with Specified requirements	No blasting or coating
Visual examination	Visual for sharp edges	100 % of all surfaces	No defects, see Specified	Defects to be repaired

	weld spatter slivers, rust grade, etc.		requirements	
Cleanliness	a) ISO 8501-1 b) ISO 8502-3	a) 100 % visual of all surfaces b) Spot checks	a) In accordance with specified Requirements b) Maximum quantity and size rating 2	a) Reblasting b) Recleaning and retesting until acceptable
Salt test	ISO 8502-6 and ISO 8502-9	Spot checks	Maximum conductivity corresponding to 20 mg/m ² NaCl	Repeated washing with potable water & retesting until acceptable
Chloride test	ISO 8502-2 ISO 8502-5	-	10 microgram/sq.cm for external & 5 microgram/sq.cm for internal vessel	-
Roughness	Comparator or stylus instrument (see ISO 8503)	Each component or once per 200 m ²	As specified	Reblasting
Curing test (for Zn silicate)	ASTM D4752	Each component or once per 100 m ²	Rating 4-5	Allow to cure
Visual examination of coating	Visual to determine curing, contamination, solvent retention, pinholes/popping, sagging & surface defects	100 % of surface after each coat	According to specified requirements	Repair of defects
Holiday detection	NACE RP0188 and as per *note -1 below	As per coating system specification	No holidays	Repair & retesting.
Film thickness	ISO 19840. Calibration on a smooth surface	ISO 19840	ISO 19840, and coating system data sheet	Repair, additional coats or recoating as appropriate
Adhesion	ISO 4624 using equipment with an automatic centered pulling force	Each component or once per 200 m ²	*See note-2 below	Coating to be rejected

	& carried out when coating system are fully cured			
--	---	--	--	--

*Note:

1. Holiday Testing
Holiday testing shall be conducted in accordance with NACE SP0188. Minimum 10% of the coated areas, which include weld seams, corners, and edges, shall be holiday detected. Any holiday is unacceptable and shall be marked and repaired according to spot repair procedures.
2. Adhesion test
Adhesion test shall be carried out on separate test plates, minimum adhesion values in accordance with ISO 4624 shall be 5,0 MPa when using automatically centered test equipment.

6.3 Qualification of supervisors, foremen and QC personnel at The Fabrication Yard

The contractor's quality control inspector shall be qualified as a coating inspector in accordance with NS 476 Inspector level I or NACE level-I.

The contractor's quality control inspector shall qualify the tradesman level as blast-cleaner, painter, and applicator etc. for painting application.

The personnel shall have relevant knowledge of health and safety hazard, use of protection equipment, coating materials, mixing and thinning of coatings, coating pot-life, surface requirements etc.

Contractor shall carry out tests in accordance with the company approved Coating Procedure Specification for all coating systems that are planned to be used for this project before commencement of painting work.

The test shall be supervised by the coating manufacturer's Authorized technical representative and the contractor's quality control inspector and shall be witnessed & inspected and accepted by the FQA of Adani. Contractor shall issue an inspection report covering the qualification tests for the company approval.

The test shall be carried out on a test panel (minimum 1 m x 1 m) and at least on one end of, angle, channel, beam and flat bar and an alternative location providing similar complexity on the component to be used.

The acceptance criteria are the requirement to the visual and non – destructive inspection of the coating system described in this specification. Operators failing to meet the requirement shall not be allowed to carry out the work on this project.

6.4 Equipment and Material

Materials, tools or equipment used in the surface preparation and coating applications, shall be inspected regularly and rejected if they do not comply with the Specification.

6.5 Inspection Instruments

The following items shall be inspected using the inspection instruments listed below:

Instrument Item	Inspection Instrument
Surface Profile	Keane-tator Surface Profile Comparator or Testex Press-o-Film Elcometer 124 with 122 testex tape
Holidays	Tinker – Rasor Model M – 1
Surface Cleanliness	SSPC – Vis – 1
Viscosity	Zahn Viscometer or Ford Cup
Wet Film Thickness(WFT)	Nordson Wet Film Thickness Gauge Sheen WFT Gauge
Temperature & Humidity	Gardner Certified Hydrometer And Temperature Indicator
Surface Temperature	Pandux Surface Temperature Thermometer Elcometer Surface temperature gauge
Compressed Air Quality	Dry white cloth

6.5.1 Calibration

Each test instrument shall be maintained and calibrated as prescribed by the manufacturer.

6.5.2 Dry Film Thickness

The dry film thickness of the coating system shall be determined in accordance with SSPC-PA2 or by a Micro test thickness gauge or comparable instrument in accordance with the following procedure.

- (a) Ten readings shall be taken for every 10m² of painted areas.
- (b) 90% of all readings shall be within the specified dry film thickness.
- (c) Where thickness accordance with the above procedure falls below the specified minimum an additional coat of the intermediate or finish coat shall be applied.

7.0 PAINT MATERIALS:

The coating manufacturer shall provide a Coating System Data Sheet (CSDS) for each coating system to be used, containing at least the following information for each product:

- Surface pre-treatment requirements;
- Dry Film thickness (maximum, minimum and specified);
- Maximum and minimum re-coating intervals at relevant temperatures;
- Information on thinners to be used (quantities and type);
- coating repair system.
- Practical consumption
- Expected life of product with guarantee.
- MSDS

Paint manufacturer shall furnish all the characteristics of paint materials on printed literature, along with the test Certificate with actual test values of supplied batch for all the specified characteristics given in the specifications.

All the paint materials shall be of first quality, should pass all pre qualification testing for corrosive category – C5-M as per ISO 12944 and conform to the following general characteristics as per the tables below:

TABLE 7.1: REQUIRED CHARACTERISTIC OF PAINT MATERIALS

Technical Name	Type & Composition	Volume of solids (approx.)	DFT (Dry Film thickness) per coat (approx.)	Weight Per liter in kgs/ liters (approx)	Touch Dry at 25°C (approx)	Hard dry at 25°C (approx.)	Over coating Interval (approx.)	Pot life (approx.) 25°C
Inorganic zinc silicate Coating Containing	A two pack air drying self –	65 %±2	65-75 µ	2.2+/- 0.02	30 mts.	Over night	Min.; 16-24 Hrs Max. Indefinite.	4 Hrs

minimum 85% ±2 zinc in dry film by weight & 96% Purity of Zinc.	curingsolvent basedInorganic Zinc silicatecoating.							
Epoxy MIO High build containing minimum 50% MIO in dry film.	Two pack, super high build, polyamide cured epoxy, pigmented with natural lamellar micaceousironoxide	Min. 80%± 2	125-150 µ	1.82+/- 0.02	3 Hrs.	Overnig ht	Min. : 18 Hrs. Max. : Indefinite	2 hrs.
Glossy Aliphatic acrylic Polyurethane Topcoat	Two Components High Build Aliphatic Acrylic Polyurethane.	min 62% ±2	50-75 µ	1.46 +/- 0.02	1.5 hrs	12 hrs	Min. ;12 hrs Max. ;As per suppliers data	3 Hr
Inorganic zinc silicate Coating Containing minimum 75% ±2 zinc in dry film by weight & 96% Purity of Zinc.	A two pack air drying self – curing solvent based Inorganic Zinc silicate coating.	Min 60%± 2	65-75 µ	2.0+/- 0.02	30 mts	Overnig ht	Min.; 16-24 Hrs Max. Indefinite.	4 Hrs
Epoxy MIO High build containing minimum 50% MIO in dry film.	Two pack, high build, polyamide cured epoxy, pigmented with lamellar MIO.	Min 60%± 2	100-125 µ	1.58+/- 0.02	4 Hrs	18 hrs	Min. : 18 Hrs. Max. : Indefinite	5 hrs
Epoxy Direct to Metal Primer cum Finish Coating	Two pack, rapid cure, high build epoxy DTM primer cum finish	Min 70%±2	75-150 µ	1.63 +/- 0.02	30 mts	60 mts	60 mts	2 hrs
Rapid cure epoxy high build zinc phosphate primer(16% ZP content)	Two pack, rapid cure, high build polyamide cure, epoxy zinc phosphate primer.	Min 63%±2	50-100 µ	1.51+/- 0.02	45 mts	3 hrs	3 hrs	6 hrs
Self -priming Surfaceretolerant High build Epoxycoating	Two pack amid amine cured self priming epoxy mastic.	Min. 80%± 2	100- 125u	1.46 +/- 0.02	5 Hrs.	24 Hrs	Min. ;24 Hrs Max –As recommended by manufacturer	2 hrs

8.0 COATING SYSTEMS

8.1 Scope

The following section outlines the requirement of supply & application of anti corrosive coatings for corrosion protection of steel structural's

exposed to environments classified by ISO 12944-2 as C5-I, C5-M, C- 4 & C-3 and to get long term life (High Durability – above 15 years)

8.2 Surface Preparation

All the parts to be sprayed shall be degreased according to SSPC-SP 1. The absence of oil and grease after degreasing shall be tested by method given elsewhere in the specification.

Grind all sharp edges and corners to a minimum radius of 2 mm. Remove all welding slag, spatter & blend grind all sharp welds & high spots. Remove all salt deposits by jetting with clean (potable) water. Thereafter the surface to be abrasive blasted to near white metal finish as per SSPC-SP 10. Using SSPC VIS 1, it is to be visually assessed that the blast cleaned surface meets requirement of SSPC-SP 10.

Thereafter clear cellophane tape test as per ISO 8502-3 shall be used to confirm absence of dust on the blasted surface. Finally blasted surface shall be tested for presence of soluble salts as per method ISO 8502-9. Maximum allowable salt content shall be considered 50mg/M². (5 micrograms/cm²) In case salt content exceeds specified limit. The contaminated surface shall be cleaned by method as per Annex – C of ISO - 12944-4 (Water Cleaning.) or as per ISO 8501 – 4 (Wa-Wa 2 ½). After cleaning the surface shall be retested for salt content after drying.

The blasting media shall be either chilled iron or angular steel grit as per SSPC-AB-3 of mesh size G-16 to G-40. Copper or Nickel slag or Garret as abrasive will also be suitable having mesh size in the range of G16 to G24, conforming to SSPC-AB-1.

Mesh size shall be required as appropriate to the anchor tooth depth profile requirement and blasting equipment used. The blasted surface should be having angular profile depth of 50 to 75 microns with sharp angular shape. The profile depth shall be measured according to NACE standard RP 0287 (Replica Tape) or ASTM D 4417 method B (Profile depth gauge).

Suitable enclosure shall be provided to carry out the blast cleaning operation. The contractor shall put up minimum three temporary sheds each of size 15m x 30m with handling facilities at site to carry out abrasive blasting. If required prior approval from the factory inspector/pollution

control board etc. shall be obtained regarding the method of blast cleaning and abrasives used therein.

For manual blasting one profile depth measurement shall be taken every 10-20 M² of blasted surface. Surface preparation shall be completed in one abrasive blast cleaning operation wherever possible. If rust bloom (visual appearance of rust) appears on the blast cleaned surface before priming, the affected area shall be re-blasted to achieve specified degree of cleanliness after which only application of inorganic zinc silicate.

Air blasting pressure at nozzle shall be normally maintained at 100 psi. Air pressure and media size should be reduced and adjusted to preclude damage/distortion to thin gauge materials. Blasting time on work piece should be adjusted to only clean the surface and cut required anchor tooth with minimum loss of metal. Blast angle should be as close to perpendicular as possible but in no case greater than $\pm 30^\circ$ from perpendicular to work surface. Blasting media must be free of debris, excessive fines, contaminants such as NaCl and sulfur salts (Ref. SEC 13.2.1.6 of this Spec).

F-Tests for blasting media, blasting air & surface contamination.

F-1- Blasting Media

(For every fresh batch of media and one random test during blasting)

- a) Blasting Media shall be visually inspected for absence of contamination and debris using 10 X magnification.
- b) Inspection for the absence of oil contamination shall be conducted using following procedure:
 - Fill a small clean 200 ml bottle half full of abrasive.
 - Fill the bottle with potable water, cap and shake the bottle.
 - Inspect water for oil film/slick. If present, the blasting media is not to be used.
- c) Soluble salt contamination if suspected shall be verified by method ASTM D4940. If present, media to be replaced.
- d) Clean blasting equipment, especially pot and hoses, then replace blasting media and retest.

F-2 Test for Blasting Air

(Once Daily before start of blasting & once at random during blasting)

The air for blasting shall be free from moisture and oil. The compressor air shall be checked for oil and water contamination per ASTM D 4285.

F-3-Test for presence of oil/grease and contamination

The steel substrate after degreasing as per SSPC-SP 1 shall be tested as per following procedure to validate absence of oil and grease contamination.

- a) Visual inspection - Continue degreasing until all visible signs of contamination are removed.
- b) Conduct a solvent evaporation test by applying several drops or a small splash of residue-free trichloromethane on the suspect area especially pitting, crevice corrosion areas or depressed areas. An evaporation ring formation is indicative of oil and grease contamination. Continue degreasing and inspection till test is passed.

8.3 Paint Systems

8.3.1 For C5-M Environment Classification

Primer Coat: 1 coat of inorganic ethyl self-curing zinc silicate primer (coating) at 75 microns DFT/Coat to be applied by airless/pressure pot for high durability >15 yrs. The primer should meet the requirements of SSPC-SP 20 performance standard. Minimum Metallic Zinc in the dry film by weight must be 85%. Volume solids of the primer must be 65% .

Intermediate coat – 1 coat of Super High build epoxy MIO coating cured with polyamide hardener at 150 microns DFT/Coat to be applied by airless spray. Minimum Natural Lamellar Micaceous Iron Oxide content in the dry film must be 50% by weight. Volume solids of the product must be 80% .

Finish Coat- Two coats of High Build Gloss Aliphatic Acrylic Polyurethane at 50 micron/coat dry film thickness to be applied by brush/airless spray. Total thickness of the finish coat will be 100 microns. Volume Solids of the product must be 62% .

Total DFT minimum: 325 Microns and maximum: 350 Microns.

Notes:

1. This paint system is equivalent to the protective paint system no's (S7.14 & S 6.08) recommended for corrosion category C5-M & C5-I in ISO 12944-5.
2. This system is satisfactory for surface temperatures to 90° C continuous dry temperature.
3. Colour for final coat shall be as per colour code.
4. All material shall be supplied in the manufacturers original cans, durably & legibly marked with the description of the contents. This shall include the batch number, date of manufacturing & the manufacturer's name.
5. All coating materials used shall confirm to the composition clauses given against each product in the specification. In meeting the composition clauses, the manufacturer shall provide evidence of compliance from approved third party lab before start of the job & internal test report along with every supplied batch.
6. Material containing cadmium, lead or any other toxic material to environment/personnel shall not be used.

8.3.2 For C-4 Environment Classification

Primer Coat: 1 coat of inorganic ethyl self curing zinc silicate primer (coating) at 75 microns DFT/Coat to be applied by airless/pressure pot. The primer should meet the requirements of IS - 14946 performance standard. Minimum Metallic Zinc in the dry film by weight must be 75%. Volume solids of the primer must be 60% .

Intermediate coat – 1 coat of High build epoxy MIO coating cured with polyamide hardener at 100 microns DFT/ Coat to be applied by airless spray. Minimum Natural Lamellar Micaceous Iron Oxide content in the dry film must be 50% by weight. Volume solids of the product must be 60% .

Finish Coat- One coat of High Build Gloss Aliphatic Acrylic Polyurethane at 50 micron/coat dry film thickness to be applied by brush/airless spray. Volume Solids of the product must be 62%.

Total DFT minimum: 225 Microns.

Notes:

1. This paint system is equivalent to the protective paint system no S4.30 recommended for corrosion category C-4- in ISO 12944-5.
2. This system is satisfactory for surface temperatures to 90° C continuous dry temperature.
3. Colour for final coat shall be as per colour code.
4. All material shall be supplied in the manufacturers original cans, durably & legibly marked with the description of the contents. This shall include the batch number, date of manufacturing & the manufacturer's name.
5. All coating materials used shall confirm to the composition clauses given against each product in the specification. In meeting the composition clauses, the manufacturer shall provide evidence of compliance from approved third party lab before start of the job & internal test report along with every supplied batch.
6. Material containing cadmium, lead or any other toxic material to environment/personnel shall not be used.

8.3.3 For C-3 Environment Classification

Covered Areas like TG Shed etc:

Primer cum Top Coat: Two coat of DTM – Direct to Metal epoxy primer cum finish with optimum loading of Zinc Silicate anti corrosive pigments at 75 microns DFT/Coat to be applied by airless/pressure pot. The total thickness of the system will be 225 microns. Volume solids of the DTM coating must be 70%.

Total DFT minimum: 225 Microns.

Uncovered Areas – Exposed to UV Rays:

Primer Coat: 2coat of Rapid Cure, High Build, Epoxy Polyamide Cure Zinc Silicate Primer with optimum loading of Zinc Silicate anticorrosive pigment at 175 microns DFT/Coat to be applied by airless/pressure pot. Minimum Zinc phosphate pigment in the dry film by weight must be 16%. Volume solids of the primer must be 63%.

Finish Coat- One coat of High Build Gloss Aliphatic Acrylic Polyurethane at 50 micron/coat dry film thickness to be applied by brush/airless spray. Volume Solids of the product must be 62% .

Total DFT minimum: 225 Microns.

Notes:

1. This paint system is equivalent to the protective paint system no S3.18 recommended for corrosion category C-3- in ISO 12944-5.
2. This system is satisfactory for surface temperatures to 90° C continuous dry temperature.
3. Colour for final coat shall be as per colour code.
4. All material shall be supplied in the manufacturers original cans, durably & legibly marked with the description of the contents. This shall include the batch number, date of manufacturing & the manufacturer's name.
5. All coating materials used shall confirm to the composition clauses given against each product in the specification. In meeting the composition clauses, the manufacturer shall provide evidence of compliance from approved third party lab before start of the job & internal test report along with every supplied batch.
6. Material containing cadmium, lead or any other toxic material to environment/personnel shall not be used.

9 COLOUR SCHEDULE

9.1 EQUIPMENT AND PIPING STANDARD COLOUR CODE FOR MECHANICAL

EQUIPMENT

S. No.	Description	Ground Colour
A	CLOSED COOLING WATER SYSTEM	
1	Closed cooling water pumps	Sea Green
2	Plate heat exchanger	Sea Green
3	Closed cycle cooling water pump	Sea Green
4	CCCW Expansion tank	Sea Green
5	CCCW chemical dosing tank	Sea Green

B	WATER TREATMENT PLANT	
1	River water & Raw water	
a	Raw water pump	Sea Green
b	Clarifier	Sea Green
c	- Raw / Fire water storage tank	Sea Green
d	DM plant supply pump	Sea Green
e	Filter air blower	Sea Green
f	Filter back wash pump	Sea Green
g	Lime slaking tank & agitator	Sea Green
h	Lime slurry transfer pump	Sea Green
i	Lime solution tank	Sea Green
j	Lime solution dosing pump	Sea Green
k	Alum solution tank	Sea Green
l	Alum solution metering pump	Sea Green
m	Polyelectrolyte solution tank	Sea Green
n	Polyelectrolyte solution metering pump	Sea Green
o	Sludge feed pump	Sea Green
p	Filter press	Sea Green
q	Service water tank for DM building	Sea Green
r	Service water tank for control annex	Sea Green
2	Demineralisation system	
a	Activated carbon filter	Sea Green
b	Cation exchanger	Sea Green
c	Anion exchanger	Sea Green
d	Deaasser tower	Sea Green
e	Air blower for deaasser tower	Sea Green
f	Strong base anion exchanger	Sea Green
g	Deaassed water transfer pump	Sea Green
h	Strong base anion exchanger	Sea Green
i	Mixed bed polisher	Sea Green
j	Air blower for mixed bed polisher	Sea Green
k	DM Water Storage tank	Sea Green
l	DM water transfer pump	Sea Green
m	Acid unloading cum transfer pump	Dark Admiralty Grey
n	Bulk acid storage tank	Dark Admiralty Grey
o	Acid measuring tank for SAC	Dark Admiralty Grey
p	Acid measuring tank for MB	Dark Admiralty Grey
q	Regeneration water pump	Dark Admiralty Grey
r	Caustic Lye unloading cum transfer pump	Dark Violet
s	Bulk caustic storage tank	Dark Violet
t	Caustic regeneration tank & agitator	Dark Violet
u	Caustic solution filter	Dark Violet

S.No.	Description	Ground Colour
v	Caustic dilution tank for SBA/WBA	Dark Violet
w	Caustic dilution tank for MB	Dark Violet
x	Caustic pump for regeneration for WBA/SBA	Dark Violet
y	Waste water recirculation cum disposal pump	Sea Green
C	CRANE & HOIST	
1	Power house EOT crane	Canary Yellow
2	CW pump house EOT crane	Canary Yellow
D	COMPRESSED AIR PLANT	
1	Air compressor	Sky Blue

	2	Compressed air dryer	Sky Blue
	3	Air receiver	Sky Blue
E		Chemical Dosing	
	1	Hydrazine preparation tank	Dark Admiralty Grey
	2	Ammonia preparation tank	Dark Admiralty Grey
	3	Hydrazine & ammonia dosing tank	Dark Admiralty Grey
	4	Hydrazine & ammonia dosing pump	Dark Admiralty Grey
	5	Phosphate preparation tank	Dark Admiralty Grey
	6	Phosphate dosing tank	Dark Admiralty Grey
	7	Phosphate dosing pump	Dark Admiralty Grey
	8	- Sampling system	Dark Admiralty Grey
F		FIRE PROTECTION SYSTEM	
	1	Diesel engine driven pump	Fire red
	2	Fuel tank for diesel engine driven pump	Fire Red
	3	Main hydrant pump (Electrical)	Fire Red
	4	Jockey pump	Fire Red
	5	Fire Water Storage tank	Fire Red
	6	CO2 cylinder	Fire Red
G		FUEL OIL SYSTEM	
	1	Fuel oil pumps skid	Light Brown
	2	Fuel oil Storage tank	Light Brown
	3	Fuel oil strainer	Light Brown
H		ASH DISPOSAL SYSTEM	
	1	Ash transmitting vessel	Aluminium
I		AIR CONDITIONING AND VENTILATION SYSTEM	
	1	Refrigerant compressor	Sky Blue
	2	Chilled / condenser pumps	Sea Green
	3	Condenser water pipe	Sea Green
	4	Fans	Grey

9.2 STANDARD COLOUR CODE FOR ELECTRICAL EQUIPMENT

Sl. No.	Description	Colour	Colour No.
1	Transformers	Light grey	Shade 631 of IS : 5
2	Bus ducts	Light grey	Shade 631 of IS:5
3	Junction boxes.	Light grey	Shade 631 of IS:5
4	HT/LT Switchboards, Distribution boards, Control & Relay panels		
	a) Indoor	Siemens	RAL 7032
	b) Outdoor	Light grey	Shade 631 of IS:5
5	UPS Panel, charger panels	Siemens	RAL 7032
6	DG Alternator	Onan Green	-
7	NGR	Light grey	Shade 631 of IS : 5
8	Motor	Light grey	Shade 631 of IS : 5
9	Lighting fittings	As per manufacturer's	As per manufacturer's
10	Cable trays	Galvanized	

Note: 1. All panels that are to be erected at CCR floor shall be painted using RAL 7032 (exterior colour). All Electrical, C&I, Fire alarm or any other panel shall have this colour.

9.3 COLOUR CODING FOR IDENTIFICATION OF PIPELINES USED IN THERMAL POWER PLANTS

Sl.No	Medium	Ground Shade		Band Shade		Remarks
		Color	Color No. as per IS:5	Color	Color No. as per IS:5	
1	Water system					
a)	Untreated or raw / service	Sea green	217	White	-	White is not included in IS - 5-2007
b)	Treated/dematerialized	Sea green	217	Light orange	557	
c)	Condensate	Sea green	217	Light brown	410	
d)	Potable water	Sea green	217	French blue	166	
e)	RO water	Sea green	217	Light orange	557	
f)	Service & clarified water	Sea green	217	French blue	166	
2	Steam system					
a)	Auxiliary steam	Aluminium	-	Signal red	537	with aluminium
3	Air system					
a)	Instrument	Sky Blue	101	White	-	White not included in IS-5 - 2007
b)	Service/Plant	Sky Blue	101	White	-	
c)	Vacuum pipes	Sky Blue	101	Black	-	Black not included in
5	Gas system					
a)	Hydrogen	Canary yellow	309	Signal red	537	White is not included in
b)	Chlorine	Canary yellow	309	Dark violet	796	
c)	Carbon dioxide	Canary yellow	309	Light grey	631	
e)	Oxygen	Canary yellow	309	White	218	

Sl.No	Medium	Ground Shade		Band Shade		Remarks
		Color	Color No. as per IS:5	Color	Color No. as per IS:5	
6	Oils					
a)	LDO/HFO	Light brown	410	Brilliant green	221	
b)	Transformer oil	Light brown	410	Light orange	557	
7	Chemical feed					
a)	Acid piping (in water treatment plant)	Dark admiralty grey	632	Signal red	537	Hazard mark is given
b)	Alkali Piping (in water treatment plant)	Dark violet	796	Golden yellow	356	Hazard mark is given
8	Fire services	Fire red	536	-	-	
9	Effluent pipes	Black	-	-	-	

9.4 COLOUR CODE FOR STRUCTURAL STEEL

SL. NO	ITEAM/SERVICE	COLOR	COLOR No. as per IS:5
1	Gantry girder & monorail	Brilliant green	221
2	Gantry girder & monorail stopper	Signal red	537
3	Building structural steel columns brackets, beams bracings, roof truss, purloin, side grit, louvers, stringers	Dark admiralty grey	632
4	Pipe rack structure & trestle	Dark admiralty grey	632
5	Chequered plate (Plain Face)	Black	-
6	Grating	Black	-
7	Ladder	Dark admiralty grey	632
8	Hand railing Hand rail	Signal red	537
9	Middle rail	Signal red	537
10	Toe Plate	Signal red	537
11	Vertical post	Black	-
12	Structural steel for Silo	Smoke grey	692

10 RECOMMENDED LIST OF PAINT MANUFACTURER

- 1.Asian Paints India Ltd
2. Shalimar Paints
- 3.Jotun
4. Akzonobel
5. Berger Paints
6. Good lass Nerolac Paints
7. Bombay Paints
8. Jenson & Nicholson

11 PROCEDURE OF APPROVAL OF NEW COATING MATERIAL

Following procedure recommended is to be followed for approval materials Manufactured by new manufactures (indigenous and foreign):

1. Sample shall be selected by adani and the manufacturer should arrange testing of the coating materials as per the List of tests given in Para 5 below from one of the reputed Government Laboratories. Testing charge shall be borne by manufacturer.
2. Samples of coating materials should be submitted to the Govt. Laboratory in sealed containers with batch number and test certificate on regular format of manufacturer's testing laboratory.
3. All test panels should be prepared by the Govt. testing agency colored photographs of test panels should be taken before and after the test and should be enclosed along with test report.

Sample batch number and manufacturers test certificate should be enclosed along with the report. Test report must contain detail of observations and rating if any as per the testing code. Suggested Govt. laboratories are:

RRL, Hyderabad
HBTI, Kanpur
DMSRDE, Kanur
IIT, Bombay
BIS, Laboratories
UDCT, Mumbai

4. Manufacturers should intimate the company, details of samples submitted for testing, name of Govt. testing agency, date. Contact personnel of the Govt. testing agency. At the end of the test the manufacturer should submit the test reports to the Company for approval. The manufacturer(s) shall be qualified based on the results of these tests and the Company's decision in this regard - shall be Final and binding on the manufacturer.
5. All tests required for evaluation of acceptance coating materials for structural steel in thermal power plant shall be as per C5-M classification in ISO 12944 – 2 relevant ISO/ASTM standards.

Types of Environment

ISO 12944 classification	Typical Environments
C1 & C2	Rural areas, low pollution. Heated building/neutral atmosphere.
C3	Urban and industrial atmospheres. Moderate sulphur dioxide levels. Production areas with high humidity.
C4	Industrial and coastal. Chemical processing plants.
C5I	Industrial areas with high humidity and aggressive atmospheres.
C5M	Marine, offshore, estuaries, coastal areas with high salinity.