

**TELENGANA SUPER THERMAL POWER
PROJECT PHASE-I**

2 X 800 MW KARIMNAGAR TPS

TECHNICAL SPECIFICATION

FOR

SCREENED CONTROL CABLE

SPECIFICATION NO. : *PE - TS - 424 - 507 - E004*

REVISION : 0



**BHARAT HEAVY ELECTRICALS LIMITED
POWER SECTOR
PROJECT ENGINEERING MANAGEMENT
NOIDA, UP (INDIA) - 201301**



DOCUMENT TITLE
2X800MW KARIMNAGAR TPS
TECHNICAL SPECIFICATION FOR
SCREENED CONTROL CABLES

SPECIFICATION NO. PE-TS-424-507-E004

VOLUME II

SECTION -

REVISION 0

DATE: 10.07.2023

SHEET 1 OF 1

CONTENTS

<u>S. NO.</u>	<u>DESCRIPTION</u>	<u>NO. OF SHEETS</u>
01	CONTENTS	01
02	SECTION – 'I'	
	a) COMPLIANCE CERTIFICATE	01
	b) SPECIFIC TECHNICAL REQUIREMENTS	02
	c) DATA SHEET-A	06
	d) DATA SHEET-C (GUARANTEED TECHNICAL PARTICULARS)	04
03	SECTION – 'II'	
	a) GENERAL TECHNICAL SPECIFICATION	02
	b) ANNEXURE- A CORE IDENTIFICATION / PAIR IDENTIFICATION	02
	c) ANNEXURE-B STEEL DRUM DRAWING	02
	d) STANDARD QUALITY PLAN	05
	e) ANNEXURE- C TO QP	04
	TOTAL NO. OF SHEETS (INCLUDING COVER/SEPARATOR SHEETS)	=XX



DOCUMENT TITLE
2X800MW KARIMNAGAR TPS

TECHNICAL SPECIFICATION FOR
SCREENED CONTROL CABLES

SPECIFICATION NO. PE-TS- 424-507-E004

VOLUME II

REVISION 00

DATE: 10.07.2023

SHEET 1 of 1

COMPLIANCE CERTIFICATE

The bidder shall confirm compliance to the following by signing/ stamping this compliance certificate and furnishing same with the offer.

1. The scope of supply, technical details, construction features, design parameters etc. shall be as per technical specification & there are no exclusion/ deviation with regard to same
2. There are no deviation with respect to specification other than those furnished in the 'schedule of deviations'
3. Only those technical submittals which are specifically asked for in NIT to be submitted at tender stage shall be considered as part of offer. Any other submission, even if made, shall not be considered as part of offer.
4. Any comments/ clarifications on technical/ inspection requirements furnished as part of bidder's covering letter shall not be considered by BHEL, and bidder's offer shall be construed to be in conformance with the specification.
5. Any changes made by the bidder in the price schedule with respect to the description/ quantities from those given in BOQ-Cum-Price schedule of the specification shall not be considered (i.e., technical description & quantities as per specification shall prevail).

BIDDER'S STAMP & SIGNATURE



DOCUMENT TITLE
2X800MW KARIMNAGAR TPS

TECHNICAL SPECIFICATION FOR
SCREENED CONTROL CABLES

SPECIFICATION NO. PE-TS- 424-507-E004

VOLUME II

SECTION I

REVISION - 0

DATE: 10.07.2023

SHEET -

SECTION – I

SPECIFIC TECHNICAL REQUIREMENTS



DOCUMENT TITLE
2X800MW KARIMNAGAR TPS

TECHNICAL SPECIFICATION FOR
SCREENED CONTROL CABLES

SPECIFICATION NO. PE-TS- 424-507-E004

VOLUME II

SECTION I

REVISION - 0

DATE: 10.07.2023

SHEET 1 OF 13

1.0 SCOPE

- 1.1 Design, Manufacture, Inspection and testing at manufacture's works, proper packing and delivery to site of **Screened Control cables** conforming to this specification.
- 1.2 General technical requirements of the Screened Control cables are indicated in Section-II. Project specific technical/ quality requirements / changes are listed in Section-I.
- 1.3 The stipulations of Section-I, followed by those of Data Sheet-A shall prevail in case of any conflict between the stipulations of Section-I, Data Sheet - A & Section-II.
- 1.4 The documents shall be in English Language and MKS system of units.

2.0 BILL OF QUANTITIES:

- 2.1 Quantity requirements shall be as per BOQ-cum-price schedule enclosed in NIT.

3.0 SPECIFIC TECHNICAL REQUIREMENTS

<u>S.No.</u>	<u>Reference Clause No. of Section- II</u>	<u>Specific Requirement/ Change</u>
1	3.1	The standard quality plan no. shall be read as 0000-999-QOI-S-035 in place of PE-QP-999-507-E004.
1	3.3	Shall be read as "Type test report requirements, routine / acceptance testing and special testing requirements shall be as per Annexure – C of QP. All acceptance and routine tests as per the specification and relevant standards shall be carried out. Charges for these shall be deemed to be included in the equipment price.
2	3.4	This clause is null & void.
3	3.7 (clause is added)	All equipment to be supplied shall be of type tested design. During detailed engineering, the successful bidder shall submit for BHEL/NTPC approval the reports of all the type tests as listed in this specification and carried out within last ten years from the date of bid opening. These reports should be for the test conducted on the equipment similar to those proposed to be supplied under this contract and the test(s) should have been either conducted at an independent laboratory or should have been witnessed by a process plant/refinery/power plant/nuclear plant client or client representatives.
4	3.8 (clause is added)	However, if the successful bidder is not able to submit report of the type test(s) conducted within last ten years from the date of bid opening, or in the case of type test report(s) are not found to be meeting the specification requirements, the successful bidder shall conduct all such tests under this contract at no additional cost to the BHEL



DOCUMENT TITLE
2X800MW KARIMNAGAR TPS

TECHNICAL SPECIFICATION FOR
SCREENED CONTROL CABLES

SPECIFICATION NO. PE-TS- 424-507-E004

VOLUME II

SECTION I

REVISION - 0

DATE: 10.07.2023

SHEET 1 OF 13

		either at third party lab or in presence of BHEL/NTPC and submit the reports for approval.
5	3.9 (clause is added)	The type test reports (for type tests carried out within last ten years from the date of bid opening) once approved for any project of NTPC shall be treated as reference. For KARIMNAGAR TPS, an endorsement sheet will be furnished by the manufacturer confirming similarity and "No design Change". Minor changes if any shall be highlighted on the endorsement sheet.
5	3.10 (clause is added)	If a cable drum fails in site testing then that drum shall be supplied again by vendor free of cost to BHEL.


4.0 DRAWINGS & DOCUMENTS TO BE SUBMITTED

Following documents/drawings shall be submitted after placement of order for BHEL customer's approval: -

Sl. No.	Drawings/Document Description	Drawings / Document Number
1.	Technical Data Sheet – Screened control cables	PE-V0-424-507-E141
2.	Cross-sectional Drawings – Screened control cables	PE-V0-424-507-E143
3.	Type Test Reports – Screened control cable	PE-V0-424-507-E144
4.	Steel drum drawing (if applicable)	PE-V0-424-507-E145
5.	Standard Quality Plan - Screened control cables	PE-V0-424-507-E916 (*)

NOTE: (*)

Standard Quality Plan as enclosed in the technical specification is to be appended with cover sheet bearing document number & description as stated above. The signed & stamped copy for the same shall be submitted to BHEL without making any changes in the contents of the document.

	DESIGN CALCULATIONS FOR LV CABLE SELECTION & SIZING	Doc. No. PE-TS-424-507-E004
	NTPC LIMITED	Rev No. 01
	2X800 MW TELANGANA TELANGANA STPP (SG ISLAND)	10.07.2023

DATA SHEET-A

CABLE DETAILS OF INSTRUMENTATION CABLES (AS PER VDE)

- 1.0 Voltage grade : 225 V (Peak)
- 2.0 Type of cable : FRLS SCREENED CONTROL CABLES
- 3.0 Standards Applicable :

1	VDE 0815, VDE 0816, VDE 0472	General Construction & tests for cables.
2	VDE 0207, Part-4, Part-5, Part-6	For insulation thickness.
3	SEN-SS-424-1475, IEC-60332 Part-3 Cat-B	Flammability Tests
4	ASTMD-2843, ASTMD-2863, IEC-754 Part-1	FRLS Tests
5	IS-8784	SPECIFICATION FOR THERMOCOUPLE COMPENSATING CABLES
6	IS-10810	METHODS OF TEST FOR CABLES
7	ANSI MC-96.1	Thermocouple cable color codes

4.0 CONDUCTOR

- a) Material : Annealed bare copper
- b) Grade : Electrolytic
- c) Standard applicable : VDE 0815
- d) Min number of strands, Dia : 7, 0.3 mm (nom), 0.5 sq.mm
and cross sectional area
- e) Maximum Conductor loop
resistance/km (in ohm) at 20 : 73.4
degrees celsius
- f) Continuous operation suitability : 70

5.0 INSULATION



**DESIGN CALCULATIONS FOR LV CABLE
SELECTION & SIZING**

Doc. No. PE-DC-424-507-E002

NTPC LIMITED

Rev No. 01

**2X800 MW TELANGANA TELANGANA STPP
(SG ISLAND)**

- a) Material : PVC as per VDE 0207 Part 4, compound Y I3
- b) Application : Extruded
- c) Insulation thickness
- Min / Max : 0.25/ 0.35 (for 0.5 sq mm)
- d) Volume resistivity (Min) : 1×10^{14} at 20 deg .C & 1×10^{11} at 70 deg. C in ohm-cm

6.0 LAYING OF CORES

- a) Min. number of twist per : 20 (For 0.5 Sqmm)
Metre for paired cables.
- b) Maximum lay of individual : 50 mm (For 0.5 Sqmm)
twisted pair
- c) Diameter of core : In accordance with clause 5 (c)

7.0 IDENTIFICATION OF CORES : Band marking

8.0 INDIVIDUALLY SCREENED (F TYPE CABLE)

- a) Material : Aluminium-Mylar tape
- b) Coverage : 100%
- c) Overlap : Minimum 20%
- d) Min thickness (Micron) : 28
- e) Binder : Polyester tape.

9.0 OVERALL SCREENED (G TYPE CABLE)

- a) Material : Aluminium-Mylar tape
- b) Coverage : 100%
- c) Overlap : Minimum 20%
- d) Min. thickness (Micron) : 55



**DESIGN CALCULATIONS FOR LV CABLE
SELECTION & SIZING**

Doc. No. PE-DC-424-507-E002

NTPC LIMITED

Rev No. 01

**2X800 MW TELANGANA TELANGANA STPP
(SG ISLAND)**

e) Binder : Polyester tape.

10.0 DRAIN WIRE

To be provided separately for individual pair shield (wherever applicable) and overall shield.

a) Material : Annealed Tin coated copper conductor as per VDE: 0815

b) Min number of strands, Dia : 7, 0.3 mm (nom), 0.5 sq.mm
and cross sectional area

11.0 ACCESSORIES (BEDDING, BINDER, TAPE REQ.)

a) Material : Mylar Tape

12.0 OUTER SHEATH

a) Material : Extruded PVC (compound YM1) as per VDE 0207 Part-5

b) Thickness : As per VDE 0816 and VDE207 Part-5

Minimum Thickness at any point : 1.8 mm for unarmoured Cable / as per IS-1554-I for armoured cable

Nominal Thickness at any point : >1.8 mm for unarmoured Cable / as per IS-1554-I for armoured cable

c) Application : Extruded

d) Colour : Blue

e) Whether FRLS : YES

f) Other : Resistant to water, Fungus, Termite & rodent attack.

g) filler : Non-hygroscopic, flame retardant

13.0 FRLS/ FLAMMABILITY TESTS

a) Oxygen Index : 29% Minimum as per ASTM D 2863

b) Temperature Index : 250 °C Minimum as per ASTM D 2863

c) Acid gas generation : less than 20% by weight (As per IEC-



**DESIGN CALCULATIONS FOR LV CABLE
SELECTION & SIZING**

Doc. No. PE-DC-424-507-E002

NTPC LIMITED

Rev No. 01


**2X800 MW TELANGANA TELANGANA STPP
(SG ISLAND)**

754-1)

- d) Smoke density rating : Not more than 60% (As per ASTM D 2843) Defined as average area under curve when the results of smoke density plotted on a curve indicating light absorption v/s time as ASTM D 2843
- e) Flammability Test : IEEE-383
- f) Swedish Chimney Test : As SEN-SS-424-1475 Class F3,
- 14.0 TOLERANCE ON OVERALL DIAMETER : ± 2 mm max. over the declared value in Technical Data Sheet
- 15.0 VARIATION IN DIA & OVALITY AT ANY CROSS-SECTION : Maximum 1 mm
: Not more than 1mm.
- Cage clam suitability – to be provided

16.0 CABLE DRUM DETAILS

- a) Material Type & Construction: Wooden as per IS 10418
- b) Standard drum length : 1000 metres: up to and including 12 Pairs.
500 metres: above 12 pairs
- c) Tolerance on drum length : $\pm 5\%$
- d) Painting : Entire surface to be painted
- e) Outermost Layer : To be covered with waterproof
- 17.0 RIP CORD : A non-hygroscopic and non-wicking non metallic cord polyethylene.
- 18.0 Markings on Outer Sheath
- a) Progressive sequential Length marking to be provided : @ 1M by Embossing / Printing
- b) Progressive marking @ 5M : Manufacturer's name, type of insulation,

	DESIGN CALCULATIONS FOR LV CABLE SELECTION & SIZING	Doc. No. PE-DC-424-507-E002
	NTPC LIMITED	Rev No. 01
	2X800 MW TELANGANA TELANGANA STPP (SG ISLAND)	

FRLS, conductor size, no. of pairs, voltage grade, type of cable, year of manufacture, BHEL-PEM & NTPC by Embossing / Printing.

19.0 TECHNICAL PARAMETERS (C & I) As per Table below

STANDARD CABLE PARAMETERS FOR INSTRUMENTATION CABLE

Parameter	0.5 mm ² (I & OS) type-F	0.5 mm ² (OS) type-G
Mutual Capacitance (max.) at 0.8 kHz, nF/Km	120	100
Conductor Loop Resistance (max.), Ohm/Km	73.4 (Plain)	73.4 (Plain)
Insulation Resistance (min), M Ohm/ Km	100	100
Cross Talk Figure (min) at 0.8kHz, dB	60	60
Characteristic impedance(max.) at 1 kHz	320	340
Attenuation(max.) at 1 kHz db/Km	1.2	1.2

Note:

1. Cable parameters indicated above are at 20 degC (+/- 3 degC)

20.0 TEST VOLTAGE

Core – Core

Core- shield

- a) High voltage test : 2kV RMS for 1 min 0.5kV RMS for 1 min
- b) Resistance to direct current test: 0.22kV DC for 240 hrs/ 10 days



DOCUMENT TITLE
2X800MW KARIMNAGAR TPS
TECHNICAL SPECIFICATION FOR
SCREENED CONTROL CABLES

SPECIFICATION NO. PE-TS-424-507-E004

VOLUME II

SECTION - I

REVISION 0

DATE: 29.09.2017

Page 1

DATA SHEET-C

S.No.	Particulars	Unit	Description
1	Manufacturer's name	-	
2	Reference design standards	-	
3	Conductor size	sq. mm	
4	Rated Voltage	V	
5	Number of pairs	No.	
6	Cable suitable for both earthed & unearthed system	-	
7	Conductor		
	a) Material	-	
	b) Reference Standard	-	
	c) Grade	-	
	d) No. of strands	No.	
	e) Diameter of strands (nom.)	mm	
	f) Approx. dia of conductor	mm	
	g) Cross Section area	sq. mm	
	h) Maximum conductor resistance per Km at 20°C	ohm	
8	Insulation		
	a) Reference Standard	-	
	b) Material composition	-	
	c) Application	-	
	d) Minimum thickness	mm	
	e) Nom.Thickness	mm	
	f) Max. thickness	mm	
	g) Minimum volume resistivity as per IS 5831	Ohm cm	
	h) Dielectric constant	-	
	i) Maximum conductor temperature withstand capacity	°C	
j) Core diameter including insulation	mm		
9	Core laying		
	a)Whether cores are twisted.	-	
	b) Maximum lay of twist	mm	
	c) Identification of cores	-	
10	Individual Shield		



DOCUMENT TITLE
2X800MW KARIMNAGAR TPS
TECHNICAL SPECIFICATION FOR
SCREENED CONTROL CABLES

SPECIFICATION NO. PE-TS-424-507-E004

VOLUME II

SECTION - I

REVISION 0

DATE: 10.07.2023

Page 2

	a) Material	-	
	b) Thickness of tape	micron	
	c) Coverage/ Overlap	%	
	d) Noise interference better than	dB	
11	Drain wire for individual shield		
	a) Reference standard	-	
	b) Size (No. of strands/ dia. of each strand)	sq. mm (no./mm)	
	c) Material	-	
	d) Resistance of drain wire per km at 20 deg.C	ohm	
12	Overall shield		
	a) Material	-	
	b) Thickness of tape	mm	
	c) Coverage/Overlap	%	
	d) Noise interference better than	dB	
13	Drain wire for overall shield		
	a) Reference standard	-	
	b) Size/ No.of strands	sq. mm/ no.	
	c) Material	-	
	d) Resistance per Km (with shield) at 20°C	Ohm/ km	
14	a) Fillers: Material (if applicable)		
	b) Bedding Material		
15	Inner sheath		
	a) Material, type and standard	-	
	b) Whether FRLS	-	
	c) Colour	-	
	d) Method of application	-	
	e) Thickness (min)	mm	
16	Armour		
	a) Material,	-	
	b) Formed wire / round wire		
	c) Minimum Coverage	%	
	d) Method of jointing	-	
	e) Breaking load of joint	-	
	f) Size (approx.)	mm	
	g) Dia of armour	mm	
	h) No. of wires	mm	
17	Outer sheath		
	a) Reference standard	-	
	b) Material	-	
	c) Minimum thickness of sheath	mm	



DOCUMENT TITLE
2X800MW KARIMNAGAR TPS
 TECHNICAL SPECIFICATION FOR
 SCREENED CONTROL CABLES

SPECIFICATION NO. PE-TS-424-507-E004

VOLUME II

SECTION - I

REVISION 0

DATE: 10.07.2023

Page 3

	d) Calculated dia under outersheath	mm	
	e) Oxygen index (as per ASTM D 2863)	-	
	f) Temperature index (in deg. C as per ASTM D 2863)	-	
	g) Maximum acid gas generation as per IEC754-1	%	
	h) Maximum smoke density rating as per ASTM D 2843	%	
	i) Colour of outer sheath	-	
18	Dia over laid-up core	mm	
19	Dia under armour	mm	
20	Dia above armour	mm	
21	Overall diameter of cable	mm	
22	Tolerance on overall diameter	mm	
23	Weight of		
	Copper (conductor & drain wire)	MT. / km	
	PVC (insulation, sheath & fillers)	MT. / km	
	Armour	MT. / km	
	Cable (approx.)	MT. / km	
24	Cable parameters at 20°C(+/-3 deg. C)		
	a) Conductor resistance (max)	Ohm/ km	
	b) Insulation resistance (min)	M-Ohm	
	c) Mutual capacitance at 0.8KHz (max)	nF/ km	
	d) Cross talk at 0.8KHz (min)	dB	
	e) Attenuation at 1 KHz (max)	dB/ km	
	f) Characteristic impedance at 1 KHz (max)	Ohm	
25	Continuous operating temp. (deg.C)	deg. C	
26	(a) Relevant IS standard including Part & category for Flame retardance of complete cable	-	
	(b) Relevant IEC standard including Part & category for Flammability of complete cable		
27	Whether complete cable passes Swedish Chimney test as per SEN 4241475 (F3)	-	
28	Identification		
	a) Length of cable marked at every mtr.	-	
	b) FRLS marked at every 5 mtrs	-	
	c) Each core of the pair numbered	-	
	d) Conductor identification details for pairs	-	
	e) Details of cable markings	-	
29	Test voltage		
	a) High voltage test/ Dielectric Strength		
	i) Voltage (KV), Core - Core	kV	
	ii) Duration	min	
	b) High Voltage test		



DOCUMENT TITLE
2X800MW KARIMNAGAR TPS
TECHNICAL SPECIFICATION FOR
SCREENED CONTROL CABLES

SPECIFICATION NO. PE-TS-424-507-E004

VOLUME II

SECTION - I

REVISION 0

DATE: 10.07.2023

Page 4

	i) Voltage (KV), Core - Screen	V	
	ii) Duration	min	
	c) Resistance to direct current test (applicable for 225 V cable as per VDE)	-	
	Voltage	V	
	Duration	hrs/days	
30	Min bending radius	mm	
31	Ovality at any cross section	mm	
32	Variation of dia through out cable length		
33	Cable cross-sectional drawings for each type of cable furnished		
34	i) Length of single coil in a drum	M	
	ii) Marking on drum	-	
	iii) Seasoned wood drum provided	-	
	iv) Both ends of cable to be sealed with PVC/ Rubber caps to prevent water/ moisture ingress		
	v) Gross weight (approx.)	kg.	
	vi) Net weight (approx.)	kg	
35	Type test procedures as per BHEL Technical Spec. and other relevant standards enclosed.		
36	Anti termite & rodent test		



DOCUMENT TITLE
2X800MW KARIMNAGAR TPS

TECHNICAL SPECIFICATION FOR
SCREENED CONTROL CABLES

SPECIFICATION NO. PE-TS-424-507-E004

VOLUME II

SECTION II

REVISION -0

DATE: 10.07.2023

SHEET -

SECTION-'II'

GENERAL TECHNICAL SPECIFICATION



DOCUMENT TITLE
2X800MW KARIMNAGAR TPS

TECHNICAL SPECIFICATION FOR
SCREENED CONTROL CABLES

SPECIFICATION NO. PE-SS-000-507-E016B

VOLUME II

SECTION II

REVISION

DATE: 10.07.2023

SHEET 1 OF 1

1.0 TECHNICAL REQUIREMENTS

- 1.1 Technical requirements for SCREENED CONTROL CABLES shall be as indicated in this section, in addition to those specified in Datasheet-A.
- 1.2 It is not the intent to specify herein all the details of design & manufacture. However, the equipment shall conform in all respects to high standards of design engineering and workmanship and shall be capable of performing in continuous commercial operation at site conditions.

2.0 CODES & STANDARDS

- 2.1 The design, material, construction, manufacture, inspection and testing of Screened control cables shall conform to the latest revision of relevant standards and codes of practices mentioned in Data Sheet - A.
- 2.2 In case of conflict between the applicable reference standard and this specification, this specification shall govern.

3.0 QUALITY ASSURANCE REQUIREMENTS

- 3.1 Bidder shall confirm compliance with the BHEL Standard Quality Plan (PE-QP-999-507-E004) as attached with the specification without any deviations. At contract stage, the successful bidder shall submit the same QP for BHEL/ ultimate customer's approval. In case bidder has reference QP agreed with ultimate customer, same can be submitted for specific project after award of contract for BHEL/ultimate customer's approval. There shall be no commercial implication to BHEL on account of minor changes in QP during contract stage.
- 3.2 All materials shall be procured, manufactured, inspected and tested by vendor/ sub-vendor as per approved Quality Plan.
- 3.3 Type testing requirements, routine/ acceptance testing and special testing requirements shall be as per Annexure –C to QP. Charges for all these tests for all the equipments & components shall be deemed to be included in the bid price (except UV Radiation & Hydraulic Stability test).
- 3.4 The charges of UV Radiation test & Hydrolytic Stability test (if applicable) shall be reimbursed extra at actual against original money receipt of Govt. Lab. (CPRI/ ERDA etc).
- 3.5 Cost of cables consumed for testing shall be to bidder's account.
- 3.6 Type Test Reports for Tests conducted shall be submitted for BHEL's/ Customer's review/approval.

4.0 Packing

- 4.1 Cables shall be supplied in non-returnable drums. Material of cable drum shall be as specified in Datasheet-A.
- 4.2 In case of wooden drums, all wooden parts shall be manufactured from seasoned wood treated with copper naphthenates/ zinc naphthenates (refer IS: 401). Dimensions of wooden drums shall be as per IS 10418. All ferrous parts shall be treated with suitable rust protective finish or coating to avoid rusting during transit and storage. BIS certification mark shall be stamped on each cable drum. Over the cables polyethylene sheet shall be wrapped and then sealed properly.
- 4.3 ~~In case of Steel drums, new or practically new cable drums made of steel and painted with epoxy resin paint are to be used. Cable ends are carefully protected before packing. Over the cables polyethylene sheet shall be wrapped and then sealed properly. For Typical details of Steel drums, Annexure-B to Section-II, may be referred by the bidder. Bidder may modify, to choose appropriate dimensions of steel drums to suite various sizes/weight/ lengths.~~



TITLE :
**TECHNICAL SPECIFICATION FOR
SCREENED CONTROL CABLES**

SPECIFICATION NO.
PE-TS-404-507-E004

VOLUME NO. IIB

SECTION: C

REV NO. : **0** DATE 10.07.2023

SHEET: 1 OF 2

ANNEXURE : A

CORE IDENTIFICATION / PAIR IDENTIFICATION



TECHNICAL SPECIFICATION FOR
SCREENED CONTROL CABLES

SPECIFICATION NO.
PE-TS-404-507-E004

VOLUME NO. IIB

SECTION: C

REV NO. : 0 DATE 10.07.2023

SHEET: 2 OF 2

ANNEXURE : B-I

The cable cores shall be colour coded as mentioned below:

PAIR	CORE	COLOUR
1 st	1 st	Blue
1 st	2 nd	Red
2 nd	1 st	Grey
2 nd	2 nd	Yellow
3 rd	1 st	Green
3 rd	2 nd	Brown
4 th	1 st	White
4 th	2 nd	Black

Each four pair is laid to form one unit and wound with Mylar tape. The cores of each unit shall then be identified by colour bands for cables of more than 4-pair. eg. All eight cores of the first unit shall have a single band of pink colour (preferably rose pink).

Unit No No.	COLOUR OF BANDS	BAND MARKS
1.	PINK	= === ==
2.		= === ==
3.		= === ==
4.		= === ==
5.	ORANGE	= === ==
6.		= === ==
7.		= === ==
8.		= === ==
9.	VIOLET	= === ==
10.		= === ==
11.		= === ==
12.		= === ==

The dimension L (distance between the marking) shall be limited to 60mm. The bands shall be neat and cover at least 2/3 of the periphery of the core.
eg: A grey wire having 3 orange bands is the first core of the second pair of the seventh unit.



ITEM : Instrumentation Cables.
SUB SYSTEM : Shielded
Instrument/ TC extension/
Compensating PVC FRLS Cable

STANDARD QUALITY PLAN

To be filled by NTPC

QP No.: 0000-999-QOI-S-035

Revision:00

Date:05/09/2012

Page:1 OF 5

Reviewed By:

Archana Nath

Rajeev Garg

Approved By:

A.K.GARG

A.K.GARG

S.samanta

Valid up to : 04/09/2015

Sl No	Component & Operations	Characteristics	Class	Type of check	Quantum of check		Reference Document	Acceptance Norms	Format of record	Agency			Remarks	
		3	4	5	M	C,N	7	8	9	D*	M	C	N	11
I. RAW MATERIAL														
A CONDUCTOR														
A1	COPPER ROD For Conductor/ Drain wire	a) Dimension	Maj.	Measu.	1 sample/lot	-	IS:613/IS:12444	IS:613/IS:12444	IMR/ TC	V	-	-	Make - As per Annexure enclosed	
		b) Conductivity/ Resistivity	Cri.	Elec.	1 sample/lot	1 sample/lot	IS:613/IS:12444	IS:613/IS:12444	IMR/ TC	V	V	-		
A2	Conductor for compensating cable	a) Size	Min	Dimen	1 Sample / lot	-	APPROVED DATASHEET	APPROVED DATA SHEET	IMR/ TC	P	-	-	Make - As per Annexure enclosed	
		b) Resistance check	Maj	Elec	1 Sample / lot	-	APPROVED DATASHEET	APPROVED DATA SHEET	IMR/ TC	P	-	-		
		c) Thermo emf	Cri	Elec	1 Sample / lot	-	ANSI MC 96.1	ANSI MC 96.1	IMR/ TC	P	-	-		
		d) Specific resistance, Temp. coefficient.	Maj	Elec/Me ch	1 Sample / lot	1 Sample / lot	Mfr. catalog	Mfr. catalog	IMR/ TC	V	V	V		
		e) Chemical composition.	Maj	Chem.	1 Sample / lot	1 Sample / lot	Mfr. catalog	Mfr. catalog	IMR/ TC	V	V	V		
B PVC COMPOUND														
B1	PVC Compound (Insulation & Sheath) Type of compound as per NTPC Spec.	a) Thermal stability (for Insulation)	Maj.	Therm.	1 sample/lot	1 sample/lot	VDE 207 Part -4/5	VDE 207 Part -4/5	IMR/ TC	P	V	-		
		b) TS & % Elongation Before and After aging and variation.	Maj.	Mech.	1 sample/lot	1 sample/lot	VDE 207 Part -4/5	VDE 207 Part -4/5	IMR/ TC	P	V	-		
		c) Loss of Mass (Sheath)	Maj.	Therm.	1 sample/lot	1 sample/lot	VDE 207 Part -4/5	VDE 207 Part -4/5	IMR/ TC	P	V	-		
B2	FR Properties for Filler Compound	a) Oxygen index	Cri.	Chem	1 sample/lot	1 sample/lot	29 %(min)ASTMD2863	29%(min)ASTMD2863	IMR/ TC	P	V	-		
		b) Temperature index deg. C	Cri.	Chem	1 sample/lot	1 sample/lot	250 deg. C(min) ASTMD2863	250 deg. C(min) ASTMD2863	IMR/ TC	P	V	-		
B3	FRLS Properties for Sheath	a) Oxygen index	Cri.	Chem	1 sample/lot	1 sample/lot	ASTMD2863/ APPROVED DATASHEET	ASTMD2863/ APPROVED DATASHEET	IMR/ TC	P	V	-		
		b) Temperature index	Cri.	Chem	1 sample/lot	1 sample/lot	ASTMD2863/ APPROVED DATASHEET	ASTMD2863/ APPROVED DATASHEET	IMR/ TC	P	V	-		
		c) Smoke density rating	Cri.	Chem	1 sample/lot	1 sample/lot	ASTMD2843/ APPROVED DATASHEET	ASTMD2843/ APPROVED DATASHEET	IMR/ TC	P	V	-		
		d) HCL Emission	Cri.	Chem	1 sample/lot	1 sample/lot	IEC754-1/ APPROVED DATASHEET	IEC754-1/ APPROVED DATASHEET	IMR/ TC	P	V	-		
C	Tapes / Binders (Aluminium Mylar, Melinex & Binders)	a) Thickness	Maj.	Mesu.	1 Sample/ Lot	1 Sample/ Lot	APPROVED DATASHEET	APPROVED DATASHEET	IMR/ TC	P	V	-		
		b) Size	Maj.	Mesu.	1 Sample/ Lot	1 Sample/ Lot	APPROVED DATASHEET	APPROVED DATASHEET	IMR/ TC	P	V	-		
D	Armour (If applicable)	a) Dimension	Maj.	Mesu.	1 Sample/ Lot	1 Sample/ Lot	APPROVED DATASHEET	APPROVED DATASHEET	IMR/ TC	P	V	-		
		b) TS & %Elongation	Maj.	Mech	1 Sample/ Lot	1 Sample/ Lot	IS 3975	IS 3975	IMR/ TC	P	V	-		
		c) Zn Coating	Maj.	Chem	1 Sample/ Lot	1 Sample/ Lot	IS 3975	IS 3975	IMR/ TC	P	V	-		
		d) Resistivity	Maj.	Elect	1 Sample/ Lot	1 Sample/ Lot	IS 3975	IS 3975	IMR/ TC	P	V	-		

LEGEND : * RECORDS, IDENTIFIED WITH " TICK" SHALL BE ESSENTIALLY INCLUDED BY SUPPLIER IN QA DOCUMENTATION .M:MANUFACTURER/ SUB SUPPLIER C:MAIN SUPPLIER,N:NTPC, P:PERFORM ,W: WITNESS and V: VERIFICATION AS APPROPRIATE, "CHP" NTPC SHALL INDICATED IN COLOUM "N" AS "W"

Format No. :QS-01-QAI-P-09/F1-R1



ITEM : Instrumentation Cables.
SUB SYSTEM : Shielded
Instrument/ TC extension/
Compensating PVC FRLS Cable

STANDARD QUALITY PLAN

To be filled by NTPC

QP No.: 0000-999-QOI-S-035

Revision:00

Date:05/09/2012

Page:2 OF 5

Reviewed By:

Archana Nath

Rajeev Garg

S.samanta

Approved By

A.K.GARG

Approved

De.....

Valid up to : 04/09/2015

Sl No	Component & Operations	Characteristics	Class	Type of check	Quantum of check		Reference Document	Acceptance		Format of record		Agency			Remarks
					M	C,N		Norms	8	9	D*	10	M	C	
1	2	3	4	5	6		7	8		9	D*	10			11
E	Wooden Drums	a) Constructional checks	Maj.	Visu.	100%	-	IS 10418	IS 10418		IMR/ TC		P	-	-	
		b) Dimensions	Maj.	Mesu.	1 Sample/ Lot	-	IS 10418	IS 10418		IMR/ TC		P	-	-	
II INPROCESS INSPECTION															
A	Wire Drawing & Annealing	a)Size	Maj.	Dimn.	1 Sample at Start and 1 Sample at End	-	Approved Datasheet	Approved Datasheet		IMR/ TC		P	-	-	
		b) Surface finish	Maj.	Visu.	100%	-	Surface shall be smooth	Surface shall be smooth		IMR/ TC		P	-	-	
		c) % of Elongation	Maj.	Mech.	1 Sample/ Lot	-	IS:8130	IS:8130		IMR/ TC		P	-	-	
B	Tinning (Only for Drain wire)	a) Size	Maj.	Dimn.	1 Sample/ Lot	-	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet		IMR/ TC		P	-	-	
		b) Percentage of Elongation	Maj.	Mech.	1 Sample/ Lot	1 Sample/ Lot	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet		IMR/ TC		P	V	V	
C	Bunching	a) Dimension and No. of strand.	Maj.	Measu.	1 Sample/ Lot	-	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet		IMR/ TC		P	-	-	
		b)Resistance	Cri	Elec.	1 Sample/ Lot	1 Sample/ Lot	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet		IMR/ TC		P	V	V	
D	Insulation	a) Surface finish	Maj.	Visu.	100%	-	Surface shall be smooth & free from scratches	Surface shall be smooth & free from scratches		IMR/ TC		P	-	-	
		b) Core Diameter	Maj.	Measu.	1 Sample/ Lot	-	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet		IMR/ TC		P	-	-	
		c) Radial Thickness(Min & Max.)	Maj.	Measu.	1 Sample/ Lot	-	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet		IMR/ TC		P	-	-	No Repairs are allowed on the Insulated core
		d) Spark Test	Maj.	Elec.	100%	100%	IS 10810(With 3KV ac)	No Spark failure is allowed		IMR/ TC		P	V	V	
		e) Volume Resistivity/ Insulation Resistance	Maj.	Elec.	1 Sample/ Lot	1 Sample/ Lot	VDE -0207/ Approved Datasheet	VDE -0207/ Approved Datasheet		IMR/ TC		P	V	V	
		f) Colour, Marking/ Identification	Maj.	Visual	100%	100%	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet		IMR/ TC		P	V	-	
		g) TS & %Elongation	Maj.	Mech.	1 Sample/ Lot	-	VDE -0207/ Approved Datasheet	VDE -0207/ Approved Datasheet		IMR/ TC		P	-	-	
E	Twisting	a) Lay length and Direction	Maj.	Measu. &	1 Sample at Start and 1 Sample at End	-	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet		IMR/ TC		P	-	-	
		b) Size/ Dimension	Maj.	Measu.	1 Sample/ Lot	-	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet		IMR/ TC		P	-	-	
		c) Pair Colour	Maj.	Visual	100%	-	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet		IMR/ TC		P	-	-	

LEGEND : * RECORDS, IDENTIFIED WITH " TICK" SHALL BE ESSENTIALLY INCLUDED BY SUPPLIER IN QA DOCUMENTATION .M:MANUFACTURER/ SUB SUPPLIER C:MAIN SUPPLIER,N:NTPC, P:PERFORM ,W: WITNESS and V: VERIFICATION AS APPROPRIATE, "CHP" NTPC SHALL INDICATED IN COLOUR "N" AS "W"

Format No. :QS-01-QAI-P-09/F1-R1



ITEM : Instrumentation Cables.
SUB SYSTEM : Shielded
Instrument/ TC extension/
Compensating PVC FRLS Cable

STANDARD QUALITY PLAN

To be filled by NTPC

QP No.: 0000-999-QOI-S-035

Revision:00

Date:05/09/2012

Page:3 OF 5

Reviewed By:

Archana Nath

Rajeev Garg

S.samanta

Approved By:

A.K.GARG

Approved

Valid up to : 04/09/2015

Sl No	Component & Operations	Characteristics	Class	Type of check	Quantum of check		Reference Document	Acceptance Norms		Format of record		Agency			Remarks
					M	C,N			D*	M	C	N			
1	2	3	4	5	6		7	8		9	10			11	
F	Laying of Pairs/ Taping/ Shielding (Wherever Applicable)	a) Construction	Maj.	Visu.	100%	-	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	IMR/ TC		P	-	-		
		b) Dimension	Maj.	Measu.	1 Sample/ Lot	-	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	IMR/ TC		P	-	-		
		c) Coverage/ Overlap	Maj.	Measu.	1 Sample/ Lot	-	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	IMR/ TC		P	-	-		
		d) Continuity	Maj.	Dimn.	1 Sample/ Lot	-	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	IMR/ TC		P	-	-		
G	Sheathing (Inner - If applicable)	a) Surface Finish	Maj.	Visual	100%	-	Smooth, free from visual defects #	Smooth, free from visual defects#	IMR/ TC		-	-	-	# Porosity, Burnt particles, Pimples (Repairs are not allowed)	
		b) Colour	Maj.	Visual	100%	-	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	IMR/ TC		P	-	-		
		c) Diameter / Thickness	Maj.	Measu.	1 Sample/ Lot	-	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	IMR/ TC		P	-	-		
H	Armouring (If applicable)	a) Surface finish	Maj.	Visual	100%	-	Smooth, free from visual defects like rusting etc.	Smooth, free from visual defects like rusting etc.	IMR/ TC		P	-	-		
		b) Direction of Lay & Coverage	Maj.	Visual	100%	-	Smooth, free from visual defects like rusting etc.	Smooth, free from visual defects like rusting etc.	IMR/ TC		P	-	-	Min coverage shall be 90 %. Gap should not be more than 1 wire/ Strip dimension.	
		c) Size of Wire/ Strip	Maj.	Measu.	1 Sample/ Lot	-	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	IMR/ TC		P	-	-		
		d) Diameter over Armouring	Maj.	Measu.	1 Sample/ Lot	-	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	IMR/ TC		P	-	-		
I	Sheathing (Outer)	a) Surface Finish	Maj.	Visual	100%	-	Smooth, free from visual defects#	Smooth, free from visual defects#	IMR/ TC		P	-	-	# Porosity, Burnt particles, Pimples (No Repairs are allowed)	
		b) Colour/ Marking/ Embossing	Maj.	Visual	100%	-	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	IMR/ TC		P	-	-		
		c) Overall Diameter, Thickness	Maj.	Measu.	1 Sample/ Lot	-	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	IMR/ TC		P	-	-		
		d) TS & %Elongation	Maj.	Mech.	1 Sample/ Lot	-	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	IMR/ TC		P	-	-		
III. FINAL INSPECTION															
A.	TYPE TEST	Type test as per agreement with NTPC Engg. Review of type test clearance from NTPC Engg. before final Inspection - CHP													
B.	ROUTINE TEST	a) Cond.resistance (Cable & Drain wire)	Cri.	Elec.	100%	100%	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	FIR	√	P	V	V		
		b) HV Test	Cri.	Elec.	100%	100%	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	FIR	√	P	V	V		

LEGEND : * RECORDS, IDENTIFIED WITH " TICK" SHALL BE ESSENTIALLY INCLUDED BY SUPPLIER IN QA DOCUMENTATION .M:MANUFACTURER/ SUB SUPPLIER C:MAIN SUPPLIER,N:NTPC, P:PERFORM ,W: WITNESS and V: VERIFICATION AS APPROPRIATE, "CHP" NTPC SHALL INDICATED IN COLOUM "N" AS "W"

Format No. :QS-01-QAI-P-09/F1-R1



ITEM : Instrumentation Cables.
SUB SYSTEM : Shielded
Instrument/ TC extension/
Compensating PVC FRLS Cable

STANDARD QUALITY PLAN

To be filled by NTPC

QP No.: 0000-999-QOI-S-035

Revision:00

Date:05/09/2012

Page:4 OF 5

Reviewed By: Archana Nath

Rajeev Garg

S.samanta

Approved By

A.K.GARG

Valid up to : 04/09/2015

Sl No	Component & Operations	Characteristics	Class	Type of check	Quantum of check		Reference Document	Acceptance Norms	Format of record	Agency			Remarks	
					M	C,N				M	C	N		
1	2	3	4	5	6		7	8	9	D*	10		11	
		c) IR Test (on drum length)	Cri.	Elec.	100%	100%	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	FIR	√	P	V	V	
		d) Drain wire contunity	Cri.	Elec.	100%	100%	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	FIR	√	P	V	V	
C.	ACCEPTANCE TEST	a) Cond.resistance (Cable & Drain wire)	Cri.	Elec.	Samples as per IS 1554/8784	Samples as per IS 1554/8784	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	FIR	√	P	W	W	
		b) HV Test	Cri.	Elec.	Samples as per IS 1554/8784	Samples as per IS 1554/8784	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	FIR	√	P	W	W	
		c) IR Test	Cri.	Elec.	Samples as per IS 1554/8784	Samples as per IS 1554/8784	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	FIR	√	P	W	W	
		d) Constructional Details & Dimensions												
		i) Constructional Details	Maj.	Visual	Samples as per IS 1554/8784	Samples as per IS 1554/8784	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	FIR	√	P	W	W	
		ii) Shield Al-mylar thickness	Maj.	Measu.	Samples as per IS 1554/8784	Samples as per IS 1554/8784	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	FIR	√	P	W	W	
		iii) Insulation thickness	Maj.	Measu.	Samples as per IS 1554/8784	Samples as per IS 1554/8784	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	FIR	√	P	W	W	
		iv) Inner/ Outer sheath thickness (as applicable)	Maj.	Measu.	Samples as per IS 1554/8784	Samples as per IS 1554/8784	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	FIR	√	P	W	W	before and after ageing for insulation.
		v) Diameter over outer sheath	Maj.	Measu.	Samples as per IS 1554/8784	Samples as per IS 1554/8784	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	FIR	√	P	W	W	
		e) Outer sheath - Colour, Marking/ Embossing & End sealing.	Maj.	Visual	Samples as per IS 1554/8784	Samples as per IS 1554/8784	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	FIR	√	P	W	W	
		f) Length checking.	Maj.	Measu.	1 No. of each size & type per Lot	1 No. of each size & type per Lot	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	FIR	√	P	W	W	
		g) Core - Band marking/ Numbering, Colour.	Maj.	Visual	1 No. of each size & type per Lot	1 No. of each size & type per Lot	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	FIR	√	P	W	W	
		h) Overall Coverage/overlap of shield & Continuity of drain wire.	Maj.	Visual	1 No. of each size & type per Lot	1 No. of each size & type per Lot	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	FIR	√	P	W	W	Continuity shall be checked as per Manufacturer practice.

LEGEND : * RECORDS, IDENTIFIED WITH " TICK" SHALL BE ESSENTIALLY INCLUDED BY SUPPLIER IN QA DOCUMENTATION .M:MANUFACTURER/ SUB SUPPLIER C:MAIN SUPPLIER, N:NTPC, P:PERFORM ,W: WITNESS and V: VERIFICATION AS APPROPRIATE, "CHP" NTPC SHALL INDICATED IN COLOUM "N" AS "W"

Format No. :QS-01-QAI-P-09/F1-R1



ITEM : Instrumentation Cables.
SUB SYSTEM : Shielded
Instrument/ TC extension/
Compensating PVC FRLS Cable

STANDARD QUALITY PLAN

To be filled by NTPC

QP No.: 0000-999-QOI-S-035

Revision:00

Date:05/09/2012

Page:5 OF 5

Reviewed By:

Archana Nath

Rajeev Garg

S.samanta

Approved By

A.K.GARG

Dt.....

Valid up to : 04/09/2015

Sl No	Component & Operations	Characteristics	Class	Type of check	Quantum of check		Reference Document	Acceptance Norms	Format of record	Agency			Remarks	
					M	C,N				M	C	N		
1	2	3	4	5	6		7	8	9	D*	10		11	
		i) Thermal EMF test (For compensating cable only)	Maj.	Elec.	Sample as per IS 8784	Sample as per IS 8784	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	FIR	√	P	W	W	
		j) Thermal Stability (Insulation & Sheath)	Maj.	Chem.	1 No. of each size & type per Lot	1 No. of each size & type per Lot	Spec./ADS/IS:5831	Spec./ADS/IS:5831	FIR	√	P	W	W	
		k) Visual & Surface Finish	Maj.	Visual	1 No. of each size & type per Lot	1 No. of each size & type per Lot	Smooth, free from visual defects #	Smooth, free from visual defects #	FIR	√	P	W	W	# Like Porosity, Burnt particles, Pimples
		l) Electrical Parameters (Mutual capacitance, Cross talk, Attenuation, Characteristic Impedence as applicable)	Maj.	Elec.	1 No. of each size & type per Lot	1 No. of each size & type per Lot	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	FIR	√	P	W	W	
		m) Persulphate Test (For Drain wire)	Maj.	Chem.	1 No. of each size & type per Lot	1 No. of each size & type per Lot	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	FIR	√	P	W	W	
		n) Swidesh chimney test (overall cable)	Maj.	Chem	1 No./ Complete lot offered \$	1 No./ Complete lot offered \$	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	FIR	√	P	W	W	\$ Irrespective of size & type.
		o) FRLS Test for outer sheath for OI(Oxygen Index), TI(Temperature Index), SDR(Smoke Density Rating) & HCL Emission.	Maj.	Chem	1 No./ Complete lot offered \$	1 No./ Complete lot offered \$	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	FIR	√	P	W	W	
		p) TS & %Elongation test of Insualtion & Sheath (Before & After aging)	Maj.	Mech	1 No./ Complete lot offered \$	1 No./ Complete lot offered \$	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	FIR	√	P	W	W	
		q) Volume Resistivity (At room and Elevated Temperature)	Maj.	Elec.	1 No./ Complete lot offered \$	1 No./ Complete lot offered \$	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	FIR	√	P	W	W	
		r) Armouring Dimension & Zn coating. (If applicable)	Maj.	Measur.	1 No./ Complete lot offered \$	1 No./ Complete lot offered \$	NTPC Tech.Specification /Approved Datasheet	NTPC Tech.Specification /Approved Datasheet	FIR	√	P	W	W	
D.	Packaing and Dispatch	Stencileing, completeness & Verification with packing list	Maj.	Visual.	100%	-	Mfg. Practice	Mfg. Practice			P	-	-	

NOTE 1 : Where witnessing and verification of records is done only by main contractor (Coloum "C"), NTPC inspection Engineer may do a survilience Verification/ Witnessing as per his discretion.

NOTE 2 : IMR : Inword Material Register, TC : Test Certificates, Mfg. : Manufacturer, FIR : Final Inspection Report.

NOTE 3: NTPC Inspection Engininer to check,approval date,revision no of reference documents at the time of Inspection.

LEGEND : * RECORDS, IDENTIFIED WITH " TICK" SHALL BE ESSENTIALLY INCLUDED BY SUPPLIER IN QA DOCUMENTATION .M:MANUFACTURER/ SUB SUPPLIER C:MAIN SUPPLIER,N:NTPC, P:PERFORM ,W: WITNESS and V: VERIFICATION AS APPROPRIATE, "CHP" NTPC SHALL INDICATED IN COLOUM "N" AS "W"

Format No. :QS-01-QAI-P-09/F1-R1


CLAUSE NO.

QUALITY ASSURANCE



INSTRUMENTATION CABLE

ITEMS	TESTS														
	Conductor Resistance ® & (A)	High Voltage ® & (A)	Insulation Resistance ® & (A)	Constructional detail, dimensions (A)	Outer-Sheathe/core marking, end sealing (A)	Thermal Stability (A) +	Visual, Surface finish (A) +	Electrical Parameters ** (A) +	Persulphate Test (A) +	Overall/Coverage/Continuity (A)	Swidesh chimney Test (SS-4241475) (A) ++	FRLS Test * (A) ++	Tensile & Elongation before & after aging (A) ++	Vol. Resistivity. at room & Elevated Temp. (A) ++	Spark test report review ®
1. Instrument cable twisted and shielded															
Conductor(IS-8130)	Y			Y			Y								
Insulation(VDE-207)				Y	Y	Y	Y						Y		Y
Pairing/Twisting				Y	Y		Y								
Shielding				Y			Y			Y					
Drain wire	Y			Y			Y		Y	Y					
Inner Sheath				Y	Y	Y	Y					Y	Y		
Outer Sheath				Y	Y	Y	Y					Y	Y		
Over all cable	Y	Y	Y	Y	Y		Y	Y			Y			Y	
Cable Drums(IS-10418)				Y			Y								
<p>Note : High Temp. cables shall be subjected to tests as per VDE-207(Part-6) Compensating cables shall be checked for Thermal EMF/Endurance test as per IS 8784.</p> <p>Note : This is an indicative list of tests/checks. The manufacture is to furnish a detailed Quality Plan indicating his practice & Procedure along with relevant supporting documents during QP finalization for all items.</p> <p>Note : ® - Routine Test A - Acceptance Test Y - Test Applicable</p> <p>Note : Sampling Plan for Acceptance test shall be as per IS 8784 (As applicable)</p> <ul style="list-style-type: none"> * FRLS Tests: Oxygen / Temp Index (ASTM D-2863), Smoke Density Rating (ASTM – D 2843), HCL Emission (IEC-754-1) ** Characterisitic Impedence, Attenuation, Mutual Capacitance, Cross Talk (As applicable) <p>+ Sample size will be One No. of each size/type per lot.</p> <p>++ Sample size will be One No. sample for complete lot offered irrespective of size/type.</p>															

	PRE-QUALIFICATION REQUIRMENTS OF SCREENED CONTROL CABLE FOR 2X800MW KARIMNAGAR TPS	PE-PQ-424-507-E016
		REVISION NO. 0 DATE 12.07.2023
		SHEET NO. 1 OF 1

ITEMS : SCREENED CONTROL CABLE	
SCOPE : Supply : YES; Erection & Commissioning : NO;	
1.0	Vendor Should be a manufacturer of screened/ instrumentation control cables.
2.0	Availability of test reports of tests on FRLS screened control cables to establish in-house Capability to carry out all routine, type acceptance as per relevant IS / International Standards (except UV radiation & hydrolytic stability Test which can be conducted at Govt. Lab/ Govt. approved Independent lab).
3.0	Capacity of manufacturing 50 km of screened control cables per month.
4.0	Manufactured and supplied at least one (1) km of FRLS cables.
5.0	Manufactured and supplied screened control cables up to 12 pairs.
6.0	Manufactured and supplied at least 50 Km of Screened Control cables in one or more orders and at least 25 Km in one single order.
7.0	Minimum two (2) nos. purchase orders for screened control cables shall be submitted which should not be more than five (5) years old from the date of techno-commercial bid opening for establishing continuity in business.

NOTES:

1. Consideration of bidder's offer is subject to NTPC approval.
2. Bidder to submit all supporting documents in English. If documents submitted by bidder are in language other than English, a self-attested English translated document should also be submitted.
3. Notwithstanding anything stated above, BHEL reserves the light to assess the capabilities and capacity of the bidder/collaborators to perform the contract, should the circumstances warrant such assessment in the overall interest of BHEL.
4. After satisfactory fulfillment of all the above criteria! requirement, offer shall be considered for further evaluation as per NIT and all the other terms of the tender.

PREPARED BY PRIYANKA <small>Digitally signed by PRIYANKA DN: cn=PRIYANKA, o=BHEL, ou=EH, email=priyankagupta@bhel.in, c=IN Date: 2023.07.12 14:11:51 +05'30'</small> NAME: PRIYANKA GUPTA DESIGNATION: MANAGER	CHECKED BY ABHISHEK <small>Digitally signed by ABHISHEK DN: cn=ABHISHEK, o=BHEL, ou=PEM, email=abhishek1@bhel.in, c=IN Date: 2023.07.12 14:36:26 +05'30'</small> NAME: ABHISHEK DESIGNATION: SR. MANAGER	REVIEWED BY Praveen Dutta <small>Digitally signed by Praveen Dutta DN: cn=Praveen Dutta, o=BHEL, ou=PS-PEM / Electrical, email=praveendutta@bhel.in, c=IN Date: 2023.07.12 14:51:29 +05'30'</small> NAME: PRAVEEN DUTTA DESIGNATION: AGM	APPROVED BY Debasisa Rath <small>Digitally signed by Debasisa Rath DN: cn=Debasisa Rath, o=BHEL, ou=PEM, email=debasisa@bhel.in, c=IN Date: 2023.07.12 15:17:06 +05'30'</small> NAME: DEBASISA RATH DESIGNATION: DH-ELECT(AGM)
--	--	--	--

Annexure-B to MOP: SCREENED CONTROL CABLE for 2X800MW NTPC KARIMNAGAR SG

PACKAGE PHASE-1

DEFAULT/ BREACH OF CONTRACT, INSOLVENCY AND RISK PURCHASE

In case of delays (beyond the maximum late delivery period as per LD clause) in supplies, or if there be defective supplies or non-fulfilment of any other terms and conditions of the Contract as enumerated subsequently in this clause, then, without prejudice to its right to recover any expenses, losses or damages to which the Buyer may be put to incur or sustain by reason of the Seller/Contractor's default or breach of Order/Contract or to suspend business dealings with the Seller/Contractor in terms of the Buyers' Guidelines for Suspension of Business Dealings as applicable from time to time, the Buyer shall also be entitled to cancel the Order/ Contract either in whole or portion thereof without compensation to Seller. On the occurrence of any of the acts/omissions mentioned below, the Buyer may if it so desires, procure upon such terms and in such manner as deemed appropriate, plant/ equipment/ stores not so delivered or others of similar description where plant/ equipment/ stores exactly complying with particulars are not, in the opinion of the Buyer (which shall be final), readily procurable, at the risk and cost of the Seller.

The Seller shall be liable to the Buyer for any excess costs incurred thereof and the Seller shall continue the performance of the Order/Contract to the extent not cancelled under the provisions of this clause. The Seller shall on no account be entitled to any gain on such repurchases. If the Bidder does not agree to this Risk Purchase clause, BHEL reserves the right to reject the bid/offer of the Bidder.

The order/contract may be cancelled in whole or part thereof and Risk & Cost Clause in line with terms and conditions of PO/Contract may be invoked by the Buyer in any of the following cases:

- i. If the Seller/Contractor fails to deliver the goods or materials or any installment thereof within the period(s) fixed for such delivery or the Seller's poor progress of the supply/services vis-à-vis delivery/execution timeline as stipulated in the contract, backlog attributable to the Seller including unexecuted portion of supply does not appear to be executable within balance period available;
- ii. delivers goods or materials not of the contracted quality and failing to adhere to the contract specifications/execution methodology;
- iii. withdrawal from or repudiation/abandonment of the supply/services by the Seller before completion as per contract or if the Seller refuses or is unable to supply goods or materials covered by the order/Contract either in whole or in part or otherwise fails to perform the Order/Contract.
- iv. Non supply by the Seller within scheduled completion/delivery period as per contract or as extended from time to time for reasons attributable to the Seller;
- v. Termination of Contract on account of any other reason(s) attributable to the Seller.
- vi. Assignment, transfer, sub-letting of Contract without BHEL's written permission resulting in termination of Contract or part thereof by BHEL.
- vii. If the Seller be an individual or a Sole Proprietorship, in the event of death or insanity of the Seller.
- viii. If the Seller/Contractor being an individual or if a partnership firm thereof, shall at any time be adjudged insolvent or shall have a receiving order for administration of his estate made against him or shall take any proceeding for composition under any Insolvency Act for the time being in force or make any assignment of the order/Contract or enter into any arrangement or composition with his creditors or suspend payment or if the firm dissolved under the Partnership Act;
- ix. If the Seller/Contractor being a Company is wound up voluntarily or by order of a Court or a Receiver, Liquidator or Manager on behalf of the debenture holders and creditors is appointed or circumstances have arisen which entitles the Court of debenture holder and creditors to appoint a receiver, liquidator or manager
- x. Non- Compliance to any contractual condition or any other default attributable to the Seller.

Such defaulting vendor/Seller shall not be eligible to participate in re-tendering conducted on account of risk purchase made due to fault of such vendor/Seller.

BHEL's right to go for Risk and Cost, Calculation of Risk and Cost amount & LD, recovery options to BHEL are given in detail in Annexure-V hereto.

ANNEXURE-V

(RISK AND COST CLAUSE)

1. BHEL reserves the right to terminate the contract or withdraw portion of work and get it done through other agency, at the risk and cost of the contractor *after due notice of a period of 14 days' by BHEL* in any of the following cases:
 - i) If the Seller/Contractor fails to deliver the goods or materials or any instalment thereof within the period(s) fixed for such delivery or the Seller's poor progress of the supply/ services vis-a-vis delivery/execution timeline as stipulated in the Contract, backlog attributable to seller including unexecuted portion of supply does not appear to be executable within balance available period;
 - ii) Delivers goods or materials not of the contracted quality and failing to adhere to the contract specifications;
 - iii) Withdrawal from or repudiation/ abandonment of the supply/ services by Seller before completion as per contract or if the Seller refuses or is unable to supply goods or materials covered by the Order/Contract either in whole or in part or otherwise fails to perform the Order/Contract;
 - iv) Non-supply by the Seller within scheduled completion/delivery period as per Contract or as extended from time to time, for the reasons attributable to the Seller;
 - v) Termination of Contract on account of any other reason (s) attributable to Seller.
 - vi) Assignment, transfer, subletting of Contract without BHEL's written permission resulting in termination of Contract or part thereof by BHEL.
 - vii) If the Seller be an individual or a sole proprietorship Firm, in the event of the death or insanity of the Seller;
 - viii) If the Seller/Contractor being an individual or if a firm on a partnership thereof, shall at any time, be adjudged insolvent or shall have a receiving order for administration of his estate made against him or shall take any proceeding for composition under any Insolvency Act for the time being in force or make any assignment of the Order/Contract or enter into any arrangement or composition with his creditors or suspend payment or if the firm dissolved under the Partnership Act;
 - ix) If the Seller/Contractor being a company is wound up voluntarily or by order of a Court or a Receiver, Liquidator or Manager on behalf of the debenture holders and creditors is appointed or circumstances shall have arisen which entitles the Court of debenture holder and creditors to appoint a receiver, liquidator or manager;
 - x) Non-compliance to any contractual condition or any other default attributable to Seller.

1.1 Risk & Cost Amount against Balance Work:

Risk & Cost amount against balance work shall be calculated as follows:

$$\text{Risk \& Cost Amount} = [(A-B) + (A \times H/100)]$$

Where,

A= Value of Balance scope of Work (*) as per rates of new contract

B= Value of Balance scope of Work (*) as per rates of old contract being paid to the contractor at the time of termination of contract i.e. inclusive of PVC & ORC, if any.

H = Overhead Factor to be taken as 5

In case (A-B) is less than 0 (zero), value of (A-B) shall be taken as 0 (zero).

1.2 * Balance scope of work (in case of termination of contract):

Difference of Contract Quantities and Executed Quantities as on the date of issue of Letter for 'Termination of Contract', shall be taken as balance scope of Work for calculating risk & cost amount.

Contract quantities are the quantities as per original contract. If, Contract has been amended, quantities as per amended Contract shall be considered as Contract Quantities.

Items for which total quantities to be executed have exceeded the Contract Quantities based on drawings issued to contractor from time to time till issue of Termination letter, then for these items total Quantities as per issued drawings would be deemed to be contract quantities.

Substitute/ extra items whose rates have already been approved would form part of contract quantities for this purpose.

Substitute/ extra items which have been executed but rates have not been approved, would also form part of contract quantities for this purpose and rates of such items shall be determined in line with contractual provisions.

However, increase in quantities on account of additional scope in new tender shall not be considered for this purpose.

NOTE: In case portion of work is being withdrawn at risk & cost of contractor instead of termination of contract, contract quantities pertaining to portion of work withdrawn shall be considered as 'Balance scope of work' for calculating Risk & Cost amount.

1.3 LD against delay in executed work in case of Termination of Contract:

LD against delay in executed work shall be calculated in line with LD clause no. 16 of GCC, for the delay attributable to contractor. For limiting the maximum value of LD, contract value shall be taken as Executed Value of work till termination of contract.

Method for calculation of LD against delay in executed work in case of termination of contract" is given below.

- i. Let the time period from scheduled date of start of work till termination of contract excluding the period of Hold (if any) not attributable to contractor = T1
- ii. Let the value of executed work till the time of termination of contract = X
- iii. Let the Total Executable Value of work for which inputs/fronts were made available to contractor and were planned for execution till termination of contract = Y
- iv. Delay in executed work attributable to contractor i.e. T2 = $[1-(X/Y)] \times T1$
- v. LD shall be calculated in line with LD clause (clause 16) of the Contract for the delay attributable to contractor taking "X" as Contract Value and "T2" as period of delay attributable to contractor.

2. Recoveries arising out of Risk & Cost and LD or any other recoveries due from Contractor

Without prejudice to the other means of recovery of such dues from the Seller recoveries from the Seller on whom risk & cost has been invoked shall be made from the following:

- a) Dues available in the form of Bills payable to seller, SD, BGs against the same contract.
- b) Dues payable to seller against other contracts in the same Region/Unit/ Division of BHEL.
- c) Dues payable to seller against other contracts in the different Region/Unit/ division of BHEL.

In-case recoveries are not possible with any of the above available options, Legal action shall be initiated for recovery against contractor.

BHEL Drawing No.	Drawing Title	Vendor Sub (Days)*	Bhel comment (Days)	Vendor Sub (Days)#	Bhel and Customer comment/approval (Days)	Total Engg Time (Days)
Primary Documents						
PE-V0-XXX-507-E143	CROSS SECTION DRGS. - SCREENEDCONTROL CABLES	7	3	2	18	30
PE-V0-XXX-507-E916	QUALITY PLAN - SCREENEDCONTROL CABLES	7	3	2	18	30
PE-V0-XXX-507-E141	TECHNICAL DATA SHEET - SCREENEDCONTROL CABLES	7	3	2	18	30
Secondary Documents						
PE-V0-XXX-507-E144	TYPE TEST CERTIFICATES - SCREENEDCONTROL CABLES	7	3	2	18	30

NOTES:

a) * 1st submission within indicated days from date of purchase order
b) # Submission (within indicated days) after incorporating all BHEL comments
c) Primary documents shall be considered for Delay analysis

Price Variation Formulae for cables -Annexure-I

1. Prices shall be variable as per price variation formulae given below (basis IEEMA).
The price variation shall be limited to + 20% of total ex-works price actually supplied (cable size wise) and -ve price variation shall be unlimited. Rates for working out price variation shall be as per rates published by IEEMA for the factors given in Annexure-II

2. Base date for prices:

Initial Price (As per IEEMA) for-Alo, Cuo, CCo, PVCCo & Feo:

Base Date shall be- 1st working day of the previous month to the date of issue of tender enquiry.

Final Price (as per IEEMA) for- AI, Cu, Cc, PVCC & Fe:

1st working day of month, one month prior to the date on which cable is notified as being ready for inspection i.e TPIA inspection call raise date on web portal.

3. Variation factor value for ALF, CuF, CCFAL, CCFCu, XLFAL, XLFCu, FeF & FeW as applicable shall be as per Technical Specification.

4. PVC shall be payable within contractual delivery period (including any extension thereto).

Vikas
15.01.19

VIKAS KUMAR SINGH
E3 - ELECTRICAL

Alekheta
15/01/19.

Manish Shukla
15/01/19

IEEMA table for Price variation cause for various type of cable

1. Aluminium conductor cable

S.No	Cable Type	AIF (Single core unarmoured & Multi core armoured)	AIF (Single core armoured)	CCFAI	XLFAL (Single core)	XLFAL (Multi core)	FeF	FeW	IEEMA Formula
1.	HT XLPE Power cable	ALP	H1	H2	XL3	XL4	H3	H5	$P = P_o + AIF(AL-Alo) + XLFAL(CC-CCo) + CCFAI(PVCC-PVCCo) + FeF(Fe-Feo)$
2.	LT XLPE Power Cable	ALP	P1	L2	XL1	XL1	P3	P3 (Additional)	$P = P_o + AIF(AL-Alo) + XLFAL(CC-CCo) + CCFAI(PVCC-PVCCo) + FeF(Fe-Feo)$
3.	LT PVC Power Cable	ALP	P1	P2	-	-	P3	P3 (Additional)	$P = P_o + AIF(AL-Alo) + CCFAI(PVCC-PVCCo) + FeF(Fe-Feo)$
4.	LT HRPVC Power Cable	ALP	P1	P2	-	-	P3	P3 (Additional)	$P = P_o + AIF(AL-Alo) + CCFAI(PVCC-PVCCo) + FeF(Fe-Feo)$

2. Copper conductor cable

S no.	Cable type	CuF	AIF (single core armoured)	CCFCu	XLFCU (Single core)	XLFCU (Multi core)	FeF	FeW	IEEMA Formula
1	HT XLPE Power cable	CUP	H4	H2	XL3	XL4	H3	H5	$P = P_o + CuF(Cu-Cuo) + XLFCU(CC-CCo) + CCFCu(PVCC-PVCCo) + FeF(Fe-Feo) + AIF(AL-Alo)$
2	LT XLPE Power Cable	CUP	P4	L2	XL1	XL1	P3	P3 (Additional)	$P = P_o + CuF(Cu-Cuo) + XLFCU(CC-CCo) + CCFCu(PVCC-PVCCo) + FeF(Fe-Feo) + AIF(AL-Alo)$

S no.	Cable type	CuF	AIF (single core armoured)	CCFCu	XLFCU (Single core)	XLFCU (Multi core)	FeF	FeW	IEEMA Formula
3	LT PVC Power Cable	CUP	P4	P2	--	--	P3	P3 (Additional)	$P=Po+CuF(Cu-Cuo) + CCFCu (PVCC-PVCCo) + FeF(Fe-Feo) + AIF(AL-Alo)$
4	LT HRPVC Power Cable	CUP	P4	P2	--	--	P3	P3 (Additional)	$P=Po+CuF(Cu-Cuo) + CCFCu (PVCC-PVCCo) + FeF(Fe-Feo) + AIF(AL-Alo)$
5	LT XLPE Control Cable	CUC	--	P5	--	XL2	P6	P6 (Additional)	$P=Po+CuF(Cu-Cuo) + XLFCU(CC-CCo) + CCFCu (PVCC-PVCCo) + FeF(Fe-Feo)$
6	LT PVC Control Cable	CUC	--	P5	--	--	P6	P6 (Additional)	$P=Po+CuF(Cu-Cuo) + CCFCu (PVCC-PVCCo) + FeF(Fe-Feo)$
7	LT HRPVC Control Cable	CUC	--	P5	--	--	P6	P6 (Additional)	$P=Po+CuF(Cu-Cuo) + CCFCu(PVCC-PVCCo) + FeF(Fe-Feo)$
8	LT XLPE Fire Survival Power Cable	CUP	P4	L2	XL1	XL1	P3	P3 (Additional)	$P=Po+CuF(Cu-Cuo) + XLFCU(CC-CCo) + CCFCu (PVCC-PVCCo) + FeF(Fe-Feo) + AIF(AL-Alo)$
9	LT XLPE Fire Survival Control	CUC	--	P5	--	XL2	P6	P6 (Additional)	$P=Po+CuF(Cu-Cuo) + XLFCU(CC-CCo) + CCFCu (PVCC-PVCCo) + FeF(Fe-Feo)$
10	LT EPR Fire Survival Power Cable	CUP	P4	L2	--	--	P3	P3 (Additional)	$P=Po+CuF(Cu-Cuo) + CCFCu (PVCC-PVCCo) + FeF(Fe-Feo) + AIF(AL-Alo)$
11	LT EPR Fire Survival Control cable	CUC	--	P5	--	--	P6	P6 (Additional)	$P=Po+CuF(Cu-Cuo) + CCFCu (PVCC-PVCCo) + FeF(Fe-Feo)$
12	Screened control Cable (Overall screen)	Cu POS	--	--	--	--	Fe POS	Fe POS	$P=Po+CuF(Cu-Cuo) + FeF(Fe-Feo)$
13	Screened control Cable (Individual)	Cu PIS	--	--	--	--	Fe PIS	Fe PIS	$P=Po+CuF(Cu-Cuo) + FeF(Fe-Feo)$

IEEMA Table for Price Variation Clause for various types of Cables**Notes:-**

(i) Cu POS, Cu PIS, Fe POS & Fe PIS tables shall be as per IEEMA circular No. IEEMA (PVC) /Instrumentation Cable/2014 effective from dtd 01.07.2014.

(ii) All other tables shall be as per IEEMA circular No. 35//DIV/CAB/05/ dated 24.04.2018.

Terms used in PVC formulae:

P = Price payable as adjusted in accordance with above appropriate formula (In Rs./Km).

Po= Price quoted/confined (in Rs./km).

1. ALUMINIUM

ALF Variation factor for aluminium.

Al =Price of aluminium.

Alo = Price of aluminium.

2 COPPER

CuF =Variation factor for copper.

Cu = Price of CC copper rods.

Cuo = Price of CC copper rods.

3.PVCc COMPOUND/POLYMER

PVCc = Price of PVC compound.

PVCco= Price of PVC compound.

CCFAL= Variation factor for PVC compound/Polymer for aluminium conductor cable.

CCFCu =Variation factor for PVC compound/Polymer for copper conductor cable.

4. XLPE COMPOUND

Cc = Price of XLPE compound.

Cco= Price of XLPE compound.

XLFAL= Variation factor for XLPE compound for aluminium conductor cable.

XLFCu =Variation factor for XLPE compound for copper conductor cable.

5.STEEL

Fe= Price of steel strips/steel wire.

Feo= Price of steel strips/steel wire.

FeF =Variation factor for steel.

FeW=Variation factor for round wire steel armouring.



501, Kakad Chambers
132, Dr. Annie Besant Road, Worli
Mumbai 400018
India

P: +91 22 2493 0532
F: +91 22 2493 2705
E: mumbai@ieema.org
www.ieema.org

IEEMA (PVC)/Instrumentation Cable/2014

Effective from: 1st July 2014

Material Price Variation Clause For Instrumentation Cables

The Price quoted/confirmed is based on the input cost of raw materials/components as on the date of quotation, and the same is deemed to be related to the prices of raw materials as specified in the price variation clause given below. In case of any variation in these prices, the price payable shall be subject to adjustment up or down in accordance with the formulae provided in this document.

Terms used in price variation formulae:

P Price payable as adjusted in accordance with above appropriate formula (in Rs/Km)

P₀ Price quoted/confirmed (in Rs/Km)

COPPER

CuF Variation factor for copper

Cu Price of CC copper rods. This price is as applicable on first working day of the month, one month prior to the date of delivery.

Cu₀ Price of CC copper rods. This price is as applicable on first working day of the month, one month prior to the date of tendering.

STEEL

FeF Variation factor for steel

Fe Price of Steel Strips/steel wire. This price is as applicable on the first working day of the month, one month prior to the date of delivery.

Fe₀ Price of steel strips/steel wire. This price is as applicable on first working day of the month, one month prior to the date of tendering.

The above prices and indices are as published by IEEMA vide Circular reference IEEMA(PVC)/CABLE/--/-- prevailing as on 1st working day of the month i.e. one month prior to the date of tendering.

The date of delivery is the date on which the cable is notified as being ready for inspection/dispatch (in the absence of such notification, the date of manufacturer's dispatch note is to be considered as the date of delivery) or the contracted delivery date (including any agreed extension thereto), whichever is earlier.

Page 1 of 2

New Delhi
Rishyamook Building, First Floor
85 A, Panchkuan Road
New Delhi 110001, India
P: +91 11 2336 3013/14
F: +91 11 2336 3015
E: delhi@ieema.org

Bangalore
204, Swiss Complex
33, Race Course Road
Bangalore 560001, India
P: +91 80 2220 1316/18
F: +91 80 2220 1317
E: bangalore@ieema.org

Kolkata
503 A, Oswal Chambers
2, Church Lane
Kolkata 700001, India
P: +91 33 6510 7855
F: +91 33 2213 1326
E: kolkata@ieema.org



IEEMA (PVC)/Instrumentation Cable/2014

Effective from: 1st July 2014

Notes

- (a) All prices of raw materials are exclusive of modvatable excise/CV duty amount and exclusive of any other central, state or local taxes, octroi, etc.
- (b) All Prices are as on first working day of the month.
- (c) The details of prices are as under:
 1. Price of CC copper rods (in Rs/MT) is ex-works price as quoted by the primary producer.
 2. Price of galvanized steel strip / steel wire (in Rs/MT) is ex-works price as quoted by the manufacturer for Round steel Wire and Flat steel strip (the relevant price of steel strip or steel wire is to be selected depending upon the type of armouring of the cable).

Price variation formula for 'Instrumentaion Cables'

$P = P_o + CuF (Cu - Cuo) + FeF (Fe - Feo)$

1. For Pair Instrumentation Over all Screen Cables

Tables References:

- Cu POS Copper Factor
- Fe POS Steel Factor

2. For Pair Instrumentation Individual and Over all Screen Cables

Tables References:

- Cu PIS Copper Factor
- Fe PIS Steel Factor

3. For Triad Instrumentation Over all Screen Cables

Tables References:

- Cu TOS Copper Factor
- Fe TOS Steel Factor

4. For Triad Instrumentation Individual & Overall Screen Cables

Tables References:

- Cu TIS Copper Factor
- Fe TIS Steel Factor


Deputy Director General
 Page 2 of 2

Copper Factors for Instrumentation Cables - CuF

Cu POS

Pair Instrumentation Over all Screen Cables					
No. of Pairs Cable size in sq.mm	0.5 sq.mm	0.75 sq.mm	1.0 sq.mm	1.5 sq.mm	2.5 sq.mm
1	0.0142	0.0185	0.0233	0.0326	0.0500
2	0.0258	0.0345	0.0440	0.0625	0.0978
3	0.0353	0.0484	0.0626	0.0904	0.1433
4	0.0448	0.0623	0.0811	0.1183	0.1888
5	0.0578	0.0800	0.1022	0.1467	0.2356
6	0.0662	0.0926	0.1210	0.1768	0.2829
7	0.0756	0.1067	0.1378	0.2000	0.3245
8	0.0852	0.1204	0.1582	0.2327	0.3741
9	0.0933	0.1334	0.1734	0.2534	0.4134
10	0.1046	0.1485	0.1959	0.2893	0.4665
11	0.1111	0.1600	0.2089	0.3067	0.5023
12	0.1236	0.1764	0.2333	0.3452	0.5580
13	0.1289	0.1867	0.2445	0.3600	0.5912
14	0.1378	0.2000	0.2623	0.3867	0.6356
15	0.1467	0.2134	0.2800	0.4134	0.6801
16	0.1618	0.2322	0.3080	0.4573	0.7409
17	0.1645	0.2400	0.3156	0.4667	0.7690
18	0.1734	0.2534	0.3334	0.4934	0.8134
19	0.1822	0.2667	0.3512	0.5201	0.8579
20	0.1911	0.2800	0.3689	0.5467	0.9023
21	0.2000	0.2934	0.3867	0.5734	0.9468
22	0.2089	0.3067	0.4045	0.6001	0.9912
23	0.2178	0.3200	0.4223	0.6267	1.0357
24	0.2381	0.3437	0.4575	0.6813	1.1068
25	0.2356	0.3467	0.4578	0.6801	1.1246
26	0.2445	0.3600	0.4756	0.7068	1.1690
27	0.2534	0.3734	0.4934	0.7334	1.2135
28	0.2623	0.3867	0.5112	0.7601	1.2579
29	0.2711	0.4001	0.5290	0.7868	1.3024
30	0.2800	0.4134	0.5467	0.8134	1.3468
31	0.2889	0.4267	0.5645	0.8401	1.3913
32	0.2978	0.4401	0.5823	0.8668	1.4357
33	0.3067	0.4534	0.6001	0.8934	1.4802
34	0.3156	0.4667	0.6179	0.9201	1.5246
35	0.3245	0.4801	0.6356	0.9468	1.5691
36	0.3334	0.4934	0.6534	0.9735	1.6135
37	0.3423	0.5067	0.6712	1.0001	1.6580
38	0.3512	0.5201	0.6890	1.0268	1.7024
39	0.3600	0.5334	0.7068	1.0535	1.7469
40	0.3689	0.5467	0.7245	1.0801	1.7913
41	0.3778	0.5601	0.7423	1.1068	1.8358
42	0.3867	0.5734	0.7601	1.1335	1.8802
43	0.3956	0.5867	0.7779	1.1601	1.9247
44	0.4045	0.6001	0.7957	1.1868	1.9691
45	0.4134	0.6134	0.8134	1.2135	2.0136
46	0.4223	0.6267	0.8312	1.2402	2.0580
47	0.4312	0.6401	0.8490	1.2668	2.1025
48	0.4710	0.6759	0.9010	1.3410	2.2009



Copper Factors for Instrumentation Cables - CuF

Cu PIS

Pair Instrumentation Individual and Over all Screen Cables					
No. of Pairs Cable size in sq.mm	0.5 sq.mm	0.75 sq.mm	1.0 sq.mm	1.5 sq.mm	2.5 sq.mm
1	0.0133	0.0178	0.0222	0.0311	0.0489
2	0.0349	0.0437	0.0531	0.0717	0.1069
3	0.0490	0.0621	0.0763	0.1041	0.1570
4	0.0630	0.0806	0.0994	0.1389	0.2071
5	0.0800	0.1022	0.1245	0.1689	0.2578
6	0.0937	0.1200	0.1484	0.2042	0.3103
7	0.1067	0.1378	0.1689	0.2311	0.3556
8	0.1218	0.1569	0.1948	0.2692	0.4107
9	0.1334	0.1734	0.2134	0.2934	0.4534
10	0.1503	0.1943	0.2417	0.3349	0.5122
11	0.1600	0.2089	0.2578	0.3556	0.5512
12	0.1785	0.2313	0.2882	0.4001	0.6128
13	0.1867	0.2445	0.3023	0.4178	0.6490
14	0.2000	0.2623	0.3245	0.4489	0.6979
15	0.2134	0.2800	0.3467	0.4801	0.7468
16	0.2350	0.3053	0.3812	0.5305	0.8141
17	0.2400	0.3156	0.3912	0.5423	0.8446
18	0.2534	0.3334	0.4134	0.5734	0.8934
19	0.2667	0.3512	0.4356	0.6045	0.9423
20	0.2800	0.3689	0.4578	0.6356	0.9912
21	0.2934	0.3867	0.4801	0.6668	1.0401
22	0.3067	0.4045	0.5023	0.6979	1.0890
23	0.3200	0.4223	0.5245	0.7290	1.1379
24	0.3479	0.4535	0.5673	0.7911	1.2165
25	0.3467	0.4578	0.5690	0.7912	1.2357
26	0.3600	0.4756	0.5912	0.8223	1.2846
27	0.3734	0.4934	0.6134	0.8534	1.3335
28	0.3867	0.5112	0.6356	0.8846	1.3824
29	0.4001	0.5290	0.6579	0.9157	1.4313
30	0.4134	0.5467	0.6801	0.9468	1.4802
31	0.4267	0.5645	0.7023	0.9779	1.5291
32	0.4401	0.5823	0.7245	1.0090	1.5780
33	0.4534	0.6001	0.7468	1.0401	1.6269
34	0.4667	0.6179	0.7690	1.0712	1.6758
35	0.4801	0.6356	0.7912	1.1024	1.7247
36	0.4934	0.6534	0.8134	1.1335	1.7736
37	0.5067	0.6712	0.8357	1.1646	1.8225
38	0.5201	0.6890	0.8579	1.1957	1.8713
39	0.5334	0.7068	0.8801	1.2268	1.9202
40	0.5467	0.7245	0.9023	1.2579	1.9691
41	0.5601	0.7423	0.9246	1.2891	2.0180
42	0.5734	0.7601	0.9468	1.3202	2.0669
43	0.5867	0.7779	0.9690	1.3513	2.1158
44	0.6001	0.7957	0.9912	1.3824	2.1647
45	0.6134	0.8134	1.0135	1.4135	2.2136
46	0.6267	0.8312	1.0357	1.4446	2.2625
47	0.6401	0.8490	1.0579	1.4757	2.3114
48	0.6887	0.8936	1.1186	1.5587	2.4186



Steel Factors for Instrumentation Cables - FeF					
Fe POS					
Pair Instrumentation Over all Screen Cables					
No. of Pairs Cable size in sq.mm	0.5 sq.mm	0.75 sq.mm	1.0 sq.mm	1.5 sq.mm	2.5 sq.mm
1	0.1490	0.1565	0.1635	0.1735	0.1930
2	0.2190	0.2335	0.2470	0.2665	0.2595
3	0.2360	0.2545	0.2690	0.2900	0.2680
4	0.2390	0.2580	0.2715	0.2945	0.2830
5	0.2630	0.2820	0.2420	0.2805	0.3155
6	0.2840	0.3160	0.2805	0.2995	0.3430
7	0.2840	0.2595	0.2805	0.2995	0.3430
8	0.3235	0.2930	0.3030	0.3315	0.3780
9	0.2805	0.3180	0.3290	0.3590	0.4205
10	0.2970	0.3215	0.3455	0.3755	0.4385
11	0.3005	0.3255	0.3490	0.3805	0.4435
12	0.3055	0.3440	0.3690	0.3880	0.4520
13	0.3265	0.3530	0.3780	0.4105	0.4785
14	0.3265	0.3530	0.3780	0.4105	0.4785
15	0.3490	0.3765	0.4015	0.4365	0.5195
16	0.3490	0.3765	0.4015	0.4365	0.5195
17	0.3590	0.4005	0.4140	0.4635	0.5470
18	0.3590	0.4005	0.4265	0.4635	0.5470
19	0.3590	0.4005	0.4265	0.4635	0.5470
20	0.3830	0.4240	0.4535	0.4920	0.5760
21	0.3830	0.4240	0.4535	0.4920	0.5760
22	0.4065	0.4520	0.4785	0.5310	0.6190
23	0.4065	0.4520	0.4810	0.5310	0.6190
24	0.4305	0.4770	0.5070	0.5595	0.6475
25	0.4305	0.4770	0.5070	0.5595	0.6475
26	0.4305	0.4770	0.5070	0.5595	0.6475
27	0.4355	0.4820	0.5245	0.5660	0.6700
28	0.4570	0.5045	0.5345	0.5895	0.6950
29	0.4570	0.5045	0.5345	0.5895	0.6950
30	0.4570	0.5045	0.5345	0.5895	0.6950
31	0.4795	0.5285	0.5595	0.6150	0.7225
32	0.4820	0.5285	0.5595	0.6150	0.7225
33	0.4820	0.5285	0.5595	0.6150	0.7225
34	0.4920	0.5520	0.5835	0.6410	0.7500
35	0.4920	0.5520	0.5835	0.6410	0.7500
36	0.4920	0.5520	0.5835	0.6410	0.7500
37	0.4920	0.5520	0.5835	0.6410	0.7500
38	0.5145	0.5760	0.6225	0.6550	0.7805
39	0.5145	0.5760	0.6225	0.6550	0.7805
40	0.5145	0.5760	0.6225	0.6550	0.7805
41	0.5395	0.6025	0.6475	0.6975	0.8230
42	0.5395	0.6025	0.6475	0.6975	0.8230
43	0.5395	0.6025	0.6475	0.6975	0.8230
44	0.5635	0.6265	0.6735	0.7250	0.8540
45	0.5635	0.6265	0.6760	0.7250	0.8540
46	0.5635	0.6265	0.6760	0.7250	0.8540
47	0.5635	0.6265	0.6760	0.7250	0.8540
48	0.5635	0.6265	0.6760	0.7375	0.8665



Steel Factors for Instrumentation Cables - FeF					
Fe PIS					
Pair Instrumentation Individual and Over all Screen Cables					
No. of Pairs Cable size in sq.mm	0.5 sq.mm	0.75 sq.mm	1.0 sq.mm	1.5 sq.mm	2.5 sq.mm
1	0.1880	0.1980	0.2070	0.2220	0.2410
2	0.2315	0.2460	0.2595	0.2815	0.2755
3	0.2505	0.2690	0.2820	0.2495	0.2830
4	0.2645	0.2830	0.2420	0.2805	0.3155
5	0.2895	0.2730	0.2805	0.3005	0.3430
6	0.2755	0.2980	0.3005	0.3280	0.3730
7	0.2755	0.2980	0.3005	0.3280	0.3730
8	0.2980	0.3215	0.3455	0.3740	0.4230
9	0.3230	0.3490	0.3730	0.4040	0.4685
10	0.3405	0.3655	0.3765	0.4215	0.4885
11	0.3430	0.3690	0.3815	0.4265	0.4945
12	0.3490	0.3765	0.4015	0.4470	0.5160
13	0.3715	0.3990	0.4255	0.4720	0.5420
14	0.3715	0.3990	0.4255	0.4720	0.5420
15	0.3955	0.4240	0.4510	0.5020	0.5720
16	0.3955	0.4240	0.4510	0.5020	0.5720
17	0.4190	0.4495	0.4795	0.5295	0.6150
18	0.4190	0.4495	0.4795	0.5295	0.6150
19	0.4190	0.4495	0.4795	0.5295	0.6150
20	0.4445	0.4770	0.5060	0.5570	0.6450
21	0.4445	0.4895	0.5060	0.5695	0.6450
22	0.4695	0.5045	0.5345	0.5870	0.6885
23	0.4695	0.5045	0.5345	0.5870	0.6885
24	0.4970	0.5310	0.5620	0.6285	0.7210
25	0.4970	0.5310	0.5620	0.6285	0.7210
26	0.4970	0.5310	0.5620	0.6285	0.7210
27	0.5035	0.5495	0.5810	0.6360	0.7410
28	0.5135	0.5610	0.6050	0.6610	0.7690
29	0.5135	0.5610	0.6050	0.6610	0.7690
30	0.5260	0.5610	0.6050	0.6610	0.7690
31	0.5495	0.5845	0.6300	0.6885	0.7990
32	0.5495	0.5845	0.6300	0.6885	0.7990
33	0.5495	0.5845	0.6300	0.6885	0.7990
34	0.5735	0.6225	0.6585	0.7285	0.8405
35	0.5735	0.6225	0.6585	0.7285	0.8405
36	0.5735	0.6225	0.6585	0.7285	0.8405
37	0.5735	0.6225	0.6585	0.7285	0.8405
38	0.5990	0.6485	0.6850	0.7575	0.8740
39	0.5990	0.6485	0.6850	0.7575	0.8740
40	0.5990	0.6485	0.6850	0.7575	0.8740
41	0.6250	0.6775	0.7135	0.7880	0.9180
42	0.6250	0.6775	0.7135	0.7880	0.9180
43	0.6250	0.6775	0.7135	0.7880	0.9180
44	0.6485	0.7050	0.7410	0.8165	0.9495
45	0.6485	0.7050	0.7410	0.8165	0.9495
46	0.6485	0.7050	0.7410	0.8165	0.9495
47	0.6485	0.7050	0.7410	0.8165	0.9495
48	0.6485	0.7050	0.7535	0.8290	0.9620



Indian Electrical & Electronics Manufacturer's Association
501, Kakad Chambers P +91 22 2493 0532
132, Dr. A. B. Road, Worli F +91 22 2493 2705
Mumbai - 400 018. E mumbai@ieema.org
INDIA. W www.ieema.org

Cir. No. 35/DIV/CAB/05/

✓ 24th April 2018

To Members of the Cable Division, Utilities, Railways & Listed purchasing organizations.

Sub: Correction in PV formulae of LT XLPE Power Cable and addition of factors for HT XLPE Power Cables

We have recently published revised Price Variation Clause for LT&HT XLPE Power Cables and made it effective from 1st November 2017 vide Cir. No.111/DIV/CAB/05 dated 5th December 2017.


While replying to a query of a buyer it is observed that the polymer factor for LT XLPE Power Cables (both aluminium and copper) was incorrectly represented by Table P2.

We have now corrected the anomaly by correcting the PV formulae of LT XLPE Aluminium and Copper Insulated Cables (Sl. No. D & E) by representing Polymer factor by Table L2.

We have also worked out factors for XLPE, Copper and Steel for 3 core HT XLPE Power Cables for 500 and 630 sq.mm.

We now enclose complete PV clause of Cable by including all the PV formulae of different types of power cable (Sl. No. A to I), polymer factor Table L2 and updated XL4, H2 and H5 Table of factors for your perusal & record.

We request to replace PV clause of Cable already circulated vide Cir. 111/DIV/CAB/05 dated 5th December 2017 with the enclosed PV clause in your records for future use.


Senior Director

Encl: as above



Indian Electrical & Electronics Manufacturer's Association
 501, Kakad Chambers, P +91 22 2493 0532
 132, Dr. A. B. Road, Worli, F +91 22 2493 2705
 Mumbai - 400 018. E rumbai@ieema.org
 INDIA. W www.ieema.org

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1st November 2017

Material Price Variation Clause For PVC And XLPE Insulated Cables

The Price quoted/confirmed is based on the input cost of raw materials/components as on the date of quotation, and the same is deemed to be related to the prices of raw materials as specified in the price variation clause given below. In case of any variation in these prices, the price payable shall be subject to adjustment up or down in accordance with the formulae provided in this document.

Terms used in price variation formulae:

P Price payable as adjusted in accordance with above appropriate formula (in Rs/Km)

Po Price quoted/confirmed (in Rs/Km)

ALUMINIUM

AIF Variation factor for aluminium

AI Price of Aluminium. This price is as applicable of first working day of the month, one month prior to the date of delivery.

Alo Price of aluminium. This price is as applicable on first working day of the month, one month prior to the date of tendering.

COPPER

CuF Variation factor for copper

Cu Price of CC copper rods. This price is as applicable on first working day of the month, one month prior to the date of delivery.

Cuo Price of CC copper rods. This price is as applicable on first working day of the month, one month prior to the date of tendering.

PVC COMPOUND

PVCc price of PVC compound. This price is as applicable on first working day of the month, one month prior to the date of delivery.

PVCco Price of PVC compound. This price is as applicable on first working day of the month, one month prior to the date of tendering.

CCFAI Variation factor for PVC compound/Polymer for aluminum conductor cable.

CCFCu Variation factor for PVC compound/Polymer for copper conductor cable.





Indian Electrical & Electronics Manufacturer's Association
 501, Kakad Chambers
 132, Dr. A. B. Road, Worli,
 Mumbai - 400 018.
 INDIA.
 P: +91 22 2493 0532
 F: +91 22 2493 2705
 E: mumbai@ieema.org
 W: www.ieema.org

**IEEMA (PVC)/CABLE(R-1)/2017
 XLPE COMPOUND**

Effective from: 1st November 2017

Cc price of XLPE compound. This price is as applicable on first working day of the month, one month prior to the date of delivery.

Cco Price of XLPE compound. This price is as applicable on first working day of the month, one month prior to the date of tendering.

XLFAL Variation factor for XLPE compound for aluminum conductor cable.

XLFCU Variation factor for XLPE compound for Copper conductor cable.

STEEL

FeF Variation factor for steel

FeW Variation factor for round wire steel armouring

Fe Price of Steel Strips/steel wire. This price is as applicable on the first working day of the month, one month prior to the date of delivery.

Feo Price of steel strips/steel wire. This price is as applicable on first working day of the month, one month prior to the date of tendering.

The above prices and indices are as published by IEEMA vide Circular reference IEEMA (PVC)/CABLE R(1)/--/-- prevailing as on 1st working day of the month i.e. one month prior to the date of tendering.

The date of delivery is the date on which the cable is notified as being ready for inspection/dispatch (in the absence of such notification, the date of manufacturer's dispatch note is to be considered as the date of delivery) or the contracted delivery date (including any agreed extension thereto), whichever is earlier.

Notes

- (a) All prices of raw materials are exclusive of GST amount.
- (b) All prices excluding Aluminium & Copper are as on first working day of the month.
- (c) The details of prices are as under:

1. Price of Aluminium is LME average Cash SELLER Settlement price of Primary Aluminium in US\$ per MT as published by London Metal Bulletin (LME) including Premium for Aluminium Ingot in US\$ per MT is converted in Indian Rs./MT.
2. Price of PVC Compound (in Rs/MT) is the ex-works price, as quoted by the manufacturer.
3. Price of XLPE Compound (in Rs/MT) is the ex-works price, as quoted by the manufacturer.
4. Price of CC copper rods (in Rs/MT) is ex-works price as quoted by the primary producer.
5. Price of galvanized steel strip / steel wire (in Rs/MT) is ex-works price as quoted by the manufacturer for Round steel Wire and Flat steel strip (the relevant price of steel strip or steel wire is to be selected depending upon the type of armouring of the cable).

proud partners in implementation



MISSION PLAN
2012-2022

HEAD OFFICE - DELHI
 Rishyamook Building, First Floor, 85 A, Panchsukian Road, New Delhi - 110001, INDIA.
 P +91 11 2336 3013 /14 • F +91 11 2336 3015 • E delhi@ieema.org • W www.ieema.org

2 page of 22

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1st November 217

Price variation formulae for 'Power Cables'

✓ A. Aluminum conductor PVC insulated 1.1 kV power cables

$$P = P_0 + AIF (AL - A_0) + CCFAI (PVCc - PVCc_0) + FeF (Fe - Fe_0)$$

For unarmoured multicore cables (without steel armour); FeF = 0

Table References:

- ✓ ALP Aluminium conductor in single core unarmoured & multicore cables
- ✓ P1 Aluminium conductor aluminium armour in single core armoured cables
- ✓ P2 PVC compound
- ✓ P3 Steel armour

✓ B. Copper conductor PVC insulated 1.1 kV power cables

$$P = P_0 + CuF (Cu - Cu_0) + CCFCu (PVCc - PVCc_0) + FeF (Fe - Fe_0) + AIF (Al - Al_0)$$

For steel armoured cables; AIF = 0 For aluminium armoured cables; FeF = 0

For unarmoured cables; FeF, AIF = 0

Tables References:

- ✓ CUP Copper conductor
- ✓ P2 PVC compound
- ✓ P3 Steel armour
- ✓ P4 Aluminium armour

C. Copper conductor PVC insulated 1.1 kV control cables

$$P = P_0 + CuF (Cu - Cu_0) + CCFCu (PVCc - PVCc_0) + FeF (Fe - Fe_0)$$

For unarmoured cables; FeF = 0

Tables References:

- ✓ CUC Copper conductor
- ✓ P5 PVC compound
- ✓ P6 Steel armour

✓ D. Aluminum conductor XLPE insulated 1.1 kV power cables

$$P = P_0 + AIF (AL - A_0) + XLFAL (CC - Cc_0) + CCFAI (PVCc - PVCc_0) + FeF (Fe - Fe_0)$$

For unarmoured multicore cables (without steel armour); FeF = 0

Table References:

- ALP Aluminium conductor in single core unarmoured & multicore cables
- P1 Aluminium conductor aluminium armour in single core armoured cables
- L2 Polymer (CCFAI)
- P3 Steel armour
- XL1 XLPE Compound (XLFAL)

E. Copper conductor XLPE insulated 1.1 kV power cables

$$P = P_0 + CuF (Cu - Cu_0) + XLFCU (CC - Cc_0) + CCFCu (PVCc - PVCc_0) + FeF (Fe - Fe_0) + AIF (Al - Al_0)$$

For steel armoured cables; AIF = 0 For aluminium armoured cables; FeF = 0



IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1st November 2017

For unarmoured cables; FeF, AIF = 0

Tables References:

✓CUP	Copper conductor
L2	Polymer (CCFCu)
P3	Steel armour
✓P4	Aluminium armour
XL1	XLPE Compound (XLFCu)

F. Copper conductor XLPE insulated 1.1 kV control cables

$$P = P_o + CuF (Cu - Cu_o) + XLFCU (CC-Cco) + CCFCu (PVCc-PVCco) + FeF (Fe-Fe_o)$$

For unarmoured cables; FeF = 0

Tables References:

CUC	Copper conductor
P5	PVC compound
P6	Steel armour
XL2	XLPE Compound

✓ G. For Aluminium conductor XLPE insulated 3.3 to 33 kV power cables

$$P = P_o + AIF (Al - Al_o) + XLFAL (CC-Cco) + CCEAI (PVCc - PVCco) + FeF (Fe - Fe_o)$$

For unarmoured multicore cables (without steel armour); FeF = 0

Table References:

ALP	Aluminium conductor in single core unarmoured & multicore cables
H1	Aluminium conductor + aluminium armour in single core armoured cables
H2	Polymer
H3/H5	Steel armour (Flat/Round)
XL3/XL4	XLPE Compound (Single core /Multicore)

✓ H. Copper conductor XLPE Insulated 3.3 to 33 kV power cables

$$P = P_o + CuF (Cu - Cu_o) + XLFCU (CC-Cco) + CCFCu (PVCc - PVCco) + FeF (Fe - Fe_o) + AIF (Al - Al_o)$$

For steel armoured cables; AIF = 0 For aluminium armoured cables; FeF = 0
For unarmoured cables; FeF, AIF = 0

Table References:

✓CUP	Copper conductor
✓H2	Polymer
✓H3/H5	Steel armour (Flat/Round)
✓H4	Aluminium armour
✓XL3/XL4	XLPE Compound (Single core /Multicore)

I. Copper conductor XLPE insulated 1.0 and 1.5 kV Solar PV DC cables

$$P = P_o + CuF (Cu - Cu_o)$$

Table CUdc Copper Conductor

[Signature]
Authorized Signatory

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1st November 217

✓ TABLE ALP

VARIATION FACTOR FOR ALUMINIUM (AIF)
POWER CABLES WITH ALUMINIUM CONDUCTOR
(EXCLUDING SINGLE CORE ARMOURED CABLES)

Nominal Cross Sectional Area (in Sq. mm.)	1 core	2 core	3 core	3.5 core	4 core
2.5	0.007	0.014	0.021	-	0.028
4	0.011	0.023	0.034	-	0.046
6	0.017	0.034	0.052	-	0.069
10	0.029	0.053	0.087	-	0.116
16	0.046	0.091	0.137	-	0.183
25/16	0.073	0.146	0.219	0.262	0.292
35/16	0.101	0.202	0.302	0.345	0.404
50/25	0.137	0.273	0.410	0.478	0.547
70/35	0.197	0.395	0.593	0.687	0.791
95/50	0.274	0.548	0.821	0.949	1.095
120/70	0.346	0.691	1.035	1.221	1.382
150/70	0.425	0.853	1.279	1.464	1.706
185/95	0.533	1.070	1.605	1.861	2.140
225/120	0.655	1.310	1.965	2.287	2.620
240/120	0.703	1.400	2.099	2.421	2.799
300/150	0.879	1.757	2.635	3.033	3.514
400/185	1.126	2.249	3.374	3.873	4.498
500	1.418	2.838	4.256	-	5.675
630	1.828	3.663	5.494	-	7.326
800	2.340	4.679	7.018	-	9.357
1000	2.951	5.890	8.934	-	11.779

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1st November 217

TABLE CUP

VARIATION FACTOR FOR COPPER CONDUCTOR (CUF)
POWER CABLES WITH COPPER CONDUCTOR

Nominal Cross Sectional Area (in Sq. mm.)	1 core	2 core	3 core	3.5 core	4 core
2.5	0.023	0.046	0.069	-	0.092
4	0.036	0.076	0.112	-	0.151
6	0.056	0.112	0.171	-	0.227
10	0.095	0.174	0.286	-	0.382
16	0.151	0.299	0.451	-	0.602
25/16	0.240	0.480	0.720	0.862	0.960
35/16	0.332	0.664	0.993	1.135	1.329
50/25	0.451	0.898	1.348	1.572	1.799
70/35	0.648	1.299	1.950	2.260	2.602
95/50	0.901	1.802	2.700	3.121	3.601
120/70	1.138	2.273	3.407	4.016	4.545
150/70	1.398	2.806	4.207	4.815	5.611
185/95	1.753	3.519	5.279	6.121	7.038
225/120	2.154	4.309	6.463	7.522	8.617
240/120	2.312	4.605	6.904	7.963	9.206
300/150	2.891	5.779	8.667	9.976	11.558
400/185	3.703	7.397	11.097	12.738	14.794
500	4.664	9.334	13.998	-	18.665
630	6.012	12.048	18.070	-	24.095
800	7.696	15.389	23.082	-	30.775
1000	9.706	19.372	29.055	-	38.741

TABLE CUsdc

VARIATION FACTOR FOR COPPER CONDUCTOR (CUF)
1.0 & 1.5KV Solar PV DC Cables with Copper Conductor

Cable Size in sq.mm.	Copper content in MT/km
2.5	0.023
4	0.038
6	0.058
10	0.090

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1st November 217

TABLE CUC

VARIATION FACTOR FOR COPPER CONDUCTOR (CUF) ✓
CONTROL CABLES WITH COPPER CONDUCTOR

No of Cores	Core size 1.5 sq mm	Core size 2.5 sq mm
2	0.026	0.047
3	0.039	0.070
4	0.052	0.094
5	0.065	0.117
6	0.078	0.141
7	0.091	0.164
8	0.110	0.182
9	0.117	0.205
10	0.130	0.235
12	0.157	0.282
14	0.183	0.329
16	0.209	0.376
18	0.246	0.410
19	0.248	0.446
20	0.260	0.456
24	0.313	0.563
27	0.352	0.634
30	0.391	0.704
37	0.483	0.869
44	0.573	1.033
52	0.678	1.221
61	0.796	1.432

IEEMA (PVC)/CABLE(R-1)/2017
TABLE P1

Effective from: 1st November 2017

VARIATION FACTOR FOR ALUMINIUM (AIF)
ALUMINIUM ARMoured SINGLE CORE PVC INSULATED 1.1 KV CABLES

Nominal cross sectional area (in Sq.mm)	Aluminium factor for Aluminium armoured cable with aluminium conductor
4	0.0685
6	0.0795
10	0.1017
16	0.1303
25	0.1693
35	0.2090
50	0.2597
70	0.3360
95	0.4567
120	0.5443
150	0.6427
185	0.7743
240	0.9737
300	1.2582
400	1.5502
500	1.8958
630	2.3650
800	2.9306
1000	3.7666

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1st November 217

TABLE P2

VARIATION FACTOR FOR PVC COMPOUND (CCFAl/CCFCu)
PVC INSULATED 1.1 KV POWER CABLES WITH COPPER/ALUMINIUM CONDUCTOR

Nominal cross Sectional Area (in Sq. mm)	1 core	2 core		3 core		3.5 core		4 core	
	Unarm	Unarm	arm	Unarm	arm	Unarm	arm	Unarm	arm
2.5	0.079	0.125	0.139	0.141	0.157	-	-	0.161	0.179
4	0.094	0.140	0.156	0.164	0.182	-	-	0.188	0.209
6	0.101	0.154	0.171	0.179	0.199	-	-	0.198	0.220
10	0.114	0.194	0.216	0.214	0.238	-	-	0.249	0.277
16	0.142	0.234	0.246	0.279	0.290	-	-	0.328	0.345
25	0.171	0.288	0.303	0.364	0.383	0.422	0.444	0.443	0.466
35	0.189	0.321	0.338	0.403	0.429	0.489	0.515	0.498	0.524
50	0.211	0.411	0.433	0.508	0.535	0.613	0.645	0.647	0.681
70	0.241	-	-	0.613	0.645	0.707	0.744	-	-
95	0.284	-	-	0.795	0.811	0.908	0.927	-	-
120	0.339	-	-	0.866	0.884	1.024	1.045	-	-
150	0.388	-	-	1.070	1.092	1.289	1.315	-	-
185	0.450	-	-	1.310	1.337	1.499	1.530	-	-
225	0.521	-	-	1.586	1.618	1.840	1.878	-	-
240	0.534	-	-	1.649	1.683	1.990	2.031	-	-
300	0.653	-	-	2.007	2.048	2.361	2.409	-	-
400	0.770	-	-	2.437	2.487	2.616	2.669	-	-
500	0.936	-	-	3.117	3.181	3.687	3.762	-	-
630	1.175	-	-	-	-	-	-	-	-
800	1.433	-	-	-	-	-	-	-	-
1000	1.642	-	-	-	-	-	-	-	-

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1st November 2017

TABLE P3

VARIATION FACTOR FOR STEEL (FeF)
PVC INSULATED 1.1 KV POWER CABLES WITH COPPER/ALUMINIUM CONDUCTOR

Nominal Cross sectional Area (in Sq. mm)	2 core	Shape	3 core	Shape	3 ½ core	Shape	4 core	Shape
4	0.305	W	0.335	W	-	-	0.363	W
6	0.348	W	0.363	W	-	-	0.407	W
10	0.392	W	0.407	W	-	-	0.293	F
16	0.235	F	0.293	F	-	-	0.323	F
25	0.293	F	0.352	F	0.382	F	0.382	F
35	0.323	F	0.382	F	0.411	F	0.440	F
50	0.382	F	0.440	F	0.469	F	0.499	F
70	0.411	F	0.499	F	-	F	0.587	F
95	0.499	F	0.587	F	0.616	F	0.645	F
120	0.528	F	0.616	F	0.675	F	0.731	F
150	0.587	F	0.675	F	0.731	F	0.790	F
185	0.645	F	0.761	F	0.820	F	0.879	F
240	0.731	F	0.879	F	0.937	F	0.996	F
300	0.820	F	0.966	F	1.055	F	1.113	F
400	0.937	F	1.083	F	1.172	F	1.231	F
500	1.055	F	1.231	F	1.348	F	1.406	F
630	1.172	F	-	-	-	-	-	-

IEEMA (PVC)/CABLE(R-1)/2017
TABLE P3 (Additional)

Effective from: 1st November 2017

VARIATION FACTOR FOR ROUND WIRE 'W' STEEL (FeF)
PVC INSULATED 1.1 KV POWER CABLES WITH COPPER/ALUMINIUM CONDUCTOR

Nominal Cross Sectional Area (in sq. mm)	2 Core	3 Core	3.5 Core	4 Core
1.5	0.247	0.259		0.288
2.5	0.273	0.289		0.329
4	0.305	0.335		0.363
6	0.348	0.363		0.407
10	0.392	0.407		0.533
16	0.439	0.523	0.014	0.573
25	0.526	0.625	0.664	0.685
35	0.591	0.685	0.729	0.761
50	0.661	0.790	0.864	1.108
70	0.745	1.122	1.200	1.256
95	1.085	1.286	1.376	1.443
120	1.147	1.386	1.479	1.562
150	1.267	1.526	1.684	2.173
185	1.403	2.090	2.315	2.421
240	1.994	2.397	2.641	2.722
300	2.180	2.642	3.670	3.842
400	2.987	3.728	4.126	4.292
500	3.517	4.226	5.958	6.301
630	4.774	6.018	6.737	7.141

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1st November 217

TABLE P4

VARIATION FACTOR FOR ALUMINIUM (AIF)
PVC INSULATED 1.1 KV POWER CABLES WITH COPPER CONDUCTOR

Nominal Cross Sectional Area (in Sq. mm)	Aluminium Factor for Aluminium armoured cable with copper conductor
4	0.058
6	0.063
10	0.073
16	0.084
25	0.096
35	0.108
50	0.123
70	0.139
95	0.183
120	0.198
150	0.218
185	0.241
240	0.271
300	0.379
400	0.424
500	0.478
630	0.537
800	0.591
1000	0.816

TABLE P5

VARIATION FACTOR FOR PVC COMPOUND (CCFCu)
PVC INSULATED CONTROL CABLES WITH COPPER CONDUCTOR

No of cores	Core size 1.5 sq mm		Core size 2.5 sq mm	
	Unarm	Arm	Unarm	Arm
2	0.118	0.121	0.125	0.139
3	0.121	0.131	0.141	0.157
4	0.137	0.152	0.161	0.179
5	0.157	0.174	0.187	0.206
6	0.179	0.199	0.234	0.260
7	0.179	0.199	0.234	0.260
8	0.193	0.215	0.292	0.325
9	0.216	0.241	0.300	0.335
10	0.236	0.262	0.303	0.337
12	0.249	0.277	0.334	0.371
14	0.311	0.327	0.389	0.409
16	0.344	0.362	0.435	0.458
18	0.352	0.371	0.474	0.500
19	0.375	0.395	0.476	0.501
20	0.391	0.412	0.519	0.546
24	0.457	0.481	0.584	0.615
27	0.491	0.517	0.631	0.664
30	0.529	0.557	0.706	0.743
37	0.615	0.647	0.835	0.879
44	0.739	0.778	1.019	1.026
52	0.845	0.889	1.100	1.158
61	0.952	1.002	1.246	1.312

IEEMA (PVC)/CABLE(R-1)/2017
TABLE P6

Effective from: 1st November 217

VARIATION FACTOR FOR STEEL (FeF)
PVC INSULATED CONTROL CABLES WITH COPPER CONDUCTOR

No of cores	Core size 1.5 sq mm	Shape of armour	Core size 2.5 sq mm	Shape of armour
2	0.243	W	0.277	W
3	0.257	W	0.289	W
4	0.277	W	0.314	W
5	0.303	W	0.342	W
6	0.329	W	0.379	W
7	0.329	W	0.379	W
8	0.341	W	0.456	W
9	0.383	W	0.275	F
10	0.408	W	0.325	F
12	0.289	F	0.342	F
14	0.306	F	0.360	F
16	0.317	F	0.372	F
18	0.332	F	0.350	F
19	0.343	F	0.397	F
20	0.368	F	0.400	F
24	0.398	F	0.475	F
27	0.414	F	0.478	F
30	0.425	F	0.503	F
37	0.461	F	0.548	F
44	0.507	F	0.601	F
52	0.556	F	0.641	F
61	0.585	F	0.685	F

IEEMA (PVC)/CABLE(R-1)/2017
TABLE P6 (Additional)

Effective from: 1st November 217

VARIATION FACTOR FOR ROUND WIRE 'W' STEEL (FeF).
PVC INSULATED CONTROL CABLES WITH COPPER CONDUCTOR

No. of Cores	Core size 1.5 sq mm	Core size 2.5 sq mm
2	0.243	0.273
3	0.257	0.289
4	0.277	0.314
5	0.303	0.342
6	0.329	0.379
7	0.329	0.379
8	0.341	0.456
9	0.383	0.508
10	0.408	0.535
12	0.510	0.572
14	0.546	0.625
16	0.581	0.660
19	0.608	0.696
24	0.714	0.819
25	0.679	0.798
27	0.732	0.837
28	0.696	0.815
30	0.758	0.881
33	0.747	0.883
37	0.820	1.217
44	0.926	1.355
48	1.122	1.308
50	1.122	1.308
52	1.149	1.361
56	1.202	1.388
61	1.299	1.520

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1st November 217

TABLE L2

VARIATION FACTOR FOR POLYMER (CCFAI / CCFCu)
XLPE INSULATED 1.1 KV POWER CABLES WITH COPPER / ALUMINIUM CONDUCTOR

Nominal Cross Sectional Area (In Sq. mm)	1 core		2 core		3 core		3.5 core		4 core	
	Unarm.	Unarm	Arm	Unarm	Arm	Unarm	Arm	Unarm	Arm	
2.5	0.055	0.163	0.175	0.166	0.177	-	-	0.177	0.188	
4	0.075	0.201	0.204	0.205	0.213	-	-	0.218	0.213	
6	0.085	0.213	0.234	0.205	0.230	-	-	0.242	0.232	
10	0.082	0.252	0.280	0.217	0.251	-	-	0.285	0.298	
16	0.089	0.278	0.341	0.289	0.246	-	-	0.300	0.279	
25	0.101	0.307	0.278	0.276	0.247	0.295	0.264	0.331	0.290	
35	0.109	0.330	0.319	0.305	0.270	0.328	0.292	0.368	0.319	
50	0.124	0.482	0.685	0.348	0.311	0.372	0.335	0.422	0.394	
70	0.146	0.354	0.335	0.469	0.397	0.489	0.420	0.528	0.464	
95	0.163	0.436	0.389	0.504	0.441	0.544	0.471	0.591	0.523	
120	0.176	0.475	0.421	0.556	0.498	0.599	0.538	0.722	0.656	
150	0.217	0.510	0.490	0.690	0.611	0.717	0.633	0.840	0.762	
185	0.236	0.631	0.608	0.836	0.738	0.854	0.756	1.007	0.899	
240	0.273	0.750	0.726	1.002	0.842	1.079	0.952	1.238	1.119	
300	0.303	0.919	0.887	1.161	1.012	1.170	1.031	1.457	1.414	
400	0.372	1.093	1.040	1.376	1.283	1.545	1.379	1.778	1.626	
500	0.413	1.342	-	1.568	1.400	1.806	1.456	-	-	
630	0.469	1.546	-	-	-	-	-	-	-	
800	0.569	-	-	-	-	-	-	-	-	
1000	0.667	-	-	-	-	-	-	-	-	

225 removed ↓

L2 LL R2

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1st November 217

TABLE XL1
VARIATION FACTOR FOR XLPE COMPOUND (XLFAL/XLFUCU)
XLPE INSULATED 1.1 KV POWER CABLES WITH COPPER/ALUMINIUM CONDUCTOR

Nominal cross Sectional Area (in.Sq. mm)	1 core		2 core		3 core		3.5 core		4 core	
	Unarm	Arm	Unarm	Arm	Unarm	arm	Unarm	Arm	Unarm	arm
2.5	0.007	0.010	0.014	0.014	0.021	0.021			0.028	0.028
4	0.009	0.012	0.018	0.018	0.027	0.027			0.036	0.036
6	0.010	0.015	0.022	0.022	0.033	0.033			0.043	0.043
10	0.013	0.018	0.025	0.025	0.039	0.039			0.053	0.053
16	0.016	0.023	0.034	0.034	0.049	0.049			0.065	0.065
25	0.021	0.030	0.048	0.048	0.070	0.070	0.084	0.084	0.093	0.093
35	0.025	0.035	0.059	0.059	0.084	0.084	0.099	0.099	0.112	0.112
50	0.033	0.044	0.075	0.075	0.108	0.108	0.130	0.130	0.144	0.144
70	0.042	0.054	0.095	0.095	0.137	0.137	0.160	0.160	0.179	0.179
95	0.048	0.062	0.110	0.110	0.160	0.160	0.190	0.190	0.211	0.211
120	0.060	0.076	0.138	0.138	0.200	0.200	0.239	0.239	0.266	0.266
150	0.078	0.095	0.180	0.180	0.259	0.259	0.296	0.296	0.344	0.344
185	0.097	0.116	0.224	0.224	0.324	0.324	0.369	0.369	0.430	0.430
240	0.116	0.137	0.266	0.266	0.388	0.388	0.446	0.446	0.518	0.518
300	0.138	0.164	0.325	0.325	0.467	0.467	0.540	0.540	0.620	0.620
400	0.175	0.214	0.357	0.357	0.536	0.536	0.619	0.619	0.714	0.714
500	0.217	0.260	0.440	0.440	0.660	0.660	0.769	0.769	0.880	0.880
630	0.265	0.318	0.542	0.542	0.814	0.814	0.941	0.941	1.085	1.085
800	0.323	0.389								
1000	0.375	0.444								

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1st November 2017

TABLE XL2
VARIATION FACTOR FOR XLPE COMPOUND (XLFCU)
XLPE INSULATED CONTROL CABLES WITH COPPER CONDUCTOR

No of cores	Core size 1.5 sq mm		Core size 2.5 sq mm	
	Unarm	Arm	Unarm	Arm
2	0.010	0.010	0.012	0.012
3	0.016	0.016	0.018	0.018
4	0.021	0.021	0.025	0.025
5	0.026	0.026	0.031	0.031
6	0.031	0.031	0.037	0.037
7	0.036	0.036	0.043	0.043
8	0.036	0.036	0.043	0.043
9	0.042	0.042	0.049	0.049
10	0.052	0.052	0.061	0.061
12	0.062	0.062	0.074	0.074
14	0.073	0.073	0.086	0.086
16	0.083	0.083	0.098	0.098
18	0.094	0.094	0.110	0.110
19	0.099	0.099	0.116	0.116
20	0.104	0.104	0.123	0.123
24	0.125	0.125	0.147	0.147
27	0.140	0.140	0.165	0.165
30	0.156	0.156	0.184	0.184
37	0.192	0.192	0.227	0.227
44	0.229	0.229	0.270	0.270
52	0.270	0.270	0.319	0.319
61	0.317	0.317	0.374	0.374

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1st November 217

TABLE XL3

VARIATION FACTOR FOR XLPE (XLFAL/XLFCE)

SINGLE CORE ARMoured / UNARMoured XLPE INSULATED 3.3 to 33 KV POWER CABLES WITH
CU / AL CONDUCTOR

Nominal Cross Sectional Area (in Sq. mm.)	XLPE Factor for Armoured/ Unarmoured Cable with AL / CU Conductor					
	3.3 KV	6.6 KV (E)	11 KV (E) / 6.6 KV (UE)	11 KV (UE)	22 KV (E)	33 KV (E)
25	0.110	0.131	0.170	0.279		
35	0.122	0.137	0.175	0.284	0.317	0.522
50	0.135	0.151	0.191	0.307	0.341	0.563
70	0.155	0.172	0.215	0.342	0.379	0.615
95	0.174	0.193	0.241	0.377	0.417	0.670
120	0.192	0.212	0.262	0.407	0.449	0.713
150	0.209	0.229	0.283	0.437	0.481	0.757
185	0.228	0.250	0.308	0.471	0.518	0.809
240	0.255	0.279	0.343	0.519	0.569	0.883
300	0.280	0.322	0.372	0.560	0.613	0.943
400	0.326	0.392	0.420	0.625	0.683	1.041
500	0.388	0.461	0.469	0.694	0.757	1.142
630	0.467	0.520	0.529	0.777	0.845	1.265
800	0.567	0.593	0.602	0.874	0.949	1.407
1000	0.656	0.665	0.660	0.955	1.036	1.525

Note : XLPE factors include Semicons for Conductor & Insulation screen

TABLE - XL4

VARIATION FACTOR FOR XLPE (CCF1A / CCF1Cu)

3 CORE XLPE INSULATED 3.3 to 33 KV POWER CABLES WITH COPPER / ALUMINIUM CONDUCTOR

Nominal Cross Sectional Area (in Sq. mm)	3.3 KV	6.6 KV (E)	6.6 KV (UE) / 11 KV (E)	11 KV (UE)	22 KV (E)	33 KV (E)
	ARM	ARM	ARM	ARM	ARM	ARM
25	0.315	0.394	0.511	0.838		
35	0.339	0.427	0.545	0.880	0.982	1.638
50	0.378	0.474	0.600	0.957	1.065	1.751
70	0.435	0.541	0.679	1.067	1.183	1.916
95	0.489	0.604	0.755	1.171	1.295	2.071
120	0.537	0.661	0.822	1.265	1.396	2.210
150	0.585	0.719	0.890	1.359	1.497	2.350
185	0.642	0.784	0.968	1.468	1.614	2.513
240	0.717	0.873	1.074	1.615	1.773	2.732
300	0.781	1.006	1.167	1.744	1.928	2.919
400	0.886	1.227	1.314	1.948	2.130	3.229
500	0.956	1.421	1.445	2.148	2.381	3.538
630	1.129	1.582	1.609	2.382	2.630	3.940

Note : XLPE factors include Semicons for Conductor & Insulation screen

Added
1/2

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1st November 217

TABLE H1
VARIATION FACTOR FOR ALUMINIUM (AIF)
ALUMINIUM ARMoured SINGLE CORE XLPE INSULATED 3.3 TO 33 KV CABLES

Nominal Cross Sectional Area (in Sq. mm.)	Aluminium Factor for Aluminium Armoured Cable with Aluminium Conductor					
	3.3 KV	6.6 KV (E)	11 KV (E)/ 6.6 KV (UE)	11 KV (UE)	22 KV (E)	33 KV (E)
35	0.251	0.284	0.301	0.344	0.358	0.473
50	0.312	0.336	0.352	0.397	0.408	0.672
70	0.385	0.409	0.423	0.469	0.501	0.723
95	0.476	0.500	0.518	0.637	0.656	0.856
120	0.561	0.586	0.601	0.726	0.744	0.949
150	0.653	0.678	0.696	0.823	0.842	1.050
185	0.773	0.797	0.893	0.949	0.965	1.183
240	0.997	1.063	1.083	1.139	1.154	1.387
300	1.209	1.271	1.283	1.333	1.307	1.753
400	1.438	1.556	1.565	1.620	1.636	2.046
500	1.873	1.901	1.910	2.110	2.128	2.484
630	2.337	2.361	2.369	2.580	2.595	2.978
800	3.007	3.071	3.080	3.145	3.163	3.588
1000	3.737	3.741	3.749	3.804	3.822	4.565

TABLE H2
VARIATION FACTOR FOR POLYMER (CCFAI / CCFCu)
3 CORE XLPE INSULATED 3.3 TO 33 KV POWER CABLES WITH COPPER / ALUMINIUM CONDUCTOR

Nominal Cross Sectional Area (in Sq. mm)	3.3 KV ARM	6.6 KV (E) ARM	6.6 KV (UE) / 11 KV (E) ARM	11 KV (UE) ARM	22 KV (E) ARM	33 KV (E) ARM
35	0.374	0.990	1.142	1.604	1.782	-
50	0.445	1.119	1.260	1.834	2.046	2.864
70	0.547	1.290	1.396	2.011	2.284	3.219
95	0.594	1.440	1.647	2.269	2.428	3.367
120	0.732	1.692	1.877	2.498	2.715	3.646
150	0.812	1.906	2.061	2.767	2.931	3.927
185	0.960	2.086	2.406	3.028	3.180	4.166
240	1.130	2.484	2.744	3.398	3.580	4.589
300	1.219	2.912	3.161	3.840	4.016	5.029
400	1.313	3.530	3.664	4.353	4.666	5.736
500	1.652	3.925	3.971	4.621	4.878	5.913
630	1.949	4.487	4.982	5.225	5.477	6.696

Fillers added in PVC consumption

Added →
Added →

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1st November 217

TABLE H3
VARIATION FACTOR FOR STEEL (FeF)
XLPE INSULATED 3.3 TO 33 KV POWER CABLES WITH COPPER / ALUMINIUM CONDUCTOR

Nominal Cross Sectional Area Sq. mm.	3.3 KV	6.6 KV (E)	11 KV (E) / 6.6 KV (UE)	11 KV (UE)	22 KV (E)	33 KV (E)
25	0.551	0.604	0.656	0.814		
35	0.645	0.645	0.731	0.879	0.937	-
50	0.675	0.703	0.761	0.937	0.966	1.181
70	0.761	0.761	0.849	0.996	1.055	1.289
95	0.820	0.849	0.907	1.083	1.113	1.348
120	0.879	0.907	0.966	1.142	1.172	1.406
150	0.966	0.966	1.055	1.201	1.259	1.494
185	1.025	1.055	1.113	1.259	1.318	1.553
240	1.142	1.142	1.231	1.377	1.406	1.641
300	1.231	1.259	1.318	1.465	1.524	1.758
400	1.348	1.406	1.435	1.582	1.641	1.876

TABLE H4
VARIATION FACTOR FOR ALUMINIUM (AIF)
XLPE INSULATED SINGLE CORE 3.3 TO 33 KV POWER CABLES WITH COPPER CONDUCTOR

Nominal Cross Sectional Area (in Sq. mm.)	Aluminium Factor for Aluminium Armoured Cable with Copper Conductor					
	3.3 KV	6.6 KV (E)	11 KV (E)/ 6.6 KV (UE)	11 KV (UE)	22 KV (E)	33 KV (E)
35	0.153	0.187	0.204	0.247	0.258	0.372
50	0.179	0.203	0.220	0.262	0.275	0.425
70	0.196	0.219	0.233	0.278	0.311	0.444
95	0.213	0.237	0.254	0.373	0.392	0.470
120	0.228	0.253	0.268	0.393	0.410	0.488
150	0.243	0.269	0.287	0.414	0.432	0.504
185	0.261	0.285	0.381	0.437	0.455	0.526
240	0.324	0.389	0.410	0.465	0.480	0.556
300	0.365	0.428	0.440	0.490	0.510	0.737
400	0.432	0.471	0.480	0.536	0.552	0.783
500	0.489	0.517	0.526	0.726	0.744	0.844
630	0.544	0.568	0.572	0.787	0.801	0.902
800	0.706	0.787	0.797	0.862	0.880	0.982
1000	0.824	0.865	0.867	0.923	0.940	1.324

TABLE - H5
VARIATION FACTOR FOR STEEL (FeW)
XLPE INSULATED 3.3KV TO 33 KV POWER CABLES WITH COPPER / ALUMINIUM CONDUCTOR

Nominal Cross Sectional Area in Sq. mm	3.3/3.3 KV	3.3/6.6 KV	11 KV (E) / 6.6 KV (UE)	11 KV (UE)	22 KV (E)	33 KV (E)
25	1.258	1.457	1.612	2.509	1.503	--
35	1.361	1.569	1.853	2.644	2.797	2.517
50	1.682	1.687	2.321	2.800	2.921	4.569
70	2.033	1.979	2.503	3.219	3.347	4.809
95	2.202	2.507	2.718	4.019	4.200	5.437
120	2.371	2.675	2.882	4.241	4.416	6.713
150	2.870	2.847	3.265	4.447	4.621	6.976
185	3.121	3.309	4.148	4.726	5.289	7.356
240	3.758	4.227	4.442	5.442	6.651	7.718
300	4.099	5.024	5.182	6.894	7.084	8.187
400	5.750	6.572	6.658	7.433	7.657	8.760
500	6.716	6.777	6.861	7.588	7.797	8.830
630	7.492	7.465	7.177	8.209	8.386	9.413

Added →
Added →

Project : 2X800MW NTPC KARIMNAGAR SG PACKAGE PHASE-1

Package : SCREENED CONTROL CABLES

GEM Bid no.

Item Number	Item Title	Item Description	HSN	Item Quantity	Unit of Measure	Consignee ID	Delivery Period (In number of days)	Quote/Unquote	Freight in terms of total Ex-works price in %	GST rate in %
1	225V Type F(IO) 4P-0.5 Unarmoured	507-31046-A	85444920	16000	MTR	BIPIN_BIHARI	90			
2	225V Type G(O) 4P-0.5 Unarmoured	507-31066-A	85444920	44000	MTR	BIPIN_BIHARI	90			