


	2X660 MW Talcher STPP	SECTION: C SUB SECTION : C&I
	SPECIFIC TECHNICAL REQUIREMENTS (C&I)	

LOCAL CONTROL PANEL

	SPECIFICATION FOR LOCAL PANELS	SPECIFICATION NO.: PE-SS-999-145-054A	
		VOLUME	II B
		SECTION	D
		REV. NO. 03	DATE : 16-09-2013
		SHEET	I OF 5

1.0 SCOPE

This specification covers the Design, Manufacture, Inspection and Testing at the manufacturer's works, proper packing for transportation and delivery to site, supervision, erection, and commissioning at site of Local Panels required for control and monitoring of the Auxiliary Plant & Equipment.

2.0 CODES AND STANDARDS

2.1 All the equipments specified herein shall comply with the requirements of the latest issue of the relevant National and International standards.

2.2 As a minimum requirement, the following standards shall be complied with:

a) IS-6005 : 1998 : Code of practice for phosphating of iron and steel.
b) IS-5 : 2007 : Colors for ready mixed paints and enamels.
c) IS-1248:2003 : Direct Acting Indicating Analog Elec Measuring Instruments.
d) IS/IEC 60947:Part 1:2004 : Low Voltage switchgear & control gear: Part-I (General Rules)
e) IS-8828:1996 : Circuit breaker for household and similar installations.
f) IS-13947 (Part-I):1993 : Low Voltage switchgear & control gear : Part-I (General Rules)
g) ISA-18.1:1979 : Annunciator Sequences and Specification
h) NFPA-496:2003 : Purged & Pressurised Enclosure for Electrical Equipment in Hazardous Locations.

3.0 TECHNICAL REQUIREMENTS

3.1 Panel Construction

3.1.1 The local panels shall house the secondary instruments, annunciation system, Single loop controller, Control switches / push buttons, indicating lamps/LED cluster, relays, timers and other devices required for operation and monitoring of the equipment locally.

3.1.2 The panels shall be of free standing type either welded construction on angle iron (minimum section of 50 x 50 x 4 mm) structure or folded construction by sheet metal formation depending upon the equipments to be mounted on it. The panels shall be robustly built and stiffeners as necessary shall be provided.


3.1.3 The panel shall be suitably reinforced to ensure adequate support for all instruments mounted thereon. All welds on exposed panel surfaces shall be ground smooth.

3.1.4 The salient features of construction shall be:

Sheet material: Cold rolled sheet steel
Frame thickness: Not less than 3.0mm
Enclosure thickness: Not less than 3.0 mm for load bearing sections (Mounted with instruments)
2.0 mm for doors and Not less than 2.0 mm for others
Panel Height: Not less than 2365 mm
Gland plate thickness: 3.0mm
Base channel: ISMC 100 with anti-vibration mounting & foundation bolts.

3.1.5 The panel shall be provided with rear doors with integral lockable handle. The door when locked shall be held at minimum three places. The door width shall not be more than 550mm. The doors shall be provided with suitable stiffeners to prevent buckling. The handle shall be on the right side of the door. The door shall be removable type with concealed hinges to facilitate maintenance work. Suitable pocket inside the door shall be provided for keeping the drawings / documents. Double door shall be provided with suitable glass windows, as per the requirement.

3.1.6 Suitable neoprene gasket shall be provided on all doors and removable covers. Suitable ventilation system along with louvers shall be provided at bottom and top of the doors covered with removable wire mesh.

	SPECIFICATION FOR LOCAL PANELS	SPECIFICATION NO.: PE-SS-999-145-054A	
		VOLUME	II B
		SECTION	D
		REV. NO. 03	DATE : 16-09-2013
		SHEET	2 OF 5

3.1.7 The class of protection shall be in accordance with IP-55

3.1.8 All steel surfaces shall be cleaned by sand / pellet blasting, treated for pickling, degreasing and phosphating etc. by seven tank method. The panel shall have a high quality finish and appearance. The panel shall be painted with two coats of primer followed by two coats of epoxy / synthetic enamel based final paint of color shade and finish Minimum thickness of the paint shall be 85 microns for external paint and 70 microns for internal paint.

3.1.9 The cable glands of the required size and type shall be supplied alongwith the Panel.

3.1.10 All operable and indicating devices shall be mounted on the front of the panel while aux. Relays / timers MCBs etc. required for realization of control logics shall be mounted on a mounting plate inside the panel. Auxiliary relays and timers etc. shall be grouped according to the control function. No operable or indicating devices shall be mounted below 750 mm and above 1800 mm (w.r.t. finished ground level). The devices shall be located in such a way so as to ensure easy access for operation / maintenance.

3.1.11 Single / dual control power supply feeders of voltage class as specified shall be provided by the purchaser. In case redundant power supply feeders are provided then auto changeover unit shall be mounted on the panel are in the panel supplier's scope. Where DC control power supply is specified an additional 240V, 50 Hz AC supply feeder for powering of space heater and lighting shall be provided by the purchaser. Suitable arrangement shall be provided inside the panel to receive and terminate the power supply feeder(s). For this purpose MCBs of suitable current rating shall be provided by the vendor. A supervisory relay along with a pilot lamp to indicate control supply 'ON' shall be provided on the panel. Any other power supply required for the operation of the devices mounted in the panel shall be arranged by the vendor.

3.1.12 The internal wiring shall be carried out with 1100 volt grade PVC insulated copper multi strand wire / flexible of 1.5mm² size. AC & DC wires shall be kept separate from each other. Separate coloured wires to be used for AC and DC circuits. All wires shall be properly numbered and identified with ferrules as per the Control scheme / wiring diagram. Wires shall be routed and run through PVC troughs.


3.1.13 Terminal blocks shall be clip on type, 1100 volts grade. Separate terminal blocks shall be used for AC & DC circuits. The terminals shall be suitable for terminating 0.5 mm² to 2.5mm² external cables. The TB points in terminal block shall be cage clamp type / screw type. The terminal for ammeters shall be provided with removable links for shorting CTs. Each terminal strip shall be provided with identification strip. The terminal shall not be mounted below 250 mm height from finished floor. The panel shall have ten (20) percent spare terminal.


3.1.14 The interior of each panel shall be suitably illuminated through fluorescent lamps / tube lights with shrouded cover of minimum 15W operable on 240V 50 Hz AC power supply through panel door switch. A 15 Amp, 3-pin Power receptacle shall be provided.

3.1.15 Suitable space heaters operable on 240 Volts 50 Hz AC power system shall be provided at the panel bottom. These shall be designed to maintain the panel temperature five (5) deg. C above the ambient temperature during maintenance shutdown. Suitable isolating and control devices comprising of MCB, thermostat etc. shall be provided for the space heater.

3.1.16 The panel shall be provided with a copper earth bus of 25 x 6 mm size running throughout the width of the panel. It shall be terminated internally with 10 mm bolts at extreme ends for connection to; main station earth. The panel mounted equipments / devices shall be connected to earth bus through green coloured PVC insulated stranded copper conductor of 2.5 mm² size.

3.1.17 Local Panel shall be provided with main name plate of 150 mm x 40 mm size having inscription of 20 mm height. The individual devices on the panels shall be as provided with separate name plate with inscription of 3 mm height. The instrument / devices shall be provided with stick on label plates inside the panel. The material of the main and individual labels shall be three (3) ply 3 mm thick Traffolyte

	SPECIFICATION FOR LOCAL PANELS	SPECIFICATION NO.: PE-SS-999-145-054A	
		VOLUME	II B
		SECTION	D
		REV. NO. 03	DATE : 16-09-2013
		SHEET	3 OF 5
<p>Sheet / 2 mm Anodised Aluminium Plate. The inscription shall be with white letters on black background on traffolyte sheet. The labels shall be fixed by self tapping non-rusting screws.</p> <p>3.1.18 Vendor shall furnish electric load and heat load list (in case panel is to be placed in ac environment) of each panel.</p> <p>3.2 Hazardous Area Panel Requirement</p> <p>3.2.1 The Local Panel located in hazardous area shall be pressurized as per NFPA-496 requirements to render it non-hazardous. Alarms shall be provided for local and remote annunciation when pressurisation falls below 2.5 mm of water column. Protection shall be of type Z of NFPA-496. It shall not be possible to switch ON the power of purged section unless it is purged as per the recommendation of NFPA-496. Vendor must provide a protective device on the panel to protect the panel from over pressurisation.</p> <p>3.2.2 Vendor shall supply pressurisation kit consisting of valves, restriction orifices, dual filter regulation, pressure gauges, pressure switches, rotameter etc. Pressurisation kit shall be surface mounting on a metal board and located outside the local panel. Pressurisation kit shall further consist of solenoid valve flow switch, timer blow off safety device etc., so as to make purging fully automatic. However final start shall be manual. Panel protection against over pressure to be provided as per NFPA-496.</p> <p>3.2.3 Pressurised local control panel pressurization kit assembly design shall provide minimum leakage flow through the Local Control Panel. Panel venting shall be as per NFPA-496.</p> <p>3.2.4 All components in the local panel like indicating instruments, push buttons switches, lamps etc., which are required to be energized without panel pressurization or before completion of purge cycle shall be explosion proof as per NEMA-7 & suitable for area classification.</p> <p>3.2.5 All push buttons etc. requiring frequent operation during machine running shall have good positive sealing. Weatherproof housing or cover to be provided wherever necessary. Vendor shall provide pressurisation bypass switch outside explosion proof enclosure of pressurized panel with lamp indication. This shall be used only during maintenance. All hinges, screws, other non-painted metallic parts shall be of stainless steel material.</p> <p>3.2.6 Provision to switch off manually all types of power shall be provided in the panel. In addition, it shall also be possible to switch off power circuits / components which are powered from motor control centre or control room manually in case of pressurization failure. All such cables from MCC and main control room shall be terminated in explosion proof boxes (NEMA-7).</p> <p>3.3 Control & Monitoring devices</p> <p>3.3.1 Instruments like Indicators, recorders, single loop controllers etc. as applicable and specified elsewhere for the plant / equipment shall be supplied and mounted on the panel.</p> <p>3.3.2 Alarm Annunciator System It shall be solid state discrete facia type having a sequence of ISA-S18.1A or as specified, opaque facia windows of 70 mm x 50 mm size, having two (2) lamps per window, and hooter of 10W, and provision for repeat group alarm at remote. The annunciator shall be provided with ten (10) percent spare windows or minimum two (2) windows along with electronics.</p> <p>3.3.3 Relays The relays shall be electromagnetic type suitable for specified control supply. Its contact configuration and rating shall be suitable for the specified control function. However minimum contact rating shall be 5 Amp AC & 2 Amp DC as applicable. There shall be ten (10) percent spare contacts.</p> <p>3.3.4 Timers The timers shall be electronic type suitable for specified control supply. Its contact configuration and rating shall be suitable for the specified control function. However, minimum contact rating shall be 5 Amp AC & 2 Amp DC as applicable.</p>			

	SPECIFICATION FOR LOCAL PANELS	SPECIFICATION NO.: PE-SS-999-145-054A	
		VOLUME	II B
		SECTION	D
		REV. NO. 03	DATE : 16-09-2013
		SHEET	4 OF 5

3.3.5 Control / Selector Switches
Switches shall be Rotary Cam type with minimum of 5 Amps AC & 2 Amp DC continuous current rating. Selector switches shall be stay put type while control switches shall be spring-return-to-neutral type. Contact configuration and rating shall be as per the control function requirement. The switches shall be lockable type wherever specified. Each switch shall be provided with engraved plates indicating the switch position / functions.

3.3.6 Push Buttons / Indicating Lights
The push buttons shall be momentary action self-resetting type, however stop P.B. for unidirectional drives shall be provided with manual reset facility. Its contact configuration & rating shall be as required for the control function but minimum 2 NO + 2 NC of 5 Amp. AC rating. It shall have round coloured projecting tab and engraved escutcheon plate / inscription plate. Colour coding of push buttons shall be as under:

RED	Motor OFF / Valve CLOSE	YELLOW	Alarm acknowledge	Left Hand Side
GREEN	Motor ON / Valve OPEN	BLACK	Lamp test	Right Hand Side

Indicating lights shall be suitable for direct connections across specified power supplies. It shall be fitted with built in resistance to prevent circuit tripping on shorting of lamp filament. It shall be fitted with LED cluster type lamp replaceable from front.

GREEN	Motor OFF / Valve CLOSED condition	AMBER	Motor tripped	Left Hand Side
RED	Motor ON / Valve OPEN condition	WHITE	Normal / healthy	Right Hand Side

3.3.7 Ammeters
Ammeter shall be 96 x 96 mm size, 90 deg. deflection, 1.5% accuracy, 1 Amp. CT operated or with 4-20mA input and Flush mounting type as called for
Ammeters for motors shall have six (6) times folded scale at upper end to enable motor starting current indication

3.3.8 Miniature Circuit Breaker (MCB)
These shall be instantaneous magnetic trip type for short circuit in addition to current time inverse delayed thermal trip feature for over current protection. The housing of MCB shall be made of non-ignitable, high impact material. It shall have minimum short circuit rating of 9 KA for AC Voltages and 4 KA for DC Voltages.


3.3.9 Makes of various instruments / devices shall be as given below

1.	Alarm Annunciators	:	Procon / IIC
2.	Ammeters	:	AEP / IMP
3.	Control / Selector Switches	:	Alsthom / Kaycee / Siemens / L&T
4.	Push Buttons / Indicating Lamps	:	Siemens / L&T / Teknic / Alsthom
5.	Auxiliary Relays	:	Jyoti / Siemens / L&T / OEN
6.	Timers	:	L&T / Alsthom / Bhartiya Cutler Hammer
7.	MCBs	:	S&S Power Engg. / Indo Asian / MDS
8.	Terminal Blocks	:	Jyoti / Elmex

4.0 TESTING AND INSPECTION

4.1 The bidder shall adopt suitable quality assurance program to ensure that the equipments offered will meet the specification requirements in full.

4.2 BHEL's standard Quality Plan for LCP is enclosed with the specification. The bidder shall furnish his acceptance to BHEL's QP and submit the signed and stamped copy of QP along with the offer.

	SPECIFICATION FOR LOCAL PANELS	SPECIFICATION NO.: PE-SS-999-145-054A	
		VOLUME	II B
		SECTION	D
		REV. NO. 03	DATE : 16-09-2013
		SHEET	5 OF 5

4.3 The vendor shall conduct the following tests as a minimum requirement:

4.3.1 Routine Tests

1. High Voltage (H.V.)
2. Insulation Resistance (I.R.)
3. Functional

4.3.2 Type Tests

1. Enclosure Class Test

5.0 SPARES AND CONSUMABLES

5.1 Commissioning Spares and consumables

The bidder shall supply all commissioning spares and consumables 'as required' during Start-up, as part of the main equipment supply.

5.2. Mandatory Spares

The bidder shall offer alongwith main offer, the Mandatory Spares as specified elsewhere in the specification. The Mandatory Spares offered shall be of the same make and type as the main equipment.

5.3. Recommended Spares

The bidder shall furnish a list of Recommended Spares indicating the normal service expectancy period and frequency of replacement; quantities recommended for 3 years operation alongwith unit rate against each item to enable BHEL/BHEL's Customer to place a separate order later, if required.

6.0 DRAWINGS AND DOCUMENTS

6.1 The bidder shall furnish the following documents in required number of copies along with the bid :

2. General Arrangement Drawing.
3. Catalogue and technical information for instruments and devices.
4. Quality Plan.

6.2 The vendor shall furnish the following documents in required number as agreed after the award of contract:

2. GA Drawing indicating layout of instruments, construction details, foundation details, cable gland plate alongwith cable glands and all details mentioned in this specification.
3. Control Schematic Diagram along with grouping of different terminals for various functions.
4. Catalogue and technical information for instruments and devices with selected options clearly marked.
5. O&M Manuals.
6. "As Built" Drawing.
7. CDs.

7.0 MARKING AND PACKING

7.1 Panel with all instruments / devices mounted on it shall be suitably packed & protected for the entire period of despatch, storage and erection against impact, abrasion, corrosion, incidental damage due to vermin, sunlight, high temperature, rain moisture, humidity, dust, sea-water spray (where applicable) as well as rough handling and delays in Transit and storage in open.

	2X660 MW Talcher STPP	SECTION: C SUB SECTION : C&I
	SPECIFIC TECHNICAL REQUIREMENTS (C&I)	

QUALITY ASSURANCE



MEASURING INSTRUMENTS

Page- 1/2

Item Components Sub System Assembly	Attributes Characteristics								
	Dimensions (R)	Make, Model, Type, Rating (R)	Process / Electrical connection (R)	Calibration (R)	Test as per standard(R)	Insulation Resistance (R)	IBR Certification (As applicable)	Hydro Test(R)	Material Test certificate ®
1. PR Gauge (IS-3624)	Y	Y	Y	Y	Y				
2. Temp. Gauge (BS-5235)	Y	Y	Y	Y	Y				
3. Pr./D.P.Switch(BS-6134)	Y	Y	Y	Y	Y	Y			
4. Electronic Transmitter(IEC-60770)	Y	Y	Y	Y	Y	Y			
5. Temp. Switch	Y	Y	Y	Y	Y	Y			
6. Electrical Metering Instrument (IS-1248)	Y	Y	Y	Y	Y	Y			
7. Transducer (IS-14570)	Y	Y	Y	Y	Y	Y			
8. Thermocouples (IEC – 584 / ANSI-MC-96.1)	Y	Y	Y	Y	Y	Y			
9. RTD(IS-2848)	Y	Y	Y	Y	Y	Y			
10. Thermowell	Y		Y				Y	Y	Y
R-Routine Test A- Acceptance Test Y – Test applicable									
<p>Note: 1) This is an indicative list of tests/checks. The manufacturer is to furnish a detailed quality plan indicating the Practices and Procedure adopted along with relevant supporting documents.</p>									



MEASURING INSTRUMENTS

Page- 2/2

Item Components Sub System Assembly	Attributes Characteristics												
	GA, Dimensions, Paint Thickness (R)	Make, Model, Type, Rating ,BOM(R)	Process / Electrical connection (R)	Calibration/Functional (R)	Requirement as per standard (R)	WPS approval (A)	Non-destructive testing (R)	Calculation for accuracy (R)	HV/ IR Test (R)	IBR Certification as applicable (R)	Hydro test (R)	Material test certificate (A)	Integral Testing of complete System
11. Orifice plate(BS-1042)	Y	Y	Y	Y*	Y	Y*	Y*			Y	Y*	Y	
12. Flow nozzle(BS-1042)	Y	Y	Y	Y*	Y	Y	Y			Y	Y	Y	
13. Impact head type element	Y	Y	Y					Y				Y	
14. Electronics Water Level Indicator (EWLI)	Y	Y	Y		Y		Y		Y	Y	Y	Y	Y
15. Flue Gas & Ambient Air Analysers	Y	Y	Y	Y					Y				Y
16- Analysers	Y	Y	Y	Y			Y		Y	Y	Y	Y	Y
R-Routine Test A- Acceptance Test Y – Test applicable													
*Calibration to be carried out on one flow element of each type and size if calibration carried out as type test same shall not be repeated.													
** As applicable													
#Vaccuminasation test of chiller assembly													
Note: 1) This is an indicative list of tests/checks. The manufacturer is to furnish a detailed quality plan indicating the Practices and Procedure adopted along with relevant supporting documents.													

CLAUSE NO.

QUALITY ASSURANCE



POWER SUPPLY FOR C&I SYSTEMS (UPS/BATTERY/BATTERY CHARGER/ACDB/DCDB)

ITEMS	TESTS																
	Visual/dimension/rating/ Paint Adhesion/ Thickness (R)	General arrangement/BOM/make of components /Mimic ®	Efficiency .regulation(R)	Input voltage variation (A)	Out put voltage and frequency adi. range(A)	Preliminary light load test(R)	Load transfer retransfer test (R) *	AC input failure and return test (R)	Parallel operation and current division(R)	Relative harmonic content(R)	Restart with PRI A.C and battery (separately)(R)	System transfer and retransfer (R)*	Asynchronous transfer(R)	Ripple content(R)	Load limiter operation (R)	IR/HV(R)	Tests as per standard &specification (R)&(A)
UPS/CONVERTER (IEC-146 PT-4)	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
VOLTAGE STABILISER	Y	Y	Y	Y	Y				Y		Y					Y	
LEAD ACID BATTERY (PLANTE)-IS-1652																	Y
Ni-CD BATTERY(IS-10918/IEC-623)																	Y
ACDB/DCDB	Y	Y														Y	Y
BATTERY CHARGER	Y	Y	Y	Y	Y			Y					Y	Y	Y	Y	Y
R-Routine Test A- Acceptance Test Y – Test applicable																	
* Transfer time and Over shoot /under shoot during load & system transfer shall be recorded.																	
Note: 1) This is an indicative list of tests/checks. The manufacturer is to furnish a detailed quality plan indicating the Practices and Procedure adopted along with relevant supporting documents.																	

INSTRUMENTATION CABLE

TESTS																		
ITEMS	Conductor Resistance ® & (A)	High Voltage ® & (A)	Insulation Resistance ® & (A)	Constructional detail, dimensions (A)	Outer-Sheath/core marking, end sealing (A)	Thermal Stability (A) +	Visual, Surface finish (A) +	Electrical Parameters ** (A) +	Persulphate Test (A) +	Overall/Coverage/Continuity (A)	Swidesh chimney Test (SS-4241475) (A) ++	FRLS Test * (A) ++	Tensile & Elongation before & after aging (A) ++	Vol. Resistivity. at room & Elevated Temp. (A) ++	Spark test report review ®			
1. Instrument cable twisted and shielded																		
Conductor(IS-8130)	Y			Y			Y											
Insulation(VDE-207)				Y	Y	Y	Y						Y					Y
Pairing/Twisting				Y	Y		Y											
Shielding				Y			Y			Y								
Drain wire	Y			Y			Y		Y	Y								
Inner Sheath				Y	Y	Y	Y					Y	Y					
Outer Sheath				Y	Y	Y	Y					Y	Y					
Over all cable	Y	Y	Y	Y	Y		Y	Y			Y							Y
Cable Drums(IS-10418)				Y			Y											

Note : High Temp. cables shall be subjected to tests as per VDE-207(Part-6) Compensating cables shall be checked for Thermal EMF/Endurance test as per IS 8784.

Note : This is an indicative list of tests/checks. The manufacture is to furnish a detailed Quality Plan indicating his practice & Procedure along with relevant supporting documents during QP finalization for all items.

Note : ® - Routine Test A - Acceptance Test Y - Test Applicable

Note : Sampling Plan for Acceptance test shall be as per IS 8784 (As applicable)

- * FRLS Tests: Oxygen / Temp Index (ASTM D-2863), Smoke Density Rating (ASTM – D 2843), HCL Emission (IEC-754-1)
- ** Characteristic Impedance, Attenuation, Mutual Capacitance, Cross Talk (As applicable)

+ Sample size will be One No. of each size/type per lot.

++ Sample size will be One No. sample for complete lot offered irrespective of size/type.

CLAUSE NO.

QUALITY ASSURANCE



ELECTRICAL ACTUATOR WITH INTEGRAL STARTER

Test/Attributes Characteristics													
ITEM/ COPONENT/ SUB SYSTEM ASSEMBLY/ TESTING	RPM ®	No Load Current ®	IR & HV Test®	Mounting Dimension®	All routine Test as per Standard & Specification®	Correct Phase Sequence®	Operation & Setting of limit Switch/Torque Switch®	Stall Torque/Current (A)	Hand Wheel operation/ Auto de clutch function (A)	Function of Aux. like Potentiometer, space heater, position indicator ®	EPT output ®	Local/ Remote (Open-Stop-Close) Operation®	Safety check (Single phasing, Phase correction, Tripping etc.) (A)
ELECTRICAL ACTUATOR with Integral Starter , Non-Intrusive Electrical Actuator (EN15714-2)													
Motor	Y	Y	Y	Y	Y								
Final Testing	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y

Note: 1) This is an indicative list of tests/checks. The manufacturer is to furnish a detailed quality plan indicating the practices and procedure adopted along with relevant supporting documents.


- SIL 2 certificate if applicable

® - Routine Test (A) - Acceptance Test Y - Test applicable

	2X660 MW Talcher STPP	SECTION: C SUB SECTION : C&I
	MRS system	

TYPE TEST REQUIREMENTS


|


CLAUSE NO.	TECHNICAL REQUIREMENTS			
<p>1.00.00</p> <p>1.01.00</p> <p>1.01.01</p> <p>1.01.02</p> <p>1.01.03</p> <p>1.01.04</p>	<p>TYPE TEST REQUIREMENTS</p> <p>General Requirements</p> <p>The Contractor shall furnish the type test reports of all type tests as per relevant standards and codes as well as other specific tests indicated in this specification. If the bidder proposes a different standard/code from that indicated at clause no 2.01.00 and at table 3.00.00, same is acceptable provided the equivalence of the proposed standard is established by the bidder. A list of such tests are given for various equipment in table titled 'TYPE TEST REQUIREMENT FOR OTHER C&I SYSTEMS' at the end of this chapter and under the item "Special Requirement for Solid State Equipments/Systems".</p> <p>(a) Out of the tests listed, the Bidder/ sub-vendor/ manufacturer is required to conduct certain type tests specifically for this contract (and witnessed by Employer or his authorized representative) even if the same had been conducted earlier, as clearly indicated subsequently against such tests.</p> <p>(b) For the rest, submission of type test results and certificate shall be acceptable provided.</p> <p>i. The same has been carried out by the Bidder/ sub-vendor on exactly the same model /rating of equipment.</p> <p>ii. There has been no change in the components from the offered equipment & tested equipment.</p> <p>iii. The test has been carried out as per the latest standards alongwith amendments as on the date of Bid opening.</p> <p>(c) In case the approved equipment is different from the one on which the type test had been conducted earlier or any of the above grounds, then the tests have to be repeated and the cost of such tests shall be borne by the Bidder/ sub-vendor within the quoted price and no extra cost will be payable by the Employer on this account.</p> <p>The schedule of conduction of type tests/ submission of reports shall be submitted and finalized during pre-award discussion.</p> <p>For the type tests to be conducted, Contractor shall submit detailed test procedure for approval by Employer. This shall clearly specify test setup, instruments to be used, procedure, acceptance norms (wherever applicable), recording of different parameters, interval of recording precautions to be taken etc. for the tests to be carried out.</p> <p>The Bidder shall indicate in the relevant BPS schedule, the cost of the type test for each item only for which type tests are to be conducted specifically for this project. The cost shall only be payable after conduction of the respective type test in presence of authorize representative of Employer. If a test is waived off, then the cost shall not be payable.</p>			
<p>TALCHER THERMAL POWER PROJECT STAGE-III (2X660 MW) EPC PACKAGE</p>	<p>TECHNICAL SPECIFICATIONS SECTION – VI, PART-B BID DOC. NO.:CS-4540-001A-2</p>	<p>SUB-SECTION-III-C-10 TYPE TEST REQUIREMENTS</p>	<p>PAGE 1 OF 8</p>	

CLAUSE NO.	TECHNICAL REQUIREMENTS	
-------------------	-------------------------------	---


3.00.00	TYPE TEST REQUIREMENT FOR OTHER C&I SYSTEMS					
	Sl. No	Item	Test Requirement	Standard	Test To Be Specifically Conducted	NTPC's Approval Req. On Test Certificate
	Col 1	Col 2	Col 3	Col 4	Col 5	Col 6
	1	Electronic transmitter	As per standard (col 4)	BS-6447 / IEC-60770	No	Yes
	2	Instrumentation Cables Twisted & Shielded*				
		-Conductor	Resistance test	VDE-0815	No	Yes
			Diameter test	IS-10810	No	Yes
			Tin Coating test (Persulphate test)	IS-8130	No	Yes
		-Insulation	Loss of mass	VDE 0472	No	Yes
			Ageing in air ovens**	VDE 0472	No	Yes
			Tensile strength and elongation test before and after ageing**	VDE 0472	No	Yes
			Heat shock	VDE 0472	No	Yes
			Hot deformation	VDE 0472	No	Yes
			Shrinkage	VDE 0472	No	Yes
			Bleeding & blooming	IS-10810	No	Yes
		-Inner sheath***	Loss of mass	VDE 0472	No	Yes
			Heat shock	VDE 0472	No	Yes
			Cold bend/ cold impact test	VDE 0472	No	Yes


TALCHER THERMAL POWER PROJECT STAGE-III (2X660 MW) EPC PACKAGE	TECHNICAL SPECIFICATIONS SECTION – VI, PART-B BID DOC. NO.:CS-4540-001A-2	SUB-SECTION-IIIC-10 TYPE TEST REQUIREMENTS	PAGE 4 OF 8
--	---	--	----------------


CLAUSE NO.	TECHNICAL REQUIREMENTS				
		Hot deformation	VDE 0472	No	Yes
		Shrinkage	VDE 0472	No	Yes
	-Outer sheath	Loss of mass	VDE 0472	No	Yes
		Ageing in air ovens**	VDE 0472	No	Yes
		Tensile strength and elongation test before and after ageing**	VDE 0472	No	Yes
		Heat shock	VDE 0472	No	Yes
		Hot deformation	VDE 0472	No	Yes
		Shrinkage	VDE 0472	No	Yes
		Bleeding & blooming	IS-10810	No	Yes
		Colour fastness to water	IS-5831	No	Yes
		Cold bend/ cold impact test	VDE-0472	No	Yes
		Oxygen index test	ASTMD-2863	No	Yes
		Smoke Density Test	ASTMD-2843	No	Yes
		Acid gas generation test	IEC-60754-1	No	Yes
	-fillers	Oxygen index test	ASTMD-2863	No	Yes
		Acid gas generation test	IEC-60754-1	No	Yes
	-AL-MYLAR shield	Continuity test		No	Yes
		Shield		No	Yes
TALCHER THERMAL POWER PROJECT STAGE-III (2X660 MW) EPC PACKAGE	TECHNICAL SPECIFICATIONS SECTION – VI, PART-B BID DOC. NO.:CS-4540-001A-2	SUB-SECTION-IIIC-10 TYPE TEST REQUIREMENTS	PAGE 5 OF 8		


CLAUSE NO.	TECHNICAL REQUIREMENTS				
	<p style="text-align: center;">thickness</p> <p style="text-align: center;">Overlap test</p> <p style="text-align: center;">-Over all cable</p> <p style="text-align: center;">Flammability Test</p> <p style="text-align: center;">Swedish Chimney Test</p> <p style="text-align: center;">Noise interference</p> <p style="text-align: center;">Dimensional checks</p> <p style="text-align: center;">Cross talk</p> <p style="text-align: center;">Mutual capacitance</p> <p style="text-align: center;">HV test</p> <p style="text-align: center;">Drain wire continuity</p>	<p style="text-align: center;">IEEE 383</p> <p style="text-align: center;">SEN 4241475</p> <p style="text-align: center;">IEEE Trans-actions</p> <p style="text-align: center;">IS 10810</p> <p style="text-align: center;">VDE-0472</p> <p style="text-align: center;">VDE-0472</p> <p style="text-align: center;">VDE-0815</p>	<p style="text-align: center;">No</p> <p style="text-align: center;">No</p> <p style="text-align: center;">No</p> <p style="text-align: center;">No</p> <p style="text-align: center;">No</p> <p style="text-align: center;">No</p> <p style="text-align: center;">No</p> <p style="text-align: center;">No</p> <p style="text-align: center;">No</p>	<p style="text-align: center;">Yes</p> <p style="text-align: center;">Yes</p> <p style="text-align: center;">Yes</p> <p style="text-align: center;">Yes</p> <p style="text-align: center;">Yes</p> <p style="text-align: center;">Yes</p> <p style="text-align: center;">Yes</p> <p style="text-align: center;">Yes</p>	<p>* 1.0 All cables to be supplied shall be of type tested quality. The Contractor shall submit for Owner's approval the reports of all the type tests as listed in this specification and carried out within last Ten years from the date of bid opening. These reports should be for the tests conducted on the equipment similar to those proposed to be supplied under this contract and the test(s) should have been either conducted at an independent laboratory or should have been witnessed by a client.</p> <p>2.0 In case the Contractor is not able to submit report of the type test(s) conducted within last Ten years from the date of bid opening, or in case the type test report(s) are not found to be meeting the specification requirements, the Contractor shall conduct all such tests either in an independent laboratory or at manufacturer's works in presence of Owner's representative under this contract free of cost to the Owner and submit the reports for approval.</p> <p>**These tests shall be carried out as per VDE0207 Part 6 & ASTM D-2116 for TEFLON insulated & outer sheathed cables</p> <p>***Applicable for armoured cables only</p> <p>3 DC Power Supply System (Applicable for each model and rating)</p> <p>1)The Type Test reports for offered rectifier module and the controller module irrespective of the rectifier bank shall be acceptable</p>
TALCHER THERMAL POWER PROJECT STAGE-III (2X660 MW) EPC PACKAGE	TECHNICAL SPECIFICATIONS SECTION – VI, PART-B BID DOC. NO.:CS-4540-001A-2	SUB-SECTION-IIIIC-10 TYPE TEST REQUIREMENTS	PAGE 6 OF 8		


CLAUSE NO.	TECHNICAL REQUIREMENTS			एनटीपीसी NTPC
		Surge Withstand Capability(SWC)	(ANSI / IEEE No C37.90.1)or (IEC-61000-4-4, IEC-61000-4-5 and IEC-61000-4-18).	Yes
		Dry Heat Test	IEC-60068-2-2 No or equivalent	Yes
		Damp Heat test	IEC-60068-2-30 No or IEC-60068-2-78 or equivalent	Yes
		Vibration test	IEC-60068-2-6 No or equivalent	Yes
		Electrostatic discharge test	IEC 61000-4-2 No or equivalent	Yes
		Radio frequency immunity test	IEC-61000-4-6 No or equivalent	Yes
		Electromagnetic field immunity	IEC 61000-4-3 No or equivalent	Yes
		Degree of Protection	IS-13947 or equivalent	Yes
4	Battery ##	As per standard (col 4)	IS-10918 (Ni-Cd Batteries) IS-1652 (Lead Acid Plant Batteries)	No No Yes
5	UPS (Applicable for each model and rating)	1) Type Test reports of same series of UPS with similar PCB's cards and controllers as the target UPS system shall be acceptable. 2) For Dry heat, Damp heat and vibration, the tests conducted on individual PCB's shall be acceptable.		Yes
		Surge Withstand Capability(SWC)	(ANSI / IEEE No C37.90.1)or (IEC-61000-4-4, IEC-61000-4-5 and IEC-61000-	Yes


CLAUSE NO.	TECHNICAL REQUIREMENTS				
		<p style="text-align: center;">4-18).</p> <p>Dry Heat Test</p> <p>Damp Heat test</p> <p>Vibration test</p> <p>Electrostatic discharge test</p> <p>Radio frequency immunity test</p> <p>Electromagnetic field immunity</p> <p>Degree of protection test</p> <p>Fuse Clearing Capability</p> <p>Short Circuit current capability</p>	<p>IEC-60068-2-2 or equivalent</p> <p>IEC-60068-2-30 or IEC-60068-2-78 or equivalent</p> <p>IEC-60068-2-6 or equivalent</p> <p>IEC 61000-4-2 or equivalent</p> <p>IEC-61000-4-6 or equivalent</p> <p>IEC 61000-4-3 or equivalent</p> <p>IS-13947</p> <p>Approved procedure</p> <p>IEC 60146-2</p>	<p>No</p> <p>No</p> <p>No</p> <p>No</p> <p>No</p> <p>No</p> <p>No</p> <p>No</p> <p>No</p>	<p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p> <p>Yes</p>
<p style="text-align: center;">6</p>	<p>Public Address System</p> <p>IP based PA system components</p>	<p>As per Standard</p> <p>IEC 60268-16</p>	<p>No</p>	<p>Yes</p>	
<p style="text-align: center;">7</p>	<p>Control Valves</p> <p>CV test</p>	<p>ISA 75.02& 75.11</p>	<p>No</p>	<p>Yes</p>	
	<p style="text-align: center;">8</p>	<p>Flow Nozzle Calibration</p> <p>Orifice plates</p>	<p>ASME PTC</p> <p>BS 1042</p>	<p>No</p> <p>Yes</p>	
<p>## The contractor shall submit for Employers approval the reports of all the type test as per latest IS-10918 carried out within last ten years from the date of Bid opening and the test(s) should have been either conducted at an independent laboratory or in presence of owner's representative. The complete type test reports shall be for any rating of Battery in a particular group based on plate dimensions being manufactured by supplier.</p>					
<p>Note:</p> <p>Type Tests are to be conducted only for the items, which are being supplied as a part of this Package.</p>					
<p>TALCHER THERMAL POWER PROJECT STAGE-III (2X660 MW) EPC PACKAGE</p>	<p>TECHNICAL SPECIFICATIONS SECTION – VI, PART-B BID DOC. NO.:CS-4540-001A-2</p>	<p>SUB-SECTION-IIIC-10 TYPE TEST REQUIREMENTS</p>	<p>PAGE 8 OF 8</p>		

CLAUSE NO.	GENERAL TECHNICAL REQUIREMENTS			
	<p>REFERENCE CODES AND STANDARDS FOR CONTROL AND INSTRUMENTATION</p> <p>The design, manufacture, inspection, testing & installation of all equipment and system covered under this specification shall conform to the latest editions of codes and standards mentioned below and all other applicable VDE, IEEE, ANSI, ASME, NEC, NEMA, ISA AND Indian Standards and their equivalents.</p> <p>Temperature Measurements</p> <ol style="list-style-type: none"> 1. Instrument and apparatus for temperature measurement - ASME PTC 19.3 (1974). 2. Temperature measurement - Thermocouples ANSI MC 96.1 - 1982. 3. Temperature measurement by electrical Resistance thermometers - IS:2806. 4. Thermometer - element - Platinum resistance - IS:2848. <p>Pressure Measurements</p> <ol style="list-style-type: none"> 1. a) Instruments and apparatus for pressure measurement - ASME PTC 19.2 (1964). <li style="padding-left: 2em;">b) Electronic transmitters BS:6447. 2. Bourdon tube pressure and vacuum gauges - IS:3624 - 1966. 3. Process operated switch devices (Pr. Switch) BS-6134. <p>Flow Measurements</p> <p>Instruments and apparatus for flow measurements - ASME PTC 19.5 (1972) Interim supplement, Part-II.</p> <p>Measurement of fluid flow in closed conduits - BS-1042.</p> <p>Electronic Measuring Instrument & Control Hardware/ Software</p> <ol style="list-style-type: none"> 1. Automatic null balancing electrical measuring instruments - ANSI C 39.4 (Rev. 1973): IS:9319. 2. Safety requirements for electrical and electronic measuring and controlling instrument - ANSI C 39.5 - 1974. 3. Compatibility of analog signals for electronic industrial process instruments - ISA - S 50.1 (1982) ANSI MC 12.1 - 1975. 4. Dynamic response testing of process control instrumentation ISA - S 26 (1968). 			
<p>TALCHER THERMAL POWER PROJECT STAGE-III (2X660 MW) EPC PACKAGE</p>	<p>TECHNICAL SPECIFICATIONS SECTION VI, PART-C BID DOC. NO.:CS-4540-001A-2</p>	<p>GENERAL TECHNICAL REQUIREMENTS</p>	<p>PAGE 98 OF 114</p>	


CLAUSE NO.	GENERAL TECHNICAL REQUIREMENTS			
	<ol style="list-style-type: none"> 5. Surge Withstand Capability (SWC) tests - ANSI C 37.90 a/IEEE-472 or suitable class of IEC-255-4 equivalent to ANSI C37.90a/IEEE-472. 6. Printed circuit boards - IPC TM - 650, IEC 326 C. 7. General requirement and tests for printed wiring boards - IS 7405 (Part-I) 1973. 8. Edge socket connectors - IEC 130-11. 9. Requirements and methods of testing of wire wrap terminations DIN 41611 Part-2. 10. Dimensions of attachment plugs & receptacles - ANSI C 73 - 1973 (Supplement ANSI C 73 a - 1980). 11. Direct acting electrical indicating instrument - IS:1248 - 1968 (R). 12. Standard Digital Interface for Programmable Instrumentation - IEEE-488.2 - 1990. 13. Information Processing Systems - Local Area Networks - Part 2 : Logical Link Control - IEEE-802.2 - 1989. 14. Standard for Local Area Networks : Carrier Sense Multiple Access with Collision Detection - IEEE-802.3 - 1985. 15. Supplements A, B, C and E to Carrier Sense Multiple Access with Collision Detection - IEEE-802.3 - 1988. 16. Standard for Local Area Networks : Token - Passing Bus Access Method - IEEE-802.4 - 1985. 17. Standard for Local Area Networks : Token - Ring Access Method and Physical Layer Specification - IEEE-802.5 - 1985. 18. IEEE Guide to Software Requirements Specifications - IEEE-830 - 1984. 19. Hardware Testing of Digital Process Computers - ISA RP55.1 - 1983. 20. Electromagnetic Susceptibility of Process Control Instrumentation - SAMA PMC 33.1 - 1978. 21. Interface Between the Data Terminal Equipment and Data Circuit - Terminating Equipment Employing Serial Binary Data Interchange - EIA-232-D-1987. 22. Electromagnetic Compatibility for Industrial Process Measurement and Control Equipment, Part 3 : Radiated Electromagnetic Field Requirements - IEC 801-3-1984. 			
<p style="text-align: center;">TALCHER THERMAL POWER PROJECT STAGE-III (2X660 MW) EPC PACKAGE</p>	<p style="text-align: center;">TECHNICAL SPECIFICATIONS SECTION VI, PART-C BID DOC. NO.:CS-4540-001A-2</p>	<p style="text-align: center;">GENERAL TECHNICAL REQUIREMENTS</p>	<p style="text-align: center;">PAGE 99 OF 114</p>	


CLAUSE NO.	GENERAL TECHNICAL REQUIREMENTS			
	<p>Instrument Switches and Contact</p> <ol style="list-style-type: none"> Contact rating - AC services NEMA ICS 2 - 1978 (with revision through May 1983), Part - 2-125, A6000. Contact rating - DC services NEMA ICS 2-1978 Part-2 125, N600. <p>Enclosures</p> <ol style="list-style-type: none"> Type of Enclosures - NEMA ICS Part - 6 - 1978 (with Rev. 1 4/80) through 110.22 (Type 4 to 13). Racks, panels and associated equipment - EIA : RS - 310 C- 1983 (ANSI C 83.9 - 1972). Protection class for Enclosures, cabinets, control panels & desks - IS:2147 - 1962. <p>Apparatus, enclosures and installation practices in hazardous area</p> <ol style="list-style-type: none"> Classification of hazardous area - NFPA 70 - 1984, Article 500. Electrical Instruments in hazardous dust location - ISA - 512.11, 1973. Intrinsically safe apparatus - NFPA 493 1978. Purged and pressurised enclosure for electrical equipment in hazardous location - NFPA 496-1982. Enclosures for Industrial Controls and Systems - NEMA IS 1.1 - 1977. <p>Sampling System</p> <ol style="list-style-type: none"> Stainless steel material of tubing and valves for sampling system - ASTM A 296-82, Grade 7 P 316. Submerged helical coil heat exchangers for sample coolers ASTM D11 92-1977. Water and steam in power cycle - ASME PTC 19.11. Standard methods of sampling system - ASTM D 1066-99. <p>Annunciators</p> <ol style="list-style-type: none"> Specifications and guides for the use of general purpose annunciators - ISA S 19.1, 1979. Surge withstand capability tests - ANSI C 37.90a - 1989/IEEE-472 or suitable class of IEC 255-4 equivalent to ANSI C37.90a 1989/IEEE-472 Damp heat cycling test - IS:2106 			
<p>TALCHER THERMAL POWER PROJECT STAGE-III (2X660 MW) EPC PACKAGE</p>	<p>TECHNICAL SPECIFICATIONS SECTION VI, PART-C BID DOC. NO.:CS-4540-001A-2</p>	<p>GENERAL TECHNICAL REQUIREMENTS</p>	<p>PAGE 100 OF 114</p>	


CLAUSE NO.	GENERAL TECHNICAL REQUIREMENTS			
	<p>4. Specification for Electromagnetic Susceptibility - SAMA DMC 33, 1/78</p> <p>Protections</p> <ol style="list-style-type: none"> 1. Relays and relay system associated with electric power apparatus. ANSI C 37.90, 1 - 1989. 2. General requirements & tests for switching devices for control and auxiliary circuits including contactor relays - IS:6875 (Part-I) - 1973. 3. Turbine water damage prevention - ASME TDP-1-1980. 4. Boiler safety interlocks - NFPA Section 85 B - 1984, 85 C - 1991. <p>UPS System</p> <ol style="list-style-type: none"> 1. Practices and requirements for semi-conductor power rectifiers - ANSI C 34.2, 1973. 2. Relays and relays system associated with electrical power apparatus - ANSI C 3.90 - 1983. 3. Surge withstand capability test - ANSI C 37.90 1 -1989. 4. Performance testing of UPS - IEC 146. 5. Stationary cells & Batteries Lead Acid type (with tubular positive plates) specification IS-1651-1991. 6. Recommended practice for sizing large lead storage batteries for generating stations & sub-stations - IEEE-485-1985. 7. Printed Circuit Board - IPC TM 650, IEC 326C. 8. General Requirements & tests for printed wiring boards, IS:7405 (Part-I) 1973. <p>Control Valves</p> <ol style="list-style-type: none"> 1. Control valve sizing - Compressible & Incompressible fluids - ISA S 75.01-1985. 2. Face to face dimensions of control valves - ANSI B 16.00 - 1973. 3. ISA Hand Book of Control Valves - (ISBN : B: 1047-087664-234-2). 4. Codes for pressure piping - ANSI B 31.1 5. Control Valve leak class - ISA RP 39.6 			
<p>TALCHER THERMAL POWER PROJECT STAGE-III (2X660 MW) EPC PACKAGE</p>	<p>TECHNICAL SPECIFICATIONS SECTION VI, PART-C BID DOC. NO.:CS-4540-001A-2</p>	<p>GENERAL TECHNICAL REQUIREMENTS</p>	<p>PAGE 101 OF 114</p>	


CLAUSE NO.	GENERAL TECHNICAL REQUIREMENTS			
	<p>Process Connection & Piping</p> <ol style="list-style-type: none"> 1. Codes for pressure piping "power piping" - ANSI B 31.1. 2. Seamless carbon steel pipe ASTM - A - 106. 3. Forged & Rolled Alloy steel pipe flanges, forged fittings and valves and parts - ASTM - A - 182. 4. Material for socket welded fittings - ASTM - A - 105. 5. Seamless ferritic alloy steep pipe - ASTM - A - 335. 6. Pipe fittings of wrought carbon steel and alloy steel - ASTM - A - 234. 7. Composition bronze of ounce metal castings - ASTM - B - 62. 8. Seamless Copper tube, bright annealed - ASTM - B - 168. 9. Seamless copper tube - ASTM - B - 75. 10. Dimension of fittings - ANSI - B - 16.11. 11. Valves flanged and butt welding ends - ANSI - B - 16.34. <p>Instrument Tubing</p> <ol style="list-style-type: none"> 1. Seamless carbon steel pipe - ASTM - A 106. 2. Material of socketweld fittings - ASTM - A105. 3. Dimensions of fittings - ANSI - B - 16.11. 4. Code for pressure piping, welding, hydrostatic testing - ANSI B 31.1. <p>Cables</p> <ol style="list-style-type: none"> 1. Thermocouples extension wires/cables - ANSI MC 96.1 - 1992. 2. Requirements for copper conductor-Wiring cables for telecommunications & information processing system - VDE:0815. 3. Colour coding of single or multi-pair cables - ICEA - S - 61-402 (third edition) NEMA WCS - 1979 with revisions through 2/83. 4. Insulation & Sheathing compounds for cables : VDE 0207 (Part-4, 5 & 6). 5. Guide design and installation of cable systems in power generating stations (insulation, jacket materials) - IEEE Std. 422-1977. 6. Rules for Testing insulated cables and flexible cables : VVDE - 0472 7. Requirements of vertical flame propagation test - IEEE 383 - 1974 (R 1980) 			
<p>TALCHER THERMAL POWER PROJECT STAGE-III (2X660 MW) EPC PACKAGE</p>	<p>TECHNICAL SPECIFICATIONS SECTION VI, PART-C BID DOC. NO.:CS-4540-001A-2</p>	<p>GENERAL TECHNICAL REQUIREMENTS</p>	<p>PAGE 102 OF 114</p>	


VFD


CLAUSE NO.	TECHNICAL REQUIREMENTS																											
1.00.0	<u>VFD</u>																											
2.00.00	GENERAL	<p>This chapter has to be read in conjunction with sub-section B-0 "General electrical specification" of Technical specification Section- VI, Part-B and Sub-Section-IIB Electrical system/Equipment of Technical Specifications Section-VI, Part-A.</p>																										
	CODES AND STANDARDS	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;">HT breaker</td> <td style="width: 40%;">IEC:60056</td> </tr> <tr> <td>DC reactor</td> <td>IEC 60289</td> </tr> <tr> <td>Transformers</td> <td>IS:2026, IEC:60076, IEC 61378</td> </tr> <tr> <td>Bushing</td> <td>IS: 2099, IEC 60137</td> </tr> <tr> <td>Adjustable Speed Electrical Power Drive Systems</td> <td>IEC 61800</td> </tr> <tr> <td>Semiconductor converters–General requirements</td> <td>IEC 60146</td> </tr> <tr> <td>IEEE Recommended practices and requirements for harmonic control in electrical power systems</td> <td>- IEEE 519</td> </tr> <tr> <td>Degrees of protection provided by enclosures (IP Code)</td> <td>IEC 60529</td> </tr> <tr> <td>Electrostatic immunity test</td> <td>IEC1000-4-2</td> </tr> <tr> <td>Fast transient immunity test</td> <td>IEC1000-4-4</td> </tr> <tr> <td>Surge immunity test</td> <td>IEC1000-4-5</td> </tr> <tr> <td>High-voltage switchgear and controlgear; Pt.102: Alternating current disconnectors and earthing switches</td> <td>IEC 62271-102</td> </tr> </table>		HT breaker	IEC:60056	DC reactor	IEC 60289	Transformers	IS:2026, IEC:60076, IEC 61378	Bushing	IS: 2099, IEC 60137	Adjustable Speed Electrical Power Drive Systems	IEC 61800	Semiconductor converters–General requirements	IEC 60146	IEEE Recommended practices and requirements for harmonic control in electrical power systems	- IEEE 519	Degrees of protection provided by enclosures (IP Code)	IEC 60529	Electrostatic immunity test	IEC1000-4-2	Fast transient immunity test	IEC1000-4-4	Surge immunity test	IEC1000-4-5	High-voltage switchgear and controlgear; Pt.102: Alternating current disconnectors and earthing switches	IEC 62271-102	
HT breaker	IEC:60056																											
DC reactor	IEC 60289																											
Transformers	IS:2026, IEC:60076, IEC 61378																											
Bushing	IS: 2099, IEC 60137																											
Adjustable Speed Electrical Power Drive Systems	IEC 61800																											
Semiconductor converters–General requirements	IEC 60146																											
IEEE Recommended practices and requirements for harmonic control in electrical power systems	- IEEE 519																											
Degrees of protection provided by enclosures (IP Code)	IEC 60529																											
Electrostatic immunity test	IEC1000-4-2																											
Fast transient immunity test	IEC1000-4-4																											
Surge immunity test	IEC1000-4-5																											
High-voltage switchgear and controlgear; Pt.102: Alternating current disconnectors and earthing switches	IEC 62271-102																											
TALCHER THERMAL POWER PROJECT STAGE-III (2X660 MW) EPC PACKAGE	TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC NO : CS-4540-001A-2	SUB-SECTION : B-03 VFD	PAGE 1 OF 11																									


CLAUSE NO.	TECHNICAL REQUIREMENTS																														
	<table border="1"> <tr> <td data-bbox="423 191 1040 373">High-voltage switchgear and controlgear; Pt.200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 KV IS/IEC: 62271-200</td> <td data-bbox="1040 191 1235 373"></td> <td data-bbox="1235 191 1313 373"></td> </tr> <tr> <td data-bbox="423 373 1040 457">AC electricity meters</td> <td data-bbox="1040 373 1235 457">IS: 722</td> <td data-bbox="1235 373 1313 457"></td> </tr> <tr> <td data-bbox="423 457 1040 541">Metal oxide surge arrester without gap for AC system</td> <td data-bbox="1040 457 1235 541">IEC: 60099-4</td> <td data-bbox="1235 457 1313 541"></td> </tr> <tr> <td data-bbox="423 541 1040 625">Terminal blocks for copper conductors</td> <td data-bbox="1040 541 1235 625">IEC: 60947-7-1</td> <td data-bbox="1235 541 1313 625"></td> </tr> <tr> <td data-bbox="423 625 1040 709">Dry transformer</td> <td data-bbox="1040 625 1235 709">IS: 11171</td> <td data-bbox="1235 625 1313 709"></td> </tr> <tr> <td data-bbox="423 709 1040 793">Motor</td> <td colspan="2" data-bbox="1040 709 1313 793">IS:15999, IEC-60034, IEC60034 / NEMA 30 & 31</td> </tr> <tr> <td data-bbox="423 793 1040 877">Contactor/Switches/Fuses etc.</td> <td data-bbox="1040 793 1235 877">IEC:60947, IS: 13947</td> <td data-bbox="1235 793 1313 877"></td> </tr> <tr> <td data-bbox="423 877 1040 961">Harmonics & EM compatibility</td> <td data-bbox="1040 877 1235 961">IEEE:519/IEC: 61000</td> <td data-bbox="1235 877 1313 961"></td> </tr> <tr> <td data-bbox="423 961 1040 1045">VFD</td> <td colspan="2" data-bbox="1040 961 1313 1045">IEC: 60034/ IEC: 61800</td> </tr> </table>			High-voltage switchgear and controlgear; Pt.200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 KV IS/IEC: 62271-200			AC electricity meters	IS: 722		Metal oxide surge arrester without gap for AC system	IEC: 60099-4		Terminal blocks for copper conductors	IEC: 60947-7-1		Dry transformer	IS: 11171		Motor	IS:15999, IEC-60034, IEC60034 / NEMA 30 & 31		Contactor/Switches/Fuses etc.	IEC:60947, IS: 13947		Harmonics & EM compatibility	IEEE:519/IEC: 61000		VFD	IEC: 60034/ IEC: 61800		
High-voltage switchgear and controlgear; Pt.200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 KV IS/IEC: 62271-200																															
AC electricity meters	IS: 722																														
Metal oxide surge arrester without gap for AC system	IEC: 60099-4																														
Terminal blocks for copper conductors	IEC: 60947-7-1																														
Dry transformer	IS: 11171																														
Motor	IS:15999, IEC-60034, IEC60034 / NEMA 30 & 31																														
Contactor/Switches/Fuses etc.	IEC:60947, IS: 13947																														
Harmonics & EM compatibility	IEEE:519/IEC: 61000																														
VFD	IEC: 60034/ IEC: 61800																														
3.00.00	OPERATING CONDITIONS																														
3.01.00	For the purpose of design of equipment/systems, an ambient temperature of 50 deg. Centigrade and also relative humidity of 95% at 40 deg. Celsius shall be considered.																														
3.02.00	All equipment shall be suitable for rated frequency of 50 Hz with a variation of +3% & -5%, and 10% combined variation of voltage and frequency unless specifically brought out in the specification.																														
3.03.00	<p>The voltage level for the VFD output to be fed to motor shall be as follows:-</p> <ol style="list-style-type: none"> 1. Upto 400 kW : 415V/690V, Low Voltage, Three Phase AC 2. Above 400kW and upto 700 KW : 690V, Low Voltage, Three Phase AC 3. Above 700KW : Medium Voltage <p>From here onwards in the specifications all the VFD Systems consisting of either 415 V or 690 V may be termed as LV VFD while the higher rated VFD System shall be termed as MV VFD. If nothing is mentioned than the Clause is applicable for both the LV and the MV VFD until deliberated otherwise.</p>																														
<p style="text-align: center;">TALCHER THERMAL POWER PROJECT STAGE-III (2X660 MW) EPC PACKAGE</p>	<p style="text-align: center;">TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC NO : CS-4540-001A-2</p>	<p style="text-align: center;">SUB-SECTION : B-03 VFD</p>	<p style="text-align: center;">PAGE 2 OF 11</p>																												


CLAUSE NO.	TECHNICAL REQUIREMENTS			
4.00.00	SYSTEM DESCRIPTION			
	Type of drive	3-Phase Diode / Thyristor / Multi Stage IGBT / IGCT / SGCT/ IEGT		
	Type of Cooling of VFD	Naturally air cooled/forced air cooled/Liquid cooled		
	Converter Type	Full wave diode rectifier/active front end type		
	Inverter Type	Thyristor/IGBT/IGCT/SGCT/IEGT		
5.00.00	GENERAL REQUIREMENTS			
5.01.00	Medium Voltage VFD: The Variable frequency drive (VFD) system shall be of a modern proven design for similar applications in power plants/industry. The system shall be either Current Source Inverter (CSI) or Voltage Source Inverter (VSI) type with minimum eighteen (18) pulse design.			
5.02.00	415 V/690 V LV VFD: The Variable frequency drive (VFD) system shall be of a modern proven design for similar applications in power plants/industry. The system shall be either Current Source Inverter (CSI) or Voltage Source Inverter (VSI) type with minimum Twelve (12) pulse design / 6 pulse with active front end harmonic filter. For drives less than 100 KW Six (6) pulse can be offered meeting all other requirements.			
5.04.00	The offered equipment shall be with state of art technology and proven field track record. No prototype equipment shall be offered.			
5.05.00	The VFD manufacturer shall ensure the proper coordination of their VFD with the Driven Motor and the supply system. The VFD operation shall have no inherent detrimental impact on the Motors/ cables & supply system.			
6.00.00	TECHNICAL AND OPERATIONAL REQUIREMENTS			
6.01.00	The system shall be designed to deliver the motor input current and torque for the complete speed torque characteristics of the driven equipment, with worst input supply voltage and frequency variation. The system shall be suitable for the load characteristics and the operational duty of the driven equipment.			
6.02.00	The overload capacity of the controller shall be 150% of the rated current of the motor for one minute for constant torque applications and 110% of rated current for one minute for variable torque applications at rated voltage. If the motor load exceeds the limit, the drive shall automatically reduce the frequency and voltage to the motor to guard against overload.			
6.03.00	The drive system shall be designed to operate in one or more of the following operating modes as to suit characteristics of the driven equipment or specified by the load: <ul style="list-style-type: none"> a. Variable torque changing as a function of speed. b. Constant torque over a specific speed range. c. Constant power over a specific speed range. 			
TALCHER THERMAL POWER PROJECT STAGE-III (2X660 MW) EPC PACKAGE		TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC NO : CS-4540-001A-2	SUB-SECTION : B-03 VFD	PAGE 3 OF 11


CLAUSE NO.	TECHNICAL REQUIREMENTS			
	d. Any other as specified in data-sheet			
6.04.00	VFDs shall comply with the latest edition of IEEE 519 & IEC 61000 for both individual as well as total harmonic voltage and current distortion limits. The Voltage and Current limits shall be applicable at the Point of Common Coupling (PCC), which shall be the MCC/ Switchgear/ from which the VFD system is fed.			
6.05.00	The above compliance shall be verified by the field measurements of harmonics at the PCC with and without VFDs operation.			
6.06.00	VFD shall be capable of withstanding the thermal and dynamic stresses and the transient mechanical torque, resulting from short circuit. Any damage resulting from such a short circuit or internal fault shall be limited to the component concerned.			
6.07.00	The system shall be suitable to maintain speed variation within range 10-110% or as per the requirement of driven equipment with speed set accuracy of +1% of rated maximum speed and steady state regulation of +0.5% of rated speed as per system requirement.			
6.08.00	The VFD System shall maintain a power factor of 0.95 (minimum) (for LV VFD system) and 0.9 (minimum) (for MV VFD system) in the entire operating range.			
6.09.00	Maximum allowable audible noise from the VFD system will be 85 dB (A) at a distance of one meter under rated loaded with all cooling fan operating conditions.			
6.10.00	All the circuit components shall be suitably protected against over voltages, surges, lightning etc.			
6.11.00	The panels shall be designed to provide easy access to hardware, to facilitate replacement of cards in case of any failure.			
6.12.00	All the VFDs for particular application shall be of same design so as to ensure 100 % interchangeability of components.			
6.13.00	For each programmed warning and fault protection function, the VFD shall display a message in complete English words or Standard English abbreviations. At least 30 time tagged fault messages shall be stored in the drive's fault history.			
6.14.00	The VFD cubicles shall be placed in air conditioned environment. However if VFDs of less than 100 kW are designed to operate in non-air condition environment the same shall also be acceptable.			
6.15.00	The 3-Phase Thyristor/IGCT/SGCT/ multistage IGBT/IEGT based VFD system shall have minimum number of components to ensure very high reliability. The input side converter shall have 3-Phase Diode/Thyristor bridge configuration modular type and inverter shall be of 3-Phase Thyristor/IGCT/SGCT/multi stage IGBT/IEGT type, using Pulse Width Modulation or better technique for generating near sine wave output to motor.			
6.16.00	Fiber optic cable connection shall be provided preferably to ensure high network reliability.			
7.00.00	VFD COMPATIBILITY WITH THE MOTOR			
7.01.00	MV VFD output current waveform, as measured at the motor, shall be inherently sinusoidal at nominal loads, with a total harmonic current and voltage distortion within acceptable/standard limits. VFD with transformers on output side are not acceptable.			
TALCHER THERMAL POWER PROJECT STAGE-III (2X660 MW) EPC PACKAGE	TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC NO : CS-4540-001A-2		SUB-SECTION : B-03 VFD	PAGE 4 OF 11


CLAUSE NO.	TECHNICAL REQUIREMENTS			
7.02.00	The system design shall not have any inherent output harmonic resonance in the operating speed range.			
7.03.00	VFD shall provide stable operation of motor from high-voltage dv/dt stress, regardless of cable length to motor. The vendor shall clearly state the limitations in the motor cable distance in his proposal. However, due to system requirements & constraints if the cable length becomes critical, filters/ chokes etc. shall be provided by the VFD manufacturers as an integral part of the VFD to mitigate the reflected wave effect of harmonics.			
8.00.00	BYPASS ARRANGEMENT (OPTIONAL, IF SPECIFIED)			
8.01.00	The VFD System shall have an optional feature to run the motor under bypass arrangement for operation of Motor with VFD bypassed. During starting (under rated conditions) the motor will be switched on in VFD Mode to limit the starting current and after gaining speed, the load would be switched over to bypass mode.			
8.02.00	Comprehensive motor protection scheme for protection and control for operation VFD during bypass mode shall be finalized during detailed engineering.			
9.00.00	STANDBY VFD ARRANGEMENT (OPTIONAL, IF SPECIFIED)			
9.01.00	A Common standby arrangement with auto/manual switchover shall be provided in case of failure of any VFD in a group of drives. Complete protection, interlocks & control required shall be provided in the changeover module.			
10.00.00	EFFICIENCY			
10.01.00	Efficiency (Drive only) shall be minimum 98% for both MV VFD and LV VFD. Overall efficiency (Includes the transformer if applicable) shall be minimum 96.5% for LV VFD and minimum 95 % for MV VFD at rated load and speed. Overall Efficiency evaluation shall include input transformer, harmonic filters and power factor correction (if applicable), VFD converters, cooling fans and output filter, as applicable in the system. Auxiliary controls, such as internal VFD control boards, cooling fans/pumps.			
10.02.00	In absence of valid test report, a factory test shall be performed at the VFD manufacturer's facility verifying the efficiencies. Manufactures who are supplying Drive and transformer from different locations, efficiency test will be conducted separately for Drive and transformer.			
11.00.00	COOLING SYSTEM			
11.01.00	VFD manufacturer to primarily offer Air cooled Design. However in case of large ratings, liquid cooled drives may be accepted subject to employer's approval. In case of liquid cooled system, there shall be no necessity of continuous water supply system (Closed Loop System).			
11.2.00	In case of Air cooled design, the VFD Cooling system shall be such that it puts minimum heat load inside the room and preferably throw the hot air outside the room with ventilation ducts. The Cooling system shall be designed in such a way that the Air Conditioning & Ventilation Air requirements are kept to minimum. The VFD Manufacturer shall furnish the data regarding heat load, air flow requirements during the detailed engineering.			
11.03.00	Air cooled VFDs shall be provided with cooling fans mounted integral to the VFD/ enclosure. The VFD shall include air-flow pressure switches and temperature detectors to monitor proper operation of the air cooling system. If the fan fails, the system must generate the alarm/trip for the fan failure.			
TALCHER THERMAL POWER PROJECT STAGE-III (2X660 MW) EPC PACKAGE	TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC NO : CS-4540-001A-2	SUB-SECTION : B-03 VFD	PAGE 5 OF 11	


CLAUSE NO.	TECHNICAL REQUIREMENTS		
12.00.00	TRANSFORMER:		
12.01.00	Type: Outdoor Mineral oil filled ONAN type or Indoor air-cooled Dry type, Three phase unit, rectifier/converter duty type transformer.		
12.02.00	All other components, technical parameters shall be as per applicable IEC/IS.		
12.03.00	Enclosure for Dry Type Transformer (as applicable) Enclosure shall be of a tested quality sheet steel of minimum thickness 2 mm & shall also accommodate cable terminations. The housing door shall be interlocked such that it should be possible to open the door only when transformer is off. The enclosure shall be provided with lifting lugs and other hardware for floor mounting.		
12.04.00	Core	Shall be High grade non-ageing cold rolled grain oriented silicon steel Laminations.	
12.05.00	Winding conductor	Shall be electrolytic grade copper. Windings shall be of class F insulation or better.	
12.06.00	Winding temperature Indicator (WTI)	Shall be Platinum resistance type temperature detector in each limb.	
12.07.00	Thermistors	Shall be embedded in each limb with alarm and trip contacts for remote annunciation.	
12.08.00	Temperature rise:	For dry type transformer the winding temperature rise shall be 95 Deg. C for Class-H insulation or 70 Deg.C for Class – F Insulation.	
13.00.00	POWER CONVERTER:		
13.01.00	The static power converter shall consist of a line side converter for operation as a rectifier and a load side power converter for operation as a fully controller inverter. Power converter shall be fast switching, most efficient and low loss type.		
13.02.00	The converter shall be coordinated with the transformers. The converter shall be able to withstand a three phase short circuit current until interrupted by normal breaker operation.		
13.03.00	Adequate short circuit and over voltage protection shall be provided for the converter and inverter system.		
13.04.00	All power converter devices shall include protective devices, snubber networks and dv/dt networks as required.		
13.05.00	The current rating of the converter's semi-conductor components shall not be less than 120% of the nominal current flowing through the elements at full load of the VFD through the whole speed range. If the parallel connection of semiconductor is applied, the above current rating shall not be less than 140% of the above values.		
13.06.00	All power diodes shall be of silicon type with minimum VBO rating at 2.5 times the rated operating voltage.		
13.07.00	The power converter circuit shall be designed so that motor can be powered at its full nameplate rating continuously without exceeding its rated temperature rise nor reducing its service factor due to harmonic currents generated by the inverter operation. The conversion		
TALCHER THERMAL POWER PROJECT STAGE-III (2X660 MW) EPC PACKAGE	TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC NO : CS-4540-001A-2	SUB-SECTION : B-03 VFD	PAGE 6 OF 11

CLAUSE NO.	<p style="text-align: center;">TECHNICAL REQUIREMENTS</p>		
	<p>devices and associated heat sinks shall be assembled such that individual devices can be replaced without requiring the use of any special precautions / tools.</p>		
13.08.00	<p>The cooling system of the electronic components, if provided, shall be monitored and necessary alarms shall be provided to prevent any consequential damage to the power control devices.</p>		
14.00.00	<p>OUTPUT FILTER (AS APPLICABLE):</p>		
14.01.00	<p>Output/ dv/dt filter shall be provided, if required. It shall be an integral part of the VFD system and included within the VFD enclosure. It shall inherently protect motor from high voltage dv/dt stress.</p>		
15.00.00	<p>DC LINK CAPACITOR (AS APPLICABLE):</p>		
15.01.00	<p>Capacitor shall be of self-healing film or electrolytic type having high life time. The capacitor shall be an integral part of VFD system. DC link Capacitors shall have discharge resistors which shall be capable of reducing the residual charges to zero just after the capacitor is disconnected from the supply source. The capacitor shall be suitable for high ripple currents.</p>		
16.00.00	<p>AC/DC Reactor (As applicable)</p> <ol style="list-style-type: none"> 1) Type: Dry type, air cored, self cooled, indoor type. Suitable for withstanding earth fault continuously. 2) Insulation: Thermal Class 155(F), temperature rise is limited to thermal class 130 (B). 3) Noise level shall not exceed value specified in NEMA TR-1. 		
17.00.00	<p>VFD PANEL REQUIREMENTS</p>		
17.01.00	<p>Enclosure frames and load bearing members shall be as per the Chapter B-05 and B06</p>		
17.02.00	<p>The cable entry shall be from the bottom of the panel and a removable bolted un-drilled gland plate.</p>		
17.03.00	<p>All Panels shall be of dust-proof and vermin-proof construction and shall be provided with a degree of protection of IP: 3X or better for MV VFD and IP: 4X or better for LV VFD as per IS/IEC 60947</p>		
17.04.00	<p>Enclosures must be designed to avoid harmonic and inductive heating effects and to shield any outside equipment from interference, enclosing and shielding the complete to eliminate any radio frequency interference. The construction of the panel shall provide effective protection against electromagnetic emissions.</p>		
17.05.00	<p>Each panel shall be provided with illuminating lamp, space heater with switch fuse and variable setting thermostat.</p>		
17.06.00	<p>Proper ventilation using air filters and fans/pumps shall be provided in the panels to ensure that maximum temperature inside the cubicle is within permissible limits for reliable and continuous operation of the system.</p>		
18.00.00	<p>NOT USED</p>		
19.00.00	<p>HT SWITCHGEAR</p>		
19.01.00	<p>The technical requirements of HT switchgear shall be as per chapter of HT switchgear in Part-B of Technical specifications.</p>		
<p style="text-align: center;">TALCHER THERMAL POWER PROJECT STAGE-III (2X660 MW) EPC PACKAGE</p>	<p style="text-align: center;">TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC NO : CS-4540-001A-2</p>	<p style="text-align: center;">SUB-SECTION : B-03 VFD</p>	<p style="text-align: center;">PAGE 7 OF 11</p>

CLAUSE NO.	TECHNICAL REQUIREMENTS			
20.00.00	MOTORS			
20.01.00	VFD shall be used to drive three (3) phase squirrel cage inverter duty Induction motor with VPI insulation (Resin poor) suitable for VFD application. These motors shall be provided with insulated bearing on at least one side for motor frame size above 250 frame. However, contractor's proven practice with respect to use of insulated bearing in VFD driven motor may be accepted subject to Employer's approval.			
20.02.00	Motors shall also meet the requirements mentioned in subsection for motors, relevant portions of the specifications for driven equipment and relevant IS/IEC.			
20.03.00	Motor shall be suitable for operation with a solid state power supply consisting of an adjustable frequency inverter for speed control & shall be suitable for the current waveforms produced by the power supply including the harmonics generated by the drive.			
20.04.00	Motor insulation shall be designed to accept the applied voltage waveform, within the Vpeak and dv/dt limits as per IEC-61800.			
20.05.00	Drive manufacturer shall coordinate with the motor manufacturer for proper selection of the motor for the given load application and the output characteristics of the drive.			
20.06.00	Other requirements of motor shall be as stipulated in technical chapter of Motors and driven equipment in Part-B of technical specifications.			
21.00.00	LT & HT CABLES			
21.01.00	Contractor's scope shall also include LT and HT cables suitable for VFD system and Motors.			
22.00.00	CONTROL AND PERFORMANCE REQUIREMENTS			
22.01.00	The VFD to provide an automatic current limiting feature to control motor currents during startup and provide a "soft start" torque profile for the motor load combination. Current and torque limit adjustments shall be provided to limit the maximum VFD output current and the maximum torque produced by the motor.			
22.02.00	It shall be possible to vary the speed of the drive and control it in either Local or Remote mode. Local / Remote selection shall be done from VFD panel unless otherwise specified.			
22.03.00	<p>Provision shall be kept for exchange of information between different VFD control system parameters thru PLC/DDCMIS.</p> <p>Man machine interface for (MV) VFD shall have one flat TFT monitor with keyboard (password protected) in the VFD room and a color laser printer for system alarm and monitoring located in control room.</p> <p>Parameter Monitoring:</p> <ul style="list-style-type: none"> -Input and output voltage of Drive - Input and output current of Drive - Motor speed - Input and output power frequency of Drive - Torque <ul style="list-style-type: none"> -Input and Output power of Drive system (covering transformer if applicable) - Output kWhr of Drive - Transformer (if applicable) temperature for alarm & trip. <ul style="list-style-type: none"> - Ambient temperature - Run/stop and local/remote status displayed 			
<p style="text-align: center;">TALCHER THERMAL POWER PROJECT STAGE-III (2X660 MW) EPC PACKAGE</p>	<p style="text-align: center;">TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC NO : CS-4540-001A-2</p>	<p style="text-align: center;">SUB-SECTION : B-03 VFD</p>	<p style="text-align: center;">PAGE 8 OF 11</p>	

CLAUSE NO.	TECHNICAL REQUIREMENTS			
22.04.00	Drive shall be equipped with a front mounted operator console panel consisting of a backlit alphanumeric display and a keypad with keys for parameterization and adjusting parameter. Control panel shall be operable with password for changing the protection setting, safety interlock etc.			
22.05.00	Operator console/Main Control Card shall have facility / port to connect external hardware such as Lap-Top etc. Console shall have facility for upload and download of all parameter settings from one drive to another drive for start up and operation.			
22.06.00	User-friendly licensed software for operation and fault diagnostic shall be loaded in the drive system panel before commissioning.			
23.00.00	PROTECTION FEATURES			
23.01.00	<p>The system offered shall incorporate adequate protection features as per IEC 61800-4: 2002 Table-8, properly coordinated for the drive control and for motor including following:</p> <ul style="list-style-type: none"> i) Converter transformer: short circuit, over current, earth fault & winding temperature high protection. ii) Incoming and outgoing line surge protection. iii) Under / over voltage protection iv) Phase loss, phase reversal, overload, negative phase sequence, locked rotor protection. v) Instantaneous Over current & Earth fault protection vi) Converter/Inverter module failure indication. vii) Over frequency/speed protection. viii) Ventilation failure indication & alarm. ix) Over temperature of VFD x) Bearing temperature protection. xi) System earth fault protection. xii) Speed reference loss protection. 			
23.02.00	Under VFD Bypass Mode (if applicable) all the electrical protections related to the Motor shall remain applicable.			
24.00.00	CONTROL FEATURES			
24.01.00	<p>Following controls shall be provided as a part of the Operator Control Panel or through separate switches on the front panel door.</p> <ul style="list-style-type: none"> i) Start / stop (in local/remote mode) ii) Speed control (Raise / lower) 			
TALCHER THERMAL POWER PROJECT STAGE-III (2X660 MW) EPC PACKAGE		TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC NO : CS-4540-001A-2	SUB-SECTION : B-03 VFD	PAGE 9 OF 11

CLAUSE NO.	TECHNICAL REQUIREMENTS			
	iii) Acknowledge/Accept/ Test Push Button for annunciation iv) Auto / Manual / Test Mode select v) Emergency stop vi) Trip-Remote Breaker			
25.00.00	DIAGNOSTIC FEATURES			
25.01.00	The VFD shall include a microprocessor/PLC based digital diagnostic system which monitors its own control functions and displays faults and operating conditions.			
25.02.00	Fault diagnostic shall be built into the system to supervise the operation and failure of the system. The information regarding failure of any of the system including shut down of the system shall be available. It shall be possible to retrieve the record of events prior to tripping of the system or de-energization. Auxiliary supply to the system components or to the electronics (firmware) for the diagnostics / display shall be taken care of by the manufacturer for this purpose.			
26.00.00	SERVICEABILITY / MAINTAINABILITY			
26.01.00	Power Component Accessibility: All power components in the converter sections shall be designed for rack-out accessibility for ease of maintenance and to minimize repair downtime.			
26.02.00	Marking / Labeling: Sleeve type wire marker tags or other acceptable means of permanent identification shall be applied to power and control wiring. Individual labels shall be provided for all major components of the VFD system.			
27.00.00	NOT USED			
28.00.00	TESTS			
28.01.00	ROUTINE TESTS			
	All acceptance and routine tests as envisaged in QA section shall be carried out. Charges for these shall be deemed to be included in the equipment price.			
28.02.00	TYPE TESTS			
	LIST OF TYPE TESTS TO BE CONDUCTED			
	The following type tests shall be conducted under this contract for MV VFD			
	i) Overall efficiency determination of VFD system including transformer/ Harmonic filters etc at motor full load ii) Temperature rise test iii) Noise level iv) Harmonics of No load current.(Input/Output)			
	LIST OF TESTS FOR WHICH REPORTS HAVE TO BE SUBMITTED			
	The following type test reports shall be submitted for VFD Panels'			
TALCHER THERMAL POWER PROJECT STAGE-III (2X660 MW) EPC PACKAGE	TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC NO : CS-4540-001A-2	SUB-SECTION : B-03 VFD	PAGE 10 OF 11	

CLAUSE NO.	TECHNICAL REQUIREMENTS			
	<p>1) VFD panels (For LV VFD used with load >= 50 KW)</p> <ul style="list-style-type: none"> i. Rated Current/ Output ii. Temperature rise test iii. Noise level test iv. Power Loss Determination Test v. Power factor measurement. vi. Degree of Protection Test vii. EMC Test viii. The Fast transient SWC tests as per ANSI / IEEE C37.901-2002 / IEC 60255-22-04-2008 / IEC 61800 <p>2) VFD panels (For MV VFD)</p> <ul style="list-style-type: none"> i. Rated Current/ Output ii. Current Sharing iii. Voltage Division iv. Power Loss Determination Test v. Power factor measurement. vi. Degree of Protection Test vii. The Fast transient SWC tests as per ANSI / IEEE C37.901-2002 / IEC 60255-22-04-2008 / IEC 61800 <p>3) AC/DC Reactor</p> <ul style="list-style-type: none"> i. Lightning impulse test(If applicable) ii. Heat run test iii. Short time current test(If applicable) iv. Noise level test <p>4) Transformers (for Non Integrated type)</p> <ul style="list-style-type: none"> i. As per requirements mentioned in subsection for Transformer chapter in technical specifications. 			
<p>TALCHER THERMAL POWER PROJECT STAGE-III (2X660 MW) EPC PACKAGE</p>	<p>TECHNICAL SPECIFICATION SECTION – VI, PART-B BID DOC NO : CS-4540-001A-2</p>	<p>SUB-SECTION : B-03 VFD</p>	<p>PAGE 11 OF 11</p>	

QUALITY ASSURANCE PLAN
FOR VFD

VFD MODULE

ATTRIBUTES / CHARACTERISTICS	Visual & Dimensional checks	Make / Type / Rating etc.	Final Inspection as ISS / IEC	Remarks
ITEMS/COMPONENTS, SUB SYSTEM ASSEMBLY				
HT Breaker (IEC 56)	Y	Y	Y	
DC Reactor	Y	Y		
Transformer	Y	Y		For details refer table for LT Indoor Transformer & Auxiliary Transformer
Motor	Y	Y		For details refer separate table for Motor
VFD Panel	Y	Y		For details refer table for VFD Panel

Note : 1) This is an indicative list of tests/checks. The manufacture is to furnish a detailed Quality Plan indicating the practices & Procedure followed alongwith relevant supporting documents during QP finalisation.
 2) Make of all major Bought Out Items will be subject to NTPC approval.

VFD PANEL

Attributes Characteristics Item Components Sub System Assembly	Electrical Properties	Mechanical Properties	Chemical Properties	Dimensions / Finish	Type/ Rating/Functional check	HV/IR	Routine test as per relevant std.	Constructional Features	IS:6005 ,Seven tank process	Paint finish/ shade/thickness	Mountings / BOM/ Make, Completeness	Interlock Functional & Operation Testing / Simulation check	Degree of Protection Test	Final testing as per Relevant IS/IEC
Sheet Steel (IS-513)		Y	Y	Y										
Aluminum / Copper Bus-bar(IS-5082/IS-613/IS-1987)	Y	Y	Y	Y										
Support Insulator (BS-2782/IEC-660/IS-10912)	Y	Y	Y	Y										
Control / Selector Switch(IS-6875)					Y	Y	Y							
Contactora/ MCB(IS-13947)					Y	Y	Y							
O/L Protection relays(IS-3231)					Y		Y							
C.T /V.T/ Indicating Meter(IS-2705/3156/1248)					Y	Y	Y							
Fuse/ Fuse carrier(IS-13703)					Y	Y	Y							
Terminals/lugs/pvc wires(IS-13947//IS-694)	Y			Y	Y	Y	Y							
Timers(IS-3231)					Y	Y	Y							
Push Button/ Lamp/ (IS-6875)					Y	Y	Y							
Control Transformer (IS-12021)					Y	Y	Y							
Mimic, Annunciater					Y		Y							
GASKET(IS-11149)		Y	Y	Y	Y		Y							
Fabrication								Y						
Pretreatment & Painting									Y	Y				
VFD panel										Y	Y	Y	Y	Y

NOTE:

1. This is an indicative list of Test/ Checks. The manufacturer to furnish a detailed Quality Plan indicating the practice and procedure along with relevant supporting documents.
2. All major Bought Out Items will be subject to NTPC approval.



TITLE

**2X660 MW TALCHAR TPP STAGE-III
MILL REJECT SYSTEM (CONVEYOR TYPE)
STANDARD TECHNICAL REQUIREMENTS**

SPECIFICATION NO. PE-TS-497-160-A101

SECTION: III

REV 00

Sub-Section

Date APR 2023

Page 1 of 1

SECTION – III

DOCUMENTS TO BE SUBMITTED ALONG WITH THE BID



TITLE

**2X660 MW TALCHAR TPP STAGE-III
MILL REJECT SYSTEM (CONVEYOR TYPE)
STANDARD TECHNICAL REQUIREMENTS**

SPECIFICATION NO. PE-TS-497-160-A101

SECTION: III

REV 00

Sub-Section

Date APR 2023

Page 1 of 1

DRAWINGS/ DOCUMENTS TO BE SUBMITTED WITH THE BID

Bidder shall submit the following drawings/documents along with their bid:

- a) Pre qualification requirement (PQR) documents
- b) Signed and stamped copy of Compliance cum Confirmation Certificate
- c) **Deviation schedule** with reference to specific clauses of the specification along with reason for such deviation in the “Cost of Withdrawal” format attached in the GCC.
- d) Signed and stamped copy of Utility requirement sheet of Vol-III.
- e) Un-priced copy of price format indicating quoted/ not quoted against each row / column.
- f) Guaranteed Power Consumption Format (shall be submitted in open along with techno commercial offer only)

OFFER WILL BE CONSIDERED AS INCOMPLETE IN ABSENCE OF ANY OF ABOVE DOCUMENTS.

DOCUMENT OTHER THAN ABOVE, IF ANY, SUBMITTED WITH THE OFFER WILL NOT FORM PART OF CONTRACT AND ACCORDINGLY WILL NOT BE CONSIDERED FOR BID EVALUATION.



TITLE 2X660 MW TALCHAR TPP STAGE-III MILL REJECT SYSTEM (CONVEYOR TYPE) STANDARD TECHNICAL REQUIREMENTS	SPECIFICATION NO. PE-TS-497-160-A101	
	SECTION: III	
	REV 00	
	Sub-Section	Date APR 2023
Page 1 of 1		

COMPLIANCE CUM CONFIRMATION CERTIFICATE

The bidder shall confirm compliance with following by signing/ stamping this compliance certificates (every sheet) and furnishes same with the offer.

- a) The scope of supply, technical details, construction features, design parameters etc. shall be as per technical specification & there are no exclusions, other than those resolved as per 'Schedule of Deviations', with regard to same.
- b) There are no other deviations w.r.t. specifications other than those furnished in the 'Schedule of Deviations'. Any other deviation, stated or implied, taken elsewhere in the offer stands withdrawn unless specifically brought out in the 'Schedule of Deviations'
- c) Bidder shall submit QP in the event of order based on the guidelines given in the specification & QP enclosed therein. QP will be subject to BHEL/ CUSTOMER approval & customer hold points for inspection / testing shall be marked in the QP at the contract stage. Inspection/ testing shall be witnessed as per same apart from review of various test certificates / Inspection records etc. This is within the contracted price with extra implications to BHEL after award of the contract.
- d) All drawings / data-sheets / calculations etc. submitted along with the offer shall be considered for reference only, same shall be subject to BHEL/ CUSTOMER approval in the event of order.
- e) The offered materials shall be either equivalent or superior to those specified in the specification & shall meet the specified / intended duty requirements. In case the material specified in the specifications is not compatible for intended duty requirements then same shall be resolved by the bidder with BHEL during the pre-bid discussions, otherwise BHEL/ Customer's decision shall be binding on the bidder whenever the deficiency is pointed out.

For components where materials are not specified, same shall be suitable for intended duty, all materials shall be subject to approval in the event of order.
- f) The commissioning spares shall be supplied on 'As Required Basis' & prices for same included in the base price itself. Prices for special tools & tackles, if any, shall also be included in the base price.
- g) All sub vendors shall be subject to BHEL/ CUSTOMER approval in the event of order.
- h) Guarantee for plant /equipment shall be as per relevant clause of GCC /SCC /Other Commercial Terms & Conditions.
- i) In the event of order, all the material required for completing the job at site shall be supplied by the bidder within the ordered price even if the same are additional to approved billing break up, approved drawing or approved Bill of quantities. This clause will apply in case during site commissioning additional requirements emerges due to customer and / or consultant's comments. No extra claims shall be put on this account.
- j) Schedule of drawings submissions, comment incorporations & approval shall be as stipulated in the specifications. The successful bidder shall depute his design personnel to



TITLE
2X660 MW TALCHAR TPP STAGE-III
MILL REJECT SYSTEM (CONVEYOR TYPE)
STANDARD TECHNICAL REQUIREMENTS

SPECIFICATION NO. PE-TS-497-160-A101
SECTION: III
REV 00
Sub-Section | **Date** APR 2023
Page 1 of 1

BHEL's/ Customer's/ Consultant's office for across the table resolution of issues and to get documents approved in the stipulated time.

- k) As built drawings shall be submitted as and when required during the project execution.
- l) That the bidder has not tempered with this compliance cum confirmation certificate and if at any stage any tempering in the signed copy of this document is noticed then same shall be treated as breach of contract and suitable actions shall be taken against the bidder.



TITLE
2X660 MW TALCHAR TPP STAGE-III
MILL REJECT SYSTEM (CONVEYOR TYPE)
STANDARD TECHNICAL REQUIREMENTS

SPECIFICATION NO. PE-TS-497-160-A101
SECTION: III
REV 00
Sub-Section _____ Date APR 2023
Page 1 of 1

PRE-BID CLARIFICATION SCHEDULE

S. No.	Section/Clause /Page No.	Statement of the referred clause	Clarification Required

The bidder hereby certifies that above mentioned are the only clarifications required on the technical specification for the subject package.

SIGNATURE: _____

NAME: _____

DESIGNATION: _____

COMPANY: _____

DATE: _____

COMPANY SEAL



TITLE
2X660 MW TALCHAR TPP STAGE-III
MILL REJECT SYSTEM (CONVEYOR TYPE)
STANDARD TECHNICAL REQUIREMENTS

SPECIFICATION NO. PE-TS-497-160-A101
SECTION: III
REV 00
Sub-Section **Date** APR 2023
Page 1 of 1

UTILITY REQUIREMENT

S. No.	Utility	Requirement	Tapping point location
1.	Instrument air	Pressure-5-7 bar Flow- 1 m ³ /min	3-6 m at first column of mill bay
2.	Service water	Pressure-2.5-3 bar Flow- 3-4 m ³ / hour	3-6 m at first column of mill bay

The bidder have to signed and stamped copy of this sheet along with bid.

2X660MW TALCHAR TPP STAGE-III - Mill Reject Handling System

GUARANTEED POWER CONSUMPTION FORMAT

Mode: CONVEYOR TYPE

Sl.No.	Description / Item	Working	Standby	Power Consumption (KW) (at motor input terminal)	Duty Factor	Total Power Consumption (KW)
1	2	3	4	5	6	7 = 3 x 5 x 6
1	Total Power Consumption per Unit	1	0		1.00	
					Total KW	
Notes						
1	Power consumption (KW) of motors shall be measured at motor input terminals when the system operating at the rated capacity, Power consumed by Horizontal conveyor and Bucket Elevator motors along with vent fan motor and vibrating feeder (if applicable) shall be taken into consideration for the purpose.					
2	The base auxiliary power is 30 KW per Unit. Quoted power by bidder at column no. (7) shall be evaluated with respect to base auxiliary power. For bid evaluation purpose, excess power quoted by bidder over base auxiliary power, shall be loaded with 5195 USD per KW (USD conversion rate shall be taken as defined in NIT).					
3	Power quoted by bidder shall be termed as 'Guaranteed Power consumption' (GPC) and bidder shall be liable to demonstrate compliance to GPC value during PG test/ Demonstration test at site. If the actual power consumption exceeds the guaranteed power consumption, liquidated damages shall be payable by the Contractor at the rate of 5195 USD per KW excess power consumption, over the guaranteed power consumption indicated by bidder in his bid. Such liquidated damages may be recovered by the BHEL by deduction from the contract price or by enforcing the contract performance guarantee or in any other manner deemed fit by the BHEL. For this purpose, the drives of standby equipment shall not be considered.					
4	Guaranteed Power Consumption Format shall be submitted in open along with techno commercial offer only.					