

### **PRE-QUALIFICATION CRITERIA**

<b>JOB</b>	DESIGN, ENGINEERING, MANUFACTURING, SUPPLY/ DELIVERY TO SITE OF CONTROL VALVES (PNEUMATICALLY OPERATED) WITH SMART POSITIONER & ACCESSORIES FOR 2 x 800 MW YERMARUS TPS.
<b>CONTRACT DURATION</b>	___ MONTHS.
<b>APPROXIMATE COST (NOT TO BE PUBLISHED IN THE WEBSITE)</b>	

BIDDER SHALL NOTE & COMPLY WITH THE POINTS REFERRED BELOW.

<b>SL NO</b>	<b>CRITERIA FOR BIDDERS NOT APPROVED WITH BHEL-PEM, NOIDA</b>
1.0	BIDDER SHOULD BE DESIGNER & DIRECT MANUFACTURER OF THE CONTROL VALVES WITH ACCESSORIES
2.0	BIDDER TO FURNISH EXPERIENCE CERTIFICATES FOR MIN. 2 YEARS OF TROUBLE FREE OPERATION FROM MINIMUM 2 DIFFERENT END USERS, PREFERABLY FROM POWER PLANT OF RATING 600MW & ABOVE.
3.0	MANUFACTURER SHOULD COMPLY WITH BHEL QUALITY PLAN & SPECIFICATION FOR CONTROL VALVES (AS PER ANNEXURE ATTACHED) A CONFIRMATION FOR THE SAME SHALL BE SUBMITTED.
4.0	BIDDER TO FURNISH EXPERIENCE LIST/ ORDER EXECUTED IN LAST FIVE YEARS.
5.0	BIDDER SHALL HAVE THE CAPABILITY/REFERENCE OF SUPPLYING CONTROL VALVES WITH <ol style="list-style-type: none"><li>1. ANSI RATING UPTO CLASS-4500</li><li>2. VALVE SIZE UPTO 16 INCH</li><li>3. SHUTOFF PRESSURE UPTO 450 KG/CM<sup>2</sup></li><li>4. DESIGN TEMPERATURES UPTO 400 DEG C</li><li>5. DIFFERENTIAL PRESSURES UPTO 150 KG/CM<sup>2</sup></li></ol> RELEVANT DOCUMENT IN SUPPORT OF ABOVE SHALL BE SUBMITTED
6.0	BIDDER TO FURNISH TECHNICAL CATALOGUE OF CONTROL VALVES.

### **NOTES**

1.0	BIDDER(S) ALREADY REGISTERED WITH BHEL-PEM-NOIDA FOR SUBJECT PACKAGE, NEED NOT SUBMIT CREDENTIALS FOR CRITERIA INDICATED ABOVE.
2.0	AFTER SATISFACTORY FULFILLMENT OF ALL THE ABOVE CRITERIA/ REQUIREMENT, OFFER SHALL BE CONSIDERED FOR FURTHER EVALUATION AS PER NIT AND ALL OTHER TERMS OF THE TENDER.
3.0	CONSIDERATION OF OFFER WILL BE SUBJECT TO END USER'S APPROVAL OF BIDDER.