

# **VOLUME-IB**

# **SPECIAL CONDITIONS OF CONTRACT (SCC)**

**FOR BOILER PACKAGE**

**BHARAT HEAVY ELECTRICALS LIMITED**

## CONTENTS

S. No.	Description	Chapter	No. of Pages
1	General Intent of the Specifications	Chapter-I	
2	General Services to be rendered by the Bidder	Chapter-II	
3	General Technical Requirements (Codes and Standards)	Chapter-III	
4	Obligations of Contractor (In respect of Tools, Tackles, Consumables, etc. employment of supervisory staff and workmen)	Chapter-IV	
5	Responsibilities of Contractor (In respect of Labour, Supervisory staff, etc.)	Chapter-V	
6	Material Handling, Storage, Preservation, etc.	Chapter-VI	
7	Drawings and Documents	Chapter-VII	
8	Inspection and Quality	Chapter-VIII	
9	HSE & OHSAS Obligations	Chapter-IX	
10	RA Bill Payment	Chapter-X	
11	Project Management	Chapter-XI	

# SPECIAL CONDITIONS OF CONTRACT (SCC) - Boiler Package

## Chapter - I : General Intent of Specifications

<b>1.0</b>	<b>GENERAL INTENT OF THE SPECIFICATION</b>
1.1	The intent of this specification is to provide services for execution of the project according to most modern and proven techniques and codes. The omission of specific reference to any method, equipment or material necessary for the proper and efficient services towards installation of the plant shall not relieve the contractor of the responsibility of providing such services / facilities to complete the work or portion of work awarded to him. The quoted / accepted rates / price shall deem to be inclusive of all such contingencies.
1.2	The work shall conform to dimensions and tolerances given in various drawings and documents that will be provided during erection. If any portion of works is found to be defective in workmanship and not conforming to drawings / documents or other stipulations, the contractor shall dismantle and re-do the work duly replacing the defective materials at their own cost, failing which recoveries, as determined by BHEL, shall be effected from contractor's bills. In case, drawings/ instructions get revised in the course of erection, latest revision shall be applicable and work has to be executed accordingly. In case, drawings/ instructions get revised after erection completion, latest revision shall be applicable and rework has to be executed accordingly by vendor without any objection. Any extra work /rework shall be paid as per respective clauses in GCC.
1.3	It is not the intent of this specification to specify herein all the details of erection and commissioning. However, the system shall conform in all respects to high standards of quality and workmanship for performing the required duties in a manner acceptable to purchaser who will interpret the meaning of drawings and specifications and shall be entitled to reject any work or material, which in his judgments is not in full accordance herewith.
1.4	The omission of specific reference to any fabrication / erection or other method, equipment or material necessary for proper and efficient working of the plant shall not relieve the tenderer of the responsibility of providing such facilities to complete the work at quoted rates. Any mismatch/ defect found due to mistake in fabrication / erection shall have to be rectified by the vendor free of cost. Inspection by BHEL/Customer does not relieve vendor of his responsibility of executing quality erection.
1.5	The work covered under this specification is of highly sophisticated nature, requiring the best quality workmanship, supervision, engineering and construction management. The contractor should ensure proper planning and successful and timely completion of the work to meet the overall project schedule. The contractor must deploy adequate quantity of tools & plants, modern / latest construction aids etc. He must also deploy adequate trained, qualified and experienced supervisory staff and skilled personnel.
1.6	Contractor shall erect and commission all the equipments and auxiliaries as per the sequence & methodology prescribed by BHEL depending upon the technical requirements. Availability of materials and fronts will decide this. BHEL Engineer's decision regarding correctness of the work and method of working shall be final and binding on the contractor. No claims for extra payment from the contractor will be entertained on the ground of deviation from the methods / sequence adopted in erection of similar sets elsewhere.
1.7	Following shall be the minimum responsibility of contractor and have to be provided within finally accepted rates / prices:

## SPECIAL CONDITIONS OF CONTRACT (SCC) - Boiler Package

### Chapter - I : General Intent of Specifications

---

1.7.1	Provision as required of all types of labour, supervisors, engineers, watch and ward, tools & tackles, calibrated MMEs (Monitoring and Measuring Equipment) as specified and otherwise required for the work, consumables for erection, testing and commissioning including material handling following safe erection methodology and BHEL HSE norms of HIRA (Hazard Identification and Risk assessment) / JSA (Job Safety analysis).
1.7.2	Achieving Proper out-turn / Turn-over as per BHEL plan and commitment.
1.7.3	Completion of work as per BHEL Schedule
1.7.4	Good quality and accurate workmanship for proper performance of the equipment
1.7.5	Repair and rectification
1.7.6	Preservation / Re-conservation of all components during storage / erection / commissioning till handing over.

# SPECIAL CONDITIONS OF CONTRACT (SCC) - Boiler Package

## Chapter - II : General Services to be rendered by the Bidder

2.0	<b>GENERAL SERVICES TO BE RENDERED BY THE BIDDER</b>
2.1	Services for construction, fabrication, equipment erection testing as well as trial run & commissioning of various equipment and accessories under the contract shall include but not be limited to the following:
2.2	Issuing materials from store/open yard from time to time for erection as per the construction Programme. The Contractor shall be the custodian of all the materials issued till the plant/equipment is officially taken over by the owner / BHEL after complete erection any successful trial run & commissioning.
2.3	Transport of material to their respective places of erection from the stores and erection of the complete plant & equipment as supplied under this specification.
2.4	Trial run and commissioning of individual equipment / sub-systems to the satisfaction of Owner/BHEL.
2.5	Deployment of all skilled and unskilled manpower required for erection, supervision of erection, watch & ward, commissioning and other services to be rendered under this specification.
2.6	Deployment of all erection tools & tackle, construction machinery, transportation vehicles and all other implements in adequate number and size, appropriate for the erection work to be handled under scope of this specification except otherwise specified.
2.7	Supply of all consumables, e.g. welding electrodes, cleaning agents, diesel oil, lubricant etc. as well as materials required for temporary supports, scaffolding etc. as necessary for such erection work, unless specified otherwise.
2.8	Providing support services for the contractor's erection staff e.g. construction of site offices, temporary stores, residential accommodation and transport to work site for erection personnel, watch and ward for security and safety of the materials under the Contractor's custody etc. as required.
2.9	Maintaining proper documentation of all the site activities undertaken by the Contractor as per the proforma mutually agreed with BHEL, Submission of monthly progress reports with photographs /PPT and any such document as and when desired by BHEL/owner, taking approval of all statutory authorities i.e. Boiler Inspector, Factory Inspector, Inspector of Explosives etc., as applicable for respective portions of work fall under the jurisdiction of such statutes of laws.
2.10	Any other service, although not specifically called for but required for a contract of the size and nature indicated in the specification.

**SPECIAL CONDITIONS OF CONTRACT (SCC) - Boiler Package**  
**Chapter - III : General Technical Requirement (Codes and Standards)**

---

<b>3.0</b>	<b>GENERAL TECHNICAL REQUIREMENTS (CODES AND STANDARDS)</b>
3.1	Except where otherwise specified, the plant/equipment shall comply with the appropriate Indian Standard or an agreed internationally accepted Standard Specification as mentioned elsewhere in contract specifications, each incorporating the latest revisions at the time of tendering. Where no internationally accepted standard is applicable, the Bidder shall give all particulars and details as necessary, to enable BHEL to identify all of the plant/equipment in the same detail as would be possible had there been a Standard Specification.
3.2	Where the Bidder proposes alternative codes or standards he shall include in his tender one copy (in English) of each Standard Specification to which materials offered shall comply. In such case, the adopted alternative standard shall be equivalent or superior to the standards mentioned in the specification.
3.3	In the event of any conflict between the codes and standards referred above, and the requirements of this specification, the requirements which are more stringent shall govern.
3.4	a) Tools brought by contractor that will be used during erection and commissioning shall not be accepted except with the specific approval of the Engineer including third party inspection if required. b) Special erection & commissioning T&Ps supplied by BHEL and used during erection & commissioning have to be restored to its original working condition with Painting/tagging and preservation prior to its handing to BHEL/Customer.
3.5	Wherever specified or required the plant/ equipment shall conform to various statutory regulations such as Indian Boiler Regulation, Indian Electricity Rules, Indian Explosive Act, Factories Act, etc, wherever required, obtaining approval for plant/ equipment supplied under the specification from statutory authorities shall be the responsibility of the successful bidder.

<b>4.0</b>	<b>OBLIGATIONS OF CONTRACTOR</b>
<b>4.1</b>	<b>CONSUMABLES &amp; OTHER ITEMS</b>
<b>4.1.1</b>	The contractor shall provide within finally accepted price / rates, all consumables (excepting those indicated in BHEL scope) like welding electrodes (including alloy steel and stainless steel), filler wires, TIG filler wires (over & above as supplied by the unit along with the plant materials, which will be given free of cost to bidder), gases (inert, welding, cutting), soldering material, dye penetrants, radiography films, etc. Other erection consumables such as tapes, jointing compound, grease, mobile oil, M-seal, Araldite, petrol, CTC / other cleaning agents, grinding and cutting wheels are to be provided by the contractor. Steel, packers, shims, wooden planks, scaffolding materials hardware items etc. required for temporary works such as supports, scaffoldings are to be arranged by the contractor. Sealing compounds, gaskets, gland packing, wooden/concrete sleepers, for temporary work, required for completion of work except those which are specifically supplied by manufacturing unit are also to be arranged by the contractor.
<b>4.1.2</b>	All the shims, gaskets and packing, which go finally as part of plant equipment, shall be supplied by BHEL free of cost.
<b>4.1.3</b>	It shall be the responsibility of the contractor to plan the activities and store sufficient quantity of consumables. Non-availability of any consumable materials or equivalent suggested by BHEL cannot be considered as reason for not attaining the required progress or for additional claim.
<b>4.1.4</b>	<b><u>TIG Filler wire for Boiler and Filler wires for Electrodes for P91/T91 piping:</u></b> These shall be supplied by BHEL free of cost as supplied by BHEL Manufacturing Units as part of regular supply. Required quantity as arrived at by calculation / standards will only be supplied. It would be the contractors' responsibility to account for the consumption of these filler wires. Additional consumption beyond standard / calculated quantity will be at cost recovery basis only unless and otherwise accounted for. Surplus quantity of TIG filler wire, if any, shall be properly stored and returned to BHEL stores.
<b>4.1.5</b>	It shall be the responsibility of the contractor to obtain prior approval of BHEL, regarding suppliers, type of electrodes etc. before procurement of welding electrodes. On receipt of electrodes at site these shall be subjected to inspection and approval by BHEL. The contractor shall inform BHEL details regarding type of electrodes, batch number, date of expiry etc. and produce test certificate for each lot / batch with correlation of batch / lot number with respective test certificate. No electrode without a valid test certificate will to be used.
<b>4.1.6</b>	Contractor shall submit Test/Batch Certificate of consumables items to BHEL. BHEL may arrange for checking of purity of argon used in Pressure Parts welding at site and reserves the right to reject the use of any consumable including electrodes, gases, lubricants / special consumables if it is not found to be of the required standard / make / purity or when shelf life has expired. Contractor shall ensure display of shelf life on consumable wherever required and records maintained.
<b>4.1.7</b>	Storage of all consumables including welding electrodes shall be done as per requirement / instruction of the Engineer by the contractor at his cost.

# SPECIAL CONDITIONS OF CONTRACT (SCC) - Boiler Package

## Chapter - IV : Obligations of Contractor

<b>4.1.8</b>	In case of improper arrangement for procurement of any consumable, BHEL reserves the right to procure the same from any source and recover the cost from the Contractor's first subsequent bill at market value plus the departmental charges of BHEL from time to time. Postponement of such recovery is normally not permitted. The decision of Engineer in this regard shall be final and binding on the Contractor.
<b>4.1.9</b>	All lubricants and chemicals required for pre-commissioning, commissioning, testing, preservation and lubricants for trial runs of the equipment shall be supplied by BHEL / BHEL's client. All services including labour and T&P will be provided by the contractor for handling, filling, emptying, refilling etc. The consumption of lubricants / chemicals shall be properly accounted for. Surplus material if any shall be properly stacked/tagged and returned to BHEL/ CUSTOMER stores at no extra cost to BHEL. BHEL reserves the right to recover costs for wastage by the contractor.
<b>4.1.10</b>	Transportation of oil drums, from stores, filling of oil for flushing, first filling, subsequent changeover if any, topping/making up till the unit is fully commissioned and handed over to customer is included in scope of this contract. The contractor shall have to return all the empty drums to BHEL / BHEL's client store at no extra cost. Any loss / damage to above drums shall be to contractor's account.
<b>4.1.11</b>	All charges on account of any kind of taxes and duties on materials obtained from any source for carrying out the works in the scope of the contractor shall be borne by the contractor.
<b>4.2</b>	<b>TOOLS AND PLANTS / MONITORING AND MEASURING EQUIPMENT (MMEs)</b>
<b>4.2.1</b>	<b>T&amp;Ps and MMEs to be provided by Contractor</b>
<b>4.2.1.1</b>	All T&Ps and MMEs excepting those specifically indicated in BHEL scope are to be provided by the Contractor. Contractor has to make his own arrangement at his cost for completing the formalities (including arrangement of Road permits/ e-way bill, if any) if required with Tax authorities, for bringing their materials, plants and equipments at site for the execution of work under this contract.
<b>4.2.1.2</b>	All suitable cranes, lifting and transport equipments for material handling at stores/yard/siding of BHEL/Customer are included in scope. BHEL's cranes will not be available for this purpose unless otherwise specifically permitted as per contract conditions
<b>4.2.1.3</b>	All T&Ps to be deployed by the contractor shall have the approval of BHEL Engineer with regard to brand, quality and specification.
<b>4.2.1.4</b>	Indicative list of Major T&Ps in the scope of Contractor are given in the Technical Conditions of Contract. Bidders to note that these are only indicative and as such all other T&P necessary for timely and satisfactory completion of work in scope shall be mobilized by Contractor as per mutually agreed plan.
<b>4.2.1.5</b>	Timely deployment of adequate T&Ps is the responsibility of the contractor. The contractor shall be prepared to augment the T&P at short notice to match the planned programme and to achieve the milestones.
<b>4.2.1.6</b>	Contractor shall maintain and operate his tools and plants in such a way that major breakdowns are avoided. In the event of major breakdown, contractor shall make alternative arrangements expeditiously so that the progress of work is not hampered.



<b>4.2.1.7</b>	<p>In the event of contractor failing to arrange the required tools, plants, machinery, equipment, material or non-availability of the same owing to breakdown, BHEL can deploy own/hired/otherwise arrange resources and recover the expenses incurred from the dues payable to contractor. Recoveries shall be actual expenses incurred plus 5% overheads or as defined in TCC.</p> <p>It is not obligatory on the part of BHEL to provide any tools and tackles or other materials other than those specially agreed to do so by BHEL. However, depending upon the availability, BHEL/ BHEL's customer handling equipment and other plants may be made available to the contractor on payment of hire charges as fixed, subject to the conditions laid down by BHEL/ Customer from time to time. Unless paid in advance, such hire charges, if applicable, shall be recovered from contractor's bill/ security deposit or any other due payment in one instalment.</p>
<b>4.2.1.8</b>	<p>The T&amp;P to be arranged by the contractor shall be in proper working condition and their operation shall not lead to unsafe condition. The movements of cranes, and other equipment should be such that no damage / breakage occurs to foundations, other equipments, material, property and men. All arrangements for the movement of the T&amp;P etc. shall be the contractor's responsibility.</p>
<b>4.2.1.9</b>	<p>Use of welding generators/ rectifiers only shall be permitted for welding. Use of welding transformers will be subject to specific approval of BHEL engineer.</p>
<b>4.2.1.10</b>	<p>The contractor at his cost shall carry out periodical testing of his construction equipments. Test certificates shall be furnished to BHEL.</p>
<b>4.2.1.11</b>	<p>Contractor shall ensure deployment of serviced and healthy T&amp;Ps including cranes, lifting tackles, wire ropes, manila ropes, winches and slings etc. History card and maintenance records for major T&amp;Ps will be maintained by the contractor and will be made available to BHEL Engineer for inspection as and when required. Fitness certificate / Test Certificates of T&amp;P shall have to be submitted before it is put in use. Identification for such T&amp;Ps will be done as per BHEL Engineer's advice.</p> <p>BHEL reserves the right to permit only new slings up to 20 mm and lifting tackles up to 3 MT capacities.</p> <p>Contractor shall deploy trained Hydra/Trailer and Crane Operator to enable safe operations at site. Necessary licenses should be available with them and a copy of the same shall be submitted to BHEL.</p>
<b>4.2.1.12</b>	<p>Contractor shall ensure deployment of reliable and calibrated MMEs (Inspection measuring and Monitoring equipment). The MMEs shall have test / calibration certificates from authorized / Government approved / accredited agencies traceable to National / International standards. Each MME shall have a label indicating calibration status i.e. date of calibration, calibration agency and due date for calibration. A list of such instruments deployed by contractor at site with its calibration status is to be submitted to BHEL Engineer for control.</p>

<b>4.2.1.13</b>	Re-testing / re-calibration shall also be arranged at regular intervals during the period of use as advised by BHEL Engineer within the contract price. The contractor will also have alternate arrangements for such MME so that work does not suffer when the particular instrument is sent for calibration. If any MMEs not found fit for use, BHEL shall have the right to stop the use of such item. It will be necessary for the contractor to deploy proper item. Any readings taken by the defective instrument will be recalled and repeat the readings taken by that instrument with a proper one. In case he fails to do so, BHEL may deploy MMEs and retake the readings at contractor's cost.
<b>4.2.1.14</b>	BHEL shall have lien on all T&P, MMEs and other equipment of the contractor brought to the site for the purpose of work awarded by BHEL. BHEL shall continue to hold the lien on all such items throughout the period of contract / extended period. The contractor and / or his sub-contractors, without the prior written approval of the Engineer, shall remove no material brought to the site for the purpose of work awarded by BHEL.
<b>4.2.1.15</b>	The month wise T&P deployment plan to execute the work is to be submitted as per relevant format as per the instruction of BHEL. It shall be the contractor's responsibility to deploy the required T&P, for timely and successful completion of the job, to any extent.
<b>4.2.2</b>	<b>Obligations in respect of T&amp;Ps and MMEs provided by BHEL</b>
<b>4.2.2.1</b>	T&Ps / MMEs being provided by BHEL to sub-contractor free of hire charges shall be shared by other subcontractors working for BHEL at site and the allotment done by BHEL Engineer shall be final and binding.
<b>4.2.2.2</b>	BHEL T&P will be issued in basic assembled condition. Additional loose components / sub-assemblies / attachments as and when necessary, will be issued by BHEL. Assembly of such additional loose components/sub-assemblies/ attachments is in contractor's scope.
<b>4.2.2.3</b>	In case of non-availability of the T&Ps to be provided by BHEL due to breakdown, major overhauls, distribution pattern or any other reason, the contractor shall plan / amend / alter his activities to meet erection / commissioning targets in consultation with BHEL.
<b>4.2.2.4</b>	The contractor shall engage trained and experienced operators for the operation of BHEL's T&Ps. Their skill / performance will be checked by BHEL Engineer before they are allowed to operate the same. However, checking of skills by BHEL does not absolve the contractor of his responsibilities for proper and safe handling of equipment, consistent good performance of operators and regular performance evaluation of operators.

4.2.2.5	<p>The day to day operation and maintenance of BHEL's T&amp;Ps (<b>Other than cranes</b>) shall be carried out by contractor as per manufacturer's / BHEL's maintenance schedule at his cost. The contractor shall arrange, at his own cost, trained operators, fuel and other consumables for their operation. BHEL shall arrange all spares needed for upkeep of major T&amp;Ps provided like Huck Bolting Machine*, DG Set, Induction Machine and Hydraulic Test pumps. The contractor has to arrange for fixing of the spares; supervision in specialized cases will be provided by BHEL. For upkeep of all other T&amp;Ps supplied by BHEL, spares shall be arranged by the Contractor. BHEL supplied T&amp;Ps shall be maintained in good working condition during the entire period of use with proper tagging &amp; preservation. T&amp;Ps in defective / damaged condition shall be rectified promptly to the full satisfaction of BHEL engineer. Contractor shall maintain records for maintenance of major T&amp;Ps. These shall be made available for Inspection whenever required. In case of any lapses on the part of the contractor, BHEL at its own discretion shall get the servicing / repair of equipment done and recover the expenses incurred from the dues payable to contractor. Recoveries shall be actual expenses incurred plus 5% overheads or as defined in TCC. Further, if there are breakdowns / damages due to negligence of the contractor, the complete service / repair charges and cost of all the spares damaged with BHEL overheads shall be recovered from contractor's RA bills.</p> <p>* for operation and maintenance of ESP Huck bolting machine, BHEL shall provide the basic power rig and hose. Balance tools i.e. Guns, chuck jaws etc. are to be arranged by contractor.</p>
4.2.2.6	<p>Increasing / shortening of the crane boom to suit work requirements shall have to be arranged by the indenting contractor at his cost including restoration to a state as directed by BHEL. All necessary manpower tools, support, consumables, illumination etc. will have to be arranged by contractor at his cost. If required, contractor has to return the crane with original boom.</p>
4.2.2.7	<p>The area and infrastructure development of the area to be carried out by the customer. However, in construction projects of this magnitude it is possible that all the areas / approaches may not be ready. In such cases backfilling of approaches where ever necessary, consolidation of ground and arrangement of sleepers / sand bag filling etc. for safe operation / movement of equipment including cranes / trailers etc. shall be the responsibility of the contractor at his cost. No compensation on this account shall be payable.</p>
4.2.2.8	<p>In the event of contractor not using and maintaining BHEL T&amp;Ps according to BHEL's instructions. BHEL will have the right to withdraw such item without any notice and no claim in this regard shall be entertained and contractor shall be responsible for delay in execution on this account.</p>
4.2.2.9	<p>The contractor shall furnish regular utilization report of the BHEL T&amp;Ps, as per requirement of BHEL.</p>
4.2.2.10	<p>Any loss / damage to any part of BHEL T&amp;Ps and MMEs shall be to the contractor's account and any expenditure on these accounts by BHEL will be recovered from the contractor's bill in case the contractor fails to make good the loss.</p>
4.2.2.11	<p>It shall be responsibility of the contractor to take delivery of T&amp;Ps and MMEs from stores or place of use by other contractor at project site, transport the same to site and return the same to BHEL store / place as intimated by Engineer in project site in good working conditions after use.</p>

<b>4.2.2.12</b>	<p>The contractor shall return BHEL T&amp;Ps and MMEs issued to him in good working condition as and when desired by BHEL (on completion or reduction of workload). If contractor delays return of T&amp;P and MME, hire charges as applicable shall be levied by BHEL from time, it was requisitioned till the time of actual return.</p> <p>T&amp;Ps and MMEs returned in damaged / unserviceable condition shall be got repaired by BHEL at its own discretion and <b>actual expenses incurred plus 5% overheads</b> shall be recovered from the contractor.</p>
<b>4.2.2.13</b>	Replacement cost including BHEL overheads in respect of irreparable / completely damaged / non return of T&Ps and MMEs shall be recovered from the contractor's running / final bills.
<b>4.2.2.14</b>	<b>Obligations in respect of Cranes provided by BHEL</b>
<b>a)</b>	<p>BHEL will make available the cranes (as per Technical Conditions of Contract) free of charge to the contractor on sharing basis mainly for the purposes enumerated/indicated therein. BHEL cranes have to be shared with other agencies / contractors of BHEL. The allocation of cranes shall be the discretion of BHEL engineer, which shall be binding on the contractor.</p> <p>The Crane shall be available for (14) fourteen hours inclusive of one-hour lunch break daily, excluding Sundays and scheduled Holidays. For Crane working beyond normal working hours or on Sundays /Holidays, prior permission of the BHEL Site In-charge/ Construction Manager is to be obtained. However, BHEL Site In-charge/ Construction Manager's decision in this regard will be final after judging the proficiency of the contractor's crane requirement.</p>
<b>b)</b>	BHEL Cranes may be initially issued in basic assembled condition. Any alteration/addition like boom reduction / extension, assembly of components/sub-assemblies needed for modulating the capacity/reach/other features of cranes and restoration to the state as directed by BHEL shall be the contractor's responsibility.
<b>c)</b>	<p>In case the BHEL cranes are not covered under AMC of BHEL, then the day-to-day upkeep and running maintenance like filling / topping up of lubricants, changing filters, etc. including repair of self-starter and dynamo of these cranes shall be the responsibility of the contractor. If on checking it is found that the same is not followed, BHEL will exercise its right to get the job/works done and <b>recover the expenses incurred from the dues payable to contractor. Recoveries shall be actual expenses incurred plus 5% overheads or as defined in TCC.</b></p> <p>In case BHEL cranes are covered under AMC awarded by BHEL, then the day-to-day upkeep and running maintenance as described above are excluded from scope. However, any additional helpers if any required during Preventive/Breakdown Maintenance, Assembly/disassembly shall be provided by contractor at no extra cost.</p> <p>BHEL may also provide cranes through crane hiring agencies in which case the day-to-day upkeep and running maintenance shall be excluded from scope of contractor.</p>
<b>d)</b>	Minor consumables like cotton cloth, cotton waste, etc. is to be supplied by Contractor. All spares and lubricants/grease is excluded from scope. Contractor to give the requirements of these items well in advance in case the cranes provided by BHEL are BHEL owned cranes
<b>e)</b>	Unless otherwise specified, trained operators for BHEL owned cranes shall be provided by the contractor. These operators should possess valid license for heavy vehicle.

f)	BHEL cranes will be withdrawn for regular and capital maintenance as per the respective schedule of maintenance. As far as possible such schedules will be intimated to the contractor in advance and may be adjusted depending on the work requirements at site. However, no claim whatsoever will be entertained on account of non-availability of cranes.
g)	Where the services of the cranes provided by BHEL are to be shared by other agencies/contractors of BHEL, the contractor's responsibilities defined above will also be apportioned accordingly to the beneficiary agency. Working arrangements in this regard will be done at site by BHEL engineer and in any case his decision shall be final and binding.
h)	Major breakdowns will be attended to by BHEL. However, in case of breakdowns or damages due to negligence of the contractor, the actual expenses towards complete service/repair charges including cost of spares <b>plus 5% overheads shall be recovered from the contractor.</b>
<b>4.2.2.15</b>	<b>Obligations in respect of Construction Lift/Elevators provided by BHEL</b>
a)	The total erection including commissioning, maintenance, statutory clearances shall be included in scope of work. Supervision by the original equipment supplier or their authorized agency shall be arranged for by BHEL, in case found necessary. Contractor shall keep trained operators for daily operation of Elevator.
b)	All day to day and routine maintenance and checking is to be carried out by the contractor as per the recommendations of the supplier. He should periodically check the brakes and carry out the all works to ensure the safety of all those using the lift/elevator. BHEL shall arrange spares required for upkeep of Construction lift/elevator
c)	The construction lift/elevator should never be overloaded as this can lead to serious accidents. Ensuring all safety aspects in operation of the lift shall be the responsibility of the contractor. Erection of all the required number of landing platforms is included in scope. Landing platforms are to be provided with proper barricades and hand railings.
d)	After completion of contractual scope of work or as per BHEL advice, the temporary elevator/lift shall be dismantled and handed over to BHEL neatly identified/tagged. Temporary structures/platforms etc. erected for the elevators/lifts are also to be dismantled and materials to be returned to stores as applicable. <b>The construction and dismantling of the foundations required for the construction/elevator lifts is included in the scope of the contractor.</b>
<b>4.3</b>	<b>Measures for prevention of Boiler Tube Leakages</b>
<b>4.3.1</b>	Guideline for selection of NDE Agency for RT (Radiography Test) (Annexure – S1) to be followed.
<b>4.3.2</b>	Pit room and film development should be inside plant premises for timely execution of NDT inspection and better transparency.

<b>5.0</b>	<b>RESPONSIBILITIES OF CONTRACTOR (in respect of Labour, Supervisory staff, etc.)</b>
5.1	Refer relevant clauses of General Conditions of Contract (GCC) also in this regard
5.2	The contractor shall deploy all the necessary skilled/semiskilled/ unskilled labour including highly skilled workmen etc. These workmen should have previous experience on similar job. They shall hold valid certificates wherever necessary. BHEL reserves the right to insist on removal of any employee of the contractor at any time if he is found to be unsuitable and the contractor shall forthwith remove him.
5.3	Contractor shall also comply with the requirements of local authorities' / project authorities calling for police verification of antecedents of the workmen, staff etc.
5.4	It is the responsibility of the contractor to engage his workmen in shifts and or on overtime basis for achieving the targets set by BHEL. This target may be set to suit BHEL's commitments to its customer or to advance date of completion of events or due to other reasons. The decision of BHEL in regard to setting the erection and commissioning targets will be final and binding on the contractor.
5.5	Contractor shall provide at different elevation suitable arrangement for urinal and drinking water facility with necessary plumbing & disposal arrangement including construction of septic tank. These installations shall be maintained in hygienic condition at all times.
5.6	The Contractor in the event of engaging 20 or more workmen, shall obtain Independent license under the Contract labour (Regulation and Abolition) Act 1970 from the concerned authorities based on Form-V issued by the Principal Employer/Customer. In order to issue Form-V by Customer, Contractor shall fulfill all Statutory requirements like Insurance Policy, PF Code/PF Account number etc. as per the requirement of BHEL/Customer
5.7	Contractor shall deduct the necessary amount towards Provident Fund and contribute equal amount as per Government of India laws. This amount will be deposited regularly to the provident Fund Commissioner. BHEL/Customer may insist for submission of the account code duly certified by PF Commissioner.
5.8	Contractor may also be required to comply with provisions of ESI Act in vogue if applicable and submit evidence to BHEL.
5.9	BHEL / customer may insist for witnessing the regular payment to the labour. They may also like to verify the relevant records for compliance with statutory requirements. Contractor shall enable such facilities to BHEL / Customer.
5.10	Contractor shall deploy only qualified and experienced engineers/ supervisors. They shall have professional approach in executing the work.
5.11	The contractor's supervisory staff shall execute the work in the most professional manner in the stipulated time. Accuracy of work and aesthetic finish are essential part of this contract. They shall be responsible to ensure that the assembly and workmanship conform to dimensions and tolerances given in the drawings/instructions given by BHEL engineer from time to time.

5.12	The supervisory staff employed by the contractor shall ensure proper outturn of work and discipline on the part of the labour put on the job by the contractor. Also in general they should see that the works are carried out in a safe and proper manner and in coordination with other labour and staff employed directly by BHEL or other contractors of BHEL or BHEL's client.
5.13	It is the responsibility of the contractor to arrange gate pass for all his employees, T&P etc. for entering the project premises. Necessary coordination with customer officials is the responsibility of the contractor. Contractor to follow all the procedures laid down by the customer for making gate passes. Where permitted, by customer / BHEL, to work beyond normal working hours, the contractor shall arrange necessary work permits for working beyond normal working hours.
5.14	The actual deployment of Labour and Engineer/supervision staff by the Contractor shall be so as to satisfy the erection and commissioning targets set by BHEL. If at any time, it is found that the contractor is not in a position to deploy the required engineers/supervisors/workmen due to any reason, BHEL shall have the option to make alternate arrangements and <b>recover the expenses incurred from the dues payable to contractor. Recoveries shall be actual expenses incurred plus 5% overheads or as defined in TCC.</b>
5.15	Contractor shall not deploy women labour at night.



SPECIAL CONDITIONS OF CONTRACT (SCC) - Boiler Package  
Chapter – VI: Material Handling, Storage & preservation

<b>6.0</b>	<b>MATERIAL HANDLING, STORAGE AND PRESERVATION ETC</b>
<b>6.1</b>	<b>MATERIAL HANDLING AND STORAGE</b>
<b>6.1.1</b>	All the equipments/materials furnished under this contract shall be received from the project stores, sheds / storage yards and transported to pre assembly area / erection site and stored in the storage spaces in a manner so that they are easily retrievable till the contractor erects them. <b>While drawing/lifting material from BHEL / customer stores, the contractor shall ensure that the balance / other materials are stacked back immediately. No claim is admissible on this account.</b>
<b>6.1.2</b>	While BHEL will endeavor to store / stack / identify materials properly in their open / close / semi closed / tarpaulins covered storage yard / shed, it shall be contractor's responsibility to assist BHEL in identifying materials well in time for erection. They should take the delivery of the same, following the procedure indicated by BHEL, and transport the material safely to pre-assembly yard / erection site in time, according to program.
<b>6.1.3</b>	The contractor shall take delivery of components, equipment / consumables from storage area after getting the approval of BHEL Engineer on standard indent forms.
<b>6.1.4</b>	The contractor shall identify and deploy necessary Engineers / supervisors / workmen for the above work in sufficient number as may be needed by BHEL, for areas covering their scope.
<b>6.1.5</b>	All the equipment shall be handled very carefully to prevent any damage or loss. No untested wire ropes / slings etc. shall be used for unloading / handling. The equipment shall be properly protected to prevent damage either to the equipment or to the floor where they are stored. The equipment from the stores shall be moved to the actual location at the appropriate time so as to avoid damage of such equipment at site.
<b>6.1.6</b>	Contractor shall ensure that while lifting slings shall be put over the points indicated on the equipment or as indicated in the manufacturer's drawings. Slings / shackles of proper size shall be used for all lifting and rigging purposes. All care shall be taken to safe guard the equipment against any damage. Dragging of piping / valves should be avoided. In case of any damage the cost shall be covered from the contractor.  Use of Lifting Belts for Piping/valves and Rotary equipment shall be done.
<b>6.1.7</b>	Approach road conditions from the stores / yards to the erection site may not be equipped and ideal for smooth transportation of the equipment. Contractor may have to be adequately prepared to transport the materials under the above circumstances without any extra cost. The contractor should make himself familiar with soil conditions at site.
<b>6.1.8</b>	Contractor shall be responsible for examining all the plant and materials issued to him and notify the Engineer immediately of any damage, shortage, discrepancy etc. before they are moved out of the stores / storage area. The contractor shall be solely responsible for any shortages or damages in transit, handling, storage and erection of the equipment once received by him. As the erection work will be spread in different areas / locations of the project, contractor has to arrange sufficient number of watch / ward personal to avoid any pilferage of material.



**SPECIAL CONDITIONS OF CONTRACT (SCC) - Boiler Package**  
**Chapter – VI: Material Handling, Storage & preservation**

<b>6.1.9</b>	The contractor shall maintain an accurate and exhaustive record-detailing out the list of all equipment received by him for the purpose of erection and keep such record open for the inspection of the engineer at any time.
<b>6.1.10</b>	All the material in the custody of contractor and stored in the open or dusty locations must be covered with suitable weather proof / fire retardant covering material wherever applicable and shall be blocked up on raised level above ground. All covering materials including blocks and sleeper shall be arranged by the contractor at his cost.
<b>6.1.11</b>	If the material belonging to the contractor are stored in area other than those earmarked for his operation, BHEL has the right to get it moved to the area earmarked for the contractor <b>and recover the expenses incurred from the dues payable to contractor. Recoveries shall be actual expenses incurred plus 5% overheads or as defined in TCC.</b>
<b>6.1.12</b>	The contractor shall be responsible for making suitable indoor storage facilities to store all equipment (drawn by the contractor from BHEL / customer stores), which require indoor storage till the time of their installation. The Engineer will direct the contractor in this regard, which item in his opinion will require indoor storage, and the contractor shall comply with Engineer's decision.
<b>6.1.13</b>	The contractor shall ensure that all surplus / damaged / scrap / unused material, packing wood / containers/ special transporting frames etc. are returned to BHEL at a place in project area identified by the Engineer. The contractor will maintain an account for all items received and returned to BHEL. Any shortage in returning such items shall be chargeable to the contractor except allowable wastage for packing wood only.
<b>6.1.14</b>	The contractor shall hand over all parts / materials remaining extra over the normal requirement with proper identification tags to the stores as directed by the concerned BHEL engineer.
<b>6.1.15</b>	The contractor shall ensure that all the packing materials and protective devices installed on equipment during transit and storage are removed before installation.
<b>6.1.16</b>	It shall be the responsibility of the contractor to keep the work / storage areas in neat, tidy and working conditions. All surplus/unusable packing and other materials shall be removed and deposited at location(s) specified by BHEL within the project premises. If required weighing of the same within the project premises will have to be carried out.
<b>6.1.17</b>	After identification of erection materials by BHEL at BHEL's store/ storage yard, it shall be the responsibility of successful bidder to take delivery of materials from BHEL's store/ storage yard by successful bidder's own manpower and re-stack the leftover materials as per erection sequence at BHEL store at their own cost. The entire activities are to be carried out under supervision of BHEL's engineer.
<b>6.2</b>	<b>PRESERVATION OF COMPONENTS</b>
<b>6.2.1</b>	After taking delivery from BHEL / customer's stores, plant materials storage shall be subjected to the following protection besides other provisions indicated in these specifications elsewhere.

**SPECIAL CONDITIONS OF CONTRACT (SCC) - Boiler Package**  
**Chapter – VI: Material Handling, Storage & preservation**

---

<b>6.2.1.1</b>	Items stored outdoors shall be stacked up at least six inches (6") off the ground. Items should not be stored in a low lying area where water logging is a possibility. Contractor should have sufficient numbers of wooden / concrete / steel sleepers for the job.
<b>6.2.1.2</b>	Motors, valves, electrical equipment, control equipment and instruments, and special or precision items requiring special care, etc. shall be stored indoors. Motor windings shall be kept dry by use of external heat or space heaters.
<b>6.2.1.3</b>	Bearings and other wearing surfaces of plant materials shall be protected against corrosion and kept clean and should be regularly monitored.
<b>6.2.1.4</b>	Insulation materials shall be stored indoors or otherwise protected against getting wet/ damaged, using suitable measures and should be protected from direct rain.
<b>6.2.2</b>	It shall be the responsibility of the contractor to apply preservatives / touch up paints (primer) on equipment handled and erected by him till such time of final painting (as per TCC). It shall be contractor's responsibility to arrange for required paints (primer), thinners, labour, scaffolding materials, cleaning materials like wire brush, emery sheets etc., cleaning of surface and provide one coat of preservatives / paints (primer) from time to time as decided by BHEL engineer (as per TCC). The accepted rate shall include this work also. It is to be noted that such painting may have to be done as and when required till such time the final painting is carried out.
<b>6.2.3</b>	The contractor shall effectively protect the finished work from action of weather and from damage or defacement and shall cover the finished parts then and there for their protection.
<b>6.2.4</b>	Any failure on the part of contractor to carry out works according to above clauses will entail BHEL to carry out the job from any other party and recover the cost from contractor.
<b>6.2.5</b>	All piping, tubing & conduit connections on equipment and equipment openings shall be closed with rough usage covers or plugs. Female threaded openings shall be closed with rough usage covers or plugs or forged steel plugs. The closures shall be taped to seal the interior of the equipment. Open ends of piping, tubing and conduit shall be sealed and taped.
<b>6.2.6</b>	All other consumables including wire brush, emery papers, painting brush, etc. to be supplied by the successful bidder within the accepted rate.
<b>6.2.7</b>	Headers and Coils may require Boroscopic Inspection before erection. The same shall be carried out by Contractor. Boroscope shall be arranged by BHEL. Any foreign material if found, shall be removed from the header as per instruction of BHEL Engineer.

SPECIAL CONDITIONS OF CONTRACT (SCC) - Boiler Package  
Chapter – VII: Drawings and Documents

---

<b>7.0</b>	<b>DRAWINGS AND DOCUMENTS</b>
<b>7.1</b>	The detailed drawings, specifications available with BHEL engineers will be made available to the contractor during execution of work at site. The contractor will also ensure availability of all drawings / documents at work place.
<b>7.2</b>	Necessary drawings to carry out the erection work will be furnished to the contractor by BHEL on loan, which shall be returned to BHEL Engineer at site after completion of work. Contractor shall ensure safe storage and quick retrieval of these documents.
<b>7.3</b>	The contractor shall maintain a record of all drawings and documents available with him in a register as per format given by BHEL Engineer. Contractor shall ensure use of pertinent drawings / data / documents and removal of obsolete ones from work place and returning to BHEL.
<b>7.4</b>	The data furnished in various annexure enclosed with this tender specification are only approximate and for guidance. However, the change in the design and in the quantity may occur as is usual in any such large scale of work. The contractors quoted rates shall be inclusive of the above factor
<b>7.5</b>	Should any error or ambiguity be discovered in the specification or information the contractor shall forthwith bring the same to the notice of BHEL before commencement of work. BHEL's interpretation in such cases shall be final and binding on the contractor.
<b>7.6</b>	Deviation from design dimensions should not exceed permissible limit. The contractor shall not correct or alter any dimension / details, without specific approval of BHEL.

SPECIAL CONDITIONS OF CONTRACT (SCC) - Boiler Package  
Chapter – VIII: Inspection and Quality

<b>8.0</b>	<b>INSPECTION AND QUALITY</b>
<b>8.1</b>	<b>Inspection, Quality Assurance, Quality Control</b>
<b>8.1.1</b>	Preparation of quality assurance log sheets and protocols with customer/ consultants/statutory authority, welding logs, NDE records, testing & calibration records and other quality control and quality assurance documentation as per BHEL engineer's instructions, is within the scope of work/specification. These records shall be submitted to BHEL/customer for approval from time to time.
<b>8.1.2</b>	The protocols between contractor and customer/ BHEL shall be made prior to installation for correctness of foundations, materials, procedures, at each stage of installation, generally as per the requirement of customer/ BHEL. This is necessary to ensure elimination of errors or keeping them within tolerable limits and to avoid accumulation and multiplication of errors.
<b>8.1.3</b>	<p>A daily log book should be maintained by every supervisor/engineer of contractor on the job in duplicate (one for BHEL and one for contractor) for detailing and incorporating alignment/clearance / centering / leveling readings and inspection details of various equipments etc.</p> <p>High pressure welding details like serial number of weld joints, welders name, date of welding, details of repair, heat treatment etc. will be documented in welding log as per BHEL Engineer's instructions.</p> <p>Record of radiography containing details like serial number of weld joints, date of radiography, repairs, if any, re-shots etc. shall also be maintained as per BHEL Engineer's instructions.</p> <p><b>Record of heat treatments performed shall be maintained as prescribed by BHEL</b></p>
<b>8.1.4</b>	The performance of welders will be reviewed from time to time as per the BHEL standards. Welders' performance record shall be furnished periodically furnished for scrutiny of BHEL's Engineer. Corrective action as informed by BHEL shall be taken in respect of those welders not conforming to these standards. This may include removal/ discontinuance of concerned welder(s). Contractor shall arrange for the alternate welders immediately
<b>8.1.5</b>	All the welders shall carry identity cards as per the proforma prescribed by BHEL/Customer/Consultant. Only welders duly authorized by BHEL/customer/consultant shall be engaged on the work.
<b>8.1.6</b>	Contractor shall provide all the Measuring Monitoring Equipments (MMEs) required for completion of the work satisfactorily. These MMEs shall be of brand, quality and accuracy specified by BHEL Engineer and should have necessary calibration and other certificates as per the requirement of BHEL Engineer. Decision of BHEL Engineer regarding acceptance or otherwise of the measuring instruments/gauges/tools for the work under this specification, is final and binding on the contractor. BHEL may give an indicative list of MMEs required for this work and to be made available by the contractor. The list will be reviewed by BHEL and the contractor shall meet any augmentation needed wherever required.
<b>8.1.7</b>	It is the responsibility of the contractor to prove the accuracy of the testing/measuring/calibrating equipments brought by him based on the periodicity of calibration as called for in the BHEL's quality assurance standards/BHEL Engineer's instructions.
<b>8.1.8</b>	Any re-laying or re-termination of cables/re-erection of instruments/ recalibration of instruments etc. required due to contractor's mistake or design requirement and found at any stage inspection, shall be carried out by the contractor at no extra cost.

**SPECIAL CONDITIONS OF CONTRACT (SCC) - Boiler Package**  
**Chapter – VIII: Inspection and Quality**

<b>8.1.9</b>	BHEL, Power Sector Regions (PSNR/PSER/PSWR/PSSR) have already been accredited with ISO 9001 certification and as such this work is subject to various audits to meet ISO 9001 requirements. One particular aspect which needs special mention is about arrangement of calibration of instruments by the contractor. Contractor shall ensure deployment of reliable and calibrated MMEs (Measuring and Monitoring Equipments). The MMEs shall have test / calibration certificates from authorized / Government approved / Accredited agencies traceable to National / International Standards. Re-testing / re-calibration shall also be arranged at regular intervals during the period of use as advised by BHEL Engineer within the contract price. The contractor will also have alternate arrangements for such MMEs so that work does not suffer when the particular equipment / instrument is sent for calibration. Also if any MMEs not found fit for use, BHEL shall have the right to stop the use of such item and instruct the contractor to deploy proper item and recall i.e., repeat the readings taken by that instrument, failing which BHEL may deploy MME and retake the readings at Contractor's cost.
<b>8.1.10</b>	Re-work necessitated on account of use of invalid MMEs shall be entirely to the contractor's account. He shall be responsible to take all corrective actions, including resource augmentation if any, as specified by BHEL to make-up for the loss of time.
<b>8.1.11</b>	In the courses of erection, it may become necessary to carry repeated checks of the work with instruments recently calibrated, re-calibrated. BHEL may counter/ finally check the measurements with their own MMEs. Contractor shall render all assistance in conduct of such counter/final measurements.
<b>8.1.12</b>	Total Quality is the watchword of the work and Contractor shall strive to achieve the Quality Standards, procedures laid down by BHEL. He shall follow all the instructions as per BHEL drawings and Quality Standards.
<b>8.2</b>	<b>Stage Inspection By FES/QA Engineers</b>
<b>8.2.1</b>	Apart from day-to-day inspection by BHEL Engineers stationed at Site and Customer's Engineers, stage inspection of equipments under erection and commissioning at various stages shall also be conducted by teams of Engineers from Field Engineering Services of BHEL's Manufacturing Units, Quality Assurance teams from Field Quality Assurance, Unit/Factory Quality Assurance and Commissioning Engineers from Technical Services etc. Contractor shall arrange all labour, tools and tackles etc. along with proper access for such stage inspections free of cost.
<b>8.2.2</b>	Any modifications suggested by BHEL FES and QA Engineers' team shall be carried out. Claims of contractor, if any, shall be dealt as per contract, and provided such modifications have not arisen for reasons attributable to the contractor.
<b>8.3</b>	<b>Statutory Inspection of Work</b>
<b>8.3.1</b>	<p>The work to be executed under these specifications has to be offered for inspection, at appropriate stages of work completion, to various statutory authorities for compliance with applicable regulations.</p> <p>The work related statutory inspections, though not limited to, are as under:</p> <ol style="list-style-type: none"> <li>1) Inspectorate of Steam Boilers and Smoke Nuisance</li> <li>2) Electrical Inspector</li> <li>3) Factory Inspector, Labour Commissioner, PF Commissioner and other authority connected to this project work</li> </ol>

**SPECIAL CONDITIONS OF CONTRACT (SCC) - Boiler Package**  
**Chapter – VIII: Inspection and Quality**

	The scope includes getting the approvals from the statutory authorities, which includes arranging for inspection visits of statutory authority periodically as per BHEL Engineer's instructions, arranging materials for ground inspection, taking rub outs for the pressure parts to be offered for inspection, submitting co-related inspection reports, documents, radiographs etc. and following up the matter with them. Contractor shall also make all arrangements for offering the Products / Systems for inspection at location, as applicable, to the concerned authority.
<b>8.3.2</b>	Contractor should be qualified to execute pressure parts & piping work coming under the purview of IBR, for which he should register himself with CIB of state concerned. contractor also should be aware of the latest IBR regulations and Electricity Act, including the amendments thereof.
<b>8.3.3</b>	Contractor shall comply with 'Qualification Tests for welders engaged in welding of Boilers and Steam Pipes under Construction, Erection and Fabrication at Site in India and in repairing Boilers and steam pipes by welding' in line with Chapter XIII of Indian Boiler Regulations 2022, for testing his welders / men / workers, including all associated fees, procedures, required instruments and equipment and their calibration thereof. It shall be contractor's responsibility to obtain approval of Statutory Authorities, wherever applicable, for the conducting of any work which comes under the purview of these authorities, at his cost.
<b>8.3.4</b>	The following fees shall be excluded from scope of Contractor: 1. Registration Fee as per Regulation 385 of Chapter IX of <b>Extant</b> Indian Boiler Regulations 2. Fees for inspection of Boiler and Steam-Pipe at the site of Construction as per Regulation 395 A, sl no 4 of Chapter IX of <b>Extant</b> Indian Boiler Regulations However all other fees like visit fees charged by the Boiler Inspector and other arrangements for his visit or visits till satisfactory completion of work, shall be included in scope of Contractor
<b>8.4</b>	The Quality Management System of BHEL, Power Sector Regions (PSNR/PSER/PSWR/PSSR) have already been certified and accredited under ISO 9002 standards in this regard. The basic philosophy of the Quality Management System is to define the organizational responsibility, work as per documented procedures, verify the output with respect to acceptance norms, identify the non-conforming product/ procedure and take corrective action for removal of non-conformance specifying the steps for avoiding recurrence of such non-conformities, & maintain the relevant quality records. The nonconformities are to be identified through the conduct of periodical audit of implementation of quality systems at various locations/stages of work. Suppliers/vendors of various products/services contributing in the work are also considered as part of the quality management system. .as such the contractor is expected not only to conform to the quality management system of BHEL but also it is desirable that they themselves are accredited under any quality management system standard.
<b>8.5</b>	<b>Field Quality Assurance</b>
<b>8.5.1</b>	Contractor shall carry out all activities conforming to the approved Field Quality Plan (FQP) as revised from time to time. Total quality shall be the watchword of the work and contractor shall strive to achieve the quality standards, procedures laid down by BHEL. He shall follow all the instructions as per BHEL drawings and quality standards. Contractor shall provide the services of quality assurance engineer as per the relevant clauses.

SPECIAL CONDITIONS OF CONTRACT (SCC) - Boiler Package  
Chapter – IX: HSE & OHSAS Obligations

---

9.0	<b>OCCUPATIONAL HEALTH, SAFETY &amp; ENVIRONMENT MANAGEMENT/ QUALITY ASSURANCE PROGRAMME:</b>  BHEL, Power Sector Regions (PSNR / ER / WR / SR) are each certified for ISO 9001. Quality of work to customer's satisfaction and fulfillment of system requirements are the essence of ISO 9001 certification. BHEL, PS Regions have HSE certification (ISO 14001:2015 & OHSAS 18001) and therefore Contractor also shall organize / plan/ perform all their activities to meet with the applicable requirements of these standards.
9.1	<b>HSE (Health, safety &amp; Environment):</b>  Contractor will comply with HSE (Health, safety & Environment) requirements of BHEL as per the "HSE Plan for Site Operations by Subcontractor" (Document No. HSEP: 14 Rev02) and any other document issued along with tender. In case of any ambiguity between these two documents, more stringent clauses(s) of the two, as decided by BHEL will be followed.



SPECIAL CONDITIONS OF CONTRACT (SCC) - Boiler Package  
Chapter – X: RA Bill Payments

---

10.0	<b>RA Bill Payments</b>
10.1	The contractor shall submit his monthly RA bills with all the details required by BHEL on specified date every month covering progress of work in all respects and areas for the previous calendar month in prescribed format with clearance from HSE, Quality and HR.
10.2	Mode of payment and measurement of work completed shall be as per relevant clauses of General Conditions of Contract
10.3	Release of payment in each running bill including PVC Bills where ever applicable will be as per stages of progressive pro rata payments.
10.4	void
10.5	<p>The payment for running bills will normally be released within 30 days of submission of running bill complete in all respects with all documents. It is the responsibility of the contractor to make his own arrangements for making timely payments towards labour wages, statutory payments, outstanding dues etc. and other dues in the meanwhile.</p> <p>60% of RA Bills complete and correct in all respects and certified by BHEL Engineer, shall be paid within 15 days of receipt. Balance payment shall be within 30 days.</p>
10.6	<p>BHEL shall release payment through Electronic Fund Transfer (EFT)/RTGS. In order to implement this system, Contractor to furnish details pertaining to his Bank Accounts where proceeds will be transferred through BHEL's banker, as per prescribed formats:</p> <p>Note: BHEL may also choose to release payment by other alternative modes as applicable</p>
10.7	Paying Authority shall be the Construction Manager of the Site. Any change in the paying Authority shall be intimated to the Contractor accordingly.



**SPECIAL CONDITIONS OF CONTRACT (SCC) - Boiler Package**  
**Chapter – XI Project Management**

<b>11.0</b>	<b>PROJECT MANAGEMENT</b>
	To meet the need of construction management at site, successful bidder shall provide the following services within accepted rates.
<b>11.1</b>	<b>PLANNING &amp; MONITORING</b>
11.1.1	Within 15 days of placement of order/ LOI by BHEL, successful bidder shall interact with BHEL site for kick-off meeting to discuss & firm up item-wise/ activity-wise schedule of erection, testing, commissioning so as to complete the entire job within the stipulated completion period, matching with project schedule.
11.1.2	Based on the discussion of the kick-off meeting or otherwise, a master schedule shall be drawn and successful bidder shall submit the same within 7 days of kick-off meeting, for review & acceptance/ approval of BHEL. Successful bidder shall interact with BHEL to ensure acceptance/ approval of the master schedule within 7 days of submission.
11.1.3	On the basis of accepted/ approved master schedule, on every month, the successful bidder shall submit to Construction Manager, BHEL schedule-wise plan vs actual status of erection, testing, commissioning, along with action plan to make-up delay, if any.
11.1.4	The project schedule might undergo revision/ modification periodically, for which the successful bidder may have to prepare/ modify schedule periodically in consultation with BHEL, so as to match with revised project milestones.
11.1.5	The successful bidder shall ensure monitoring of these activities at least on fortnight basis or at other frequency as mutually agreed with BHEL.
11.1.6	Successful bidder shall submit daily work program based on above schedule. Deferment of above schedule is not acceptable. Successful bidder will adhere to schedule & augment resources to ensure completion as per schedule.
11.1.7	Progress reviews on entire activities will be held periodically as per direction of BHEL. These meetings will be used as a forum for discussing all areas where progress needs to be expedited. The successful bidder shall be further responsible for ensuring that suitable steps are taken to meet various targets decided upon such meetings.
11.1.8	Successful bidder shall prepare progress report indicating progress on key activities, management summary for critical activities, list of actions requiring BHEL's attention. The schedule shall preferably be made in MS Projects, so that the same is compatible with BHEL's project management software.
<b>11.2</b>	void
<b>11.3</b>	<b>PROGRESS REPORTING</b>

**SPECIAL CONDITIONS OF CONTRACT (SCC) - Boiler Package**  
**Chapter – XI Project Management**

11.3.1	The bidder shall submit daily, weekly and monthly progress reports for work force, materials reports, consumables (gases/electrodes) report and other reports as per pro-forma considered necessary by BHEL. In case of any failure on successful bidder's part to comply with this, BHEL may at its discretion, consider to withhold part payment against their RA bills.
11.3.2	The progress report shall indicate the progress achieved against planned with reasons indicating delays, if any, and shall give the remedial actions which the successful bidder intends to take to make good the slippage or lost time, so that further works again proceed as per the original program and the slippages do not accumulate and effect the overall program.
11.3.3	The daily work force reports shall clearly indicate the work force deployed, category-wise specifying also the activities in which they are engaged.
11.3.4	Weekly progress review meetings will be held at site during which actual progress during the week vis-à-vis scheduled program shall be discussed or actions to be taken for achieving targets. For discussions, the successful bidder shall present program of subsequent week. The successful bidder shall constantly update/ revise his work program to meet the overall requirement.
11.3.5	Periodic progress reviews on the entire activities of execution in respect of supply and works in scope of successful bidder will be held once in a month at site/HQ. These meetings will be attended by reasonably higher officials of the successful bidder and will be used as a forum for discussing all areas where progress needs to be speeded up. The successful bidder shall be further responsible for ensuring that suitable steps are taken to meet various targets decided upon such meetings.
11.3.6	During construction successful bidder shall take adequate digital photograph/ slides (indicating date) each month (not less than nine per week) of the works during progress and submit the soft/hard copy to BHEL office.
11.3.7	Successful bidder has to provide for electronic/ computerized storing and re-production/ printing/ plotting of various data, log sheets, protocols, measurements etc. These may be stored in CD (as per requirement) and handed over to BHEL as per requirement.
<b>11.4</b>	<b>SITE ORGANIZATION</b>
11.4.1	Successful bidder shall maintain a site organization of adequate strength in respect of manpower, construction machinery and other implements at all time for smooth execution of the contract headed by a competent Site In-charge (SIC) for site operations with sufficient level of authority to take site decisions. The successful bidder will submit organization chart (showing the name of SIC) with individual bio-data indicating various levels of experts to be posted for supervision in the fields of supervision & execution, quality, material management, planning, safety, etc. The organization shall be reinforced from time to time, as required to make up slippage (if any) from schedule without any commercial implication to BHEL. The organization chart is to be submitted within 10 days from date of LOI.

**Guidelines for Selection of NDE agency for RT (Radiography Test), UT & MPI and Heat Treatment**

**1. Guidelines for Selection of NDE agency for RT**

- A. The NDE agency should have executed at least 30% of the proposed work quantity in a similar single job. In case, multiple agencies are proposed to be deployed, each agency should have executed at least 30% of proposed quantity in a similar single job. The necessary documents (*viz.* copy of Work Order, End User Performance Certificate, *etc.*) for above to be produced by agency.
- B. Agency will submit their organizational setup, supervision arrangement and list of radiography sources to be deployed at site.
- C. Agency to submit the documents of BARC / AERB Level- I & II personnel for doing RT & Interpretation of films, respectively. Personnel's skill & capability will be reviewed by FQA before engaging them in job.
- D. The agency shall comply with all safety norms as per BARC/AERB & agency must submit source movement authorization for the subject site from BARC/AERB before start of work. The source movement within the site shall also be maintained by the agency in the log book. The agency shall fulfil all the safety precautions as per statutory requirements including Radiological safety at their own cost.
- E. Manpower & Resources:
  - i. For a single unit, the agency shall deploy one BARC/AERB certified site in-charge and minimum of two numbers of BARC/AERB qualified Level-1 radiographers for deployment of each number of source and one number of Trained, experienced and BARC/AERB qualified RT Level-11 film interpreter. Personnel's skill & capability will be reviewed by FQA before engaging them in job.
  - ii. Agency shall mobilize one full time Radiation Safety Officer (RSO) and one site incharge at site and maintained as per BARC and BHEL OCP guidelines.
  - iii. For a single unit, the NDE agency shall have permission from BARC/AERB for mobilizing a minimum of two radioactive sources (as per contractual guidelines) of sufficient strength all the time (minimum of 10 Curie). The source should be replaced immediately after decay to 10 Curie. Agency shall be capable to arrange additional source on emergency.
  - iv. The Agency has to submit the decay chart and all records regarding movement of the source.
  - v. The agency should be responsible for security of their source in the plant or during movement of camera at site.
  - vi. All employees of the agency to use TLD badges & pocket dosimeters while doing radiography testing at site. Also submit annual dose report of radiation workers.

- vii. The agency to calculate cordon-off distance & provide 'Radiography warning sign boards & symbols' with cordon-off rope & warning alarm while carrying out the radiography.
  - viii. Radiography team to be available at site round the clock
  - ix. Equipment, Film and other consumables used shall be BHEL approved brands.
- F. Agency has to demonstrate and establish various parameters for the quality of radiograph (*e.g.* Image density, sensitivity, source size, source to film distance, geometric unsharpness etc.) to the satisfaction of BHEL.

### **2. Specific Guidelines for selection of NDE Agency for UT & MPI**

- A. The NDE agency should have executed at least 30% of the proposed work quantity in a similar single job. In case, multiple agencies are proposed to be deployed, each agency should have executed at least 30% of proposed quantity in a similar single job. The necessary documents (viz. copy of Work Order, End User Performance Certificate, etc.) for above to be produced by agency.
- B. Agency will submit their organizational setup, supervision arrangement and list of resources to be deployed at site.
- C. For a single unit, the NDE agency shall deploy a minimum of two number Digital type Pulse Echo A Scan UT equipment (preferably of OLYMPUS, EINSTEIN-II & Krautkramer) along with required calibration block at site.
- D. For a single unit, the NDE agency shall deploy a minimum of two numbers of Trained, experienced and certified Level-I UT technicians and one number of Trained, experienced and certified Level-II Interpreter in UT.
- E. For a single unit in MPI work, the NDE agency shall deploy a minimum of two sets of magnetic yokes, pie indicators, iron oxide particles, colour contrast, etc. Should have portable AC/HWAC equipment delivering current of minimum of 1000 amps and portable AC/DC electromagnetic yokes. Calibrated Equipment/ Ammeters shall be used for testing. The equipment should be capable of testing with visual and fluorescent magnetic particles.
- F. The agency shall deploy a minimum of two numbers of Trained, experienced and certified Level-I technician in MPI and one number of Trained, experienced and certified Level-III Interpreter in MPI

### **3. Specific Guidelines for selection of Heat Treatment Agency**

- A. The NDE agency should have executed at least 30% of the proposed work quantity in a similar single job. In case, multiple agencies are proposed to be deployed, each agency should have executed at least 30% of proposed quantity in a similar single job. The necessary documents (viz. copy of Work Order, End User Performance Certificate, etc.) for above to be produced by agency.

- B. Agency will submit their organizational setup, supervision arrangement and list of resources to be deployed at site.
- C. The T & P's for Resistance Heating being deployed by Heat Treatment agency at site viz. PID Control Heating panels, Thermocouples, heating elements, Recorders shall be calibrated and in good working condition. Also to be noted that insulation being used should be in workable condition.
- D. The T & P's for Induction Heating being deployed by Heat Treatment agency at site viz. Induction Heating equipment, induction cables, Thermocouples, recorders shall be calibrated and in good working condition. Also, to be noted that insulation being used should be in workable condition.
- E. The agency shall be capable of mobilising required number of machines and against each machine one experienced operator & one technician-cum-electrician must be deployed. The competency of operator & condition of equipment must be verified at site
- F. The agency should have capability of mobilising flexible ceramic pads as & when advised by BHEL.
- G. One trial Heat Treatment must be conducted by BHEL FQA engineer before start of work, to assess the competency of the deployed persons and the condition of the machinery. The thickness may be selected based on the maximum thickness material to be heat treated at site.

*Note : Applicant shall submit supporting documents along with Annex S1-a and Annex S1-b*

## SPECIAL CONDITIONS OF CONTRACT (SCC) - Boiler Package

### Annex S1-a

**Application for approval of NDE / Heat Treatment Agency at .....**  
(Name of Project)

Name of the NDE / Heat Treatment Agency : .....  
Address : .....

Name of the Proprietor : .....  
Contact No. : .....  
Email address : .....

1. Details of Qualified / Certified NDT Personnel (ASNT / ISNT)  
(Including BARC certified Radio grapher-RT-1, Site In-charge-RT-2, RSO)

Sl. No.	Name	NDT Method	Level	Date of first Certification	Certificate Valid upto	Certifying Authority

2. Details of Heat Treatment Personnel

Sl. No.	Name	Qualification	Previous Experience

3. Details of NDE / HT Equipment proposed to be mobilized

Sl. No.	Equipment (Make)	Type (RT/ UT/ MPI/ PAUT/ HT)	Quantity	Specification / Rating	Capacity of the Equipment

4. Details of Previous work done (in past 3 years):

Sl. No.	Project Name & Customer	Type of Job (RT/ UT/ MPI/ PAUT/ HT)	Number of Tube Joints completed	Number of Pipe Joints Completed

.....  
Signature of the Owner of the Agency & seal

.....  
Signature of BHEL's E&C Associate & seal

**Check list for Annex S1-a**

Note : Applicant shall fill the following details and no column shall be left blank		
<b>Sl. No.</b>	<b>Description</b>	
A.	Name of the Proposed Agency	
B.	Quantum of job being proposed for the agency	
C.	Copy of agencies Govt. Registration	Page no.
D.	Duly filled in Annex S1-a	Page no.
E.	Certificates for Individuals as mentioned in Sl. No. 1 of Annex S1-a (Not applicable for HT agency)	Page no. from ..... to .....
F.	AERB approval certificate (for RT agency Only)	Page no. from ..... to .....
G.	Supporting documents for previous work Experience as mentioned in Sl. No. 2 of Annex S1-a	Page no. from ..... to .....
H.	Supporting documents for previous work Experience as mentioned in Sl. No. 3 of Annex S1-a	Page no. from ..... to .....

.....  
Signature of BHEL's E&C Associate & seal