

**2 x 500 MW SAGARDIGHI TPS  
UNIT # 3 & 4**


**VOLUME: IIB & III**

**TECHNICAL SPECIFICATION  
FOR  
LT XLPE FIRE SURVIVAL CABLES**

**SPECIFICATION NO.: PE-TS-373-507-E005, Rev. 00**



**BHARAT HEAVY ELECTRICALS LIMITED  
POWER SECTOR, PROJECT ENGINEERING MANAGEMENT  
NOIDA 201301**

	<b>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</b>	<b>Doc. No. PE-TS-373-507-E005</b>	
		<b>Volume IIB</b>	<b>Section ---</b>
		<b>Rev. : 0</b>	<b>Date : 25.11.11</b>
		<b>Page 1</b>	

## PREAMBLE

1 The Tender document contains three (3) volumes. The bidder shall meet the requirements of all three volumes.

### 1.1 VOLUME - I **CONDITIONS OF CONTRACT**

This consists of four parts as below:-

**Volume – IA** This part contains Instructions to bidders for making bids to BHEL.

**Volume – IB** This part contains General Commercial Conditions of the Tender & includes provision that vender shall be responsible for the quality of item supplied by their sub-vendors.

**Volume – IC** This part contains Special Conditions of Contract.

**Volume – ID** This part contains Commercial conditions for Erection & Commissioning site work, as applicable.

### 1.2 VOLUME – II **TECHNICAL SPECIFICATIONS**

Technical requirements are stipulated in Volume – II, which comprises of:-

**Volume – IIA** General Technical Conditions.

**Volume – IIB** Technical Specification including Drawings, if any.

### 1.3 VOLUME – IIB

This volume is sub-divided in to following sections:-

**Section – A** This section outlines the Intent of Specification

**Section – B** This section provides “Projection Information”.

**Section – C** This section indicates Technical Requirements specific to Contract, not covered in Section -- D

**Section – D** This section comprises of Technical Specifications of Equipments Complete with Datasheets A, B, C.

**Data sheet - A: -** Specific data and other requirements pertaining to the equipments.


**Data sheet - B: -** Specific Data to be filled by bidder (Data Sheet - B is contained in Volume - III).

**Data sheet – C: -** Indicates data / documents to be furnished after the award of Contract as per agreed schedule by the vendor (as applicable)

### 1.4 VOLUME – III

This volume contains Technical Schedule and Data Sheets–B, which are to be duly filled by bidder and the same shall be furnished with the technical bid.

2.0 This requirements mentioned in Section – C / Data Sheet – A of Section – D shall prevail and govern in case of conflict between the same and the corresponding requirements mentioned in the descriptive portion in Section – D.

	<b>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</b>	Doc. No. PE-TS-373-507-E005	
		Volume IIB	Section A
		Rev. : 0	Date : 25.11.11
		Page 1	


**CONTENTS (VOL-II B)**

<b><u>S. NO.</u></b>	<b><u>CONTENTS</u></b>	<b><u>NO. OF SHEETS</u></b>
01	PREAMBLE	01
02	CONTENTS	01
03	SECTION – ‘A’ (SCOPE OF ENQUIRY)	02
04	SECTION – ‘B’ (PROJECT INFORMATION)	02
05	SECTION – ‘C’ (SPECIFIC TECHNICAL REQUIREMENTS)	03
06	ANNEXURE-A TO SECTION-C (BOQ)	01
07	SECTION – ‘D’ (STANDARD TECHNICAL SPECIFICATION)	03
08	DATA SHEET-A INCL. TESTING REQUIREMENTS	06
09	DATA SHEET-C (GUARANTEED TEST PARTICULARS)	05


**CONTENTS (VOL-III)**

09	DATA SHEET – ‘B’	04
10	TECHNICAL DEVIATION/ CLARIFICATION SHEET	01

**TOTAL NO. OF SHEETS= 30**  
(INCLUDING COVER/ SEPARATOR SHEETS)


	<b>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</b>	Doc. No. PE-TS-373-507-E005	
		Volume IIB	Section A
		Rev. : 0	Date : 25.11.11
		Page 1	

**SECTION – A**  
**(SCOPE OF ENQUIRY)**

	<b>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</b>	Doc. No. PE-TS-373-507-E005	
		Volume IIB	Section A
		Rev. : 0	Date : 25.11.11
		Page 1	

### SCOPE OF ENQUIRY

- 1.0 This specification covers the design, manufacture, inspection and testing at manufacturer's works, proper packing and delivery of **LT XLPE FIRE SURVIVAL CABLES** to 2 x 500 MW SAGARDIGGI TPS site as mentioned in different sections of this specification for the project as indicated in Section B (Project Information).
- 2.0 It is not the intent to specify herein all the details of design & manufacture. However, the equipment shall conform in all respects to high standards of design engineering and workmanship and shall be capable of performing in continuous commercial operation up to bidder's guarantee.
- 3.0 The general terms and conditions, instructions to bidders and other attachment referred to elsewhere be hereby made part of technical specification.
- 4.0 The bidders shall be responsible for and governed by all requirements stipulated hereinafter.
- 5.0 Requirements of the specification shall be agreed upon for total compliance by Bidders without any deviations.  
Price offers of only those bidders complying with the above requirement shall be acceptable.
- 6.0 The documents shall be in English language and MKS system of units.

	<b>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</b>	Doc. No. PE-TS-373-507-E005	
		Volume IIB	Section C
		Rev. : 0	Date : 25.11.11
		Page 1	

## **SECTION – B**

**(PROJECT INFORMATION)**



DOCUMENT TITLE:

**TECHNICAL SPECIFICATION  
FOR LT XLPE FIRE SURVIVAL CABLES**

SPECIFICATION NO. PE-TS-373-507-E005

VOLUME NO. : **II-B**

SECTION :

REV NO. : **0** DATE: 25.11.2011SHEET : **1** OF **1****1. SOURCE OF COAL**

The Power Station has been linked to Jhanjra, Chitra and Sarpi mines of Eastern Coal fields (ECL) and Panchwara & Damagoria for extension units.

Coal will be transported on broad-gauge line of Eastern Railways from the coal fields to the Power station in BOBRN rake loads.

Fuel oil (HFO/LDO) will normally be transported by railway oil tankers from nearest oil depot.

**2. SOURCE OF WATER**

The water requirement for the Power station will be met by drawing water from river Bhagirathi at a distance of 6 KM east of project site.

The Power station will operate on closed cooling system using Natural Draft Cooling Towers. In addition, all water conservation and recycling measures will be adopted to minimize requirement of makeup water.

**3. ASH DISPOSAL AREA**


The ash disposal area for the station is located about 1 Km from the plant site.

The Site Location Plan will give an idea of the locations of the site, colony, ash disposal area and rail and road connections.

**4. SALIENT CLIMATOLOGICAL AND DESIGN DATA**

Unless otherwise specified, the following design conditions shall be considered for the equipment offered:


- a) Design ambient dry bulb : 50 °C maximum, 5 °C minimum temperature
- b) Maximum relative humidity : 84%
- c) Average relative humidity : 73%
- d) Highest wet bulb temp. : 26.9 °C
- e) Average annual rainfall : 1389 MM
- f) Seismic zone : Zone-III as per IS-1893 latest revision
- g) Wind load : In accordance with IS-875 for a basic wind speed of 47 m/sec upto a height of 10 metres above mean ground level. For further details refer Volume II-G of this specification.
- h) Altitude : 34M above MSL.

	<b>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</b>	Doc. No. PE-TS-373-507-E005	
		Volume IIB	Section C
		Rev. : 0	Date : 25.11.11
		Page 1	

## **SECTION – C**

**(SPECIFIC TECHNICAL REQUIREMENTS)**



	<b>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</b>	Doc. No. PE-TS-373-507-E005	
		Volume IIB	Section C
		Rev. : 0	Date : 25.11.11
		Page 2	

## 1.0 SCOPE OF ENQUIRY

- 1.1 This enquiry covers the supply of LT XLPE Fire Survival Cables conforming to this specification as detailed below.
- 1.2 General technical requirements of the cables are indicated in Section-D. Project specific technical/ quality requirements/ changes are listed in Datasheet-A and below.
- 1.3 Cables shall conform in all respects to the requirements stipulated in all the above parts of the specification.
- 1.4 The stipulations of Section-C, followed by those of Datasheet-A shall prevail in case of any conflict between the stipulations of Section-C, Datasheet-A and Section-D.

## 2.0 BILL OF QUANTITIES:

- 2.1 Quantity requirements shall be as per Annexure-A (Bill of Quantities (BOQ)) enclosed.
- 2.2 Delivery schedule (i.e. contractual calendar dates) for the package shall be given separately to the bidders for compliance. Supplies shall be completed conforming to the lot requirements stipulated in the BOQ within the overall delivery schedule.

## 3.0 SPECIFIC TECHNICAL REQUIREMENTS

### 3.1 Technical:

- (a) Latest revisions of all relevant Standards in this specification shall be referred.
- (b) Data Sheet-B for power cables (enclosed with Vol. III of this specification) shall be duly filled in and furnished along with the offer. Data Sheet-B in the enclosed format only shall be accepted. Data furnished in any other format will make the offer incomplete and shall not be considered for analysis.

### 3.2 Quality/ Inspection:


The successful bidder shall submit their Manufacturing Quality Plan. The same shall be subject to customer/ BHEL approval.

- 3.3 The successful bidder shall submit the standard list of raw material suppliers/ sub-vendors of each bidder for approval without any commercial implications. Changes to the same for specific projects, if proposed by any bidder, shall be to BHEL approval.

### 3.4 Technical & Quality documentation to be submitted by all bidders is as under:

- (i) Data Sheet-B [Refer 3.1 (b)]
- (ii) Technical Deviations, if any in the format enclosed with Vol-III of TS.
- (iii) Technical Catalogue
- (iv) Type Test Reports of similar type of cables supplied by bidder in various other contracts. [Refer 2.4.1 (b), Section-D].
- (v) List of orders/ customers to whom bidder has supplied Fire Survival Cables.

### 4.0 Document distribution schedule for the project shall be as per ANNEXURE-I attached.

	<b>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</b>	Doc. No. PE-TS-373-507-E005	
		Volume IIB	Section C
		Rev. : 0	Date : 25.11.11
		Page 2	

5.0 List of drawings / documents required to be furnished by successful bidder after award of contract shall be as below:


SL. No.	DOCUMENT TITLE	DWG. / DOCUMENT No.
1	Data Sheet for LT Fire Survival Power Cables	PE-V5-373-507-E001
2	Cross-sectional Drawings for LT Fire Survival Power Cables	PE-V5-373-507-E002
3	Quality Plan for LT XLPE Fire Survival Power Cables	PE-V5-373-507-E003
4.	Type Test Reports for Tests conducted under this contract	PE-V5-373-507-E004
5	Type Test Procedures/ Schedule	PE-V5-373-507-E005
6	Acceptance test procedures/ Schedule	PE-V5-373-507-E006

**BILL OF QUANTITY FOR LT XLPE FIRE SURVIVAL CABLES**

<b>COPPER CONDUCTOR, XLPE INSULATED, ARMoured FIRE SURVIVAL CABLE</b>			
<b>APPLICABLE TO TECHNICAL SPECIFICATION No. PE-TS-373-507-E005</b>			
<b>S. No.</b>	<b>Cable Sizes (no. of cores Cross section area (sqmm))</b>	<b>Order Quantity (meters)</b>	<b>Drum Length (meters)</b>
1	1C-300	1000	500


**Notes:**

- Quantities indicated above shall be known as Order Quantities. Quantity variation shall be +/- 30% of total quantity till the completion of supplies for the Project.
- The bidder shall indicate the unit price of each type and size of cables listed above. The unit prices shall apply for adjustment of variation in quantity as stipulated above.
- Order Quantity shall be cleared for manufacturing along with LOI. However, manufacturing of the cables shall be taken up by the successful bidder only after approval of technical and quality documentation, and supply shall be completed within four months from the date of approval of documentation. Subsequent lots shall be cleared for manufacture based on progress of engineering and site requirements. A lead-time of three months shall be given for completion of supply for each subsequent lot from the date of clearance of the quantities.
- The standard drum length shall be as indicated above. Tolerance on individual drum length shall be  $\pm 5\%$ .
- Overall tolerance on total dispatched quantity of each size shall be **(-) 2% and (+) 0%**. Cables consumed for testing and inspection shall be to bidder's account.
- Bidder shall indicate unit price of cables inclusive of type test charges. No separate charges shall be payable for type tests.

	<b>3</b>  <b>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</b>	<b>Doc. No. PE-TS-373-507-E005</b>	
		<b>Volume IIB</b>	<b>Section D</b>
		<b>Rev. : 0</b>	<b>Date : 25.11.11</b>
		<b>Page 1</b>	

## SECTION – D

### STANDARD TECHNICAL SPECIFICATION

	<b>3</b>  <b>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</b>	<b>Doc. No. PE-TS-373-507-E005</b>	
		<b>Volume IIB</b>	<b>Section D</b>
		<b>Rev. : 0</b>	<b>Date : 25.11.11</b>
		<b>Page 2</b>	

## 1.0 TECHNICAL REQUIREMENTS

- 1.1 Technical requirements for LT XLPE cables shall be as indicated in this section.
- 1.2 Project specific technical requirements shall be indicated in Datasheet-A and Section–C.

## 2.0 QUALITY ASSURANCE REQUIREMENTS


- 2.1 Bidder shall confirm compliance with BHEL Quality Plan as attached with the specification without any deviations.
- 2.2 The successful bidder shall submit the Manufacturing Quality Plan (MQP) for approval by BHEL/ Owner during detailed engineering stage without any commercial implications.
- 2.3 Bidders shall submit their list of proven sub-vendors for raw materials, which will be to approval/acceptance.
- 2.4 Testing requirements shall be as detailed below.
  - 2.4.1 Type Tests
    - a. All cables to be supplied shall conform to type tests as per relevant standards and proven type.
    - b. The bidder shall furnish the reports of all the type tests listed in Annexure-B of S. No. II of Datasheet-A carried out in within last five years of the date indicated in Section–C. These reports should be for the tests conducted either in government approved third party laboratory or witnessed by client (such as major utilities/ industries) on identical/ similar cables to those ordered under this contract.
    - c. Irrespective of the bidder furnishing type test report as indicated above, BHEL will get type tests conducted (indicated in Datasheet-A) on the lots offered for inspection.
    - d. Minor changes in the final Type Test Procedure (which shall be to approval during contract stage) shall be without any commercial implication.
  - 2.4.2 Routine and Acceptance Tests
    - a. Routine testing shall be conducted in line with the applicable standards and as per the Manufacturing Quality Plan approved for the project for every lot offered for inspection.
    - b. Acceptance tests shall be conducted on every lot offered for inspection as per details indicated in Datasheet A.
  - 2.4.3 Cost of conduction of routine, type and acceptance testing shall be deemed to have been included in the quoted supply prices.
  - 2.4.4 Cost of cables consumed for testing shall be to bidder's account.

## 3.0 PACKING

- 3.1 Cables shall be supplied in non-returnable heavy construction drums. All wooden parts shall be manufactured from seasoned wood treated with copper naphthenates/ zinc naphthenates (refer IS: 401). All ferrous parts shall be treated with suitable rust protective finish or coating to avoid rusting during transit and storage. BIS certification mark shall be stamped on each cable drum.


## 4.0 PROJECT SPECIFIC TECHNICAL AND QUALITY DOCUMENTATION TO BE SUBMITTED

- 4.1 During tender stage (Before award of contract): Refer clause 3.1, 3.4 Section-C
- 4.2 The following documents shall be submitted by Successful Bidder (for approval during contract stage)


	<b>3</b>  <b>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</b>	<b>Doc. No. PE-TS-373-507-E005</b>	
		<b>Volume IIB</b>	<b>Section D</b>
		<b>Rev. : 0</b>	<b>Date : 25.11.11</b>
		<b>Page 3</b>	

- a. Cross-section drawings of the cables.
- b. Datasheet C in the format provided to the successful bidder along with LOI.
- c. Manufacturing Quality Plan in case BHEL SQP is not applicable.
- d. List of sub-vendors/ suppliers of raw materials.
- e. Type Test Procedure.
- f. Field Quality Plan.
- g. Type Test Procedure.

- 4.3 Two copies of the above documentation shall be submitted for first review. Number of copies to be submitted for second and subsequent submissions (till Cat-I approval is accorded), and those for final distribution prints of approved documentation and test certificates shall be as indicated separately in section C.
- 4.4 Wherever required, soft copy of all approved technical/ quality documentation shall be submitted as specified without any additional commercial implication. Soft copies may be required both in native file format (e.g. MS Word/ MS Excel) as well as PDF files.

<sup>1</sup> 	<b>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</b>	Doc. No. PE-TS-373-507-E005	
		Volume III	Section ---
		Rev. : 0	Date : 25.11.11
		Page 1	

**DATASHEET A**


	<b>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</b>	Doc. No. PE-TS-373-507-E005	
		Volume III	Section ---
		Rev. : 0	Date : 25.11.11
		Page 2	

## DATA SHEET-A

### I. TECHNICAL DATA;

1.0	Type of Cable	Fire Survival cables (FS type)
2.0	Standard applicable in general	BS 7846/ BS 6724 & Technical specification
3.0	Voltage Grade	1100V
4.0	Number of cores, cross sectional area of conductors and quantities	As per BOQ, Annexure-A to Section-C
5.0	<b>CONDUCTOR</b>	
(a)	Material	Copper Un-Tinned
	Grade and Class	Stranded plain Class 2
(b)	Standard Applicable	BS 6360
(c)	Shape	Circular/Circular Compacted/ shaped
(d)	Min. number of strands	As per Table-2 of BS-6360
6.0	<b>FIRE BARRIER TAPE</b>	Glass Mica tape in two layers with minimum 50% overlap, suitable to meet performance requirements as per Clause 12.0 below
7.0	<b>INSULATION</b>	
(a)	Material	GP8 (XLPE)
(b)	Standard Applicable	BS 7655, Section-1.2 OR BS 7655, Section-1.3
(c)	Continuous withstand temperature	90°C
(d)	Short-circuit withstand temperature	250°C
(e)	Method of application	Pressure extruded (sleeve extrusion is not acceptable).
7.0	<b>CORE IDENTIFICATION</b>	Colour coding as per BS 6724
8.0	<b>INNER SHEATH</b>	
(a)	Material	Polymeric material
(b)	Colour	Black
(c)	Type	<b>LSZH, suitable to meet performance reqmt. mentioned at clause 11.0 below</b>
(d)	Fillers	Not Acceptable
(e)	Method of application	Pressure Extruded
9.0	<b>ARMOUR</b>	
(a)	Material:	Aluminium round wire as per BS 7846 & BS 6724
(b)	Gap between armour wires/ formed wires	Shall not exceed one armour round wire space (No cross-over/ over-riding).
(c)	Breaking load of joint	95 % of normal armour
10.0	<b>OUTERSHEATH</b>	
(a)	Material	Polymeric material
(b)	Colour	Black
(c)	Type	<b>LSZH, suitable to meet performance reqmt. as defined at clause 11.0 below</b>
(d)	Method of application	Pressure Extruded
(e)	Marking	A. By Embossing @ 5m interval 1. Cable size (Nominal cross sectional area and no. of cores) and voltage grade. 2. Letters "FS"



	<b>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</b>	Doc. No. PE-TS-373-507-E005	
		Volume III	Section ---
		Rev. : 0	Date : 25.11.11
		Page 3	

		3. Manufacturer's Name/Trade Name 4. Year of manufacture B. By Embossing/ Printing @ 1m interval:- Progressive sequential marking
11.0	<b>FRLS CHARACTERISTICS FOR OUTER SHEATH</b>	
(a)	Oxygen index at room temperature of 50 deg C	Min 30 (As per ASTM D 2863)
(b)	Temperature index	Min. 350°C (As per ASTM D 2863)
(c)	Acid gas generation	Max. 2.0% (as per IEC-60754-1)
(d)	Smoke density rating	Max. 20% as per ASTM D 2843
(e)	Flammability Test	As per IEC: 60332-I, Swedish chimney test & flammability test on multiple cables as per BS EN 50266, CAT-B
12.0	<b>FIRE RESISTANCE CHARACTERISTICS</b>	Meet the requirement of Circuit Integrity test for Min. 3HR. AT 750 DEG. C AS PER IEC 60331
13.0	<b>TEST FOR RODENT &amp; TERMITE TEST</b>	Applicable as per manufacturer standard
14.0	<b>TOLERANCE ON OUTER DIAMETER</b>	±2mm
15.0	<b>STANDARD DRUM LENGTH</b>	as specified in BOQ.

## II. TESTING REQUIREMENTS

### A. Type Test Conduction:


- Type tests are listed at Annexure-B in the last column as either 'T' or 'S' and the same shall be conducted as type tests on one size/lot of finished cable except the Fire Survival Test, Flammability tests & Electrical tests listed at clause no. 7,8 & 10 for which the sampling plan shall be 'all sizes/ lot'.  
The Type tests may be witnessed by BHEL/ Owner, for which due notice shall be given by the vendor.

### B Acceptance Test Conduction:


- Acceptance tests are listed at Annexure-B in the last column as 'A' and the same shall be conducted as acceptance tests.

### C. Routine Test Conduction:


- Routine tests are listed at Annexure-B in the last column as 'R' and the same shall be conducted on 100% of cables.

	<b>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</b>	Doc. No. PE-TS-373-507-E005	
		Volume III	Section ---
		Rev. : 0	Date : 25.11.11
		Page 4	

## TYPE TEST REQUIREMENTS FOR FRLS POWER CABLES


	<b>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</b>	Doc. No. PE-TS-373-507-E005	
		Volume III	Section ---
		Rev. : 0	Date : 25.11.11
		Page 5	

S. No.	TEST	APPLICABLE FOR	REF. STD	CLASSIFICATION OF TEST
<b>1.0</b>	<b>Tests for Conductor</b>			
a)	Persulphate test	For copper conductor only	BS-7846/BS-6360	S,A
b)	Annealing test	For copper conductor only	"	T, A
c)	Resistance test	For Cu	"	T, A,R
d)	Tensile, Wrapping & Elongation test	For Cu	"	T,A
<b>2.0</b>	<b>Tests for Armour</b>			
a)	Measurement of dimensions/Armour Diameter	for armour wire	BS-7846	S,A
b)	Mass of zinc coating test	For G. S. armour wires	"	T
c)	Wrapping test	Galvanized armour wires	"	T
d)	Armour resistance test	for armour wire	BS-7846	S,R
<b>3.0</b>	<b>Test for Fire Barrier Tape</b>		-	
a)	Test for minimum thickness	Fire barrier tape	-	S,A
<b>4.0</b>	<b>Tests for Insulation (XLPE/GP-8)</b>			
a)	Material	Applicable for insulation	BS-7846	T
b)	Test for thickness	"	"	S,A
c)	Spark Test	"	"	R
d)	Tensile strength and elongation test	Applicable for insulation	BS-7655,1.3	T,A
e)	Ageing in air oven	Applicable for insulation	BS 7846	T
f)	Insulation resistance	Applicable for insulation	"	T,A
g)	Hot set test	Applicable for insulation	"	T,A
h)	Water absorption test	Applicable for insulation	"	T
i)	Shrinkage of insulation	Applicable for insulation	BS-7846	T
j)	Abrasion	On complete cable	"	T
k)	Power factor & permittivity test	Applicable for insulation	"	A
<b>5.0</b>	<b>Test for Inner Sheath (Bedding)</b>		"	
	Physical Properties	Applicable for inner sheath	"	T
	Test for thickness	Applicable for inner sheath	"	S,A
	Corrosive and acid gas emission	Applicable for Inner sheath	IEC-60754-I	S
<b>6.0</b>	<b>Test for Over Sheath</b>		"	
	Physical Properties	Applicable for Over sheath	"	T
	Test for thickness	Applicable for Over sheath	"	S,A
	Spark test	Applicable for Over sheath	"	R
	Corrosive and acid gas emission	Applicable for Over sheath	IEC-60754-I	S

	<b>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</b>	Doc. No. PE-TS-373-507-E005	
		Volume III	Section ---
		Rev. : 0	Date : 25.11.11
		Page 6	

S. No.	TEST	APPLICABLE FOR	REF. STD	CLASSIFICATION OF TEST
	Shrinkage of over sheath	For complete cable	"	T
	IR constant of oversheath	For complete cable	"	T
<b>7.0</b>	<b>Flammability Tests</b>		"	
a)	Oxygen Index test	For PVC outer sheath only	ASTMD-2863	T,A
b)	Temperature index test	For PVC outer sheath only	ASTMD-2863	T,A
c)	Smoke density test	For PVC outer sheath only	ASTMD 2843	T,A
d)	Smoke emission	For complete cable	BS-7846	S,A
e)	Swedish chimney test	For complete cable	SEN-SS-424-1475	T
<b>8.0</b>	<b>Electrical Tests</b>			
a)	High Voltage Test	On complete cable	BS-7846	T,R
b)	Insulation Resistance Test (Volume resistivity method)	Over sheath	BS-7846	T
<b>9.0</b>	Compatibility	Over Complete cable	BS-7846	T
<b>10.0</b>	<b>Fire Survival Tests</b>			
a)	Flame propagation on single cable	For complete cable	IEC 60331	S,A
b)	Flame propagation on multiple cables	For complete cable	BS-50266, CAT-B	T


T & S: SHALL BE CONDUCTED AS TYPE TEST  
R: ROUTINE TEST  
A: ACCEPTANCE TEST

<div data-bbox="79 82 263 257"> <div>7</div>  </div>	<div data-bbox="263 82 973 257"> <div>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</div> </div>	Doc. No. PE-TS-373-507-E005	
		Volume III	Section ---
		Rev. : 0	Date : 25.11.11
		Page 7	

# DATASHEET C

## **GUARANTEED TECHNICAL PARTICULARS (TO BE SUBMITTED BY SUCCESSFUL BIDDER)**

The above shall be submitted by the successful bidder during contract stage in the format provided by BHEL.

	<b>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</b>	Doc. No. PE-TS-373-507-E005	
		Volume III	Section ---
		Rev. : 0	Date : 25.11.11
		Page 8	

**DATASHEET C**  
**GUARANTEED TECHNICAL PARTICULARS**  
**(TO BE SUBMITTED BY SUCCESSFUL BIDDER)**

**1.0 General**

1.1 Name of manufacturer :

1.2 Place of Manufacture :

**2.0 Standards applicable**

2.1 For general specification of XLPE Fire Survival Cables

2.2 For conductor material

2.3 For material of innersheath & outersheath.

2.4 For armour of 3 core/ single core cables

2.5 For method of tests in general

2.6 For cable drums

2.7 For oxygen index test

2.8 For flammability test

For Fire Survival Test

2.9 For acid gas generation test on outer sheath

2.10 For smoke generation test on outer sheath

2.11 Current rating of cables conforms to :

2.12 Short circuit rating conforms to :

**3.0 CABLE CONSTRUCTION**

BIDDER TO SPECIFY SIZE WISE (WHEREVER APPLICABLE)

3.1 VOLTAGE GRADE

3.2 No. of Cores X Size

3.3 BASE CURRENT RATING AS PER STANDARD


(a) INSTALLATION CONDITIONS

(i) In air

(ii) In ground

(iii) In ducts

3.4 SHORT CIRCUIT RATING & STANDARD REF.

	<b>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</b>	Doc. No. PE-TS-373-507-E005	
		Volume III	Section ---
		Rev. : 0	Date : 25.11.11
		Page 9	

### 3.5 CONDUCTOR

- |    |   |   |         |
|----|---|---|---------|
| a) | Conductor material, grade & standard                      | : |         |
| b) | Shape of conductor  | : |         |
| c) | No & dia of wires in each core<br>before stranding        | : | no x mm |
| d) | Applicable standard                                       | : |         |
| e) | D.C. resistance of conductor at<br>20 deg. C              | : | ohm/km  |
| f) | A.C. resistance of conductor at<br>90 deg. C              | : | ohm/km  |
| g) | Reactance of cable<br>at normal frequency                 | : | ohm/km  |
| h) | Electrostatic capacitance of cable<br>at normal frequency | : | mF/km   |
| i) | Maximum conductor temperature                             | : |         |
| j) | Maximum Short Circuit Temperature                         | : |         |

### 3.6 HEAT BARRIER TAPE

- |    |                        |
|----|------------------------|
| a) | Material               |
| b) | Thickness of tape      |
| c) | No. of layers, overlap |
| d) | Standard ref.          |

### 3.7 INSULATION

- |    |  |
|----|--|
| a) | Material & standard  |
| b) | Method of cross –linking                                     |
| c) | Method of curing   |
| d) | Extrusion process  |
| e) | Thickness of insulation &<br>Minimum thickness of insulation |
| f) | Dielectric strength of insulation.                           |
| g) | Resistivity of insulation                                    |
| h) | Acid gas generation of insulation & tape in %                |

### 3.8 CORE IDENTIFICATION


Specify standard

### 3.9 INNER SHEATH

- |    |                                   |
|----|-----------------------------------|
| a) | Material & type                   |
| b) | Extrusion process                 |
| c) | Nominal & minimum Thickness       |
| d) | Type & Shape of fillers (if used) |
| e) | Colour                            |

### 3.10 ARMOUR

- |    |                                 |
|----|---------------------------------|
| a) | Material, type & standard       |
| b) | Dimensions                      |
| c) | No. of wires                    |
| d) | Maximum DC resistance of armour |
| e) | Maximum AC resistance of armour |
| f) | Minimum coverage                |

	<b>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</b>	Doc. No. PE-TS-373-507-E005	
		Volume III	Section ---
		Rev. : 0	Date : 25.11.11
		Page 10	

### 3.11 OUTER SHEATH

- a) Material & type
- b) Extrusion process
- c) Nominal & minimum Thickness
- d) Colour

### 4.0 Permissible voltage & frequency variation

- a) Voltage : (+/-)10%
- b) Frequency : (+/-) 5 %
- c) Voltage-frequency combined : |ABS| 10%

### 5.0 CHARACTERISTICS OF LSLH INNER & OUTER SHEATH (SPECIFY ALONG WITH STANDARD)

- a) Oxygen index at room temp. of 50 deg. C :
- b) Temperature index :
- c) Acid gas generation :
- d) Smoke density rating :

### 2.0 Applicable Tests under Fire conditions For single cable & multiple cables

### 3.0 Applicable Standard for Circuit Integrity Test

- a) Temperature
- b) Duration

### 8.0 CABLE DRUMS

- a) Type & construction :
- b) Standard drum length : as per BoQ
- c) Tolerance on drum length : (+/-) 5%

### 9.0 DOCUMENTATION


Whether following enclosed

- a) X-sectional drawing with constructional details :
- b) Manufacturer Quality Plan :
- c) Type test, Acceptance test & routine test reports
- d) Technical Catalog
- e) List of orders/ customers to whom bidder has supplied Fire Survival cables

### 10.0 Diameters in mm.

- a) Overall Dia of Conductor
- b) Overall dia over taped conductor
- c) Approximate cable diameter of insulated conductor
- e) Approximate Cable diameter under armour/over inner sheath



	<b>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</b>	<b>Doc. No. PE-TS-373-507-E005</b>	
		<b>Volume III</b>	<b>Section ---</b>
		<b>Rev. : 0</b>	<b>Date : 25.11.11</b>
		<b>Page 11</b>	

- f) Approximate cable diameter over armour  
g) Approximate overall diameter of cable

11.0 Tolerance on overall diameter : (±)mm

12.0 Minimum bending radius : x O.D.

13.0 Safe pulling force : kg.

14.0 Weight of cable components/ cable in Kg/ m

- (i) Weight of conductor
- (ii) Weight of Fire Barrier Tape
- (iii) Weight of XLPE
- (iv) Weight of PVC/ Polymeric material
- (v) Weight of armour (Galvanised steel/ Aluminium)
- (vi) Total weight of cable

15.0 Shipping weight : kg.

16.0 Identification mark on outer sheath : A) By embossing @5m interval

1) Cable size (Nominal cross sectional area and no. of cores) and voltage grade

2) Letters "FS"

3) Manufacturer's Name/Trade mark


4) Year of manufacture

5) 2 x 600 MW Malwa TPS

B) By embossing /printing @ 1m interval progressive sequential marking

<div data-bbox="79 80 263 257"> <div>12</div> <div>बी एच ई एल</div> <div>BHEL</div> </div>	<div data-bbox="263 80 973 257"> <div>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</div> </div>	Doc. No. PE-TS-373-507-E005	
		Volume III	Section ---
		Rev. : 0	Date : 25.11.11
		Page 12	

**DATASHEET B**

	<b>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</b>	Doc. No. PE-TS-373-507-E005	
		Volume III	Section ---
		Rev. : 0	Date : 25.11.11
		Page 13	

**DATASHEET B**

**(TO BE SUBMITTED ALONG WITH THE BID)**

**1.0 General**

1.1 Name of manufacturer :

1.2 Place of Manufacture :

**2.0 Standards applicable**

2.1 For general specification of XLPE Fire Survival Cables

2.2 For conductor material

2.3 For material of innersheath & outersheath.

2.4 For armour of 3 core/ single core cables

2.5 For method of tests in general

2.6 For cable drums

2.7 For oxygen index test

2.8 For flammability test  
For Fire Survival Test

2.9 For acid gas generation test on outer sheath

2.10 For smoke generation test on outer sheath

2.11 Current rating of cables conforms to :

2.12 Short circuit rating conforms to :

**3.0 CABLE CONSTRUCTION**

BIDDER TO SPECIFY SIZE WISE (WHEREVER APPLICABLE)


3.1 VOLTAGE GRADE

3.2 No. of Cores X Size

3.3 BASE CURRENT RATING AS PER STANDARD

- (a) INSTALLATION CONDITIONS
- (vii) In air
- (viii) In ground
- (ix) In ducts

3.4 SHORT CIRCUIT RATING & STANDARD REF.

	<b>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</b>	Doc. No. PE-TS-373-507-E005	
		Volume III	Section ---
		Rev. : 0	Date : 25.11.11
		Page 14	

### 3.5 CONDUCTOR

- |    |   |   |         |
|----|---|---|---------|
| e) | Conductor material, grade & standard            | : |         |
| f) | Shape of conductor                              | : |         |
| g) | No & dia of wires in each core before stranding | : | no x mm |
| h) | Applicable standard                             | : |         |
| e) | D.C. resistance of conductor at 20 deg. C       | : | ohm/km  |
| f) | A.C. resistance of conductor at deg. C          | : | ohm/km  |
| g) | Maximum conductor temperature                   | : |         |
| h) | Maximum Short Circuit Temperature               | : |         |

### 3.6 HEAT BARRIER TAPE

- |    |                        |
|----|------------------------|
| i) | Material               |
| j) | Thickness of tape      |
| k) | No. of layers, overlap |
| l) | Standard ref.          |

### 3.7 INSULATION

- |    |   |
|----|---|
| i) | Material & standard                                       |
| j) | Method of cross –linking                                  |
| k) | Method of curing  |
| l) | Extrusion process   |
| m) | Thickness of insulation & Minimum thickness of insulation |
| n) | Dielectric strength of insulation.                        |
| o) | Resistivity of insulation                                 |
| p) | Acid gas generation of insulation & tape in %             |

### 3.8 CORE IDENTIFICATION


Specify standard

### 3.9 INNER SHEATH

- |    |                                   |
|----|-----------------------------------|
| a) | Material & type                   |
| b) | Extrusion process                 |
| c) | Nominal & minimum Thickness       |
| d) | Type & Shape of fillers (if used) |
| e) | Colour                            |

### 3.10 ARMOUR

- |    |                                 |
|----|---------------------------------|
| g) | Material, type & standard       |
| h) | Dimensions                      |
| i) | No. of wires                    |
| j) | Maximum DC resistance of armour |
| k) | Maximum AC resistance of armour |
| l) | Minimum coverage                |

	<b>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</b>	Doc. No. PE-TS-373-507-E005	
		Volume III	Section ---
		Rev. : 0	Date : 25.11.11
		Page 15	

### 3.11 OUTER SHEATH

- a) Material & type
- b) Extrusion process
- c) Nominal & minimum Thickness
- d) Colour

### 4.0 Permissible voltage & frequency variation

- a) Voltage : (+/-)10%
- b) Frequency : (+/-) 5 %
- c) Voltage-frequency combined : |ABS| 10%

### 5.0 CHARACTERISTICS OF LSLH INNER & OUTER SHEATH (SPECIFY ALONG WITH STANDARD)

- a) Oxygen index at room temp. of 50 deg. C :
- b) Temperature index :
- c) Acid gas generation :
- d) Smoke density rating :

### 6.0 Applicable Tests under Fire conditions For single cable & multiple cables

### 7.0 Applicable Standard for Circuit Integrity Test

- c) Temperature
- d) Duration

### 8.0 CABLE DRUMS

- a) Type & construction :
- b) Standard drum length : as per BoQ
- c) Tolerance on drum length : (+/-) 5%

### 8.0 DIAMETERS in mm.

- a) Overall Dia of Conductor
- b) Overall dia over taped conductor
- c) Approximate cable diameter of insulated conductor
- d) Approximate Cable diameter under armour/over inner sheath
- e) Approximate cable diameter over armour
- f) Approximate overall diameter of cable


9.0 Tolerance on overall diameter : (±)mm

10.0 Minimum bending radius : x O.D.

11. Safe pulling force : kg.

### 12.0 Weight of cable components/ cable in Kg/ m

- (i) Weight of conductor
- (ii) Weight of Fire Barrier Tape
- (iii) Weight of XLPE
- (x) Weight of PVC/ Polymeric material
- (xi) Weight of armour (Galvanised steel/ Aluminium)
- (xii) Total weight of cable

<sup>1</sup> 	<b>TECHNICAL SPECIFICATION FOR LT XLPE FIRE SURVIVAL CABLES</b>	Doc. No. PE-TS-373-507-E005	
		Volume III	Section ---
		Rev. : 0	Date : 25.11.11
		Page 1	

**TECHNICAL DEVIATION/ CLARIFICATION SHEET**

S. NO.	REF. CLAUSE NO. OF TECHNICAL SPECIFICATION	TECHNICAL CLARIFICATION/ DEVIATION SOUGHT BY BIDDER