

	Document No: ETC-BOQ/GIS/NOTE.2 Rev.0
Title:	SCOPE NOTE 2 - PROJECT SPECIFIC SCOPE NOTE FOR E.T.C. WORKS
Sr No.	PARTICULARS
2.01	Cable fire sealing - Shall be as per TANGEDCO specification SE/C/UP/EE/E/OT No.01/2015-16, SECTION-3.27.
2.02	All ETC works shall be done as per BHEL/TANGEDCO Specification. Miscellaneous works pertaining to 400kV GIS and Pothyard are deemed inclusive. (enclosed).
2.03	Equipment bolted connection after being checked and tested shall be painted with anticorrosive paint / compound be welded. For rust protection, the welds shall be treated with zinc chromate primer and coated with zinc rich paint.
2.04	Attached Drawings i.e. SLD, PLAN, Section, EKD e.t.c. are tentative and subject for revision during detailed engineering / contract stage. Bidder to quote accordingly.
2.05	Rating & type of Battery & Battery Charger are tentative and subject for revision during detailed engineering / contract stage. Bidder to quote accordingly.