


PROJECT	2X660 MW UDANGUDI SUPERCRITICAL TPS, STAGE-I	
CUSTOMER	TAMILNADU GENERATION AND DISTRIBUTION CORPORATION LIMITED (TANGEDCO)	
CONSULTANT	TATA CONSULTING ENGINEERS LIMITED, BENGALURU	
	BHARAT HEAVY ELECTRICALS LTD. TRANSMISSION PROJECTS DIVISION	
UNIT:	CONTROL ROOM BUILDING: LAYOUT & RCC DETAILS OF FOUNDATION	
DRG. NO.:	TB-1-400-607-624_R1	R1

REPLY TO COMMENTS

Date: 17-03-2020

SL. NO.	Comments	Reply
1.	Refer comments in design doc and revise accordingly	Noted & incorporated.
2.	Delete ductile detailing refer comments in design	Incorporated.
3.	BHEL TO HAVE A THOROUGH INTERNAL CHECKS REGARDING CORRECTNESS OF CALNS,EQUPT.INPUTS,STAAD MODEL AND MATCHING OF DETAILS IN DWGS. THIS IS BHEL'S COMPLETE RESPONSIBILITY. PERFORM THESE CHECKS INTERNALLY AND CONFIRM VIDE CRS IN NEXT REVISION	Noted & incorporated.
4.	BETTER TO AVOID TAPERED FDNS DUE TO DIFFICULTY IN CONSTN,BHEL TO REVIEW THIS AND DECIDE ACCORDINGLY	Noted & incorporated.