

Quantity of Cable Glands for Sikka Project as Annexed to ETC-BOQ

Sr No.	Double compression, Heavy Duty. Nickel plated (coating thickness not less than 10 microns) Brass cable glands. (The cable glands shall be tested as per BS: 6121)	Quantity (Nos.)
1.	5C x 2.5 sqmm PVC/ Cu.	300
2.	10C x 2.5 sqmm PVC/ Cu.	2500
3.	14C x 2.5 sqmm PVC/ Cu.	400
4.	19C x 2.5 sqmm PVC/ Cu.	400
5.	3.5C x 35 sqmm PVC/Cu.	100
6.	3.5C x 300 sqmm PVC/Cu.	25
7.	1C x 630 sqmm PVC/Cu.	50
8.	3.5C x 95 sqmm PVC/Cu.	25
9.	3.5C x 70 sqmm PVC/Cu.	25
10.	2C x 6 sqmm PVC/Cu.	150
11.	3/4C x 6 sqmm PVC/Cu.	250
12.	1C x 70 sqmm PVC/Cu.	25
13.	3/4C x 16 sqmm PVC/Cu.	15
14.	2C x 2.5 sqmm PVC/Cu.	100

The above quantities are indicative for the above substation. The supplier has to supply the cable glands as per the actual requirement at site. No additional price will be payable against this item if the quantities are increased.