

Annexure-A

Project : 400/220 kV S/S at Nelamangla & Hoody

Customer : KPTCL

Annexure	Drawing/Doc No.	Drawing Title
B	TB 1 341 510 001 TB 1 341 510 001A	Single Line Diagram for 400/220kV Nelamangla S/S Single Line Diagram for 400/220kV Hoody S/S
C	TB 0 341 316 002 TB 0 342 316 002A	Layout Plan & Section for 400/220kV Nelamangla S/S Layout Plan & Section for 400/220kV Hoody Ext. S/S
D	Annexure-D	Procedure for welding of Al. tubes
E1	Annexure-E1	Technical Specification of Cable Glands
E2	Annexure-E2	Quantity of Cable Glands
F	TB 4 341 316 005	Equipment & Structure Earthing Details
G	Annexure-G	KPTCL spec for Earthing and cable laying
H	Annexure-H	Precommissioning tests for Reactor, Circuit Breaker, Isolator, Current transformer, Surge Arresters
I	Annexure-I	KPTCL drg. for cable duct