



Bharat Heavy Electricals Limited
Solar Business Division
Malleswaram, Bangalore
Department: WEX

TECHNICAL SPECIFICATION

PR No. 50003350 /15.02.2022

SI No	Requirement of BHEL
1	Manufacture and Supply of one 600 Dia Chimney 30 Mtrs height with Base Plate, platform step ladder with cage, thunder and lightening arrestor. 3. Supply of Base plate and anchor bolt is in the scope of supplier. Base plate and foundation bolt should suit the concrete foundation constructed and provided by BHEL. Base plate and foundation bolts shall be supplied by bidder. Foundation drawing is enclosed
2	Installation of the chimney at BHEL site. 4. Installation And commissioning work involves erection of the chimney as per BHEL site condition and connecting the existing 600 mm exhaust duct. Scope of installation involves : 1. Erection/ labour works 2. Erection by Hydraulic crane 3. Building top truss and sheet removal and refixing 4. Diverting the existing exhaust duct line to the chimney and giving connection
3	Bidder to inspect BHEL site for better understanding of the site conditions before quoting. Bids submitted without visiting BHEL site will not be considered for evaluation purpose.
4	Bidder should have experience in similar works. Proof of 2 similar works in terms of Purchase order/ Completion report in last 5 years to be submitted by bidder. Similar work are : Supply and installation of Chimney/ supply and installation of exhaust ducting system


Amaryoti Saikia
Dy. Manager