

# ELECTRIC HOIST

## GeM Tender Enquiry for ELECTRIC HOIST for 4X270 MW BHADRADRI TPS -FGD

### Index of Annexures

Sl. No.	Description	Annexures
1.	Additional terms and conditions	Annexure I
2.	An undertaking regarding Model Clauses	Annexure II
3.	Instruction to Packing List	Annexure III
4.	Certificate for local Content	Annexure IV
5.	DELIVERY SCHEDULE	
6.	DOCUMENT REQUIRED FOR CUSTOMER APPROVAL	-
7.	BOQ	-
8.	PQR	-
9.	Technical Specification	-

**Project: - 4X270 MW BHADRADRI TPS -FGD**  
**Package: - ELECTRIC HOIST**  
**GeM BID No....., Dtd. ....**  
**ANNEXURE –I**

**Additional clauses of NIT**

**1. Dispatch Markings: -**

Each box shall be marked with Capital Letters in “Red” indicating the PEM supply (Main Supply OR Commissioning spare) for **4X270 MW BHADRADRI TPS -FGD**. Each package delivered under the Contract shall be marked by Supplier and such marking must be distinct and in English Language (all previous irrelevant markings being carefully obliterated). Such marking shall show the description and quantity of contents, the name and address of consignee, the Gross weight and Net weight of the package, the name of the Supplier, PEM P.O. reference number, with a distinctive number of mark sufficient for purposes of identification. Besides above necessary, packing shall bear a special marking `TOP`, `BOTTOM`, `DO NOT TURN OVER`, “KEEP DRY”, “HANDLE WITH CARE”, etc.

**IMPORTANT**

- Two copies of respective standard manufacturer’s erection instruction/operation instruction manual shall be kept in each package / container for immediate reference by BHEL site and same shall be reflected in packing slip also
- The Packing list details for the consignment must be put inside the Box/Boxes.

**Mandatory Spares:** - The Mandatory spares shall be properly packed separately in separate box painted in Red, indicating Mandatory Spares in bold letters and each spare shall be properly tagged giving details i.e. item number of the equipment in line with the CUSTOMER approved BBU for Mandatory spares & Number per item (to match the description given in the packing slip) to facilitate their proper identification by ultimate customer TSGENCO. One Copy of Packing list must be put inside the Box along with Manufacturing drawing no. reference, Catalogue reference etc.

Note :- MDCC for mandatory Spares shall be issued only after receipt of detailed list of mandatory spares & photographs before final packing clearly showing mandatory spares with due tagging as per packing list ( to be sent over mail/CD). Separate dispatch clearance will be issued for the mandatory spares in line with availability of customer’s stores at site.

**2. Liquidated Damages: -**

- a) **Main Supply:-** Purchaser reserves the right to recover from the Seller/ Contractor, as agreed liquidated damages and not by way of penalty, a sum equivalent to half (½) percent and applicable GST thereon, of the total main supply & commissioning spares contract price excluding GST per week or part thereof, subject to a maximum of ten(10) percent of the total main supply & commissioning Spares contract price excluding GST, if the Seller/ Contractor fails to deliver any part of the ordered goods/stores within the period stipulated in the Order/ Contract.
- b) **LD on service portion** (demonstration charges, PG test, installation check, supervision of erection / commissioning charges, engineering charges, O&M, study, calibration charges, type test, AMC, etc.) where delivery for services are defined separately in the NIT. LD shall be applicable @ ½ percent and applicable GST thereon, of the total service portion contract value excluding GST per week or part thereof. However, total

**Project: - 4X270 MW BHADRADRI TPS -FGD**

**Package: - ELECTRIC HOIST**

**GeM BID No....., Dtd. ....**

LD (main supply and services) shall be limiting to 10% of cumulative total contract value (main supply +services) excluding GST

- c) **LD on mandatory spares portion:** - LD shall be applicable @ ½ percent and applicable GST thereon, of the total mandatory spares portion contract value excluding GST per week or part thereof, limiting to 10% of total contract value of mandatory spares excluding GST.

**NOTE:**

i. LR/RR date for indigenous supplies (Bill of Lading/AWB for Foreign supplies) shall be treated as the date of dispatch for levying LD. However, if receipted LR date for indigenous supply is beyond 30 days for FTL/ 45 days for PTL from the date of LR (PTL to be clearly mentioned in LR), such excess period shall be considered for LD purpose irrespective of dispatch date. Import General Manifest (IGM)/Bill of entry date (whichever is earlier), for foreign supplies, is beyond 90 days from the date of Bill of Lading/AWB, such excess period shall be considered for LD purpose irrespective of dispatch date.

ii. In case of any amendment/ revision, LD shall be linked to the amended/ revised contract value and delivery date(s).

iii. If Order/ Contract involves two or more Units/ Sets/ Lots/ Stages, then Liquidated Damages shall be levied on order/ contract value excluding GST of the delayed Unit/ Set/ Lot/ Stage, provided delivery stipulated in the Order/ Contract is Unit/ Set/ Lot/Stage wise, however total LD amount shall be limited to 10% of total order/ amended order value excluding GST of delayed Unit/ Set/ Lot/Stage. Any subsequent lot released (not envisaged in original contract) due to increase in quantity within permissible quantity variation shall be treated as separate lot for the purpose of LD.

iv. The sum specified above is not a penalty but a genuine pre-estimate of the loss/ damage which will be suffered by purchaser on account of delay on the part of the Contractor/Seller and the said amount will be deductible without proof of actual loss or damage caused by such delay.

**3. Risk & Cost Purchase**

BHEL reserves the right to terminate the contract or withdraw portion of work and get it done through other agency, at the risk and cost of the contractor after due notice of a period of 14 days' by BHEL in any of the following cases:

i) If the Seller/Contractor fails to deliver the goods or materials or any instalment thereof within the period(s) fixed for such delivery or the Seller's poor progress of the supply/ services vis-à-vis delivery/execution timeline as stipulated in the Contract, backlog attributable to seller including unexecuted portion of supply does not appear to be executable within balance available period;

ii) Delivers goods or materials not of the contracted quality and failing to adhere to the contract specifications;

iii) Withdrawal from or repudiation/ abandonment of the supply/ services by Seller before completion as per contract or if the Seller refuses or is unable to supply goods or materials covered by the Order/Contract either in whole or in part or otherwise fails to perform the Order/Contract;

**Project: - 4X270 MW BHADRADRI TPS -FGD**

**Package: - ELECTRIC HOIST**

**GeM BID No....., Dtd. ....**

- iv) Non-supply by the Seller within scheduled completion/delivery period as per Contract or as extended from time to time, for the reasons attributable to the Seller;
- v) Termination of Contract on account of any other reason (s) attributable to Seller.
- vi) Assignment, transfer, subletting of Contract without BHEL's written permission resulting in termination of Contract or part thereof by BHEL.
- vii) If the Seller be an individual or a sole proprietorship Firm, in the event of the death or insanity of the Seller;
- viii) If the Seller/Contractor being an individual or if a firm on a partnership thereof, shall at any time, be adjudged insolvent or shall have a receiving order for administration of his estate made against him or shall take any proceeding for composition under any Insolvency Act for the time being in force or make any assignment of the Order/Contract or enter into any arrangement or composition with his creditors or suspend payment or if the firm dissolved under the Partnership Act;
- ix) If the Seller/Contractor being a company is wound up voluntarily or by order of a Court or a Receiver, Liquidator or Manager on behalf of the debenture holders and creditors is appointed or circumstances shall have arisen which entitles the Court of debenture holder and creditors to appoint a receiver, liquidator or manager;
- x) Non-compliance to any contractual condition or any other default attributable to Seller.

Such defaulting vendor/Seller shall not be eligible to participate in re-tendering conducted on account of risk purchase made due to fault of such vendor/Seller.

### 3.1 **Risk & Cost Amount against Balance Work:**

Risk & Cost amount against balance work shall be calculated as follows:

$$\text{Risk \& Cost Amount} = [(A-B) + (A \times H/100)]$$

Where,

A= Value of Balance scope of Work (\*) as per rates of new contract

B= Value of Balance scope of Work (\*) as per rates of old contract being paid to the contractor at the time of termination of contract i.e. inclusive of PVC & ORC, if any.

H = Overhead Factor to be taken as 5

In case (A-B) is less than 0 (zero), value of (A-B) shall be taken as 0 (zero).

### 3.2 **Balance scope of work (in case of termination of contract):**

Difference of Contract Quantities and Executed Quantities as on the date of issue of Letter for 'Termination of Contract', shall be taken as balance scope of Work for calculating risk & cost amount.

Contract quantities are the quantities as per original contract. If, Contract has been amended, quantities as per amended Contract shall be considered as Contract Quantities.

**Project: - 4X270 MW BHADRADRI TPS -FGD**

**Package: - ELECTRIC HOIST**

**GeM BID No....., Dtd. ....**

Items for which total quantities to be executed have exceeded the Contract Quantities based on drawings issued to contractor from time to time till issue of Termination letter, then for these items total Quantities as per issued drawings would be deemed to be contract quantities.

Substitute/ extra items whose rates have already been approved would form part of contract quantities for this purpose.

Substitute/ extra items which have been executed but rates have not been approved, would also form part of contract quantities for this purpose and rates of such items shall be determined in line with contractual provisions.

However, increase in quantities on account of additional scope in new tender shall not be considered for this purpose.

NOTE: In case portion of work is being withdrawn at risk & cost of contractor instead of termination of contract, contract

quantities pertaining to portion of work withdrawn shall be considered as 'Balance scope of work' for calculating Risk & Cost amount.

### **3.3 LD against delay in executed work in case of Termination of Contract:**

LD against delay in executed work shall be calculated in line with above LD clause, for the delay attributable to contractor. For limiting the maximum value of LD, contract value shall be taken as Executed Value of work till termination of contract.

Method for calculation of LD against delay in executed work in case of termination of contract" is given below.

- i. Let the time period from scheduled date of start of work till termination of contract excluding the period of Hold (if any) not attributable to contractor = T1
- ii. Let the value of executed work till the time of termination of contract = X
- iii. Let the Total Executable Value of work for which inputs/fronts were made available to contractor and were planned for execution till termination of contract = Y
- iv. Delay in executed work attributable to contractor i.e.  $T2 = [1-(X/Y)] \times T1$
- v. LD shall be calculated in line with LD clause (clause 16) of the Contract for the delay attributable to contractor taking "X" as Contract Value and "T2" as period of delay attributable to contractor.

### **3.4 Recoveries arising out of Risk & Cost and LD or any other recoveries due from Contractor**

Without prejudice to the other means of recovery of such dues from the Seller recoveries from the Seller on whom risk & cost has been invoked shall be made from the following:

- a) Dues available in the form of Bills payable to seller, SD, BGs against the same contract.
- b) Dues payable to seller against other contracts in the same Region/Unit/ Division of BHEL.

**Project: - 4X270 MW BHADRADRI TPS -FGD**

**Package: - ELECTRIC HOIST**

**GeM BID No....., Dtd. ....**

c) Dues payable to seller against other contracts in the different Region/Unit/ division of BHEL.

In-case recoveries are not possible with any of the above available options, Legal action shall be initiated for recovery against contractor.

4. For recognition of dispatch, vendor to submit following documents to BHEL by e-mail/ fax immediately on dispatch: - GST compliant invoice, LR for Indian Vendors (indicating Invoice No., no. of boxes, PTL (if applicable) etc.) / Bill of Lading or AWB for foreign vendor, Packing List (Must be indicating No. of boxes, Packing size, Gross weight and net weight of each package, Contents of the package with cross reference to BoM item code no. or item serial no. and Quantity of each item separately), Insurance Intimation to underwriter through email/fax, Dispatch Clearance.

**B. Following ATC available in GEM shall also be part of NIT: -**

i. Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

ii. Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.

iii. Data Sheet of the product(s) offered in the bid, are to be uploaded along with the bid documents. Buyers can match and verify the Data Sheet with the product specifications offered. In case of any unexplained mismatch of technical parameters, the bid is liable for rejection.

iv. The bidder is required to upload, along with the bid, all relevant certificates such as BIS license, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.

v. While generating invoice in GeM portal, the seller must upload scanned copy of GST invoice and the screenshot of GST portal confirming payment of GST.

VI. OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.

VII. Nominated Inspection Agency: On behalf of the Buyer organization, any one of the following Inspection Agency would be conducting inspection of stores before acceptance:

Pre-dispatch Inspection at Seller Premises (applicable only if pre-dispatch inspection clause has been selected in ATC): BHEL TPIA

Post Receipt Inspection at consignee site before acceptance of stores: NA

**Project: - 4X270 MW BHADRADRI TPS -FGD**

**Package: - ELECTRIC HOIST**

**GeM BID No....., Dtd. ....**

**Additional Terms and Conditions for subject Tender Enquiry to be complied by Bidders for Consideration in this tender:**

- A.** Bidders to ensure that Third party/Customer issued certificates being submitted as proof of PQR qualification should have verifiable details of document/certificate issuing authority such as name & designation of Issuing Authority and its organization contact number and E-mail Id. In case the same is found not available, BHEL has the right to reject such document from evaluation.
- B.** "This item /package/system falls under the list of items defined in para 3 of ministry of finance guideline date 20.09.16 (procurement of items related to public safety, health, critical security operations and Equipment's etc.) & hence criteria of prior experience /turnover shall be same for all bidders including start up /MSME".
- C.** **Guarantee & Warrantee** shall be as per Cl. No. 10 of GTC on GeM for the bid. However, Guarantee & Warrantee time period shall be 18 months from the date of last supply in the contract for Main Supply.
- D.** Evaluation shall be on the basis of total all inclusive, landed price at consignee destination (Refer cl. No. 6 of GTC on GEM).
- E.** **Terms of Delivery:** - Terms of delivery shall be F.O.R. dispatch station. All dispatches shall be through Road Carriers on Freight Pre-Paid basis. Road Permit/E-way Bill if required will be arranged by Supplier. However, loading & Transit insurance shall be in the scope of Seller and unloading of items at delivery point shall be in the scope of BHEL. Bidder to quote prices accordingly.
- F.** Further, w.r.t. Transit Insurance supplier has to inform the details of dispatches (such as Policy No., Consignee Name, Consignment Packing details, Project Name, Purchase Order No., LR No. & date, Invoice No. & date, Dispatch Origin & destination details etc.) to policy underwriter.
- G.** Bidder has to provide the details as per TECHNICAL PQR (attached with Specifications of product catalogue) in its offer and has to note that bids of only those bidders shall be evaluated who meet the Technical Pre-Qualifying requirements'. The terms of technical PQR shall prevail in conflict (if any).
- H.** PQR criteria uploaded with Buyer uploaded Bid Specific document shall prevail Value of Experience criteria and Past performance parameter mentioned in GeM bid.
- I.** "Due to COVID-19 pandemic condition prevailing in the country BHEL/PEM may go for Remote Inspection of Offered items if required. Vendors are requested to be equipped with the facilities/gadgets as indicated in the guidelines available at : <https://pem.bhel.com/Documents/VendorSection/Vendor/Guidelines.pdf> to take up the inspection remotely.
- J.** **Inspection call to be raised by bidder on BHEL CQIR portal** (details shall be shared at the of execution of order) and Inspection agency shall attend at the inspection within seven (07) days of the date on which the material is notified as being ready. In case of delay in witnessing of inspection beyond stipulated time (i.e. 7 days from the date on which the material is notified as being ready), by BHEL arising due to reasons not attributable to vendor, BHEL will extend the delivery period for such delay in carrying out inspection. If BHEL is not able to witness inspection up to 15 days then in addition to delay beyond stipulated period, extension in delivery time of 07 days for arranging fresh inspection will be given.

When the tests have been satisfactorily completed at Seller/ Contractor's works, the Inspection Agency shall issue an inspection report that effect within seven (07) days after completion of the tests, but if the tests were not witnessed by the Inspection Agency or his representative, the material acceptance report would be issued within seven (07) days after receipt of the test certificates by the Purchaser.

Purchaser will issue MDCC to the Seller/ Contractor within 7 days based on inspection report/ test certificates/Certificate of Conformance as applicable. In case of delay in issuance of MDCC beyond 7 days

**Project: - 4X270 MW BHADRADRI TPS -FGD**

**Package: - ELECTRIC HOIST**

**GeM BID No....., Dtd. ....**

stipulated time (i.e. from the date of successful inspection report), by BHEL arising due to reasons not attributable to vendor, BHEL will extend the delivery period for such delay in issuing MDCC. If BHEL is not able to issue MDCC up to 15 days then in addition to delay beyond stipulated period, 7 days' additional time shall be given to vendor to facilitate the vendor for arranging logistics arrangements.

- K.** All Bidders shall be required to submit applicable Freight % & GST % included in their prices during clarification stage of Tender.
- L.** Performance Bank Guarantee: shall be as per Cl. No. 7 of GTC of GeM. Performance Security amount shall be @5% of the value of contract value. In case any benefit with respect to BG reduction is applicable at later stage KOTHAGUDAM project, then similar benefit shall be passed onto the bidders for subject tender as well.
- M. Payment Terms:** For Supply Portion incl. Mandatory Spares: - As per clause no. 12 (i) of GTC on GeM. Supplier has to provide original+1 copy of Tax invoice, Packing List, LR/RR or AWB, CRAC, Insurance intimation, Guarantee Certificate, E-way bill (as applicable) for payment.  
For Services (**Supervision of E & C**) :- As per clause no. 12 (i) of GTC on GeM. Supplier has to provide Tax invoice, CRAC for payment.  
Offline payment mode shall be selected. Payment will be released within 90 days for Non MSME after submission of complete documents (45 days for Micro & Small Enterprises (MSEs), 60 days for Medium Enterprises.
- N. Bid reserved for Make in India products:** - Procurement under this bid is reserved for purchase from Class 1 local suppliers as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a class 1 local supplier is denoted in the bid document as **SIXTY (60)%**. All bidders must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which the bid is liable to be rejected.  
Regarding verification of local content, the local supplier at the time of tender, bidding or solicitation shall be required to provide certification (as per enclosed annexure-IV) as per para 9 of PP-MII order revision dated 16.09.2020.
- O. This is conditional tender enquiry. Financial bid opening (Part-II) of a bidder shall be subjected to following: -**
- (i) Techno-Commercial evaluation/recommendation by BHEL.
  - (ii) Qualification of Technical PQR
  - (iii) Offered item should mandatorily conform to PP-MII order provisions.
  - (iv)** Approval of vendor from end Customer (TSGENCO). shall be taken up by BHEL-PEM with customer. Bidders who are not approved from TSGENCO (end customer) should furnish the credentials as per TSGENCO (end customer) format - (Annexure -A) along with their bid.
- P. Consignee Details** (for PRC - Provisional Receipt Certificate & CRAC - Consignee's Receipt cum Acceptance Certificate, as applicable) shall be as per Project Site official details.
- Q.** The Bidder has to declares that they will not enter into any illegal or undisclosed agreement or understanding, whether formal or informal with other Bidder(s). This applies in particular to prices, specifications, certifications, subsidiary contracts, submission or non-submission of bids or any other actions to restrict competitiveness or to introduce cartelization in the bidding process. In case, the bidder is found having indulged in above activities, suitable action shall be taken by BHEL as per extant policies/guidelines.

**Project: - 4X270 MW BHADRADRI TPS -FGD**

**Package: - ELECTRIC HOIST**

**GeM BID No....., Dtd. ....**

**R. Bidders to ensure the following: -**

- Ensure compliance to Ministry of Power (MoP) Order No. 11/05/2018 Coord. dt. 28/07/2020, if applicable.
- Ensure compliance of Ministry of Finance (MoF) Order (Public Procurement No. 1 & 2) F. No. 6/18/2019/PPD dt. 23/07/2020.
- to submit “Model Certificate for Tenders” as per Annexure-III of Ministry of Finance (MoF) Order (Public Procurement No. 1 & 2) F. No. 6/18/2019/PPD dt. 23/07/2020. Bidder to submit the following undertaking on their letter head duly signed from the highest competent authority at your end (i.e Owner, partner, CMD, Director etc.)

**“I have read the clause regarding restrictions on procurement from a bidder of a country which shares a land border with India; I hereby certify that this bidder is not from such a country and is eligible to be considered”**

Note: - This bidder is to be replaced with bidders’ organizational name.

- S. Delivery Period:** As per attached Annexure-II. Delivery Days mentioned in GeM bid is indicative only. Delivery shall be as per Annexure-II.
- T.** For registration in BHEL PEM- Online registration portal is operational, Non-registered Vendors who wish to apply for registration in BHEL-PEM can apply through Online Registration Portal available at [www.pem.bhel.com](http://www.pem.bhel.com) - vendor section - Online Supplier Registration. All credentials and/or documents duly signed and stamped related to registration can be uploaded on the website and submit the application for registration. However, registration of suppliers is not mandatory in case of open tender
- U.** Total quoted price against Supervision of E & C at site (VISIT CHARGES & MANDAYS CHARGES) should not exceed 2% of the total contract value.
- V.** Instructions to Packing List (annexure –III) and Certification reg. Local content (annexure –IV) to be complied by bidders.
- W. Quantity Variation:** - Maximum Qty Variation shall be quantity variations as +25%, bidder to quote accordingly. The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract.
- X.** Material shall be dispatched by vendor after issuance of MDCC by BHEL only.
- Y.** CIF is not available for this Package.
- Z.** All the Buyer Added Bid Specific Additional Terms and Conditions shall supersede relevant terms & conditions of GeM GTC and shall prevail in case of conflict with any other terms & conditions of tender (if any).
- AA.** All other terms & conditions shall be as per selected Additional Terms & Conditions for subject bid from GeM library and GTC version 4.0 (Version 1.5) available on GeM Portal on enquiry floating date shall be applicable.

Project: - 4X270 MW BHADRADRI TPS -FGD

Package: - ELECTRIC HOIST

GeM BID No....., Dtd. ....

**An undertaking regarding Model Clauses (To be provided alongwith bid)**

Refer,

PROJECT	:- 4X270 MW BHADRADRI TPS -FGD
PACKAGE	:- ELECTRIC HOIST
Primary product category on GeM	:-.....
BID No. (Through GeM)	:- ....., Dtd. ....

M/s .....

Reference:

**TO WHOM SO IT MAY CONCERN**

This is with reference to Ministry of Finance circular dated 23.07.20 reg. restriction under rule 144 (xi) of GFR.

“I have read the clause regarding restrictions on procurement from a bidder of a country which shares a land border with India. I hereby certify that M/s ..... is not from such a country and is eligible to be considered against GeM enquiry no: ....., **Dtd. ....**”

Sign & Signature

Date:

**Project: - 4X270 MW BHADRADRI TPS -FGD**  
**Package: - ELECTRIC HOIST**  
**GeM BID No....., Dtd. ....**  
**ANNEXURE -III TO INSTRUCTIONS TO PACKING LIST**

For faster verification of bills, successful bidder to submit detailed Bill of Material (BOM) at the time of drawings/ documents submission after placement of PO. Each item of the BOM to be uniquely identified with item code no. or item Sl. No. Supplier to ensure that all items which will find separate mention in the packing list are covered in this detailed BOM.

Supplier to also give the following undertaking in the BOM:

“The BOM provided herewith completes the scope (in content and intent) of material supply under PO No. .... Dated ..... Any additional material which may become necessary for the intended application of the supplied items/package will be supplied free of cost in most reasonable time.

Packing List must indicate:

- a) Packing size
- b) Gross weight and net weight of each package
- c) Contents of the package with cross reference to BOM item code no. / Sl. No.
- d) Quantity of each items separately.

The packing list must cover all the BOM items.

Supplier to give following undertaking in the packing list:

The Packing list provided herewith is as per BOM approved under PO No. ----

Project: - 4X270 MW BHADRADRI TPS -FGD

Package: - ELECTRIC HOIST

GeM BID No....., Dtd. ....

**ANNEXURE IV**

**Letter head of Company**

Ref.....

Date.....

To,  
Bharat Heavy Electricals Limited  
PEM, PPEI Building, Plot No 25,  
Sector 16A, Noida (U.P) 201301

**Subject: Certification regarding local content**

Reference: Tender Enquiry No....., **Dtd.** .....

Name of Package: **ELECTRIC HOIST.**

Dear Sir,

We hereby certify that items offered by us of **ELECTRIC HOIST** for **4X270 MW BHADRADRI TPS -FGD**, M/s .....  
..... meets the requirement of minimum local content as a class – I local supplier in line with clause of NIT (GeM NIT)  
and the Public Procurement (Preference to Make in India), Order 2017 dated 15.06.2017, 28.05.2018 & 29.05.2019,  
04.06.20 & 16.09.20

We further confirm that details of location at which the local value addition is made will be our registered works  
at

.....  
...(address of the works)

Yours very truly

..... (authorized signatory of company)

..... (firm name)

authorized signatory  
of company

**Project: - 4X270 MW BHADRADRI TPS -FGD**

**Package: - ELECTRIC HOIST**

**GeM BID No....., Dtd. ....**

**Project:- 4X270 MW BHADRADRI TPS -FGD  
Package:- ELECTRIC HOIST  
Annexure II to NIT- Delivery Schedule**

Sl. No.	Package Code	BHEL Drawing No	Drawing Title	Primary/Secondary	BHEL Inputs	Drng Sch for Vendors	Standard Delivery Terms for Supply Portion	Scope of Services, (if any, as per Indent) and corresponding schedule for rendering the services
1	563-12000-A	PE-V1-440-563-A210	Mechanism Sizing Calculation OF ELECTRIC HOIST	Primary		R-0 within 21 days from PO & subsequent revisions within 10 days of comments received from BHEL. BHEL shall furnish comments / approval on each submission within 18 days from receipt.	Within Five (05) months from date of CAT-1 approval of Primary drawing/documents or BHEL manufacturing clearance whichever is later, subjected to drawing/ document submission/re-submission schedule as stipulated, in case of any delay in submission/re-submission of Primary drawing/documents, then same shall be reduced from the given delivery period.	Supervision of E&C:  Vendor to depute its service engineer for Supervision of E&C within 15 days from BHEL's intimation (for deputing service engineer).  For delay in deputing service engineer, LD on Supervision of E&C portion shall be applicable @ ½% of the total Supervision of E&C portion contract value (excluding element of taxes) per week or part thereof, with applicable GST. However, total LD (supply + Supervision of E&C) shall be limited to 10% of cumulative total contract value excluding taxes and freight (supply + Supervision of E&C).
		PE-V1-440-563-A201	Manufacturing Quality Plan with Sub vendor list OF ELECTRIC HOIST	Primary				
		PE-V0-440-563-A219	Schematic Circuit Diagram including cable schedule and panel diagram	Primary				
		PE-V1-440-563-A202	GA Drawing for Electric Hoist, DSL arrangement and painting details OF ELECTRIC HOIST	Primary				
		PE-V1-440-563-A208	Erection procedure OF ELECTRIC HOIST	Secondary				
		PE-V0-XXX-563-A209	<del>See worthy pending (if applicable) OF ELECTRIC HOIST</del>	Secondary				
		PE-V1-440-563-A207	Mandatory spare parts list (if applicable) OF ELECTRIC HOIST	Secondary				
		PE-V1-440-563-A218	Detailed BOM/BOQ for Hoist	Secondary				
		PE-V1-440-563-A206	O & M Manual	Secondary				
<b>Notes:-</b>								
(i) The end period specified is for completion of the deliveries. Deliveries to start progressively so as to meet the completion schedule.								
(ii) The delivery conditions specified are for contractual LD purposes, however BHEL may ask for early deliveries without any compensation thereof.								
(iii) Non-applicable drawings shall be decided during bid evaluation.								
(iv) Wherever schedule of drawings/documents submission / re-submission is stipulated in the Technical Specifications, same shall be superseded by delivery specified in NIT.								
(v) Vendor to start manufacturing activities only after obtaining specific manufacturing clearance from BHEL Purchase group.								
(vi) In case BHEL manufacturing clearance date is later than the date of Cat-1 approval of Primary drawing/documents, then the contractual delivery period will be calculated by setting off the time gap between Cat-1 approval date of Primary drawing/documents and the manufacturing clearance date, from any delay by vendor in submission/re-submission of Primary drawing/documents.								

**Project:- 4X270 MW BHADRADRI TPS -FGD**  
**Pacake:- ELECTRIC HOIST**  
**Annexure II to NIT- Delivery Schedule**

Sl. No.	Package Code	BHEL Drawing No	Drawing Title	Primary/ Secondary	BHEL Inputs	Drg Sch for Vendors	Standard Delivery Terms for Supply Portion	Scope of Services, (if any, as per Indent) and corresponding schedule for rendering the services
1	563-12000-A	PE-V1-440-563-A210	Mechanism Sizing Calculation OF ELECTRIC HOIST	Primary		R-0 within 21 days from PO & subsequent revisions within 10 days of comments received from BHEL. BHEL shall furnish comments / approval on each submission within 18 days from receipt.	Within Five (05) months from date of CAT-1 approval of Primary drawing/documents or BHEL manufacturing clearance whichever is later, subjected to drawing/ document submission/re-submission schedule as stipulated, in case of any delay in submission/re-submission of Primary drawing/documents, then same shall be reduced from the given delivery period.  <b>Mandatory Spares:</b> Within four (04) months from the date of BHEL manufacturing clearance. Separate dispatch/ manufacturing clearance will be issued for mandatory spares	Supervision of E&C:  Vendor to depute its service engineer for Supervision of E&C within 15 days from BHEL's intimation (for deputing service engineer).  For delay in deputing service engineer, LD on Supervision of E&C portion shall be applicable @ ½% of the total Supervision of E&C portion contract value (excluding element of taxes) per week or part thereof, with applicable GST. However, total LD (supply + Supervision of E&C) shall be limited to 10% of cumulative total contract value excluding taxes and freight (supply + Supervision of E&C).
		PE-V1-440-563-A201	Manufacturing Quality Plan with Sub vendor list OF ELECTRIC HOIST	Primary				
		PE-V0-440-563-A219	Schematic Circuit Diagram including cable schedule and panel diagram	Primary				
		PE-V1-440-563-A202	GA Drawing for Electric Hoist, DSL arrangement and painting details OF ELECTRIC HOIST	Primary				
		PE-V1-440-563-A208	Erection procedure OF ELECTRIC HOIST	Secondary	R-0 within 30 days from PO & subsequent revisions within 10 days of comments received from BHEL. BHEL shall furnish comments / approval on each submission within 18 days from receipt.			
		PE-V0-XXX-563-A209	<del>Sea worthy packing (if applicable) OF ELECTRIC HOIST</del>	Secondary				
		PE-V1-440-563-A207	Mandatory spare parts list (if applicable) OF ELECTRIC HOIST	Secondary				
		PE-V1-440-563-A218	Detailed BOM/BOQ for Hoist	Secondary				
		PE-V1-440-563-A206	O & M Manual	Secondary				
					within 30 days of issuance of MDCC			

**Notes:-**

(i)	The end period specified is for completion of the deliveries. Deliveries to start progressively so as to meet the completion schedule.
(ii)	The delivery conditions specified are for contractual LD purposes, however BHEL may ask for early deliveries without any compensation thereof.
(iii)	Non-applicable drawings shall be decided during bid evaluation.
(iv)	Wherever schedule of drawings/documents submission / re-submission is stipulated in the Technical Specifications, same shall be superseded by delivery specified in NIT.
(v)	Vendor to start manufacturing activities only after obtaining specific manufacturing clearance from BHEL Purchase group.
(vi)	In case BHEL manufacturing clearance date is later than the date of Cat-1 approval of Primary drawing/documents, then the contractual delivery period will be calculated by setting off the time gap between Cat-1 approval date of Primary drawing/documents and the manufacturing clearance date, from any delay by vendor in submission/re-submission of Primary drawing/documents.

<b>CUSTOMER/ BHEL LOGO</b>	<b>VENDOR CREDENTIALS SUMMARY SHEET (TO BE FILLED BY BIDDER AND SUBMITTED WITH BID)</b>
------------------------------------	---

i.	Item/Scope				
ii.	Address of the registered office	<b>Details of Contact Person</b> (Name, Designation, Mobile, Email)			
iii.	Name and Address of the proposed vendor's works where item is being manufactured	<b>Details of Contact Person:</b> (Name, Designation, Mobile, Email)			
iv.	Annual Production Capacity for proposed item				
v.	Annual production for last 3 years for proposed item				
vi.	<b>Details of proposed works</b>				
1.	Year of establishment				
2.	Factory Registration Certificate	<b>Details attached at Annexure – F2.1 (Page No....)</b>			
3.	Overall organization Chart with Manpower Details (Design/Manufacturing/Quality etc.)	<b>Details attached at Annexure – F2.2 (Page No....)</b>			
4.	After sales service set up in India, in case of foreign sub-vendor (Location, Contact Person, Contact details etc.)	<b>Applicable / Not applicable</b> <b>Details attached at Annexure – F2.3 (Page No....)</b>			
5.	Sources of Raw Material/Major Bought Out Item	<b>Details attached at Annexure – F2.4 (Page No....)</b>			
6.	Quality Control exercised during receipt of raw material/BOI, in-process, Final Testing, packing	<b>Details attached at Annexure – F2.5 (Page No....)</b>			
7.	Manufacturing facilities (List of machines, special process facilities, material handling etc.)	<b>Details attached at Annexure – F2.6 (Page No....)</b>			
8.	Testing facilities (List of testing equipment)	<b>Details attached at Annexure – F2.7 (Page No....)</b>			
9.	Supply reference list including recent supplies (Preferably of reputed, well known clients to whom the vendor has supplied the material and are of quantum of item/scope at point (i) above)	<b>Reputed client name (s).....</b> <b>Details attached at Annexure – F2.8 (as per format given below)</b> <b>(Page No....)</b>			
<b>Project/ package</b>	<b>Customer Name</b>	<b>Supplied Item (Type/Rating/Model /Capacity/Size etc)</b>	<b>PO ref no/date</b>	<b>Supplied Quantity</b>	<b>Date of Supply</b>

<b>CUSTOMER/ BHEL LOGO</b>	<b>VENDOR CREDENTIALS SUMMARY SHEET (TO BE FILLED BY BIDDER AND SUBMITTED WITH BID)</b>
------------------------------------	---

10.	Product satisfactory performance feedback letter/certificates/End User Feedback	Attached at annexure - F2.9 (Page No....)			
11.	Average annual turnover for last three years with documentary proof.				
12.	Summary of Type Test Report (Type Test Details, Report No, Agency, Date of testing) for the proposed product (similar or higher rating) Note:- Reports need not to be submitted	<b>Applicable / Not applicable</b>  Details attached at Annexure – F2.10 (if applicable) (Page No....)			
13.	Copy of ISO 9001 certificate (if available)	Attached at Annexure – F2.11 (Page No....)			
14.	Product technical catalogues for proposed item (if available)	Details attached at Annexure – F2.12 (Page No....)			
<b>Name</b>		<b>Desig</b>		<b>Sign:</b>	
					<b>Date</b> :

**Company's Seal/Stamp:-**

<b>SUGGESTED PRICE FORMAT</b>	<b>Doc No:</b>	PE-PF-440-563-A002
	<b>Rev No:</b>	0
	<b>Date of issue</b>	24.12.22

<b>NAME OF PROJECT:</b>	<b>4X270 MW BHADRADRI TPP (FGD System)</b>
<b>NAME OF PACKAGE:</b>	<b>ELECTRIC HOIST</b>
<b>TECHNICAL SPECIFICATION:</b>	<b>PE-TS-440-563-A002</b>

S. No.	DESCRIPTION	UNIT	QTY	HSN CODE	AMOUNT (Ex-Works)
1	Total lump sum firm price inclusive of all prevailing taxes, duties and other levies for <b>SUPPLY PART &amp; MANDATORY SPARES</b> comprising of design (i.e. preparation and submission of drawing /documents including "As Built" drawings and O&M manuals), engineering, manufacture, fabrication, assembly, inspection / testing at vendor's & sub-vendor's works, painting, maintenance tools & tackles, fill of lubricants & consumables, supervision of E&C, mandatory spares alongwith spares for erection, startup and commissioning as required, forwarding, proper packing, shipment and delivery at site for project and package specified above complete with all accessories for the total scope defined as per BHEL NIT & tender technical specification, amendment & agreements till placement of order.	Lot	1		
<b>2.0</b>	<b>MAJOR BREAK-UP OF PRICES GIVEN IN 1.0 ABOVE.</b>				
2.1	Prices inclusive of all prevailing taxes, duties and other levies for <b>SUPPLY</b> part comprising of design (i.e. preparation and submission of drawing /documents including "As Built" drawings and O&M manuals), engineering, manufacture, fabrication, assembly, inspection / testing at vendor's & sub-vendor's works, painting, maintenance tools & tackles, fill of lubricants & consumables, supervision of E&C, alongwith spares for erection, startup and commissioning as required, forwarding, proper packing, shipment and delivery at site, for project and package specified above complete with all accessories for following items for the total scope defined as per BHEL NIT & tender technical specification, amendment & agreements till placement of order. <b>(Break-up of prices as per Annexure I)</b>	Lot	1	8425 11 10	
2.2	Total lumpsum firm price inclusive of all prevailing taxes, duties and other levies for <b>Mandatory spares</b> comprising of manufacture, fabrication, assembly, inspection / testing at vendor's & sub-vendor's works, painting, forwarding, proper packing, shipment, delivery at site & guarantee as per tender technical specification above, amendment & agreements till placement of order. (Price break up of mandatory spares is to be furnished as per Annexure- II).	Lot	1	8431 10 10	

Note:  
1.) PG to consider and suitably incorporate taxes, duties and other commercial aspects.  
2) Bidder to quote the Prices in 'figures' along with corresponding 'words'.

<b>Particulars of bidder / authorised representative</b>					
<b>Name</b>	<b>Designation</b>	<b>Signature</b>	<b>Date</b>	<b>Company Seal</b>	

**SUGGESTED PRICE FORMAT  
ANNEXURE-I**

<b>Doc No:</b>	PE-PF-440-563-A001
<b>Rev No:</b>	0
<b>Date of issue</b>	24.12.2022

<b>NAME OF PROJECT:</b>	<b>4X270 MW BHADRADRI TPP (FGD System)</b>
<b>NAME OF PACKAGE:</b>	<b>ELECTRIC HOIST</b>
<b>TECHNICAL SPECIFICATION:</b>	<b>PE-TS-440-563-A002</b>

<b>S. No.</b>	<b>DESCRIPTION</b>	<b>UNIT</b>	<b>QTY</b>	<b>AMOUNT (Ex-Works)</b>
<b>2.0</b>	<b>BREAK-UP OF SUPPLY PRICES GIVEN IN 2.1 OF MAIN SHEET.</b>			
<b>2.1</b>	Breakup of Prices inclusive of all prevailing taxes, duties and other levies for <b>SUPPLY</b> part comprising of design (i.e.preparation and submission of drawing /documents including "As Built" drawings and O&M manuals), engineering, manufacture, fabrication, assembly, inspection / testing at vendor's & sub-vendor's works, painting, maintenance tools & tackles, fill of lubricants & consumables, supervision of E&C, alongwith spares for erection, startup and commissioning as required, forwarding, proper packing, shipment and delivery at site, for project and package specified above complete with all accessories for following items for the total scope defined as per BHEL NIT & tender technical specification, amendment & agreements till placement of order.	Lot	1	
<b>2.1.1 (a)</b>	For <b>FGD Control Room</b> Capacity: 10 T Lift: 12 M Travel path (Straight): 6 M	No.	1	
<b>2.1.1 (b)</b>	PVC Shrouded bus bar (GI) type DSL complete with all accessories.	Mtr	6	
<b>2.1.1 (c)</b>	Trailing cable for movable type pendent	Mtr	6	
<b>2.1.2 (a)</b>	For <b>ESP cum FGD Control Room</b> Capacity: 2 T (suitable for curved path) Lift: 2.5 M Travel path (Straight): 45 M	No.	1	
<b>2.1.2 (b)</b>	PVC Shrouded bus bar (GI) type DSL complete with all accessories. (curved path)	Mtr	45	
<b>2.1.3</b>	<b>Maintenance tools and tackles</b>	set	1	
<b>2.1.4</b>	<b>Commisioning spares for 10 T hoist (non hazardous)</b>	set	1	
<b>2.1.5</b>	<b>Commisioning spares for 2 T hoist (non hazardous)</b>	set	1	
<b>2.1.6 (a)</b>	<b>Supervision of E&amp;C (1 set)</b>	<b>Charges per visit</b>	No.	1
<b>2.1.6 (b)</b>		<b>Charges per man-day</b>	No.	1


Note:  
1) PG to incorporate taxes, duties and other commercial aspects.  
2) Bidder to quote the Prices in 'figures' along with corresponding 'words'.  
3) The requirement for visit &/or supervision at site as indicated at sl no. 2.1.6 (a) & 2.1.6 (b) shall vary as per requirement of site. Any variation shall be adjusted as per Unit rate mentioned above.  
4) Any variation in length of DSL due to change in bay length will be adjusted based on unit rates arrived from 2.1.1 (b) & 2.1.2 (b)above.

<b>Particulars of bidder / authorised representative</b>				
<b>Name</b>	<b>Designation</b>	<b>Signature</b>	<b>Date</b>	<b>Company Seal</b>

<b>SUGGESTED PRICE FORMAT ANNEXURE-II LIST OF MANDATORY SPARES</b>		Doc No:	PE-PF-440-563-A001
		Rev No:	0
		Date of issue	24.12.2022
NAME OF PROJECT:		4X270 MW BHADRADRI TPP (FGD System)	
NAME OF PACKAGE:		ELECTRIC HOIST	
TECHNICAL SPECIFICATION:		PE-TS-440-563-A002	
Sl. No.	DESCRIPTION	TOTAL QNTY	AMOUNT (Ex-Works)
2.2	<b>BREAK-UP OF SUPPLY PRICES GIVEN IN 2.2 OF MAIN SHEET.</b>		
A	<b>MANDATORY SPARES FOR ELECTRIC HOISTS (FOR 10T HOIST)- FGD control room (for each type and rating, hoists)</b>		
1.1	Bearings for travel wheels	4 set	
1.2	Bearings for gear boxes for each type of hoist	4 set	
1.3	Break liners for all the brakes	200% of total population of each type & size	
1.4	Oil seals	200% of total population of each type, size rating	
1.5	Brake springs for all brakes	200% of total population of each type, size rating	
1.6	Wire ropes for hooks	200% installed on each crane and hoist	
1.7	Solenoid coils for brakes	4 set	
1.8	Overload relay for motors	4 Nos.	
1.9	Limit switches for hoists and travel mechanisms	4 set	
1.10	(i) Spare motors for hoist motion	2 Nos.	
	(ii) Spare motors for travel motion	2 Nos.	
1.11	Travel machinery		
	i. Gear wheel	2 set	
	ii. Internal clip	4 Nos.	
	iii. Pinion	2 No.	
2	Electrical Items		
2.1	415 Volt Motor (Upto 30 KW Rating)		
a	Driving End & Non-Driving End Bearing	4 Set for each type and rating of Motor	
b	Cooling Fan	4 Nos. for each type and rating of Motor	
c	Motor Terminal Block	10 Nos. for each type and rating of Motor	
d	Complete Set of Coupling	2 Set of each application	
3	C&I Items		
a	Back-up panel mounted devices (Selector switches/ Push buttons/ Indicators etc.	10% of installed capacity	
b	Lamps/ LEDs	200% of the total quantity	
c	Blank Tiles	20% of installed capacity	
d	MCBs	20% of each type & rating	
e	Fuses/ Fuse holder	200% of each type & rating	

<b>B</b>	<b>MANDATORY SPARES FOR ELECTRIC HOISTS (FOR 2T HOIST)- FGD control room (for each type and rating, hoists)</b>		
1.1	Bearings for travel wheels	4 set	
1.2	Bearings for gear boxes for each type of hoist	4 set	
1.3	Break liners for all the brakes	200% of total population of each type & size	
1.4	Oil seals	200% of total population of each type, size rating	
1.5	Brake springs for all brakes	200% of total population of each type, size rating	
1.6	Wire ropes for hooks	200% installed on each crane and hoist	
1.7	Solenoid coils for brakes	4 set	
1.8	Overload relay for motors	4 Nos.	
1.9	Limit switches for hoists and travel mechanisms	4 set	
1.10	(i) Spare motors for hoist motion	2 Nos.	
	(ii) Spare motors for travel motion	2 Nos.	
1.11	Travel machinery		
	i. Gear wheel	2 set	
	ii. Internal clip	4 Nos.	
	iii. Pinion	2 No.	
2	Electrical Items		
2.1	415 Volt Motor (Upto 30 KW Rating)		
a	Driving End & Non-Driving End Bearing	4 Set for each type and rating of Motor	
b	Cooling Fan	4 Nos. for each type and rating of Motor	
c	Motor Terminal Block	10 Nos. for each type and rating of Motor	
d	Complete Set of Coupling	2 Set of each application	
3	C&I Items		
a	Back-up panel mounted devices (Selector switches/ Push buttons/ Indicators etc.	10% of installed capacity	
b	Lamps/ LEDs	200% of the total quantity	
c	Blank Tiles	20% of installed capacity	
d	MCBs	20% of each type & rating	
e	Fuses/ Fuse holder	200% of each type & rating	

Note: Mandatory spares listed above is bare minimum requirement. In case any additional mandatory spares requirement is covered elsewhere in the tender specification apart from specified above, same shall be deemed to have been covered in bidders scope of supply.

	<b>PRE-QUALIFICATION REQUIREMENT</b>	PE-PQ-440-563-A002	
	(TECHNICAL)	DATE	26/12/2022
	<b>PROJECT: BHADRADRI FGD</b> <b>PACKAGE : - ELECTRIC HOISTS</b>	REV NO	00

1.0	Bidder should have capabilities for design, manufacture and having testing facility for Electric hoist of minimum 3T capacity.
2.0	<p>The Bidder has to submit following supporting documents meeting above mentioned pre-qualifying requirement:</p> <p>a. Copy of minimum one (1) performance certificate (in English) from end user along with copy of related Purchase Order (PO) or Letter of intent (LOI) or Letter of Award (LOA) or Work Order (WO) specifying that the product/equipment is running successfully for one (1) year from date of commissioning meeting the minimum prequalifying requirement. OR</p> <p>b. Minimum two PO/ LOI/ LOA/ WO placed with a minimum gap of six (6) months from same purchaser meeting the minimum pre-qualifying requirement. OR</p> <p>c. Minimum one PO/ LOI/ LOA/ WO after commissioning of first order from same purchaser meeting the minimum pre-qualifying requirement. OR</p> <p>d. Minimum three customer's /third party's inspection reports / test certificates meeting the minimum pre-qualifying requirement.</p>
3.0	Bidder shall submit design documents to substantiate technical parameters specified in PQR, if the same is not mentioned in performance certificate/purchase order.
4.0	Minimum one (1) no. Purchase order shall be submitted which should not be more than seven (7) years old as on date of bid submission, for establishing continuity in business. This is over and above the requirement of PO mentioned of PQR clause at S. No. 2.0 above.
5.0	Bidder to submit all supporting documents in English. If documents submitted by bidder are in language other than English, a self-attested English translated document should also be submitted.
6.0	Notwithstanding anything stated above, BHEL reserves the right to assess the capabilities and capacity of the bidder to perform the contract, should the circumstances warrant such assessment in the overall interest of BHEL.
7.0	Consideration of offer shall be subject to customer's approval of bidders, if applicable.
8.0	After satisfactory fulfilment of all the above criteria/ requirement, offer shall be considered for further evaluation as per NIT and all the other terms of the tender.

**TELANGANA STATE POWER GENERATION  
CORPORATION LTD.**

4 X 270MW BHADRADRI TPS AT MANUGURU,  
KHAMMAM, TS

TECHNICAL SPECIFICATION  
FOR  
ELECTRIC HOIST

SPECIFICATION NO.: PE-TS-440-563-A002



**BHARAT HEAVY ELECTRICALS LTD**

**POWER SECTOR PROJECT ENGINEERING MANAGEMENT  
PPEI, NOIDA-INDIA**



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS**

SPECIFICATION NO. PE-TS-440-563-A002

INDEX

DATE 26.12.2022

REV 00

DATE JULY 2020

**VOLUME – IIB**

SECTIONS	TITLE	Page no.
SECTION-I	SPECIFIC TECHNICAL REQUIREMENT	1
SECTION-IA	SPECIFIC TECHNICAL REQUIREMENT (MECHANICAL)	2-9
	QUALITY ASSURANCE PLAN	10-12
	CUSTOMER SPECIFICATION	13-86
SECTION-IB	SPECIFIC TECHNICAL REQUIREMENT (ELECTRICAL)	87-103
SECTION-IC	DATA SHEET-A	104-107
	<b><u>ANNEXURES</u></b>	
i)	ANNEXURE-I - MAKES OF SUB-VENDOR ITEMS	109-115
ii)	ANNEXURE-II -MANDATORY SPARE LIST	116-117
	ANNEXURE-III – PAINTING SPECIFICATION	118
	ANNEXURE-IV – INSPECTION AND TESTING REQUIREMENT	119
	ANNEXURE-V - DRAWINGS/ DOCUMENTS TO BE SUBMITTED AFTER AWARD OF CONTRACT	120
iii)	ANNEXURE-VI – CHECK LIST FOR OPERATION AND MAINTENANCE MANUAL	121-123
SECTION-IIA	STANDARD TECHNICAL REQUIREMENT (MECHANICAL)	124-131

**VOLUME-III**

SECTIONS	TITLE	Page no.
1	List of documents to be submitted with bid	133
2	Compliance cum confirmation certificate	134-135
3	Pre Bid Clarification Schedule	136

PEM-6666-0



**TECHNICAL SPECIFICATION FOR**  
**ELECTRIC HOIST**  
**4X270 MW BHADRADRI TPS- FGD**

SPECIFICATION NO. PE-TS-440-563-A002	
VOLUME II - B	DATE 26.12.2022
SECTION -I	
REV 00	DATE JULY 2020

**SECTION-I**

**SPECIFIC TECHNICAL REQUIREMENT**

**SUB-SECTION IA**  
**SUB-SECTION IB**  
**SUB-SECTION IC**

**SPECIFIC TECHNICAL REQUIREMENT (MECHANICAL)**  
**SPECIFIC TECHNICAL REQUIREMENT (ELECTRICAL)**  
**DATA SHEET A**

PEM-6666-0



**TECHNICAL SPECIFICATION FOR**  
**ELECTRIC HOIST**  
**4X270 MW BHADRADRI TPS- FGD**

SPECIFICATION NO. PE-TS-440-563-A002	
VOLUME II - B	DATE 26.12.2022
SECTION -I	
REV 00	DATE JULY 2020

**SUB-SECTION IA**  
**SPECIFIC TECHNICAL REQUIREMENT (MECHANICAL)**



**TECHNICAL SPECIFICATION FOR**  
**ELECTRIC HOIST**  
**4X270 MW BHADRADRI TPS- FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME II - B

DATE 26.12.2022

SECTION - I

REV 00

DATE JULY 2020

**SCOPE OF ENQUIRY**

- 1.1 The specification is intended to cover design (i.e. preparation and submission of drawing /documents including "As Built" drawings and O&M manuals), engineering, manufacture, fabrication, assembly, inspection / testing at vendor's & sub-vendor's works, painting, maintenance tools & tackles, fill of lubricants & consumables, mandatory spares along with spares for erection, start-up and commissioning as required, forwarding, proper packing, shipment and delivery at site, along with Supervision of Erection and Commissioning at site for project and package specified complete with all accessories for the total scope defined for **ELECTRIC HOIST**
- 1.2 The contractor shall be responsible for providing all material, equipment & services, which are required to fulfil the intent of ensuring operability, maintainability, reliability and complete safety of the complete work covered under this specification, irrespective of whether it has been specifically listed herein or not. **Omission of specific reference to any component / accessory necessary for proper performance of the equipment shall not relieve the contractor of the responsibility of providing such facilities to complete the supply of ELECTRIC HOIST.**
- 1.3 It is not the intent to specify herein all the details of design and manufacture. However, the equipment shall conform in all respects to high standards of design, engineering and workmanship and shall be capable of performing the required duties in a manner acceptable to purchaser who will interpret the meaning of drawings and specifications and shall be entitled to reject any work or material which in his judgement is not in full accordance herewith.
- 1.4 The extent of supply under the contract includes all items shown in the drawings, notwithstanding the fact that such items may have been omitted from the specification or schedules. Similarly, the extent of supply also includes all items mentioned in the specification and /or schedules, notwithstanding the fact that such items may have been omitted in the drawing.
- 1.5 The general term and conditions, instructions to tenderer and other attachment referred to elsewhere are made part of the tender specification. The equipment materials and works covered by this specification is subject to compliance to all attachments referred to in the specification. The bidder shall be responsible for and governed by all requirements stipulated herein.
- 1.6 While all efforts have been made to make the specification requirement complete & unambiguous, it shall be bidders' responsibility to ask for missing information, ensure completeness of specification, to bring out any contradictory / conflicting requirement in different sections of the specification and within a section itself to the notice of BHEL and to seek any clarification on specification requirement in the format enclosed under Vol-III of the specification **within 10 days of receipt of tender documents.** In absence of any such clarifications, in case of any contradictory requirement, the more stringent requirement as per interpretation of Purchaser/Customer shall prevail and shall be complied by the bidder without any commercial implication on account of the same. Further in case of any missing information in the specification not brought out by the prospective bidders as part of pre-bid clarification, the same shall be furnished by Purchaser/ Customer as and when brought to their notice either by the bidder or by purchaser/ customer themselves. However, such requirements shall be binding on the successful bidder without any commercial & delivery implication.



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS- FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME II - B

DATE 26.12.2022

SECTION -I

REV 00

DATE JULY 2020

- 1.7 The bidder's offer shall not carry any sections like clarification, interpretations and /or assumptions.
- 1.8 Deviations, if any, should be very clearly brought out clause by clause in the enclosed deviation schedule along with cost of withdrawal; otherwise, it will be presumed that the vendor's offer is strictly in line with NIT specification. If no cost of withdrawal is given against the deviation, it will be presumed that deviation can be withdrawn without any cost to BHEL/its customer.
- 1.9 In case all above requirements are not complied with, the offer may be considered as incomplete and would become liable for rejection.
- 1.10 Unless specified otherwise, all through the specification, the word contractor shall have same meaning as successful bidder /vendor and Customer/ Purchaser/Employer will mean BHEL and /or TSGENCO including their consultant as interpreted by BHEL in the relevant context. For details refer the relevant clause in GCC.

**Note:**

Bidder to note that BHEL reserves the right for drawing/document submission through web based Document Management System. Bidder would be provided access to the DMS for drawing/document approval and adequate training for the same. Detailed methodology would be finalized during the kick-off meeting. Bidder to ensure following at their end.

- Internet explorer version – Minimum Internet Explorer 7.
- Internet speed – 2 mbps (Minimum preferred).
- Pop ups from our external DMS IP (124.124.36.198) should not be blocked.
- Vendor's Internal proxy setting should not block DMS application's link (<https://www.bhelpem.com/WrenchWeb>).



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS- FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME II - B

DATE 26.12.2022

SECTION -I

REV 00

DATE JULY 2020

**1.0.0 SCOPE OF WORK****1.1.0 SUPPLIES**

1.1.1 Equipment and services to be furnished by the bidder for the **WIRE ROPE ELECTRIC HOIST** with accessories as per the details given in data sheet-A. Any equipment / accessories not specified in the specification but required to make the hoist units complete and efficient shall also be under the bidder's scope of work.

Each hoist shall include all necessary items but shall not be limited to the following: -

1. Travelling Trolley with drive arrangement.
2. Hoisting mechanism (motor and gear box, wire rope, load hook and hook block)
3. Electrical equipment (control panel, motor, limit switches, DSL current collector etc)
4. Cable for motor, brake, limit switches, etc.
5. Painting of hoist.
6. Power supply thru' DSL along with fixing brackets
7. Testing of hoist at manufacturers works.
8. Main isolating switch with earth fault protection and power cable from 1.5M above ground / operating floor upto DSL/junction box/terminal box.
9. Pendent push button with fixed type cabling
10. Initial fill of lubricants, grease etc.
11. Earthing arrangement
12. Any equipment / accessories not specified here but required to make the equipment complete and efficient shall be under bidder's scope of work.

**1.1.2 Maintenance Tools and Tackles**

One (1) complete unused new set of special purpose tools, tackles and accessories along with detailed instructions and maintenance manual shall be supplied. Each tool and wrench shall be stamped so as to be identified easy for its use. The tools shall be supplied in steel toolbox and with a copy of instruction manual. The items supplied shall be of the best quality, specially protected against rusting in tropical climate. The following shall be provided as minimum requirement:

<b>S-No.</b>	<b>Description</b>	<b>Qty.</b>
1	Complete set of ring spanners (Indicate the sizes offered)	1 Set**
2	Complete set of screwdrivers (Indicate the sizes)	1 Set**
3.	Adjustable Spanner	1 No.



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS- FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME II - B

DATE 26.12.2022

SECTION -I

REV 00

DATE JULY 2020

- |    |                 |       |
|----|-----------------|-------|
| 4. | Insulated plier | 1 No. |
| 5. | Grease gun      | 1 No. |
| 6. | Oil gun         | 1 No. |
| 7. | Line tester     | 1 No. |

(\*\*) – Set shall comprise of complete range of spanners suiting requirement for various capacities of electric hoists.

**Note:** - Bidder shall ensure that the tools & tackles mentioned in above list are sufficient to handle all sizes/capacities of hoists & in case any other /additional tool is required for handling/maintenance any size/capacity of hoist the same shall be included in this list.

### 1.1.3 Erection and commissioning spares.

Erection and commissioning spares, as deemed necessary by the bidder shall be supplied along with each Equipment. List of these commissioning spares shall be furnished by the bidder along with their offer. Any item not quoted by the bidder but found necessary during erection and commissioning shall have to be supplied by the bidder without any cost implication.

Sl no.	Description of equipment/item	Quantity
1	Overload Relay	1 set for each type of EH
2	Limit Switch	1 set for each type of EH
3	Fuse Link	1 set for each type of EH
4	Any other as per manufacture's recommendation	

N:B: One set shall mean 100% requirement for one electric hoist

### 1.1.4 Mandatory Spares -

A complete unused and new set of Mandatory Spare parts shall be supplied. Each part shall be stamped so as to be identified, easy for it use. The items supplied shall be of the best quality and specially protected against rusting in tropical climate. The minimum requirement of mandatory spare parts is listed in Annexure –II, Section IA of this specification.

### 1.2.0 Services to be provided by the bidder

**1.2.1.** Scope of work for delivery & transportation etc shall be as per commercial terms and conditions of NIT.

**1.2.2.** Document approval by customer under Approval category or information category shall not absolve the vendor of their contractual obligations of completing the work as per specification requirement. Any deviation from specified requirement shall be reported by the vendor in writing and require written approval. Unless any change in specified requirement has been brought out by the vendor during detail engineering in writing while submitting the document



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS- FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME II - B

DATE 26.12.2022

SECTION -I

REV 00

DATE JULY 2020

to customer for approval, approved document (with implicit deviation) will not be cited as a reason for not following the specification requirement. In case vendor submits revised drawing after approval of the corresponding drawing, any delay in approval of revised drawing shall be to vendor's account and shall not be used as a reason for extension in contract completion

**1.2.3.** Any other service mentioned in GCC & SCC as relevant to the package.

**1.3.0 Inspection and Testing**

Shall be as per manufacturing quality plan, drawings /documents approved during detail engineering and relevant IS codes. The standard manufacturing quality plan is included in this specification to enable the bidder to understand the extent of inspection and testing requirements to execute the job. Procedure is indicated at Annexure IV, Volume IIB. The successful bidder has to follow the requirement in the above documents along with the relevant standards.

**1.4.0 Drawing / design document for submission after award of contract**

Drawing/ design documents to be submitted as per list & submission schedule attached as Annexure-V, section-II, volume II-B of this specification.

Any other design document/ drawing as required by customer/ BHEL shall be submitted by bidder during detail engineering without any implication.

**1.5.0 Number of drawing and documents for submission**

The number of prints / copies required for various drawing and documents are listed in Annexure –V, of GTR

**1.6.0 Supervision of erection & commissioning:** Bidders shall also be required to extend supervision of erection and commissioning of equipment's under the scope of supply of this specification on project to project basis (as per requirement). Rate on per visit and per man day basis shall be quoted in the price schedule. The actual no of days shall be informed on project to project basis, as and when required. Scope for charges per visit including service at site as per price schedule: Total lump sum price for visits should include travel expenses to & fro site, insurance (if applicable) & boarding and lodging etc for one day of stay at site including supervision charges for erection, commissioning, load testing or any other service at site. . Scope for charges for subsequent stay at site as per price schedule: shall include charges for supervision of erection, commissioning, load testing or any other service at site including boarding & lodging for subsequent stay at site. This shall be from the day of actual commencement of supervision at site/ availability at site for supervision activity, excluding travel time to & from site. These charges shall commence if the representative of vendor has to provide service at site beyond one day.



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS- FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME II - B

DATE 26.12.2022

SECTION -I

REV 00

DATE JULY 2020

Note: Bidder shall be informed at least 10 days in advance for the requirement of visit at site. Visiting team shall consist of one or two expert as deemed necessary by the bidder.

**1.7.0 Surface Preparation, Painting & Colour Scheme**

Detailed painting procedure has been attached as Annexure III, Section IA, Volume IIB. Bidder shall follow the same.

**2.0.0. Works Excluded**

2.1.0 Supply of ISMB monorail for electric hoist travel

2.2.0 Erection and Commissioning of electric hoists.

2.3.0 Purchaser shall provide single point 415V, 3 phase, and 50Hz power feeder at any point of the bay or in the middle of the bay. Vendor shall provide main isolating switch at 1.5 M above the ground / operating floor level and cable required from isolating switch to DSL. Any other supply required by the bidder shall be arranged by the bidder himself, using suitable transformer as per the specification.

**3.0.0. Deviations**

If the bid submitted has got any deviation from the technical stipulations in the tender document, bidder shall tabulate the same in the appropriate "Schedule of Deviations", given in General Condition of Contract ( GCC), furnishing full particular of such deviations along with cost of withdrawal of deviation. Priced copy shall be submitted along with price schedule. Unpriced schedule shall be submitted along with technical offer. Unpriced format should contain " QUOTED" / "NIL" / "NA" against each deviation. Deviations are to be furnished with mention to specific clause number. Reasons / explanations for such deviations shall be furnished. If there are no deviations from the tender document, bidder shall furnish NO DEVIATION CERTIFICATE regarding the same.

**4.0.0. Demonstration Guarantee**

Hoist along with its drives, controls and other accessories shall be demonstrated for the rated capacity against the rated speed of motions and for the service conditions specified as specified in QAP and as per IS 3938.

The bidder shall have the full responsibility for the safe and efficient operation of the hoist with associated accessories as a single unit.

If the shop performance tests indicate the failure of any of the components to achieve the guaranteed performance, the deficiency shall be made good at bidder's cost.

Demonstration tests shall be carried out each time after the rectification /modification is carried out.

**5.0.0. Make of Sub - Vendor items**



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS- FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME II - B

DATE 26.12.2022

SECTION -I

REV 00

DATE JULY 2020

Make of bought out items will be as per Annexure-I, section IA, volume II-B of the specification. No other make will be acceptable, until and unless specifically got approved by BHEL/Customer during detail engineering. Acceptance/non acceptance of same shall not have any impact on manufacturing & delivery schedule and on cost of crane.

**6.0.0 Packing**

Refer General Technical Requirement.

**7.0.0 INFORMATION TO BE FURNISHED BY BIDDER ALONG WITH THE OFFER**

As detailed in "List of documents to be submitted with bid", Section III

**8.0.0 OTHER REQUIREMENTS**

Successful bidder shall furnish detailed erection manual for each of the equipment supplied under this contract along with supply of concerned equipment / component.

Document approval by customer under Approval category or information category shall not absolve the vendor of their contractual obligations of completing the work as per specification requirement. Any deviation from specified requirement shall be reported by the vendor in writing and require written approval. Unless any change in specified requirement has been brought out by the vendor during detail engineering in writing while submitting the document to customer for approval, approved document (with implicit deviation) will not be cited as a reason for not following the specification requirement.

In case vendor submits revised drawing after approval of the corresponding drawing, any delay in approval of revised drawing shall be to vendor's account and shall not be used as a reason for extension in contract completion.

**Annexure A:**

S No.	Area/Equipment Description	Qty (Nos.)	Capacity (T)	Lift (m)	Travel (m)
1	FGD Control Room	1	10 T	12	6
2	ACW/ECW PH for FGD (curved path)	1	2T	2.5	45

**Annexure B:**

List of Commissioning Spares		Total quantity required	Total quantity required
Sl.no	Description	For 2T cap. EH	For 10T cap. EH
i)	Overload Relay	1 set	1 set
ii)	Limit Switch	1 set	1 set
iii)	Fuse Link	1 set	1 set
iv)	Any other		

\* 1 set defined as 100% requirement for one hoist.

PEM-6666-0



**TECHNICAL SPECIFICATION FOR**  
**ELECTRIC HOIST**  
**4X270 MW BHADRADRI TPS- FGD**

SPECIFICATION NO. PE-TS-440-563-A002	
VOLUME II - B	DATE 26.12.2022
SECTION -I	
REV 00	DATE JULY 2020

**QUALITY ASSURANCE PLAN**

		MANUFACTURING QUALITY PLAN								DATE 26.12.2022				TO BE FILLED IN BY CLIENT	
MANUFACTURER'S Name & Address :		ITEM : ELECTRIC WIRE ROPE HOIST CAPACITY UP TO 10 TON.				Sign. Of Mfr.		CLIENT: M/S BHARAT HEAVY ELECTRICALS LIMITED				APPROVED BY :			
		BHEL DOC. NO.						PROJECT : 4X270 MW BHADRADRI TPS							
		REV. NO : 0		DATE:				PAGE NO. :							
SL. NO	COMPONENT & OPERATIONS	CHARACTERISTICS	CLASS	TYPE OF CHECK	QUANTUM OF CHECK		REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD	D	AGENCY			REMARKS	
					M	C/N					M	C	N		
1	2	3	4	5	6	7	8	9	**10			11			
<b>(1) RAW MATERIAL</b>															
1.1	STRUCTURAL MATERIAL - (PLATES For Trolley)	CHEMICAL & MECHANICAL	MAJOR	Chemical & Mechanical	1 Sample/ Lot	1 Sample/ Lot	IS:2062-2011, Gr. A / BR, Approved Drawing / Data sheet	IS:2062-2011 Gr. A or BR, Approved Drawing / Data sheet	I.R/ MTC	✓	P	V	V	TEST WILL BE CARRIED IN ABSENCE OF MILL TC	
		NDT plate > 25mm Thick	MAJOR	UT	100%	100%	ASTM A 435-2004	NOTE-1 PROB FRQ2-5 MHZ	I.R.	✓	P	V	V		
1.2	GEARS, PINIONS, SHAFTS' AXLES (MH, CT)	CHEMICAL & MECHANICAL	MAJOR	CHEMICAL & MECHANICAL	100%	100%	DIN17210/ BS970/ Approved DRG/ DATA SHEET	16MnCr5/ 20MnCr5/ EN8/ EN9/ Approved DRG/ DATA SHEET	I.R.	✓	P	V	V	There is no Mechanical Properties specified in DIN 17210	
		U.T. FOR DIA/ THICKNESS ABOVE 50MM	MAJOR	UT	100%	100%	ASTM A388-2004	Note-1 Prob. FRQ2-5MHZ	I.R.	✓	P	V	V		
1.4	SHEAVES, PULLEYS & GEAR BOX BODY ( If Casting)	Mechanical, VISUAL	MAJOR	Mechanical	1 Sample / Cast/ Lot	1 Sample / Cast/ Lot	As per Approved Drg./ Data sheet/ IS:210-1993(FG200)	As per Approved Drg./ Data Sheet/ IS:210-1993(FG200)	I.R.	✓	P	V	V		
1.5	SEAMLESS FABRICATED PIPE FOR WIRE ROPE DRUM	CHEMICAL, MECHANICAL, FLATTENING, ACID ETCHING TEST (If Seamless Tube)	MAJOR	CHEMICAL, MECHANICAL, FLATTENING, ETCHING	1 Sample/ LENGTH/ Lot	1 Sample/ LENGTH/ Lot	ASTM A106-2004/ Approved DATA SHEET/ DRG. IS:2062 (Welded Pipes)	ASTM A106-2004 / Approved DATA SHEET/ DRG. IS:2062(Welded Pipes)	I.R	✓	P	V	V		
1.6	WHEEL (CT)	CHEMICAL & MECHANICAL	MAJOR	CHEMICAL & MECHANICAL	1 Sample/ Lot	1 Sample/ Lot	BS970-1970/ Approved DATA SHEET/ Approved. Drg.	EN8/ EN9/ Approved. Drg./ Approved Data Sheet	I.R.	✓	P	V	V		
1.7	HOOK	CHEMICAL, MECHANICAL, VISUAL, DIMENSION	MAJOR	CHEMICAL & MECHANICAL.	100%	100%	IS:15560-2005 Approved DATA SHEET/ DRG.	IS:15560-2005 Approved DATA SHEET/ DRG.	MTC/ IR	✓	P	V	V		
		UT IF SHANK DIA MORE THAN 50MM	MAJOR	U.T.	100%	100%	ASTM A388-2004/ IS:3664-1984	NOTE-1	I.R	✓	P	V	V		
1.8	WIRE ROPE	MAKE, SIZE, CONSTRUCTION	MAJOR	Visual	100%	100%	APPD DATA SHEET/ DRG/ IS:2266-1989	Approved DATA SHEET/ DRG. / IS:2266-1989	MTC	✓	P	V	V		
1.9	MOTORS	MAKE/ TYPE/ RATING, ROUTINE TESTS	MAJOR	Visual	100%	100%	Approved DRG/ DATA SHEET/ IS:325	Approved DRG/ DATA SHEET/ IS:325	MTC	✓	P	V	V		
1.10	BRAKES/DCEM/ EHT	MAKE/ TYPE/ RATING	MAJOR	Visual	100%	100%	Approved DRG/ DATA SHEET/ SPEC/ IS:3938-1983	Approved DRG/ DATA SHEET/ SPEC/ IS:3938-1983	MTC	✓	P	V	V		
1.11	CABLES FOR LI POWER/ CONTROL/ TRAILING	MAKE/ TYPE/ RATING	MAJOR	Visual	100%	100%	Approved DRG/ DATA SHEET/ IS: 9968-1968/ IS:1554-1988/ IS:4289/ IS:694	IS: 9968-1968/ IS:1554-1988/ IS:4289/ IS:694	MTC	✓	P	V	V	REFER NOTE 2	
<b>(2) IN-PROCESS INSPECTION</b>															
2.1	WELDING	WPS	MAJOR	VISUAL	100%	100%	ASME SEC IX	ASME SEC IX	QW-482	✓	P	V	V	NTPC/ LLYOD APPROVED WPS AND QUALIFIED WELDERS TO BE USE.	
		WPS & WELDER QUALIFICATION	MAJOR	VISUAL	100%	100%	ASME SEC IX	ASME SEC IX	QW-483 & 484	✓	P	V	V		
<b>LEGEND:</b> *RECORDS, IDENTIFIED WITH "TIO" (✓) SHALL BE ESSENTIALLY INCLUDED BY SUPPLIER IN QA DOCUMENTATION. **M-MANUFACTURER/ SUB-SUPPLIER C-MAIN SUPPLIER CONTRACTOR, N-OWNER P-PERFORM W-WITNESS AND V-VERIFICATION. AS APPROPRIATE, CHP-CUSTOMER/ OWNER SHALL IDENTIFIED IN COLUMN "N" AS "W".									<b>NOTE:</b> # IN-INSPECTION ENGINEER TO CHECK APPROVAL DATE/ REVISION ON NO. OF REFERENCE DOCUMENTS AT THE TIME OF INSPECTION						

		MANUFACTURING QUALITY PLAN										TO BE FILLED IN BY CLIENT		
MANUFACTURER'S Name & Address :		ITEM : ELECTRIC WIRE ROPE HOIST CAPACITY UP TO 10 TON.					Sign. Of Mfr.		CLIENT: M/S BHARAT HEAVY ELECTRICALS LIMITED			DATE 26.12.2022		
		BHEL DOC. NO.							PROJECT : 4X270 MW BHADRADRI TPS					
		REV. NO : 0:		DATE:			PAGE NO. :			APPROVED BY :				
		SL. NO	COMPONENT & OPERATIONS	CHARACTERISTICS	CLASS	TYPE OF CHECK	QUANTUM OF CHECK		REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD	D	AGENCY	
1	2	3	4	5	M	C/N	6	7	8	9	**10			11
2.2	TROLLY	NDT (On Fillet Weld)	MAJOR	DPT	100%	10%	ASTM E 165	NO LINEAR/ ROUND INDICATION	I.R.	✓	P	V	V	REVIEW OF FILM AT THE TIME OF FINAL INSPECTION
		NDT (On Butt Weld)	MAJOR	RT	100%	100%	ASME SEC VIII	ASME SEC VIII Div-1	I.R.	✓	P	V	V	
		NDT (On Butt Weld)	MAJOR	DPT	100%	100%	ASTM E 165	NO LINEAR/ ROUND INDICATION	I.R.	✓	P	V	V	
2.3	GEARS, PINIONS	HARDNESS	MAJOR	HARDNESS	100%	100%	APP. DRG./ DATA SHEET	APP. DRG./ DATA SHEET	I.R.	✓	P	V	V	In case Hardness Not Mentioned in Data Sheet Consider 55±5 HRC for Low Carbon Alloy Steel & 26±4 HRC for Medium Carbon Steel.
		MPI	MAJOR	MPI	100%	100%	ASTM E-709-2004	NO LINEAR INDICATION	I.R.	✓	P	V	V	
2.4	WHEELS	HARDNESS	MAJOR	HARDNESS	100%	100%	APP. DRG./ DATA SHEET	APP. DRG./ DATA SHEET	I.R.	✓	P	V	V	
		MPI	MAJOR	MPI	100%	100%	ASTM E-709-2004	NO LINEAR INDICATION	I.R.	✓	P	V	V	
2.5	ASSEMBLED GEAR BOX (MH)	A) REDUCTION RATIO B) SOUND LEVEL C) TEMP. RISE D) VIBRATION E) OIL LEAKAGE	MAJOR	NO LOAD RUN TEST (HOISTING GEAR BOX)	100%	100%	Sound Level-85dB., Temp. Rise-R.T.+20°C, Vibration-75µ, Oil Leakage-No oil Leak., Reduction Ratio-as per drg. (After 2hrs. Ideal Running)	Sound Level-85dB., Temp. Rise-R.T.+20°C, Vibration-75µ, Oil Leakage-No oil Leak., Reduction Ratio-as per drg. (After 2hrs. Ideal Running)	I.R.	✓	P	V	V	SOUND LEVEL MEASUREMENT TAKEN AT DISTANCE 1 Mtr. FROM GEAR BOX
2.6	HOOK	PROOF LOAD AT 200% (UPTO 32T) OF LIFTING CAPACITY	CRITICAL	PROOF LOAD	100%	100%	IS-15560-2005 CLAUSE NO.10	IS-15560-2005 CLAUSE NO.10	I.R.	✓	P	V	V	
		DPT AFTER PROOF LOAD	CRITICAL	DPT	100%	100%	ASTM E-165	NO LINEAR INDICATION	I.R.	✓	P	V	V	
<b>(3) FINAL INSPECTION</b>														
3.1	CONTROL PANEL / PENDENT PUSH BUTTON STATION	MAKE / TYPE / RATING OF BOI	MAJOR	VISUAL	100%	10%	APPD DRG./ DATA SHEET/ MAKE LIST OF BOI/ IS8623	APPD DRG./ DATA SHEET/ MAKE LIST OF BOI/ IS8623	I.R.	✓	P	W	V	
		HV/ IR, FUNCTIONAL & DIMENSIONS	MAJOR	MSMT	100%	10%	H.V. AT 2.5KV FOR 1Min. & IR AT 1000 V.D.C.	H.V. AT 2.5KV FOR 1Min. & IR AT 1000 V.D.C.	I.R.	✓	P	W	V	
		DEGREE OF PROTECTION BY PAPER INSERTION METHOD	MAJOR	VISUAL	100%	10%	BY PAPER INSERTION METHOD	PAPER SHOULD NOT SLIDE	I.R.	✓	P	W	V	
3.2	ASSEMBLED HOIST WITH ACTUAL CONTROL PANEL	DIMENSIONS	MAJOR	MEASUREMENT	100%	100%	APP. GA DRG. / DATA SHEET	APP. GA DRG. / DATA SHEET	I.R.	✓	P	W	V	
3.3	PERFORMANCE - LOAD TEST AT SWL	SPEED & CURRENT MEASUREMENTS AT SWL. BRAKE OPERATION FOR MH & CT	MAJOR	PERFORMANCE	100%	100%	APPD DRG./ DATA SHEET/ SPECS/IS:3938/ IS:807/ Approved PROCEDURE	APPD DRG./ DATA SHEET/ SPECS/ IS:3938/ IS:807/ Approved PROCEDURE	I.R.	✓	P	W	V	
3.4	OVER LOAD TEST	OVER LOAD TEST AT 125% OF SWL	MAJOR	BRAKE FUNCTION	100%	100%	ASPER IS:3938/ IS807/ Approved PROCEDURE	ASPER IS:3938/ IS807/ Approved PROCEDURE	I.R.	✓	P	W	V	
3.5	PAINTING	ADHESION, VISUAL & DFT MEASUREMENT	MAJOR	VISUAL & MEASUREMENT	100%	100%	ASPER Approved Drg./ Data sheet/ approved spec.	ASPER Approved Drg./ Data sheet/ approved spec.	I.R.	✓	P	V	V	
3.6	SPARE	MAKE / TYPE / RATING OF BOI	MAJOR	VISUAL	100%	10%	APPD DRG./ DATA SHEET/ MAKE LIST OF BOI	APPD DRG./ DATA SHEET/ MAKE LIST OF BOI	I.R.	✓	P	V	V	
NOTE-1	WHEN BACK WALL ECHO SET AT 100% ON CRT SCREEN THEN (A) DEFECT ECHO SHOULD NOT EXCEED 20% (B) B.W.E. SHOULD BE MIN 80% IN ANY AREA													
NOTE-2	BOUGHT OUT ITEMS ( ELECTRICAL & MECHANICAL ) SHALL BE AS PER APPROVED MAKE LIST OF BOI.													
NOTE-3	Final Painting of Hoist will be done at the time of Dispatch as per Approved Drawing/ Surface Preparation shall be ISO5801-1-SA2 1/ 2/ Specification.													
NOTE-4	100% of the hoist of same capacity to be witnessed for load & overload test.													
NOTE-5	CT speed shall be demonstrated for standard/ built up beams.													
LEGAND : *RECORDS IDENTIFIED WITH "TICK" (✓) SHALL BE ESSENTIALLY INCLUDED BY SUPPLIER IN QA DOCUMENTATION. **M:MANUFACTURER/ SUB-SUPPLIER CMAIN SUPPLIER/ CONTRACTOR, N:OWNER P:PERFORM W:WITNESS AND V:VERIFICATION. AS APPROPRIATE, CHP-CUSTOMER/ OWNER SHALL IDENTIFIED IN COLUM "N" AS "W".									NOTE : # INSPECTION ENGINEER TO CHECK APP. DRG./ DATA SHEET/ MAKE LIST OF BOI OF REFERENCE DOCUMENTS AT THE TIME OF INSPECTION					

PEM-6666-0



**TECHNICAL SPECIFICATION FOR**  
**ELECTRIC HOIST**  
**4X270 MW BHADRADRI TPS- FGD**

SPECIFICATION NO. PE-TS-440-563-A002	
VOLUME II - B	DATE 26.12.2022
SECTION -I	
REV 00	DATE JULY 2020

**CUSTOMER SPECIFICATION**

## CONTENT

<b>CLAUSE NO.</b>	<b>DESCRIPTION</b>
1.00.00	CODES AND STANDARDS
2.00.00	RESPONSIBILITY FOR DESIGN
3.00.00	NAME PLATES (RATING PLATES)
4.00.00	SAFETY AND SECURITY
5.00.00	GUARDS
6.00.00	LOCATION AND LAYOUT REQUIREMENTS
7.00.00	OPERATION, MAINTENANCE AND AVAILABILITY CONSIDERATIONS
8.00.00	MATERIALS
9.00.00	LUBRICATION
10.00.00	LUBRICANTS & CONTROL FLUIDS
11.00.00	OPERATION AND MAINTENANCE
12.00.00	PLANT LIFE AND MODE OF OPERATION
13.00.00	PACKAGING & MARKING
14.00.00	PROTECTION
15.00.00	ENVIRONMENT PROTECTION AND NOISE LEVEL REQUIREMENT
16.00.00	INSPECTION AND TESTING
17.00.00	TRAINING OF OWNER'S PERSONNEL
18.00.00	DEVIATIONS
	<b>ATTACHMENTS</b>
ANNEXURE-I	LIST OF STANDARDS FOR REFERENCE
ANNEXURE-II	CRITERIA FOR LAYOUT

## **GENERAL TECHNICAL REQUIREMENTS**

### **1.00.00 CODES AND STANDARDS**

1.01.00 Except where otherwise specified, the Plant shall comply with the appropriate Indian Standard or an agreed internationally accepted Standard Specification as listed in the annexure to this Section and mentioned in detailed specifications, each incorporating the latest revisions at the time of tendering. Where no internationally accepted standard is applicable, the Bidder shall give all particulars and details as necessary; to enable the Owner to identify all of the Plant in the same detail as would be possible had there been a Standard Specification.

1.02.00 Where the Bidder proposes alternative codes or standards he shall include in his tender one copy (in English) of each Standard Specification to which materials offered shall comply. In such case, the adopted alternative standard shall be equivalent or superior to the standards mentioned in the specification.

1.03.00 The plant will be designed in compliance with applicable National and International Codes and Standards such as ASME, ASTM, DIN, BS, IEC, IEEE, IS, etc. Wherever specified or required the Plant shall conform to various statutory regulations such as Indian Boiler Regulations, Indian Explosives Act, Indian Factories Act, Indian Electricity Act, Environmental Regulations, etc. Wherever required, approval for the plant supplied under the specification from statutory authorities shall be the responsibility of the Contractor.

1.04.00 In the event of any conflict between the codes and standards referred above, and the requirements of this specification, the requirements, which are more stringent, shall govern.

1.05.00 In case of any change of code, standards and regulations between the date of purchase order and the date the Contractor proceeds with manufacturing the Owner shall have the option to incorporate the changed requirements. It shall be the responsibility of the Contractor to advise Owner of the resulting effect.

1.06.00 Successful Bidder to furnish two (2) sets of latest of national/inter-national codes and standards to owner.

### **2.00.00 RESPONSIBILITY FOR DESIGN**

2.01.00 The Contractor shall assume full responsibility for the design of the whole and every portion of the Plant, whether or not the design work was undertaken specifically in relation to the Contract and whether or not the Contractor was directly involved in the design work.

- 2.02.00 Notwithstanding the Owner's wish to receive the benefits of new, advanced and improved technologies, a prime requirement is that all the systems and components proposed shall have been already adequately developed and shall have demonstrated good reliability under similar, or more arduous conditions elsewhere, at least for continuous 2 years in two different power station.
- 2.03.00 The successful bidder shall have to carry out surge analysis, BFP transient analysis and other transient condition studies as may be necessary and as required by the Owner as per proven engineering practice.
- 2.04.00 The Bid shall include a detailed discussion on the development status of, and the reasons for any changes made in proposed systems or components for the Plant, as compared with similar items previously supplied in other installations cited by the bidder as reference plants.
- 2.05.00 The Bidder may also make alternate offers, provided such offers are superior in his opinion in which case adequate technical information, operating feed back, etc. are to be enclosed with the offer, to enable the Owner to assess the superiority and reliability of the alternatives offered. In case of each alternative offer, its implications on the performance, guaranteed efficiency, auxiliary power consumptions, etc. shall be clearly brought out to the Owner to make an overall assessment. In any case, the base offer shall necessarily be in line with the specifications i.e. Base offer shall be as per the technical specifications and the same will be considered for techno-commercial evaluation.
- 3.00.00 **NAME PLATES (RATING PLATES)**
- 3.01.00 Instruction plates, name plates or labels shall be permanently attached to each main and auxiliary item of plant in a conspicuous position. These plates shall be engraved with the identifying name, type and manufacturers serial number, together with the loading conditions under which the item of plant has been designed to operate.
- 3.02.00 Items such as valves, etc. which are subject to hand operation, shall be provided with nameplates so constructed as to remain clearly legible throughout the life of the plant giving due consideration to the difficult climatic conditions to be encountered. Nameplates shall be securely mounted where they will not be obscured in service by insulation, cladding, actuators or other equipment. Direction of flow is also to be engraved.
- 3.03.00 All trade nameplates and labels shall be in English language. All measurements shall be in M.K.S. Units.
- 3.04.00 The size and location of nameplates shall be subject to Approval of the Engineer.
- 4.00.00 **SAFETY AND SECURITY**
- 4.01.00 The design shall incorporate every reasonable precaution and provision for the safety of all personnel and for the safety and security of all persons and

property. The design shall comply with all appropriate statutory regulations relating to safety. All structures and equipment shall be designed and constructed to withstand every foreseeable static and dynamic loading condition, including loading under earthquake conditions, with an adequate margin of safety.

- 4.02.00 Ready and safe access with clear head room shall be provided to all parts of the plant for operation, inspection, cleaning and maintenance.
- 4.03.00 Escape routes and clear ways shall be provided to allow speedy evacuation of the plant in the event of fire or explosion, and the plant layout shall allow for ease of access to all parts of the Works by rescue and fire fighting teams. The plant layout shall be designed to localise and minimise the effects of any fire or explosion. The recommendations of NFPA, OSHA, and TAC etc. as necessary shall be followed in all respects.
- 4.04.00 The use of corrosive, explosive, toxic or otherwise hazardous materials shall be kept to a minimum during construction and the design of the plant shall minimise the requirement for such materials during operation and maintenance. Where such materials must be used, all necessary precautions shall be taken in the design, manufacture and layout of equipment to minimise the resulting hazard, and all equipment necessary for the protection and first-aid treatment of personnel in the event of accidents shall be provided. Particular attention is drawn to avoid the use of materials containing asbestos in any form.
- 5.00.00 **GUARDS**
- 5.01.00 Effective guards and fences must be provided to prevent injury to operators through accident or malpractice.
- 5.02.00 Mesh guards which allow visual inspection of equipment with the guard in place are generally preferable. The guards shall be constructed of mesh attached to a rigid framework of mild steel rod, tube, or angle and the whole galvanised to prevent loss of strength by rusting or corrosion. The guards shall be designed to facilitate removal and replacement during maintenance.
- 5.03.00 All drive belts, couplings, gears, sharp metallic edges and chains must be safely guarded. Any lubricating nipple requiring attention during normal running must be positioned where they can be reached without moving the guards.
- 5.04.00 Guards for couplings and rotating shafts shall be in accordance with BS 5304-1975 or similar approved standard. All rotating shafts and parts of shafts must be covered.
- 5.05.00 Suitable fencing shall be provided to enclose all openings or doorways used for the hoisting and lowering of machinery etc. This fencing must be securely fixed but quickly detachable when required. A secure hand hold must be provided on each side of the opening or doorway.

The majority of plant and equipment (excluding steam generator and some other auxiliaries) shall all be of indoor installation. A broad list of buildings housing such equipment is given elsewhere in this specification. Layout should facilitate access for operation-maintenance and inspection of any one or more equipment/components at a time without disturbing the operation or installation of rest of the plant. Further, Bidder should comply with the criteria given under the various equipment and system specifications as well as those stipulated in Annexure-II attached to this section.

Enclosed General Layout and other tender layout drawings show the location of major installations and auxiliary buildings. The Bidder shall try to retain these locations as far as practicable. The layout of equipment within the power house as shown in the tender drawings is indicative. The Bidder may, subject to Owner's approval alter the same to suit the space requirement of the equipment offered.

Bidder may give as an alternative his own preferred layout clearly indicating the advantages and other implications, if any. Such alternative will not be considered for evaluating the bid, but may be considered with the successful Bidder if Owner/Engineer finds the proposal more attractive in terms of techno-economic consideration.

While developing the layout of buildings the following criteria shall be given effect :

- a) The minimum width of clear access corridors around equipment shall be 1.2 meter.
- b) Each building shall have an identified vacant space for equipment unloading and maintenance and preferably a separate bay altogether in buildings housing heavy equipment. Provision for handling equipment by monorail hoist and/or overhead crane shall be made as specified.
- c) The minimum clear height available between two consecutive floor slabs shall not be less than five (5) meters. A clear head room of 2.5m shall be maintained between the floor and any overhead piping/ cables or other obstruction. Adequate provision for natural ventilation and illumination shall be made as per good engineering practices.
- d) There shall be at least two (2) nos. main access doors, one on either side of each building, of which one shall be minimum 3 meters wide with rolling shutters for equipment entry. For multistoried buildings, at least two (2) nos. regular staircases diagonally opposite to each other shall be provided connecting all the floors and roof. These minimum requirements shall be augmented as required depending on the floor area, statutory requirements and TAC recommendations.
- e) All buildings shall have provision for toilet and associated effluent discharge system together with facility for drinking water. The criteria for ventilation, fire protection and illumination of building spaces specified

---

elsewhere in this specification shall be complied with.

DATE 26.12.2022

- f) All rail/road crossings for pipe/cable racks shall be done with minimum 8 meters headroom from top of rail/road to bottom of rack. Similarly top cover over underground pipes/cables shall be minimum one (1) meter. For other detail refer to Annexure-II.
- g) Cubicle for operating personnel shall be located at safe place near the equipment.
- h) Interplant cable routing will be on overhead cable trays on pipe cum cable trestle or on cable trestle except where approved by purchaser/consultant. In exceptional case, small stretch of outdoor run of interplant cable routing may be taken through cable trench only with the Employer's prior approval.
- i) Concept of various mechanical and electrical equipment location and building dimensions (including column-row spacing) as shown in Plot Plan/Floor Plan drawing are to be adhered to. Any departure from this suggestive layout is primarily not recommended.

**7.00.00 OPERATION, MAINTENANCE & AVAILABILITY CONSIDERATIONS**

7.01.00 Equipment/works offered shall be designed for high availability, high reliability, low maintenance and ease of operation & maintenance. The Bidder shall specifically state the design features incorporated to achieve high degree of reliability, availability, operability and ease of maintenance. He shall also furnish details of availability records in plants stated in his experience list.

7.02.00 Ample space for ease of operation and maintenance including equipment removal, tube bundle/cartridge/rotor pulling etc. shall be provided. All valves, gates, dampers and other devices shall be located and oriented in such a way that they are accessible from operating floor levels. Where this cannot be adhered to, platforms and walkways with access ladders shall be provided to facilitate operation and maintenance.

7.03.0 Motorised lifting devices, i.e. hoists, chain pulleys, jacks, etc. shall be provided for handling and carrying out maintenance of any equipment and/or part having weight in excess of 2000 Kg. Suitable beams, hooks etc. for this purpose shall be provided in the buildings.

No lifting arrangement is necessary for part having weight less than 500 Kg. Hoist shall be well protected by environment. Suitable painting and coating covering hoist at outdoor shall be provided.

Lifting devices like lifting tackles, slings, etc. to be connected to hook of the hoist/crane shall be provided by the Bidder for lifting the equipment, accessories covered under this specification.

7.04.00 All similar parts of the equipment shall be made to gauge and shall be interchangeable with and shall be made of same material and workmanship as the corresponding parts of the equipment. Where feasible common

components shall be employed in different pieces of equipment in order to optimize the spares inventory and utilization. DATE 26.12.2022

8.00.00 **MATERIALS**

8.01.00 In selecting materials of construction of equipment, the Contractor shall pay particular attention to the atmospheric conditions existing at the Site and the nature of material/fluid handled. Wherever deviations are taken in respect of materials specified, the reasons shall be spelt out clearly in the proposal.

All materials shall be new, and shall be of the quality most suited to the proposed application.

8.02.00 In as far as is possible; materials shall be in accordance with Indian or international standard specifications and shall be used in accordance with Indian or international codes of practice. Where such standards or codes of practice are not available sufficient information shall be provided to allow the Owner to assess the suitability of the material for the particular application.

All materials used shall have performed lengthy satisfactory service in similar or more arduous conditions to those proposed by the Contractor.

8.03.00 All parts which could deteriorate or corrode under the influence of the atmospheric, meteorological or soil conditions at the Site, or under the influence of the working conditions shall be suitably and effectively protected so that such deterioration or corrosion is a minimum over the life of the plant.

9.00.00 **LUBRICATION**

9.01.00 Provision shall be made for suitable efficient lubrication where necessary to ensure smooth operation free from undue wear.

9.02.00 Non ferrous capillary tubing shall be used throughout.

9.03.00 Gear boxes and oil baths shall be provided with filling and drain plugs, both of adequate size. An approved means of oil indication including level switches and temperature indication shall be provided.

9.04.00 All high speed gears shall be oil bath lubricated. Low speed gears shall be lubricated by means of soft grease. Removable and accessible drip pans shall be provided to collect lubricant which may drop from operating parts.

9.05.00 All lubrication points shall be conveniently situated for maintenance purposes. It must be possible to carry out lubrication from a gangway or landing and without the removal of guarding or having to insert the hand into it. Where accessibility to a bearing for oiling purposes would be difficult a method of remote lubrication shall be fitted.

9.06.00 The Contractor shall supply grease gun equipment suitable to service each type of nipple fitted.

**10.00.00 LUBRICANTS AND CONTROL FLUIDS**

- 10.01.00 The Contractor shall provide a detailed and comprehensive specification for all lubricating oils, greases and control fluids required for the entire plant. A sufficient supply of these shall be provided by the Contractor for initial commissioning, first fill and till COD of the unit.
- 10.02.00 The Contractor shall supply a detailed schedule giving the lubricant testing, cleaning and replacement procedures. All equipment and facilities necessary for the testing, cleaning and changing of lubricants and control fluids shall be provided. The Contractor shall endeavor to reduce the varieties and grades of required lubricants and control fluids to a minimum, matching them where possible to those already in use in the generating station in order to simplify procurement and minimise storage requirements. All lubricants and control fluids shall be of internationally recognised standards and shall be easily obtainable from a large number of Indian suppliers. Bidder shall also indicate the equivalent Indian Standard for the above for easy procurement in future.
- 10.03.00 No lubricant or control fluid shall have toxic or other harmful effects on personnel or on the environment.

**11.00.00 OPERATION AND MAINTENANCE**

- 11.01.00 The plant shall be designed and constructed so that operation and maintenance manpower requirements are minimised.
- The design and layout shall facilitate inspection, cleaning, maintenance and repair. The importance of continuity of operation is second only to that of safety.
- 11.02.00 Spare parts for equipment shall be interchangeable with the original components and, so far as possible, be of common design and manufacture.
- 11.03.00 All similar standard components/parts of similar standard equipment provided shall be interchangeable with one another. Further identical equipments shall be provided for similar duties so that the same are interchangeable with one another in totality and component wise.
- 11.04.00 All heavy parts (500 Kg and above) must be provided with a convenient arrangement for slinging and handling during erection and overhaul. Any item of plant normally stripped or lifted during periods of maintenance and weighing one tonne or above, shall be clearly marked with its weight.
- 11.05.00 On completion of commissioning, a complete set of tools for the maintenance of the entire plant shall be provided by the Contractor. This shall include all necessary spanners, special wrenches, extraction equipment and any special tools reasonably required by the Engineer. Tools used during erection and commissioning shall not be accepted except with the specific approval of the Engineer.
- 11.06.00 All equipment and major valves should be provided with adequate maintenance approach and facility.

The complete plant including all the equipment and systems individually and collectively shall be designed for continuous operation for an economic service life of thirty (30) years under the prevailing site conditions and for the type of duty intended.

The critical components of the Steam Generator, Turbine-Generator and Auxiliary equipment, the life of which is limited by time and temperature dependent mechanisms such as thermal stress, creep and low cycle fatigue, are to be designed considering expected (hot, warm and cold) start-up, shut-down and cyclic load variations.

The allowable stresses shall be reduced so that life expectancy to minimum 2,00,000 hours of operation can be achieved. The Bidder shall discuss this aspect in his technical proposal.

The unit would be operated on base load with cyclic load variation. The load variation is expected to be as per schedule depending on power demand.

The expected start-ups should be considered as minimum  
(Based on HPT metal temperature)

Cold start-up ( >72 hrs. shutdown)	:	6 per year
Warm start-up (between 10 to 72 hrs. of shutdown)	:	40 per year
Hot start-up (less than 10 hrs. shutdown)	:	160 per year

**PACKAGING & MARKING**

All the equipment shall be suitably protected, coated, covered or boxed and crated to prevent damage or deterioration during transit, handling and storage at site till the time of erection. While packing all the materials, the limitations from the point of view of availability of railway wagon sizes in India should be taken account of. The details of various wagons normally available with Indian Railways for transportation of heavy equipment shall be considered by the Bidder. The Contractor shall be responsible for all loss or damage during transportation, handling and storage due to improper packing.

As per the information available, the dimensions of OD consignment for transportation of the equipment by rail (if any equipment to be handled through rail transportation) are as below :

a)	Width of the Package (from centre-line of rails - 1.6 metres on both sides)	:	3.2 Meters
b)	Height of the package from rail top	:	4.47 Meters

The above indicates the dimensions which can be normally transported on the

wagons without infringement of the "moving gauge". This is however not indicative of the consignment which can be carried out with infringement of "moving gauge" duly authorised and approved by the Indian Railways. There may be difference between the "moving gauge" and the "fixed structure gauge" and consignments infringing the "moving gauge" can be moved after investigation regarding possible infringement with the fixed structures. As the critical fixed structures in each route are different, consignments infringing moving dimensions have to be individually investigated to select a route and also determine the restrictions under which such movement is to be carried out. Such routes selected or other mode of transport envisaged is to be clearly brought out in the proposal wherever transport of over dimensional equipment is involved.

Bidder to consider unloading of material delivered through rail transportation, at near by railway station/ site unloading siding. The subsequent transportation up to project work place shall be considered by road only. All unloading and handling equipment both at railway station siding and at project site shall be arranged by the Bidder. Necessary arrangement to be organized with the railway authority for such purpose shall also be under the scope of services of the Bidder. Bidder may consider entire material delivered up to site through rail transportation only.

The identification marking indicating the name and address of the consignee shall be clearly marked in indelible ink on two opposite sides and top of each of the packages. In addition the Contractor shall include in the marking gross and net weight, outer dimension and cubic measurement. Each package shall be accompanied by a packing note (in weather proof paper) quoting specifically the name of the Contractor, the number and date of contract and names of the office placing the contract, nomenclature of contents and Bill of Material.

For imported equipment and material, suitable port facilities may be used in which case material may be transported from the port by tractor-trailer. Bidder may consider this aspect.

14.00.00

## **PROTECTION**

Equipment having antifriction or sleeve bearings shall be protected by weather-tight enclosures. Coated surfaces shall be protected against impact, abrasion, discoloration and other damages. Surfaces that are damaged shall be repainted.

Electrical equipment, controls and insulations shall be protected against moisture and water damages. All external gasket surfaces and flange faces, couplings, rotating equipment shafts, bearings and like items shall be thoroughly cleaned and coated with rust preventive compound as specified above and protected with suitable wood, metal or other substantial type covering to ensure their full protection. All exposed threaded parts shall be greased and protected with metallic or other substantial type protectors.

All piping, tubing and conduit connections on equipment and other equipment openings shall be closed with rough usage covers or plugs. Female threaded openings shall be closed with rough usage covers or forged steel plugs. The closures shall be taped to seal the interior of the equipment. Open ends of

pipings, tubing and conduit shall be sealed and taped.

DATE 26.12.2022

Returnable containers and special shipping devices shall be returned by the manufacturer's field representative at the Contractor's expense.

15.00.00 **ENVIRONMENT PROTECTION AND NOISE LEVEL REQUIREMENT**

15.01.00 **Environment Protection**

The plant shall be designed for installation and operation in harmony with the surrounding environment and all measures of pollution control shall be ensured by the Bidder to restrict pollution from the liquid effluent and stack emission within the limits as given below with due consideration of Environment (Protection) Rules 1986 as amended till date.

In case the Ministry of Environment & Forest stipulate any other conditions not specified hereunder while clearing the project shall be complied with the plant by the contractor.

15.01.01 For Liquid Effluent

- a) Provision laid down in schedule-I for Thermal Power Plants and also in Schedule-VI. General Standards for discharge of Environmental pollutants Part-A : Effects of Environmental (protection) Rules 1986, as amended till date.
- b) Any specific requirement of State Pollution Authorities over and above the above stipulation.

15.01.02 For Air Emission

- a) Suspended Particulate Matter i.e. dust burden at chimney outlet - Maximum 50 mg/Nm<sup>3</sup> (with worst coal and one field out at TMCR).
- b) NO<sub>x</sub> - 365 ppm Max. or 750 mg/Nm<sup>3</sup> (Equivalent NO<sub>2</sub>).
- c) SO<sub>2</sub> - Concentration based standard 2000 mg/Nm<sup>3</sup>. Load based standard 0.2 metric tonne /MWe/day (for first 500 MW and 0.1 metric tonne/MWe/day for rest of the capacity above 500 MW)

In absence of Indian Standard for emission from power plants as on date, for certain gaseous effluents, the internationally accepted World Bank Standard is to be followed. Indian Standard for emission of power plants are under formulation. Should this standard is published before finalisation of the contract, the bidder has to comply the more stringent of the above norm or the new Indian Standard.

The bidder shall include in his scope all necessary equipment and measuring instruments to comply with above requirements. Location and accessibility of the instruments shall be properly coordinated.

**Noise Level Requirement**

The plant will be designed, constructed and provided with suitable acoustic measures to ensure the noise level criteria as per the following stipulations.

- a) Maximum noise level shall not exceed 85 dB (A) when measured at 1.0M away from the noise emission source.
- b) Maximum noise level from its source within the premises shall not exceed 70 dB (A) as per Environment (Protection) Rules 1986, Schedule-III, 'Ambient Air Quality Standards' in respect of noise.
- c) Any statutory changes in stipulations regarding noise limitation that may occur in future according to State Pollution Control Board or Central pollution Control Board or Ministry of Environment & Forest regulation during tenure of the contract, the contractor shall comply with the requirement.

An exception will be made for the plant at startup operations and other big pressure reducing devices operating during emergency periods and for the safety valves.

## 16.00.00

**INSPECTION AND TESTING**

## 16.01.00

**Inspection and Tests during Manufacture**

## 16.01.01

The method and techniques to be used by the Contractor for the control of quality during manufacture of all plant and equipment shall be agreed with the Owner prior to the Award of Contract.

## 16.01.02

The Owner's general requirements with respect to quality control and the required shop tests are set out elsewhere in this specification.

## 16.01.03

Before any item of plant or equipment leaves its place of manufacture the Owner shall be given the option of witnessing inspections and tests for compliance with the specification and related standards.

## 16.01.04

Advance notice shall be given to the Owner as agreed in the Contract, prior to the stage of manufacture being reached, and the piece of plant must be held at this stage until the Owner has inspected the piece, or has advised in writing that inspection is waived. If having consulted the Owner and given reasonable notice in writing of the date on which the piece of plant will be available for inspection, the Owner does not attend the Contractor may proceed with manufacture having forwarded to the Owner duly certified copies of his own inspection and test results.

The Contractor shall forthwith forward to the engineer duly certified copies of the Test Certificates in six copies (one to the Purchaser and five to the Consulting Engineer) for approval. Distribution of six (6) copies of Test Certificates for approval will be two(2) copies to owner and four(4) copies to consultant. These four(4) copies will be further distributed by consultant after approval to owner, site and bidder. One copy will be retained with the

Further, nine (9) copies of Shop Test Certificates shall be bound with Instruction Manuals referred to elsewhere. Distribution of nine (9) copies of Shop Test Certificates for approval will be Two (2) copies to owner, Three (3) copies to site, Two (2) copies to consultant, Two (2) copies to owner's library / record.

16.01.05 Under no circumstances any repair or welding of castings be carried out without the consent of the Owner's Engineer. Proof of the effectiveness of each repair by radiographic and/or other non-destructive testing technique, shall be provided to the Engineer along with Defect Map.

16.01.06 All the individual and assembled rotating parts shall be statically and dynamically balanced in the works.

Where accurate alignment is necessary for component parts of machinery normally assembled on site, the Contractor shall allow for trial assembly prior to despatch from place of manufacture.

16.01.07 All materials used for the manufacture of equipment covered under this specification shall be of tested quality. Relevant test certificates shall be made available to the Purchaser. The certificates shall include tests for mechanical properties and chemical analysis of representative material or any other test as required by approved QAP/ Material specification.

16.01.08 All pressure parts connected to pumping main shall be subjected to hydraulic testing at a pressure of 150% of shut-off head for a period not less than one hour. Other parts shall be tested for one and half times the maximum operating pressure or as required by design code of that part, for a period not less than one hour.

16.01.09 All necessary non-destructive examinations shall be performed to meet the applicable code requirements.

16.01.10 All welding procedures adopted for performing welding work shall be qualified in accordance with the requirements of Section-IX of ASME code or IBR as applicable. All welded joints for pressure parts shall be tested by liquid penetrant examination according to the method outlined in ASME Boiler and Pressure Vessel code. Radiography, magnetic particle examination magnflux and ultrasonic testing shall be employed wherever necessary/recommended by the applicable code. At least 10% of all major butt welding joints shall be radiographed.

16.01.11 Statutory payments in respect of IBR approvals including inspection for design and manufacturer of equipment shall be made by the Bidder. All payment for erection and testing at site (i.e. under IBR jurisdiction) shall also be made by the Bidder. In such case Contractor's scope shall also be extended to preparation of all necessary documents, co-ordination and follow-up with IBR authorities for above approval.

16.02.00 **Performance Tests at Site**

- 16.02.01 The full requirements for testing the system shall be agreed between the Owner and the Bidder prior to Award of Contract. The completely erected System shall be tested by the Contractor on site under normal operating conditions. The Contractor shall also ensure the correct performance of the System under abnormal conditions, i.e. the correct working of the various emergency and safety devices, interlocks, etc.
- 16.02.02 The Bidder shall provide complete details of his normal procedures for testing, for the quality of erection and for the performance of the erected plant. These tests shall include site pressure test on all erected pipe work to demonstrate the quality of the piping and the adequacy of joints made at site.
- 16.02.03 The Contractor shall furnish the quality procedures to be adopted for assuring quality from the receipt of material at site, during storage, erection, pre-commissioning to tests on completion and commissioning of the complete system/equipment.
- 16.03.00 For details of specific tests required on individual equipment refer to respective section of this specification.

**17.00.00 TRAINING OF OWNER'S PERSONNEL**

The Contractor shall extend all possible assistance and co-operation to the Purchaser regarding the transfer of technology and developing expertise in the area of engineering operation and maintenance of the Plant.

Number of man-days of training as mentioned below shall be included in his Tender.

**17.01.00 Training at Contractor's Premises**

The Contractor shall conduct training of sixty (60) engineers of the Owner on engineering, operation and maintenance of the Plant at the Contractor's or Associates or Sub-contractor's premises where adequate training facilities are available during the design and manufacturing stage of the Contractor.

The total man-months for training of engineers shall be maximum sixty (60), having following indicative break-up :

Discipline	No. of Engineers	No. of Man-month
Operation	20 heads	20
Maintenance Boiler, Turbine, Mechanical	20 heads	20
Electrical Maintenance	8 heads	4
Control & Instrumentation	8 heads	4
Maintenance Planning	4 heads	2
	-----	-----

However, the details of the training programme will be discussed and finalised with the successful Bidder.

The training may also be arranged by the Contractor in any Plant where the equipment manufactured by the Contractor or his Associates is under installation, operation or testing to enable the trainees to become familiar with the equipment being furnished by the Contractor. All expenses inherently related to the training shall be borne by the Contractor and shall include but not limited to travel expenses (international and inland fares), lodging and per diem charges as well as medical insurance, instructors fee, programme and miscellaneous cost to be incurred during the training.

The training programme shall be adequate for the trainees to acquire the necessary expertise and competence in the area of engineering, operation and maintenance and as trainers for in-house technology transfer programme of the Purchaser.

The Contractor shall be responsible for the development of the Training Module and Programme Schedule which shall be submitted to the Purchaser for approval.

The components of the training modules shall include but not be limited to the training procedures/methodology, instructional materials such as audio visual materials, CDs and slides and manuals for each trainee.

Three (3) sets of the materials included in the training modules shall be handed over to the Purchaser upon completion of the training. An evaluation shall be jointly undertaken by the Contractor and the Purchaser's representative on the adequacy, appropriateness and relevance of the training and the programme effectiveness after the training. The training material shall be in English language only.

The content of the training programme shall include but not be limited to:

1. Coal fired thermal plant principles in management and practice for operators, technicians and maintenance personnel.
2. Plant operation and systems training for operators including simulator training as applicable.
3. Maintenance training programme covering electrical, mechanical and instrumentation and control.

Said training programme shall be submitted to the Purchaser for approval.

The timing of the training should be such that the participants will be conversant with sufficient know-how to participate in the pre-commissioning and commissioning tests of the Plant.

The Contractor shall provide qualified English speaking instructors and training

17.02.00      **Operation and Maintenance Training at Site**

The Contractor shall provide a comprehensive training programme related to design application, plant management, operation and maintenance, including trouble shooting, of the Contractor's supplied system and equipment at the Site starting from Start of Commissioning and thereafter up to the Final Acceptance of the first Unit.

The following instructors shall be at the Site continuously during the training :

- a)      One (1) for Steam Generator and Auxiliaries ;
- b)      One (1) for Turbine Generator and Auxiliaries ;
- c)      One (1) for Electrical Works ;
- d)      One (1) for Instrumentation and Control (Boiler and Auxiliaries) ;
- e)      One (1) for Instrumentation and Control (Turbine and Auxiliaries).

17.03.00      **On-the-Job Training**

During the period of pre-commissioning, commissioning and trial operation, the Purchaser shall provide operation and maintenance personnel to assist the Contractor in the operation and maintenance of his supply and work under the direction of the Contractor for the purpose of on-the-job training.

The Purchaser shall have the right to send to the Site his employees later intended to operate and maintain the equipment supplied under this Contract. The Contractor shall, without additional cost, use his site staff to instruct these employees on the operation and maintenance of the equipment. All instructions shall be in the English language.

17.04.00      For detail C&I training refer to Volume-VI, Section-9.

18.00.00      **DEVIATIONS**

The Bidder is required to submit with his proposal in the relevant schedules a detail list of any and all deviations taken by him clearly without any ambiguity. In the absence of such a list it will be understood and agreed that the Bidder's proposal is based on strict conformance to this specification and no post-contract negotiations would be allowed in this regard.

Unless otherwise specifically indicated in the deviation list, it will be construed and agreed that details indicated in documents & drawings furnished by the Bidder along with the offer is in-line with the specification requirement.

**LIST OF STANDARDS FOR REFERENCE**

- a) International Standards Organisation (ISO).
- b) International Electro-technical Commission (IEC).
- c) American Society of Mechanical Engineers (ASME).
- d) American National Standards Institute (ANSI).
- e) American Society for Testing and Materials (ASTM).
- f) American Institute of Steel Construction (AISC).
- g) American Welding Society (AWS).
- h) Architecture Institute of Japan (AIJ).
- i) National Fire Protection Association (NFPA).
- j) National Electrical Manufacturer's Association (NEMA).
- k) Japanese Electro-technical Committee (JEC).
- l) Institute of Electrical and Electronics Engineers (IEEE).
- m) Federal Occupational Safety and Health Regulations (OSHA).
- n) Instrument Society of America (ISA).
- o) National Electric Code (NEC).
- p) Heat Exchanger Institute (HEI).
- q) Tubular Exchanger Manufacturer's Association (TEMA).
- r) Hydraulic Institute (HIS).
- s) International Electro-Technical Commission (IEC) Publications.
- t) Power Test Code for Steam Turbines (PTC).
- u) Applicable German Standards (DIN).
- v) Applicable British Standards (BS).
- w) Applicable Japanese Standards (JIS).

- x) Electric Power Research Institute (EPRI).
- y) Standards of Manufacturer's Standardization Society (MSS).
- z) Bureau of Indian Standards Institution (BIS).
- aa) Indian Electricity Rules.
- bb) Indian Boiler Regulations (IBR).
- cc) Indian Explosives Act.
- dd) Indian Factories Act.
- ee) Tariff Advisory Committee (TAC) rules.
- ff) Emission regulation of Central Pollution Control Board (CPCB).
- gg) Pollution Control regulations of Dept. of Environment, Govt. of India
- hh) Central Board of Irrigation and Power (CBIP) Publications.
- ii) The Air Prevention and Control of Pollution Act.
- jj) The Environmental Protection Act
- kk) The Public Liability Insurance Act.
- ll) The Forest Conservation Act
- mm) The Wildlife protection Act.
- nn) The EIA Notification, 1994.
- oo) IS: 14665-Specification for Electric Traction Lift
- pp) Any other statutory Codes/Standards/Regulations

DATE 26.12.2022

## CRITERIA FOR LAYOUT

## PLOT PLAN LAYOUT REQUIREMENTS

ITEM	SPECIFICATION REQUIREMENT
A. Site conditions to be considered	
1. Prevalent wind direction	See wind-rose in plot plan. Also refer Metrological Data.
B. Layout Requirements	
1. Maximum permissible slope in	
a) Rail track	1 in 400
b) Road	1 in 30
c) Sides of unpaved embankment	1 in 2
2. Required road width	
a) Main roads	As per Civil DBR
b) Auxiliary interconnections	
c) Road to the power house unloading bay :	
• Only for entry to the unloading bay	Yes
• To pass through the unloading bay	No
3. Required minimum horizontal distance between the nearest points of	
a) Plant boundary and the boundary of residential area	(Local municipality/factory rule)
b) Electrical transformer and any other building/facility	As per the Tariff Advisory Committee/ LPA Rules
c) Fire water supply installation and any building/facility subject to fire risk.	As per the Tariff Advisory Committee/ LPA Rules
d) Inflammable liquid (fuel oil, etc.) storage & handling installation and their fencing and other buildings/facilities.	Rules of the Indian Explosive (Indian Explosives Act) and Indian Petroleum Code

**ITEM****SPECIFICATION REQUIREMENT**

DATE 26.12.2022

4.	Required minimum vertical clearance	
a)	Under pipes/cable racks at road crossings	8.0 Metres
b)	Soil coverage over underground pipes	1.0 Metre (minimum)
5.	Railway Wagon clearance	Rules of the Indian Railways
6.	Minimum Clearance between any road edge and building/structure/ any fixed installation.	3 Metres
7.	Required level, above the local developed grade level, of	
a)	top of all roads	150 mm above FGL
b)	all outdoor paved areas	100 mm above FGL
c)	Temporary storage areas, workshops, offices, residence etc. required at the time of erection work.	Yes
d)	Green belt around power plant area	As per environmental guidelines of MOEF, Govt. of India.

**BUILDING/ EQUIPMENT LAYOUT REQUIREMENTS**

A.	Minimum clear space required at all working and walking areas for operating & maintenance personnel	
1.	Horizontal, in all directions	
a)	Adjacent to any electrical equipment, electrical cables, running (rotating/reciprocating) equipment, safety valve or vent/drain pipe outlet, pipe/ equipment of surface temperature exceeding 60°C.	1200 mm
b)	Adjacent to any other plant facilities (including walls/structures)	1000 mm
2.	Vertical (head-room clearance)	
a)	Under any pipe/equipment surface of temperature exceeding 60°C and any electrical cables or other electrical items.	2.5 Metre
b)	Under any other plant facilities (including structures, pipes etc.)	2.5 Metre

**ITEM****SPECIFICATION REQUIREMENT**

DATE 26.12.2022

- |    |  |   |
|----|--|---|
| 3. | For all areas where any equipment (including trucks, trolleys and other material handling equipment) will move or maneuver.  | Minimum 500 mm clear in all direction from the outer edges of the equipment   |
|    |  |   |
| 4. | Minimum clear hand space required for  |   |
| a) | The application of thermal insulation  | 100 mm  |
| b) | Welding work   | 150 mm  |
| c) | Bolt tightening  | 150 mm  |
|    |  |   |
| B. | Floors, platforms, staircase, ladders, walls, doors & windows  |   |
|    |  |   |
| 1. | Statutory Requirement  | As per the regulations of Tariff Advisory Committee, Indian National Building Code, Indian Factories Act, Local Municipal Rules, etc. |
|    |  |   |
| 2. | Operation & Maintenance Requirement  |   |
| a) | Adequate floor space shall be kept to permit dismantling, temporary storing and in-situ maintenance of plant & equipment parts, satisfying the clear space requirements stated above. A separate unloading bay for such purpose is required. | Yes   |
| b) | Floors or fixed/portable platforms with stairs/ ladders shall be provided for easy approach to any plant item, including valves, instruments, etc. to be operated, observed and/or to be frequently (more than once a month) maintained.     | Yes   |
|    |  |   |
| 3. | Plinth level of all buildings, above the finished grade level  | 500 mm  |
|    |  |   |
| 4. | Minimum access opening required (with rolling shutter) for transportation, wherever entry of truck for material handling is envisaged  | 3.5M wide x 4M high or, more depending upon the equipment size to be handled.   |

---

**ITEM****SPECIFICATION REQUIREMENT**

DATE 26.12.2022

**C. Other Maintenance Requirement****1. Generator stator handling**

In case the Generator stator cannot be handled by the turbine house crane, all provisions for its overhauling, including the arrangement to slide the stator on the turbine house floor, the foundation work for stator jacking /lowering assembly, dismantling of building end walls/structures etc. shall be kept.

Yes

**2. Maintenance of the internals/impellers of all important equipment, like boiler feed pumps, feed water heaters, Surface Condenser, fans of the boiler draft plant, Intake and circulating water pumps, cooling water pumps, coal mills, compressors, blowers, heat exchangers, fuel oil pumps, filters etc.**

Shall be possible without disconnecting or dismantling any piping/ducting.

**3. Overhauling and handling of the casings for the above items**

Shall be possible without disturbing/dismantling any piping/ducting not directly connected to them.

**4. Crane Approach**

Wherever required the unobstructed approach of the crane hook/other hoisting equipment hook to various plant & equipment shall be possible.

Yes

**D. Central Control Room**

All electronic equipment other than those directly associated with control, operation or presentation of displays shall be mounted external to the control room in air conditioned control equipment room.

Yes

The bidder shall describe in his bid the proposed layout philosophy of the Central Control Room and Control Equipment Room and the arrangement of equipment best suited for the system offered by him and as per good ergonomically consideration.

However, as a guide line, following features are given :

- a) False ceiling and false flooring shall be provided.
- b) Uniform height, colouring schemes for cabinets etc. shall be available.

**ITEM****SPECIFICATION REQUIREMENT**

DATE 26.12.2022

- c) The total area of floor space covered by Control Consoles/Panels in the Control Room shall not exceed 15% of floor area.
- d) No opening shall be provided from Boiler side.
- e) Two double leaf doors, suitably located for entering the Control room shall be provided with opening towards the turbine floor.
- f) Cable entry for the panels/consoles shall be from bottom and suitable openings shall be provided.
- g) The Control Room lighting shall be designed to provide a glare free uniform illumination. The level of illumination shall be minimum 400 LUX.
- h) Necessary Air Conditioning shall be provided for Central Control room, Control Equipment Room and SWAS room etc.
- i) Basic amenities like toilet, Tiffin rooms, wash basins, rest rooms etc. shall be provided near the Control Room.

E. Toilet and drinking water facility

Required in all buildings and on all floors wherever operating personnel are to be deployed.

## **PROJECT MANAGEMENT AND SITE SERVICES**

## CONTENT

<b>CLAUSE NO.</b>	<b>DESCRIPTION</b>
1.00.00	PROJECT MANAGEMENT SERVICES
2.00.00	SITE SERVICES
3.00.00	PROJECT INFORMATION AND MANAGEMENT SYSTEM, INCLUDING DCOUMENT MANAGMENT SERVER (DMS)

## **PROJECT MANAGEMENT AND SITE SERVICES**

### **1.00.00 PROJECT MANAGEMENT SERVICES**

#### **1.01.00 Responsibility**

The Bidder shall identify a separate and independent project management team headed by a Project Manager for the execution of this project. Responsibilities of this project Management team shall cover the areas listed below :

- a) Planning and Monitoring
- b) Engineering Management
- c) Contracts Management
- d) Project Safety Management
- e) Quality Assurance, Inspection & Expediting
- f) Construction Management
- g) Spares Management
- h) Erection & Commissioning Management

Detailed responsibilities in the above areas are discussed below :

#### **1.02.00 Organisation**

##### **1.02.01 Headquarters**

The headquarters of the project management team shall be headed by a senior level executive designated as the Project Manager who shall be responsible to Owner for the execution of the project. He should have adequate financial power and authority to give decision.

Separately, designated leaders shall be identified for each of the areas mentioned under 1.01.00, who, in turn, will report to the Project Manager for all matters relative to this contract.

##### **1.02.02 Central Co-ordination Cell**

The central coordination cell shall have sufficient technical personnel to coordinate technical matters and to quickly resolve day to day queries or

---

references made by Owner and his Consultants without having the need to refer to his headquarters each time.

DATE 26.12.2022

1.02.03 Site Organisation

The site should have a competent construction manager for all site operations with adequate financial power and sufficient level of authority to take site decisions. The organisation chart for site should indicate the various levels of experts to be posted for supervision in the various fields in civil construction, erection, commissioning etc.

1.02.04 Organisation Chart

The Bidder shall furnish a detailed organisation chart for the project management team, clearly identifying the key personnel in each of the areas mentioned at 1.01.00 above. The expected number of executives at different levels shall also be indicated, separately for headquarters, central coordination cell and site organisation.

1.03.00 **Implementation Schedule**

The schedule for the completion of the Project would be as follows :

As per project specific special condition of contract.

To achieve these targets, the Contractor shall furnish to the Owner, various schedules as defined below:

1.03.01 Engineering Schedules

These schedules shall cover various design submissions indicating different engineering activities to be performed. Such schedules shall be furnished by the Bidder for each and every plant/systems/ equipment item covered in the scope of this specification.

1.03.02 Manufacturing Schedule

The Contractor shall submit to the Engineer his manufacturing and delivery schedules for all equipment within thirty (30) days from the date of issue of the Letter of Intent (LOI). Such schedules shall be in line with the detailed network for all phases of the work of the Contractor. Such schedules shall be reviewed, updated and submitted to the Engineer, once in every two months thereafter, by the Contractor. Schedules shall also include the materials and equipment purchased from outside suppliers.

### 1.03.03 Erection Schedules

In order to achieve the overall completion schedule, the Contractor shall provide the Owner all the information covering erection sequence, testing and commissioning activities. These schedules may be based on the recommended erection procedures and will be subject to discussions/agreements with the Owner subsequent to the award of contract.

1.03.04 The successful Bidder shall have to provide all the above schedules (i.e. 1.03.01, 1.03.02 & 1.03.03) in a tabular form in addition to that in the form of L2 & L3 networks and these shall necessarily include information not limited to the earliest and latest dates for various activities/submissions and also any related constraints. However, the Bidder shall include in his proposal a Level-1 (L-1) network showing the major activities and various milestones to achieve the above mentioned completion schedule.

1.03.05 The Contractor shall provide the Owner the original disc/software for all such schedules alongwith requisite no. of copies (as required by the Owner) within an agreed time schedule. This time schedule will be agreed between Owner/Bidder at the time of award of contract. The Contractor's project management software shall be compatible with that of the Owner and the input data shall be furnished to the Owner in a manner compatible with Owner's project management software, SAP.

### 1.04.00 Detailed Responsibilities

#### 1.04.01 Planning & Monitoring

##### a) Planning

The Bidder shall prepare a Master Network Schedule in the form of PERT network.

The network shall be prepared on a Work Breakdown Structure for the project which sub-divides the project into a set of manageable systems/sub-systems. The master network will identify milestones of key events for each system/package in the areas of engineering, procurement, manufacture and despatch and erection and commissioning. The master network shall represent the Level-I plan and will form the basis for development of detailed second and third tier execution plans. The master network shall conform to the overall schedule prescribed by Owner.

The master network should be submitted along with the bid which would be mutually discussed and finalised before the Award of Contract. This master network would clearly indicate the responsibility of the Bidder and project management team. This master network would form a part of the contract. The master network shall also identify a complete list of inputs to be furnished by the Owner which may be required for proper interfacing and tie-up. Scheduled dates for providing such inputs shall also be indicated, which will be mutually discussed and finalised.

## b) Monitoring &amp; Progress Reporting

The progress reports would be emanated every month, one from the head office of the Contractor and another from the site office. The progress report emanating from the head office should necessarily include the following sections:

- i) Report on key milestones.
- ii) Management summary indicating critical areas with details of actions initiated and effect of any on the project.
- iii) Action needing attention of the Owner/Consultant.
- iv) Detailed packagewise status of engineering submissions, quality plan submissions and approval, procurement manufacture and despatch.

The monthly report generated from the site office should necessarily include:

- i) Report on key milestones.
- ii) Management summary indicating critical areas with details of actions initiated and effect if any on the project.
- iii) Action needing attention of the Owner/Consultant.
- iv) This report would also cover the areas pertaining to the receipt of the equipment at the port, port clearance, transport, receipt at site, erection and commissioning.

In addition to the above, as the project execution progresses, the Contractor shall also be responsible for generating more frequent reports in the form of fax/e-mail information on progress in critical areas so that actions can be expedited. The exact format of the progress report shall be finalised after award of Contract.

## 1.04.02 Engineering Management

Based on the master network for the project (L-1) the Contractor will prepare an exhaustive list of engineering activities for the equipment/systems covered in his scope and a detailed programme of accomplishing the same within the time frame specified in the master network. This schedule will form the Level-2 (L-2) network for engineering activities.

Based on (L-2) network, the Contractor shall further develop the Level-3 (L-3) network for engineering activities which will indicate schedule for data availability, drawing release date and document submission dates.

Detailed (L-2) and (L-3) networks would be submitted sequentially by the Contractor within two months from the date of issue of Letter of Intent and finalised within one (1) month thereafter. DATE 26.12.2022

All such networks shall be provided in MS PROJECT software as well as in other format / software suitable to Owner.

The engineering management team should also co-ordinate all interface engineering activity between the Contractor and the equipment sub-vendors so as to ensure the correctness and completeness of related engineering documentation before the same is submitted to the Owner.

TSGENCO is implementing SAP ERP. Hence the bidder apart from submission of the hard copies shall upload all the documents, drawings etc. in soft format in the relevant C- folder environment (web based) and comply with the additional requirements, if any.

#### 1.04.03 Contracts Management

Based on the master network, the Contractor shall submit L-2 programmes of manufacture and despatch. In addition, the master network shall also include periods considered for site activities viz. erection, commissioning etc. These L-2 programmes would be submitted in 2 months time from the date of award of contract and finalised within one (1) month thereafter. The Contractor will also submit site mobilisation plan. This programme would be submitted at the time of finalisation of award of contract and agreed immediately thereafter so that immediate development of the various activities at site could take place.

The Contractor should also submit L-3 programmes for the manufacturing, despatch of the various items. These networks shall also show the customer hold points (CHP) which have to be cleared by Owner or their authorised representative(s) before further manufacture can take place. These L-3 programmes for the manufacture and despatch would clearly identify responsibilities of the Contractor, sub-Contractor and Owner. These networks shall be submitted within one (1) month of the date of finalisation of the various sub-contracts by the Contractor.

In case all the manufacture is being done by the Contractor then the L-2 programmes would be themselves amplified to cover details of the manufacture, inspection, clearance by Owner and despatch.

The Contractor shall also submit the programme for procurement of boughtout items, detailed shipping schedule and cash flow statement for Owner's approval.

#### 1.04.04 Quality Assurance, Inspection and Expediting

The Contractor shall submit the list of manufacturers/sub-vendors from whom the equipment are expected to be procured and the quality assurance plans thereof for the manufacture shall be approved by the QA group of Owner before the manufacture is commenced. The list of major suppliers would be submitted along with the bid and this shall be mutually discussed and approval will be given by the Owner during contract negotiation meeting prior

---

to placement of Letter of Intent. This approved list will be binding to the bidder. In the said list, Owner reserves the right to include reputed/reliable vendors of his own choice. Regarding the various other sub-vendors, the list would be submitted within six (6) months of the award of the contract that shall be scrutinized by the Owner to accord approval. In such list Owner reserves the right to include vendors of his own choice. No further vendor approval will be given after twelve (12) months. On the quality plans, the customer hold points will also be identified based on which Owner would give clearance for the manufacture to proceed further.

DATE 26.12.2022

Quality assurance/Inspection group of Owner or its representative would issue a material despatch clearance certificate (MDCC) after the inspection clearance which will enable the Contractor to despatch the equipment and claim the payment. In the despatch programme, the Contractor shall indicate a schedule of estimated programme, tonnages specifically identifying various oversize dimensioned consignments (ODC). Further the Contractor will also be required to ensure at all stages of shipment that packing of all shipments despatched are suitable for ocean freight to India, handling at the port of entry, inland transportation and preservation at site upto erection. All despatch details & item lists shall be made available to both Owner & site immediately after shipping.

The Contractor shall also expedite all despatches from their own works/works of their sub-vendors, so as to match with the various activities mentioned at 1.04.03 above.

#### 1.04.05 Construction Management

Based on the L-1 Master Network Programme, within two (2) months of the issue of Letter of Intent, the Contractor shall submit a programme of construction/ erection/ commissioning, either in continuation with the manufacture and despatch or separately for the implementation. These programmes would be amplified showing when the civil drawings shall be released by him and construction of civil works shall be completed by him to facilitate start of erection and subsequent activities and shall form the basis for site execution and detailed monitoring. The three monthly rolling programme with the first month's programme being tentative based on the site conditions would be prepared based on these L-3 programmes. The Contractor shall also be involved along with the Owner to tie up detailed resource mobilisation plan over the period of time of the contract matching with the performance targets.

The L-3 programme would be jointly finalised by the site in charge of the Contractor with the Owner's project coordinator as well as the site planning representative. The erection programme will also identify the sequential erectable tonnages that are required for various equipment which should be taken care of in the despatch programmes.

Erection and commissioning of the equipment shall also be done under the supervision of experts from the respective equipment/ system supplier.

#### 1.04.06 Spares Management

Alongwith the proposal for the plant and equipment, the Contractor shall also submit proposals/schedule for the following: DATE 26.12.2022

- a) Mandatory spares
- b) Recommended spares

While the award for mandatory spares will be finalised at the time of the award of contract, recommended spares will be finalised thereafter.

#### 1.05.00 **Project Progress Review Meetings**

Keeping in mind the overall responsibility of the Contractor it is intended that periodic progress reviews on the entire activities of execution of the project will be held initially at least once in two (2) months at Hyderabad/site/ at the discretion of the Owner.. During peak period it may be held once in a month. These meetings will be attended by reasonably higher officials of the Contractor and their leading sub- contractors and will be used as a forum for discussing all areas where progress needs to be speeded up. Actions will be placed on the concerned agencies and decisions will be taken to expedite/speed up the progress. Minutes of such meetings will be issued reflecting the major discussions and decisions taken and circulated to all concerned for reference and action. The Contractor shall be further responsible for ensuring that suitable steps are taken to meet various targets decided upon such meetings.

In addition to the above, and to streamline the construction and erection at site, a suitable frequency and forum of periodic meetings between the Contractor and the Owner will be decided upon as part of erection coordination procedure. Site co-ordination meeting may be held on weekly basis.

#### 1.06.00 **Owner's Consultant**

The Owner would appoint a consultant to assist him in some of the areas mentioned at 1.01.00 above. The details of interaction and procedures for coordination between Owner / Owner's Consultant and Contractor/ Contractor's project management team shall be finalised during contract negotiations.

#### 1.07.00 **Commissioning Management**

1.07.01 For commissioning of the various equipment/system covered under the scope of contract, Owner will form an organisation structure which may consist of the following committees. The Contractor shall nominate his representative on one or more of the committee as decided by the Owner:

- a) Steering Committee
- b) Commissioning Panel.
- c) Working Parties
- d) Testing Teams.

1.07.02 Commissioning documents shall be prepared by the Contractor in the

following manner and submitted for Owner's approval :

DATE 26.12.2022

a) Field Quality Plan

This document shall be prepared for the various equipment/ systems under commissioning and shall have the following objectives to fulfill and shall be submitted for Owner's approval at least six (6) months before their actual commissioning :

- i) Establish design data against which Plant Performance will be compared.
- ii) Set-out the testing objectives and proposals.
- iii) Define the documentation required.

b) Testing/Commissioning Schedule

These shall be prepared for the various equipment/systems under consideration and shall contain sections like detailed testing method, programme, safety, individual responsibility and results.

c) Standard Check Lists

Standard check lists are intended for use at the completion of erection to ensure correct erection, testing and to a limited extent operation for repetitive items.

1.07.03 Test Reports

After the completion of commissioning activity of equipment/ systems, the Contractor shall prepare the test reports which shall include all the relevant information related to various commissioning checks, tests carried out, any deviations/commissions noticed with respect to the intended design requirements, sequence of various commissioning activities as actually adopted vis-a-vis as recommended in the procedures, programme schedules achieved and any other such information as required. These test reports shall be submitted in requisite number of copies to the Owner and this should be duly signed jointly by the Owner/Consultant and the Contractor/Equipment supplier, who are involved during the commissioning activities.

2.00.00 **SITE SERVICES**

These services shall be rendered by the Bidder as part of the overall project management service. The services shall broadly include but not be limited to the following :

2.01.00 Arranging material despatch from the shop by rail/road and/or sea as applicable.

2.02.00 Monitoring movement of materials & follow-up as necessary with Railways, road transport, port clearance etc. from the time of despatch F.O.R. works/ F.O.B. port of shipment by Contractor till receipt of the same at site.

- 2.03.00 Unloading of materials at Railway Station/Railway Siding inside project area/ Road Transportation, transportation to site store, assessment of lost/damaged items in transit and arranging insurance claims and replacement of lost/damaged items. The Contractor shall submit to the Engineer a report detailing all the receipts during the week as well as storing, preservation of material at site.
- 2.04.00 Issuing materials from site store/open yard from time to time for erection as per the construction programme. The Contractor shall be the custodian of all the materials issued till the plant is officially taken over by the Owner after complete erection and successful trial run & commissioning.
- 2.05.00 Transportation of materials to their respective places of erection and erection of the complete plant & equipment as supplied under this specification.
- 2.06.00 Trial run and commissioning of individual equipment/sub-systems and the plant as a whole to the satisfaction of the Owner, including supply of temporary equipment & services for chemical cleaning, steam blowing as well as performance guarantee tests.

Apart from Boiler, proper chemical cleaning shall be carried out in following pipe lines/equipment before commissioning

- a) Deaerator
- b) Boiler feed suction, recirculation leak-off lines
- c) Boiler Feed discharge line by passing heaters
- d) Attemperation lines
- e) Condensate suction & discharge piping upto deaerator by passing the feed water heaters.
- f) Fuel oil lines.

Provision for preservation of individual equipment after trial run and commissioning e.g. Nitrogen blanketing etc. as necessary shall also be in the scope of the Bidder.

Safe disposal of effluent after chemical cleaning shall be done by the contractor.

- 2.07.00 Supply and application of the final paints and first fill lubricants on all the equipment to be erected under this specification. Supply of chemicals, lub oils and other consumables upto COD.
- 2.08.00 For the purpose of erection and commissioning the Contractor's scope of work shall include but not be limited to the following :
- 2.08.01 Deployment of all skilled and unskilled manpower required for erection, supervision of erection, watch & ward, commissioning and other services to

---

be rendered under this specification.

DATE 26.12.2022

- 2.08.02 Deployment of all erection tools & tackle, construction machinery, transportation vehicles and all other implements in adequate number and size, appropriate for the erection work to be handled under the scope of this specification.
- 2.08.03 Supply of all consumables, e.g. welding electrodes, cleaning agents, diesel oil, grease, lubricant etc. as well as materials required for temporary supports, scaffolding etc. as necessary for such erection work except those listed under exclusion elsewhere in this specification.
- 2.08.04 Construction of all civil/structural/architectural works, including construction of foundation for all equipment supplied as required, grouting of equipment on foundation after alignment, and all other incidental civil activities as detailed elsewhere.
- 2.08.05 All structural steel fabrication and erection work as detailed elsewhere in the specification.
- 2.08.06 Providing support services for the Contractor's erection staff e.g. construction of site offices, temporary stores, residential accommodation and transport to work site for erection personnel, insurance cover, watch & ward for security and safety of the materials under the Contractor's custody etc. as required.
- 2.08.07 Maintaining proper documentation of all the site activities undertaken by the Contractor as per the proforma mutually agreed with the Owner; submitting monthly progress reports as also any such document as and when desired by the Owner; taking approval of all statutory authorities e.g. Boiler Inspector, Factory Inspector, Inspector of Explosives, Electrical Inspector etc. for respective portions of work under the jurisdiction of such statutes or laws.
- 2.08.08 The Contractor shall provide 'Industrial Relations' unit and 'Medical' unit to take care of his erection staff and the Owner shall have no obligation in the regard.
- 2.08.09 The successful Bidder shall arrange for Tower cranes of adequate capacity for speedy erection activities.
- 2.09.00 **Site Organisation**

The Contractor shall maintain a site organisation of adequate strength in respect of manpower, construction machinery and other implements at all times for smooth execution of the contract. This organisation shall be reinforced from time to time, as required, to make up for slippages from the schedule without any commercial implication to the Owner. The site organisation shall be headed by a competent construction manager having sufficient authority to take decisions at site.

On award of contract, the Contractor shall submit to the Owner a site organisation chart indicating the various levels of experts to be deployed on the job. The Owner reserves the right to reject or approve the list of personnel

---

proposed by the Contractor. The persons, whose bio-data have been approved by the Owner, will have to be posted at site and deviations in this regard will not generally be permitted. DATE 26.12.2022

The Contractor shall also submit to the Owner for approval a list of construction equipment, erection tools, tackle etc. prior to commencement of site activities. These tools & tackle shall not be removed from site without written permission of the Owner.

**2.10.00 General Guidelines for Field Activities**

2.10.01 The Contractor shall execute the works in a professional manner so as to achieve the target schedule without any sacrifice on quality and maintaining highest standards of safety and cleanliness.

2.10.02 The Contractor shall co-operate with the Owner and other Contractors working in site and arrange to perform his work in a manner so as to minimise interference with other Contractors' works. The Owner's engineer shall be notified promptly of any defect in other Contractor's works that could affect the Contractor's work. If rescheduling of Contractor's work is requested by the Owner's engineer in the interest of overall site activities, the same shall be complied with by the Contractor. In all cases of controversy, the decision of the Owner shall be final and binding on the Contractor without any commercial implication.

2.10.03 The Engineer shall hold weekly meetings of all the Contractors working at Site at a time and a place to be designated by the Engineer. The Contractor shall attend such meetings and take notes of discussions during the meeting and the decisions of the Engineer and shall strictly adhere to those decisions in performing his Work. In addition to the above weekly meeting, Engineer may call for other meetings either with individual contractors or with selected number of contractors and in such a case the Contractor, if called will also attend such meetings.

2.10.04 Time is the essence of the Contract and the Contractor shall be responsible for performance of his Work in accordance with the specified construction schedule. If at any time the Contractor is falling behind the schedule, he shall take necessary action to make good of such delays by increasing his work force or by working overtime or otherwise accelerate the progress of the work to comply with the schedule and shall communicate such action in writing to the Engineer, satisfying that his action will compensate for the delay. The Contractor shall not be allowed any extra compensation for such action.

2.10.05 The Engineer shall however not be responsible for provision of additional labour and or materials or supply or any other services to the Contractor except for the co-ordination work between various Contractors as set out earlier.

2.10.06 The works under execution shall be open to inspection & supervision by the Owner's engineer at all times. The Contractor shall give reasonable notice to the Owner before covering up or otherwise placing beyond the reach of inspection any work in order that same may be verified, if so desired by the Owner.

- 2.10.07 Every effort shall be made to maintain the highest quality of workmanship by stringent supervision and inspection at every stage of execution. Manufacturer's instruction manual and guidelines on sequence of erection and precautions shall be strictly followed. Should any error or ambiguity be discovered in such documents, the same shall be brought to the notice of the Owner's engineer. Manufacturer's interpretation in such cases shall be binding on the Contractor.
- 2.10.08 The Contractor shall comply with all the rules and regulations of the local authorities, all statutory laws including Minimum Wages, Workmen Compensation etc. All registration and statutory inspection fees, if any, in respect of the work executed by the Contractor shall be to his account.
- 2.10.09 All the works such as cleaning, checking, leveling, blue matching, aligning, assembling, temporary erection for alignment, opening, dismantling of certain equipments for checking and cleaning, surface preparation, edge preparation, fabrication of tubes and pipes as per general engineering practice at site, cutting grinding, straightening, chamfering, filling, chipping, drilling, reaming, scrapping, shaping, fitting-up bolting/welding, etc., as may be applicable in such erection and are necessary to complete the work satisfactorily, are to be treated as incidental and the same shall be carried out by the Contractor as part of the work.
- 2.10.10 In case of any class of work for which there is no such specification as laid down in the contract such as, blue matching, welding of stainless steel parts, etc., the work shall be carried out in accordance with the instructions and requirements of the Engineer and as per the Standards.
- 2.10.11 It may sometimes be necessary to remove some of the erected structural members to facilitate erection of bigger/pre-assembled equipment. In such cases, the removal and re-erection of such members, which are essential, and if so agreed by the Engineer, will have to be done by the Contractor.
- 2.10.12 Attachment welding of necessary instrumentation tapping points, thermocouple pads, root valves, condensing vessels, flow nozzles and control valves etc., both for regular measurement and performance testing to be provided on equipment, its auxiliaries or pipelines covered within the scope of this tender, will also be the responsibility of the Contractor and the same will be done as per the instructions of Engineer. The erection and welding of all above items will be the Contractor's responsibility, even if :
- a) Product groups under which these items are re-leased are not covered in the scope of this tender.
  - b) Items are supplied by an agency other than the Contractor.
- 2.10.13 Preservation of all materials/equipment under custody of the Contractor during storage, pre-assembly & erection, commissioning etc., shall be the responsibility of the Contractor. All necessary preservatives and consumables like paints, etc., shall be arranged by the Contractor. Necessary touch up painting, periodic application of preservatives/paints on pressure parts/other equipment even after erection until completion of work shall be carried out by

the Contractor. The Contractor shall fabricate piping, install lub oil systems and carry out the acid cleaning of fabricated piping. The Contractor shall also service the lub. oil system, carryout the hydraulic test of oil coolers, etc. DATE: 26.12.2022

- 2.10.14 It is responsibility of the Contractor to do the alignment etc. if necessary, repeatedly to satisfy Engineer, with all the necessary tools & tackle, manpower, etc. The alignment will be complete only when jointly certified so, by the Contractor's Engineer & Owner. Also the Contractor should ensure that the alignment is not disturbed afterwards.
- 2.10.15 Additional platforms for approaching different equipment as per site requirement, which may not be indicated in drawings, shall be fabricated and erected by the Contractor. The materials required for these works shall be supplied by the Contractor and he will have to fabricate them to suit the requirement.
- 2.10.16 Equipment and material which are wrongly installed shall be removed and reinstalled to comply with the design requirement at the Contractor's expense, to the satisfaction of the Owner/ Consultant.
- 2.10.17 Before erection of any equipment on a foundation, the Contractor shall check and undertake if necessary rectification of foundation bolts, reaming of holes, drilling of dowels, matching of bolts and nuts, making new dowel pin, etc.
- 2.10.18 Assistance for calibrating/testing the power cylinders, valves, gauges, instruments, etc., and setting of actuators coming under various groups shall be provided by Contractor.
- 2.10.19 It shall be the responsibility of the Contractor to provide ladders on columns for initial works till such time stairways are completed. For this, the ladder should not be welded on the column and should be prefabricated clamping type. No temporary welding on any structural member is permitted except under special circumstances with the approval of Owner.
- 2.10.20 Structural materials required for the supporting/operating platforms required for the valves at various levels for the same operation of valves will be arranged by the Contractor.
- 2.11.00 **Safety**
- Safety and overall cleanliness of work site shall be given top priority.
- 2.11.01 The Contractor shall ensure the safety of all workmen, materials and equipment either belonging to him or to others working at site. He shall observe safety rules & codes applied by the Owner at site without exception.
- 2.11.02 The Contractor shall notify the Owner of his intention to bring to site any equipment or material which may create hazard. The Owner shall have the right to prescribe the conditions under which such equipment or material may be

handled and the Contractor shall adhere to such instructions. The Owner may prohibit the use of any construction machinery, which according to him is unsafe. No claim for compensation due to such prohibition will be entertained by the Owner. DATE 26.12.2022

- 2.11.03 Storage of petroleum products & explosives for construction work shall be as per rules and regulation laid down in Petroleum Act, Explosive Act and Petroleum and Carbide of Calcium Manual. Approvals as necessary from Chief Inspector of Explosives or other statutory authorities shall be the responsibility of the Contractor.
- 2.11.04 The Contractor shall be responsible for safe storage of his and his sub-contractor's radioactive sources.
- 2.11.05 All requisite tests & inspection of handling equipment, lifting tools & tackle shall be done by the Contractor and certified copies shall be supplied to the Owner. Defective equipment shall be removed from service. Any equipment shall not be loaded in excess of its recommended safe working load.
- 2.11.06 All combustible waste and rubbish shall be collected and removed from the worksite at least once each day. Use of undercoated canvas paper, corrugated paper, fabricated carton, plastic or other flammable materials shall be restricted to the minimum and promptly removed.
- 2.11.07 The Contractor shall provide adequate number of fire protection equipment of the required types for his stores, office, temporary structures, labour colony etc. Personnel trained for fire-fighting shall be made available by the Contractor at site during the entire period of the Contract.
- 2.11.08 All electrical appliances used in the work shall be in good working condition and shall be properly earthed. No maintenance work shall be carried out on live equipment. The Contractor shall maintain adequate number of qualified electricians to maintain his temporary electrical installation.
- 2.11.09 All workmen of the Contractor working in construction site shall wear safety helmets, safety boots and safety belts. The Contractor shall take appropriate insurance cover against accidents for his workmen as well as third party.
- 2.11.10 All the worksites shall be provided with adequate lighting facilities e.g. flood lighting, hand lamps, area lighting etc. by the Contractor for proper working environment during night times.
- 2.11.11 All safety precautions shall be taken for welding and cutting operations as per IS-818.
- 2.11.12 All safety precautions shall be taken for foundation and other excavation marks as per IS-3764.
- 2.12.00 **Taking Delivery & Storage**
- 2.12.01 The Contractor shall arrange issue of all equipment and materials to be erected under the contract from the stores/open yard at site by signing on standard indent forms. After completion of work, detailed auditing of the

materials so issued shall be submitted to the Owner.

DATE 26.12.2022

- 2.12.02 The Contractor shall arrange for proper and safe storage of materials till the same are taken over by the Owner as per terms of the contract. Manufacturer's instructions for preservation shall be strictly followed.
- 2.12.03 All empty containers, packing materials, gunny bags, transport frames and also surplus and unused materials reconciliation prior to completion of contract shall be the property of the Owner and returned to the Owner by the Contractor.
- 2.13.00 **Site Welding & Heat Treatment**
- 2.13.01 Welding shall be done in accordance with IS-813, IS-816, IS-9595 & other relevant IS/International standards and as per instructions of Contractor. Only those welders, who are qualified as per IS-817 for ordinary welds and as per IBR/ASME Section-IX for high pressure welds, shall be employed in the job.
- 2.13.02 All welders shall be tested and approved by Engineer before they are actually engaged on the work even though they may possess the requisite certificates. The Owner reserves the right to reject any welder without assigning any reason. The welder identification code as approved by the Engineer shall be stamped by the welder on each joint done by them. The Contractor will be responsible for the periodic renewal, re-testing of the welders as demanded by Owner.
- 2.13.03 The Engineer is entitled to stop Contractor's any welder from his work if his work is unsatisfactory for any technical reason or there is a high percentage of the rejection of joints welded by him, which in the opinion of Engineer will adversely affect the quality of welding even though the welder has earlier passed the tests. The welders having passed the tests do not relieve the Contractor from his contractual obligations, to check the performance of the welders.
- 2.13.04 All charges for testing of welders including destructive and non- destructive tests if conducted by Owner or by the inspection authority at site shall have to be borne by the Contractor. The necessary test materials and consumables will have to be arranged by the Contractor and all testing facility made available, as required.
- 2.13.05 All welded joints shall be subject to acceptance by Engineer. Inspection of welds shall be in accordance with IS-822 or equivalent code.
- 2.13.06 Preheating/post heating and stress relieving after welding are part of fabrication and erection work and shall be performed by the Contractor in accordance with the instruction of Engineer. Contractor shall arrange to supply heating equipment with automatic recording devices. Also the Contractor shall have to arrange for the labour, heating elements, thermocouples, compensating cables, insulation materials like mineral wools, asbestos cloth, ceramic beads, asbestos rope, etc. required for the heat-treatment and stress relieving works. During pre- heat/stress relieving operations, the temperature shall be measured at one or more points as required by attaching thermocouples and recorded on a continuous printing

type recorder. All the record graphs for the heat treatment works carried out shall be got signed by the Engineer prior to the commencement of each cycle and handed over to Engineer on completion. The graphs will be the property of Owner. The Contractor has to provide thermo-chalks temperature recorders, thermocouple attachments, units, graph sheets, etc. required for the job and maintain them in good condition.

- 2.13.07 All electrodes shall be baked and dried in the electric/electrode drying oven to the required temperature and for the period specified by the Engineer before they are used in erection work. The electrodes used shall be as per IS-814, IS-815, IS-1442, IS-7280 and other codes as applicable, and shall be of approved reputed manufacture. The electrodes shall meet the requirement of the pipe material. No electrode manufactured more than 12 months ago and the type covered under certificate issued after conducting tests more than 6 months ago shall be used. All electrodes shall be preserved at works and at site as per manufacturer's recommendations.
- 2.13.08 Oxy-acetylene flame or Exothermic chemical heating for stress relieving is not permitted. Heating shall be by means, of electric induction coil or electric resistance coil.
- 2.13.09 It may become necessary to adopt inter layer radiography/MPT/UT depending upon the site/technical requirement necessitating interruptions in continuation of the work and making necessary arrangement for carrying out the above work.
- 2.13.10 Gas tungsten arc welding process (TIG) shall be adopted for all root pass welds except for structural works until 4.75 mm thickness is deposited. Subsequent welding after root pass can be carried out by manual metal arc welding with coated electrodes. For pipes of thickness less than 6 mm the entire welding has to be carried out by TIG welding.
- Fillet weld shall be made by shielded metal arc process as per applicable codes.
- However, the Engineer will have the option of changing the method of welding as per site requirement. The method adopted for manual arc welding shall be weaving technique and the width of weaving shall not exceed 1.5 times of the dia. of the electrode.
- In case of deviation from welding process and electrodes, the Contractor shall take approval of the Owner prior to adoption of same.
- 2.13.11 The root pass for butt joints shall be such as to achieve full penetration with complete fusion of root edges.
- 2.13.12 Each pass shall be cleared and freed of slag before the next pass is deposited.
- 2.13.13 On completion of each run, craters, weld irregularities, slag etc. shall be removed by grinding or chipping.
- 2.13.14 Each layer of welding shall have an even and smooth appearance.

- 2.13.15 Welding sequence shall be adjusted in such a way that distortion due to welding shrinkage is minimised. Further any movement, shock or vibration during welding shall be avoided to prevent weld cracks.
- 2.13.16 Proper protection of welders and the work shall be taken during periods of rain. No welding shall be carried out when surface to be welded are wet from any cause.
- 2.13.17 Following will be stages of inspection during welding :
- a) Two pieces to be joined shall be individually checked for the weld edge preparation and profile dimensionally and to the template. Dye penetrant check shall be carried out on edge prepared surfaces at random. The percentage will depend upon on criticality as specified by Engineer.
  - b) Joint fit up will be a stage of inspection. Misalignment after fit up may vary from 0.3 mm to 1.6 mm depending on outside diameter and thickness.
  - c) All joints shall be offered for visual inspection after root run. Subsequent welding should be made only after the approval of root run.
- 2.13.18 All welded joints shall be painted with anti-corrosive paint immediately on completion of radiography and stress-relieving.

3.00.00 **PROJECT INFORMATION AND MANAGEMENT SYSTEM, INCLUDING DCOUMENT MANAGMENT SERVER (DMS)**

3.01.00 Contractor shall submit as part of its Work Scope detailed documentation as outlined in this section and / or required by the Technical Requirements. The content and format of the documentation to be submitted are subject to Owner's approval.

3.02.00 Contractor shall utilise a computer based system for control and management of project documentation. The system must be capable of producing customized reports and information on demand. This control system should have been successfully applied to similar projects and be familiar to the project control personnel selected. Contractor's detailed project documentation plan shall identify all documentation requirements for the project, the party responsible for production of the document, the basic content of the document and the required timing for issue. This plan shall include, but not be limited to the details of all Drawings to be produced, plant specification / definition documentation, equipment orders and manuals. The documentation identified shall be entered into the computer based control system The database thus created shall be capable of being sorted and

ordered on a variety of selected parameters such as document type, subject description, responsible party, start date and finish date, to enable review and update to be conducted only on those documents which are relevant. DATE 26.12.2022

3.03.00 Regular documentation control progress reports shall be prepared by the Contractor to record the status of documentation. In the event either Party or Engineer expresses concern with the content of such progress reports, the accuracy of progress reports, status of documentation production and other such matters, the concern will be identified to the Project Manager. Within five days of notification of this concern, the Project Manager will attend a meeting with relevant Owner Representatives and provide details of specific actions to be initiated to satisfactorily overcome the difficulties identified. It will be the Project Manger,s responsibility to initiate whatever action is necessary to ensure that the production of documentation is completely in accordance with Project Information Management System (PIMS).

3.04.00 Within 90 days after Effective Date of Contract, the Contractor shall establish an integrated PIMS which will support the needs of Project and management, detail design and engineering, procurement, construction and operation, and maintenance.

PIMS shall utilise software which links various software and database programs to form a composite system. The typical scope of PIMS shall include, but not be limited to, the following:

- (a) Power plant systems and equipment data, from which Project specific flow diagrams, data sheets and other integrated data are derived. The Power plant systems and equipment data, from which Project specific flow diagrams, data sheets and other integrated data are derived. This data shall include, but not be limited to, the following:
  - (i) System descriptions and design requirements and design criteria
  - (ii) Equipment and material technical specifications for all engineering disciplines
- (b) Detail engineering data to create flow diagrams, plant arrangements, piping configurations, equipment layout and design, electrical and instrumentation systems, structures, and other systems. The software tool used shall be capable of manipulation and storage of plant layout and design information. The 3D model of the plant shall also contain details of the various components like pipe, structural steel work, etc., and relevant information shall be available on-line from relevant data base. Software shall be multi-user, multi-access nature allowing the designers of Contractor and major Sub-Contractors, if required, to work in interactive real time environment and software shall be capable of interference checking. The software shall allow access to different types of information held in the database. It shall estimate the type and quantity of materials required to build the plant and it shall be possible for such data to be taken off the system at any time.

---

(c) Construction data to monitor and manage site activities, including material control, scheduling and progress, quality control, start-up and testing, operation, maintenance, training, and all other site functions. DATE 26.12.2022

(d) Plant design and construction records to provide data for safe and efficient maintenance and operation. Records to include may be maintenance schedule, man power tracking, tools, spare parts, and test equipment inventory, equipment list, drawing, control, technical specifications, and equipment instruction manuals.

3.05.00 The PIMS shall be installed in a distributed processing array system and operated through personal computer work stations at the Contractor's site office. A complete integrated system shall be implemented. This system shall be utilised by Contractor during the Project execution.

## ENGINEERING SERVICES

# CONTENT

DATE 26.12.2022

<b>CLAUSE NO.</b>	<b>DESCRIPTION</b>
1.00.00	GENERAL
2.00.00	DESIGN COORDINATION MEETING
3.00.00	CO-OPERATION WITH OTHER CONTRACTORS AND CONSULTING ENGINEERS
4.00.00	GUIDELINES FOR ENGINEERING SERVICES
5.00.00	OPERATING MANUALS AND MAINTENANCE INSTRUCTIONS
6.00.00	PLANT HANDBOOK
7.00.00	CONTRACT STAGE DOCUMENT SUBMISSION AND APPROVAL PROCEDURE
8.00.00	TENDER STAGE DOCUMENT SUBMISSION

## ATTACHMENTS

ANNEXURE-1	DISTRIBUTION SCHEDULE
------------	-----------------------

## **ENGINEERING SERVICES**

### **1.00.00 GENERAL**

1.01.00 As part of the overall project management activity, the Contractor shall be responsible for proper engineering and co-ordination of activities during various phases of execution of the contract. The Contractor shall identify a person, designated as Project Manager, with whom the Owner, the Consulting Engineer or the Review Consultant shall interact on matters related to engineering as well as execution of the contract. The Project Manager shall be the single-point contact person on behalf of the Contractor and shall be responsible for all engineering co-ordination. The Owner/Consultant/Review Consultant shall interact with the Project Manager only on all matters of co-ordination between the Owner and the Contractor or on matters involving the Contractor, his manufacturing units and sub-vendors. For the purpose of expediting the Owner or his representative may sometimes interact with the manufacturing units or sub-vendors of the contractors. However such interaction will not, under any circumstance, dilute the responsibility of the Contractor to provide a fully engineered and co-ordinated package under this contract.

1.02.00 On finalization of the contract, a procedure for exchange of engineering information will be mutually agreed and finalized between the Owner and the Contractor.

### **2.00.00 DESIGN COORDINATION MEETING**

The Contractor and his sub-vendors will be called upon to attend design co-ordination meetings with the Engineer, other Contractors and the Consultants of the Owner during the period of execution of contract. The Contractor including his sub-vendors shall attend such meetings at their own cost at Owner's or Consultant's office in Kolkata or at mutually agreed venue as and when required and fully cooperate with such persons and agencies involved during those discussions.

### **3.00.00 CO-OPERATION WITH OTHER CONTRACTORS AND CONSULTING ENGINEERS**

The Contractor shall agree to cooperate with the Owner's other Contractors and Consulting Engineers and freely exchange with them such technical information as is necessary to obtain the most efficient and economical design and to avoid unnecessary duplication of efforts. The Engineer shall be provided with copies of all correspondences addressed by the Contractor to other Sub- contractors and Consulting Engineers in respect of such exchange of technical information.

- 4.00.00 **GUIDELINES FOR ENGINEERING SERVICES**
- 4.01.00 Prior to commencement of the engineering work as part of design submissions, all aspects of design viz., criteria for selection and sizing of all equipment and systems, design margins etc. including that for structural steel and civil work shall be outlined and these shall form the basis for the detailed engineering work.
- 4.02.00 Engineering work shall be performed on modern and proven concepts and internationally accepted good engineering practices but fully compatible with the Indian environments. Owner shall have the right to review and approve the engineering work by themselves and/or through consultant and ask for any clarifications and changes/modifications to the work performed by Contractor.
- 4.03.00 At any stage during the performance of assignment, the Contractor may be required to make certain changes/modification/improvements in design/drawing/other documents which are applicable to 800 MW Unit, which in the opinion of the Owner could result in better improved design, layout, operability, plant availability, maintainability, reliability or economy of the plant and its systems/sub-systems in view of revised and more accurate information/data available at a later date(s) or feedback(s) received during execution / operation of similar units. Such changes / modifications/improvements required could be identified by Owner and/or consultant and mutually discussed. Owner requires the Bidder to incorporate such action in the subject assignment appropriately without any additional cost liability and time implication to the Owner and same shall be within the responsibilities and scope of the Contractor.
- 4.04.00 During the course of review of detailed engineering stages, it may be essential in the opinion of Owner to obtain certain classified data for review purposes only. In case Owner so desires, the Bidder shall submit such data to Owner.
- 4.05.00 During the course of review of detailed engineering, it may be essential in Owner's opinion to obtain data and information on similar equipment and plants engineered by the Bidder. In case Owner so desires the Bidder shall submit such data and information to the Owner.
- 4.06.00 It is not the intent to give details of every single task covered in the total engineering work to be carried out by Contractor, however, all engineering work required for the satisfactory completion of the plant/systems as specified shall be carried out by the Contractor. Broadly, the following are the minimum requirements in respect of scope of major items of work:
- 4.06.01 Preparation, updating and finalisation of scheme drawings, control and interlock diagrams, detailed and fully dimensioned layout drawings (plant layout and equipment layout detailed plan, elevation and cross-sectional drawings at different elevations / floor levels) covering all mechanical, electrical, C&I, civil and structural items, equipment, systems and facilities. Drawings and Schedules prepared by the Contractor from time to time, as detailed designs are developed, shall be submitted for Owner's / Consultant's

approval before the work is taken up. Revisions, corrections, additions to drawings and schedules shall not be considered to change the scope of work. DATE 26.12.2022

- 4.06.02 Preparation of detailed technical specifications including data sheets, tender drawings and bill of material for all bought out items, as also finalisation of corresponding sub-contractors.
  - 4.06.03 Review of sub-contractor's data, drawings, design calculations, schedules, bill of materials, instruction manuals etc. for all equipment, before forwarding them to Owner/Consultant for approval.
  - 4.06.04 Preparation of civil construction drawings for all equipment showing foundation details and full details regarding equipment loads, floor openings, details of embedments etc. required for preparation of civil construction drawings and also as referred at relevant sections of Scope, Terminal Points & Exclusions. These documents shall be preceded by appropriate design calculations, static and dynamic analysis as necessary.
  - 4.06.05 Preparation and finalisation of process piping and instrumentation diagrams and schematics, complete in all respects for all systems/packages of the power plant.
  - 4.06.06 Preparation of consolidated schedules and bills of materials, including line numbers, tag numbers, source of supply, service conditions, specifications, materials, types and connections details, quantities for items of the plant including dampers, steam traps, strainers, instrumentations, ducting.
  - 4.06.07 Sizing of all piping and equipment as per the stipulated design criteria; carrying out of flexibility analysis/dynamic analysis as necessary; hangers & support engineering.
  - 4.06.08 Final revision of all documents including preparation and compilation of Instruction Manuals for installation, commissioning, operation and maintenance for all equipment and systems. Refer clause 5.00.00 for the specific requirement in this regard.
  - 4.06.09 Certification and submission of final as-built drawings for all areas.
  - 4.06.10 Preparation and compilation of all drawings, schedules and instructions which may be required at site, whether separately mentioned or not.
  - 4.06.11 All erection and assembly drawings which may be required at site.
  - 4.06.12 For all bought out item packages, the Contractor shall provide complete material / component list along with detail specification, drawings, component part no. etc. during detail engineering stage prior to final approval. Such approved drawing/document shall be made available at site in adequate number prior to commencement of work. Moreover, such document/drawing shall be provided in soft form (CD)
  - 4.06.13 Preparation of necessary documentation, design calculations etc. required for submission to statutory authorities like IBR, Chief Electric Inspector, Factory Inspector etc.
-

5.00.00 **OPERATING MANUALS AND MAINTENANCE INSTRUCTIONS**

5.01.00 The Contractor shall provide at least six (6) months before the time of commissioning and before taking over of the plant and equipment, all necessary maintenance manuals and operating instructions. The instruction manual shall be submitted in the form of one (1) soft copy in CD and 15 hard copies as per distribution schedule (Annexure-1).

5.02.00 The information provided, which shall be contained in loose leaf stiff backed covers, shall include :

- a) A complete inventory of all main items of plant, with identification details.
- b) Service manuals for all plant and equipment giving full descriptions of the main items and auxiliary items such as power packs, hydraulic equipment, actuators, lubricating pumps, etc.
- c) A separate electrical manual covering items such as switchgear, cabling, instrumentation, controls, cabling layouts and wiring diagrams.
- d) A schedule of recommendations for routine maintenance of all electrical and mechanical equipment, recommended inspection point, information on detection, cause and rectifications of troubles & faults.
- e) A lubrication schedule with all necessary drawings diagrams to identify the lubrication points.
- f) Manufacturer's literature.

5.03.00 The instruction manual shall be subject to the approval of Owner.

6.00.00 **PLANT HANDBOOK**

The Contractor shall submit to the Engineer, a preliminary plant handbook preferably in A-4 size sheets which shall contain the design and performance data of various plant, equipment and systems covering the complete project including single line flow diagrams, within twenty four (24) months from the date of his acceptance of the Letter of Intent. The final plant handbook complete in all respects shall be submitted by the Contractor six (6) months before start-up and commissioning activities. The plant handbook shall be submitted as per distribution schedule.

7.00.00 **CONTRACT STAGE DOCUMENT SUBMISSION AND APPROVAL PROCEDURE**

7.01.00 Within fifteen (15) days to one month of issue of Letter of Intent (LOI) by the Owner, the Contractor shall furnish a schedule of drawings and design

document to be submitted by him to the Owner/Engineer indicating dates against each document. DATE 26.12.2022

The documents shall be divided into two categories : a) for approval and b) for information/further engineering and co-ordination by the Owner.

In preparing this schedule, the Contractor shall allow two (2) weeks from date of receipt for review and comments by the Owner/Engineer for each submission of a document.

This document submission schedule shall require approval by the Owner/Engineer.

7.02.00 All contract documents shall be marked, without fail, with the name of the Owner, the Project, the specification title and number and the unit designation.

All dimensions shall be in metric units.

All notes, markings etc. shall be in English.

7.03.00 Documents/Drawings, submitted during tender stage, shall be revalidated or revised as required and submitted as certified contract document for approval / information of the Owner/Engineer.

7.04.00 Unless specified otherwise, the following categories of documents/drawings would require approval of the Owner/Engineer:

- a) List of sub-vendors (from Owner only)
- b) System scheme and instrumentation diagrams
- c) Design basis justifying selection of equipment & process parameters where not specified in the Contract
- d) Equipment data sheets and general arrangement drawings
- e) Materials of construction
- f) Layout drawings.
- g) Operation logic diagrams.
- h) Typical control circuit.
- i) Drawings of Instrumentation and control.

7.05.00 Unless specified otherwise, the following categories of documents/ drawings would be treated for information/further engineering by the Owner/Engineer. The Contractor shall, however, incorporate all additional information and clarifications in these documents / drawings as and when desired by the Owner/Engineer.

- a) Equipment foundation drawings.
- b) Equipment cross-section drawings, product literature etc. which are of proprietary nature.
- c) Predicted performance curves of equipment.
- d) Various bills of quantity, schedules etc.
- e) Piping fabrication drawings, isometrics etc.
- f) Panel wiring diagrams.
- g) Instruction/Operation manuals.
- h) Service manuals and trouble shooting guide for C & I system including field instruments.
- i) Cable schedule and interconnection chart.
- j) Drive/feederwise control scheme showing all external interfaces.

DATE 26.12.2022

In essence, the Contractor is solely responsible for corrections and adequacy of design & engineering for documents under this category.

7.06.00

Upon review, the Owner/Engineer shall put his remarks and one of the following action stamps on the drawing/document:

- a) A - Drawing submitted as approved, proceed with fabrication
- b) B - Drawing approved subject to comments noted, proceed with fabrication, considering our comments. Correct as necessary and resubmit for record.
- c) C - See attached memo.
- d) D - Correct your original drawing incorporating our comments and resubmit for approval.
- e) E - Information furnished is noted.
- f) F - Prints not enclosed

For action stamps in category (c) & (d), documents must be resubmitted for review by the Owner/Engineer. For action stamp in category (b), further review by Owner/Engineer would not be necessary provided the Contractor agrees & incorporates the comments made on the document.

Except for action stamp under category (c) & (d), the Contractor can proceed with manufacturing and other sequential activities for those areas of a drawing/document which do not have any review comment by the Owner/Engineer.

The Owner/Engineer may accord approval in category (c) or (d) in more than one submission of a document till he is satisfied that the intent of the specification has been fully complied with. The Contractor shall be responsible for delay in such cases and no extension of time shall ordinarily be allowed on such grounds. Approval of contract documents by the Owner/Engineer shall not relieve the Contractor of his responsibility for any errors and fulfillment of contract requirements.

DATE 26.12.2022

The Contractor's work shall be in strict accordance with the finally approved drawings and no deviation shall be permitted without written approval of the Owner/Engineer.

- 7.07.00 Except key plan/general yard plan, any layout drawing requiring scrutiny shall not be drawn to a scale less than 1:50.
- 7.08.00 For review by the Consulting Engineer, the Contractor shall furnish soft copies of drawings & documents and three (3) prints of each drawing/document. Two (2) prints of such submission shall also be sent to the Owner. After review, comment/approval will be sent to the Contractor. Upon action under category (a) or (e), the Contractor shall directly distribute the documents to the various offices of the Owner and other agencies in number of copies as specified in the contract document. Such distribution copies shall be marked with the reference and date of the letter by which the Owner/Engineer has accorded his final approval. Penal action shall be taken against the Contractor for any unauthorised revision in the drawings so distributed from the drawings approved by the Owner/Engineer. The contractor shall furnish three (3) CDs of all as built/final drawings for Owner/Consultant site.
- 7.09.00 In case of contradiction between the stipulations above and those stated elsewhere in the specification, the stipulations herein shall prevail.

**ANNEXURE-1**

**DISTRIBUTION SCHEDULE**

S. No	Description	TSGENCO										Consultant		Equipment Vendor	Remarks
		Director Projects	Director Technical	CE/Civil Thermal Projects Hyd.	CE/ TPC-I, Hyd	CE/ O&M/	SE/ Civil	SE/E&M /	DE Constr.	HYD	BTPS				
A	<b>Letter Of Intent or Contract Documents</b>	1	1	1	S	1	2	2	1	1	1	1	2		
B	<b>Vendor Drawings</b>														
1.	Preliminary	1	1	1	2	1	1	2	2	12	1	-	S		
2.	Return preliminary with comments	-	-	1	2	1	1	1	1	S	1	-	1		
3.	Final and any revision thereof														
	a. Civil	1	1	6+1T	1	1	6+1T	1	-	2+1T	1	1	S		
	b. E&M	1	1	1	6+1T	1	1	6+1T	1	2+1T	1	1	S		
C.	<b>Design Drawings</b>														
1.	Preliminary														
	a. Civil	1	1	2	1	1	2	1	1	4	1	1	S		
	b. E&M	1	1	1	2	1	1	2	1	4	1	1	S		
2.	Released for construction														
	a. Civil	1	1	2	1	1	6	1	1	1	1	2	S		
	b. E&M	1	1	1	1	2	1	6	1	1	1	2	S		
3.	Return marked 'As built'														
	a. Civil	-	-	1	-	-	1	-	-	1	1	S	1		
	b. E&M	-	-	-	1	-	-	1	1	1	1	S	1		
4.	As built drawings														
	a. Civil	-	-	1+1T	-	2+1T	5+1T	-	1	1+1T	-	1	S		
	b. E&M	-	-	1	2+1T	2+1T	-	5+1T	1+1T	1+1T	-	1	S		

DATE 26.12.2022

S. No	Description	TSGENCO										Consultant		Equipment Vendor	Remarks		
		Director Projects	Director Technical	CE/Civil Thermal Projects Hyd.	CE/ TPC-I, Hyd	CE/ O&M/	SE/ Civil	SE/E&M /	DE Constr.	HYD	BTPS						
D	Progress Report Monthly																
1.	Equipment vendor	1	1	1	2	1	1	2	1	1	1	1	1	1	1	S	
2.	Consultant	1	1	2	2	1	1	2	1	1	S	1	1	1	1	Nil	
E	Test & Inspection Reports																
1.	Equipment manufacturer																
	a. Civil	1	1	1	2	1	1	1	1	1	11	1	1	1	1	S	
	b. E&M	1	1	-	2	1	-	1	1	11	1	1	1	1	1	S	
2.	Consultant	1	1	-	2	1	-	1	1	S	-	-	1	1	-	-	
F	Instruction Manuals/Data Books																
1.	Equipment manufacturer																
	a. Civil	1	1	1+1T	1	1	6+1T	1	1	2+1T	1	1	1	1	1	S	
	b. E&M	1	1	-	3+1T	1	-	6+1T	2	3+1T	1	1	1	1	1	S	
2.	Consultant	1	1	-	10+1T	1	-	15+1T	-	S	1	1	1	1	Nil		
G	Consultant	1	1	1	8+1T	1	1	2	1	1	1	1	1	1	1	S	
H	Design Calculations	1	1	1	8+1T	1	1	2	1	1	1	1	1	1	1	S	
I	Final consulting Engineering Report	1	1	1	10	1	1	2	1	S	1	1	1	1	1	Nil	

S – Source, T – Transparency & Soft Copy on CD,

TSGENCO : Telangana State Power Generation Corporation Limited  
 Director, Projects, Hyd : Director/ Projects, TSGENCO, Vidyut Soudha, Hyderabad – 500 082

DATE 26.12.2022

# **QUALITY ASSURANCE REQUIREMENTS**

## CONTENT

<b>CLAUSE NO.</b>	<b>DESCRIPTION</b>
1.00.00	QUALITY ASSURANCE PROGRAMME
2.00.00	GENERAL REQUIREMENTS QUALITY ASSURANCE
3.00.00	QUALITY ASSURANCE DOCUMENTS
4.00.00	INSPECTION, TESTING & INSPECTION CERTIFICATES
<b>ATTACHMENTS</b>	
ANNEXURE-I	FORMAT OF QUALITY ASSURANCE PROGRAMME
ANNEXURE-II	FIELD WELDING SCHEDULE

## QUALITY ASSURANCE REQUIREMENTS

### 1.00.00 QUALITY ASSURANCE PROGRAMME

1.01.00 To ensure that the equipment and services under the scope of Contract whether manufactured or performed within the Contractor's works or at his Sub-contractor's premises or at the Owner's site or at any other place or work are in accordance with the specifications, the Contractor shall adopt suitable quality assurance programme to control such activities at all points, as necessary. Such programmes shall be outlined by the Contractor and shall be finally accepted by the Owner/Authorised representative after discussions before the award of contract. A quality assurance programme of the Contractor shall generally cover the following :

- a) His organisation structure for the management and implementation of the proposed quality assurance programme.
- b) Documentation control system.
- c) Qualification data for Bidder's key personnel.
- d) The procedure for purchase of materials, parts, components and selection of Sub-contractor's services including vendor analysis, source inspection, incoming raw-material inspection, verification of materials purchased etc.
- e) System for shop manufacturing and site erection control including process controls and fabrication and assembly controls.
- f) Control of non-conforming items and system for corrective actions.
- g) Inspection and test procedure both for manufacture and all site related works.
- h) Control of calibration and testing of measuring and testing equipments.
- i) System for quality audit.
- j) System for indication and appraisal of inspection status.
- k) System for authorising release of manufactured product to the Owner.
- l) System for handling storage and delivery.
- m) System for maintenance of records.

- n) Furnishing of quality plans for manufacturing and field activities detailing out the specific quality control procedure adopted for controlling the quality characteristics relevant to each item of equipment/component as per format enclosed at Annexure-I to this section for Owners approval
- o) Internal standards, if referred in the quality plans shall generally be compatible with National / International standards and shall be mentioned in the quality plans. Alternatively bidder shall furnish extracts of the internal standards detailing out acceptance norm for the product / material.

## 2.00.00 GENERAL REQUIREMENTS - QUALITY ASSURANCE

2.01.00 All materials, components and equipment covered under this specification shall be procured, manufactured, erected, commissioned and tested at all the stages, as per a comprehensive Quality Assurance Programme. An indicative programme of inspection/tests to be carried out by the Contractor for some of the major items is given in the respective technical specification. This is however, not intended to form a comprehensive programme as it is the Contractor's responsibility to draw up and implement such programme duly approved by the Owner/Consultant. The detailed Quality Plans for manufacturing and field activities should be drawn up by the Bidder, separately in the format attached at Annexure-I and will be submitted to Owner/Authorised representative for approval. Schedule of finalisation of such quality plans will be finalised before award.

Contractor shall furnish list of Manufacturing Quality Plans of major equipments indicating proposed inspection categorisation indicating items that will be offered for Owner's inspection etc and the Field Quality Plans

2.02.00 Manufacturing Quality Plan for all the major equipment will detail out their respective important components, their in-process various tests/inspection & final inspection / tests, to be carried out as per the requirements of this specification and standards mentioned therein and quality practices and procedures followed by Contractor's Quality Control organization. The relevant reference documents and standards, acceptance norms, inspection documents raised etc., during all stages of materials procurement, manufacture, assembly and final testing/performance testing are to be comprehensibly documented by Contractor.

Manufacturing Quality Plan for all major equipments/ items will be approved by owner. In these approved quality plans, Owner / Authorised representative shall identify customer hold points (CHP), test / checks which shall be carried out in presence of the Owners Engineer or his authorised representative and beyond which the work shall not proceed without consent of Owner / Authorised representative in writing. Inspection/ Test reports are to be submitted to owner as specified in final approved Manufacturing Quality Plans.

2.03.00 Field Quality Plans / Procedures for all field activities shall be submitted to

---

owner for review / approval. These Quality Plans / procedures will detail out for all equipment, the quality practices and procedures etc. to be followed by the Contractor's site Quality Control organisation, during various stages of site activities from receipt of materials/ equipment at site. DATE 26.12.2022

- 2.04.00 The Bidder shall also furnish copies of the reference documents/plant standards/acceptance norms/tests and inspection procedure etc., as referred in Quality Plans along with Quality Plans. These Quality plans and reference documents/standards etc. will be subject to Owner's approval without which manufacture shall not proceed. These approved documents shall form a part of the contract. In these approved quality plans, Owner/Authorised representative shall identify customer hold points (CHP), test/checks which shall be carried out in presence of the Owners Engineer or his authorised representative and beyond which the work will not proceed without consent of Owner/Authorised representative in writing. All deviations to this specification, approved quality plans and applicable standards must be documented and major deviations in the form of Non Conformity Report shall be referred to Owner/Authorised representative for approval and dispositioning.
- 2.05.00 No material shall be despatched from the manufacturer's works before the same is accepted subsequent to pre-despatch final inspection including verification of records of all previous tests/inspections by Owner's Engineer/ Authorised representative for "CHP" and "W" points marked in quality plans , and duly authorised for despatch by issuance of Material Despatch Clearance Certificate (MDCC). For items which is not under owner's inspection the contractor shall apply for despatch clearance (MDCC) from owner by submitting their internal inspection reports and quality records
- 2.06.00 All materials used or supplied shall be accompanied by valid and approved materials certificates and tests and inspection report. These certificates and reports shall indicate the sheet serial numbers or other such acceptable identification numbers of the material. The material certified shall also have the identification details stamped on it.
- 2.07.00 Castings and forgings used for construction shall be of tested quality. Details of results of chemical analysis, heat treatment record, mechanical property test results shall be furnished.
- 2.08.00 All welding and brazing shall be carried out as per procedure drawn and qualified in accordance with requirements of ASME Section - IX (latest edition) or other International equivalent standard acceptable to the Owner.

All brazers, welders etc. employed on any part of the contract at Contractor's/ Sub-Contractor's works or at site shall be qualified as per ASME Section-IX (latest edition) or equivalent international standard approved by the Owner. Such qualification tests shall be conducted in presence of Owner / his authorised representative or owner approved Third Party Inspection Agency(TPIA). Previously qualified WPS & PQR shall be acceptable if witnessed by owner's approved TPIA.

For welding of pressure parts and high pressure piping coming under IBR purview, the requirements of IBR shall also be complied with.

---

2.09.00 All non-destructive examination (NDT) shall be carried out in accordance with LIST OF STANDARDS FOR REFERENCE as given below in this section. DATE 26.12.2022

The NDT operator shall be qualified as per SNT-TC-IA (of American Society of non- destructive examination). Results of NDT for the list major equipments / items identified for owner's inspection shall be properly recorded and submitted for review and approval. Other items not covered under owner's inspection, contractor shall review and approve the NDT results and such reports shall be submitted to owner in the final documentation of the items / equipments

2.10.00 All the sub-vendors proposed by the Contractor for procurement of major bought out items including castings, forgings, semi-finished and finished components/equipment list of which shall be drawn up by the Contractor and finalised with the Owner shall be subject to Owner's approval. Quality Plans of the successful vendors shall be discussed, finalised and approved by the Owner/Authorised representative and form part of the Purchase Order between the Contractor and the Vendor.

2.11.00 All the purchase specifications for the major bought-out items, list of which shall be drawn up by the Contractor and finalised with the Owner shall be furnished to the Owner for comments and subsequent approval before orders are placed.

Owner reserves the right to carry out quality audit and quality surveillance of the systems and procedures of the Contractor's or their sub-vendor's quality management and control activities. The Contractor shall provide all necessary assistance to enable the Owner carry out such audit and surveillance.

Quality audit/approval of the results of tests and inspection will not prejudice the right of the Owner to reject equipment not giving the desired performance after erection and shall not in no way limit the liabilities and responsibilities of the Contractor in earning satisfactory performance of equipment as per specification.

2.12.00 Quality requirements for main equipment shall equally apply for spares and replacement items.

2.13.00 Repair/rectification procedures to be adopted to make any job acceptable shall be subject to the approval of the Owner.

2.14.00 For quality assurance of all civil works refer to the specifications for civil works.

### 3.00.00 **QUALITY ASSURANCE DOCUMENTS**

3.01.00 The Contractor shall be required to submit two (2) copies and two (2) sets of microfilms / CDs of the following Quality Assurance documents within three (3) weeks after despatch of the equipment:

a) Material mill test reports on components as specified by the specification.

- DATE: 26.12.2022
- b) The inspection plan with verification, inspection plan check points, verification sketches, if used and methods used to verify that the inspection and testing points in the inspection plan were performed satisfactorily.
  - c) Non-destructive examination results /reports including radiography interpretation reports.
  - d) Factory tests results for testing required as per applicable codes and standards referred in the specification.
  - e) Welder identification list listing welder's and welding operator's qualification procedure and welding identification symbols.
  - f) Sketches and drawings used for indicating the method of traceability of the radiographs to the location on the equipment.
  - g) Stress relief time temperature charts.
  - h) Inspection reports duly signed by QA personnel of the Owner and Contractor for the agreed inspection hold points. During the course of inspection, the following will also be recorded :
    - i) When some important repair work is involved to make the job acceptable.
    - ii) The repair work remains part of the accepted product quality.
  - i) Letter of conformity certifying that the requirement is in compliance with finalised specification requirements.

#### 4.00.00 **INSPECTION, TESTING AND INSPECTION CERTIFICATES**

4.01.00 The Owner's Engineer, or his duly authorised representative and/or an outside inspection agency acting on behalf of the Owner shall have access inside the workshops, test labs, establishments at all reasonable times to inspect and examine the materials and workmanship of the works during its manufacture or erection and if part of the works is being manufactured or assembled on other premises or works, the Contractor shall obtain for the Owner's Engineer and for his duly authorised representative permission to inspect as if the works were manufactured or assembled on the Contractor's own premises or works.

4.02.00 The Contractor shall give the Owner's Engineer/ Authorized Inspector twenty one (21) days written notice for "CHP" / "W" points of any material being ready for testing by owner' engineer / Authorized inspector. Such tests shall be to the Contractor's account except for the expenses of the Inspector. The Engineer/ Inspector, unless the witnessing of the tests is virtually waived, will attend such tests within fifteen (15) days of the date on which the equipment is notified as being ready for test/inspection. If owner's Engineer / Authorised Inspector fail to attend the inspection, next mutually convenient date for test shall be agreed with Contractor. Contractor shall, in

---

no case proceed with the test without owner or his authorized inspectors, unless the witnessing is officially waived and advised Contactor to proceed with the test. Contractor shall forthwith forward duly certified completed test report and a product quality certificate in six (6) copies to owner upon completion of such test. DATE 26.12.2022

- 4.03.00 The Engineer or Inspector shall within fifteen (15) days from the date of Inspection as defined herein give notice in writing to the Contractor, or any objection to any drawings and all or any equipment and workmanship which is in his opinion not in accordance with the contract / QAP or other approved quality documents. The Contractor shall give due consideration to such objections and shall either make modifications that may be necessary to meet the said objections or shall confirm in writing to the Engineer/Inspector giving reasons therein, that no modifications are necessary to comply with the contract / QAP or other approved quality documents.
- 4.04.00 When the factory tests have been completed at the Contractor's or sub-contractor's works, the Engineer/Inspector shall issue a certificate to this effect fifteen (15) days after completion of tests excluding the test completion date subject to submission of all certified documents related to the test, If the tests are not witnessed by the Engineer/Inspectors, the certificate shall be issued within fifteen (15) days of the receipt of the Contractor's test certificate by the Engineer/Inspector. Failure of the owner's Engineer/Inspector to issue such a certificate shall not prevent the Contractor from proceeding with the works. The completion of these tests, or the issue of the certificates shall not bind the Owner to accept the equipment should it, on further tests after erection be found not to comply with the contract / QAP or other approved quality documents.
- 4.05.00 In all cases where the contract provides for tests whether at the premises or works of the Contractor or any sub-contractor, the Contractor, except where otherwise specified shall provide free of charge such items as labour, materials, electricity, fuel, water, stores, apparatus and instruments as may be reasonably demanded by the owner's Engineer/Inspector or his authorised representatives to carry out effectively such tests on the equipment in accordance with the Contract / QAP or other approved quality documents. Contractor and shall give facilities to the owner's Engineer/ Inspector or to his authorised representative to accomplish testing.
- 4.06.00 To facilitate advance planning of inspection in addition to giving inspection notice as per Clause 4.02.00, the Contractor shall furnish quarterly inspection programme indicating proposed schedule dates of inspection at customer hold point and final inspection stages. Updated quarterly inspection plans will be made for each three consecutive months and shall be furnished before beginning of each calendar month.

## LIST OF STANDARDS FOR REFERENCE

DATE 26.12.2022

- a) International Standards Organisation (ISO).
- b) International Electro-technical Commission (IEC).
- c) American Society of Mechanical Engineers(ASME)
- d) American National Standards Institute (ANSI).
- e) American Society for Testing and Materials (ASTM).
- f) American Institute of Steel Construction (AISC).
- g) American Welding Society (AWS).
- h) Architecture Institute of Japan (AIJ).
- i) National Fire Protection Association (NFPA).
- j) National Electrical Manufacturer's Association (NEMA).
- k) Japanese Electro-technical Committee (JEC).
- l) Institute of Electrical and Electronics Engineers (IEEE).
- m) Federal Occupational Safety and Health Regulations (OSHA).
- n) Instrument Society of America (ISA).
- o) National Electric Code (NEC).
- p) Heat Exchanger Institute (HEI).
- q) Tubular Exchanger Manufacturer's Association (TEMA).
- r) Hydraulic Institute (HIS).
- s) International Electro-Technical Commission Publications.
- t) Power Test Code for Steam Turbines (PTC).
- u) Applicable German Standards (DIN).
- v) Applicable British Standards (BS).
- w) Applicable Japanese Standards (JIS).
- x) Electric Power Research Institute (EPRI).
- y) Standards of Manufacturer's Standardization Society (MSS)

---

z) Bureau of Indian Standards Institution (BIS).

DATE 26.12.2022

aa) Indian Electricity Rules.

bb) Indian Boiler Regulations (IBR).

cc) Indian Explosives Act.

dd) Indian Factories Act.

ee) Tariff Advisory Committee (TAC) rules.

ff) Emission regulation of Central Pollution Control Board (CPCB).

gg) Pollution Control regulations of Dept. of Environment, Govt. of India

hh) Central Board of Irrigation and Power (CBIP) Publications

**ANNEXURE-I  
FORMAT OF QUALITY ASSURANCE PROGRAMME**

<b>VENDOR'S LOGO , NAME &amp; ADDRESS</b>	<b>MANUFACTURING QUALITY ASSURANCE PLAN</b>	<b>DOC NO:</b> XXXXX-CAL-QAP-M-0001	<b>REV NO:</b> 0 1 2 3 4	<b>DATE :</b>
<b>CLIENT :</b>	<b>ITEM :</b>	<b>LOCATION :</b>		
<b>PROJECT :</b>		<b>REFERENCE PURCHASE ORDER NO. &amp; DT :</b>		
<b>VENDOR :</b>		<b>REFERENCE APPROVED DATA SHEET :</b>		
<b>SUB VENDOR :</b>		<b>REFERENCE APPROVED DRAWING. NO. :</b>		
<b>ABBREVIATIONS :</b>	<b>AGENCY :</b>	<b>GENERAL REMARKS</b>		
<p>QAP - QUALITY ASSURANCE PLAN,      MATL - MATERIAL,      1 - PROJECT AUTHORITY</p> <p>CR - CRITICAL,                            APP - APPROVED,      2 - SUPPLIER</p> <p>MA - MAJOR,                                DWG - DRAWING,      3 - SUB-SUPPLIER</p> <p>MI - MINOR                                  SUPL - SUPPLIER,      4 - MANUFACTURER</p> <p>SPEC - SPECIFICATION,                  PROC - PROCEDURE    5 - THIRD PARTY INSPECTION AGENCY</p> <p>TC - TEST CERTIFICATES</p> <p>P - PERFORM</p> <p>w - WITNESS</p> <p>V - VERIFY</p> <p><b>CHP - CUSTOMER HOLD POINT</b></p>	<p>1 - THE ITEMS WHICH ARE FALLING UNDER ANY STATUTORY AUTHORITY'S (LIKE I.B.R. ETC.) SCOPE SHALL BE SUBJECTED TO THAT STATUTORY AUTHORITY'S INSPECTION CLEARANCE.</p>			
<b>NOTES:</b>	<p>1. EXACT MATERIAL / PROCESS / INSPECTION / TESTS FOLLOWED BY THE MANUFACTURER SHALL BE SPECIFIED</p> <p>2. EXACT REFERENCE DOCUMENT/ACCEPTANCE STANDARD SHALL BE SPECIFIED</p> <p>3. IN CASE SPECIFIED ACCEPTANCE STANDARD / NORMS IS OTHER THAN NATIONAL / INTERNATIONAL STANDARDS STANDARD / COPY OF THE ACCEPTANCE NORMS FOLLOWED BY THE MANUFACTURER SHALL BE SUBMITTED FOR REVIEW RECORD</p> <p>4 FINAL INSPECTION DOSSIER SHALL BE PREPARED BY MANUFACTURER &amp; SHALL BE ENDORSED BY INSPECTION AGENCY</p>			
Revision	Prepared by	Checked by	Approved By	
DATE	R0	R0	R0	R2
	R1	R1	R1	R2
	R2	R2	R2	R2

26.12.2022



**ANNEXURE-II**

**FIELD WELDING SCHEDULE**

PROJECT : FWS NO :  
 CONTRACTOR : REV NO. :  
 PACKAGE : FIELD WELDING CODE :  
 SYSTEM : PAGE NO. :

Sl No.	Drawing No. for Weld Locations & Identification mark	Description of parts to be welded	Material specification	Dimensions	Process of Welding	Type of Weld	Electrode Filler Specification	WPS No.	Minimum Pre-heat Temperature	Heat Treatment Temperature [Holding Time in secs]	NDT Method	NDT Specification Number	Acceptance Norm Ref.	Remarks
--------	--	-----------------------------------	------------------------	------------	--------------------	--------------	--------------------------------	---------	------------------------------	---	------------	--------------------------	----------------------	---------

The Field Welding Schedule should be submitted for :

- 0 Pressure Parts
- 0 Tanks/Vessels
- 0 Piping
- 0 Heavy/Important Structural Steel
- 0 Heat Exchangers
- 0 Bus Ducts

DATE 26.12.2022

**REQUIREMENTS OF SPARES, TOOLS & TACKLE,  
LUBRICANTS/OIL/CONSUMABLES**

## CONTENT

<b>CLAUSE NO.</b>	<b>DESCRIPTION</b>
1.00.00	TOOLS AND TACKLE
2.00.00	SPARES
	<b>ATTACHMENT</b>
ANNEXURE-I	MANDATORY SPARE LIST

**REQUIREMENTS OF SPARES, TOOLS & TACKLE,  
LUBRICANTS/OIL/CONSUMABLES**

**1.00.00 TOOLS & TACKLE**

The Contractor shall supply with the equipment one complete set of special tools and tackle as required for the erection, assembly, dismantling & maintenance of the equipment. These special tools will also include special material handling equipment, jigs & fixtures for maintenance and calibration/readjustment, checking & measurement aids etc. A list of such tools & tackle shall be submitted by the Bidder along with the offer. Detailed description of each tools/tackle, its function along with the equipment/part for which it is meant for and the price of each tools/tackle shall also be indicated in the offer. These tools & tackle shall be separately packed and sent to site before the first unit commissioning. The Bidder shall also ensure that these tools are not used for erection purpose.

**2.00.00 SPARES**

**2.01.00 General**

The Bidder shall indicate and include in his scope of supply all the necessary start-up, commissioning and recommended spares in addition to mandatory spares as specified elsewhere in the specification. The Owner reserves the right to buy any or all mandatory and recommended spares. The Contractor shall also state for each item of spares both mandatory and recommended, the normal expected service life.

2.01.01 All spares supplied under this contract shall be strictly interchangeable with the parts for which they are intended to replace. The spares shall be treated and packed for long storage under the climatic conditions prevailing at the site, e.g. small items shall be packed in sealed transparent plastic bags with dessicator packs as necessary.

2.01.02 Each spare part shall be clearly marked or labelled on the outside of the packing with the description. When more than one spare part is packed in a single case, a general description of the contents shall be shown on the outside and a detailed list enclosed. All cases, containers and other packages must be suitably marked and numbered for the purposes of identification.

2.01.03 All cases, containers or other packages are liable to be opened for examination as may be considered necessary by the Engineer.

2.01.04 All mandatory spares shall be delivered to site within one to three months prior to the scheduled date of the trial operation of the plant. However, they shall not be despatched before the despatch of the associated main equipment.

2.01.05 The Bidder shall also guarantee supply of spare parts, which will be made, based on manufacturer's drawings on special order from the Purchaser for 30 years after commissioning of the plant.

2.02.00 **Recommended Spares**

2.02.01 The Contractor shall provide a list of recommended spares giving unit prices and total prices for 2 years of normal operation of the plant for spares of indigenous origin, and for 5 years of normal operation for spares of non-indigenous origin. This list shall take into consideration the mandatory spares specified elsewhere in the specification and should be a separate list.

2.02.02 The price of recommended spares will not be used for the evaluation of bids. The price of these spares shall remain valid for a period as specified elsewhere in the specification from the date of Award of the Contract. Where the recommended spares are the same as mandatory spares, the prices shall be the same. The prices of any recommended spares, which are not common with mandatory spares, shall be subject to review by the Owner, and shall be finalised after mutual discussion.

2.03.00 **Start-up Commissioning Spares**

2.03.01 Start-up commissioning spares are those spares which may be required during the start-up and commissioning of the equipment/system. All spares used until the plant is handed over to the Owner shall come under this category. Said spares, properly marked, shall be supplied together with the main equipment and shall be used by the Contractor, if needed, during erection & commissioning stage. All such spares which remain unused till issuance of Taking Over Certificate by the Owner, along with an equipment-wise quantitative consumption report shall be returned to the Owner during time of handover. The list of commissioning spares to be brought by the Contractor to ensure smooth commissioning of the plant shall be subject to the Engineer's approval.

2.03.02 The Contractor shall submit a complete BBU list inclusive of recommended, mandatory, initial start-up and commissioning spares. Costs of the above spares, which are consumed before the handing-over of the plant, shall be deemed to have been included in the lump sum proposal price of the package, and the Contractor shall have no claim on this account to the Owner.

2.04.00 **Mandatory Spare Parts**

2.04.01 The Owner considers some of the spares are essential for running the equipment irrespective of whether they are included in the list of recommended spares by the Bidder as mentioned above.

Since the components involved can not be foreseen at the bidding stage, only

---

broad requirements of the Owner in this respect are outlined hereinafter. The bidder shall include his proposal, on the basis of this guideline, an item-wise list of all components and the quantity, unit prices & total price thereof, offered as mandatory spares for each and every equipment. This list shall be separate from the list of recommended spares and shall be used for bid evaluation purposes. Any clarification in this respect may be obtained by the Bidder at the pre-bidding stage.

DATE 26.12.2022

- 2.04.02 The mandatory spares should be supplied to the Owner at least one month before the trial run. The despatch programme is subject to approval of the Owner/Consultant after award of contract.

PEM-6666-0



**TECHNICAL SPECIFICATION FOR**  
**ELECTRIC HOIST**  
**4X270 MW BHADRADRI TPS- FGD**


SPECIFICATION NO. PE-TS-440-563-A002	
VOLUME II - B	DATE 26.12.2022
SECTION -I	
REV 00	DATE JULY 2020

**SUB-SECTION IB**  
**SPECIFIC TECHNICAL REQUIREMENT (ELECTRICAL)**

## STANDARD ELECTRICAL SCOPE BETWEEN BHEL AND VENDOR

PACKAGE: ELECTRIC HOIST  
 PROJECT : 4 X 270 MW BHADRADRI TPS-FGD  
 SCOPE OF VENDOR: SUPPLY

<u>S. NO</u>	<u>DETAILS</u>	<u>SCOPE SUPPLY</u>	<u>SCOPE E&amp;C</u>	<u>REMARKS</u>
1	Isolating Switch	Vendor	BHEL	BHEL will provide one number 415 V(3ph, 4W) supply feeder only up to isolating switches for cranes/hoists. Any other voltage level (AC/DC) required will be derived by the vendor. Motor starter shall be part of crane/ hoist control panel.
2	Power cables, control cables, screened control cables and any special cables (if required) between equipment supplied by vendor.	Vendor	BHEL	Cable from supply feeder to isolating switch shall be in BHEL scope.
3	Cabling material (cable trays, accessories, cable tray supporting system, conduits etc).	Vendor	BHEL	
4	Equipment Earthing	BHEL	BHEL	All equipment metallic enclosures / frames, metal structure etc. shall be grounded at two points each to the nearest grounding points / risers provided by BHEL
5	Motors	Vendor	BHEL	
6	Cable glands and lugs for equipment supplied by vendor	Vendor	BHEL	1. Double compression Ni-Cr plated brass cable glands 2. Solder less crimping type heavy duty tinned copper lugs for power & control cables.
7	a) Input cable schedules (C & I) b) Cable interconnection details for above c) Cable block diagram	Vendor Vendor Vendor	- - -	Cable listing for Control and Instrumentation Cable in enclosed excel format shall be submitted by vendor during detailed engineering stage.
8	Equipment layout drawings	Vendor	-	
9	Electrical Equipment GA drawing	Vendor	-	For necessary interface review.

	<b>ELECTRICAL EQUIPMENT SPECIFICATION FOR ELECTRIC HOIST</b>  <b>4X270MW BHADRADRI TPS</b>	SPECIFICATION NO.
		VOLUME NO. : <del>DTE</del> 26.12.2022
		SECTION : C
		REV NO. : 00 DATE :

**1.0 EQUIPMENT & SERVICES TO BE PROVIDED BY BIDDER:**

- a) Services and equipment as per “Electrical Scope between BHEL and Vendor”.
- b) Any item/work either supply of equipment or erection material which have not been specifically mentioned but are necessary to complete the work for trouble free and efficient operation of the plant shall be deemed to be included within the scope of this specification. The same shall be provided by the bidder without any extra charge.
- c) Supply of mandatory spares as specified in the specifications of mechanical equipments.
- d) Electrical load requirement for ELECTRIC HOIST
- e) All equipment shall be suitable for the power supply fault levels and other climatic conditions mentioned in the enclosed project information.
- f) Bidder to furnish list of makes for each equipment at contract stage, which shall be subject to customer/BHEL approval without any commercial and delivery implications to BHEL
- g) Various drawings, data sheets as per required format, Quality plans, calculations, test reports, test certificates, operation and maintenance manuals etc shall be furnished as specified at contract stage. All documents shall be subject to customer/BHEL approval without any commercial implication to BHEL.
- h) Motor shall meet minimum requirement of motor specification.
- i) Vendor to clearly indicate equipment locations and local routing lengths in their cable listing furnished to BHEL.
- j) Cable BOQ worked out based on routing of cable listing provided by the vendor for “ both end equipment in vendor’s scope”shall be binding to the vendor with +10 % margin to take care of slight variation in routing length & wastages.

**2.0 EQUIPMENT & SERVICES TO BE PROVIDED BY PURCHASER FOR ELECTRICAL & TERMINAL POINTS:**

Refer “Electrical Scope between BHEL and Vendor”.

**3.0 DOCUMENTS TO BE SUBMITTED ALONG WITH BID**

- 3.1 The electrical specification without any deviation from the technical/quality assurance requirements stipulated shall be deemed to be complied by the bidder in case bidder furnishes the overall compliance of package technical specification in the form of compliance certificate/No deviation certificate.
- 3.2 No technical submittal such as copies of data sheets, drawings, write-up, quality plans, type test certificates, technical literature, etc, is required during tender stage. Any such submission even if made, shall not be considered as part of offer.

**4.0 List of enclosures :**

- a) Electrical scope between BHEL & vendor (Annexure –I)
- b) Standard BHEL specification for motors.
- c) Datasheets(A&C) & quality plan for motors.
- d) Electrical Load data format (Annexure –II)
- e) BHEL cable listing format (Annexure –III)
- f) Explanatory notes for cable routing



<b>GENERAL TECHNICAL REQUIREMENTS</b>  <b>FOR</b>  <b>LV MOTORS</b>	SPECIFICATION NO. PE-SS-999-506-E101
	VOLUME NO. : <del>DATE</del> 26.12.2022
	SECTION : <b>D</b>
	REV NO. : <b>00</b> DATE : 28.01.10
	SHEET : 1 OF 1

**GENERAL TECHNICAL REQUIREMENTS**

**FOR**

**LV MOTORS**

**SPECIFICATION NO.: PE-SS-999-506-E101 Rev 00**

<b>TITLE :</b> <b>GENERAL TECHNICAL REQUIREMENTS</b>  <b>FOR</b>  <b>LV MOTORS</b>	<b>SPECIFICATION NO.</b> PE-SS-999-506-E101
	<b>VOLUME NO. :</b> <del>D1E</del> 26.12.2022
	<b>SECTION :</b> <b>D</b>
	<b>REV NO. : 00</b> <b>DATE :</b> 28.01.10
	<b>SHEET :</b> 1 OF 4

**1.0 INTENT OF SPECIFICATION**

The specification covers the design, materials, constructional features, manufacture, inspection and testing at manufacturer's work, and packing of Low voltage (LV) squirrel cage induction motors along with all accessories for driving auxiliaries in thermal power station.

Motors having a voltage rating of below 1000V are referred to as low voltage (LV) motors.

**2.0 CODES AND STANDARDS**

Motors shall fully comply with latest edition, including all amendments and revision, of following codes and standards:

IS:325	Three phase Induction motors
IS : 900	Code of practice for installation and maintenance of induction motors
IS: 996	Single phase small AC and universal motors
IS: 4722	Rotating Electrical machines
IS: 4691	Degree of Protection provided by enclosures for rotating electrical machines
IS: 4728	Terminal marking and direction of rotation rotating electrical machines
IS: 1231	Dimensions of three phase foot mounted induction motors
IS: 8789	Values of performance characteristics for three phase induction motors
IS: 13555	Guide for selection and application of 3-phase A.C. induction motors for different types of driven equipment
IS: 2148	Flame proof enclosures for electrical appliance
IS: 5571	Guide for selection of electrical equipment for hazardous areas
IS: 12824	Type of duty and classes of rating assigned
IS: 12802	Temperature rise measurement of rotating electrical machines
IS: 12065	Permissible limits of noise level for rotating electrical machines
IS: 12075	Mechanical vibration of rotating electrical machines

In case of imported motors, motors as per IEC-34 shall also be acceptable.

**3.0 DESIGN REQUIREMENTS**

3.1 Motors and accessories shall be designed to operate satisfactorily under conditions specified in data sheet-A and Project Information, including voltage & frequency variation of supply system as defined in Data sheet-A

3.2 Motors shall be continuously rated at the design ambient temperature specified in Data Sheet-A and other site conditions specified under Project Information  
 Motor ratings shall have at least a 15% margin over the continuous maximum demand of the driven equipment, under entire operating range including voltage & frequency variation specified above.

**3.3 Starting Requirements**

3.3.1 Motor characteristics such as speed, starting torque, break away torque and starting time shall be properly co-ordinated with the requirements of driven equipment. The accelerating torque at any speed with the minimum starting voltage shall be at least 10% higher than that of the driven equipment.

3.3.2 Motors shall be capable of starting and accelerating the load with direct on line starting without exceeding acceptable winding temperature.

<b>TITLE :</b> <b>GENERAL TECHNICAL REQUIREMENTS</b>  <b>FOR</b>  <b>LV MOTORS</b>	<b>SPECIFICATION NO.</b> PE-SS-999-506-E101
	<b>VOLUME NO. :</b> <del>D1E</del> 26.12.2022
	<b>SECTION :</b> <b>D</b>
	<b>REV NO. : 00</b> <b>DATE :</b> 28.01.10
	<b>SHEET :</b> 2 OF 4

The limiting value of voltage at rated frequency under which a motor will successfully start and accelerate to rated speed with load shall be taken to be a constant value as per Data Sheet - A during the starting period of motors.

3.3.3 The following frequency of starts shall apply

- i) Two starts in succession with the motor being initially at a temperature not exceeding the rated load temperature.
- ii) Three equally spread starts in an hour the motor being initially at a temperature not exceeding the rated load operating temperature. (not to be repeated in the second successive hour)
- iii) Motors for coal conveyor and coal crusher application shall be suitable for three consecutive hot starts followed by one hour interval with maximum twenty starts per day and shall be suitable for minimum 20,000 starts during the life time of the motor

**3.4 Running Requirements**

3.4.1 Motors shall run satisfactorily at a supply voltage of 75% of rated voltage for 5 minutes with full load without injurious heating to the motor.

3.4.2 Motor shall not stall due to voltage dip in the system causing momentary drop in voltage upto 70% of the rated voltage for duration of 2 secs.

**3.5 Stress During bus Transfer**

3.5.1 Motors shall withstand the voltage, heavy inrush transient current, mechanical and torque stress developed due to the application of 150% of the rated voltage for at least 1 sec. caused due to vector difference between the motor residual voltage and the incoming supply voltage during occasional auto bus transfer.

3.5.2 Motor and driven equipment shafts shall be adequately sized to satisfactorily withstand transient torque under above condition.

3.6 Maximum noise level measured at distance of 1.0 metres from the outline of motor shall not exceed the values specified in IS 12065.

3.7 The max. vibration velocity or double amplitude of motors vibration as measured at motor bearings shall be within the limits specified in IS: 12075.

**4.0 CONSTRUCTIONAL FEATURES**

4.1 Indoor motors shall conform to degree of protection IP: 54 as per IS: 4691. Outdoor or semi-indoor motors shall conform to degree of protection IP: 55 as per IS: 4691 and shall be of weather-proof construction. Outdoor motors shall be installed under a suitable canopy

4.2 Motors upto 160KW shall have Totally Enclosed Fan Cooled (TEFC) enclosures, the method of cooling conforming to IC-0141 or IC-0151 of IS: 6362.

Motors rated above 160 KW shall be Closed Air Circuit Air (CACA) cooled

4.3 Motors shall be designed with cooling fans suitable for both directions of rotation.

<b>TITLE :</b> <b>GENERAL TECHNICAL REQUIREMENTS</b>  <b>FOR</b>  <b>LV MOTORS</b>	SPECIFICATION NO. PE-SS-999-506-E101
	VOLUME NO. : <del>DAT</del> 26.12.2022
	SECTION : <b>D</b>
	REV NO. : <b>00</b> DATE : 28.01.10
	SHEET : 3 OF 4

- 4.4. Motors shall not be provided with any electric or pneumatic operated external fan for cooling the motors.
- 4.5. Frames shall be designed to avoid collection of moisture and all enclosures shall be provided with facility for drainage at the lowest point.
- 4.6. In case Class 'F' insulation is provided for LV motors, temperature rise shall be limited to the limits applicable to Class 'B' insulation.  
In case of continuous operation at extreme voltage limits the temperature limits specified in table-1 of IS:325 shall not exceed by more than 10°C.
- 4.7. **Terminals and Terminal Boxes**
- 4.7.1 Terminals, terminal leads, terminal boxes, windings tails and associated equipment shall be suitable for connection to a supply system having a short circuit level, specified in the Data Sheet-A.  
  
Unless otherwise stated in Data Sheet-A, motors of rating 110 kW and above will be controlled by circuit breaker and below 110 kW by switch fuse-contactor. The terminal box of motors shall be designed for the fault current mentioned in data sheet "A".
- 4.7.2 Unless otherwise specified or approved, phase terminal boxes of horizontal motors shall be positioned on the left hand side of the motor when viewed from the non-driving end.
- 4.7.3 Connections shall be such that when the supply leads R, Y & B are connected to motor terminals A B & C or U, V & W respectively, motor shall rotate in an anticlockwise direction when viewed from the non-driving end. Where such motors require clockwise rotation, the supply leads R, Y, B will be connected to motor terminals A, C, B or V W & V respectively.
- 4.7.4 Permanently attached diagram and instruction plate made preferably of stainless steel shall be mounted inside terminal box cover giving the connection diagram for the desired direction of rotation and reverse rotation.
- 4.7.5 Motor terminals and terminal leads shall be fully insulated with no bar live parts. Adequate space shall be available inside the terminal box so that no difficulty is encountered for terminating the cable specified in Data Sheet-A.
- 4.7.6 Degree of protection for terminal boxes shall be IP 55 as per IS 4691.
- 4.7.7 Separate terminal boxes shall be provided for space heaters.. If this is not possible in case of LV motors, the space heater terminals shall be adequately segregated from the main terminals in the main terminal box. Detachable gland plates with double compression brass glands shall be provided in terminal boxes.
- 4.7.8. Phase terminal boxes shall be suitable for 360 degree of rotation in steps of 90 degree for LV motors.
- 4.7.9 Cable glands and cable lugs as per cable sizes specified in Data Sheet-A shall be included. Cable lugs shall be of tinned Copper, crimping type.
- 4.8 Two separate earthing terminals suitable for connecting G.I. or MS strip grounding conductor of size given in Data Sheet-A shall be provided on opposite sides of motor frame. Each terminal box shall have a grounding terminal.

<b>TITLE :</b> <b>GENERAL TECHNICAL REQUIREMENTS</b>  <b>FOR</b>  <b>LV MOTORS</b>	<b>SPECIFICATION NO.</b> PE-SS-999-506-E101
	<b>VOLUME NO. :</b> <del>D1E</del> 26.12.2022
	<b>SECTION :</b> <b>D</b>
	<b>REV NO. : 00</b> <b>DATE :</b> 28.01.10
	<b>SHEET :</b> 4 OF 4

**4.9 General**

- 4.9.1 Motors provided for similar drives shall be interchangeable.
- 4.9.2 Suitable foundation bolts are to be supplied alongwith the motors.
- 4.9.3 Motors shall be provided with eye bolts, or other means to facilitate safe lifting if the weight is 20Kgs. and above.
- 4.9.4 Necessary fitments and accessories shall be provided on motors in accordance with the latest Indian Electricity rules 1956.
- 4.9.5 All motors rated above 30 kW shall be provided with space heaters to maintain the motor internal air temperature above the dew point. Unless otherwise specified, space heaters shall be suitable for a supply of 240V AC, single phase, 50 Hz.
- 4.9.6 Name plate with all particulars as per IS: 325 shall be provided
- 4.9.7 Unless otherwise specified, the colour of finish shall be grey to Shade No. 631 and 632 as per IS:5 for motors installed indoor and outdoor respectively. The paint shall be epoxy based and shall be suitable for withstanding specified site conditions.

**5.0 INSPECTION AND TESTING**

- 5.1 All materials, components and equipments covered under this specification shall be procured, manufactured, as per the BHEL standard quality plan No. PED-506-00-Q-006/0 and PED-506-00-Q-007/2 enclosed with this specification and which shall be complied.
- 5.2 LV motors of type-tested design shall be provided. Valid type test reports not more than 5 year shall be furnished. In the absence of these, type tests shall have to be conducted by manufacturer without any commercial implication to purchaser.
- 5.3 All motors shall be subjected to routine tests as per IS: 325 and as per BHEL standard quality plan.
- 5.4 Motors shall also be subjected to additional tests, if any, as mentioned in Data Sheet A.

**6.0 DRAWINGS TO BE SUBMITTED AFTER AWARD OF CONTRACT**

- a) OGA drawing showing the position of terminal boxes, earthing connections etc.
- b) Arrangement drawing of terminal boxes.
- c) Characteristic curves:  
(To be given for motor above 55 kW unless otherwise specified in Data Sheet).
  - i) Current vs. time at rated voltage and minimum starting voltage.
  - ii) Speed vs. time at rated voltage and minimum starting voltage.
  - iii) Torque vs. speed at rated voltage and minimum voltage.  
For the motors with solid coupling the above curves i), ii), iii) to be furnished for the motors coupled with driven equipment. In case motor is coupled with mechanical equipment by fluid coupling, the above curves shall be furnished with and without coupling.
  - iv) Thermal withstand curve under hot and cold conditions at rated voltage and max. permissible voltage.

**Explanatory notes for filling up cable list for routing through WinPath, the cable routing program**  
 (developed by Corporate R&D) being used in PEM.

DATE 26.12.2022

1. For the purpose of clarity, it may please be noted that the information given in regard to the cables to be routed through WinPath as per the system elaborated below is called "Cable List", while the term "Cable Schedule" applies to the cable list with routing information added after routing has been carried out.
2. The cable list shall be entered as an MS Excel file in the format as per enclosed template EXT\_CAB\_SCH\_FORMAT.XLS. No blank lines, special characters, header, footer, lines, etc. shall be introduced in the file. No changes shall be made in the title line (first line) of the template.
3. The field properties shall be as under:
  - a. UNITCABLENO: A/N, up to sixteen (16) characters; each cable shall have its own unique, unduplicated cable number. In case this rule is violated, the cable cannot be taken up for routing.
  - b. FROM: A/N, up to sixty (60) characters; the "From" end equipment/ device description and location to be specified here. Information in excess of 60 characters will be truncated after 60 characters.
  - c. TO: A/N, up to sixty (60) characters; the "To" end equipment/ device description and location to be specified here. Information in excess of 60 characters will be truncated after 60 characters.
  - d. PURPOSE: A/N, up to sixty (60) characters; the purpose (i.e. power cable/ indication/ measurement, etc.) to be specified here. Information in excess of 60 characters will be truncated after 60 characters.
  - e. REMARKS: A/N, up to forty (40) characters; Any information pertinent to routing to be specified here (e.g., cable number of the cable redundant to the cable number being entered). Information in excess of 40 characters will be truncated after 40 characters.
  - f. CABLESIZE: A/N, 7 characters exactly as per the codes indicated below shall be specified here. The program cannot route cables described in any other way/ format.
  - g. PATHCABLENO: Field reserved for utilization by the program. User shall not enter any information here.
4. One list shall be prepared for each system/ equipment (i.e., separate and unique cable lists shall be prepared for each system).
5. The cables shall be described as per the scheme listed below:

A	NN	A	NNN
Cable	No. of cores	Cable code	Cable size
Voltage	(e.g. 01,03,3H, 07)	(See C below)	(e.g. 035,185,2.5, 0.5)
Code (see B below)			

(A) SYSTEM VOLTAGE CODES:

(ac) A = 11KV, B = 6.6KV, C = 3.3KV, D = 415V, E = 240V, F = 110V  
 (dc) G = 220V, H = 110V, J = 48V, K = +24V, L = -24V

(B) CABLE VOLTAGE CODES:

A = 11KV (Power cables)

Explanatory notes for filling up cable list for routing through WinPath, the cable routing program  
(developed by Corporate R&D) being used in PEM.

DATE 26.12.2022

- B = 6.6KV (Power cables)
- C = 3.3KV (Power cables)
- D = 1.1KV (LV & DC system power & control cables)
- E = 0.6KV (0.5 sq. mm. Control cables)

(C) CABLE CODES

PVC Copper

- A = Armoured FRLS
- C = unarmoured FRLS
- B = Armoured Non-FRLS
- D = Unarmoured Non-FRLS

PVC Aluminium

- E = Armoured FRLS
- G = unarmoured FRLS
- F = Armoured Non-FRLS
- H = Unarmoured Non-FRLS


XLPE Copper

- J = Armoured FRLS
- L = unarmoured FRLS
- K = Armoured Non-FRLS
- M = Unarmoured Non-FRLS

XLPE Aluminium

- N = Armoured FRLS
- Q = unarmoured FRLS
- P = Armoured Non-FRLS
- R = Unarmoured Non-FRLS

- S = FIRE SURVIVAL CABLES
- T = TOUGH RUBBER SHEATH
- U = OVERALL SCREENED
- V = PAIRED OVERALL SCREENED
- W = PAIRED INDIVIDUAL SCREENED
- Y = COMPENSATING CABLES
- I = PRE-FABRICATED CABLES
- Z = JELLY FILLED CABLES

	TITLE	<b>LV MOTORS</b>		SPECIFICATION NO.	
		<b>DATA SHEET-A</b>		VOLUME	II B
		<b>4 X 270 MW BHADRADRI</b>		SECTION	D
		<b>TPS</b>	REV NO.	DATE	18.03.15
			SHEET	1	OF

1.0	Design ambient temperature	:	50 °C
2.0	Maximum acceptable kW rating of LV motor	:	160KW *
3.0	Installation (Indoors/ Outdoors)	:	As required
4.0	Details of supply system		
a)	Rated voltage (with variation)	:	415V ± 10%
b)	Rated frequency (with variation)	:	50 Hz + 3 % to - 5%
c)	Combined voltage & freq. variation	:	10% (sum of absolute values)
d)	System fault level at rated voltage	:	50 kA for 1 sec
e)	Short time rating for terminal boxes		
o	110 kW and above (Breaker : Controlled)	:	50 KA for 0.20 sec..
o	Below 110 kW (Contactor : Controlled)	:	50 KA protected by HRC fuse
f)	LV System grounding	:	Solidly
5.0	Class of insulation	:	Class 'F', with temp rise limited to class B.
6.0	Minimum voltage for starting (As percentage of rated voltage)	:	(a) 85% below 110KW (b) 80% from 110KW to 160KW (c) 85% above 160KW to 1000KW (d) 80% from 1001 KW to 4000KW (e) 75% > 4000KW
7.0	Power cables data	:	Shall be given during detailed engg.
8.0	Earth Conductor Size & Material	:	As per attached Datasheet of Earthing.
9.0	Space heater supply	:	240 V, 1ϕ, 50 Hz (for motors above 30 Kw)
10.0	Rating up to which Single phase motor	:	Acceptable below 0.20 kW
11.0	Locked rotor current		
a)	Limit as percentage of FLC	:	As per IS 12615*
12.0	Flame-proof motor		
a)	Enclosure suitable (As per IS: 2148)	:	As per requirement
b)	Classification of Hazardous area (As per IS: 5572 part-I)	:	As per requirement
13.0	Makes	:	BHEL/ Customer approval
14.0	Paint shade	:	Shall be given during detailed engg
15.0	Degree Of protection for motor/ terminal box	:	IP 54/ IP 55



TITLE

**LV MOTORS****DATA SHEET-A****4 X 270 MW BHADRADRI****TPS**

SPECIFICATION NO.

VOLUME II B

SECTION D

REV NO. DATE 18.03.15

SHEET 1 OF 2

\* Continuous duty LT motors up to 160 KW Output rating (at 50 deg.C ambient temperature), shall be High efficiency (IE2) as per IEC: 60034-30/ IS:12615

**16.0 TESTING****16.1 Type Tests**

For LT Motors above 55kW, type test reports for type tests as per IS: 325/ IS: 12615 conducted on equipment similar to those proposed to be supplied and carried out within last five years from the date of bid opening shall be submitted. However, if such reports are not available, one motor of each type shall be subjected to type tests for free of cost.

**16.2 Routine Tests**

All motors shall be subjected to routine tests as per IS: 325/ IS: 12615 in the presence of customer or customer representative.

<b>TITLE</b>  <b>MOTOR</b>  <b>DATA SHEET - C</b>	<b>SPECIFICATION NO.</b>
	<b>VOLUME II B</b>
	<b>SECTION D</b>
	<b>REV NO. 00 DATE 18.03.15</b>
	<b>SHEET 1 OF 2</b>


S. No.	Description	Data to be filled by successful bidder
<b>A.</b>	<b>General</b>	
1	Manufacturer & country of origin	
2	Motor type	
3	Type of starting	
4	Name of the equipment driven by motor & Quantity	
5	Maximum Power requirement of driven equipment	
6	Rated speed of Driven Equipment	
7	Design ambient temperature	
<b>B.</b>	<b>Design and Performance Data</b>	
1	Frame size & type designation	
2	Type of duty	
3	Rated Voltage	
4	Permissible variation for	
5	a) Voltage	
6	b) Frequency	
7	c) Combined voltage & frequency	
8	Rated output at design ambient temp (by resistance method)	
9	Synchronous speed & Rated slip	
10	Minimum permissible starting voltage	
11	Starting time in sec with mechanism coupled	
12	a) At rated voltage	
13	b) At min starting voltage	
14	Locked rotor current as percentage of FLC (including IS tolerance)	
15	Torque	
	a) Starting	
	b) Maximum	
16	Permissible temp rise at rated output over ambient temp & method	
17	Noise level at 1.0 m (dB)	
18	Amplitude of vibration	
19	Efficiency & P.F. at rated voltage & frequency	
	a) At 100% load	
	c) At 75% load	


NAME OF VENDOR			SEAL	REV.	
NAME	SIGNATURE	DATE			

	<b>TITLE</b>  <b>MOTOR</b>  <b>DATA SHEET - C</b>	<b>SPECIFICATION NO.</b>
		<b>VOLUME</b> <b>II B</b>
		<b>SECTION</b> <b>D</b>
		<b>REV NO.00</b> <b>DATE</b> <b>18.03.15</b>
		<b>SHEET</b> <b>2</b> <b>OF</b> <b>2</b>

S. No.	Description	Data to be filled by successful bidder
	c) At starting	
<b>C.</b>	<b>Constructional Features</b>	
1	Method of connection of motor driven equipment	
2	Applicable Standard	
3	DOP of Enclosure	
4	Method of cooling	
5	Class of insulation	
6	Main terminal box	
	a) Type	
	b) Power Cable details (Conductor, size, armour/unarmour)	
	c) Cable Gland & lugs details (Size, type & material)	
	d) Permissible Fault level ( kArms & duration in sec)	
7	Space heater details (Voltage & watts)	
8	Flame proof motor details (if applicable)	
	a) Enclosure	
	b) suitability for hazardous area	
	i    Zone	O / I / II
	ii    Group	IIA / IIB / IIC
9	No. of Stator winding	
10	Winding connection	
11	Kind of rotor winding	
12	Kind of bearings	
13	Direction of rotation when viewed from NDE	
14	Paint Shade & type	
15	Net weight of motor	
16	Outline mounting drawing No (To be enclosed as annexure)	
<b>D.</b>	<b>Characteristic curves/ drawings</b> (To be enclosed for motors of rating $\geq 55$ KW)	
	a) Torque speed characteristic	
	b) Thermal withstand characteristic	
	c) Current vs time	
	d) Speed vs time	

NAME OF VENDOR			SEAL	REV.	
NAME	SIGNATURE	DATE			

		CUSTOMER : TSGENCO				PROJECT		SPECIFICATION :			
		QUALITY PLAN		TITLE		4X270MW BHADRADRI TPS		NUMBER :			
SHEET 1 OF 2		BIDDER/ VENDOR		QUALITY PLAN		SPECIFICATION		TITLE			
SL. NO.	COMPONENT/OPERATION CHARACTERISTICS CHECK	SYSTEM CAT.	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORM	FORMAT OF RECORD	SECTION AGENCY	VOLUME III REMARKS		
1	2	3	4	5	6	7	8	9	10		
								P	W	V	
1.0	ASSEMBLY	MA	VISUAL	100%	MANUF'S SPEC	MANUF'S SPEC	-DO-	2	-	-	
	1.WORKMANSHIP	MA	-DO-	-DO-	MFG. DRG./ MFG. SPEC.	MFG. DRG./ MFG. SPEC.	-DO-	2	-	-	
	2.DIMENSIONS	MA	VISUAL	100%	MFG.SPEC./ RELEVANT IS	MFG.SPEC./ RELEVANT IS	-DO-	2	-	-	
	3.CORRECTNESS COMPLETENESS TERMINATIONS/ MARKING/COLOUR CODE	MA	VISUAL	SAMPLE	MANUF'R'S SPEC/BHEL SPEC./RELEVANT STANDARD	BHEL SPEC. SAME AS COL.7	LOG BOOK	2	-	-	
2.0	PAINTING	MA	-DO-	100%	IS-325/ BHEL SPEC./ DATA SHEET	SAME AS COL.7	TEST REPORT	2	1	NOTE -1 & NOTE-3	
3.0	TESTS	MA	MEASUREMENT & VISUAL	100%	APPROVED DRG/DATA SHEET	APPROVED DRG/DATA SHEET & RELEVANT IS	INSPN. REPORT	2	1	NOTE -1 & NOTE-3	
BHEL		PARTICULARS		BIDDER/VENDOR							
		NAME									
		SIGNATURE									

		<b>CUSTOMER : TSGENCO</b>		<b>PROJECT</b> 4X270MW BHADRADRI TPS		SPECIFICATION : NUMBER :					
		<b>QUALITY PLAN</b> BIDDER/ VENDOR : SYSTEM :		TITLE CRANES & HOISTS		SPECIFICATION : TITLE :					
SHEET 2 OF 2 COMPONENT/OPERATION CHARACTERISTICS CHECK		TYPE/METHOD OF CHECK		REFERENCE DOCUMENT		ACCEPTANCE NORM		FORMAT OF RECORD		SECTION VOLUME III AGENCY P W V REMARKS	
1	2	3	4	5	6	7	8	9	10	11	
		3.NAMEPLATE DETAILS	IMA	VISUAL	100%	IS-325 & DATA SHEET	IS-325 & DATA SHEET	INSPN. REPORT	2	1	-
NOTES: 1 ROUTINE TESTS ON 100% MOTORS SHALL BE DONE BY THE VENDOR. HOWEVER, BHEL SHALL WITNESS ROUTINE TESTS ON RANDOM SAMPLES. THE SAMPLING PLAN SHALL BE MUTUALLY AGREED UPON WHERE EVER CUSTOMER IS INVOLVED IN INSPECTION, (1) SHALL MEAN BHEL AND CUSTOMERS BOTH TOGETHER. 2 3 FOR EXHAUST/VENTILATION FAN MOTORS OF RATING UPTO 1.5KW , ONLY ROUTINE TEST CERTIFICATES SHALL BE FURNISHED FOR SCRUTINY.											
Legends for Inspection agency 1. BHEL/CUSTOMER 2. VENDOR (MOTOR MANUFACTURER) 3. SUB-VENDOR (RAW MATERIAL/COMPONENTS SUPPLIER) P. PERFORM W. WITNESS V. VERIFY											
BHEL		PARTICULARS		BIDDER/VENDOR							
		NAME									
		SIGNATURE									
		DATE									
										BIDDER'S/VENDORS COMPANY SEAL	



**TECHNICAL SPECIFICATION FOR**  
**ELECTRIC HOIST**  
**4X270 MW BHADRADRI TPS-FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME - IIB

DATE 26.12.2022

SECTION - I

SUB-SECTION - IC

REV 00

DATE JULY 2020

**SUB-SECTION - IC**  
**DATA SHEET-A**



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS-FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME - IIB

DATE 26.12.2022

SECTION - I

SUB-SECTION - IC

REV 00

DATE JULY 2020

**A.0.0 TECHNICAL DATA SHEET OF ELECTRIC HOIST**

Sl.no	DESCRIPTION	TECHNICAL PARTICULARS
1.0	Type	Steel wire electric hoist with electrically operated trolley
2.0	Scope (Qty., Capacity, Lift, Travel Length)	As per Annexure A, sec I, Vol-IIB
3.0	Type of service	Indoor
4.0	Overload test	125% of SWL
5.0	Design Ambient temperature	50° C
6.0	General Design	As per IS: 3938 / 1983 or latest
6.1	Design standards	IS: 3938, IS: 2266, IS: 4029, IS: 900, IS: 4237, IS: 694, IS: 3043, IS: 1822, IS: 2147, IS: 1554, IS: 325, IS: 15660, IS 9968 Part I etc as per latest revision
6.2	Duty class	Class II duty
7.0	Operating speed	
7.1	Hoisting speed	3 MPM.
7.2	Trolley speed	15 MPM
8.0	Type of transmission	Through Electric motor and gear box.
9.0	Wire Rope	
9.1	Construction / core	6 X 36/ 6X37 Steel core
9.2	Code	IS:2266
9.3	Number of falls	Min. 4
9.4	Factor of safety	5
10.0	Load Hook and block	NORMALISED HOOK ONLY
10.1	Type of load hook	Plain shank trapezoidal section with safety latch.
10.2	Load hook Code	IS: 15560
10.3	Load hook Material	As per IS:15560
10.4	Hook suspension	Thrust bearing
10.5	Material of block suspension	Fabricated from steel plate, Material: IS: 2062
11.0	Gearing	
11.1	Type	Spur / Helical
11.2	Gear/ pinion material	as per IS 3938
11.3	Lubrication	Oil splash/ grease lubricated
11.4	Bearing type	Antifriction Ball / Roller
12.0	Trolley drive	



**TECHNICAL SPECIFICATION FOR**  
**ELECTRIC HOIST**  
**4X270 MW BHADRADRI TPS-FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME - IIB

DATE 26.12.2022

SECTION - I

SUB-SECTION - IC

REV 00

DATE JULY 2020

12.1	Wheel	Single flange taper thread
12.2	Wheel conform to (Std. / code)	IS: 3938
12.3	Wheel material	C55Mn75/ En-8/ En-9/ As per IS 3938. (Max hardness 200 BHN)
12.4	Bearing type	Antifriction Ball / Roller
12.5	Trolley type	Rolled structural steel with side plates extended beyond wheel flanges to protect wheels.
12.6	Hardness	Max hardness 200 BHN
13.0	SHEAVE	
13.1	Material	Fabricated from steel plate. IS: 2062 Gr. A or Gr. B / as per IS: 3938
13.2	Bearing type	Antifriction Ball / Roller.
14.0	BRAKE (HOIST and TROLLEY)	
14.1	Type	DC EM brakes disc type (fail to safety).
14.2	Capacity	150 % of FLT for hoisting, 125% of FLT for travel
14.3	Number	One number for each motor.
15.0	ROPE DRUM	As per IS 3938
15.1	Material	Seamless steel pipe. ASTM A106 / A53 grade B
15.3	Type of groove	Right hand groove or Right hand and left hand groove. (Shall be decided during detail engineering)
17.0	TYPE OF DSL (Travel)	PVC Shrouded bus bar (GI) conductor type DSL
16.0	<b>Buffer stop/wheel stop</b>	Buffer shall be provide at the end of monorail beam
18.0	MOTORS	
18.1	Type	Sq. Cage induction, TEFC, S4 duty, 40% CDF.
18.2	Number of start	150 starts / hr
18.3	Voltage, Phase and Frequency	415V + 10%, 3 phase, 4 wire, 50 Hz, ± 5 %
18.4	Class of insulation	Class "F" and temperature rise limited to class B.
18.5	Type of enclosure	TEFC
18.6	Degree of protection provided for enclosure	IP-54/IP-55 depending upon Indoor / Outdoor application
18.7	Margin	Motor rating will be calculated keeping margin of at least 15% over the maximum power requirement in the duty condition specified.
19.0	LIMIT SWITCHES	Hoisting <span style="float: right;">Trolley</span>



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS-FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME - IIB

DATE 26.12.2022

SECTION - I

SUB-SECTION - IC

REV 00

DATE JULY 2020

19.1	Type	Snap action, self actuating type	Lever type
20.0	Control panel	<ul style="list-style-type: none"> <li>* Fabricated from Cold rolled sheet steel not less than 2.5mm for front &amp; rear &amp; 2mm for side, top &amp; bottom portion with gland plate of 3mm thick.</li> <li>* Degree of protection shall be IP 54.</li> <li>* Power on indicating lamps shall be provided</li> <li>* Panel illumination lamps operated by door switch.</li> <li>* 2 nos earthing terminals on panel.</li> <li>* 20 % spares terminals (clip on type) shall be provided.</li> <li>* Power and control terminals (clip on type) shall be on separate channels.</li> <li>* Gland plate shall be double brass compression type.</li> </ul>	
20.1	Qty	1 No.	
21.0	Pendent Push buttons	Up /down / forward / Reverse push buttons. Indicative marking for easy operation shall be provided.	
22.0	<b>Emergency stop push button</b>	Provided. ( Mushroom head)	
23.0	Power cables	FRLS / EPR flexible Cu cable / Aluminum cable	
24.0	Control cable	FRLS / EPR flexible Cu cable	
25.0	Flexible trailing cable	FRLS / EPR flexible Cu cable / Aluminum cable	
26.0	Control Voltage	110 V (shall be derived through suitably rated 415/110V control transformer.)	

PEM-6666-0



**TECHNICAL SPECIFICATION FOR**  
**ELECTRIC HOIST**  
**4X270 MW BHADRADRI TPS -FGD**

SPECIFICATION NO. PE-TS-440-563-A002	
VOLUME II - B	DATE 26.12.2022
SECTION -I	
REV 00	DATE JULY 2020

**ANNEXURES**

- #
- #
- #
- #
- #
- #
- #
- #



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS -FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME II - B

DATE 26.12.2022

SECTION - I

REV 00

DATE JULY 2020

**ANNEXURE-I  
MAKES OF SUB VENDORS ITEMS**

SR. NO.	ITEM	SUPPLIERS	PLACE	REMARKS
1.	STEEL	SAIL		
		TISCO		
		JINDAL		
		ESSAR		
2.	HOOKS	STEEL FORGING & ENGG. CO.,	KOLKATA	
		SIMRITI FORGING		
		KARACHIWALA		UP TO 25T CAPACITY
3.	GEAR COUPLINGS	ALLIANCE		
		FLEX-TRANS (formerly known as HICLIFF)		
		SAHARA		
		NUTECH		
		OEM		
4.	WIRE ROPE	USHA MARTIN		
		FORT WILLIAMS		
		BHARAT WIRE ROPES		
5.	BEARINGS	SKF		
		FAG		
		TATA		
		NBC		
6.	MOTORS	SIEMENS		
		NGEF (up to 15KW)		
		CROMPTON		
		KIRLOSKAR		
		BHARAT BIJLI		
		MARATHON		
		ABB		
LHP				
7.	BRAKES	ELECTROMAG		
		SPEED-O- CONTROL		
		BCH		FOR DCEM BRAKES ONLY
		KAKKU		
		PETHE		
8.	CONTACTOR	SIEMENS		
		L&T		
		SCHNEIDER (Earlier TELE MECHANIQUE)		
		BCH		
9.	OVER LOAD RELAYS	SIEMENS		
		L&T		



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS -FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME II - B

DATE 26.12.2022

SECTION - I

REV 00

DATE JULY 2020

SR. NO.	ITEM	SUPPLIERS	PLACE	REMARKS
		ABB		
		SCHNEIDER (Earlier TELE MACHANIQUE)		
10.	HRC FUSES	SIEMENS		
		L&T		
		ENGLISH ELECTRIC		
		GE POWER		
		EATON (BUSSMANN)		
		ABB		
11.	ISOLATING SWITCH	SIEMENS		
		L&T		
		CONTROL & SWITCH GEAR		
		ABB		
12.	SWITCH FUSE UNITS	SIEMENS		
		L&T		
		CONTROL & SWITCH GEAR		
		ABB		
13.	TIME DELAY RELAYS	SIEMENS		
		L&T		
		ABB		
		BCH		
		SCHNEIDER (Earlier TELE MACHANIQUE )		
14.	TRANSFORMERS	INDCOIL		
		LOGICSTAT		
		KAPPA		
		AUTOMATIC ELECTRIC		
		PRECISE ELECTRICALS		
		SILKAAN ELECTRIC MFG. CO. LTD.		
		SOUTHERN ELECTRIC		
		NEC		
15.	CABLE LUGS (HEAVY DUTY)	DOWELLS		
		UML ENGINEERS	KOLKATA	
		JAINSON		
16.	PVC POWER CABLES	APAR INDUSTRIES LTD.	MUMBAI	
		CORDS CABLE INDUSTRIES LTD.	NEW DELHI	
		DIAMOND POWER INFRASTRUCTURE LTD	VADODARA	
		GOYOLENE FIBRES (INDIA) PVT.LTD	MUMBAI	
		GOVIND CABLE INDUSTRIES	KOLKATA	
		GUPTA POWER INFRASTRUCTURE LIMITED	BHUBNESWAR	



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS -FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME II - B

DATE 26.12.2022

SECTION - I

REV 00

DATE JULY 2020

SR. NO.	ITEM	SUPPLIERS	PLACE	REMARKS
		HAVELLS INDIA LIMITED	NOIDA	
		KEI INDUSTRIES LTD.	NEW DELHI	
		KRISHNA ELECTRICAL INDUSTRIES LTD	GWALIOR	
		KEC INTERNATIONAL LIMITED	MUMBAI	
		MANSFIELD CABLES COMPANY LTD.	NOIDA	
		NICCO CORPORATION LTD.	KOLKATA	
		PARAMOUNT COMMUNICATIONS LTD.	NEW DELHI	
		POLYCAB WIRES PVT. LTD.	MUMBAI	
		RADIANT CORPORATION PRIVATE LIMITED	HYDERABAD	
		RAVIN CABLES LIMITED	MUMBAI	
		SUYOG ELECTRICALS LTD.	VADODARA	
		SRIRAM CABLES PVT. LTD.	NEW DELHI	
		SCOT INNOVATION WIRES AND CABLES PVT. LTD.	SOLAN	
		SAM CABLES & CONDUCTORS (P) LTD	UDHAM SINGH NAGAR	
		THERMO CABLES LTD	HYDERABAD	
17.	PVC CONTROL CABLES	ADVANCE CABLE TECHNOLOGIES (P) LTD	BANGALORE	
		APAR INDUSTRIES LTD., CMI LTD	MUMBAI	
		CMI LIMITED	FARIDABAD	
		CORDS CABLE INDUSTRIES LTD	NEW DELHI	
		CRYSTAL CABLE INDUSTRIES LTD	KOLKATA	
		DELTON CABLES LTD	NEW DELHI	
		DIAMOND POWER INFRASTRUCTURE LTD	VADODARA	
		ELKAY TELELINKS LTD	NEW DELHI	
		GEMSCAB INDUSTRIES LTD	NEW DELHI	
		GOVIND CABLE INDUSTRIES	KOLKATA	
		GUPTA POWER INFRASTRUCTURE LIMITED	BHUBNESWAR	
		HAVELLS INDIA LIMITED	NOIDA	
		INCOM CABLES (P) LTD	NEW DELHI	
		KEI INDUSTRIES LTD	NEW DELHI	
		KRISHNA ELECTRICAL INDUSTRIES LTD	GWALIOR	
		KEC INTERNATIONAL LIMITED	MUMBAI	



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS -FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME II - B

DATE 26.12.2022

SECTION - I

REV 00

DATE JULY 2020

SR. NO.	ITEM	SUPPLIERS	PLACE	REMARKS
		MANSFIELD CABLES COMPANY LTD	NOIDA	
		NICCO CORPORATION LTD	KOLKATA	
		PARAMOUNT COMMUNICATIONS LTD	NEW DELHI	
		POLYCAB WIRES PVT. LTD	MUMBAI	
		RAVIN CABLES LIMITED	MUMBAI	
		SUYOG ELECTRICALS LTD	VADODARA	
		SPECIAL CABLES PVT. LTD	NEW DELHI	
		SCOT INNOVATION WIRES AND CABLES PVT. LTD	SOLAN	
		SAM CABLES & CONDUCTORS (P) LTD	UDHAM SINGH NAGAR	
		SPM POWER & TELECOM PVT. LTD	HYDERABAD	
		TORRENT CABLES LTD	AHMEDABAD	
		THERMO CABLES LTD	HYDERABAD	
		TIRUPATI PLASTOMATICS PVT. LTD	JAIPUR	
		UNIVERSAL CABLES LTD	SATNA	
18.	TRAILING CABLES	NICCO	KOLKATA	
		UNIVERSAL	SATNA	
		INCAB		
		ICL	NEW DELHI	
		APAR INDUSTRIES LTD	MUMBAI	
		CMI LTD	FARIDABAD	
		KEI INDUSTRIES LTD	NEW DELHI	
		SUYOG ELECTRICALS LTD	VADODARA	
19.	XLPE POWER CABLES	APAR INDUSTRIES LTD	MUMBAI	
		CORDS CABLE INDUSTRIES LTD	NEW DELHI	
		CRYSTAL CABLE INDUSTRIES LTD	KOLKATA	
		DIAMOND POWER INFRASTRUCTURE LTD	VADODARA	
		GEMSCAB INDUSTRIES LTD	NEW DELHI	
		GOVIND CABLE INDUSTRIES	KOLKATA	
		GUPTA POWER INFRASTRUCTURE LIMITED	BHUBNESWAR	
		HAVELLS INDIA LIMITED	NOIDA	
		KEI INDUSTRIES LTD	NEW DELHI	
		KRISHNA ELECTRICAL INDUSTRIES LTD	GWALIOR	
		KEC INTERNATIONAL LIMITED	MUMBAI	
		MANSFIELD CABLES	NOIDA	



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS -FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME II - B

DATE 26.12.2022

SECTION - I

REV 00

DATE JULY 2020

SR. NO.	ITEM	SUPPLIERS	PLACE	REMARKS
		COMPANY LTD		
		PARAMOUNT COMMUNICATIONS LTD	NEW DELHI	
		POLYCAB WIRES PVT. LTD	MUMBAI	
		RAVIN CABLES LIMITED	MUMBAI	
		SUYOG ELECTRICALS LTD	VADODARA	
		SPECIAL CABLES PVT. LTD	NEW DELHI	
		SCOT INNOVATION WIRES AND CABLES PVT. LTD	SOLAN	
		SRIRAM CABLES PVT. LTD	NEW DELHI	
		TORRENT CABLES LTD	AHMEDABAD	
		THERMO CABLES LTD	HYDERABAD	
		TIRUPATI PLASTOMATICS PVT. LTD	JAIPUR	
20.	XLPE CONTROL CABLES	APAR INDUSTRIES LTD	MUMBAI	
		CABLE CORPORATION OF INDIA LTD	MUMBAI	
		CRYSTAL CABLE INDUSTRIES LTD	KOLKATA	
		DIAMOND POWER INFRASTRUCTURE LTD	VADODARA	
		GEMSCAB INDUSTRIES LTD	NEW DELHI	
		HAVELLS INDIA LIMITED	NOIDA	
		KEI INDUSTRIES LTD	NEW DELHI	
		KRISHNA ELECTRICAL INDUSTRIES LTD	GWALIOR	
		KEC INTERNATIONAL LIMITED	MUMBAI	
		PARAMOUNT COMMUNICATIONS LTD	NEW DELHI	
		POLYCAB WIRES PVT. LTD	MUMBAI	
		RADIANT CORPORATION PRIVATE LIMITED	HYDERABAD	
		RAVIN CABLES LIMITED	MUMBAI	
		SUYOG ELECTRICALS LTD	VADODARA	
		SRIRAM CABLES PVT. LTD	NEW DELHI	
		TORRENT CABLES LTD	AHMEDABAD	
		UNIVERSAL CABLES LTD	SATNA	
21.	CABLE GLAND	COMMET		
		SUNIL&CO		
		ARUP ENGINEERING		
		JAINSON		
		DOWELL		
22.	PUSH BUTTONS	SIEMENS		
		L&T		
		BCH		



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS -FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME II - B

DATE 26.12.2022

SECTION - I

REV 00

DATE JULY 2020

SR. NO.	ITEM	SUPPLIERS	PLACE	REMARKS
		SCHNEIDER		
23.	LIMIT SWITCHES	SPEED-O-CONTROL ELECTROMAG		
24.	PENDENT PUSH BUTTON STATION	OEM		
25.	INDICATING LAMPS	TECKNIC BCH SIEMENS STANDARD		
26.	MCB	MDS INDO COPP STANDARD SIEMENS L&T ABB SCHNEIDER		
27.	PANELS	OEM RITTAL PYROTECH		
28.	RESISTANCE BOXES	ENAPROS OEM SAFEX FIRE SERVICES LTD UNITED FIRE EQUIPMENTS PVT. LTD ZENITH FIRE SERVICES (INDIA) PVT LTD		
29.	VVVF	YASKAWA ABB SIEMENS SCHNIEDER FUJI ELECTRIC MITSUBISHI ELECTRIC CG POWER & INDUSTRIAL SOLUTIONS LTD		
30.	SHROUDED DSL	SUSHEEL STROMAG		
31.	LOAD CELL	IPA SARTORIUS		
32.	GEAR BOX	OEM ELECON ENGINEERS SHANTI GEARS PBL* NAW* NORD* SEW*		* = Applicable for Geared Motors only



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS -FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME II - B

DATE 26.12.2022

SECTION -I

REV 00

DATE JULY 2020

SR. NO.	ITEM	SUPPLIERS	PLACE	REMARKS
		BONGFILIOLI*		

**Note:**

1. MAKE IS INDICATIVE, SUBJECT TO CUSTOMER'S / CONSULTANT APPROVAL DURING DETAIL ENGINEERING. ACCEPTANCE/NON ACCEPTANCE OF SAME SHALL NOT HAVE ANY IMPACT ON MANUFACTURING, DELIVERY SCHEDULE AND ON COST OF THE ELECTRIC HOIST.
2. THE INSPECTION CATEGORY WILL BE INTIMATED AFTER AWARD OF CONTRACT BY BHEL/CUSTOMER. HOWEVER, THE SAME WILL BE ADHERED BY THE BIDDER WITHOUT ANY COMMERCIAL AND DELIVERY IMPLICATION TO BHEL/ CUSTOMER.



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS -FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME II - B

DATE 26.12.2022

SECTION - I

REV 00

DATE JULY 2020

**ANNEXURE –II**

**MANDATORY SPARES FOR ELECTRIC HOIST**

1.1	Bearings for travel wheels	4 set
1.2	Bearings for gear boxes for each type of hoist	4 set
1.3	Break liners for all the brakes	200% of total population of each type & size
1.4	Oil seals	200% of total population of each type, size rating
1.5	Brake springs for all brakes	200% of total population of each type, size rating
1.6	Wire ropes for hooks	200% installed on each crane and hoist
1.7	Solenoid coils for brakes	4 set
1.8	Overload relay for motors	4 Nos.
1.9	Limit switches for hoists and travel mechanisms	4 set
1.10	(i) Spare motors for hoist motion	2 Nos.
	(ii) Spare motors for travel motion	2 Nos.
1.11	Travel machinery	
	i. Gear wheel	2 set
	ii. Internal clip	4 Nos.
	iii. Pinion	2 No.
2	Electrical Items	
2.1	415 Volt Motor (Upto 30 KW Rating)	
a	Driving End & Non-Driving End Bearing	4 Set for each type and rating of Motor
b	Cooling Fan	4 Nos. for each type and rating of Motor
c	Motor Terminal Block	10 Nos. for each type and rating of Motor
d	Complete Set of Coupling	2 Set of each application
3	C&I Items	
a	Back-up panel mounted devices (Selector switches/ Push buttons/ Indicators etc.	10% of installed capacity
b	Lamps/ LEDs	200% of the total quantity
c	Blank Tiles	20% of installed capacity
d	MCBs	20% of each type & rating
e	Fuses/ Fuse holder	200% of each type & rating

- a. "One (1) set of each type & size" is defined as 100% requirement for one hoist.  
b. 200% of total population of each type, size and rating is defined as 200% requirement for one hoist.

**NOTES**

- 1 Set for the particular equipment, would include all components required to replace the item, for example a set of bearing shall include all hardware normally required while replacing the bearings. It is further, intended that the assembly / sub-assembly which have different orientation (like left hand or right hand, top or bottom), different direction of rotation or mirror image positioning or any other



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS -FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME II - B

DATE 26.12.2022

SECTION -I

REV 00

DATE JULY 2020

reasons which result in maintaining two different sets of the spares to be used for the subject assembly / sub-assembly, these shall be considered as different types of assembly/sub-assembly. One (1) set means 100% requirement for one crane.

- 2 Wherever the quantities have been indicated for each type, size, thickness, material, radius, range etc. these shall cover all the items supplied and installed.
- 3 In case spares indicated in the list are not applicable to the particular design offered by the bidder, the bidder should offer spares applicable to offered design with quantities generally in line with the approach followed in the above list.
- 4 Any item which is quoted as “not applicable” in the above list and is found to be “applicable” at a later date shall be supplied by the Bidder without any commercial implications. The Bidder shall note that if there is any change/ variation in equipment/ system during detail engineering which causes any change/ variation in the essential spares quantity, the same shall be supplied without any commercial implications. The price indicated for the mandatory spares shall be considered for the purpose of evaluation.
- 5 Mandatory spares shall not be dispatched before dispatch of corresponding main equipment. The spares shall be treated and packed for a long storage under the climatic condition prevailing at site.
- 6 **Interchangeability and Packings:**  
All spares supplied under this contract shall be strictly interchangeable with parts for which they are intended for replacements. These spares should include all mounted accessories like components, boards, add on items, fitting, connectors etc. and be complete in all respects so that the replacement of the main items by these spares does not require any additional item. The vendors must conform to the pair to pair compatibility of each electrical spares modules with the modules should be supplied in the original package. All electronic modules should be pre-set and/or preprogrammed for ready use at site. Alternatively, suitable instruction sheet indicating the details of required PCB jumper position, BCD which is setting, EPROM/PROM listing etc. should be packed along with each module. Also a caution mark sign should be put on all such module which needs pre-setting/pre-programming before putting them in to service. The spare shall be treated and properly packed for long term storage.
- 7 **Identification:**  
Each spare shall be clearly marked and labeled on the outside of the packing with its description. When more than one spare part is packed in single case, a general description of the contents shall be shown on the outside of such case and a detailed list enclosed. All cases, containers and other packages must be suitably marked and numbered for the purpose of identification.
- 8 Mandatory spares listed above is bare minimum requirement. In case any additional mandatory spares requirement is covered elsewhere in the tender specification, same shall be deemed to have been covered in bidder's scope of supply.



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS -FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME II - B

DATE 26.12.2022

SECTION -I

REV 00

DATE JULY 2020

**ANNEXURE-III  
PAINTING SPECIFICATION**

**A) Structural**

**Surface preparation** : De greasing and Mechanical cleaning with wire brush or hand tool. (SA 1/ ST 2 / ST 3 as applicable)

**Primer** : Red oxide Zinc phosphate (Alkyd medium)- 2 coat , DFT 35  $\mu$  per coat.

**Finish Coat** : Synthetic enamel (Alkyd medium) as per IS: 2932- 2 coats, DFT 35  $\mu$  per coat.

**Total DFT** : 140 $\mu$

**B) Electrical /Control Panel**

**Surface preparation**: Seven tank process

**Primer** : Red Oxide Zinc phosphate (Alkyd medium)- 2 coat , Minimum DFT 35  $\mu$  per coat.

**Finish Coat** : Synthetic enamel (Alkyd medium) as per IS: 2932- 2 coats, Minimum DFT 35  $\mu$  per coat.

**Total DFT** : 140  $\mu$

**COLOR SHADE FOR CRANE**

S. No	Item Description	Color Shade	Remarks
1	Structure	Golden yellow, shade 356 as per IS-5	
2	Bottom block assembly	Golden yellow, shade 356 as per IS-5	With black strip
3	Hooks	Golden yellow, shade 356 as per IS-5	With 100 mm wide black zebra strip
4	Panels and motors	Color shade for Control panels shall be Opaline green for exterior and semi glossy white for interior	

**Notes:**

- Surface preparation shown above is as per Swedish Standards SIS 05-5900. Degreasing will be as per Standard SSPC-SP1.
- In case of insulated surfaces, only primer coats shall be applied.
- Gun metal/SS items with piping and G.I. pipes will not be painted. Further SS/GI piping shall be given necessary colour banding for identification as per colour scheme.
- All instruments shall be painted as per manufacturer standard practice.
- All structural steel items shall be painted at site. Piping shall go with primer coating & finish paint shall be applied at site. Equipment shall be finish painted at shop.
- Method of painting application shall be as per paint manufacturer's recommendation.
- Paint makes - Asian Paints/Berger Paints/Shalimar Paints/Goodlass Nerolac/Addison Paints/Grand Paints/Bombay Paints/Jenson & Nicholson/CDC Carboline/Jotun/Hemple/Akzonoble



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS -FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME II - B

DATE 26.12.2022

SECTION -I

REV 00

DATE JULY 2020

**ANNEXURE IV- INSPECTION AND TESTING REQUIREMENT**

**Procedure for Load/Overload testing of Electric wire rope hoist at Manufacturer's Works**

Objective: To demonstrate final No load, Load, Overload, Deflection & Functional tests of assembled hoist for the purpose of acceptance in line with IS 3938 and other relevant standards.

**Basic Assumptions / Inputs for testing at Works:**

- 1) Actual job hook shall be used for load, overload tests for hoisting.
- 2) Actual wire ropes shall be used for load, overload testing.
- 3) Shop cables can be used for temporary power supply for the purpose of showing various functional tests at shop.
- 4) Interlock and limit switch operation check will be shown for hoisting and CT motion.

**Procedure for Load / Overload testing:** Complete procedure shall be as per IS 3938.

- 1) All electrical and mechanical equipment shall be tested in accordance with the appropriate Indian Standards at the hoist or equipment maker's works.
- 2) The motor currents shall be checked and shall be within the rated full load current of each motor at safe working load. Normal speeds shall be achieved during full load tests.
- 3) The hoist shall be tested at manufacturer's works at 125 percent of the safe working load. The hoist shall be capable of lifting load from mid-air.
- 4) Brakes -The brakes shall be capable of holding a load 25 percent in excess of maximum safe working load when the load is suspended by the hook.
- 5) Safety device - Test for the effectiveness of the automatic device to limit the upward and downward travel of the hook.
- 6) Any test required by the purchaser beyond those called for in the appropriate Indian Standard shall be carried out.
- 7) Insulation Tests - Before the hoist is connected to the supply, the insulation of the electrical equipment shall be tested by a suitable instrument and any defect revealed shall be rectified.
- 8) All hoists performance test shall be duly certified by government approved agency.



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS -FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME II - B

DATE 26.12.2022

SECTION -I

REV 00

DATE JULY 2020

**ANNEXURE-V**

**A: DRAWINGS/ DOCUMENTS TO BE SUBMITTED AFTER AWARD OF CONTRACT**

The successful bidder shall submit the following drawings / documents during detail engineering for customer's approval /information:

Sl. No.	BHEL DRG.NO	DRAWING TITLE	Primary/ Secondary	SUBMISSION SCHEDULE
1	PE-V1-440-563-A201	Manufacturing Quality Plan with Sub vendor list	Primary	R-0 WITHIN 21 DAYS FROM PO & SUBSEQUENT REVISIONS WITHIN 10 DAYS OF COMMNETS RECEIVED FROM BHEL. BHEL SHALL FURNISH COMMENTS/ APPROVAL ON EACH SUBMISSION WITHIN 18 DAYS FROM RECEIPT
2	PE-V1-440-563-A202	GA Drawing for Electric Hoist, DSL arrangement and painting details	Primary	
3	PE-V1-440-563-A210	Mechanism Sizing Calculation	Primary	
4	PE-V0-440-563-A219	Schematic Circuit Diagram including cable schedule and panel diagram	Primary	
5	PE-V1-440-563-A208	Erection procedure	Secondary	R-0 WITHIN 30 DAYS FROM PO & SUBSEQUENT REVISIONS WITHIN 10 DAYS OF COMMNETS RECEIVED FROM BHEL. BHEL SHALL FURNISH COMMENTS/ APPROVAL ON EACH SUBMISSION WITHIN 18 DAYS FROM RECEIPT
6	PE-V1-440-563-A207	Mandatory spare parts list	Secondary	
7	PE-V1-440-563-A218	Detailed BOM/BOQ for electric hoist	Secondary	
8	PE-V1-440-563-A206	O & M Manual	Secondary	Within 30 days of issuance of MDCC

Note: INCOMPLETE DRAWINGS/DOCUMENTS SHALL NOT BE TREATED AS SUBMITTED.



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS -FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME II - B

DATE 26.12.2022

SECTION - I

REV 00

DATE JULY 2020

**ANNEXURE -VI**

**Check List for Operation & Maintenance Manual**

0Project name :  
 1Project number :  
 2Package Name :  
 3PO reference :  
 4Document number :  
 5Revision number :

Sl.no. & Sections	Description	Tick ( √ )if included in Manual			Remarks
		Yes	No	Not Applicable	
<b>1.</b>	<b>Cover page</b>				
<b>1.1</b>	Project Name				
<b>1.2</b>	Customer/consultant Name				
<b>1.3</b>	Name of Package				
<b>1.4</b>	Supplier details with phone, FAX ,email address , Emergency Contact number				
<b>1.5</b>	Name and sign of prepared by , checked by & approved by				
<b>1.6</b>	Revision history with approval Details				
<b>2.0</b>	<b>Index</b>				
<b>2.1</b>	showing the sections & related page nos All the pages should be numbered section wise				
<b>3.0</b>	<b>Description of Plant/System</b>				
<b>3.1</b>	Description /write up of operating principle of system equipment/ associated sub-systems & accessories/controls system , operating conditions, performance parameters under normal , start up and special cases				
<b>3.2</b>	Equipment list and basic parameter with Tag numbers				
<b>3.3</b>	Data sheets approved by Customer/for information and catalogues provided by original manufacturer				
<b>3.4</b>	Associated other packages and Interface /terminal points				
<b>3.5</b>	P&ID & Process Diagrams				
<b>3.6</b>	GA Layout drawings, As-built drawings , Actual photograph of items/system (Drawings of A2 & bigger sizes are to be attached in the last)				
<b>3.7</b>	Single line/wiring diagrams				
<b>3.8</b>	Control philosophy /control write-ups				
<b>4.0</b>	<b>Commissioning Activities (if not covered in separate document i.e. erection manual, commissioning manual)</b>				
<b>4.1</b>	Pre-Commissioning Checks				



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS -FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME II - B

DATE 26.12.2022

SECTION - I

REV 00

DATE JULY 2020

4.2	handling of items at site				
4.3	Storage at site				
4.4	Unpacking & Installation procedure				
5.0	<b>Operation Guidelines for plant personal/user/operator</b>				
5.1	Interlock & Protection logic along with the limiting values of protection settings for the equipment along with brief philosophy behind the logic, drawings etc. to be provided.				
5.2	Start up, normal operation and shut down procedure for equipments along with the associated systems in step by step mode. Valve sequence chart, step list, interlocks etc. with Equipment isolating procedures to be mentioned.				
5.3	Do's & Don't of the equipments.				
5.4	Safety precautions to be taken during normal operation. Safety symbols, Emergency instructions on total power failure condition/lubrication failure/any other condition				
5.5	Parameters to be monitored with normal values and limiting values				
5.6	Trouble shooting with causes and remedial measures				
5.7	Routine operational checks, recommended logs & records				
5.8	Changeover schedule if more than one auxiliary for the same purpose is given				
5.9	Painting requirement and schedule				
5.10	Inspection, repair , Testing and calibration procedures				
6.0	<b>Maintenance guidelines for plant personal</b>				
6.1	List of Special Tools and Tackles required for Overhaul/Trouble shooting including special testing equipment required for calibration etc.				
6.2	Stepwise dismantling and re-assembly procedure clearly specifying the tools to be used, checks to be made, records to be maintained, clearances etc. to be mentioned. Tolerances for fitment of various components to be given.				
6.3	Preventive Maintenance & Overhauling schedules linked with running hours/calendar period along with checks to be given				
6.4	Long term maintenance schedules especially for structural, foundations etc.				
6.5	Consumable list along with the estimated quantity required during commissioning,				



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS -FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME II - B

DATE 26.12.2022

SECTION -I

REV 00

DATE JULY 2020

	normal running and during maintenance like Preventive Maintenances and Overhaul. Storage/handling requirement of consumables/self-life.				
<b>6.6</b>	List of lubricants with their Indian equivalent, Lubrication Schedule, Quantity required for each equipment for complete replacement is to be given				
<b>6.7</b>	List of vendors & Sub-vendors with their latest addresses, service centres ,Telephone Nos., Fax Nos., Mobile Nos., e-mail IDs etc.				
<b>6.8</b>	List of mandatory and recommended spare parts list				
<b>6.9</b>	Tentative Lead time required for ordering of spares from the equipment supplier				
<b>6.10</b>	Guarantee and warranty clauses				
<b>7.0</b>	<b>Statutory and other specific requirements considerations.</b>				
<b>8.0</b>	<b>List of reference documents</b>				
<b>9.0</b>	<b>Binding as per requirement</b>				

Checked by  
Dealing Engineer

Key Resource Person

Section Head



**TECHNICAL SPECIFICATION FOR**  
**ELECTRIC HOIST**  
**4X270 MW BHADRADRI TPS**

SPECIFICATION NO. PE-TS-440-563-A201

VOLUME - IIB

DATE 26.12.2022

SECTION - II

SUB-SECTION - IIA

REV 00

DATE JULY 2020

**SUB-SECTION - IIA**  
**STANDARD TECHNICAL REQUIREMENT**  
**(MECHANICAL)**



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS**

SPECIFICATION NO. PE-TS-440-563-A201

VOLUME - IIB

DATE 26.12.2022

SECTION - II

SUB-SECTION - IIA

REV 00

DATE JULY 2020

### **STANDARD TECHNICAL SPECIFICATION**

This specification covers the design, engineering, manufacture, inspection and testing at manufacturer's works, properly packed and delivery to site for the steel wire rope electric hoist as specified in the Data Sheet A enclosed. The equipment specified shall include all accessories required for trouble free operation.

#### **2.0.0 Design Particulars**

The steel wire rope electric hoist covered in this specification shall be suitable for the lift as specified in Annexure- A, Sec I, Vol IIB. Equipment offered shall be conforming to specification requirements as per IS: 3938 (latest edition) and other specified Indian Standards.

#### **3.0.0 Technical Particulars**

**3.1.0 Type** - Electrically operated with trolley.

#### **3.2.0 Applicable IS**

#### **DESCRIPTION**

IS: 3938	Specification for electrical wire rope hoist
IS: 2266	Specification for steel wire ropes for general engineering purposes.
IS: 900	Code of practice for installation and maintenance of induction motor
IS: 4237	General requirement of switchgear and control gear for voltage motor exceeding 1000 Volts.
IS: 694	Copper conductors PVC insulated cables for voltage up to 1000 Volts
IS: 3043	Code of practice for Earthing.
IS: 1822	Motor starters for Voltages up to 650V.
IS: 2147	Degree of protection provided by enclosures for low voltage switch gear and control gear.
IS: 1554	PVC insulated (Heavy-duty) electric cables for working voltages and including 1100 volts.
IS: 325	Three phase induction motors.
IS: 15660	Point hook with shank.
IS 9968 Part I	Flexible trailing cables
IS: 4029	Guide testing induction motor.

#### **4.0.0 Quality Plan & Inspection**

To ensure that the equipment and services are in accordance with the specification, the vendor shall follow/adopt BHEL's STANDARD QUALITY PLAN (enclosed herewith)/Customer approved QAP to control critical activities at all essential points. The enclosed standard quality plan should be duly signed and



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS**

SPECIFICATION NO. PE-TS-440-563-A201

VOLUME - IIB

DATE 26.12.2022

SECTION - II

SUB-SECTION - IIA

REV 00

DATE JULY 2020

stamped as a token of acceptance and submitted by the bidder along with the offer.

Inspection shall be carried out by BHEL/customer representative as the case may be in line with the approved drawing / document.

#### 5.0.0 Name Plate

All the electric hoists shall be provided with individual nameplate indicating minimum the following data's:

Name of manufacturer

Capacity (in tons)

Lift (in meters)

Serial No.

Any other detail as per IS 3938

#### 6.0.0 Painting Procedure

6.1.0 Refer annexure-III, section-I for painting specification & color scheme

6.2.0 All surfaces to be painted shall be thoroughly cleaned of all grease, oil, loose mill scale, dust, rust and any other foreign matter. Mechanical cleaning by power tool and scrapping with steel wire brushes shall be adopted to clear the surfaces.

6.3.0 Machined and bearing surface shall be protected with varnish or thick coat of grease.

#### 7.0.0 GENERAL DESIGN FEATURE

- I. Design shall conform to IS: 3938 (Latest edition) and other standards as specified.
- II. Parts requiring replacement or lubrication shall be easily accessible & without dismantling type.
- III. Equipment shall include the devices as required and comply with applicable standards/specification requirements.
- IV. Defects in material not acceptable/allowed. Rectification of any flaw is permissible only with the approval of Purchaser.
- V. Hoist shall be rigid in construction and all movements shall be smooth and non-jerky.
- VI. Design shall provide for easy maintenance of all parts, particularly the wheel bearings.
- VII. Design shall conform to IS: 3938 and other standards as specified.
- VIII. Both hoists and trolleys are driven electrically. Wheels shall be single flanged type and to suit different monorail beam sizes and the same shall be intimated to purchaser during of manufacturing stage.
- IX. Hook shall be swiveling type and fitted with a safety latch.
- X. Hoists shall be designed for minimum headroom above the highest position of hook and for closest hook approaches.
- XI. Two no end stoppers of MOC IS 2062 and of adequate capacity shall be supplied for each electric hoist.



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS**

SPECIFICATION NO. PE-TS-440-563-A201

VOLUME - IIB

DATE 26.12.2022

SECTION - II

SUB-SECTION - IIA

REV 00

DATE JULY 2020

- XII. Gear Box: Gears shall be completely covered and enclosed in oil tight casing & sealed with gasket. The gearboxes shall be of mild steel or cast steel as per IS 3938. All fabricated gearboxes shall be stress relieved. Gears shall be of cast or forged steel and pinions shall be forged steel and shall be machine cut. Gear and pinion teeth shall be treated for resistance to wear.
- XIII. Bearing: Ball and roller antifriction bearing shall be used throughout, except where specified otherwise. Life of bearing shall be calculated in accordance with manufacturers recommendations. Provision shall be made for service lubrication of all bearings. Bearing enclosures shall be designed as far as possible to exclude dirt and prevent oil leakage.
- XIV. Couplings: Motor shafts shall be connected to gear box input extension shafts through flexible gear coupling.
- XV. Wire ropes: Ropes of steel /fibre core as specified in Data Sheet – A shall be of right hand lay, of 6x36 construction of best plough steel having minimum tensile strength as 160-180 kg/mm<sup>2</sup>. Left hand lay wire ropes shall not be used (Reverse bend ropes shall not be used).

### 8.0.0 ELECTRICAL MOTOR DESIGN

Motor shall be squirrel cage induction type, and suitable for AC supply of 415V, 3 /4 phase, 50 Hz, 40%/60% CDF (as per data sheet-A) with IP—55 degree of protection. Motors shall be class 'F' insulated with temperature rise limited class B & suitable for 150/300 starts per hour (as per data sheet-A). Motors shall conform to IS 325, IS 12615:2011 and IS/IEC 60034-1:2014 as per norms. Motor terminal box shall be provided with suitable earthing stud inside the terminal box. It shall be possible to rotate the terminal box by 90 degrees. Insulation shall be minimum Class F or better insulation materials with additional phase insulating material, extra end-turn bracing and Class H spike resistant wire. Motors shall be capable of a 20 second stall at six times full load current without injurious heating to motor components. The pull out torque of the motor shall not be less than 275 % of the full load torque. All the motors shall be suitable for reversing, frequent starting and braking.

### 9.0.0 Protective Panel / Controls

Heavy duty, electrical panel, direct on reversing type Air brake contactors, electrically interlocked for safety with necessary control gears such as control transformer, MCB (Control and Power), limit switches, thermostat, space heater, neutral link, ON/OFF 3 Phase door interlock switch, wrong connection preventor, overload relays, single phase preventor, indicating lamps, cable glands, lugs, terminals, cables etc. housed in totally enclosed IP- 55 degree of panel. Control voltage shall be 24V/110V. Actual control voltage level shall be informed on project to project basis. Control circuit shall be protected by individual control MCB's with minimum. short ckt. rating 9kA and rating 16A. The electrical protective panel shall be a cubicle fabricated from 2 mm thick sheet steel with lockable-hinged door. It shall be dust and vermin proof with degree of protection as IP-55 or as specified in data sheet A. All the equipment inside the panel



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS**

SPECIFICATION NO. PE-TS-440-563-A201

VOLUME - IIB

DATE 26.12.2022

SECTION - II

SUB-SECTION - IIA

REV 00

DATE JULY 2020

shall have permanent identification. The panels shall be front connected type with front-hinged door for access to wiring and terminals. Engraved nameplate shall be furnished for all panels and also for the equipments and devices mounted there on. The following minimum equipments shall be provided.

- a) One triple pole air break type main contactor with thermal overload relay.
- b) One triple pole main line connecting/disconnecting switch.
- c) Switch fuse unit with D.O.L. starter for each motion.
- d) Thermal overload relay for each drive. It shall be ambient temperature compensated and adjustable type.
- e) Contactors, timer and auxiliary contactors.
- f) Control transformer with fuses.
- g) Indicating lamps to indicate the live condition of all three phases.
- h) Other equipments as per supplier's standard practice. Air break contactors shall conform to category AC-4 duty. The contactor drop off voltage shall be between 45-50% of rated voltage.
- i) All internal wiring shall be identified with numbering ferrules at both ends as per the relevant wiring diagram.

#### **10.0.0 LIMIT SWITCH**

The hoist mechanism of the hoist shall be provided with rotary/gravity/snap action type limit switch to open the control circuit and in order to prevent the hook from over hoisting and over lowering. One gravity type back-up limit switch of hand-reset type shall be provided. This switch shall operate in the event of failure of main limit switch if called for in data sheet "A". Rotary + gravity type hand reset limit switches shall be provided for hoisting. Lever operated limit switches shall be provided for cross traverse. These limit switches shall be self-reset type.

The limit switches shall be housed in robust metallic oil and dust tight enclosure conforming to IP:65. At least 2 NO and 2 NC contacts shall be provided for each limit switch. All limit switch shall confirm to IEC-60947-5-1. Material of contact shall be high grade silver cadmium plated with high conductivity and non-corrosive type.

#### **11.0.0 BRAKE**

The hoist and cross traverse motors are fitted with an DC electro-magnetic disc type brake designed and built to arrest, and hold safely the full load capacity of load. The brakes shall be fail-safe type wherein failure of current immediately applies the brake.

#### **12.0.0 PUSH BUTTON STATION**

Pendent push button station shall be provided with glow type push buttons for hoisting/lowering, cross traverse forward/reverse and emergency stop (mushroom head type) etc. The contactors are operated by



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS**

SPECIFICATION NO. PE-TS-440-563-A201

VOLUME - IIB

DATE 26.12.2022

SECTION - II

SUB-SECTION - IIA

REV 00

DATE JULY 2020

pendent push button station suspended from the hoist for easy operation and suspension is made on steel wire/ link chain. Normally pendent shall be fixed type. Necessary, T track / taut wire arrangement including fixing arrangements such as auxiliary beam, brackets, supporting plates etc. as applicable shall be provided in order to clear the pendent and its cable from auxiliary structure, piping, equipment's etc. Necessary cable glands, lugs, terminals along with connecting cable of 14Core, 1.5sqmm copper flexible cable shall be provided. Emergency stop push button shall be mushroom head (lockable) type. Push buttons shall return to off position when released. It shall be suspended by wire rope to prevent pull on the cables. The following minimum push buttons key operated type.

- a) Main" ON", "OFF" push button key operated and lockable in "OFF" position. This push button will operate the main contactor.
- b) Hoist and lower directions. (2Nos.)
- c) Trolley travels both directions. (2 Nos.)
- d) Inching speed for hoisting & lowering
- e) Inching speed for trolley motion.
- f) Creep speeds ( if applicable)
- h) Emergency stop push button (mushroom type).
- i) Alarm bell push button.

### 13.0.0 EARTHING & GROUNDING

The hoist structure, motor frame and all other electrical equipments shall be grounded in accordance with the Indian Electricity Rules. The connections from hoist to 4th conductor of down shop leads shall be by means of current collector.

The equipment fed by flexible cables shall be grounded by means of fourth core provided in the flexible trailing cable. Pendent push button station shall be earthed separately and independently.

### 14.0.0 POWER SUPPLY TO HOIST:

Purchaser shall provide single point 415V, 3 /4 phase, and 50Hz supply at any point of the bay. Bidder shall provide main isolating switch at 1.5 M above the ground / operating floor level to receive this incoming power. The details of incoming cable shall be provided to the bidder on project to project basis during detail engineering. It shall be bidder's responsibility to supply isolators suitable for the incoming cable. Isolating switch shall be equipped with MCCB with three indicators for phases.

Power feeding to the hoist shall be thru one of the following methods-

- i) Shrouded Bus Bar Conductor Type DSL complete with brackets and other fixing arrangements.
- ii) EPR flexible trailing cable: Trailing cable shall be 1100 V grade, tinned copper, heat resistant, with EPR insulation and as per Class – 5 of IS-8130. Also should have inner PCP sheath and outer CSP sheath with nylon chord reinforcement & heat resistant, oil resistant and flame retardant heavy duty FRLS type



**TECHNICAL SPECIFICATION FOR**  
**ELECTRIC HOIST**  
**4X270 MW BHADRADRI TPS**

SPECIFICATION NO. PE-TS-440-563-A201

VOLUME - IIB

DATE 26.12.2022

SECTION - II

SUB-SECTION - IIA

REV 00

DATE JULY 2020

complete with DSL trolley on T track / taut wire arrangement retractable type including necessary fixing arrangements such as auxiliary beam, brackets, supporting plates, junction box etc.

DSL/Flexible trailing cables shall be sized considering both hoisting, travel motion as well as other auxiliary power requirement. Voltage drop requirement of maximum 3% across the DSL/trailing cable from the incoming supply to motor terminal with hoist at extreme end of travel and with allowance of minimum 20% for wear & tear shall be considered while sizing the conductor along with other factors like derating etc . Calculation for the same be furnished as and when required by purchaser/end customer.

The collector system per conductor shall be spring loaded type metallic shoes to maintain adequate contact pressure.

**15.0.0 WIRING SYSTEM:**

- a) The supplier shall furnish all power, control and auxiliary circuit wiring of the equipment and the panel located on the trolley.
- b) The wiring shall be complete in all respect to ensure the proper functioning of the equipment.
- c) Power wiring to any motor shall be done with 1100V grade Cu conductor, PVC insulated / armoured /FRLS cable of suitable sizes as specified in Data Sheet A.
- d) For selecting the cable rating, cable for power wiring, consideration shall be given to the motor duty, ambient temperature grouping and disposition of the cables voltage drop etc.
- e) All control and auxiliary external circuit wiring shall be done with PVC insulated FRLS type 2.5mm stranded copper conductor.
- f) Armoured cables or un-armoured running through the flexible conduits may be used for power wiring / control and auxiliary circuit wiring shall run through flexible conduits.
- g) Each motor shall be wired independently. Power and control wiring shall be effectively separated.
- h) Each wire shall be identified at both ends with wire designation in accordance with circuit wiring diagram.
- i) All wire termination to the panels shall be provided with clamp type connections screw. Type terminals with screw directly impinging on conductors are not acceptable.
- j) Multi-way terminal blocks complete with screw nut, washer and marking strips shall be furnished for terminating the panel wiring and outgoing.
- k) Not more than two wires shall be connected to any terminal on either side of terminal block. If necessary number of terminals shall be jumped together to provide the wiring points
- l) Each terminal block shall be marked with designation in accordance with conductors wiring diagram.
- m) Adequate short circuit protection shall be provided for main and individual circuits.
- n) All power & control cables shall be tagged at both ends (as per approved drawings) for quick identification. The cables & wiring system for each motion shall be independent & common runs



**TECHNICAL SPECIFICATION FOR**  
**ELECTRIC HOIST**  
**4X270 MW BHADRADRI TPS**

SPECIFICATION NO. PE-TS-440-563-A201

VOLUME - IIB

DATE 26.12.2022

SECTION - II

SUB-SECTION - IIA

REV 00

DATE JULY 2020

shall be avoided. Power cables & control cables shall be effectively separated & all connections shall be terminated to terminal box suitable for outside connections.



**TECHNICAL SPECIFICATION FOR**  
**ELECTRIC HOIST**  
**4X270 MW BHADRADRI TPS-FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME III

DATE 26.12.2022

REV 00

DATE JULY 2020

**VOLUME - III**

#



**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS-FGD**

SPECIFICATION NO. PE-TS-440-563-A002

VOLUME III

DATE 26.12.2022

REV 00

DATE JULY 2020

**LIST OF DRAWINGS / DOCUMENTS TO BE SUBMITTED WITH THE BID**

Bidder shall submit the following drawings / documents along with their bid

- a) Deviation schedule with reference to specific clauses of the specification along with reason for such deviation in the format given in GCC. In case of no deviation, bidder to mention "No deviation" on signed and stamped copy of Deviation sheet.
- b) Copy of pre-bid clarifications, if any, duly signed & stamped
- c) Signed/ Stamped copy of Compliance cum Confirmation Certificate (Vol-III)
- d) Un priced copy of price format indicating quoted/ not quoted against each row/column along with cost of withdrawal / price implication format for deviations.

OFFER WILL BE CONSIDERED AS INCOMPLETE IN ABSENCE OF ANY OF ABOVE DOCUMENTS. DOCUMENT OTHER THAN ABOVE, IF ANY, SUBMITTED WITH THE OFFER WILL NOT FORM PART OF CONTRACT AND ACCORDINGLY WILL NOT BE CONSIDERED FOR BID EVALUATION.



TITLE:  
**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS-FGD**

SPEC. NO.: PE-TS-440-563-A002

VOLUME: III

DATE 26.12.2022

SECTION:

REV. NO. 0

Date: JULY 2020

### **COMPLIANCE CUM CONFIRMATION CERTIFICATE**

The bidder shall confirm compliance with following by signing/ stamping this compliance certificate (every sheet) and furnish same with the offer.

- a) The scope of supply, technical details, construction features, design parameters etc. shall be as per technical specification & there are no exclusions other than those mentioned under "exclusion" and those resolved as per 'Schedule of Deviations', if applicable, with regard to same.
- b) There are no other deviations w.r.t. specifications other than those furnished in the 'Schedule of Deviations'. Any other deviation, stated or implied, taken elsewhere in the offer stands withdrawn unless specifically brought out in the 'Schedule of Deviations'.
- c) Bidder shall submit QP in the event of order based on the guidelines given in the specification & QP enclosed therein. QP will be subject to BHEL/ CUSTOMER approval & customer hold points for inspection/ testing shall be marked in the QP at the contract stage. Inspection/ testing shall be witnessed as per same apart from review of various test certificates/ Inspection records etc. This shall be within the contracted price with no extra implications to BHEL after award of the contract.
- d) All drawings/ data-sheets / calculations etc. submitted along with the offer shall not be taken cognizance
- e) The offered materials shall be either equivalent or superior to those specified in the specification & shall meet the specified / intended duty requirements. In case the material specified in the specifications is not compatible for intended duty requirements then same shall be resolved by the bidder with BHEL during the pre-bid discussions, otherwise BHEL / Customer's decision shall be binding on the bidder whenever the deficiency is pointed out. For components where materials are not specified, same shall be suitable for intended duty, all materials shall be subject to approval in the event of order.
- f) The commissioning spares shall be supplied on 'As Required Basis' & prices for same included in the base price itself.
- g) All sub vendors shall be subject to BHEL / CUSTOMER approval in the event of order.
- h) Guarantee for plant/equipment shall be as per relevant clause of GCC / SCC / Other Commercial Terms & Conditions.
- i) In the event of order, all the material required for completing the job at site shall be supplied by the bidder within the ordered price even if the same are additional to approved billing break up, approved drawing or approved Bill of quantities within the scope of work as tender specification. This clause will apply in case during site commissioning, additional requirements emerges due to customer and / or consultant's comments. No extra claims shall be put on this account
- j) Schedule of drawings submissions, comment incorporations & approval shall be as stipulated in the specifications. The successful bidder shall depute his design personnel to BHEL's / Customer's / Consultant's office for across the table resolution of issues and to get documents approved in the stipulated time.
- k) As built drawings shall be submitted as and when required during the project execution.



TITLE:  
**TECHNICAL SPECIFICATION FOR  
ELECTRIC HOIST  
4X270 MW BHADRADRI TPS-FGD**

SPEC. NO.: PE-TS-440-563-A002

VOLUME: **III**

DATE 26.12.2022

SECTION:

REV. NO. **0**

Date: JULY 2020

- l) The bidder has not tempered with this compliance cum confirmation certificate and if at any stage any tempering in the signed copy of this document is noticed then same shall be treated as breach of contract and suitable actions shall be taken against the bidder.
- m) Successful bidder shall furnish detailed erection manual for each of the equipment supplied under this contract at least 3 months before the scheduled erection of the concerned equipment / component or along with supply of concerned equipment / component whichever is earlier.
- n) Document approval by customer under Approval category or information category shall not absolve the vendor of their contractual obligations of completing the work as per specification requirement. Any deviation from specified requirement shall be reported by the vendor in writing and require written approval. Unless any change in specified requirement has been brought out by the vendor during detail engineering in writing while submitting the document to customer for approval, approved document (with implicit deviation) will not be cited as a reason for not following the specification requirement.
- o) In case vendor submits revised drawing after approval of the corresponding drawing, any delay in approval of revised drawing shall be to vendor's account and shall not be used as a reason for extension in contract completion.

