



 An ISO 9001:2015 Company	INSULATION SYSTEMS ENGINEERING	IN.SK. 46121
	BHEL BHOPAL	Rev. No.: 01
	ADDITIONAL EVALUATION PARAMETERS FOR SEMI CONDUCTING TAPE TO IN. SK. 46089	Rev. Dt.: 25/01/2025
		Page 1 of 4

Semi conducting tape to IN. SK. 46089 is used for End Corona Protection in High Voltage A.C. machine stator coils with VPI technology.

This specification gives the details of evaluation parameters for Semi conducting tape in addition to parameters mentioned in IN. SK. 46089.


Conditions for technical acceptance of the material (In addition to IN. SK. 46089)


The following evaluation is to be conducted only for new vendors / new material grades (non-approved) of existing vendors / type test requirement / trial / development orders.

Distribution:	Date of Rev.00: 13/08/2022	Name	Signature
ISE CIM MDX QFD AME	Prepared by	Abha Otti	
	Checked by	Ankur Goyal	
	Approved by	Bishwanath Oraon	
	Issued by	Anjani Kumar Dubey	

CONFIDENTIAL


The information on this document is the property of Bharat Heavy Electricals Limited, it must not be used directly or indirectly in any way detrimental to the interest of the company


 An ISO 9001:2015 Company	INSULATION SYSTEMS ENGINEERING	IN.SK. 46121
	BHEL BHOPAL	Rev. No.: 01
	ADDITIONAL EVALUATION PARAMETERS FOR SEMI CONDUCTING TAPE TO IN. SK. 46089	Rev. Dt.: 25/01/2025 Page 2 of 4

Sl. No.	Type of Test	Desired Parameters
1.0	Lab Evaluation	
1.1	Voltage endurance test on 11 kV rated voltage sample bar(s)/coil(s)	No appreciable audio and visual corona shall occur during testing.
1.2	<u>High voltage test on tube:</u> One-half overlapped layer of the semi-conducting tape is applied on a phenolic cotton laminate/ glass/ fibreglass laminate tube of outer diameter approx. 40 mm as per sketch shown. This is suitably cured in electric oven. Aluminium foil electrodes are applied as per the arrangement shown in Figure-I. The sample is subjected to the following tests:	<p>FIGURE-I</p> 

CONFIDENTIAL


The information on this document is the property of Bharat Heavy Electricals Limited, it must not be used directly or indirectly in any way detrimental to the interest of the company

 An ISO 9001:2015 Company	INSULATION SYSTEMS ENGINEERING		IN.SK. 46121
	BHEL BHOPAL		Rev. No.: 01
	ADDITIONAL EVALUATION PARAMETERS FOR SEMI CONDUCTING TAPE TO IN. SK. 46089		Rev. Dt.: 25/01/2025
			Page 3 of 4

(a)	Voltage current measurement at 1-40 kV DC	<p>The voltage current (VI) characteristic should be similar to the symbolic graph given below.</p>  <p>X-axis – Voltage, Y-axis - Current</p>
(b)	High voltage test at 60 kV for 10 minutes between the two electrodes	<p>The sample is considered to have passed the test, if there is no flashover or tracking during the test duration. Appreciable heating may take place on the surface of the sample during testing.</p>

CONFIDENTIAL

The information on this document is the property of Bharat Heavy Electricals Limited, it must not be used directly or indirectly in any way detrimental to the interest of the company

 An ISO 9001:2015 Company	INSULATION SYSTEMS ENGINEERING	IN.SK. 46121
	BHEL BHOPAL	Rev. No.: 01
	ADDITIONAL EVALUATION PARAMETERS FOR SEMI CONDUCTING TAPE TO IN. SK. 46089	Rev. Dt.: 25/01/2025
		Page 4 of 4

2.0	Shop Application (Application on stator coils)	
2.1	Physical observation	Tape should be satisfactory in application. No breaking of tape, stiff and dry tape should be observed. Adequate stretchability and adhesion should be present for tightening and sticking of adjacent layers.

CONFIDENTIAL

The information on this document is the property of Bharat Heavy Electricals Limited, it must not be used directly or indirectly in any way detrimental to the interest of the company