

Request for Quotation (RFQ)

Collective No : B5D1Z50136

S.No	PR Number	Material code	Description of item	Drawing No-Var, Rev Specification,Rev	MU	Qty	Project Name
1	8000150136	TC9517350759	ROTOR FORGING	23030120145-00,00 HY19473,04	EA	1	RELIANCE UTILITIES & POWER, HAZIRA

- Delivery Terms: FOR Destination to BHEL, Hyderabad, 01-Stores - For Indian vendors
CIF -Mumbai - For Foreign vendors.
 - Acceptance of the offer shall be subject to approval by BHEL and/or the End Customer, whichever is applicable.
 - The vendor shall submit a Technical Offer without price on the company letterhead containing all relevant technical details, including:
 - i) Material Code
 - ii) Item Description
 - iii) Drawing Number
 - iv) Specification Number
 - v) Quantity
 - vi) Compliance to Technical Requirements
 - vii) Any other applicable technical conditions
 - Vendor has to submit Instructions to Bidder (**ITB**) duly filled, signed and stamped on each paper, along with their technical offer.
 - Vendor has to submit Annexure-I, Annexure-II, Annexure-III & Annexure-IV duly filled, signed and stamped, along with their technical offer.
 - **Technical Pre-Qualification Criteria (PQC)** along with supporting documentary evidence, shall be submitted without fail as part of the Technical Offer.
 - **Third Party Inspection** is applicable and it is mandatory.
 - a) For Indian vendors:**
Third party inspection by M/s. TUV SUD (or) M/s. QUEST
TPI charges by BHEL-Hyd. (*TPI charges shall be loaded to vendor during price evaluation)
 - b) For Foreign vendors:**
Third party inspection by M/s. LLOYDS REGISTER / BEREAU VERITAS / DNV / TUV
TPI charges shall be included in quoted prices.
 - Vendor has to submit **Integrity Pact** (IP) duly filled, signed and stamped along with their technical offer.
 - The Quality Plan shall be submitted after placement of the Purchase Order (PO) for approval by BHEL and/or the End Customer. The approved Quality Plan shall be strictly adhered to during execution of the order.
 - Relevant drawings and specifications are enclosed with this enquiry. For any further clarifications, vendors may contact through e-mail at "**mohanj@bhel.in**"
- Bidder has to provide their compliance to the drawing & specification.
- The price quoted in your offer is firm and final, inclusive of all applicable charges, costs, duties, taxes, packing, forwarding, freight, **inspection, testing**, documentation and any other incidental charges, as applicable. No additional charges over and above the total quoted amount shall be payable by BHEL during execution of the order.
 - BHEL reserves the right to accept or reject any offer, wholly or partially, and/or cancel the tender at any stage without assigning any reason thereof.
 - Delivery required in 150 days from the date of PO.

Supplier Declaration

I, _____ (Name of Supplier / Authorized Representative), hereby declare that I have read, understood, and accepted all the above-mentioned requirements, terms, and conditions, and confirm compliance while submitting our quotation.

Authorized Signatory: _____

Name: _____

Designation: _____

Company Name: _____

Signature & Company Seal

Date: _____



(Attachment to Enquiry No. XXXXXXXXXX Due on Date XX.XX.XXXX for submission by 11.00 hrs to open from 14.00 hrs.)

INSTRUCTIONS TO BIDDER (ITB)

NOTE: Bidder to confirm in affirmative by typing "YES" or "Applicable Data" in the response column. Deviations, if any shall be recorded in deviations/comments column (Separate sheet can be attached if needed). Non deviatable clauses are indicated as "NON DEVIATABLE".

Sl. No.	DETAILED TERMS & CONDITIONS	BIDDER RESPONSE (YES/NO)	DEVIATIONS / COMMENT
1	SCOPE OF SUPPLY:		
	Signed & Sealed offers are invited for the Scope of Supply of goods or services or both as detailed in the enquiry. Relevant enclosures/supporting documents / catalogue, if any shall be enclosed to the technical offer.		
2	DEFINITIONS		
A	'The Buyer' means BHEL-HPEP, Ramachandrapuram, Hyderabad-502 032 of Bharat Heavy Electricals Limited (A Govt. of India Undertaking) incorporated under the companies Act having its registered office at BHEL House, Siri fort, New Delhi-110049, India and shall be deemed to include its successors and assigns. It may also be referred to as BHEL.		
B	'The Bidder' means the persons, firm, company or organization on whom the Purchase order is placed and shall be deemed to include the bidder's successors, representatives, heirs, executors and administrator as the case may be. It may also be referred to as Contractor, supplier or bidder.		
C	'Contract' shall mean and include the Purchase order incorporating various documents viz., Notice Inviting Tender (NIT), Offer, Letter Of Intent/Acceptance (LOI/LOA), Instruction to Bidders (ITB) and Special Conditions of Contract (SCC), specifications, inspection/quality plan, schedule of prices and quantities, drawings, if any, enclosed by Bidder/ provided by the Buyer or his authorized nominee and the samples or patterns if any to be provided under the provision of the contract. In case of any inconsistency or contradiction between any of the documents, the order of precedence shall be Purchase Order, LOI/LOA followed by Minutes Of Meeting (MOM), NIT, SCC, ITB.		
D	'Parties to the contract' shall mean the bidder and the buyer as named in the main body of the Purchase Order.		
E	'Goods/Material' shall include Works and Services which are incidental or consequential to supply.		
3	GENERAL INSTRUCTIONS:		
A	Mode of submission of offer shall be as indicated in SCC		Non Deviatable
B	The quotation should be neatly typed and free from over writing/ erasures. Any correction or addition must be authenticated. The offer including annexures and brochures should be submitted in English / Hindi. All Pages of Techno Commercial Bids (Main Pages), ITB, SCC should be signed and Stamped. If there is a conflict in case of bilingual submission, the submission in English will be final. Prices shall be quoted both in figures and words. In case of any discrepancy in value, the prices quoted in words shall be considered for evaluation and establishing L1 Status. Any discount / revised offer / bids submitted by a bidder on his own shall be considered, provided it is received on or before the due date and time of offer / bid submission (Part-1). Conditional discounts shall not be considered for evaluation of tenders.		Non Deviatable
C	Incomplete offers are liable for rejection.		Non Deviatable
D	Bidders to please note that the Terms & conditions contained in this document and SCC are to be read fully before submission of quotations.		Non Deviatable
E	Bidders are advised to comply with ITB and SCC, should there be any deviations (where deviations are permitted), it shall be entered in the deviation column. BHEL reserves the right to reject such offers or load the bid suitably for evaluation.		Non Deviatable
F	Offers shall be submitted directly, only by the bidder or by their authorized representative / agent and the offer should be in line with the regulatory guidelines (i.e. A valid Agency agreement between principal bidder and agent / representative shall be attached and the agreement shall cover the scope of services rendered by Agent, Agency Commission and any other information called for as per the regulatory guidelines). OEM / Mill details shall be provided if bidder is not a manufacturer. Bid envelops shall bear the name of Bidder. In case of submission through authorized representative/agent, the name of representative/agent should also be mentioned apart from bidder name.		Non Deviatable
G	Offer received after the specified time and date of submission will be rejected. No further correspondence shall be entertained.		Non Deviatable
H	Unsolicited offers will not be considered.		Non Deviatable
4	OTHER PARTICULARS (Please indicate applicable data)		
A	Name of the Bid currency (freely tradable foreign currency for imports and Indian Rupees for indigenous purchase).		
B	Name of the Port of loading and Port of Discharge (applicable to imports).		



5	BID SUBMISSION PROCEDURE FOR CONVENTIONAL TENDER:		
A	For Single Part Bids:		
	The complete bid shall be submitted in a single sealed cover superscribing the Tender number and due date, addressed to Sr DGM/CMM, 4 th Floor Administrative Building, BHEL, Hyderabad and sent by appropriate mode to above address or dropped in tender box located at Admin II Gate on or before the specified time and date of submission of offers, preferably in the bidder's envelope. E- mail bids shall be sent to mail ID pricebid_hyd@bhel.in only as an attachment.		Non Deviatable
B.	For two-Part Bids:		
i	The offer is to be submitted in two parts viz., Techno-commercial Bid - (Part-I), with all technical specification & scope including bill of material etc., Earnest Money Deposit (EMD)(wherever applicable) and unpriced bid with all applicable Commercial Terms and Conditions, rates of agency commission, duties, taxes and other charges, Signed and Stamped ITB and SCC, <u>except the price</u>, shall be kept in a separate sealed cover, superscribing enquiry No. (Techno-Commercial Bid) and due date AND Price Bid (Part-II), containing ONLY the price (including agency commission, if any) and the applicable duties/taxes/other charges shall be kept in a separate sealed cover superscribing Enquiry no. (Price bid) & due date. Both the above covers (Part –I & II) shall be kept in a Third cover superscribing Enquiry no. & due date. Bidder can also submit offer through email. Technical offer to be submitted to mail ID technicalbid_hyd@bhel.in, and price bid to be submitted to mail ID pricebid_hyd@bhel.in only as an attachment. Interchanging the information in the mails may lead to rejection of the offer. Bidder shall have no claim on e-mail offers sent to any other e-mail ID. In case of e-mail offers, the mail subject should contain Enquiry Number, Due date and Bidder name. Bidder address including contact details shall be mentioned in the content of the mail. Without these details, the offer is liable for rejection. All techno commercial terms & conditions mutually agreed prior to price bid opening shall prevail and supersede any terms and conditions specified otherwise in price bid.		Non Deviatable
ii	The bidders whose bids are techno commercially not accepted will be informed and EMD shall be returned wherever submitted.		
iii	Bidders will be allowed to submit the impact on their quoted prices due to changes in technical scope, specifications, and commercial terms/conditions as specified in NIT which in the opinion of BHEL , warrant changes in prices.		Non Deviatable
C	Bids shall be opened on due time and date in the presence of bidders who may like to be present. Only one representative of each bidder shall be permitted to attend the bid opening. Only the price bids of bidder (in case of two part bid) whose techno commercial bids are accepted will be opened later on a specified date.		Non Deviatable
6	DELIVERY TERMS		
A	Indigenous Purchase		
	a. Terms of Delivery for dispatches to BHEL Hyderabad (HPEP) shall be FOR Destination. b. Terms of Delivery for Direct Dispatch (DD) items shall be Ex Works. i. Incase specified in SCC that insurance is in customer/BHEL scope, price quoted shall include Freight charges up to Destination. ii. Otherwise, price quoted shall include Freight and Insurance upto Destination. However, beneficiary for insurance shall be BHEL.		
B.	Imports		
	The goods shall be delivered on FCA capital airport basis in case of freight by Air and CIP basis in case of freight by Sea.		
7	Documentation for Payment		
A	Indigenous Purchase		
	Following documents shall be submitted immediately on dispatch of material to BHEL HPEP / Site a. Two numbers of Original Tax Invoice (Refer ITB clause no 11 for Tax Compliance)/ e-invoice of GST Portal if applicable) b. Packing List - clearly showing number of packages, gross weight and net weight. c. Test/Warranty/Guarantee certificates, O&M Manual (If specified in SCC) d. Insurance intimation/declaration certificate e. Pre-dispatch Inspection report /Third Party Inspection Certificates. f. Consignee copy of LR signed & stamped by Customer/Site representative for DD Items g. e-waybill h. Any other documents as specified in SCC.		Non Deviatable

B	Softcopies of the above documents shall be uploaded in SUVIDHA portal https://suvidha.bhel.in/suvidha/ or https://hpep.bhel.com/mm/main.jsp Vendor Bills tab. immediately after dispatch of the material. Upload of Documents is mandatory for material Entry. Imports i) Bidder shall inform BHEL the readiness of material along with packing details 30 days in advance from the date of delivery. For Hazardous cargo/DG cargo, supplier must provide the following documents prior to handing over shipment to freight forwarder, wherever freight is in BHEL scope: 1. Valid MSDS 2. DGD certificate with appropriate UN numbers. 3. Labelling and marking on DG cargo along with photo of packaging. 4. Self-declaration for consignment 5. Packaging Certificate as per DG Standards 6. TSA Approved Truckers details to be provided to forwarder at the time of shipment In addition to the above, supplier should ensure to comply all IATA DG regulations, if any new requirement is added in future. ii). Bidder shall also upload the soft copy of the dispatch documents consisting of BL / AWB, Invoice, delivery note, packing list, country of origin & Test certificates and other documents as specifically indicated in the SCC in PRADAN Portal (https://hpep.bhel.com/mm) within Five days from the B/L date for sea shipment and One day from AWB date for Air shipment and sent to email ids: mssea@bhel.in, msair@bhel.in, cmmfe@bhel.in. iii) AWB/BL must contain the information of BHEL GST no., and PAN no. iv) Air Shipments: Bidder shall ensure the following a) Port of discharge -- Mumbai/Chennai/Hyderabad (as indicated in SCC). b) Consignee shall be BHEL, Hyderabad. Material shall be air freighted through cargo mode only and not through Courier. c) Upon handing over the cargo to the forwarder, bidder shall ensure the acknowledgement receipt with wordings "Cargo handed over in sound condition for Air freighting". Note: Warehouse receipt will not be considered for penalty calculations. d) In case of CIF/ shipments, bidder shall also inform BHEL the information about discharge port agent details and cargo arrival information within one day from the date of Shipment. e) Following dimensions of single package may be noted. - i). Maximum dimension of the cargo(ODC) -- 125" x 88" x 63" - ii). Maximum weight of the cargo -- 3.5 MT. If any package dimension or weight exceeds the above set limits, it will be treated as Over Dimension Cargo (ODC) or Over Weight Cargo and bidder shall inform BHEL 30 days in advance to the delivery date to enable BHEL to finalize the freight forwarder. - f). If package falls under Hazardous category, bidder shall communicate BHEL 30 days in advance period with document support. v) Sea Shipments:- bidder shall ensure the following - a). Port of discharge -- Nhavaseva/Mumbai/Chennai. - b). Place of Delivery / Final Destination for CIP shipments - Nhavaseva CFS / Chennai CFS. - c). In case of FOB shipments, bidder shall handover the material to BHEL nominated forwarder and obtain the cargo receipt. - d). If the material cannot be containerized in 20 or 40 GP containers, an advance information of 30 days prior to the delivery date shall be communicated to BHEL for necessary arrangements and finalisation of freight forwarder. - e). For CIP shipments 1. In case of FCL shipments, Detention free period must be 14 days. 2. Bidder shall also inform BHEL the information about discharge port agent details and cargo arrival information within 5 days from the date of Shipment. 3. No charges for the services rendered till place of destination will be payable by BHEL. In case liner / forwarder insist for charges, not in the scope of BHEL, the same will be adjusted from bidder account. 4. In case of CIF shipments -- Bidder must select a forwarder/liner whose discharge port published tariff for THC and other services is available. Any charges over and above the published tariff will not be borne by BHEL or will be adjusted from the bidder's bill. 5. bidder must insure the cargo for 110% of material value including the freight amount. (vi). Recovery charges for non-submission of documents: - Bidder shall submit all the required documents to BHEL as prescribed in the Purchase order and NIT.		
---	---	--	--



	If BHEL incurs any charges such as Penalty, demurrage, container detention, wharfage, storage, Ground rent etc., due to non - compliance / non - submission of documents prescribed in Purchase Order/ NIT/Letter of credit, the same shall be recovered from the bidder as under: 1. EUROPE/USA/Black Sea/ Far East/Middle East/South East sector A. For FOB Sea Consignments:- Penalty for late submission / negotiation of documents beyond 14 days shall be as under: <table><tr><th rowspan="2">Sl. no</th><th rowspan="2">Period (From Date of Bill of Lading)</th><th>Recoverable Charges</th><th colspan="2">Recoverable Charges per day per container</th></tr><tr><th>LCL per week/ Break bulk cargo per day</th><th>20FT Container</th><th>40FT Container</th></tr><tr><td>i</td><td>Upto 14th day</td><td>Nil</td><td>Nil</td><td>Nil</td></tr><tr><td>ii</td><td>15th day onward</td><td>USD 10</td><td>USD 110</td><td>USD 200</td></tr></table> B. For CIP Sea Shipments: - Bidder shall provide rates for detention charges after free period at the time of offer itself in case of engagement of 20FT Container and 40FT category. In case of late presentation of documents to the bank recovery will be effected from the Bidder as per the rates quoted by the Bidder at the time of offer in this regard. In case of Break bulk cargo and LCL, Demurrage charges shall be recovered at the rate of USD 1 per Ton per day and storage charges at the rate of USD 10 per week respectively shall be charged as late presentation charges. (vii) Description of items in invoice, packing list, BL / AWB or LR shall be same as PO item description. Bidders shall ensure that invoice shall contain PAN nos. of both bidder and BHEL along with other tax related numbers. BHEL PAN AAACB4146P and BHEL TAN HYDB00086C Any other additional documents sought by the statutory authorities, the same shall be produced by the bidder on priority basis. (viii) Bidder shall provide package details including number of packages, gross weight, net weight etc. (ix) The bidder shall provide the following documents at the time of submission of offer: a) No Business Connection in India declaration issued by the bidder as per the format specified. (or) b) (i) No Permanent Establishment in India declaration issued by the bidder as per the format specified. (ii) Tax Residence Certificate issued by the bidder's tax authorities. (iii) Form 10F, as attached in Annexure V, to be issued by the bidder. c) In case the bidder has a Business Connection in India as per Section 9 of Income Tax Act or significant economic presence in India as per rule 11 UD of IT Act or Permanent Establishment in India as per Article 5 of Double Taxation Avoidance Agreement between India and the bidder's country, the bidder shall provide a withholding tax order issued by the Indian Income Tax authority for recovery of applicable tax.	Sl. no	Period (From Date of Bill of Lading)	Recoverable Charges	Recoverable Charges per day per container		LCL per week/ Break bulk cargo per day	20FT Container	40FT Container	i	Upto 14th day	Nil	Nil	Nil	ii	15th day onward	USD 10	USD 110	USD 200		
Sl. no	Period (From Date of Bill of Lading)			Recoverable Charges	Recoverable Charges per day per container																
		LCL per week/ Break bulk cargo per day	20FT Container	40FT Container																	
i	Upto 14th day	Nil	Nil	Nil																	
ii	15th day onward	USD 10	USD 110	USD 200																	
8	Delivery Schedule																				
	The tendered goods shall be delivered within the period stipulated in NIT/ SCC as accepted. Inordinate delay/early supply are liable for rejection/Hold on payment.		Non Deviatable																		
9	Pricing Terms																				
	Quoted price shall be inclusive of Packing & Forwarding and shall remain firm and valid during the execution of PO. Offers with PVC will be rejected outright except in cases where specifically called for in the SCC.		Non Deviatable																		
10	PRICE VALIDITY :																				
	Unless otherwise specified, offer shall be valid for a period of 90 days from the date of bid opening (Technical bid /part-I in case of two part bid). However the prices quoted for spare parts of the Main equipment shall be kept valid for a period as specified in SCC.		Non Deviatable																		

11	Taxes & Duties (RATE TO BE INDICATED by the bidder against the space provided)	
A	Indigenous Purchase i) Only valid GST registered bidders will be considered for the tender. The GSTIN of the bidder should be clearly mentioned in the offer. ii) If bidder is exempted from GST registration under any provision of the GST Law, a declaration with due supporting documents should be furnished for considering the offer. iii) Bidder to quote the applicable taxes in the following manner: - Harmonized System of Nomenclature (HSN) of Goods - Services Accounting Code(SAC) of Services. - IGST/CGST/SGST/UTGST: Rate of Tax to be quoted as extra in % against the space provided iv) Bidders to ensure correct applicability of IGST/CGST/SGST/UTGST based on the Inter / Intra state movement of goods/services. v) In case Bidder has opted for GST Composition Scheme, the same may be stated explicitly both in their technical and price bids. An undertaking to the effect that any change in the status of the bidder will be intimated. vi) Any other taxes & duties not covered anywhere above may be indicated separately. Taxes deducted at source: - TDS as per the extant statutes shall be deducted. - In case bidder does not provide PAN details, higher rate of tax shall be deducted as per the Act. - Concessional certificates, if any, should be provided well in time for lower deduction of tax.	Non Deviatable
	Terms & Conditions to be complied 1. All invoices (incl. Credit Notes, Debit Notes) to contain BHEL HPEP GSTIN ie 36AAACB4146P1ZG. Invoices submitted should be in the format as specified under GST Law. All details as mentioned in Invoice Rules including Dealer GST registration number (GSTIN), invoice number with date of issue, quantity, rate, value, taxes with nomenclature – CGST, SGST, UGST, IGST mentioned separately, HSN Code / SAC Code etc. 2. Reimbursement of GST amount will be made only upon completion of the following: i. Bidder declaring such invoice in their GSTR-1 Return/ IFF ii. Receipt of Goods or Services and Submission of Tax invoice by BHEL iii. The tax invoice is reflected in the GSTR2B of BHEL, HPEP (buyer). Payment of GST will be made only if it is matching with data uploaded by the Bidder in GST portal. 3. In case of discrepancy in the data uploaded by the bidder in the GSTN portal vis-a-vis the tax invoice or in case of any shortages or rejection in the supply, then BHEL will not be able to avail the tax credit. The same would be available in PRADAN Portal for the bidder's information. Bidder has to rectify the data discrepancy in the GSTN portal or issue credit note or debit note (details also to be uploaded in GSTN portal) for the shortages or rejections in the supplies or additional claims for processing of such invoices. 4. In cases where invoice details have been uploaded by the bidder but failed to remit the GST amount to GST Department within stipulated time, then GST on the invoices in default will be recovered from the bidder along with the applicable interest. 5. In case GST credit is delayed/denied to BHEL due to non/delayed receipt of goods and/or tax invoice or expiry of timeline prescribed in GST law for availing such ITC, or any other reasons not attributable to BHEL, such GST amount will be recoverable from bidder along with interest levied/ leviable on BHEL. 6. GST TDS deducted as per GST Act, is uploaded in GSTN portal along GSTR7. Bidders can directly download the GST TDS Certificate from the GSTN Portal. 7. Bidders to note that Rules & Regulations pertaining to E-way bill system are to be strictly adhered to, as and when notified by Govt. authorities. 8. Vendors who fall under the E-Invoice regulations, i.e., having an annual turnover of Rs. 10 crores (Rs 5 crore w.e.f 01.08.2023) in the previous year shall issue e-invoice in line with Rule 48(4) of CGST Rules failing which GST amount will not be reimbursed to the vendor even if the other requirements are fulfilled. 9. In case the vendor is exempted by the GST department under the Rule 48(4) of CGST Rules from issuing E-invoice, a declaration as prescribed in the Notification 17/2022 - Central Tax dated 01-08-2022 shall be provided on the invoice. 10. Vendors who do not fall under the E-Invoice regulations, i.e., whose annual turnover is less than Rs. 10 crores (Rs 5 crore w.e.f 01.08.2023) in the previous year have to give an undertaking indemnifying BHEL that the vendor is not falling under the E-invoice requirement category and that in case of any breach of this E-invoicing requirement, the vendor indemnifies BHEL of any consequences that may arise due to such a breach. 11. No GST shall be levied on liquidated damages / penalty.	

B.	Foreign Purchase (Imports) The offered price shall be inclusive of all the Taxes and duties as applicable in country of export / country of dispatch for the quoted price. Taxes deducted at source: a. In case of goods or services subject to Income tax in India, such tax as per the extant statute shall be recovered. b. In case bidder does not provide necessary documents for beneficial taxation (Refer clause 7-B-(ix) a-c of ITB), the TDS deduction shall be at the maximum percentage stipulated as per the provisions of Income Tax Act.		Non Deviatable
12	Payment Terms: Unless otherwise specified in SCC, following shall be the terms of Payment.		
A	Indigenous: a. Micro & Small Enterprises (MSEs) - 100% EFT payment within 45 days b. Medium Enterprises - 100% EFT payment within 60 days c. Non MSME Bidders - 100% Direct EFT Payment within 90 Days Note A. Above due date is reckoned from the date of Receipt of material or 15 days from the date of submission of complete set of documents as per PO whichever is later. Objections, if any on the invoice, available on SUVIDHA portal need to be closed. In such instances, due date is reckoned from the closure of objections. Vendors are advised to get familiarized with the document exchange feature on SUVIDHA portal. Payment will be made for Material accepted value. B. MSEs (covered under MSME Act) need to register and renew periodically and update the same with BHEL C. The taxes that are reimbursed are limited to applicable taxes as on the Purchase Order delivery date or the amount actually paid whichever is less. D. Adherence to the above time schedule of payment is contingent upon Bidder complying with GST provisions and availment of Input Tax Credit by BHEL before the date of payment. E. In case of packaged items, 10% of supply value will be retained till completion of total supplies. F. Bidders to comply with clause 11 on GST requirements G. MSE benefits are not applicable to Traders / Wholesalers registered as MSEs. H. In respect of procurement of goods or services from Micro, Small and Medium enterprises (MSMEs), the settlement of invoice shall be only through any of the TReDS platform (i.e RXIL, MI xchange, Invoicemart, KReDX, C2FO), authorised by the Reserve Bank of India. Such MSME suppliers to select their preferred TReDS platform before award of contract so that the data is captured in the Order /Contract database of the Unit. They also will have the option to change the TReDS platform from the drop down menu on Suvidha portal of BHEL, at the time of invoice submission. Wherever the Trade Receivable is accepted by BHEL, the same shall be validated by the Unit on the respective TReDS platform selected by the supplier. The routing of invoices through the TReDS platform shall not be construed as mandating discounting of such invoices and the MSMEs supplier shall have the option to avail or not avail financing or discounting of its receivables on the TReDS platform. In case discounting is not availed by the supplier on TReDS, the trade receivables will be paid through TReDS as per the payment timelines indicated in the contract.		
B	Imports: i) 100% payment (less Indian Agency Commission, if any) shall be through Wire Transfer with a credit period of 45 days - Cash Against Documents (CAD) ii) In case Bidder opts for Letter of Credit payment, the LC Usance period shall be 90 days with respective bank charges to respective accounts and loading of 0.50% iii) Indian Agency commission if payable and so specified in the Purchase order shall be paid in Indian Rupees, considering the SBI TT selling exchange rate, as on the date of payment after successful completion of the contract.		
C	Conditions for LC: a. LC validity period will be 90 days and for any extension, applicable charges will be to bidder's account. b. LC will be opened after successful completion of pre dispatch inspection prior to the scheduled / agreed delivery date. LC will be opened within 15 bank working days from the date of request.		Non Deviatable
D	Conditions for both Indigenous & Foreign Bidders: a. In case Bidders insist for lesser Credit period and BHEL accepts, a loading of 0.60% for every 15 days reduction will be applicable. b. In case PBG as required is not furnished, Payment will be released deducting the BG amount, which will be paid after expiry of warranty period against submission of supplementary claim. c. Payment does not imply in any respect whatsoever a waiver of Buyer's right to performance of the Order. Buyer is entitled to set off claimable debts against claimable liabilities with the bidder by means of a setoff Note.		Non Deviatable

E	Wherever EMD is applicable, the EMD will be paid back to unsuccessful bidders within fifteen days after award of the contract. Successful bidder's EMD will be retained till submission of Performance Bank Guarantee (PBG). Tender Fee wherever applicable is not refundable. No interest shall be payable by BHEL on earnest money or security deposit or any money due to the contractor by BHEL.		Non Deviatable
13	Penalty clause: In the event of delay in supply /part-supply of goods, Penalty as detailed below is leviable a. Penalty of 0.5% per week or part there of shall be levied, limited to a max of 10% (ten percent) of order value. b. Penalty applicable for delay in documentation is as per SCC. c. Date Reckoned for Penalty - Indigenous Orders with delivery terms FOR HPEP: C Note date. - Indigenous Orders (Others): Date of e-waybill. - Imports: For CIP/CIF Orders: IGM date - Imports: For FOB Orders: AWB / BL date - Imports: - For FCA Orders: - Date of acknowledgement from Freight Forwarder. - For Ex Work Orders (both air and sea): - Latest of Air Freight Request (AFR), Invoice, Packing List, Inspection date (if applicable) or any other documentary evidence confirming material readiness. d. In case of Deviation to above Penalty clause, loading applicable to the extent to which not agreed by Bidder. e. Timelines as mentioned in the Annexure 1 will be considered for reckoning delivery.		
14	Excess materials supplied beyond tolerance limit as specified in PO will not be paid and bidder may raise credit note for the excess/unaccepted material as per GST law.		Non Deviatable
15	Rejected materials, if any, shall be collected by the bidder within 90 days of such communication to the bidder. Beyond this period the bidder forfeits their right to the materials.		Non Deviatable
16	Guarantee / Warranty Period: Wherever required, and so provided in the specifications/SCC/Purchase Order, the bidder shall guarantee that the goods supplied shall comply with the specifications laid down, for materials, workmanship and performance. a. Guarantee period shall be 12 months from the date of commissioning or 18 months from the date of supply whichever is earlier. b. In case erection & commissioning is involved, guarantee period shall be 12 months from the date of commissioning. c. In case of equipment bought as a package which are intended to be incorporated in installations or systems, the guarantee period shall be 12 months from the date of commissioning of such equipment. The guarantee period shall be extended by the period during which the goods are not in compliance. If the delivery is found to be non-complaint, bidder shall replace, repair or re-execute the as requested by BHEL. If the bidder defaults on his obligations, buyer has the right to proceed to replace, repair or re-execute at the bidder's expense. A guarantee period as described above shall apply afresh to replaced, repaired or re-executed parts of a delivery. Loading for deviation: In case warranty specified in SCC is over and above the period mentioned in b & c above; loading will be 1% per annum for the deviation in warranty end period, on the contract value. Expected commissioning period is as indicated in SCC.		Non Deviatable

17	PERFORMANCE BANK GUARANTEE (PBG) (Applicable in case mentioned in SCC) In case enquiry specifically spells out PBG requirement, PBG is to be submitted by Bidder in requisite format as per Annexure VII. Further detailing on PBG as specified in SCC. The PBG shall be for the performance of the goods and shall remain binding notwithstanding such variations, alterations or extensions of item as may be made, give, conceded or agreed to between the Bidder and BHEL under these Terms and conditions or otherwise.		Non Deviatab le																									
NOTE: Deviations (Commercial as well as Technical) from the tender specifications and conditions are generally not acceptable. However, deviation if any, shall be brought out clearly with proper justification in the offer. The deviation, if considered by BHEL, shall be loaded for comparison, while evaluating the offer. If a bidder unconditionally withdraws any deviation before price bid opening, the same shall not be loaded. Loading criteria in respect of major commercial conditions where deviations if any are accepted shall be as per clause No.18. The Bidders may specifically note the following.																												
18	Evaluation and Loading Criteria: i) Evaluation Currency for this tender shall be “INR”. ii) Evaluation of prices shall be done item-wise unless otherwise specified in the SCC. iii) Evaluation shall be on the basis of delivered cost, i.e. “Total Cost to BHEL” w.r.t the finalized technical scope and commercial conditions (after considering incidence of applicable taxes and duties and loading). iv) In the course of evaluation, if more than one Bidder happens to occupy L1 status, effective L1 will be decided by soliciting discounts from the respective L1 Bidders. In case more than one Bidder happens to occupy the L1 status even after soliciting discounts, the L1 Bidder shall be decided by a toss/draw of lots, in the presence of the respective L1 Bidders or their representatives. Ranking will be done accordingly. BHEL decision in such situations shall be final and binding. INDIGENOUS a. Bidder shall ensure to indicate the applicable taxes against each line item, failing which the same will be considered as inclusive/NIL. b. Ex-works offers received (as against FOR Destination mentioned in enquiry) shall be loaded by 2% of Ex-works value. c. GST and any other charges quoted will be added to the base price. However, in case input credit is available for GST (SGST, CGST/IGST), the same shall be excluded for arriving at “Total Cost to BHEL” IMPORTS For evaluation of offers in foreign currency, exchange rate (TT selling rate of State Bank of India) as on the date of bid opening (Part-I, in case of two-part bids) shall be considered. If the relevant day happens to be a bank holiday, then the forex rate as on the previous bank (SBI) working day shall be taken. In case of foreign Bidders, the quoted price shall be loaded by the following factors to arrive at “Total Cost to BHEL”: - Import duty as applicable on the date of Part-I bid opening. - Loading will be as per the table below <table><tr><td></td><td>Ex Works</td><td>FOB/F CA</td><td>CIF/C FR</td><td>CIP</td></tr><tr><td>Foreign Inland freight and insurance</td><td>2%</td><td></td><td></td><td></td></tr><tr><td>Marine freight and marine insurance</td><td>3%</td><td>3%</td><td></td><td></td></tr><tr><td>Destination Port handling charges</td><td>0.50%</td><td>0.50%</td><td>0.50%</td><td></td></tr><tr><td>clearing charges & inland freight and insurance</td><td>2%</td><td>2%</td><td>2%</td><td>2%</td></tr></table> COMMON LOADING FOR IMPORTS & INDIGENOUS that will be added for arriving the "Total Cost to BHEL" A. Loading on Deviated Penalty clause shall be 10% or to the extent to which the bidder has opted for deviation. B. Loading for payment terms as per clause 12 of ITB C. Loading for deviation in Warranty & PBG as per clause 16,17.				Ex Works	FOB/F CA	CIF/C FR	CIP	Foreign Inland freight and insurance	2%				Marine freight and marine insurance	3%	3%			Destination Port handling charges	0.50%	0.50%	0.50%		clearing charges & inland freight and insurance	2%	2%	2%	2%
	Ex Works	FOB/F CA	CIF/C FR	CIP																								
Foreign Inland freight and insurance	2%																											
Marine freight and marine insurance	3%	3%																										
Destination Port handling charges	0.50%	0.50%	0.50%																									
clearing charges & inland freight and insurance	2%	2%	2%	2%																								

19	Procurement directly from the manufacturers/ suppliers shall be preferred. However, no agent shall be allowed to represent more than one manufacturer/ supplier in the same tender. Moreover, either the agent could bid on behalf of the manufacturer/ supplier or the manufacturer / supplier could bid directly but not both. In case bids are received from both from the manufacturer/ supplier and the agent, bid received from the agent shall be ignored.												
20	RIGHT OF REJECTION /NON- PLACEMENT OF PO: BHEL reserves the right to accept or reject any or all bid/s in full or part without assigning any reason whatsoever.												
21	INTEGRITY PACT Bidders shall have to enter into Integrity Pact with BHEL as per Annexure VI - for Tender value of rupees two crores and above and shall be signed by the authorized signatory along with the offer, failing which Bidder's offer will be rejected.												
22	Public Procurement												
A	Make in India For this Procurement, the local content to categorize a bidder as a Class I local bidder / Class II local bidder / Non-Local bidder and purchase preference to Class I local bidder, is as defined in Public Procurement (Preference to Make in India) order No P-45021/2/2017-PP(BE-II) dated 04-06-2020 issued by DPIIT as amended from time to time. Proforma for self-certification for minimum local content and auditor's certification is given in Annexure III.												
B	Any Bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with competent authority. GOI website https://www.mea.gov.in/ to be referred for latest details of competent authority and exemptions . Proforma for self-certification for compliance is given in Annexure IV.												
C	Startups: For Start-ups duly registered with DPIIT (Copy of certificate to be provided), condition of prior turnover and prior experience in Public Procurement may be relaxed subject to meeting of Quality and Technical Specifications. Startups are exempt from paying EMD.												
23	Benefits earmarked for Purchase from Micro & Small Enterprises (MSEs) – Indigenous Purchase												
A	All Micro and Small Enterprises (MSEs) as defined in MSE Procurement Policy are exempt from Paying EMD. NSIC/UDYAM registered bidders shall submit NSIC/UDYAM Certificate along with bid documents. Any Bidder falling under MSE category shall furnish the following details & submit documentary evidence/ Govt. Certificate etc. in support of the same along with their techno-commercial offer. <table border="1"><tr><td>Type under MSE</td><td>SC/ST Owned</td><td>Women Owned</td><td>Others (excluding SC/ST & Women Owned)</td></tr><tr><td>Micro</td><td></td><td></td><td></td></tr><tr><td>Small</td><td></td><td></td><td></td></tr></table> Note: If the bidder does not furnish the above in the tender, offer shall be processed construing that the bidder is not falling under MSE category. Date to be reckoned for determining the deemed validity will be the last date of Technical bid submission. Non- submission of such document will lead to consideration of their bid, at par with other bidders and MSE status of such bidders shall be shifted to Non- MSE Category till the bidder submits these documents.	Type under MSE	SC/ST Owned	Women Owned	Others (excluding SC/ST & Women Owned)	Micro				Small			
Type under MSE	SC/ST Owned	Women Owned	Others (excluding SC/ST & Women Owned)										
Micro													
Small													
B	MSE suppliers can avail the intended benefits in respect of the procurements related to the Goods and Services only (Definition of Goods and Services as enumerated by Govt. of India vide Office Memorandum F. No. 21(8)/2011-MA dtd. 09/11/2016 office of AS & DC, MSME) and subsequent amendments & clarifications, if any. Documents NSIC/UDYAM Certificate submitted by the bidder shall be verified by BHEL for rendering the applicable benefits.												
C	If an enterprise falling under MSME category as defined in the Act, graduates to a higher category from its original category or beyond the purview of the Act, it shall continue to avail all non-tax benefits of its original category notified by the Ministry of Micro, Small and Medium Enterprise for a period of three years from the date of such graduation to the higher category.												
D	BHEL HPEP is registered with TReDS (RXIL , M1XCHANGE , InvoiceMart) platform. MSME bidders are requested to get registered with TReDS(RXIL / M1XCHANGE / InvoiceMart/ exchanges added from time to time) platform to avail the facility as per the GOI guidelines.												
24	Inspection Measuring and Test Equipment (IMTE) used by the Bidder/ Contractor or sub-contractor shall be calibrated, maintained and controlled. Calibration shall be valid and IMTE maintained in sound condition during usage.												
25	ISO-9001, ISO14001 & OHSMS 45001 shall be complied.												
26	If BHEL registered supplier is not quoting against this NIT, supplier shall send regret letter positively with valid reasons for not participating. Repeated lack of response on the part of supplier may lead to deletion of such registered supplier from BHEL's approved supplier's list as per BHEL SEARP Guidelines.												

27	BREACH OF CONTRACT, REMEDIES AND TERMINATION 27.1 BREACH OF CONTRACT: The following shall amount to breach of contract: - Non-supply of material/ non-completion of work by the Supplier/Vendor within scheduled delivery/ completion period as per contract or as extended from time to time. - The Supplier/Vendor fails to perform as per the activity schedule and there are sufficient reasons even before expiry of the delivery/ completion period to justify that supplies shall be inordinately delayed beyond contractual delivery/ completion period. - The Supplier/Vendor delivers equipment/ material not of the contracted quality. - The Supplier/Vendor fails to replace the defective equipment/ material/ component as per guarantee clause. - Withdrawal from or abandonment of the work by the Supplier/Vendor before completion as per contract. - Assignment, transfer, subletting of Contract by the Supplier/Vendor without BHEL's written permission resulting in termination of Contract or part thereof by BHEL. - Non-compliance to any contractual condition or any other default attributable to Supplier/Vendor. - Any other reason(s) attributable to Vendor towards failure of performance of contract. In case of breach of contract, BHEL shall have the right to terminate the Purchase Order/ Contract either in whole or in part thereof without any compensation to the Supplier/Vendor. - Any of the declarations furnished by the contractor at the time of bidding and/ or entering into the contract for supply are found untruthful and such declarations were of a nature that could have resulted in non-award of contract to the contractor or could expose BHEL and/ or Owner to adverse consequences, financial or otherwise. - Supplier/Vendor is convicted of any offence involving corrupt business practices, antinational activities or any such offence that compromises the business ethics of BHEL, in violation of the Integrity Pact entered into with BHEL has the potential to harm the overall business of BHEL/ Owner. Note- Once BHEL considers that a breach of contract has occurred on the part of Supplier/Vendor, BHEL shall notify the Supplier/Vendor by way of notice in this regard. Contractor shall be given an opportunity to rectify the reasons causing the breach of contract within a period of 14 days. In case the contractor fails to remedy the breach, as mentioned in the notice, to the satisfaction of BHEL, BHEL shall have the right to take recourse to any of the remedial actions available to it under the relevant provisions of contract
	27.2 Remedies in case of Breach of Contract.: - Wherein the period as stipulated in the notice issued under clause 27.1 has expired and Supplier/Vendor has failed to remedy the breach, BHEL will have the right to terminate the contract on the ground of "Breach of Contract" without any further notice to contractor. - Upon termination of contract, BHEL shall be entitled to recover an amount equivalent to 10% of the Contract Value for the damages on account of breach of contract committed by the Supplier/Vendor. This amount shall be recovered by way of encashing the security instruments like performance bank guarantee etc available with BHEL against the said contract. In case the value of the security instruments available is less than 10% of the contract value, the balance amount shall be recovered from other financial remedies (i.e. available bills of the Supplier/Vendor, retention amount, from the money due to the Supplier/Vendor etc. with BHEL) or the other legal remedies shall be pursued. - Wherever the value of security instruments like performance bank guarantee available with BHEL against the said contract is 10% of the contract value or more, such security instruments to the extent of 10% contract value will be encashed. In case no security instruments are available or the value of the security instruments available is less than 10% of the contract value, the 10% of the contract value or the balance amount, as the case may be, will be recovered in all or any of the following manners: - In case the amount recovered under sub clause (a) above is not sufficient to fulfil the amount recoverable then; a demand notice to deposit the balance amount within 30 days shall be issued to Supplier/Vendor. - If Supplier/Vendor fails to deposit the balance amount within the period as prescribed in demand notice, following action shall be taken for recovery of the balance amount: - from dues available in the form of Bills payable to defaulted Supplier/Vendor against the same contract. - If it is not possible to recover the dues available from the same contract or dues are insufficient to meet the recoverable amount, balance amount shall be recovered from any money(s) payable to Supplier/Vendor under any contract with other Units of BHEL including recovery from security deposits or any other deposit available in the form of security instruments of any kind against Security deposit or EMD. - In-case recoveries are not possible with any of the above available options, Legal action shall be initiated for recovery against defaulted supplier/Vendor. - It is an agreed term of contract that this amount shall be a genuine pre-estimate of damages that BHEL would incur in completion of balance contractual obligation of the contract through any other agency and BHEL will not be required to furnish any other evidence to the Supplier/Vendor for the purpose of estimation of damages. - In addition to the above, imposition of liquidated damages, debarment, termination, de-scoping, short-closure, etc., shall be applied as per provisions of the contract. - Non-performance of contract attracts penal provisions in line with BHEL guidelines for Suspension of Business Dealings (SBD). Note: 1) The defaulting Supplier/Vendor shall not be eligible for participation in any of the future enquiries floated by BHEL to complete the balance work. The defaulting contractor shall mean and include: - In case defaulted Supplier/Vendor is the Sole Proprietorship Firm, any Sole Proprietorship Firm owned by same Sole Proprietor. - In case defaulted Supplier/Vendor is The Partnership Firm, any firm comprising of same partners/ some of the same partners; or sole proprietorship firm owned by any partner(s) as a sole proprietor.
28	Any other terms and conditions of the bidder attached / referred against the tender enquiry will not be considered.
29	All drawings, patterns and tools supplied by BHEL or made at BHEL's expense are BHEL's property. These cannot be used or referred to any other party and must be used only in the execution of BHEL's orders.
30	Any amount payable by the bidder under any of the conditions of this contract shall be liable to be adjusted against any amount payable to the bidder under any other work / contract awarded by BHEL HPEP or any other BHEL Units. This is without prejudice to any other action as may be deemed fit by BHEL.

31	The bids of the bidders who are on the banned list and also the bids of the bidders, who engage the services of the banned firms, will be rejected. The list of firms banned by BHEL is available on BHEL web site: www.bhel.com
32	Ordering and confirmation of order
	The bidder shall send the order acceptance within one week from the date of LOI/Purchase order or such other period as specified/agreed by the Buyer. Buyer reserves the right to revoke the order placed if the order confirmation differs from the original order placed. Buyer shall be legally bound, only if agreed for any deviation explicitly in writing. The acceptance of deliverables or supplies by Buyer as well as payments made in this regard shall not imply acceptance of any deviations. The Purchase order will be deemed to have been accepted if no communication to the contrary is received within one week (or the time limit as specified /agreed by the Buyer) from the date of P.O. Buyer, is at liberty to send signed P.O. through electronic media such as e-mail and the receipt of which shall be treated as receipt of order.
33	Execution
	The whole contract is to be executed in the most workman like manner, substantial and approved as per the contracted terms.
34	Progress Report
	The bidder shall render such report as to the progress of work and in such form as may be called for by the Buyer from time to time. The submission and acceptance of such reports shall not prejudice the rights of the buyer in any manner. Bidder shall communicate to BHEL immediately, the change of address, ownership, contact person(s), the mobile numbers and e-mail of the dealing person concerned. Milestones shall be periodically updated by bidder through PRADAN Portal (https://hpep.bhel.com/mm/). Non updation will adversely affect service rating of bidder performance.
35	Non-disclosure Obligations
	Drawings, technical documents or other technical information received by one party shall not without the consent of the other party, be used for any other purpose than that for which they were provided. They may not, without the consent of the submitting party, otherwise be used or copied, reproduced, transmitted or communicated to third parties. All information and data contained in general product documentation, whether in electronic or any other form, are confidential and binding only to the extent that they are by reference expressly included in the contract. The bidder shall, as per agreed date/s but not later than the date of delivery, provide free of charge any information and/or drawings which are necessary to permit the Buyer to erect, commission, operate and maintain the product. Such information and drawings shall be supplied as specified in technical specification. All intellectual properties, including designs, drawings and product information etc. exchanged during the formation and execution of the contract shall continue to be the property of the submitting party. The bidder shall provide Buyer with all information pertaining to the delivery in so far as it could be of importance to Buyer. The bidder shall not reveal confidential information to its own employees not involved with the tender/contract and its execution and delivery or to third parties, unless Buyer has agreed to this in writing beforehand. The bidder shall not be entitled to use the Buyer's name in advertisements and other commercial publications including website without prior written permission from Buyer. In the event of violation of the confidentiality as agreed, BHEL will take legal action as deemed fit. Non-disclosure agreement to be entered as per Annexure- II wherever applicable.
36	Inspection and Testing
A	The goods and stores shall be manufactured by approved quality system and each part/component may be inspected and tested by the Buyer prior to shipment and shall comply with relevant requirements. Buyer has the right to inspect at any stage during manufacture/ delivery.
B	Buyer or his authorized representative shall be entitled at all reasonable times during execution to inspect, examine and test at the bidder's premises the material and workmanship of all stores to be supplied under the contract, and if the part of the stores are being manufactured at other premises, the bidder shall obtain for buyer or his authorized representative permission to inspect, examine and test as if the said stores are being manufactured at the bidder's premises. Such inspection, examination and testing, if made shall not release the bidder from any obligation under the contract. For indigenous bidders all costs related to first inspection request shall be borne by the buyer and the cost of subsequent inspections due to non-readiness of material/rework/ rejections shall be borne by the bidder. In case of imports all inspection charges including third party inspections if any shall be borne by the bidder. The cost of inspection staff/third party specified by the Buyer shall be borne by bidder unless otherwise specifically agreed. If the contract provides for tests on the premises of the bidder or any of his sub-contractor/s, bidder shall be responsible to provide such assistance, labor, materials, electricity, fuels, stores, apparatus, instruments as may be required and as may be reasonably demanded to carry out such tests efficiently. Cost of any type test or such other special tests shall be borne by the bidder unless otherwise specifically agreed in the contract. The Bidder shall give the authorized representative of the buyer reasonable notice in writing of the date on and the place at which any stores will be ready for inspection/ testing as provided in the Contract. Annexure – I, may strictly be complied with for the time lines. Any delay in submission of the documents by the bidder will not alter the delivery date.
37	Quality and Condition of the Deliverables
	The bidder shall be responsible for compliance with applicable technical, safety, quality, environmental requirements and other regulations in relation to products, packaging and raw and ancillary materials.
38	Packaging and Dispatch
	The bidder shall package the deliverables safely and carefully and pack them suitably in all respects considering the

	peculiarity of the material for normal safe transport by sea/air/rail/road to its destination suitably protected against loss, damage, corrosion in transit and the effect of tropical salt laden atmosphere. The packages shall be provided with fixtures/hooks and sling marks as may be required for easy and safe handling by mechanical means. Special packaging conditions/ environmental conditions as defined in the NIT shall be fully complied. Each package must be marked with consignee name, address, P.O. number, Package Number, gross weight & net weight, dimensions (L x B x H) and bidder's name. The packing shall allow for easy removal and checking of goods on receipt and comply with carrier's conditions of packing or established trade practices. Packing list for goods inside each package with P.O. item No. & quantity must also be fixed securely outside the box to indicate the contents. If any consignment needs special handling instruction, the same shall be clearly marked with standard symbols/instructions. Hazardous material should be notified as such and their packing, transportation and other protection must conform to relevant regulations.
39	Contract variations; Increase or decrease in the scope of supply
	Buyer may vary the contracted scope during execution due to exigencies of project requirement. If the bidder is of the opinion that the variation has an effect on the agreed price or delivery period, Buyer shall be informed of this immediately in writing along with technical details, and in the event of additional work, submit a quotation with regards to the price and period involved, as well as the effect this additional work will have on the other work to be performed by the bidder. Wherever unit rates are available in the contract, the same shall be applied to such additional work. The bidder shall not perform additional work before buyer has issued written instructions/amendment to the purchase order to that effect. The work which the bidder should have or could have anticipated in terms of delivering the service (s) and functionality (ies) as described in this agreement should be executed by the bidder without any price implication. In case of no change in the scope / technical specifications, bidder shall endeavor to keep the material ready and intimate the same to BHEL within the contractual delivery date, failing which, the delay if any will be attributed to supplier, and any upward price variation thereof for delivery at a later date is not admissible.
40	Rejected/Short shipments/ warranty/guarantee replacements
	In case of any short shipment during initial supply which is subsequently dispatched by the bidder or any guarantee / warranty replacements shall be dispatched on "DDP-Delivered duty paid BHEL stores" basis for imported items and "FOR-BHEL Stores/designated destination" basis for indigenous items.
41	Export Administration Regulations
	If a delivery includes such technology and / or supply that is subjected to the export regulations the bidder shall obtain due permissions, approvals, license etc.
42	Force Majeure
	The bidder shall not be considered in default if delay occurs due to causes beyond their control such as Acts of God, Natural calamities, Fire, Frost, Flood, Civil War, civil commotion, riot, Government Restrictions. Only those causes that have duration of more than seven days shall be considered cause of force majeure. Notification to this effect duly certified by local chamber of commerce/statutory authorities with supporting documents shall be given by the bidder to BHEL by registered letter/courier service immediately without loss of time. In the event of delay due to such causes the delivery schedule shall be extended for a length of time equal to the period of Force Majeure or at the option of BHEL the order may be cancelled. Such cancellation would be without any liability whatsoever on the part of BHEL. In the event of such cancellation the bidder shall refund any amount advanced or paid to the bidder by BHEL and deliver back any material issued to him by BHEL and release facilities, if any provided by BHEL.
43	Non-waiver of Defaults
	If any individual provision of the contract is invalid, the other provisions shall not be affected.
44	Settlement of Disputes
	Except as otherwise specifically provided in the contract, all disputes concerning questions of the facts arising under the contract, shall be decided by the Buyer, subject to written appeal by the bidder to the buyer, whose decision shall be final. Any disputes of differences shall to the extent possible be settled amicably between the parties thereto, failing which the disputed issues shall be settled through arbitration The bidder shall continue to perform the contract, pending settlement of disputes(s).
45	Conciliation clause
	CONCILIATION CLAUSE FOR CONDUCTING CONCILIATION PROCEEDINGS UNDER THE BHEL CONCILIATION SCHEME, 2018: The Parties agree that if at any time (whether before, during or after the arbitral or judicial proceedings), any Disputes (which term shall mean and include any dispute, difference, question or disagreement arising in connection with construction, meaning, operation, effect, interpretation or breach of the agreement, contract or the Memorandum of Understanding, penalty deduction, time extension), which the Parties are unable to settle mutually, arise inter-se the Parties, the same may, be referred by either party to Conciliation to be conducted through Independent Experts Committee to be appointed by competent authority of BHEL from the BHEL Panel of Conciliators. The proceedings of Conciliation shall broadly be governed by Part-III of the Arbitration and Conciliation Act 1996 or any statutory modification thereof and as provided in Procedure in http://www.bhel.com/index.php/story_details?story=2454 . The Procedure together with its Formats will be treated as if the same is part and parcel hereof and shall be as effectual as if set out herein in this ITB


46	ARBITRATION
	46.1 Except as provided elsewhere in this Contract, in case Parties are unable to reach amicable settlement (whether by Conciliation to be conducted as provided in Clause 45 herein above or otherwise) in respect of any dispute or difference; arising out of the formation, breach, termination, validity or execution of the Contract; or, the respective rights and liabilities of the Parties; or, in relation to interpretation of any provision of the Contract; or, in any manner touching upon the Contract (hereinafter referred to as the 'Dispute'), then, either Party may, refer the disputes to IAMC (International Arbitration and Mediation Centre, Hyderabad) and such dispute to be adjudicated by Sole Arbitrator appointed in accordance with the IAMC Rules. 46.2 A party willing to commence arbitration proceeding shall invoke Arbitration Clause by giving notice to the other party in terms of section 21 of the Arbitration & Conciliation Act, 1996 (hereinafter referred to as the 'Notice') before referring the matter to IAMC. The Notice shall be addressed to the Head of the Unit, BHEL, executing the Contract and shall contain the particulars of all claims to be referred to arbitration with sufficient detail and shall also indicate the monetary amount of such claim including interest, if any. 46.3 After expiry of 30 days from the date of receipt of aforesaid notice, the party invoking the Arbitration shall submit that dispute to IAMC and that dispute shall be adjudicated in accordance with their respective Arbitration Rules. The matter shall be adjudicated by a Sole Arbitrator who shall necessarily be a Retd Judge having considerable experience in commercial matters to be appointed/nominated by the respective institution. The cost/expenses pertaining to the said Arbitration shall also be governed in accordance with the Rules of the respective Arbitral Institution. The decision of the party invoking the Arbitration for reference of dispute to a specific Arbitral institution for adjudication of that dispute shall be final and binding on both the parties and shall not be subject to any change thereafter. The institution once selected at the time of invocation of dispute shall remain unchanged. 46.4 The fee and expenses shall be borne by the parties as per the Arbitral Institutional rules. 46.5 The Arbitration proceedings shall be in English language and the seat and venue of Arbitration shall be Hyderabad. 46.6 Subject to the above, the provisions of Arbitration & Conciliation Act 1996 and any amendment thereof shall be applicable. All matters relating to this Contract and arising out of invocation of Arbitration clause are subject to the exclusive jurisdiction of the Court(s) situated at Hyderabad. 46.7 Notwithstanding any reference to the Designated Engineer or Conciliation or Arbitration herein, a. the parties shall continue to perform their respective obligations under the Contract unless they otherwise agree. Settlement of Dispute clause cannot be invoked by the Contractor, if the Contract has been mutually closed or 'No Demand Certificate' has been furnished by the Contractor or any Settlement Agreement has been signed between the Employer and the Contractor. 46.8 It is agreed that Mechanism of resolution of disputes through arbitration shall be available only in the cases where the value of the dispute is less than Rs. 10 Crores. 46.9 In case the disputed amount Claim, Counter claim including interest is Rs. 10 crores and above, the parties shall be within their rights to take recourse to remedies other than Arbitration, as may be available to them under the applicable laws after prior intimation to the other party. Subject to the aforesaid conditions, provisions of the Arbitration and Conciliation Act, 1996 and any statutory modifications or re-enactment thereof as amended from time to time, shall apply to the arbitration proceedings under this clause. 46.10 In case, multiple arbitrations are invoked (whether sub-judice or arbitral award passed) by any party to under this contract, then the cumulative value of claims (including interest claimed or awarded) in all such arbitrations shall be taken in account while arriving at the total claim in dispute for the subject contract for the purpose of clause 46.9. Disputes having cumulative value of less than 10 crores shall be resolved through arbitration and any additional dispute shall be adjudicated by the court of competent jurisdiction. In the event of any dispute or difference relating to the interpretation and application of the provisions of commercial contract(s) between Central Public Sector Enterprises (CPSEs)/ Port Trusts inter se and also between CPSEs and Government Departments/Organizations (excluding disputes concerning Railways, Income Tax, Customs & Excise Departments), such dispute or difference shall be taken up by either party for resolution through AMRCD (Administrative Mechanism for Resolution of CPSEs Disputes) as mentioned in DPE OM No. 05/0003/2019-FTS-10937 dated 14-12-2022 as amended from time to time.
47	Applicable Laws and jurisdiction of Courts
	This contract shall be governed by the Law for the time being in force in the Republic of India. Subject to clause 46 of this contract, the Civil Court having original Civil Jurisdiction at Hyderabad, shall alone have exclusive jurisdiction in regard to all matters in respect of the Contract."
48	BHEL-Fraud prevention policy shall be adhered to.
	The Bidder along with its associate/ Collaborators/ Sub-contractors/ sub-bidders/ consultants/ service providers shall strictly adhere to BHEL Fraud Prevention policy displayed on BHEL Website http://www.bhel.com and shall immediately bring to the notice of BHEL management about any fraud or suspected fraud as soon as it comes to their notice. List of nodal officers is hosted on BHEL Hyderabad website https://hpep.bhel.com/.
49	Suspected Cartel Formation
	The Bidder declares that they will not enter into any illegal or undisclosed agreement or understanding, whether formal or informal with other Bidder(s). This applies in particular to prices, specifications, certifications, subsidiary contracts, submission or non-submission of bids or any other actions to restrict competitiveness or to introduce cartelization in the bidding process. In case , the Bidder is found having indulged in above activities, suitable action shall be taken by BHEL as per extant policies / guidelines .

50	Treatment of cases regarding conflict of interest: The bidder notes that a conflict of interest would said to have occurred in the tender process and execution of the resultant contract, in case of any of the following situations: i) If its personnel have a close personal, financial, or business relationship with any personnel of BHEL who are directly or indirectly related to the procurement or execution process of the contract, which can affect the decision of BHEL directly or indirectly; ii) The bidder (or his allied firm) provided services for the need assessment/procurement planning of the Tender process in which it is participating; iii) Procurement of goods directly from the manufacturers/ suppliers shall be preferred. However, if the OEM/ Principal insists on engaging the services of an agent, such agent shall not be allowed to represent more than one manufacturer/ supplier in the same tender. Moreover, either the agent could bid on behalf of the manufacturer/ supplier or the manufacturer/ supplier could bid directly but not both. In case bids are received from both the manufacturer/supplier and the agent, bid received from the agent shall be ignored. However, this shall not debar more than one Authorized distributor (with/ or without the OEM) from quoting equipment manufactured by an Original Equipment Manufacturer (OEM) in procurements under a Proprietary Article Certificate. iv) A bidder participates in more than one bid in this tender process. Participation in any capacity by a Bidder (including the participation of a Bidder as a partner/ JV member or sub-contractor in another bid or vice-versa) in more than one bid shall result in the disqualification of all bids in which he is a party. However, this does not limit the participation of an entity as a subcontractor in more than one bid if he is not bidding independently in his own name or as a member of a JV. The Bidder declares that they have read and understood the above aspects, and the bidder confirms that such conflict of interest does not exist and undertakes that they will not enter into any illegal or undisclosed agreement or understanding, whether formal or informal with other Bidder(s), in this regard. This applies in particular to prices, specifications, certifications, subsidiary contracts, submission or non-submission of bids or any other actions to restrict competitiveness or to introduce cartelization in the bidding process. In case, the Bidder is found having indulged in above activities, the same will be considered as a violation of the tender conditions, and suitable action shall be taken by BHEL as per extant policies/guidelines.																	
51	Escalation Matrix <table border="1" data-bbox="258 1133 1925 1383"> <thead> <tr> <th>Details</th><th>Name</th><th>Contact Number</th></tr> </thead> <tbody> <tr> <td>Authorised representative</td><td></td><td></td></tr> <tr> <td>Technical In-charge</td><td></td><td></td></tr> <tr> <td>Finance and Taxation</td><td></td><td></td></tr> <tr> <td>Escalation for above</td><td></td><td></td></tr> </tbody> </table>			Details	Name	Contact Number	Authorised representative			Technical In-charge			Finance and Taxation			Escalation for above		
Details	Name	Contact Number																
Authorised representative																		
Technical In-charge																		
Finance and Taxation																		
Escalation for above																		
52	Grievance Redressal Mechanism To promote transparency and ensure fair treatment of all bidders, a structured Grievance Redressal Mechanism is in place to address any concerns or issues arising during the tendering process or in subsequent business dealings with the company. Suppliers/Contractors are requested to follow the below escalation process for grievance resolution: 1. First Level: Any grievance should initially be addressed to the designated Dealing Officer, whose contact details are provided in the Notice Inviting Tender (NIT)/Contract. 2. Second Level: If the issue remains unresolved, it may be escalated by lodging a formal grievance through the SUVIDHA Portal: https://suvidha.bhel.in/suvidha/ . Responses will be provided in accordance with the defined escalation matrix."																	
53	Third Party Inspection: (Mandatory) <table border="1" data-bbox="258 1792 1925 2214"> <tbody> <tr> <td data-bbox="258 1792 1087 1976"> a) For Indian vendors: Third party inspection by M/s. TUV SUD (or) M/s. QUEST TPI charges by BHEL-Hyd. </td><td data-bbox="1087 1792 1925 1976"></td></tr> <tr> <td data-bbox="258 1976 1087 2214"> b) For Foreign vendors: Third party inspection by M/s. LLOYDS REGISTER / BEREAU VERITAS / DNV / TUV TPI charges shall be included in quoted prices. </td><td data-bbox="1087 1976 1925 2214"></td></tr> </tbody> </table>			a) For Indian vendors: Third party inspection by M/s. TUV SUD (or) M/s. QUEST TPI charges by BHEL-Hyd.		b) For Foreign vendors: Third party inspection by M/s. LLOYDS REGISTER / BEREAU VERITAS / DNV / TUV TPI charges shall be included in quoted prices.												
a) For Indian vendors: Third party inspection by M/s. TUV SUD (or) M/s. QUEST TPI charges by BHEL-Hyd.																		
b) For Foreign vendors: Third party inspection by M/s. LLOYDS REGISTER / BEREAU VERITAS / DNV / TUV TPI charges shall be included in quoted prices.																		
54	For Foreign Bidders only: (Confirm the following) a) Name of the bid currency : b) Name of the port of loading.																	
55	RAW MATERIAL : Indicate the source of Raw material																	
56	The price quoted in your offer is firm and final, inclusive of all applicable charges, costs, duties, taxes, packing, forwarding, freight, inspection, testing, documentation and any other incidental charges, as applicable. No additional charges over and above the total quoted amount shall be payable by BHEL during execution of the order.																	



57	Delivery period: Required delivery in 150 days from the date of PO	
58	BHEL SPECIFICATIONS: Vendor shall confirm total compliance to BHEL specifications mentioned against each item of the enquiry. Deviations if any shall be brought out in their technical offer. Otherwise, it will be presumed that offered items will be complying to specs mentioned in the enquiry.	
59	In the event and to the extent of any inconsistency between two or more documents which form part of this enquiry, those documents will be interpreted in the following order of priority: i. Enquiry ii. ITB iii. Vendor quotation	

(BEARING SPAN) 7000




TECHNICAL REQUIREMENTS:

- 1) ROTOR FORGING IS TO BE SUPPLIED AS PER PURCHASE SPECIFICATION NO. HY19473
- 2) ALL UNMENTIONED RADII =R10
- 3) T = TANGENTIAL TEST PIECE Q = RADIAL TEST PIECE
4. THE THERMAL STABILITY TEST SHALL BE DONE AS PER HW0850197

M1 M2 M3 MEASURING LOCATIONS FOR THERMAL STABILITY TEST.
EXACT LOCATION FOR MEASURING IS TO BE DECIDED BY THE SUPPLIER.

DETAIL- X



GENERAL DIMENSIONAL LIMITS,FITS & TOLERANCES AS PER HY0230261

INVENTORY NO		SIGN. AND DATE		REF. DRG NO 3-303-01-20154 1-303-01-20066		COMPUTER FILE NAME		THE INFORMATION ON THIS DOCUMENT IS THE PROPERTY OF BHARAT HEAVY ELECTRICALS LIMITED. IT MUST NOT BE USED DIRECTLY OR INDIRECTLY IN ANY WAY DETRIMENTAL TO THE INTEREST OF THE COMPANY			
F		E		D		C		B		A	
1		2		3		4		5		6	
REV.		DATE		REV.		DATE		REV.		DATE	
CHD/APPD		CHD/APPD		CHD/APPD		CHD/APPD		CHD/APPD		CHD/APPD	
ZONE		ZONE		ZONE		ZONE		ZONE		ZONE	
1		2		3		4		5		6	
7		8		9		10		11		12	
13		14		15		16		17		18	
19		20		21		22		23		24	
25		26		27		28		29		30	
31		32		33		34		35		36	
37		38		39		40		41		42	
43		44		45		46		47		48	
49		50		51		52		53		54	
55		56		57		58		59		60	
61		62		63		64		65		66	
67		68		69		70		71		72	
73		74		75		76		77		78	
79		80		81		82		83		84	
85		86		87		88		89		90	
91		92		93		94		95		96	
97		98		99		100		101		102	
103		104		105		106		107		108	
109		110		111		112		113		114	
115		116		117		118		119		120	
121		122		123		124		125		126	
127		128		129		130		131		132	
133		134		135		136		137		138	
139		140		141		142		143		144	
145		146		147		148		149		150	
151		152		153		154		155		156	
157		158		159		160		161		162	
163		164		165		166		167		168	
169		170		171		172		173		174	
175		176		177		178		179		180	
181		182		183		184		185		186	
187		188		189		190		191		192	
193		194		195		196		197		198	
199		200		201		202		203		204	
205		206		207		208		209		210	
211		212		213		214		215		216	
217		218		219		220		221		222	
223		224		225		226		227		228	
229		230		231		232		233		234	
235		236		237		238		239		240	
241		242		243		244		245		246	
247		248		249		250		251		252	
253		254		255		256		257		258	
259		260		261		262		263		264	
265		266		267		268		269		270	
271		272		273		274		275		276	
277		278		279		280		281		282	
283		284		285		286		287		288	
289		290		291		292		293		294	
295		296		297		298		299		300	
301		302		303		304		305		306	
307		308		309		310		311		312	
313		314		315		316		317		318	
319		320		321		322		323		324	
325		326		327		328		329		330	
331		332		333		334		335		336	
337		338		339		340		341		342	
343		344		345		346		347		348	
349		350		351		352		353		354	
355		356		357		358		359		360	
361		362		363		364		365		366	
367		368		369		370		371		372	
373		374		375		376		377		378	
379		380		381		382		383		384	
385		386		387		388		389		390	
391		392		393		394		395		396	
397		398		399		400		401		402	
403		404		405		406		407		408	
409		410		411		412		413		414	
415		416		417		418		419		420	
421		422		423		424		425		426	
427		428		429		430		431		432	
433		434		435		436		437		438	
439		440		441		442		443		444	
445		446		447		448		449		450	
451		452		453		454		455		456	
457		458		459		460		461		462	
463		464		465		466		467		468	
469		470		471		472		473		474	
475		476		477		478		479		480	
481		482		483		484		485		486	
487		488		489		490		491		492	
493		494		495		496		497		498	
499		500		501		502		503		504	
505		506		507		508		509		510	
511		512		513		514		515		516	
517		518		519		520		521		522	
523		524		525		526		527		528	
529		530		531		532		533		534	
535		536		537		538		539		540	
541		542		543		544		545		546	
547		548		549		550		551		552	
553		554		555		556		557		558	
559		560		561		562		563		564	
565		566		567		568		569		570	
571		572		573		574		575		576	
577		578		579		580		581		582	
583		584		585		586		587		588	
589		590		591		592		593		594	
595		596		597		598		599		600	
601		602		603		604		605		606	
607		608		609		610		611		612	
613		614		615		616		617		618	
619		620		621		622		623		624	
625		626		627		628		629		630	
631		632		633		634		635		636	
637		638		639		640		641		642	
643		644		645		646		647		648	
649		650		651		652		653		654	
655		656		657		658		659		660	
661		662		663		664		665		666	
667		668		669		670		671		672	
673		674		675		676		677		678	
679		680		681		682		683		684	
685		686		687		688		689		690	
691		692		693		694		695		696	
697		698		699		700		701		702	
703		704		705		706		707		708	
709		710		711		712		713		714	
715		716		717		718		719		720	
721		722		723		724		725		726	
727		728		729		730		731		732	
733		734		735		736		737		738	
739		740		741		742		743		744	
745		746		747		748		749		750	
751		752		753		754		755		756	
757		758		759		760		761		762	
763		764		765		766		767		768	
769		770		771		772		773		774	
775		776		777		778		779		780	
781		782		783		784		785		786	
787		788		789		790		791		792	
793		794		795		796		797		798	
799		800		801		802		803		804	
805		806		807		808		809		810	
811		812		813		814		815		816	
817		818		819		820		821		822	
823		824		825		826		827		828	
829		830		831		832		833		834	
835		836		837		838		839		840	
841		842		843		844		845		846	
847		848		849		850		851		852	
853		854		855		856		857		858	
859		860		861		862		863		864	
865		866		867		868		869		870	
871		872		873		874		875		876	
877		878		879		880		881		882	
883		884		885		886		887		888	
889		890		891		892		893		894	
895		896		897		898		899		900	
901		902		903		904		905		906	
907		908		909		910		911		912	
913		914		915		916		917		918	
919		920		921		922		923		924	
925		926		927		928		929		930	
931		932		933		934		935		936	

 TD219 Rev.00	PLANT PURCHASING SPECIFICATION HYDERABAD	HY 194 73 REV. NO. 04 PAGE 1 OF 7
<u>ALLOY STEEL FORGINGS FOR STEAM TURBINE ROTORS</u> <u>GR: 30 Cr Mo Ni V 511</u> (Material No.1.6946)		
1.0 GENERAL:	This specification governs the technical requirements of steam turbine rotors forged out of steel grade 30 Cr Mo Ni V 511.	
2.0 APPLICATION:	Steam turbine rotors having diameters up to 1500 mm	
3.0 CONDITION OF DELIVERY:	The rotor forgings shall be supplied in vertically heat treated and rough machined condition.	
4.0 DIMENSIONS AND TOLERANCES:	The rotor forgings shall be supplied to the dimensions shown on the ordering drawing. The tolerance shall be as follows unless otherwise specified in the drawing/order. Upto 500 mm : + 1 mm Over 500 mm : + 2 mm	
5.0 MANUFACTURE :	5.1 The steel shall be made from basic electric furnace and shall be subsequently refined by Vacuum Carbon Deoxidation (VCD) or Electro Slag refining (ESR) process. 5.2 Sufficient discard from Top and Bottom shall be made from the ingot to ensure freedom from piping, segregation and other injurious defects. 5.3 The forging process adopted shall ensure homogeneity of material throughout the section. 5.4 It is important to maintain the actual centre of the forging, as far as possible identical with the center of the ingot. 5.5 Press straightening, if necessary, may be performed before heat-treatment. 5.6 The material as per this specification shall be supplied by the manufacturers who are having complete in-house steel melting, refining, hot rolling/forging/blooming/etc., heat treatment and testing facilities.	
Revisions: Modified Cl. No. 6 (Added note for permitting Cr content upto 2.00% max. for forgings of 1400-1500mm Diameter)		Issued : STANDARDS ENGINEERING & IPR COORDINATION DEPARTMENT
Rev. No. 04	Amd. No.	Reaffirmed:
Dt. APR. 2014	Dt.	Year : 2021
Prepared: MALTS. ENGG.		Approved: AGM(E&CC)
Dt. of 1st Issue		SEP . 1993

HY 194 73	PLANT PURCHASING SPECIFICATION HYDERABAD	TD219 Rev.00	
REV. NO. 04			
PAGE 2 OF 7			

5.7 CLOCKING SYMBOL :

Before heat-treatment, clocking symbols 3-6-9-12 shall be stamped on the rotor. If the symbols are transferred during manufacture, they shall be re-stamped in the same clock wise position. The clocking symbols shall be used for reference purposes in recording the position of defects, etc. The clocking symbols shall be encircled with oil paint for easy identification.

5.8 After heat-treatment, the forging shall be rough machined to the dimensions and surface finish shown on the ordering drawing.

5.9 If the manufacturer has not supplied the forgings as per the ordering drawing in the past, a new Manufacturing and Inspection Sequencing plan (MIP) in accordance to the specification HY 0652099 of BHEL Hyderabad shall be submitted for review & approved by BHEL. Same can be used till there are no changes in the manufacturing process and the facilities used for the manufacture of the forging.

6.0 CHEMICAL COMPOSITION:

The chemical composition of the material shall be as follows:

Element		C	Si	Mn	Cr*	Mo	Ni	V	P	S	Al (Total)
VCD Process	Min.	0.27	-	0.30	1.10	1.00	0.50	0.25	-	-	-
	Max.	0.31	0.10	0.80	1.40	1.20	0.75	0.35	0.007	0.007	0.008
ESR process	Min	0.27	-	0.30	1.10	1.00	0.50	0.25	-	-	-
	Max	0.31	0.20	0.80	1.40	1.20	0.75	0.35	0.007	0.005	0.010

*** Note:** For rotor forgings from 1400-1500 mm diameter, Cr content upto 2.00 % maximum is permitted.

Tramp Elements: The tramp elements shall be within following limits.

Cu = 0.12 max. ; As = 0.02 max.; Sb = 0.02 max. ; Sn = 0.015 max.

Small deviations in chemical composition are permissible only after approval from BHEL, provided that the specified properties are not impaired.

7.0 HEAT TREATMENT:

7.1 The rotor forging shall be heat treated vertically followed by oil or mist quenching. The heat treatment shall be done to obtain tempered upper bainitic structure uniformly through-out the cross section free of ferrite in the centre. The hardening temperature shall be between 940°C and 960°C but 950°C shall be the target. The tempering cycle shall be selected suitable to achieve the 0.2 % yield strength with the possible toughness and minimum residual stresses in the forging. It shall between 690 °C and 710°C.

At the option of the manufacturer, the rotor forgings may be suitably stress relieved (in vertical condition only) so as to achieve the residual stresses within the limits specified in Cl. 8.0.

Actual heat treatment cycles followed shall be reported in test certificate.

7.2 In case the required properties have not been obtained, reheat-treatment of the forging is to be carried out. The maximum number of reheat-treatment permitted is two. However, re-tempering is not considered as reheat treatment.



TD219
Rev.00

PLANT PURCHASING SPECIFICATION HYDERABAD

HY 194 73

REV. NO. 04

PAGE 3 OF 7

8.0 RESIDUAL STRESS MEASUREMENT:

8.1 The residual stress measurement shall be carried out as per BHEL Corporate Standard AA0850150. In lieu of BHEL standard AA0850150, residual stress measurement may be carried out by 'Blind hole method' as per ASTM E 837. However, all the other conditions of AA0850150 such as location of tests, acceptance criteria etc. remain same.

8.2 Additionally, for the rotors having barrel diameter up to 500 mm & length up to 1700 mm, Residual stress measurement by Ring cutting method is also acceptable. However, the rings shall be cut from T1 & T2 locations specified on the ordering drawing. The residual stresses shall not be more than 45 N/mm². The procedure for carrying out RSM by ring cutting method shall be submitted by the vendor for approval by BHEL Hyderabad.

9.0 SELECTON OF TEST SAMPLES:

9.1 The location of the test pieces shall be shown on the ordering drawing. The test samples shall not be removed before heat treatment of the rotor forging. However the method of removal of the test pieces is left to the discretion of the supplier.

9.2 The test samples shall be identified according to the locations specified in the ordering drawing. The test shall be carried out on the above identified samples and the balance test pieces (duly identified) shall be sent to BHEL for further testing.

10.0 MECHANICAL PROPERTIES:

10.1 The mechanical properties, when tested on the tangential or radial test pieces shall conform to the following at room temperature.

Tensile Strength N/mm ² Max.	0.2% proof Stress N/mm ²	% Elongation L=5d Min.	% Reduction in area Min.	Impact Strength J Min.
850	550 - 700	15	40	24

10.2 Axial core testing: If specified on the ordering drawing, axial trepanned core shall be tested in accordance with the standard AA0850155 and the following properties shall be obtained on the samples taken in radial direction.

0.2% Proof Stress : 530 N/mm² min.

Impact Strength : 55 J min. at +80° C
(Average of 3 samples)
ISO-V notch

FATT : ≤ +80° C,

T: Tangential Test piece, Q: Radial test piece.

The axial core shall be clearly marked, so that its original position can be easily identified with respect to the shaft. The stamp of the manufacturer's authorized inspector close to the identification number shall confirm traceability of the trepanned core to the forging.

HY 194 73	PLANT PURCHASING SPECIFICATION HYDERABAD	TD219 Rev.00	
REV. NO. 04			
PAGE 4 OF 7			

Note: a) Tensile test shall be carried out as per IS: 1608 or any National Standard.

b) Impact test shall be carried out as per IS: 1757 ISO-V notch or any National standard. The minimum impact strength value specified above is the average of three samples at the same location. Only one value is permitted below the specified min. value, but in no case shall be lower than the 2/3 of the same. All values shall be reported in test certificate.

11.0 NON-DESTRUCTIVE TESTS:

11.1 Ultrasonic Test:

Ultrasonic test and evaluation shall be carried out as per BHEL Corporate Standard AA0850106.

11.2 Magnetic particle test:

Magnetic particle test and evaluation shall be carried out as per BHEL Corporate Standard AA0850106.

12.0 METALLOGRAPHIC TEST:

Metallographic test shall be conducted on samples taken from broken tensile test pieces. The photo micrographs at 500X shall show tempered upper bainitic structure and the photomicrograph (original) shall be submitted to BHEL along with test certificates.

13.0 THERMAL STABILITY TEST:

If specified in the ordering drawing, thermal stability shall be carried out according to BHEL Standard AA0850152.

14.0 FIRST PIECE QUALIFICATION TESTS:

Whenever the supplies are made for the first time to BHEL, the requirements of BHEL specification HY0800099 shall also be applicable in addition to this specification.

15.0 INSPECTION AT SUPPLIER'S WORKS:

BHEL representative shall have all reasonable facilities offered to him, at any time, by the supplier to satisfy himself that the material is being furnished in accordance with this specification. The representative shall have free access at all times while the work on the contract is being performed, to all parts of the manufactures works.

16.0 QUALITY PLAN:

16.1 Vendor shall follow the Quality Plan Ref. BHEL/QP/HY19473 Rev.04 attached as Annexure 'A' unless conditions stipulated in Cl.16.2 & 16.3 are applicable.

16.2 In case Customer / Project related additional requirements are applicable in the enquiry / tender, vendor may be asked to submit a separate QP including such requirements.

16.3 In case of new vendors or first time supplies according to drawings mentioned in BHEL enquiry, a separate QP shall be submitted for approval by BHEL.

	TD219 Rev.00	PLANT PURCHASING SPECIFICATION HYDERABAD	HY 194 73
			REV. NO. 04
			PAGE 5 OF 7

17.0 TEST CERTIFICATE:

17.1 Five copies of test certificates (in English) giving the following details shall be furnished.

- a) HY 19473 Rev .04
- b) BHEL Order No.
- c) Item Description and Drawing No. of the forging.
- d) Supplier's Name.
- e) Melt No. and Forge No. (Steel making & refining processes)
- f) Results of chemical analysis alongwith trace elements.
- g) Results of Mechanical Tests & FATT (if applicable)
- h) Results of residual stresses.
- i) Report of ultrasonic testing giving details of probe type and size, frequency, sensitivity, sketch showing the areas covered etc.
- j) Report of Metallographic test alongwith microphotographs (original).
- k) Actual Heat treatment charts
- l) Results of thermal stability test, if called for in the drawing/purchase order.
- m) Report magnetic particle inspection.
- n) Copy of approved MIP duly attested by BHEL Hyderabad.

17.2 The certificate shall be attested by chief of inspection/chief metallurgist of the supplier and BHEL representative.

18.0 MARKING:

The following details shall be punched clearly on one end of the forging.

- a) HY 19473 Rev.04
- b) Forging No. and Melt No.
- c) Drawing NO.
- d) Manufacturer's Stamp.
- e) BHEL Inspector's stamp
- f) Clocking symbols.
- g) Top and Bottom sides of ingot.

19.0 PACKING AND TRANSPORTATION:

Rotor forgings shall be properly protected from corrosion and damage during transit, journal portions shall be protected with anti-corrosive compound.

20.0 REJECTION AND REPLACEMENT:

In the event of any forging proving defective in machining, testing erection and operation such forging shall be rejected notwithstanding any previous acceptance. The supplier shall replace the rejected forging at his own cost.

ANNEXURE A (as per clause 16.0)									HY19473REV.04 PAGE 6 OF 7			
Vendor's Name & Address				Customer:			BHEL ENQ. NO.		QP No. BHEL/HY19473 Rev.04			
				Project:			Date:		Page: 1 of 2			
				Product:			BHEL Spec. HY19473 Rev.04					
Sl. No.	Component Operation	Characteristics	Class	Type of Check	Quantum	Reference Document	Acceptance Norms	Format of records	AGENCY			Remarks
									P	W	V	
1.	Melting	Chemical composition	Critical	Chemical	100%	Vendors standard	HY19473Rev.04	TC	2	-	1	Steel melting & refining process shall be specified in TC
2.	Forging	Forging Steps	Major	Visual	100%	-do-	BHEL approved MIP	TC	2	-	1	Overall reduction ratio shall be mentioned in TC
3.	Preliminary Heat Treatment	Time Temp. Control	Major	Measure	100%	-do-	-do-	Internal Record	2	-	1	
4.	Marking of Clocking Symbols		Major		100%	BHEL Drawing & Spec.	BHEL Drawing & Spec.		2	1	-	
5.	Quality Heat Treatment (in vertical condition)	Time Temp. Control	Major	Measure	100%	BHEL Drawing & Spec.	BHEL Drawing & Spec.	TC	2	-	1	
6.	Ultrasonic test & Magnetic particle test	Ultrasonic test & Magnetic particle test	Major	Internal Defects	Whole volume/ surface of the forging	BHEL Drawing & Spec.	BHEL Drawing & Spec.	TC	2	1	-	
7.	Residual Stress Measurement	Residual Stress Testing	Major	Internal stresses	Each rotor	BHEL Drawing & Spec.	BHEL Drawing & Spec.	TC	2	1	-	
8.	Sampling for Mechanical Testing		Major		As per drg.	BHEL Drawing & Spec.	BHEL Drawing & Spec.		2	1	-	
9.	Mechanical Testing & Metallography	Tensile test Impact test Microstructure	Major	Mechanical & Metallography	Each rotor	BHEL Drawing & Spec.	BHEL Drawing & Spec.	TC	2	1	-	
10.	Trepanning of Axial core		Major			BHEL Drawing & Spec.	BHEL Drawing & Spec.		2	-	-	If specified on the ordering drg.
11.	Axial Mechanical Test	Tensile test Impact test , FATT & Microstructure	Major	Core properties	As per drg. & BHEL Spec	BHEL Drawing & Spec.	BHEL Drawing & Spec.	TC	2	1	-	If specified on the ordering drg.

ANNEXURE A (as per clause 16.0)									HY19473 REV.04 PAGE 7 OF 7			
Vendor's Name & Address				Customer:			BHEL ENQ. NO.		QP No. BHEL/HY19473 Rev.04			
				Project:			Date:		Page: 2 of 2			
				Product:			BHEL Spec. HY19473 Rev.04					
Sl. No.	Component Operation	Characteristics	Class	Type of Check	Quantum	Reference Document	Acceptance Norms	Format of Records	AGENCY			Remarks
									P	W	V	
12.	Thermal stability test	Dimensions	Major	Heat stability of rotor	Each rotor as per drg.	BHEL Drawing & Spec.	BHEL Drawing & Spec.	TC	2	-	1	If specified on the ordering drg.
13.	Boroscopic & MPI of Axial Bore	Boroscopic & Magnetic particle test	Major	Boroscopic & MPI	100%	BHEL Drawing & Spec.	BHEL Drawing & Spec.	TC	2	1	-	If axial bore test specified on the drg.
14.	Plugging of Axial Bore			Visual check	Each rotor	BHEL Drawing & spec.	BHEL Drawing & Spec.		2	-	-	If axial bore test specified on the drg.
15.	Finish Machining	Dimensions	Major	Measure	100%	Drawing	Drawing	TC	2	1	-	
16.	Completeness of documents, test certificates, HT charts etc.		Major	Verification	Each rotor	BHEL Drawing & spec.	BHEL Drawing & Spec.	Endorsement by TPIA on all documents	2	-	1	
17.	Marking preservation & Packing	Marking Preservation & packing	Major	Visual check	100%	BHEL drawing & spec.	BHEL drawing & spec.		2	-	1	

Legend: P Perform ;W Witness ;V Verification ; Indicate 1 for BHEL or BHEL nominated inspection agency & 2 for vendor / sub vendor as appropriate against each component / characteristic under P, W & V columns.

Signature of the supplier with Company Stamp
(To be submitted along with the technical offer)

PRE-QUALIFYING CRITERIA FOR PROCUREMENT OF ST ROTOR FORGING:

Enquiry No.

Scope of supply:

Supply of steam turbine rotor forging shall be as per the following applicable documents.

- a) Rotor Forging as per drawing no. mentioned in the enquiry.
- b) Weight / size of rotor forging (in rough machined condition as per above Drawing No.)
- c) Material specification HY19473 Rev. 04
- d) Manufacturing and Inspection sequencing plan standard: HY 0652099, Rev. 00
- e) Supply condition as per HY19473 Rev 04 & Ordering drawing
- f) Applicable NDT standard: AA0850106, Rev. 01
- g) Mechanical test standard: ASTM A 370 or any equivalent National or International standard (latest version)
- h) Residual Stress Measurement standard: AA0850150 Rev 00
- i) Thermal Stability Test standard: AA0850151 Rev 02 or AA0850152 Rev 00
- j) QA plan Ref: BHEL/HY19473 Rev. 04 (with additional tests as per this PQC)

Pre-Qualification Criteria is as follows:

A. Manufacturing and Test Facilities:

Vendor shall have following in-house manufacturing & testing facilities for the manufacture of turbine rotor forgings, as a minimum requirement,

- a) Steel melting including refining facility.
- b) Forging press with required capacity
- c) Vertical heat treatment facility for rotor (Indicating max dia & length)
- d) Testing Facilities like Mechanical, UT, MPI, etc.

In addition to above in-house facilities, vendor shall also have the following facilities like Thermal stability facility at temperature $\geq 660^{\circ}\text{C}$, Axial core trepanning facility & Machining as per enquiry drawing and specification. (These processes can be outsourced to competent agencies and details of their facility at outsourced agencies to be submitted).

Vendor has to submit filled annexure 1 for in house manufacturing and testing facilities.

B. Manufacturing Experience:

B.1 Vendor must have supplied minimum three rotor forgings for Steam Turbines applications and is to be furnished in the format given below.

Sl.NO	Purchase order number /customer details	Material Grade	Dimension: diameter (max) & length	Delivered weight	Year of supply
1					
2					
3					

The above data is required to ascertain the steel melting and forging capability of the vendor.

Note: Evidence of the dispatched rotors of above forgings (preferably Material Test Certificate copies) shall be submitted.

B.2 Experience for supply of minimum 3 Rotor forgings for same or higher weights of **high temperature applications of Creep resistant material grades** and are suitable for Steam Turbine applications shall be furnished in the format given below:

Sl.NO	Purchase order number /customer details	Material grade	Dimension: diameter (max) & length	Delivered weight	Year of supply
1					
2					
3					

The above data is required to ascertain the Heat treatment (Vertical) capability of the vendor.

Note: Evidence of the dispatched rotors of above forgings (preferably Material Test Certificates copies) shall be submitted.

C. Vendor to confirm supply shall be as per BHEL enquiry drawing and specification and all cross-referred documents referred there in. Pointwise confirmation to BHEL specification shall be provided.

Annexure 1

Vendor to submit details of manufacturing and testing facilities as per format below:

STEEL MELTING FACILITIES:

Melting furnaces details (type, capacity etc.)	
Refining facility details (vacuum degassing, ESR, etc)	
Maximum ingot size - Diameter [mm] - Length [mm] - Weight [mm]	

FORGING FACILITY:

Press capacity in KN	
Max. forging weight in MT	
Manipulator Capacity	
Remarks:	

Heat treatment facilities

1. Availability of vertical heat treatment facility for heat treatment of rotor	
2. Maximum diameter, length and weight of shaft which can be vertically heat treated	
3. Quenching type & medium	

Testing facilities:

1. Chemical analysis , tensile testing, impact, micro-examination etc.	
2. NDT facilities- UT,MPI, boroscopic, residual stress measurement etc	

Machining facilities:

Facility for axial core trepanning 1. minimum & maximum diameter of the core which can be trepanned 2. maximum length of axial core that can be trepanned	
Surface finish of axial bore (Specify achievable value)	
Concentricity, cylindricity and parallelity to achieve drawing requirements.	

Heat stability testing facilities

Max. diameter of forging Max. length of forging Max. weight of forging Max. testing temperature	
--	--

Note: The manufacturer shall submit the above information in English with relevant evidences, duly signed and company stamped.

This document shall be provided by the manufacturer only. Documents with the sign and stamp of marketing agent's/representatives companies is not acceptable.

(Sign and seal of Manufacturer)



Annexure-I				
Major Activity timelines shall be considered for indigenous purchases				
S No	Activity	Agency	Timeline	Acceptance / Remarks
1	PO acknowledgement	Vendor	04 days from the date of receipt of PO	
2	First submission of Drawings, Data sheets and QP Rev-00	Vendor	15 days from receipt of PO	
3	commented / approved drawings / data sheets and QP to vendor	BHEL/Customer	07 days from the receipt of Rev-00 submission.	
4	Subsequent submission of revised drawings / data sheets and QP	Vendor	07 days from the receipt of commented drawings / data sheets and QP	
5	Subsequent Approved /commented Drawings and QP to vendor	BHEL/Customer	07 days from the date of receipt of revised drawings / data sheets and QAP.	
6	Raising of Inspection Call	Vendor	07 days before the proposing inspection date. (BHEL will provide approved QP before raising inspection call)	
7	Inspection completion	BHEL Third party inspection agency / Customer	07 days from inspection call date.	
8	Despatch Instructions	BHEL	07 days from the date of receipt of final approved inspection report to BHEL.	
9	Receipt of Material at BHEL stores/ site	Vendor	15 days from Despatch instructions	

Absence of this annexure in NIT will entail non processing of delivery extension cases in case of delay in supplies of goods owing to reason attributable to BHEL.

Vendor's Signature



ANNEXURE IV

Proforma for self-certification by Supplier for Compliance to below Clause

Clause: Any Bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with competent authority. <https://www.mea.gov.in/> to be referred for latest details of competent authority and exemptions.

I have read the clause regarding restrictions on procurement from a bidder of a country which shares a land border with India and I certify that M/s _____ **(Name of firm)**

(Tick the Appropriate)

☐

Is not from such a country

☐

Is from such a country and has been duly registered with the Competent

authority. (If, Yes Please enclose the Approval obtained from Competent Authority)

I hereby certify M/s _____ **(Name of firm)** fulfills all requirements in this regard and is eligible to be considered (where applicable, valid registration by the competent authority shall be attached)

Sd/-
Authorized Signatory with Stamp

(To be executed on Non- Judicial Stamp Paper for an appropriate value.
To be stamped as an agreement)

(For Suppliers on Unit's / Division's PMD)

ANNEXURE-II

Framework Confidentiality Agreement Cum Undertaking

This Agreement made on this the _____ day of (month) _____ 20 ____ ("Effective Date") by and between M/s. BHARAT HEAVY ELECTRICALS LIMITED, having registered office at "BHEL House", Siri Fort, New Delhi – 110049 (India), acting through its _____ Unit (hereinafter may be referred to as "BHEL" or "the company").

And

M/s. _____ (address) _____
represented by authorized representative Sri _____ (herein after referred to as the "Supplier").

The supplier and the company may, unless the context otherwise requires, hereinafter be collectively referred to as "Parties" or singly as the "Party".

RECITALS

Whereas, BHEL is engaged in the design, engineering, manufacturing, construction, testing, commissioning and servicing of a wide range of products, systems and services for the core sectors of the economy, viz. Power, Transmission, Industry, Transportation, Renewable energy, Oil & Gas and Defence and providing associated services to varied customers in relation to which BHEL / its affiliates own valuable information of a secret and confidential nature.

Whereas the Company may, in connection with contract(s) (as defined hereunder) placed or to be placed upon the supplier, or otherwise, from time to time, make available, Technical Information as is defined hereunder.

And Whereas BHEL is willing to provide such Technical Information to the Supplier from time to time and the Supplier understands and acknowledges that such Technical Information is valuable for the Company and as such is willing to protect confidentiality of such information, subject to the terms and conditions set out hereunder.

Now therefore, in view of the foregoing premises and in consideration of the mutual covenants and agreements hereinafter set forth, the parties agree as under:

1. Definitions:

Unless the context so requires, in this Agreement, the following terms will bear the meaning ascribed to the said term in this clause.

- A. **“Contract”** means the contract entered into with a supplier and includes a Purchase Order, or a Work Order for procurement of any goods or for provision of any services.
- B. **“Effective Date”** means the date of this Agreement as mentioned in the preamble of this Agreement.
- C. **“Supplier”** includes a Contractor or a Vendor of the Company whether for supplying of goods or for providing any services under a Contract or both.
- D. **“Technical Information”** includes Drawings, and / or Product Standards and / or Specifications and / or Corporate / Plant Specifications and / or Technological Process Sheets and / or Technical Data Sheets and / or Jigs & Fixtures and / or Pattern & Dies and / or Special Gauges and / or Tools etc. Belonging to or wherein the Company has acquired from a third party a right of user and includes any improvement thereto from time to time whether carried out by the Company or by the Suppliers.
- E. **“Intended Purpose”** means the purpose for which the Technical Information is provided to the supplier under or in connection with a contract.
- F. **“Improvement”** includes any modification made to, or adaptation of, the Technical Information which enhances or is calculated to enhance the performance (Whether in terms of effectiveness or in terms of efficiency or both) of the product and / or the service to be provided by the Supplier under a Contract.

2. This Agreement shall come into force / deemed to have come into force, as the case may be, on the Effective Date; or, on the first date when the Technical Information or any part thereof is provided by BHEL to the supplier; whichever is earlier.

3. **Agreement deemed to be incorporated in each contract:** Unless and to the extent otherwise stipulated in the Contract, the conditions of this Agreement are deemed to be incorporated in all Contracts which may be entered into between the Company and the Supplier. Further, unless otherwise stipulated, the obligations under this Agreement are and will be independent of the obligations under the Contracts and such obligations of the Supplier hereunder will remain of full effect and validity notwithstanding that the period of validity of the Contract has expired by efflux of time stipulated therein; or, the contract has been discharged by performance or breach; or, the termination of the Contracts for any reason whatsoever.

4. **Ownership:**

4.1 The Company may, from time to time, make available to the Supplier, Technical Information on a non-exclusive basis by way of loan.

4.2 The Supplier acknowledges and agrees that all Technical Information and copies thereof that are or may be provided by the Company to the Supplier, are and shall remain the property of

BHEL or that of the concerned entity from whom BHEL has obtained the Technical Information and such Technical Information are and shall constitute trade secrets of the BHEL. Nothing in this Agreement or in any disclosures made hereunder by or on behalf of the Company shall be construed as granting upon the Supplier any patent, copyright or design or any other intellectual property rights of whatsoever description that subsists or may hereinafter exist in the Technical Information. Furthermore, nothing in this Agreement or in any disclosures made hereunder by or on behalf of the Company shall be construed as granting upon the supplier any license or right of use of such patent, copyright or design or any other intellectual property rights of whatsoever description which may now or hereafter exist in the Technical Information except for use of the Technical Information strictly in accordance with this Agreement and the contract and / or as directed in writing by the Company, solely for the Intended Purpose under the Contract.

- 4.3 Neither party is obligated by or under this Agreement to purchase from or provide to the other party any service or product and that any such purchase / sale of any product and / or service by one party to the other party will be governed by the Contract if any, that may be entered into by and between the Company and the Supplier.
- 4.4 The Supplier is / has been made well aware and acknowledges that the Technical Information being / which may be shared with it by the Company has been either generated by the Company by incurring huge investment and cost or obtained from foreign collaborators under Technical Collaboration Agreement (TCA) with stringent confidentiality conditions.
- 4.5 The supplier agrees and undertakes to adhere to confidentiality requirements as applicable to BHEL under a TCA and also ensure that the confidentiality requirements are adhered to by all its concerned employees or sub-contractors /suppliers (where permitted to be engaged by BHEL). Any damages, losses, expenses of any description whatsoever, arising out of or in connection with a breach of the confidentiality requirements under a TCA owing to any act or omission on the part of the supplier or its employees or sub-contractors / suppliers that is claimed by a foreign collaborator from the Company shall be wholly borne by the Supplier and it shall keep BHEL fully indemnified in this behalf. The demand by the Company shall be conclusive upon the Supplier who shall thereupon forthwith pay to the Company without demur, dispute or delay the amount as demanded without demanding any further proof thereof.
- 4.6 The Supplier agrees and undertakes that unless so decided and advised by the Company in writing all rights / title to any Improvement to the Technical Information shall vest in the Company. The Supplier undertakes and agrees to inform forthwith to the Company of any such Improvement made to the Technical Information and transfer all drawings / documents or other materials connected with such Improvement to the Company and also agrees to fully cooperate with the Company for protecting the Company's interests in such Improvements

in the Technical Information including but not limited to obtaining necessary protection for the intellectual property rights in such improvement, if so desired by the Company. If a question arises whether a modification amounts to improvement to the Technical Information, the same shall be decided by the Company and such decision shall be final and binding upon the supplier.

5. Use and Non – Disclosure:

5.1 Unless otherwise stipulated by the Company, all Technical Information made available to the supplier, by the Company shall be treated as Confidential irrespective of whether the same is marked or otherwise denoted to be Confidential or not.

5.2 The Supplier undertakes and agrees that the Technical Information in its possession shall be held in strict confidence and will be used strictly in accordance with this Agreement and solely for the Intended Purpose under the Contract. Use of the Technical Information for any other purpose other than Intended Purpose is prohibited.

5.3 In particular, the Supplier shall not use Technical Information or any Improvement in its possession for the manufacture or procurement of the product(s) or components or parts thereof or use the Technical Information or any portion thereof or any modification or adaptation thereof in any form to provide any product and / or service to any third party, without the prior written consent of the Company.

5.4 The Supplier shall not disclose any of such Technical Information to any third party without the prior written consent of the Company. The Supplier agrees that without prior written consent of the Company, the supplier shall not disclose to a third party about the existence of this Agreement, or of the fact that it is / was in possession of or has experience in the use of any Technical Information nor shall the Supplier share in any manner whatsoever, with a third party, the name or details of any Contract(s) awarded by the Company to it or performed by the Supplier or the scope of work thereof or share any document or correspondence by and between the Company and the supplier in or in connection with this Agreement or such Contract(s). Notwithstanding what is stated elsewhere, the overall responsibility of any breach of the confidentiality provisions under this Agreement shall rest with the Supplier.

5.5 This Supplier undertakes and agrees not to make copies or extracts of and not to disclose to other any or all of the Technical Information in its possession, except as follows:

(a) The Supplier may disclose the Technical Information to such of its officers and employees strictly to the extent as is necessary for such officer or employee for the Intended Purpose, provided that the Confidential Information (or copies thereof) disclosed shall be marked

clearly as the confidential and proprietary information of Company and that such officers and employees shall similarly be bound by undertakings of confidence, restricted use and non-disclosure in respect of the Technical Information. The Supplier shall be responsible for any breach of such confidentiality provisions by such officers and employees.

- (b) With the prior written consent of Company, the supplier may disclose for the Intended Purpose such Technical Information as is provided for in such consent to such of its professional advisers: consultants, insurers and subcontractors who shall be similarly bound by undertakings of confidence, restricted use and non-disclosure in respect of such Technical Information.
- (c) The Supplier shall not be prevented to make any disclosure required by (i) order of a court of competent jurisdiction or (ii) any competent regulatory authority or agency where such disclosure is required by law, provided that where the supplier intends to make such disclosure, it shall first consult Company and take all reasonable steps requested by it to minimize the extent of the Technical Information disclosed and to make such disclosure in confidence and also shall cooperate with the Company in seeking any protective order or any other remedy from proper authority in this matter.

6. Exceptions:

The Obligations of the Supplier pursuant to the provisions of this agreement shall not apply to any Confidential Information that:

- a) was / is known to, or in the possession of the Supplier prior to disclosure thereof by the Company;
- b) is or becomes publicly known, otherwise than as a result of a breach of this agreement by the Supplier.
- c) is developed independently of the Disclosing party by the Supplier in circumstances that do not amount to a breach of the provisions of this Agreement or the Contract;
- d) is received from a third party in circumstances that do not result in a breach of the provisions of this Agreement.

- 7. The Obligation of maintaining confidentiality of the Technical Information on each occasion, shall subsist for the entire duration during which the Technical Information / equipment is in possession of the Supplier and shall thereafter subsist for a further period of _____ years from the date when the complete Technical Information has been returned in portions on different dates, the period of ____ years will be reckoned from the date when the last portion of the Technical Information has been returned. Notwithstanding the expiry of the confidentiality obligation, the obligation of the Supplier under clause 5.4 shall continue to subsist for a further period of _____ years.

8. Warranties & Undertakings:

- a) The Supplier undertakes to ensure the due observance of the undertakings of confidence, restricted use and non-disclosure by its persons to whom it discloses or releases copies or extracts of the Technical Information.
- b) The Supplier shall keep the Technical Information or improvement made therein properly segregated and not mix up the same with any other material / documents belonging to him / it or to any other third party.
- c) The Supplier further undertakes that he / it shall not hypothecate or give on lease or otherwise alienate or do away with any of the Technical Information and / or equipment of the Company, made available to him / it, and undertakes that he / it shall hold the same as a trustee, in capacity of custodian thereof and use / utilise the same solely for the purpose of executing the contract awarded by the Company.
- d) The Supplier further undertakes that he / it shall return all the equipment and / or Technical Information as far as practicable in the same condition in which the same was made available to him / it by the Company together with any Improvement thereon and the documents connected with such Improvement, to the Company forthwith upon completion of the scope of work or contract for which such Technical Information was provided by the Company to it or as directed by the Company together with a confirmation by way of an affidavit or in such manner as directed by the Company that it has not retained any equipment and / or Technical Information / improvement thereof. In case any such equipment and / or Technical Information or thereof shall remain in his possession or is not capable of being returned, the retention and use of such Technical Information or improvement thereto shall continue to be governed by this Agreement.
- e) The Supplier undertakes to indemnify the Company for all the direct, indirect and / or consequential losses, damages, expenses whatsoever including any consequential loss of business, profits suffered by the Company owing to breach by the Supplier of its obligations under this Agreement and / or the confidentiality requirements, if any, contained in the Contract and that the Supplier hereby agrees that the decision of the Company in all such or any such matter/s shall be final and binding on the Supplier. On mere written demand of the Company, the Supplier shall forthwith and without demur or delay pay to the Company any such sum as determined by the Company as the amount of loss or damage or expense which has been suffered by the Company. The Supplier agrees that the Company shall be entitled to withhold and appropriate any amount payable to the Supplier under any Contract then existing between the Company and the Supplier, in case the Supplier fails to make payment, in terms of the written demand, within 7 days thereof. Without prejudice to the forgoing actions, in respect to any breach of this Agreement, the Company shall be entitled to take

any other action against the Supplier as per applicable laws, the Contract, Company's applicable policies, guidelines rules, procedures, etc.

9. Without prejudice to any other mode of recovery as may be available to the Company for recovery of the amount determined as due as per Clause 9 (f) hereinabove, the Company shall have a right to withhold, recovery and appropriate the amount due towards such losses, damages, expenses, from any amount due to the Supplier in respect of any other Contract (s) placed on him / it by any department / office / unit/ division of the said Company.

10. Arbitration & Conciliation:

Except as provided elsewhere in this contract, in case amicable settlement is not reached between the parties, in respect of any dispute or difference; arising out of the formation, breach, termination, validity or execution of the contract; or, the respective rights and liabilities of the parties; or, in relation to interpretation of any provision of the contract; or, in any manner touching upon the contract, then, either party may, by a notice in writing to the other party refer such dispute or difference to the sole arbitration of an arbitrator appointed by head of the BHEL unit issuing the contract.

The Arbitrator shall pass a reasoned award and the award of the Arbitrator shall be final and binding upon the parties.

Subject as aforesaid, the provisions of Arbitration and Conciliation Act 1996 (India) or statutory modifications or re-enactments thereof and the rules made thereunder and for the time being in force shall apply to the arbitration proceedings under this clause, the seat of arbitration shall be at Hyderabad.

The cost of arbitration shall be borne as per the award of the Arbitrator.

Subject to the arbitration in terms of clause 55, the courts at Sangareddy, Telangana State shall have exclusive jurisdiction over any matter arising out of or in connection with this contract.

Notwithstanding the existence or any dispute or differences and / or reference for the arbitration, the contractor shall proceed with and continue without hindrance the performance of its obligations under this contract with due diligence and expedition in a professional manner except where the contract has been terminated by either party in terms of this contract.

In case of contract with Public Sector Enterprise (PSE) or a Government Department, the following shall be applicable:

In the event of any dispute or difference relating to the interpretation and application of the provisions of the contract, such dispute or difference shall be referred by either party for arbitration to the sole arbitrator in the Department of Public Enterprises to be nominated by the secretary to the Government of India in-charge of the Department of Public Enterprises. The Arbitration and Conciliation Act, 1996 shall not be applicable to arbitration under this clause. The award of the arbitrator shall be binding upon the parties to the dispute, provided, however, any party aggrieved by such award may make further reference for setting aside or revision of the award to the Law Secretary, Department of Legal Affairs, Ministry of Law and

justice, Government of India. Upon such reference the dispute shall be decided by the Law secretary or the special Secretary or Additional secretary when so authorized by the Law secretary, whose decision shall bind the parties hereto finally and conclusively. The parties to the dispute will share equally the cost of arbitration as intimated by the arbitrator.

11. Governing Law & Jurisdiction:

This agreement shall be construed and interpreted in accordance with the laws of India and shall have exclusive jurisdiction of Sangareddy/Hyderabad courts, Telangana, India.

SIGNATURE

WITNESSES

1

Name:

Address:

2

Name:

Address:

Annexure - III

Proforma for self-certification by Supplier for minimum local content on their letter head for tender value less than Rs 10 Crore

"We _____ (Name of Manufacturer) undertake that we meet the mandatory minimum Local Content (LC) requirement i.e. _____ (to be filled as notified in the policy) for claiming Purchase Preference linked with Local Contents under the Govt. policy against tender no. _____."

Auditor's certification with respect to minimum local content on the letter head of Statutory Auditor for tender value above Rs.10 crore

"We _____ the statutory auditor of M/s _____ (name of the bidder) hereby certify that M/s _____ (name of manufacturer) meet the mandatory Local Content requirements of the Goods and/or Services i.e. _____ (to be filled as notified in the policy) quoted vide offer No. _____ dated _____ against BHEL's tender No. _____ by M/s _____ (Name of the bidder)."

INTEGRITY PACT**Between**

Bharat Heavy Electricals Ltd. (BHEL), a company registered under the Companies Act 1956 and having its registered office at "BHEL House", Siri Fort, New Delhi - 110049 (India) hereinafter referred to as "The Principal", which expression unless repugnant to the context or meaning hereof shall include its successors or assigns of the ONE PART

and

_____, (description of the party along with address), hereinafter referred to as "The Bidder/ Contractor" which expression unless repugnant to the context or meaning hereof shall include its successors or assigns of the OTHER PART

Preamble

The Principal intends to award, under laid-down organizational procedures, contract/s for _____

_____. The Principal values full compliance with all relevant laws of the land, rules and regulations, and the principles of economic use of resources, and of fairness and transparency in its relations with its Bidder(s)/ Contractor(s).

In order to achieve these goals, the Principal will appoint Independent External Monitor(s), who will monitor the tender process and the execution of the contract for compliance with the principles mentioned above.

Section 1- Commitments of the Principal

1.1 The Principal commits itself to take all measures necessary to prevent corruption and to observe the following principles:-

1.1.1 No employee of the Principal, personally or through family members, will in connection with the tender for, or the execution of a contract, demand, take a promise for or accept, for self or third person, any material or immaterial benefit which the person is not legally entitled to.

1.1.2 The Principal will, during the tender process treat all Bidder(s) with equity and reason. The Principal will in particular, before and during the tender process, provide to all Bidder(s) the same information and will not provide to any Bidder(s) confidential/ additional information through which the Bidder(s) could obtain an advantage in relation to the tender process or the contract execution.

1.1.3 The Principal will exclude from the process all known prejudiced persons.

1.2 If the Principal obtains information on the conduct of any of its employees which is a penal offence under the Indian Penal Code 1860 and Prevention of Corruption Act 1988 or any other statutory penal enactment, or if there be a substantive suspicion in this regard, the Principal will inform its Vigilance Office and in addition can initiate disciplinary actions:

Section 2 - Commitments of the Bidder(s)/ Contractor(s)

- 2.1 The Bidder(s)/ Contractor(s) commit himself to take all measures necessary to prevent corruption. He commits himself to observe the following principles during his participation in the tender process and during the contract execution.
- 2.1.1 The Bidder(s)/ Contractor(s) will not, directly or through any other person or firm, offer, promise or give to the Principal or to any of the Principal's employees involved in the tender process or the execution of the contract or to any third person any material, immaterial or any other benefit which he/ she is not legally entitled to, in order to obtain in exchange any advantage of any kind whatsoever during the tender process or during the execution of the contract.
- 2.1.2 The Bidder(s)/ Contractor(s) will not enter with other Bidder(s) into any illegal or undisclosed agreement or understanding, whether formal or informal. This applies in particular to prices, specifications, certifications, subsidiary contracts, submission or non-submission of bids or any other actions to restrict competitiveness or to introduce cartelization in the bidding process.
- 2.1.3 The Bidder(s)/ Contractor(s) will not commit any penal offence under the relevant Indian Penal Code (IPC) and Prevention of Corruption Act; further the Bidder(s)/ Contractor(s) will not use improperly, for purposes of competition or personal gain, or pass on to others, any information or document provided by the Principal as part of the business relationship, regarding plans, technical proposals and business details, including information contained or transmitted electronically.
- 2.1.4 Foreign Bidder(s)/ Contractor(s) shall disclose the name and address of agents and representatives in India and Indian Bidder(s)/ Contractor(s) to disclose their foreign principals or associates. The Bidder(s)/ Contractor(s) will, when presenting his bid, disclose any and all payments he has made, and is committed to or intends to make to agents, brokers or any other intermediaries in connection with the award of the contract.
- 2.2 The Bidder(s)/ Contractor(s) will not instigate third persons to commit offences outlined above or be an accessory to such offences.
- 2.3 The Bidder(s)/ Contractor(s) shall not approach the Courts while representing the matters to IEMs and will await their decision in the matter.

Section 3 - Disqualification from tender process and exclusion from future contracts

If the Bidder(s)/ Contractor(s), before award or during execution has committed a transgression through a violation of Section 2 above, or acts in any other manner such as to put his reliability or credibility in question, the Principal is entitled to disqualify the Bidder(s)/ Contractor(s) from the tender process or take action as per the separate "Guidelines on Banning of Business dealings with Suppliers/ Contractors", framed by the Principal.

Section 4 - Compensation for Damages

- 4.1 If the Principal has disqualified the Bidder from the tender process prior to the award according to Section 3, the Principal is entitled to demand and recover the damages equivalent Earnest Money Deposit/ Bid Security.
- 4.2 If the Principal has terminated the contract according to Section 3, or if the Principal is entitled to terminate the contract according to section 3, the Principal shall be entitled to

demand and recover from the Contractor liquidated damages equivalent to 5% of the contract value or the amount equivalent to Security Deposit/ Performance Bank Guarantee, whichever is higher.

Section 5 - Previous Transgression

- 5.1 The Bidder declares that no previous transgressions occurred in the last 3 years with any other company in any country conforming to the anti-corruption approach or with any other Public Sector Enterprise in India that could justify his exclusion from the tender process.
- 5.2 If the Bidder makes incorrect statement on this subject, he can be disqualified from the tender process or the contract, if already awarded, can be terminated for such reason.

Section 6 - Equal treatment of all Bidders/ Contractors / Sub-contractors

- 6.1 The Principal will enter into agreements with identical conditions as this one with all Bidders and Contractors. In case of sub-contracting, the Principal contractor shall be responsible for the adoption of IP by his sub-contractors and shall continue to remain responsible for any default by his sub-contractors.
- 6.2 The Principal will disqualify from the tender process all bidders who do not sign this pact or violate its provisions.

Section 7 - Criminal Charges against violating Bidders/ Contractors /Subcontractors

If the Principal obtains knowledge of conduct of a Bidder, Contractor or Subcontractor, or of an employee or a representative or an associate of a Bidder, Contractor or Subcontractor which constitutes corruption, or if the Principal has substantive suspicion in this regard, the Principal will inform the Vigilance Office.

Section 8 - Independent External Monitor(s)

- 8.1 The Principal appoints competent and credible Independent External Monitor for this Pact. The task of the Monitor is to review independently and objectively, whether and to what extent the parties comply with the obligations under this agreement.
- 8.2 The Monitor is not subject to instructions by the representatives of the parties and performs his functions neutrally and independently. He reports to the CMD, BHEL.
- 8.3 The Bidder(s)/ Contractor(s) accepts that the Monitor has the right to access without restriction to all contract documentation of the Principal including that provided by the Bidder(s)/ Contractor(s). The Bidder(s)/ Contractor(s) will grant the monitor, upon his request and demonstration of a valid interest, unrestricted and unconditional access to his contract documentation. The same is applicable to Sub-contractor(s). The Monitor is under contractual obligation to treat the information and documents of the Bidder(s)/ Contractor(s) / Sub-contractor(s) with confidentiality in line with Non- disclosure agreement.
- 8.4 The Principal will provide to the Monitor sufficient information about all meetings among the parties related to the contract provided such meetings could have an impact on the contractual relations between the Principal and the Contractor. The parties offer to the Monitor the option to participate in such meetings.

- 8.5 The role of IEMs is advisory, would not be legally binding and it is restricted to resolving issues raised by an intending bidder regarding any aspect of the tender which allegedly restricts competition or bias towards some bidders. At the same time, it must be understood that IEMs are not consultants to the Management. Their role is independent in nature and the advice once tendered would not be subject to review at the request of the organization.
- 8.6 For ensuring the desired transparency and objectivity in dealing with the complaints arising out of any tendering process, the matter should be examined by the full panel of IEMs jointly as far as possible, who would look into the records, conduct an investigation, and submit their joint recommendations to the Management.
- 8.7 The IEMs would examine all complaints received by them and give their recommendations/ views to CMD, BHEL, at the earliest. They may also send their report directly to the CVO and the Commission, in case of suspicion of serious irregularities requiring legal/ administrative action. IEMs will tender their advice on the complaints within 10 days as far as possible.
- 8.8 The CMD, BHEL shall decide the compensation to be paid to the Monitor and its terms and conditions.
- 8.9 IEM should examine the process integrity, they are not expected to concern themselves with fixing of responsibility of officers. Complaints alleging mala fide on the part of any officer of the organization should be looked into by the CVO of the concerned organisation.
- 8.10 If the Monitor has reported to the CMD, BHEL, a substantiated suspicion of an offence under relevant Indian Penal Code/ Prevention of Corruption Act, and the CMD, BHEL has not, within reasonable time, taken visible action to proceed against such offence or reported it to the Vigilance Office, the Monitor may also transmit this information directly to the Central Vigilance Commissioner, Government of India.
- 8.11 The number of Independent External Monitor(s) shall be decided by the CMD, BHEL.
- 8.12 The word 'Monitor' would include both singular and plural.

Section 9 - Pact Duration

- 9.1 This Pact shall be operative from the date IP is signed by both the parties till the final completion of contract for successful bidder and for all other bidders 6 months after the contract has been awarded. Issues like warranty / guarantee etc. should be outside the purview of IEMs.
- 9.2 If any claim is made/ lodged during currency of IP, the same shall be binding and continue to be valid despite the lapse of this pact as specified above, unless it is discharged/ determined by the CMD, BHEL.

Section 10 - Other Provisions

- 10.1 This agreement is subject to Indian Laws and jurisdiction shall be registered office of the Principal, i.e. New Delhi.

- 10.2 Changes and supplements as well as termination notices need to be made in writing. Side agreements have not been made.
- 10.3 If the Contractor is a partnership or a consortium, this agreement must be signed by all partners or consortium members.
- 10.4 Should one or several provisions of this agreement turn out to be invalid, the remainder of this agreement remains valid. In this case, the parties will strive to come to an agreement to their original intentions.
- 10.5 Only those bidders / contractors who have entered into this agreement with the Principal would be competent to participate in the bidding. In other words, entering into this agreement would be a preliminary qualification.

J MOHAN

Digitally signed by J MOHAN
Date: 2026.09.26 09:17:36
+05'30'

For & On behalf of the Principal

(Office Seal)

Place-----

Date-----

Witness:_____

(Name & Address) _____

For & On behalf of the Bidder/

Contractor

(Office Seal)

Witness:_____

(Name & Address) _____



CORPORATE STANDARD

AA 085 0106

Rev. No. 01

PAGE 1 OF 15

Non Destructive Examination of Turbine & Generator Shafts

List of Contents

Page

1	General	2
1.1	Scope of Application	2
1.2	Purpose of Examination	2
1.3	Certificate of Examiners	2
2	Applicable Standards	2
3	Preparation of Forging	2
4	Testing of UT-Equipment	2
4.1	UT-Instrument	2
4.2	Probes	3
4.3	Check of Testing Equipment	3
4.4	Calibration of Testing Instrument	3
4.5	Couplant	3
5	Test Planning	3
6	Execution of Examination	4
6.1	Scope of Examination	4/5
6.2	Speed of Testing	5
7	Special Features due to the Applied Examination Technique	5
7.1	Plexiglas-adapter- wedges	5
8	Description of Indications	5
8.1	Flaw Echo Height	5
8.2	Flaw Echo Shape	5/6
8.3	Dynamic Characteristic, Extent of Indications	6
8.4	Dependence of frequency	6
8.5	Back Wall Echo drop ≥ 3 dB	6
8.6	Limit of the Flaw Detection sensitivity	6
9	Recording- and Decision Criteria's	6/7
10	Surface Crack Examination of the cross-section transitions	7
11	Surface Crack Examination of the axial hole bore	7
12	Reporting	7/8/9
	Figure 1 and Figure 2	10
	Table 1 and Table 2	11
	Table 3 and Table 4	12
	2 Enclosure	

Revisions:

As per Email dt: 23/01/2009 from Shri P Nath ,
DGM/ MTE, HEEP , Haridwar.

APPROVED:

INTERPLANT MATERIAL RATIONALISATION
COMMITTEE-MRC (FCF+HTM)

Rev. No. 01

Amd.No.

Dt: 1.2.2009

Dt :

Year :

Prepared

HARIDWAR

Issued

Corp. R&D

Dt. of 1st. Issue

FEB' 2008

**1 General****1.1 Scope of Application**

This test procedure is applicable for the manual ultrasonic examination and surface crack examination (MT) of free forgings for turbine and generator shafts by the supplier. It may also be used up to the preparation of a specific test instruction for automated UT-Examination for such examinations.

It determines the conditions for UT-examination of forging items after machining in as simple as possible contour condition with body surfaces parallel to the axis. The last heat treatment, which determines the mechanical properties must already have been done. If a retempering is needed, then it must be tested by UT for minimum all recordable indications to 100%. All surface examinations must be repeated. The user must first create an equipment-specific procedure before the test equipment is qualified by both the user and BHEL. The test procedure must be approved by BHEL.

1.2 Purpose of Examination

The purpose of examination is to check as much as possible of the volume of the shaft under consideration of geometry and labour consumption for flaws resulting from the manufacturing process. It is aimed at finding flaws through to the core area of the shaft with highest detection sensitivity (see para 9 "recording- and decision criteria"). Furthermore cross-section transitions and the axial boring of the shafts are to be checked for surface crack examination (MT).

1.3 Certificate of Examiners

The forgings have to be tested by experienced and level II certified NDT-personnel (UT/MT) according to EN 473 or ASNT SNT-TC-1A. A current list of certified NDT-personnel according to the required certification shall be sent to BHEL.

2 Applicable Standards

SEP 1923, EN 12223, EN 27963, EN 10204, EN 10 228-1, EN 12668-1

3 Preparation of Forging

The examination surface of the forging shall be according to order drawing ($R_a < 20 \mu\text{m}$), in order to get a coupling of probes on the shaft which is as perfect as possible.

4 Testing of UT Equipment**4.1 UT-Instrument**

UT instrument deployed for this examination shall be in accordance with the relevant standards and rules (DIN 54 126). They shall be of impulse-echo type and with the aid of a gain controller, adjustable in decibel (dB), measurements of echo relationship shall be rendered possible with ≤ 1 dB accuracy. In the working range of the applied equipment sensitivity the amplifier shall have no threshold and shall show no saturation. The testing ranges shall overlap, whereby the time base shall be linear adjustable with an accuracy of $< 2\%$ of testing range.



CORPORATE STANDARD

AA 085 0106

Rev. No. 01

PAGE 3 OF 15

A regular inspection and maintenance of the instruments at least once a year must be proved.

4.2 Probes

The testing probes will generally be used with straight-longitudinal waves (e.g. B2S, B4S, B5S, SEB4H0³) and angle-transversal waves (e.g. WB4 5-2N, and WB70-2N), therefore the selection of probes conforms to the geometrical conditions of the shaft.

In the application of the probes it must be taken into consideration that probes shall be adapted to the contour of the surface of the shaft in sound direction or small probes shall be used. This is always the case, when the curvature of the surface of the shaft is $R \leq A^2 / 4$. Therefore A is the length of the coupling area of the probe in bend direction.

4.3 Check of Testing Equipment

For equipment calibration and for control of equipment function and probes calibration blocks 1 and 2 according to EN 12223 and EN 27963 or other calibration blocks shall be available.

4.4 Calibration of Testing Instrument

The calibration of the time base range shall be done with the aid of calibration blocks according to EN 12223 or EN 27963 respectively or on the test piece, where at least two reference echo's with known sound paths shall be used.

4.5 Couplant

The couplant shall wet the surface of the shaft enough to ensure a perfect coupling on the test surface. The applied couplant must not cause any corrosive damage.

5 Test Planning

The identification number must be stamped on the face of the shaft end according to the order drawing. The marking field must be placed in the original position of the shaft after any subsequent machining. In the delivery condition of the shaft the marking shall be framed with oil paint. The correctness of the identification shall be certified by the responsible factory quality representative by hard stamping of his sign in the identification area.

Before inspection, the inspector must use the relevant drawings of the shaft to find out the position of the axial bore holes which will be drilled later, as well as the geometrical contour, dimensions etc. In addition, the inside area / volume of the area for the axial bore holes must be checked by UT before drilling. The order drawing gives a reference base groove area for axial 0-point to be used during ultrasonic testing. The reference point is the position on the face of the shaft end as shown in the drawing. There must be a stamp field on the face of the shaft before the test start. However, at this point of test, the groove should not have been machined. After machining the groove area on the shaft, the marking field must be transferred to the identical circumferential position. In addition, if a reference bore needs to be drilled according to the drawing, then it must be transferred as a reference point in the identical circumferential position. The excess length during the ultrasonic test must also be tested.

Indications from detection limit in the bore hole volume must be recorded.



It should be possible to turn the shaft during the examination. In case of recordable indications, the shaft must be rotatable.

6 Execution of Examination

6.1 Scope of Examination

Sound directions (according to SEP 1923) have to be applied as follows:

A5 Sound attenuation measurement according to SEP 1923 in radial direction over the whole length of the shaft, therefore the axial distance between two measurement points should not be more than 1000 mm. In the case of the attenuation measurement, irregularities which require further investigations can occur. For example, can probe- and/or material dependent attenuation values be identical and/or lower with the higher frequency (e.g. 5 MHz) as with the lower frequency (e.g. 4 MHz). In such cases possibly further investigations of the frequency spectrums of the probes must be carried out. Narrow-band probes whose center frequency fits as close to the nominal frequency should be used. This should if possible be engaged by a probe particular frequency analysis. The Specimen number of the used probes is to be recorded in the UT record.

A3 Examination of the total surface of the shaft in radial direction with the probe B2S. Exceptionally the probe B4S with the 4 MHz - frequency may be used, when spurious echo's (phantom echo's) or insufficient detection sensitivity limit (> 1 mm FBH) occurs by using the probe B2S.

A4 Examination in axial direction from all face areas and sections with the probes B2S and B4S. The maximum beam path for the detection sensitivity limit of 3,0 mm FBH (flat bottom hole) in the direction A4 is to be reported.

A7 Examination of the total circumferential surface of the shaft in both circumference direction (cw and ccw) with angles of incidence of 7° , 14° and 21° for the probe B2S. In case of spurious echo's (phantom echo's), the probe B4S with corresponding angles of incidence of 3.5° , 7° , 10.5° , 14° , 17.5° , 21° and 24.5° is to be taken into consideration for this circumferential direction (A7).

From experience it is known that with the application of B2S-probe spurious echo's occur only by the angles of incidence of 0° to 14° .

A7 Examination of the total circumferential surface of the shaft in both circumference direction with an angle of incidence of 45° (WB45-2 N).

A8 Examination of the body in near-surface range up to a depth of about 150 mm (for generator shafts up to 250mm depth because of the coil slots) in axial direction with an angle of incidence of 70° (WB70-2N).

A9 Examination of body in near- surface range up to a depth of about 150 mm in radial direction with the probe SEB4H0° in case the detection sensitivity limit in the volume range near the back wall echo will not be ≤ 1 mm FBH when tested in radial direction (A3).

The prescribed directions of incidence are presented in **Figure 1**.

The above mentioned sound directions are valid for shafts with parallel surfaces in axial direction only.



CORPORATE STANDARD

AA 085 0106

Rev. No. 01

PAGE 5 OF 15

Examination of cross-section transitions:

The cross-section transitions in the meaning of this procedure are areas where the diameters differ at quality heat treatment $\geq 200\text{mm}$.

All cross-section transitions are to be tested to 100% from the accessible surface in radial-axial direction (A8) with angles of incidence of 70° (WB7 0-2N) according to **figure 2**. It is sufficient to test the volume up to the middle of the shaft from one side only. There is no need of this examination, if the detection limit is verified $\leq 3\text{ mm FBH}$ from the axial direction (A4) for the corresponding crossing.

6.2 Speed of Testing

For visual screen monitoring the testing speed shall not exceed 100 mm/s .

7 Special Features due to the Applied Examination Technique

7.1 Plexiglas-Adapter- Wedges

For acoustic incidence of longitudinal waves in radial-tangential sound direction according to the above mentioned angles plexiglas adapter-wedges may be used. The resulting occurrence of loss of sound energy may reduce the detection sensitivity limit. To minimize losses and disturbing spurious echo's it is taken care that the thickness of plexiglas-adapter- wedges between transducer and testing surface shall be as small as possible.

According to experience loss of sound energy of 4 dB arises by plexiglas-adapter- wedges with 5 mm thickness and 0° -angle of incidence. It is important that all other used plexiglas-adapter wedges shall have the same thickness.

8 Description of Indications

Indications from defects inside the material must be characterized by their echo height and shape, by their dynamic characteristics and if necessary by their frequency dependence. Furthermore, indications in connection with back wall echo drop $\geq 3\text{ dB}$ are to be recorded as well as the detection sensitivity limit for the largest sound path.

8.1 Flaw Echo Height

The evaluation of indications on the basis of their echo amplitude will be done according to the AVG (DGS)-method, whereby the equivalent reflector size should be recorded as equivalent flat bottom hole (FBH) in mm.

8.2 Flaw Echo Shape

The indications are characterized according to the following echo shapes:

single echo (in German <u>E</u> inzele <u>e</u> cho)	EE
many single echo's (in German <u>v</u> iele <u>E</u> inzele <u>e</u> chos)	VE
group echo resolvable (in German <u>G</u> ruppene <u>e</u> cho <u>a</u> uflösbar)	GA
group echo not resolvable (in German <u>G</u> ruppene <u>e</u> cho <u>n</u> icht auflösbar)	GN
<u>r</u> ing <u>z</u> one	RZ
<u>g</u> ross (structural indications)	GR



The max. FBH-size in an area of group indications (GA's and GN's) must be always determined by using the max. echo peak.

The screen patterns of the relevant echo shapes are shown in **Table 3**.

8.3 Dynamic Characteristic, Extension of Indications

The determination of the extent of single indications has to be done according to the half amplitude method. The sound field characteristics of the probes are to be taken into consideration. In the event that during the determination of the half amplitude extension of the flaw a change in the beam path is detected, the existence of a flaw with a plane angular orientation has to be assumed and recorded.

If the existence of angular or eccentric oriented flaws is suspected, the echo amplitude is to be recorded after optimising the angles of incidence. The following shall be taken into account:

- The reflectivity of an indication in case of radial/ tangential direction from 0° | 21° (A3, A7) according to table 1 goes through a maximum, no additional examinations are necessary.
- If an increase goes in reflectivity of the indication in radial/ tangential direction from 0° , 21° (A3, A7), according to table 1, is noted, then additional examinations with sound angles 28° and 35° shall be performed independent of the recordability of the indication.
- If recordable indications from direction A7 45° (cw/ccw) in the "long sound path" are detected, they must be tested and recorded additionally in "short sound path" with the probes VS 60 or VS 70 and if necessary with MWB60 or MWB70. The choice of the above probes is dependent on the depth of indications.

8.4 Dependence of Frequency

By means of changing the test frequency within the range of 2 | 4 MHz reflection positions can provide portions with differing sound reflection amplitudes. This dependence of frequency is to be recorded, if the FBH-values of the same individual flaw which have been determined with different frequencies deviate for 50% and more from each other. The recording should happen only in case the decision limit has been passed over by the indication.

8.5 Back Wall Echo drop ≥ 3 dB

The back wall echo drop is to be measured in the area of recordable indications of the shaft.

8.6 Limit of the Flaw Detection Sensitivity

The minimum detectable size is the value of the smallest detectable circular disk reflector (FBH) under consideration of a signal/noise ratio of 6 dB. The minimum detectable size is to be determined for all applied probes and sound directions and to be recorded in FBH together with the corresponding details, e.g. probe, sound direction, sound path, etc.

For areas with quality level 1a a detection limit of 0.5 mm FBH is to be aimed for and for the remaining areas a detection limit of 1.0 mm FBH.

9 Recording- and Decision Criteria's

Recordable are:

- Indications according to table 2



CORPORATE STANDARD

AA 085 0106

Rev. No. 01

PAGE 7 OF 15

Decision limits are:

- Indications according to table 2
- Transgression of the attenuation values
 - 2 MHz : 2 dB/m
 - 4 MHz : 6 dB/m
 - 5 MHz : 10 dB/m
- Indications from flaw areas, which will be exposed after final machining of the shaft
- In case of recordable indications in the area of the later bore hole, a special permission for drilling is required
- detection limit exceeds 1.5 mm FBH in direction A3 and A7 with the probes B2S or B4S and WB45-N2
- detection limit exceeds 1.0 mm FBH in direction A9 and A7 with the probe SEB4H0° and in direction A8 with the probe WB70-N2

With transgression of the above-mentioned features, a deviation report is to be prepared.

10 Surface Crack Examination of the cross-section transitions

The areas of the cross-section transitions (areas with diameter differences ≥ 200 mm at the heat treatment) are subjected additionally to a surface crack examination (MT) in dependence EN 10228-1 in the **delivery condition**. A yoke magnet with alternating current is to be used for magnetization. The surface roughness must correspond to $R_a < 20 \mu\text{m}$. For the recording limit and admissibility criteria, quality class 3 is to be used (see EN 10 228-1, table 2).

11 Surface-Crack-Examination of the Axial Hole Bore

The axial boring is subjected to a surface crack examination (MT) to preferably in length direction in the delivery condition. The surface roughness must correspond to $R_a < 6.3 \mu\text{m}$. For the recording limits and admissibility criteria, quality class 4 is to be used (see EN 10228-1, table 2). An Eddy current examination (ET) can also be carried out alternatively. For this the manufacturer must make out a test instruction and submit it to the purchaser for confirmation.

12 Reporting

Following the examinations an inspection and testing certificate 3.1 B according to EN 10204 is to be drawn up. The MT must be documented in accordance with EN 10 228-1. The UT report must contain the following information for the purpose of repeatability of the examination:

- a) Details about the examined object
 - identification data (ident-No., material, heat-No., etc.)
 - surface condition
 - step of the production flow when the examination happened
- b) Details about the examination technique
 - examination instruction
 - scope of examination
 - instrument

- probes
- frequency
- couplant
- kind of calibration
- values of correction
- c) Results of the examination
 - limit of the flaw detection sensitivity
 - sound attenuation values in dB/m
 - recorded indications

The indications to be recorded are to be described by sufficient information concerning their position, location, size and/or depth extension etc. and are to be described in a dimensioned sketch of the shaft, the sectional view or a handling of the surface true to size to register. Here, minimum entries must be made in accordance with the indication list (enclosure 1). While filling out the table, the following is to be considered:

- The position specifications of the table are probe positions.
- Volume positions are always entered in degrees.
- Indication types EE+VE of extension and/or GA, GN and RZ are always indication areas. Here, it is necessary for the axial and volume positions and also for the beam path to register the from-, to - and maximum values. In the case of EE+VE without extension (punctual), the maximum values information is sufficient.
- In the column "FBH", the replacement reflector size of indication is indicated. Here, the information is sufficient up to the first place after the comma.
- Back wall drop ≥ 3 dB is entered in the column "BEA".
- In the columns "Angle of incidence" both, the angle as well as the direction referring to the reference point, is to be specified. The following information e.g. must be made like this:

Probe-No. Acc. to SEP 1923	Angle of incidence (degree)		Remarks
	axial	tangential	
A3	0	0	T = direction TS G = direction GS Possible combination
A7	0	7cw	
A7	0	7ccw	
A7	0	14cw	
A7	0	14ccw	
A8	70T	0	
A8	70G	0	
A7/A8	7T	7cw	

GS = generator side and therefore always output end. The information of the output end is always given in the order drawing (BZ).

- In the column "probe", the trade name of the used probe registered e.g. becomes B2S, WB45-N2, SEB4H0° and so on.
- The column "file name" can be used if the dates to indications are saved electronically.



CORPORATE STANDARD

AA 085 0106

Rev. No. 01

PAGE 9 OF 15

- At the column "inspection areas", the following insertions e.g. are reasonable:
 - coupling TS or GS
 - journal TS or GS
 - Body
- In the column "remark" e.g., references of additional indication representations in other enclosures are reasonable.
- d) General
 - date of examination, location of examination
 - name of examiner (during the application by several examiners, it must be followable which test section was tested by which examiner)




Figure 1 : Direction of incidence




Figure 2 : Examination of the transitions of the cross section



CORPORATE STANDARD

AA 085 0106

Rev. No. 01

PAGE 11 OF 15

Table-1 : Scope of inspection

Test-No.	testing area	sound direction
A3	100% surface area of journal and body	radial with the probe B2S (B4S)
A4	100% front face of body and front face of clutch	axial with the probe B2S and B4S
A5	sound attenuation measurement per 1000 mm	radial with the probe B2S, B4S and B5S
A7	100% surface area of body and journal	2 circumferential directions in case of probe B2S with $\alpha = 7714721^\circ$ in case of probe B4S with $\alpha = 3.577710.5714717.5721724.5^\circ$ in case of probe WB45-N2 with $\alpha = 45^\circ$
A8	100% surface area of body	2 axial directions with the probe WB70-2N, $\alpha = 70^\circ$ up to a depth of about 150 mm (for generator shafts upto a depth of 250mm) additionally cross section transitions with probe WB70-2N, $\alpha = 70^\circ$ when acc. to point 6 required
A9	100% surface area of body up to a depth of about 150 mm	radial with the probe SEB4 when acc. to point 6 required



Table 2: Recording / decision limit

testing area		EE/VE without extension		EE/VE with extension GA, GN, RZ		backwall echo drop [dB]	maximum actual reflector length EE/VE	Maximum areas length (axial or radial) GA, GN
		recording limit mm FBH	decision limit mm FBH	recording limit mm FBH	decision limit mm FBH			
body area 0-150 mm ⁴⁾		1	2	all indications	1	3	10 mm ¹⁾	10 mm ¹⁾
Center area ≤40% shaft diameter		2	4	1	2	3	10 mm ¹⁾	X ¹⁾²⁾³⁾
Rest area	1%-Cr-steel	2	4	1	2	3	10 mm ¹⁾	X ¹⁾²⁾³⁾
	2%-10% steel	2	4	1	2.5	3	10 mm ¹⁾	X ¹⁾²⁾³⁾
	2%-10% Ni-steel	3	6	2	3	3	10 mm ¹⁾	X ¹⁾²⁾³⁾

1) The sound field properties of probe are to be taken in to consideration

2) Total radial extension: 40% of shaft diameter at the indication area






3) It is to be considered, whether indications occur with extension > beam diameter within the area of clustered indications. The decision limit of the real reflector length applies to such indications.

4) For generator shafts applies 0-250mm because of the coil slots

Table 3: Standard shaft materials

	Material identification
1% -Cr-steel	30CrMoNiV 511
2%-Cr-steel	23CrMoNiWV 88
10%-Cr-steel	X12CrMoWVNbN 1011 X12CrMoWVNbN 1011(B)
Ni-steel	26NiCrMoV 115 26NiCrMoV 145 26NiCrMoV 1010

Table 4: Echo shapes in the application of ultrasonic testing of shafts

Screen picture	Echo shape	Symbol
	single echo	EE
	many single echos ¹⁾	VE
	group echos resolvable ₂₎	GA
	group echos not resolvable ₂₎	GN
	ringzone	RZ

- 1) An echo shape is to be classified as VE, if the depth distance between the single echos is more than 5% of shaft-diameter on the test location.
- 2) Group echos are considered resolvable, if the distance between the peak of the largerst echo and the base of the adjoining echo is > 18 dB. This classification is applicable for 500 mm the time-base range only.

[illegible]



TD-213
Rev.00

REAFFIRMATION NOTIFICATION

HY 065 20 99, Rev No. 00

TITLE

MANUFACTURING AND INSPECTION SEQUENCE PLAN (MIP) FOR FORGINGS

This standard is reviewed and reaffirmed.

REF
IOM REF.
HY/R&DEC/SEIPR/SM/2021/SG;
Dated 27/01/2021

APPROVED BY
S N THAMKE
AGM / R&D and EC

ISSUED BY
STANDARDS
ENGINEERING

DATE
09/07/2021

CUM Sr.No.
R 2738

	TD-218 Rev. 00	PLANT STANDARD HYDERABAD	HY 065 20 99		
		REV.NO. 00			
		PAGE 1 OF 4			

MANUFACTURING AND INSPECTION SEQUENCE PLAN (MIP) FOR FORGINGS

1.0 SCOPE OF APPLICATION:

This specification describes about "Manufacturing and Inspection Sequence Plan (MIP) for open die forgings which shall be submitted by the supplier and sent to BHEL for approval before starting the manufacturing.

2.0 GENERAL REQUIREMENTS:

2.1 For each forging a manufacturing and inspection sequence plan (MIP) shall be prepared. By the supplier for its approval by BHEL before starting the manufacturing.

2.2 A new MIP shall also be submitted for forging

- when the supplier intends to change the existing / BHEL approved manufacturing or in testing / inspection method.
- for every new purchase order of the forging.

2.3 Each MIP for a specific forging shall contain forging drawing reference, supplier identification no., material grade & specification, purchase order reference and other required details.

2.4 Basis for the MIP is the applicable purchase specification, ordering drawing, test specification of BHEL as well as special quality assurance requirements given in the purchase order. All the information given in MIP by the supplier shall be fixed also in the internal working instructions of the manufacturer, which have to be used for the manufacturing and inspection process.

2.5 MIP shall be submitted to BHEL well before starting manufacturing for approval by BHEL. By approving the MIP, BHEL does not take any responsibility for processes or manufacturing details of the supplier.

Revisions :			Issued :		
			STANDARDS ENGINEERING DEPARTMENT		
Rev.No.	Rev.Date	Revised	Prepared	Approved	Dt.of 1st Issue
00			M.ATLS ENGG.	DGM / TS	OCT. 2003

HY 065 20 99	TD-218 Rev.00	PLANT STANDARD HYDERABAD	
Rev.No. 00			
PAGE 2 OF 4			

2.6 BHEL has to be informed in writing about the manufacturing steps to be performed by sub-suppliers. The supplier has to ensure, that all the quality assurance requirements agreed with BHEL in MIP, shall be applied to the sub- suppliers also.

2.7 Deviations during manufacturing from the agreed procedures mentioned in the MIP have to be submitted to BHEL in writing for approval along with justifications.

2.8 BHEL or its representatives (3rd party inspection agency) may witness manufacturing and /or testing besides the acceptance inspections which are mentioned in the Purchase Specifications.

3.0 **CONTENTS OF MIP:**

At least following information shall be given in detail in MIP along with the reference documents, copy of which shall be enclosed with MIP.

3.1 **Melting, Steel Treatment, Ingot Pouring**

- Ladle analysis
- Melting Process
- Ladle treatment
- Method of de-oxidation / Degassing
- Secondary Refining
- Method of ingot pouring
- Number and weight of melts in the ingot
- Pouring temperature
- Ingot weight and average diameter
- L / D ratio

3.2 **Forging Process**

- Power of the press
- Forging weight
- % Top discard
- % Bottom Discard
- Number of forging in the ingot
- Confirmation of final forging contour as per drawing
- Detailed forging sequence with sketch of forging dimensions and data of forging heats
- Special forging procedures are to be reported
- Total forging ratio



TD-218 Rev.00

**PLANT STANDARD
HYDERABAD****HY 065 20 99****REV.NO. 00****PAGE 3 OF 4****3.3 Preliminary Heat Treatment: HT cycle sketch to be submitted**

- Type of heat-treatment furnaces
- Heating rate
- Holding temperature and holding time
- Cooling rate
- Cooling medium
- Number of cycles
- Method of temperature measurement
- HT cycle sketch

3.4 Internal Tests and Inspections before Quality Heat Treatment**3.5 Quality Heat Treatment:**

- HT cycle sketch to be submitted
- Sketch of heat treatment contour of forging including ingot position and test piece locations
- Type of heat treatment furnaces
- Heat treatment position: vertical and horizontal
- Heating rate
- Holding temperature and holding time
- Cooling rate
- Cooling medium
- Method of cooling, quenching or spraying
- Temperature in the forging core
- Method of temperature measurement

3.6 Tests and Inspection after Heat Treatment:

- Mechanical tests: with details of test piece location and sizes (preferably with sketches), Test method
- Residual stress measurement (position of test and method of measurement, if applicable).
- Surface condition after machining for non destructive examination
- Surface crack inspection with details of test with details of inspection procedure
- Any other special tests (e.g.axial core test etc.)
- Ultrasonic test with details of test procedure preferably with sketch

HY 065 20 99	TD-718 Rev. 00	PLANT STANDARD HYDERABAD	
Rev.No. 00			
PAGE 4 OF 4			

- Dimensional check
- Acceptance norms of all tests and inspections along with reference documents
- TC review, Acceptance tests and inspection by BHEL / 3rd party

3.7 Heat Stability Test (If required as per technical purchase specification or ordering drawing)

- Position of bearing and measuring areas (with sketches)
- Method of heating
- Test procedure in detail
- Anti rust coating on surface
- Acceptance norms along with reference documents

3.8 Test Certificates to be submitted as per technical purchase specification

3.9 Marking, Preservation and Despatch

4.0 CROSS REFERRED STANDARDS:

- Nil -



CORPORATE STANDARD

AA 085 01 50

Rev. No. 00

PAGE 1 OF 4

Residual Stress Measurement on Turbine and Generator shafts

1. Residual Stress Condition

In the Course of heat treatment processes of turbine and generator shafts compressive residual stresses are induced in near surface areas. They are matched by tensile residual stresses in the interior. As turbine and generator shafts always undergo operational tensile stress, the residual stresses remaining after the heat treatment process are unfavorable. Therefore try to reduce residual Stresses as far as possible.

BHEL delivery specifications do not define the cooling down rates from tempering temperature conditions. Instead of this it has been specified that the compressive residual stresses must not exceed 60 N/mm² at any place on the surface. This has to be proved by Residual Stress Measurements performed by the manufacturer.

2. Residual Stress measurements

2.1 Residual Stress measurements are to be performed by the ring-core-method. To assure a conforming assessment of the results by the manufacturer and BHEL, the residual Stresses have to be calculated for the depth region from 2 to 4 mm using following formulas:

$$\sigma^{\tan} = \frac{\varepsilon^{\tan}(2\text{mm}) - \varepsilon^{\tan}(4\text{mm})}{2.36} + \frac{\varepsilon^{\text{ax}}(2\text{mm}) - \varepsilon^{\text{ax}}(4\text{mm})}{11.2}$$

$$\sigma^{\text{ax}} = \frac{\varepsilon^{\text{ax}}(2\text{mm}) - \varepsilon^{\text{ax}}(4\text{mm})}{2.36} + \frac{\varepsilon^{\tan}(2\text{mm}) - \varepsilon^{\tan}(4\text{mm})}{11.2}$$

These formulas are valid for 26NiCrMoV 145 and ring core of 14 mm in diameter. Stresses (σ) are given in N/mm², strains (ε) in $\mu\text{m/m}$.

2.2 Stress measurements have to be performed after the last tempering treatment on the contour as tempered. The appropriate location of the three measuring Points are marked in annex 1 and 2. Measurements have to be performed at the Points specified, being offset by 120° on circumference.

Revisions :

CL 33.1.0 of MOM of FC&F+HTM

APPROVED :

INTERPLANT MATERIAL RATIONALISATION
COMMITTEE-MRC (FCF+HTM)

Rev. No. 00

Amd.No.

Reaffirmed:

Prepared

Issued

Dt. of 1st. Issue

Dt:

Dt :

Year :

HARIDWAR

Corp. R&D

FEB. 2008



- 2.3 If measurements are to be performed on the contour as delivered, contact BHEL in any case to ensure that the cutting allowance available will suffice. Should the occasion arise, certain locations can be specified by BHEL.
- 2.4 Repeat the Stress measurements, if re-heat treatment or re-tempering is required.
- 2.5 In case, the relevant Stress condition cannot be determined unambiguously, BHEL reserves the right to define additional measuring Points.
- 2.6 An immediate and close exchange of experience regarding the measured values between manufacturer and BHEL is necessary.



CORPORATE STANDARD

AA 085 01 50

Rev. No. 00

PAGE 3 OF 4

Annexure-1

Customer

Drawing no.

Order no.


Identification no:

Subject

Material:

Heat treatment

Residual stress measurement
Test method: ring-core-method



	Heat treatment contour			Delivery contour			
Test position	1	2	3	1	2	3	
Reference point specification							Time pos.
σ_{tg}							N/mm ²
σ_{ax}							N/mm ²

Date

Company
Dept.



Annexure-2

Customer

Drawing no.

Order no.


Identification no:

Subject

Material:

Heat treatment

Residual stress measurement
Test method: ring-core-method



	Heat treatment contour			Delivery contour			
Test position	1	2	3	1	2	3	
Reference point							Time pos.
specification							N/mm ²
σ_{tg}							N/mm ²
σ_{ax}							N/mm ²

Date

Company
Dept.



PLANT STANDARD

HEEP-HARDWAR

HW 0850197

PAGE 1 OF 6

HEAT-STABILITY TEST

1.0 SCOPE:

This specification is valid for heat stability test for H.P and I.P rotor shaft forging of steam turbine.

2.0 REFERENCE DOCUMENTS:

Assistance has been taken from SEP 1950, 5/87.

3.0 REASON FOR TESTING :

The heat stability test gives information of proper heat-treatment in respect of

- unsymmetrically distributed residual stresses remaining after the tempering operation, which may get relaxed during the service time and thus may cause bending of rotor (B type deflection).
- A rotationally symmetrical microstructure (C-Type deflection)

4.0 SHAFTS TO BE TESTED :

The heat stability test is carried out on shafts only, which have a service temperature of $> 450^{\circ}\text{C}$. The rotors which have to work at temperature much lower than 150°C from tempering temperature, insignificant stresses will be released & hence no stability test is required. In addition to these for low service temperature, the shafts are of material having excellent hardenability.

A heat stability test will be carried out in case of

- prototypes
- new suppliers
- special service conditions or service stresses (decision by design/calculation department)

SUPERCEDES THE ~~REV~~ SHEET
UNDER THE SAME NO. 301
TSK-MTE-98-452
CHANGE ADVISE TO
NAME ~~ALS~~ - SIGN ~~th~~ - DATE ~~28.1.99~~

COPYRIGHT AND CONFIDENTIAL
The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in any way detrimental to the interest of the company.

INVENTORY No. P-22	SIGN & DATE 21/1/99	REVISION :				APPROVED:	
		NAME				SIGN & DATE	
		TSK	R. BHATIA	R.Bhatia/29-1-99	DRAWN		
		QAX	TSK with	R. Bhatia	WORKED	A.K. SARKAR	21/1/99
		STE	A.S.	21/1/99	CHECKED	J.P. MEENA	21/1/99
		AGREED DEPT	NAME	SIGN & DATE	SUPERVISED	V.B. ARORA	21/1/99
					PLANT		
					STANDARDIZATION COMMITTEE		
					6.48		
					PREPARED:	ISSUED:	DATE:
					MTE	STANDARDS DIVISION	29.1.99



PLANT STANDARD HEEP-HARDWAR

HW 0850197

PAGE 2 OF 6

SIGN & DATE

SUPERSEDES
INVENTORY No.

COPYRIGHT AND CONFIDENTIAL

The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in any way detrimental to the interest of the company.

SIGN & DATE

INVENTORY No.

5.0 TYPES OF DEFLECTION:

The possible types of deflection which can appear during the heat stability test are represented in Annexure : 01 (REFER SEP-1950)
5/87

6.0 PERFORMANCE OF TEST :

The heat stability test is carried out in the rotational symmetrically machined condition after the completed heat-treatment operation as per the cycle given in Annexure:02.

6.1 Rate of heating up and Temperature Cycle:

About 50°C / hr

6.2 Testing Temperature:

Tempering temperature minus 30°C.

In special cases other temperatures can be agreed upon.

The testing temperature should lie above the service temperature as high as possible to assure that during the later turbine operation possibility of rotor deflection is avoided. The cycle (Ref. Ann:02) marked as firm/dark line is mandatory i.e. one dip of about 150 °C is essential as shown in sketch.

6.3 Cooling Rate:

To avoid new stresses during cooling from testing temperature to room temperature a cooling rate of about 15°C/h till approximately 200°C is to be applied; than a quicker cooling rate can be used.

Ⓒ SUPERCEDES THE OLD SHEET
UNDER THE SAME N 301
CHANGE ADV C 10 JSK-MTE-98-452
NAME AKS - SIGN [Signature] - DATE 28-1-99

REVISION :

WORKED BY

AKSARKAR

[Signature]

12-1-99

CHECKED BY

JPMEENA

[Signature]

12-1-99



PLANT STANDARD HEEP-HARDWAR

HW 0850197

PAGE 3 OF 6

SIGN & DATE

SUPERSEDES
INVENTORY No.

COPYRIGHT AND CONFIDENTIAL

The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in any way detrimental to the interest of the company.

SIGN & DATE

INVENTORY No.

P-22

12/2/99

6.4 Location of Deflection:

On the coupling a clockwise numbering is to be provided in direction of power run which makes possible the fixing of an appeared deflection on the circumference.

6.5 Readings:

Temperature, deflection and location of deflection are to be checked each hour and documented.

7.0 ACCEPTANCE CRITERIA :

A and D type deflections are caused by radiation and have no influence on the later turbine operation; here exists convection only. These are acceptable.

In case of detection of B - type deflections the cycling of testing temperature shall be continued till the rotor becomes stable, i.e. after the temperature dip of about 150 °C the deflection of the shaft shall lie approximately at the same level in each case at the end of the holding times at testing temperature. After reaching heat stability the shaft is acceptable, independent of the value of the B-type deflection.

C-type deflections ≥ 0.05 mm are not acceptable.

C

SUPERCEDES THE OLD Dwg SHEET
UNDER THE SAME NO. 3.1
CHANGE ADV. CE NO. TSX-MTE-98-452
NAME AKB S. CH DATE 12.1.99

REVISION :

WORKED BY

AUSARKAR

12.1.99

CHECKED BY

JP MEENA

12.1.99



PLANT STANDARD


HEEP—HARDWAR

HW 0850197

PAGE 4 OF 6

ANNEXURE-01

TYPES OF DEFLECTION



SUPERCEDES THE OLD Dwg. SHEET
UNDER THE SAME NO. Dwg.
CHANGE ANY Dwg. NO. TSX-MTE-98-452
NAME A.K.S. DATE 29.1.99

WORKED BY A.K.SARKAR

CHECKED BY J.P.MEENA

12.1.99

12.1.99



PLANT STANDARD


HEEP—HARDWAR

HW 0850197

PAGE 5 OF 6

ANNEXURE-02

HEAT STABILITY CYCLE



COPYRIGHT AND CONFIDENTIAL

The information on this document is the property of Bharat Heavy Electricals Limited
It must not be used directly or indirectly in any way detrimental to the interest of the company

SIGN & DATE

INVENTORY NO

SUPERSEDES INVENTORY NO

SIGN & DATE

P-22-199

REVISION BY: A.K.S. SARKAR
DATE: 12-01-99
REVISION NO: 01
REVISION DESCRIPTION: 1st revision
REVISION BY: J.P. MEENA
DATE: 12-01-99
REVISION NO: 02
REVISION DESCRIPTION: 2nd revision

WORKED BY

A.K. SARKAR

12-01-99

CHECKED BY

J.P. MEENA

12-01-99



PLANT STANDARD

HW 0850197

PAGE 6 OF 6

ANNEXURE-I

RECORD OF CHANGES

REV CODE	NO OF CHGS	DOCU NO	SHEET NO	SIGN	DATE	REV CODE	NO OF CHGS	DOCU NO	SHEET NO	SIGN	DATE
C	-	TSX-MTE-98-452	SUPERSEDES OLD SPEC. UNDER THE SAME NUMBER	<i>[Signature]</i>	12.1.99						

(C)
 SUPERCEDES THE OLD DATA SHEET
 UNDER THE SAME NUMBER
 CHANGE ADVISED TO TSX-MTE-98-452
 NAME AKS S.L.N. DATE 12/1/99

DISTRIBUTION OF PRINTS

DEPTT	TGE	STE	AME	DME	HGE	HTE	ACE	HXE	MTE	MRL	IN-SUL SYS	HLE	TSX	THC	PPX	MCX	CSX
		✓							✓	✓			✓				
DEPTT	AIX	OSX	CCX	FAX	TFX	TLX (J&T)	TTX-GTX	TTX ST	TTX HT	TTX EM	WT	QAX	QCX	PCM	WC 202	WC 205	WC 227
								✓				✓	✓				
DEPTT	FBM BL II	HTM WC276	STM WC236	TLM WC832	ACM WC291	CIM WC330	FGM WC356 /361	SUM WC370	WWM WC386	HXM WC390	WEX WC 6100	ESX	TRX	TAX	AVP	BP GFE	HY
																✓	4
REVISION									DRAWN								
									WORKED				A.K.SARKAR <i>[Signature]</i> 12.1.99				
									CHECKED				J.P.NEENA <i>[Signature]</i> 12.1.99				

SIGN & DATE

INVENTORY NO
SUPERSEDS

COPYRIGHT AND CONFIDENTIAL

The information on this document is the property of Bharat Heavy Electricals Limited.
It must not be used directly or indirectly in any way detrimental to the interest of the company.

SIGN. & DATE

INVENTORY NO.

P-22

12/1/99