

PRE QUALIFYING CRITERIA

JOB	MANUFACTURING & SUPPLY OF 'CAST BASALT LINED PIPE CUT PIECES – 2x600 MW NORTH CHENNAI THERMAL POWER PROJECT.
-----	--

Bidder shall note & comply with the technical pre-qualification requirements mentioned below.

SL NO	PRE-QUALIFICATION CRITERIA
1.0	Bidder should be a manufacturer / supplier of cast basalt lined pipes / bends of internal diameter not less than 200mm having minimum cast basalt lining thickness of 20mm (with permissible tolerance ± 2 mm)
2.0	The bidder must be in business of supply of cast basalt lined pipes and should have supplied at least 200 meters of cast basalt lined pipes of internal diameter not less than 200mm (having minimum cast basalt lining thickness of 20mm with permissible tolerance ± 2 mm) to any PSU / government organization / private organization / industrial establishment. Copy of purchase order and shop test / inspection report by customer shall be submitted for BHEL review.
3.0	The bidder should have testing facilities available or should be able to arrange testing facilities at owner approved laboratories for carrying out complete analysis of the cast basalt lined MS pipes as specified in the technical specification / quality plans of the owner.