



CONTROLS & INSTRUMENTATION (FB)
PRE-QUALIFICATION REQUIREMENT (PQR)

CI:PE:PQR:026

Rev. No: 01

Dt. : 05-08-2021

Flame Proof Junction Box 96AJF - ITEM CODE

S.No.	Bid Requirements (Allowed Values)	Vendor's Confirmation
1.	Type of Bidder: Bidder should be an Original Equipment Manufacturer for Flameproof junction boxes.	
2.	In House Facility: - Bidder should have all machineries and facilities for complete in-house manufacturing of Flame Proof junction boxes. List of in-house machineries and facilities shall be furnished.	
3.	Ingress protection: - Bidder should have manufactured IP-65 Flame proof Junction boxes supported with test reports not earlier than 7 Years from the date of enquiry.	
4.	Credentials in Power plant/ Heavy Industries: - Bidder should have supplied Flame Proof Junction Boxes of similar dimensions as called in enquiry to coal fired thermal power plants in India. PO for the same and Reference list for the similar supplies to be furnished.	

- End of document -