

ENQUIRY No.
Project: 5X800 MW YADADRI TPP
Package: EPR INSULATED FIRE SURVIVAL CABLES
Annexure-I (BHEL-PEM Scope of supply)

ANNEXURE-I

S. No.	DESCRIPTION	HSN CODE	UNIT	TOTAL QTY (PEM Scope)	LOT-1 Quantity	Drum Length	UNIT EX- WORKS PRICE (INR)	TOTAL EX- WORKS PRICE(DULY PACKED) (INR)	Freight rate in %	Freight Amount,as applicable in Rs.	TOTAL PRICES (Total Ex works + Freight(as applicable)) (INR)	GST type	GST rate in %	GST amount in Rs.	TOTAL PRICE F.O.R SITE PRICE (INR)	Total FOR site Price In Words
Total A+B		85444930	MTR	1	1				0							
A	1.1 kV Stranded, Tinned annealed high conductivity, Class 2 Copper conductor Power cable, EPR insulated, HOFR Innersheath, GS round wire armour for multicore cable & Aluminium round wire armour for single core cable, HOFR Outersheath generally conforming to IS-9968, Part-I & BHEL specification.															
A2	1C - 400- AL ARMoured	85444930	MTR	7000	5000	500	0	0	0.00%	0	0			0	0	
A3	2C - 95- GS ARMoured	85444930	MTR	6000	4000	500	0	0	0.00%	0	0			0	0	
A4	3C-240 GS ARMoured	85444930	MTR	1000	1000	500	0	0	0.00%	0	0			0	0	
B	1.1 kV Stranded, Tinned annealed high conductivity, Class 2 Copper conductor Control cable, EPR insulated, HOFR Innersheath, GS round wire armour for multicore cable & Aluminium round wire armour for single core cable, HOFR Outersheath generally conforming to IS-9968, Part-I & BHEL specification.															
B1	3C - 2.5- GS ARMoured	85444930	MTR	2500	2000	1000	0	0	0.00%	0	0			0	0	
B2	5C - 2.5- GS ARMoured	85444930	MTR	5000	4000	1000	0	0	0.00%	0	0			0	0	

NOTES :

- Quantities indicated above for S.No. (A) & (B) shall be known as Order Quantities. The variation in quantities of all sizes put together shall be limited to (-) 30% to (+) 30% of the total contract value derived on the basis of the Ordered quantities.
- The bidder shall indicate the unit price of each type and size of cables listed as per the BOQ-Cum-Price Schedule. The unit prices shall apply for adjustment of variation in quantity as stipulated above.
- Lot-I quantities indicated above shall be cleared for manufacturing along with PO. However, manufacturing of the cables shall be taken up by the successful bidder only after approval of technical and quality documentation. Subsequent lots shall be cleared for manufacture based on progress of engineering & site requirements.
- The standard drum length shall be as indicated above for each cable size. Tolerance on individual drum length shall be $\pm 5\%$.
- Overall tolerance on total dispatched quantity of each size shall be (-) 2% and (+) 0% except where the total ordered quantity is one single drum length of 500m, in which case it shall be -5%/0%. Cables consumed for testing and inspection shall be to bidder's account.
- For each individual cable size, one short length of not less than 200m may be accepted only in the final drum length to complete the supply (except where the total ordered quantity is one single drum length of 500m). The overall tolerance limits stipulated above shall continue to apply (in case short lengths are accepted).
- In case of the quantities of any one lot cleared by BHEL for manufacturing are manufactured and offered for inspection by successful bidder in more than one batch, BHEL reserves the right to witness type testing on all batches without any price implications.
- Bidder shall indicate unit price of cables inclusive of type test charges. No separate charges shall be payable for type tests.

Particulars of bidder / authorised representative

Name	Designation	Signature		Date

Company Seal

ENQUIRY No.
Project: 5X800 MW YADADRI TPP
Package: EPR INSULATED FIRE SURVIVAL CABLES
Annexure-II (BHEL-TBG Scope of supply)

ANNEXURE-II

S. No.	DESCRIPTION	HSN CODE	UNIT	TOTAL QTY (PEM Scope)	LOT-1 Quantity	Drum Length	UNIT EX- WORKS PRICE (INR)	TOTAL EX- WORKS PRICE(DULY PACKED) (INR)	Freight rate in %	Freight Amount,as applicable in Rs.	TOTAL PRICES (Total Ex works + Freight(as applicable)) (INR)	GST type	GST rate in %	GST amount in Rs.	TOTAL PRICE F.O.R SITE PRICE (INR)	Total FOR site Price In Words
A	1.1 kV Stranded, Tinned annealed high conductivity, Class 2 Copper conductor Power cable, EPR insulated, HOFR Innersheath, GS round wire armour for multicore cable & Aluminium round wire armour for single core cable, HOFR Outersheath generally conforming to IS-9968, Part-I & BHEL specification.															
A1	1C - 150- AL ARMoured	85444930	MTR	1000	1000	500	0	0	0.00%	0	0		0%	0	0	

NOTES :

- 1
- Quantities indicated above for S.No. (A) & (B) shall be known as Order Quantities. The variation in quantities of all sizes put together shall be limited to (-) 30% to (+) 30% of the total contract value derived on the basis of the Ordered quantities.
- 2
- The bidder shall indicate the unit price of each type and size of cables listed as per the BOQ-Cum-Price Schedule. The unit prices shall apply for adjustment of variation in quantity as stipulated above.
- 3
- Lot-I quantities indicated above shall be cleared for manufacturing along with PO. However, manufacturing of the cables shall be taken up by the successful bidder only after approval of technical and quality documentation. Subsequent lots shall be cleared for manufacture based on progress of engineering & site requirements.
- 4
- The standard drum length shall be as indicated above for each cable size. Tolerance on individual drum length shall be ±5%.
- 5
- Overall tolerance on total dispatched quantity of each size shall be (-) 2% and (+) 0% except where the total ordered quantity is one single drum length of 500m, in which case it shall be -5%/0%. Cables consumed for testing and inspection shall be to bidder's account.
- 6
- For each individual cable size, one short length of not less than 200m may be accepted only in the final drum length to complete the supply (except where the total ordered quantity is one single drum length of 500m). The overall tolerance limits stipulated above shall continue to apply (in case short lengths are accepted).
- 7
- In case of the quantities of any one lot cleared by BHEL for manufacturing are manufactured and offered for inspection by successful bidder in more than one batch, BHEL reserves the right to witness type testing on all batches without any price implications.
- 8
- Bidder shall indicate unit price of cables inclusive of type test charges. No separate charges shall be payable for type tests.

Particulars of bidder / authorised representative

Name	Designation	Signature		Date

Company Seal