

## **TENDER SPECIFICATIONS**

**E- TENDER SPECIFICATION NUMBER: BHE/PW/PUR/WNS-U5/2990**

**FOR**

**HANDLING AT SITE STORES/STORAGE YARD, TRANSPORTATION TO SITE OF WORK, COMPLETE ERECTION, TESTING, COMMISSIONING AND HANDING OVER OF ELECTRICAL WORKS OF ESP R&M SYSTEM AND ITS AUXILIARIES /ASSOCIATED EQUIPMENT FOR ESP R&M WANAKBORI U# 5 PROJECT**

### **VOLUME I – TECHNICAL BID**

**THIS TENDER SPECIFICATION CONSISTS OF:**

<b>Notice Inviting Tender</b>	
<b>Volume-IA</b>	<b>Technical Conditions of Contract</b>
<b>Volume-IB</b>	<b>Special conditions of Contract</b>
<b>Volume-IC</b>	<b>General conditions of Contract</b>
<b>Volume-ID</b>	<b>Forms &amp; Procedures</b>
<b>Volume II</b>	<b>Price Bid</b>

**Bharat Heavy Electricals Limited**  
(A Government of India Undertaking)  
Power Sector – Western Region  
345-Kingsway, Nagpur-440001

CONTENTS		
Volume No	Description	Hosted in website bhel.com (Briefly) and detailed in BHEL e-Procurement Portal as files titled
NIL	Tender Specification Issue Details	(Part of <b><u>Vol-IA-2990</u></b> )
NIL	Notice Inviting Tender	(Part of <b><u>Vol-IA-2990</u></b> )
I-A	Technical Conditions of Contract	Vol-I-A-2990
I-B	Special Conditions of Contract	Vol-I-BCD-2990
I-C	General Conditions of Contract	(Part of Vol-I-BCD-2990)
I-D	Forms & Procedures	(Part of Vol-I-BCD-2990)
<del>I-E</del>	<del>Technical Specification &amp; Drawing</del>	<del>Vol-IE-2990</del>
II	Price Bid Specification as specified in E-Procurement Portal	Volume-II-2990

## **E-TENDER SPECIFICATIONS**

**E- TENDER SPECIFICATION NUMBER: BHE/PW/PUR/WNS-U5/2990**

**FOR**

**HANDLING AT SITE STORES/STORAGE YARD, TRANSPORTATION TO SITE OF WORK, COMPLETE ERECTION, TESTING, COMMISSIONING AND HANDING OVER OF ELECTRICAL WORKS OF ESP R&M SYSTEM AND ITS AUXILIARIES /ASSOCIATED EQUIPMENT FOR ESP R&M WANAKBORI U# 5 PROJECT**

EARNEST MONEY DEPOSIT: Refer Notice Inviting Tender

LAST DATE FOR                      Refer Notice Inviting Tender  
TENDER SUBMISSION

THESE TENDER SPECIFICATION DOCUMENTS CONTAINING VOLUME-I AND VOLUME- II ARE ISSUED TO:

M/s. ....  
.....

PLEASE NOTE:  
THESE TENDER SPECS DOCUMENTS ARE NOT TRANSFERABLE.

For Bharat Heavy Electricals Limited

**GM (Purchase)**

Place: Nagpur

Dae:

**BHEL PSWR**  
**Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 4 of 108

Date: 12-07-2024

**NOTICE INVITING TENDER (NIT)**

**NOTE: BIDDER MAY DOWNLOAD FROM WEB SITES**

**To,**

Dear Sir/Madam,

**Sub : NOTICE INVITING E-TENDER**

Sealed offers in two part bid system (National competitive bidding (NCB) or International Competitive Bidding (ICB) are invited from reputed & experienced bidders (meeting PRE QUALIFICATION CRITERIA as mentioned in Annexure-1) through E-Procurement Portal <https://eprocurebhel.co.in> only, for the subject job by the undersigned on the behalf of BHARAT HEAVY ELECTRICALS LIMITED as per the tender document. Following points relevant to the tender may please be noted and complied with.

**1.0 Salient Features of NIT**

S No.	ISSUE	DESCRIPTION
i	TENDER NUMBER	BHE/PW/PUR/WNS-U5/2990
ii	Broad Scope of job	HANDLING AT SITE STORES/STORAGE YARD, TRANSPORTATION TO SITE OF WORK, COMPLETE ERECTION, TESTING, COMMISSIONING AND HANDING OVER OF ELECTRICAL WORKS OF ESP R&M SYSTEM AND ITS AUXILIARIES /ASSOCIATED EQUIPMENT FOR ESP R&M WANAKBORI U# 5 PROJECT
iii	DETAILS OF TENDER DOCUMENT	
A	Volume-IA	Technical Conditions of Contract (TCC) consisting of Scope of work, Technical Specification, Drawings, Procedures, Bill of Quantities, Terms of payment, etc. <span>Applicable</span>
B	Volume-IB	Special Conditions of Contract (SCC) <span>Applicable</span>
C	Volume-IC	General Conditions of Contract (GCC) <span>Applicable</span>
D	Volume-ID	Forms and Procedures <span>Applicable</span>
E	Volume-IE	Drawing and Plot Plan <span>Applicable</span>
	Volume-II	Price Schedule (Absolute value). <span>Applicable</span>
iv	Issue of Tender Documents	Tender documents will be available for downloading from BHEL website ( <a href="http://www.bhel.com">www.bhel.com</a> ) or e-procurement portal ( <a href="https://eprocurebhel.co.in">https://eprocurebhel.co.in</a> ) as per schedule below: <b>Start: 18/07/2024, Time :17:00 Hrs</b> <b>Closes: 01/08/2024, Time: 13:00 Hrs</b> Brief information of the tenders shall also be available at central public procurement portal. ( <a href="https://eprocure.gov.in/epublish/app">https://eprocure.gov.in/epublish/app</a> ) <span>Applicable</span>

**BHEL PSWR**  
**Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 5 of 108

S No.	ISSUE	DESCRIPTION	
v	<b>DUE DATE &amp; TIME OF OFFER SUBMISSION</b>	<p><b>Date: 01/08/2024, Time :13:00 Hrs</b></p> <p>The bidder should submit their offer online only in e-Procurement portal at <a href="https://eprocurebhel.co.in">https://eprocurebhel.co.in</a></p> <p><b><u>Bidders are requested to upload their offer well in advance in order to avoid last minute congestion at this website.</u></b></p> <p>Hard copy bid or bids through E-mail / fax shall not be accepted.</p>	Applicable
vi	<b>OPENING OF TENDER (Techno-Commercial Bid)</b>	<p><b>Date:01/08/2024, Time: 17:00 Hrs</b></p> <p>Notes:</p> <p>(1) In case the due date of opening of tender becomes a non-working day, then the due date &amp; time of offer submission and opening of tenders get extended to the next working day.</p> <p>(2) Bidder may depute representative to witness the opening of tender. For e-Tender, Bidder may witness the opening of tender through e-Procurement portal only.</p>	Applicable
vii	<b>EMD AMOUNT</b>	<p><b>NIL- Bid Security Declaration-Annexure-13</b></p> <p><b>Important Note: Bidders kindly to take note that EMD (Earnest Money Deposit) shall be furnished by MSE bidders as well, as per the amount and procedure indicated in the NIT/GCC.</b></p>	Applicable
viii	<b>COST OF TENDER</b>	NIL	Not Applicable
ix	<b>LAST DATE FOR SEEKING CLARIFICATION</b>	One day before Bid Submission Date	Applicable
x	<b>SCHEDULE OF Pre Bid Discussion (PBD)</b>	---	Not Applicable
xi	<b>INTEGRITY PACT &amp; DETAILS OF INDEPENDENT EXTERNAL MONITOR (IEM)</b>	<p>1) Shri Otem Dai, IAS (Retd.)</p> <p>2) Shri Bishwamitra Pandey, IRAS (Retd.)</p> <p>3) Shri Mukesh Mittal, IRS (Retd.)</p>	Not Applicable
xii	<b>Latest updates</b>	<p>Latest updates on the important dates, Amendments, Correspondences, Corrigenda, Clarifications, Changes, Errata, Modifications, Revisions, etc to Tender Specifications will be hosted in BHEL webpage (<a href="http://www.bhel.com">www.bhel.com</a>--&gt;Tender Notifications →View Corrigendum), Central Public Procurement portal (<a href="https://eprocure.gov.in/epublish/app">https://eprocure.gov.in/epublish/app</a>) &amp; on e-tender portal <a href="https://eprocurebhel.co.in">https://eprocurebhel.co.in</a> and not in the newspapers. Bidders to keep themselves updated with all such information.</p>	

**BHEL PSWR**  
**Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 6 of 108

- 2.0 The offer shall be submitted as per the instructions of tender document and as detailed in this NIT. Bidders to note specifically that all pages of tender document, including these NIT pages of this particular tender together with subsequent correspondences shall be submitted by them, duly signed digitally using Class III DSC & uploaded in E-Procurement Portal, as part of offer. **Rates/Price including discounts/rebates, if any, mentioned anywhere/in any form in the techno-commercial offer other than the Price Bid, shall not be entertained.**
- 3.0 Not Used
- 4.0 Unless specifically stated otherwise, bidder shall deposit EMD as per clause 1.9 of General Conditions of Contract.

For Electronic Fund Transfer the details are as below:-

NAME OF THE BENEFICIARY	BHARAT HEAVY ELECTRICALS LTD
ADDRESS OF THE COMPANY	5th Floor, SHREE MOHINI COMPLEX 345, KINGSWAY,NAGPUR
NAME OF BANK	STATE BANK OF INDIA
NAME OF BANK BRANCH AND BRANCH CODE	SBI,NAGPUR MAIN BRANCH ,CODE-00432
CITY	NAGPUR
ACCOUNT NUMBER	40227423158
ACCOUNT TYPE	MC-C C Clean (C&I)
IFSC CODE OF THE BENEFICIARY BANK BRANCH	SBIN0000432
MICR CODE OF THE BANK BRANCH	440002002

(Note -: In case of E-Tenders, proof of remittance of EMD should be uploaded in the E-Procurement Portal and originals, as applicable, shall be sent to the officer inviting tender within a reasonable time, failing which the offer is liable to be rejected.

(Note -: In case of E-Tenders, proof of remittance of EMD should be uploaded in the E-Procurement Portal and originals, as applicable, shall be sent to the officer inviting tender within a reasonable time, failing which the offer is liable to be rejected.

**5.0 Procedure for Submission of Tenders:**

This is an E-tender floated online through our E-Procurement Site (<https://eprocurebhel.co.in>). The bidder should respond by submitting their offer online only in our e-Procurement platform at (<https://eprocurebhel.co.in>). Offers are invited in two-parts only.

**Documents Comprising the e-Tender**

The tender shall be submitted online ONLY EXCEPT EMD (in physical form) as mentioned below:

**a. Technical Tender (UN priced Tender)**

All Technical details (e.g. Eligibility Criteria requested (as mentioned below)) should be attached in e-tendering module, failing which the tender stands invalid & may be REJECTED. Bidders shall furnish the following information along with technical tender (preferably in pdf format):

- i. Earnest Money Deposit (EMD) furnished in accordance with NIT Clause 4.0. ~~Alternatively, documentary evidence for claiming exemption as per clause 29 of NIT.~~

**BHEL PSWR  
Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 7 of 108

ii. Technical Bid (without indicating any prices).

**b. Price Bid:**

- i. Prices are to be quoted in the attached Price Bid format online on e-tender portal.
- ii. The price should be quoted for the accounting unit indicated in the e-tender document.

**Note:**

- It is the responsibility of tenderer to go through the Tender document to ensure furnishing all required documents in addition to above, if any. Any deviation would result in REJECTION of tender and would not be considered at a later stage at any cost by BHEL.
- A person signing (manually or digitally) the tender form or any documents forming part of the contract on behalf of another shall be deemed to warrantee that he has authority to bind such other persons and if, on enquiry, it appears that the persons so signing had no authority to do so, the purchaser may, without prejudice to other civil and criminal remedies, cancel the contract and hold the signatory liable for all cost and damages.
- A tender, which does not fulfil any of the above requirements and/or gives evasive information/reply against any such requirement, shall be liable to be ignored and rejected.

**DO NOT'S**

Bidders are requested NOT to submit the hard copy of the Bid. In case offer is sent through hard copy/fax/telex/cable/electronically in place of e-tender, the same shall not be considered. **Also, uploading of the price bid in prequalification bid or technical bid may RESULT IN REJECTION of the tender.**

**Digital Signing of e-Tender**

Tenders shall be uploaded with all relevant PDF/zip format. The relevant tender documents should be uploaded by an authorized person having Class 3- SHA2- 2048 BIT- SIGNING & ENCRYPTION digital signature certificate (DSC).

**The Requirement:**

1. A PC with Internet connectivity &
2. DSC (Digital Signature Certificate) (**Class 3- SHA2- 2048 BIT- SIGNING & ENCRYPTION**)

BHEL has finalized the e-procurement service Provider:-

**NIC PORTAL (<https://eprocurebhel.co.in>)**

**For E-PROCUREMENT ASSISTANCE & TRAINING, NIC PORTAL HELPDESK CONTACTS AS PER FOLLOWING:**

**For any technical related queries, please call at 24 x 7 Help Desk Number**

**0120-4001 002**

**0120-4200 462**

**0120-4001 005**

**0120-6277 787**

**1. Peter Raj, NIC, Ph: 9942069052**

**Email Support: [support-eproc@nic.in](mailto:support-eproc@nic.in)**

**Other details/update yourself from : <https://eprocurebhel.co.in>**

Registered Office: BHEL House, Siri Fort, New Delhi – 110 049, India

Website: [www.bhel.com](http://www.bhel.com)

**BHEL PSWR**  
**Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 8 of 108

The process of utilizing e-procurement necessitates usage of **DSC (Digital Signature Certificate) (Class 3- SHA2- 2048 BIT- SIGNING & ENCRYPTION)** and you are requested to procure the same immediately, if not presently available with you. Please note that only with DSC, you will be able to login the e-procurement secured site and take part in the tendering process.

The contact details of the DSC certifying authority:-  
please refer <http://www.mca.gov.in/> → MCA SERVICES → DSC SERVICES

Vendors are requested to go through seller manual available on <https://eprocurebhel.co.in>.

**Procedure for Submission of Tenders (To be used in case of Paper bid only):** The Tenderers must submit their Tenders to Officer inviting Tender, as detailed below:

- ~~PART I consisting of 'PART I A (Techno Commercial Bid)' & 'PART I B (EMD)' in two separate sealed and superscribed envelopes (ENVELOPE I & ENVELOPE II)~~
- ~~PART II (Price Bid) — in sealed and superscribed envelope (ENVELOPE-III)~~

One set of tender documents shall be retained by the bidder for their reference

- 6.0 The contents for ENVELOPES and the superscription for each sealed cover/Envelope are as given below.  
**(All pages to be signed and stamped) (To be used in case of Paper bid only):**

Sl. no.	Description	Remarks
	<b>Part I A</b>	
	<del><b>ENVELOPE – I superscribed as:</b> PART I (TECHNO COMMERCIAL BID) TENDER NO:- NAME OF WORK:- PROJECT:- DUE DATE OF SUBMISSION:-  <b>CONTAINING THE FOLLOWING:-</b></del>	
i. —	<del>Covering letter/Offer forwarding letter of Tenderer.</del>	
ii. —	<del>Duly filled in 'No Deviation Certificate' as per prescribed format to be placed after document under sl no (i) above.  <b>Note:</b> a. — In case of any deviation, the same should be submitted separately for technical &amp; commercial parts, indicating respective clauses of tender against which deviation is taken by bidder. The list of such deviation shall be placed after document under sl no (i) above. It shall be specifically noted that deviation recorded elsewhere shall not be entertained. b. — BHEL reserves the right to accept/reject the deviations without assigning any reasons, and BHEL decision is final and binding. i). — In case of acceptance of the deviations, appropriate loading shall be done by BHEL ii). — In case of unacceptable deviations, BHEL reserves the right to reject the tender</del>	
iii. —	<del>Supporting documents/ annexure/ schedules/ drawing etc. as required in line with Pre-Qualification criteria.</del>	



**BHEL PSWR**  
**Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 9 of 108

	It shall be specifically noted that all documents as per above shall be indexed properly and credential certificates issued by clients shall distinctly bear the name of organization, contact ph. no, FAX no, etc.	
iv. —	All Amendments/Correspondences/Corrigenda/Clarifications/Changes/Errata etc. pertinent to this NIT.	
v. —	Integrity Pact Agreement (Duly signed by the authorized signatory)	If applicable
vi. —	Duly filled in annexures, formats etc. as required under this Tender Specification/NIT	
vii. —	Notice inviting Tender (NIT)	
viii. —	Volume – I A : Technical Conditions of Contract (TCG) consisting of Scope of work, Technical Specification, Drawings, Procedures, Bill of Quantities, Terms of payment, etc.	
ix. —	Volume – I B : Special Conditions of Contract (SCC)	
x. —	Volume – I C : General Conditions of Contract (GCC)	
xi. —	Volume – I D : Forms & Procedures	
xii. —	Volume – II (UNPRICED – without disclosing rates/price, but mentioning only 'QUOTED' or 'UNQUOTED' against each item	
xiii. —	Any other details preferred by bidder with proper indexing.	

	<b>PART-I B</b>	
	<b><u>ENVELOPE – II superscribed as:</u></b> PART-I (EMD) TENDER NO : NAME OF WORK : PROJECT: DUE DATE OF SUBMISSION:  <b><u>CONTAINING THE FOLLOWING:-</u></b>	
	Earnest Money Deposit (EMD) in the form as indicated in this Tender	

	<b>PART-II</b>	
	<b>PRICE BID</b> consisting of the following shall be enclosed	
	<b><u>ENVELOPE-III</u></b> superscribed as: PART-II (PRICE BID) TENDER NO : NAME OF WORK : PROJECT: DUE DATE OF SUBMISSION:  <b><u>CONTAINING THE FOLLOWING</u></b>	
i	Covering letter/Offer forwarding letter of Tenderer enclosed in Part I	
ii	Volume II – PRICE BID ( Duly Filled in Schedule of Rates – rate/price to be entered in words as well as figures)	

	<b>OUTER COVER</b>	
	<b><u>ENVELOPE-IV</u></b> (MAIN ENVELOPE / OUTER ENVELOPE) superscribed as:	

**BHEL PSWR**  
**Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 10 of 108

	<del>TECHNO COMMERCIAL BID, PRICE BID &amp; EMD</del> <del>TENDER NO:</del> <del>NAME OF WORK:</del> <del>PROJECT:</del> <del>DUE DATE OF SUBMISSION:</del>  <del>CONTAINING THE FOLLOWING:</del>	
i	<del>○ Envelopes I</del> <del>○ Envelopes II</del> <del>○ Envelopes III</del>	

- **SPECIAL NOTE: All documents/ annexures to be submitted should be uploaded in respective places in the E-Tender portal as per the list mentioned given in this NIT. BHEL shall not be responsible for any in-complete documents.**

- 7.0 Deviation with respect to tender clauses and additional clauses/suggestions in Techno-commercial bid / Price bid shall NOT be considered by BHEL. Bidders are requested to positively comply with the same.
- 8.0 BHEL reserves the right to accept or reject any or all Offers without assigning any reasons thereof. BHEL also reserves the right to cancel the Tender wholly or partly without assigning any reason thereof. Also BHEL shall not entertain any correspondence from bidders in this matter (except for the refund of EMD).
- 9.0 **Assessment of Capacity of Bidders:**

**Bidder's capacity for executing the job under tender shall be assessed based on its 'LOAD and PERFORMANCE' and 'AVERAGE ANNUAL TURNOVER', as per the following:**

- I. ~~**LOAD:**~~ Load takes into consideration ~~**ALL**~~ the contracts of the Bidder under execution with BHEL Regions, irrespective of whether they are similar to the tendered scope or not. The cut off month for reckoning 'Load' shall be the 3<sup>rd</sup> Month preceding the month corresponding to the 'latest date of bid submission', in the following manner-

~~(Note: For example, if latest bid submission is in Jan 2017, then the 'load' shall be calculated up to and inclusive of Oct 2016)~~

~~Total number of Packages in hand = Load (P)~~

~~Where 'P' is the sum of all unit wise identified packages (refer table-1) under execution with BHEL Regions as on the cut off month defined above, including packages yet to be commenced, excepting packages which are on Long Hold.~~

- II. ~~**PERFORMANCE:**~~ Here 'Monthly Performance' of the bidder for all the packages (under execution/ executed during the 'Period of Assessment' in all Power Sector Regions of BHEL) ~~**SIMILAR**~~ to the packages covered under the tendered scope, excepting packages not commenced shall be taken into consideration. The 'Period of Assessment' shall be 6 months preceding and including the cut off month. The cut off month for reckoning 'Period of Assessment' shall be the 3<sup>rd</sup> Month preceding the month corresponding to 'latest date of bid submission', in the following manner:

**BHEL PSWR**  
**Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 11 of 108

(Note: For example, if 'latest date of bid submission' is in Jan 2017, then the 'performance' shall be assessed for a 6 months' period up to and inclusive of Oct 2016 (i.e. from May 2016 to Oct 2016), for all the unit wise identified packages (refer Table I))

i). Calculation of Overall 'Performance Rating' for 'Similar Package/Packages' for the tendered scope under execution at Power Sector Regions for the 'Period of Assessment':

This shall be obtained by summing up the 'Monthly Performance Evaluation' scores obtained by the bidder in all Regions for all the similar Package/packages', divided by the total number of Package months for which evaluation should have been done, as per procedure below:

- a)  $P_1, P_2, P_3, P_4, P_5, \dots, P_N$  etc. be the packages (under execution/ executed during the 'Period of Assessment' in all Regions of BHEL) **SIMILAR** to the packages covered under the tendered scope, excepting packages not commenced. Total number of similar packages for all Regions =  $P_T$  (i.e.  $P_T = P_1 + P_2 + P_3 + P_4 + \dots + P_N$ )
- b) Number of Months ' $T_1$ ' for which 'Monthly Performance Evaluation' as per relevant formats, should have been done in the 'Period of Assessment' for the corresponding similar package  $P_1$ . Similarly  $T_2$  for package  $P_2$ ,  $T_3$  for package  $P_3$ , etc. for the tendered scope. Now calculate cumulative total months ' $T_T$ ' for total similar Packages ' $P_T$ ' for all Regions (i.e.  $T_T = T_1 + T_2 + T_3 + T_4 + \dots + T_N$ )
- c) Sum ' $S_1$ ' of 'Monthly Performance Evaluation' Scores ( $S_{1-1}, S_{1-2}, S_{1-3}, S_{1-4}, S_{1-5}, \dots, S_{1-T_1}$ ) for similar package  $P_1$ , for the 'period of assessment' ' $T_1$ ' (i.e.  $S_1 = S_{1-1} + S_{1-2} + S_{1-3} + S_{1-4} + S_{1-5} + \dots + S_{1-T_1}$ ). Similarly,  $S_2$  for package  $P_2$  for period  $T_2$ ,  $S_3$  for package  $P_3$  for period  $T_3$  etc. for the tendered scope for all Regions. Now calculate cumulative sum ' $S_T$ ' of 'Monthly Performance Evaluation' Scores for total similar Packages ' $P_T$ ' for all Regions (i.e. ' $S_T = S_1 + S_2 + S_3 + S_4 + S_5 + \dots + S_N$ ')
- d) **Overall Performance Rating ' $R_{BHEL}$ ' for the Similar Package/Packages** (under execution/ executed during the 'Period of Assessment') in all the Power Sector Regions of BHEL

$$\frac{\text{Aggregate of Performance scores for all similar packages in all the Regions}}{\text{Aggregate of months for each of the similar packages for which performance should have been evaluated in all the Regions}} = \frac{S_T}{T_T}$$

- e) **Bidders to note that the risk of non-evaluation or non-availability of the 'Monthly Performance Evaluation' reports as per relevant formats is to be borne by the Bidder.**

- f) **Table showing methodology for calculating 'a', 'b' and 'c' above**

**BHEL PSWR**  
**Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 12 of 108

Sl. No.	Item Description	Details for all Regions							Total
(i)	(ii)	(iii)	(iv)	(v)	(vi)	(vii)	(viii)	(ix)	(x)
1	Similar Packages for all Regions → (under execution/ executed during period of assessment)	P <sub>1</sub>	P <sub>2</sub>	P <sub>3</sub>	P <sub>4</sub>	P <sub>5</sub>	...	P <sub>N</sub>	Total No. of similar packages for all Regions = P <sub>T</sub> i.e. Sum (Σ) of columns (iii) to (ix)
2	Number of Months for which 'Monthly Performance Evaluation' as per relevant formats should have been done in the 'period of assessment' for corresponding Similar Packages (as in row 1)	T <sub>1</sub>	T <sub>2</sub>	T <sub>3</sub>	T <sub>4</sub>	T <sub>5</sub>	...	T <sub>N</sub>	Sum (Σ) of columns (iii) to (ix)  = T <sub>T</sub>
3	Monthly performance scores for the corresponding period (as in Row 2)	S <sub>1-1</sub> S <sub>1-2</sub> S <sub>1-3</sub> S <sub>1-4</sub> ... S <sub>1-T1</sub>	S <sub>2-1</sub> S <sub>2-2</sub> S <sub>2-3</sub> S <sub>2-4</sub> ... S <sub>2-T2</sub>	S <sub>3-1</sub> S <sub>3-2</sub> S <sub>3-3</sub> S <sub>3-4</sub> ... S <sub>3-T3</sub>	S <sub>4-1</sub> S <sub>4-2</sub> S <sub>4-3</sub> S <sub>4-4</sub> ... S <sub>4-T4</sub>	S <sub>5-1</sub> S <sub>5-2</sub> S <sub>5-3</sub> S <sub>5-4</sub> ... S <sub>5-T5</sub>	= ... ...	S <sub>N-1</sub> S <sub>N-2</sub> S <sub>N-3</sub> S <sub>N-4</sub> ... S <sub>N-TN</sub>	-----
4	Sum of Monthly Performance scores of the corresponding Package for the corresponding period (as in row-3)	S <sub>1</sub>	S <sub>2</sub>	S <sub>3</sub>	S <sub>4</sub>	S <sub>5</sub>	...	S <sub>N</sub>	Sum (Σ) of columns (iii) to (ix) = S <sub>T</sub>

ii). Calculation of Overall 'Performance Rating' (R<sub>BHEL</sub>) in case at least 6 evaluation scores for 'similar Package/Packages' for the tendered scope ARE NOT AVAILABLE, during the 'Period of Assessment':

This shall be obtained by summing up the 'Monthly Performance Evaluation' scores obtained by the bidder in all Regions for ALL the packages, divided by the total number of Package months for which evaluation should have been done. 'R<sub>BHEL</sub>' shall be calculated subject to availability of 'performance scores' for at least 6 'package months' in the order of precedence below:

- a) 'Period of Assessment' i.e. 6 months preceding and including the cut-off month
- b) 12 months preceding and including the cut-off month
- c) 24 months preceding and including the cut-off month

**BHEL PSWR**  
**Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 13 of 108

In case,  $R_{BHEL}$  cannot be calculated as above, then Bidder shall be treated as 'NEW VENDOR'. Further eligibility and qualification of this bidder shall be as per definition of 'NEW VENDOR' described in 'Explanatory Notes'.

iii). Factor "L" assigned based on Overall Performance Rating ( $R_{BHEL}$ ) at Power Sector Regions:

Sl. no.	Overall Performance Rating ( $R_{BHEL}$ )	Corresponding Value of 'L'
1	$\leq 60$	NA
2	$> 60 \text{ and } \leq 65$	0.5
3	$> 65 \text{ and } \leq 70$	0.45
4	$> 70 \text{ and } \leq 75$	0.4
5	$> 75 \text{ and } \leq 80$	0.375
6	$> 80 \text{ and } < 90$	0.35
7	$\geq 90$	0.33

iv). Performance Systems: The performance rating as mentioned in II (i) and (ii) above, shall be calculated as per Online Systems i.e. Contractor Performance Evaluation System (CPES) and Safety Performance Evaluation System (HSEPES). The scores assigned in HSEPES shall be scaled down to 10 and assigned in CPES against the category "HSE" (mentioned in Form F-15).

**III. i) 'Assessment of Capacity based on 'LOAD and PERFORMANCE':**

a) 'Assessment of Capacity of Bidder' is based on the Maximum number of packages for which a vendor is eligible, considering the performance scores of similar packages, as below:

Max number of packages  $P_{Max} = (R_{BHEL} - 60)$  divided by corresponding value of 'L', i.e.  $(R_{BHEL} - 60)/L$

Note:

i). In case the value of  $P_{Max}$  results in a fraction, the value of  $P_{Max}$  is to be rounded off to next whole number

ii). For  $R_{BHEL} = 60$ ,  $P_{Max} = '1'$

The Bidder shall be considered 'Qualified' on 'Performance basis' as per 'Assessment of Capacity of Bidder' for the subject Tender if  $P \leq P_{Max}$   
(Where P is calculated as per clause 'I' above)

b) In addition to above, in case contractor fails to score 5 or more than 5 (five) marks in the scaled down scores of HSEPES for "3 or more than 3 months in a period of 6 months preceding and including the cut off month in any single package", the contractor shall be considered disqualified for ongoing tender(s) of BHEL. Qualification of bidder for further tendering process shall be subject to qualifying this condition in addition to qualifying requirements mentioned in PQR. Bidders who did not qualify this condition shall not be considered under the provisions of clause 9 IV (iv) of NIT.

**ii) Assessment of Capacity based on 'AVERAGE ANNUAL TURNOVER':**

**BHEL PSWR**  
**Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 14 of 108

If the 'value of contracts in hand' across all PS Regions by a contractor is less than the product of "annual average turnover of the Contractor and multiplying factor", then such bidder shall be considered qualified on 'Annual Average Turnover basis'. The 'value of contracts in hand' will be computed by summing up "50% of the annualized awarded value of each contract" unless performance evaluation is not closed in the online CPES.

Based on the performance rating of the Contractor, the above mentioned multiplying factor shall be as below:

Sl. no.	Overall Performance Rating ( $R_{BHEL}$ )	-(Multiplying factor to Average Annual Turnover)
1	$\geq 60$ and $\leq 70$	1
2	$> 70$ and $\leq 80$	2
3	$> 80$	3

**'Assessment of Capacity of Bidder':**

**The bidder will be considered qualified for the tender if it qualifies on 'Load and Performance basis' as well as on 'Average Annual Turnover basis'.**

**However, 'New Vendor'/'Consortium Partner' shall be considered qualified based on only 'Load and Performance' (they will be regarded pre-qualified on 'Average Annual Turnover' criteria).**

**IV. Explanatory note:**

i). Similar package means Boiler or ESP or Piping or Turbine or Civil or Structure or Electrical or C&I etc. at the individual level irrespective of rating of Plant and irrespective of whether the subject tender is a single package or as part of combined/composite packages. Normally Boiler, ESP, Piping, Turbine, Electrical, C&I, Civil, Structure etc. is considered individual level of package. For example, in case the tendered scope is a Boiler Vertical Package comprising of Boiler, ESP and Power Cycle Piping (i.e. the 'identified packages as per Table-1 below), the 'PERFORMANCE' part against sl.no. II above, needs to be evaluated considering all the identified packages (i.e. Boiler, ESP and Power Cycle Piping) and finally the Bidder's capacity to execute the tendered scope is assessed in line with III above.

ii). Identified Packages (Unit wise)

**Table 1**

Civil	Electrical and C&I	Mechanical
i). Enabling works	i). Electrical	i). Boiler & Aux (All types including CW Piping if applicable)
ii). Pile and Pile Caps	ii). C&I	ii). Power Cycle Piping/Critical Piping
iii). Civil Works including foundations	iii). Others (Elect. and C&I)	iii). ESP
iv). Structural Steel Fabrication & Erection	iv). Electrical Enabling Works	iv). LP Piping

**BHEL PSWR**  
**Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 15 of 108

v). Chimney		v). Steam Turbine Generator set & Aux
vi). Cooling Tower		vi). Gas Turbine Generator set & Aux
vii). Others (Civil)		vii). Hydro Turbine Generator set & Aux
		viii). Turbo Blower (including Steam Turbine)
		ix). Material Management
		x). FGD
		xi). ACG
		xii). Others (Mechanical)

iii). ~~Bidders who have not been evaluated for at least six package months in the last 24 months preceding and including the Cut-off month in the online BHEL system for contractor performance evaluation in BHEL PS Regions, shall be considered "NEW VENDOR".~~

~~A 'NEW VENDOR' shall be considered qualified subject to satisfying all other tender conditions.~~

~~A 'NEW VENDOR' if awarded a job (of package/packages identified under this clause) shall be tagged as "FIRST TIMER" on the date of first LOI from BHEL.~~

~~The "FIRST TIMER" tag shall remain till completion of all the contracts against which vendor has been tagged as First Timer or availability of 6 evaluation scores within last 24 months preceding and including the Cut-off month in the online BHEL system for contractor performance evaluation in BHEL PS Regions.~~

~~A Bidder shall not be eligible for the next job as long as the Bidder is tagged as "FIRST TIMER" excepting for the Tenders which have been opened on or before the date of the bidder being tagged as 'FIRST TIMER'.~~

~~After removal of 'FIRST TIMER' tag, the Bidder shall be considered 'QUALIFIED' for the future tenders subject to satisfying all other tender conditions including 'Assessment of Capacity of Bidders'.~~

iv). ~~Consequent upon applying the criteria of 'Assessment of Capacity of Bidders' detailed above on all the bidders qualified against Technical and Financial Qualification criteria, if the number of qualified bidders reduces to less than four, then for further processing of the Tender, BHEL at its discretion reserves the right to also consider the bidders who are "not qualified" as per criteria of 'Assessment of Capacity of Bidders' and for this, procedure described in following three options shall be followed:~~

**BHEL PSWR**  
**Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 16 of 108

- a) All the bidders having Overall Performance Rating ('R<sub>BHEL</sub>') ≥ 60 shall be considered qualified against criteria of 'Assessment of Capacity of Bidders'.
- b) If even after using option "a", the number of qualified bidders remains less than four, then in addition to bidders considered as per option "a", "First timer" bidders having average of available performance scores ≥ 60 upto and including the Cut Off month shall also be considered qualified against criteria of 'Assessment of Capacity of Bidders'.
- c) If even after using option "a" and "b", the number of qualified bidders remains less than four, then in addition to bidders considered as per option "a" and "b", "First timer" bidders for whom no performance score is available in the system upto and including the Cut Off month, shall also be considered qualified against criteria of 'Assessment of Capacity of Bidders'.

**Note:-** In case, the number of bidders qualified against Technical and Financial Qualification criteria itself is less than four, then all bidders (a) having Overall Performance Rating ('R<sub>BHEL</sub>') ≥ 60, (b) "First timer" bidders having average of available performance scores ≥ 60 upto and including the Cut Off month, (c) "First timer" bidders for whom no performance score is available in the system upto and including the Cut Off month, shall be considered qualified against criteria of 'Assessment of Capacity of Bidders' for further processing of tender.

v). 'Under execution' shall mean works in progress as per the following:

- a. Up to execution of 90% of anticipated Contract Value in case of Civil, MM, Structural and Turbo Blower Packages
- b. Up to Steam Blowing in case of Boiler/ESP/Piping Packages
- c. Up to Synchronization in all Balance Packages

**Note:** BHEL at its discretion can extend (or reduce in exceptional cases in line with Contract conditions) the period defined against (a), (b) and (c) above, depending upon the balance scope of work to be completed.

vi). Contractor shall provide the latest contact details i.e. mail ID and Correspondence Address to SCT Department, so that same can be entered in the Contractor Performance Evaluation System, and in case of any change/discrepancy same shall be informed immediately. Login Details for viewing scores in Contractor Performance Evaluation System shall be provided to the Contractor by SCT Department.

vii). Performance Evaluation for Activity Month shall be completed in Evaluation Month (i.e. month next to Activity Month) or in rare cases in Post Evaluation Month (i.e. month next to Evaluation Month) after approval from Competent Authority. In case scores are not acceptable, Contractor can submit Review Request to GM Site/ GM Project latest by 27<sup>th</sup> of Evaluation Month or 5 days after approval of score, whichever is later. However, acceptance/rejection of 'Review Request' solely depends on the discretion of GM Site/GM Project. After acceptance of Review Request, evaluation score shall be reviewed at site and the score after completion of review process shall be acceptable and binding on the contractor.

viii). Project on Hold due to reasons not attributable to bidder—

- a. **Short hold:** Evaluation shall not be applicable for this period, however, Loading will be considered.
- b. **Long hold:** Short hold for continuous six months and beyond or hold on account of Force Majeure shall be considered as Long Hold. Evaluation as well as Loading shall not be considered for this period.



**BHEL PSWR**  
**Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 17 of 108

~~ix). Performance evaluation as specified above in this clause is applicable to Prime bidder and Consortium partner (or Technical tie up partner) for their respective scope of work~~

- 10.0 Since the job shall be executed at site, bidders must visit site/ work area and study the job content, facilities available, availability of materials, prevailing site conditions including law & order situation, applicable wage structure, wage rules, etc. before quoting for this tender. They may also consult this office before submitting their offers, for any clarifications regarding scope of work, facilities available at sites or on terms and conditions.
- 11.0 For any clarification on the tender document, the bidder may seek the same in writing or through e-mail and/or through e-procurement portal <https://eprocurebhel.co.in>, as per specified format, within the scheduled date for seeking clarification, from the office of the undersigned. BHEL shall not be responsible for receipt of queries after due date of seeking clarification due to postal delay or any other delays. Any clarification / query received after last date for seeking clarification may not be normally entertained by BHEL and no time extension will be given.
- 12.0 BHEL may decide holding of pre-bid discussion [PBD] with all intending bidders as per date indicated in the NIT. The bidder shall ensure participation for the same at the appointed time, date and place as may be decided by BHEL. Bidders shall plan their visit accordingly. The outcome of pre-bid discussion (PBD) shall also form part of tender.
- 13.0 In the event of any conflict between requirement of any clause of this specification/ documents/drawings/data sheets etc. or requirements of different codes/standards specified, the same to be brought to the knowledge of BHEL in writing for clarification before due date of seeking clarification (whichever is applicable), otherwise, interpretation by BHEL shall prevail. Any typing error/missing pages/ other clerical errors in the tender documents, noticed must be pointed out before pre-bid meeting/submission of offer, else BHEL's interpretation shall prevail.
- 14.0 Unless specifically mentioned otherwise, bidder's quoted price shall deemed to be in compliance with tender including PBD.
- 15.0 Bidders shall submit Integrity Pact Agreement (Duly signed by authorized signatory who signs in the offer), **if applicable**, along with techno-commercial bid. This pact shall be considered as a preliminary qualification for further participation. **The names and other details of Independent External Monitor (IEM) for the subject tender is as given at point (1) above.**

**"Integrity Pact (IP)"**

- (a) IP is a tool to ensure that activities and transactions between the Company and its Bidders/ Contractors are handled in a fair, transparent and corruption free manner. Following Independent External Monitors (IEMs) on the present panel have been appointed by BHEL with the approval of CVC to oversee implementation of IP in BHEL.

Sl. No.	IEM	Email
1.	Shri Otem Dai, IAS (Retd.)	<a href="mailto:iem1@bhel.in">iem1@bhel.in</a>
2.	Shri Bishwamitra Pandey, IRAS (Retd.)	<a href="mailto:iem2@bhel.in">iem2@bhel.in</a>
3.	Shri Mukesh Mittal, IRS (Retd.)	<a href="mailto:iem3@bhel.in">iem3@bhel.in</a>

**BHEL PSWR**  
**Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 18 of 108

- (b) The IP as enclosed with the tender is to be submitted (duly signed by authorized signatory) along with techno-commercial bid (Part-I, in case of two/ three part bid). Only those bidders who have entered into such an IP with BHEL would be competent to participate in the bidding. In other words, entering into this Pact would be a preliminary qualification.
- (c) Please refer Section-8 of IP for Role and Responsibilities of IEMs. In case of any complaint arising out of the tendering process, the matter may be referred to any of the above IEM(s). All correspondence with the IEMs shall be done through email only.

**Note:**

*No routine correspondence shall be addressed to the IEM (phone/ post/ email) regarding the clarifications, time extensions or any other administrative queries, etc. on the tender issued. All such clarification/ issues shall be addressed directly to the tender issuing (procurement) department's officials whose contact details are provided below:*

**Details of contact person(s):**

Name:	P K Biswas/ GM (Purchase)	Varun Vaidya/Manager (Purchase)
Dept:	Purchase Department	
Address:	Floor No. 5 & 6, Shreemohini Complex, 345 Kingsway, Nagpur-440001	
Email:	<a href="mailto:pkbiswas@bhel.in">pkbiswas@bhel.in</a>	<a href="mailto:vvaidya@bhel.in">vvaidya@bhel.in</a>
Phone:		9792334127

- 16.0 The Bidder has to satisfy the Pre-Qualifying Requirements stipulated for this Tender in order to be qualified. The Price Bids of only those bidders will be opened who will be qualified for the subject job on the basis of satisfying the Pre-Qualification Criteria specified in this NIT as per Annexure-I (as applicable), past performance etc. and date of opening of price bids shall be intimated to only such bidders. BHEL reserves the right not to consider offers of parties under HOLD.
- 17.0 In case BHEL decides on a 'Public Opening', the date & time of opening of the sealed PRICE BID shall be intimated to the qualified bidders and in such a case, bidder may depute one authorized representative to witness the price bid opening. BHEL reserves the right to open 'in-camera' the 'PRICE BID' of any or all Unsuccessful/Disqualified bidders under intimation to the respective bidders.
- 18.0 Validity of the offer shall be for **six months** from the latest due date of offer submission (including extension, if any) unless specified otherwise.
- 19.0 **Reverse Auction:** "BHEL shall be resorting to Reverse Auction (RA) (Guidelines as available on [www.bhel.com](http://www.bhel.com)) (<https://www.bhel.com/guidelines-reverse-auction-2021>) for this tender. RA shall be conducted among the techno-commercially qualified bidders.

Price bids of all techno-commercially qualified bidders shall be opened and same shall be considered for RA. In case any bidder(s) do(es) not participate in online Reverse Auction, their sealed envelope price bid along with applicable loading, if any, shall be considered for ranking."

**Note:-**

1. No benefits to MSE bidders w.r.t Reverse Auction Guidelines as available on [www.bhel.com](http://www.bhel.com) against works contract.
2. In case of enquiry through e-procurement the sealed electronic price bid (e-bid) is to be treated as sealed envelope price bid.

**BHEL PSWR**  
**Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 19 of 108

- 20.0 On submission of offer, further consideration will be subject to compliance to tender & qualifying requirement and customer's acceptance, as applicable.
- 21.0 In case the bidder is an "Indian Agent of Foreign Principals", 'Agency agreement has to be submitted along with Bid, detailing the role of the agent along with the terms of payment for agency commission in INR, along with supporting documents.
- 22.0 The bidders shall not enter into any undisclosed M.O.U. or any understanding amongst themselves with respect to tender.
- 23.0 Consortium Bidding (or Technical Tie up) shall be allowed only if specified in Pre-Qualifying Requirement (PQR) criteria, and in such a case the following shall be complied with:
- 23.1 Prime Bidder and Consortium Partner or partners are required to enter into a consortium agreement for the said contract with a validity period of six months initially. In case bidder becomes L1, Consortium Agreement valid till contractual completion period shall be submitted to BHEL before signing the contract. Consortium Agreement shall be kept valid till scope of work awarded to consortium partner(s) as per contract is completed.
- 23.2 'Standalone' bidder cannot become a '**Prime Bidder' or a 'Consortium bidder' or 'Technical Tie up bidder' in a consortium (or Technical Tie up) bidding.** Prime bidder shall neither be a consortium partner to other prime bidder nor take any other consortium partners. However, consortium partner may enter into consortium agreement with other prime bidders. In case of non-compliance, consortium bids of such Prime bidders will be rejected.
- 23.3 Number of partners for a Consortium Bidding (or Technical Tie up) including Prime Bidder shall be NOT more than 3 (three).
- 23.4 Prime Bidder shall be as specified in the Pre-Qualification Requirement, else the bidder who has the major share of work.
- 23.5 In order to be qualified for the tender, Prime Bidder and Consortium partner or partners shall satisfy (i) the Technical 'Pre Qualifying Requirements' specified for the respective package, (ii) "Assessment of Capacity of Bidder" as specified in clause 9.0.
- 23.6 Prime Bidder shall comply with additional 'Technical' criteria of PQR as defined in 'Explanatory Notes for the PQR'.
- 23.7 Prime Bidder shall comply with all other Pre Qualifying criteria for the Tender unless otherwise specified
- 23.8 In case customer approval is required, then Prime Bidder and Consortium Partner or partners shall have to be individually approved by Customer for being considered for the tender.
- 23.9 Prime Bidder shall be responsible for the overall execution of the contract.
- 23.10 In case of award of job, Performance shall be evaluated for Prime Bidder and Consortium Partner or partners for their respective scope of work(s) as per prescribed formats.
- 23.11 In case the Consortium partner or partners back out, their SDs shall be encashed by BHEL and BHEL shall take necessary action as per extant guidelines. In such a case, other consortium partner or

**BHEL PSWR**  
**Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 20 of 108

partners meeting the PQR have to be engaged by the Prime Bidder, and if not, the respective work will be withdrawn and executed on risk and cost basis of the Prime Bidder. The new consortium partner or partners shall submit fresh SDs as applicable.

23.12 In case Prime Bidder withdraws or insolvency / liquidation / winding up proceedings have been initiated / admitted against the Prime Bidder, BHEL reserves the right to cancel, terminate or short close the contract or take any other action to safeguard BHEL's interest in the Project / Contract. This action will be without prejudice to any other action that BHEL can take under Law and the Contract to safeguard interests of BHEL.

23.13 After execution of work, the work experience shall be assigned to the Prime Bidder and the consortium partner or partners for their respective scope of work. After successful execution of one work with a consortium partner under direct order of BHEL, the Prime Bidder shall be eligible for becoming a 'standalone' bidder for works similar to that for which consortium partner was engaged, for subsequent tenders.

23.14 The consortium partner shall submit SD equivalent to 1% of the total contract value in addition to the SD to be submitted by the Prime Bidder for the total contract value. In case there are two consortium partners, then each partner shall submit SD equivalent to 0.5% of the total contract value in addition to the SD to be submitted by the Prime Bidder for the total contract value. However, Prime Bidder has also option for submission of SD on behalf of consortium partner (s).

SD submitted by Consortium Partner(s) may be released in case corresponding scope of work of the respective Consortium partner(s) has been completed upto the extent of 80% based on certification by Construction Manager and concurrence by the prime bidder.

23.15 In case of a Technical Tie up, all the clauses applicable for the Consortium partner shall be applicable for the Technical Tie up partner also..

24.0 The bidder shall submit/upload documents in support of possession of 'Qualifying Requirements' duly self-certified and stamped by the authorized signatory, indexed and properly linked in the format for PQR. In case BHEL requires any other documents/proofs, these shall be submitted immediately.

25.0 The bidder may have to produce original document for verification if so decided by BHEL.

26.0 The consultant / firm (and any of its affiliates) shall not be eligible to participate in tender(s) for the related works or services for the same project, if they were engaged for the consultancy services.

27.0 Guidelines/rules in respect of Suspension of Business dealings, Vendor evaluation format, Quality, Safety & HSE guidelines, Experience Certificate, etc. may undergo change from time to time and the latest one shall be followed. The abridged version of extant 'Guidelines for suspension of business dealings with suppliers/ contractors' is available on [www.bhel.com](http://www.bhel.com) on "supplier registration page".

28.0 The offers of the bidders who are on the banned/ hold list and also the offer of the bidders, who engage the services of the banned/ hold firms, shall be rejected. The list of **banned/ hold firms** is available on BHEL web site [www.bhel.com](http://www.bhel.com).

28.1 Integrity commitment, performance of the contract and punitive action thereof:

28.1.1 **Commitment by BHEL:**

**BHEL PSWR**  
**Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 21 of 108

BHEL commits to take all measures necessary to prevent corruption in connection with the tender Process and execution of the contract. BHEL will during the tender process treat all Bidder(s) in a transparent and fair manner, and with equity.

**28.1.2 Commitment by Bidder/ Supplier/ Contractor:**

- (i) The bidder/ supplier/ contractor commit to take all measures to prevent corruption and will not directly or indirectly influence any decision or benefit which he is not legally entitled to nor will act or omit in any manner which tantamount to an offence punishable under any provision of the Indian Penal Code, 1860 or any other law in force in India.
- (ii) The bidder/ supplier/ contractor will, when presenting his bid, disclose any and all payments he has made, and is committed to or intends to make to agents, brokers or any other intermediaries in connection with the award of the contract and shall adhere to relevant guidelines issued from time to time by Govt. of India/ BHEL.
- (iii) The bidder/ supplier/ contractor will perform/ execute the contract as per the contract terms & conditions and will not default without any reasonable cause, which causes loss of business/ money/ reputation, to BHEL.

If any bidder/ supplier/ contractor during pre-tendering/ tendering/ post tendering/ award/ execution/ post-execution stage indulges in mal-practices, cheating, bribery, fraud or and other misconduct or formation of cartel so as to influence the bidding process or influence the prices or acts or omits in any manner which tantamount to an offence punishable under any provision of the Indian Penal Code, 1860 or any other law in force in India, then, action may be taken against such bidder/ supplier/ contractor as per extent guidelines of the company available on [www.bhel.com](http://www.bhel.com) and / or under applicable legal provisions.

**29.0 Micro and Small Enterprises (MSE)**

Any Bidder falling under MSE category, shall furnish the following details & submit documentary evidence/ Govt. Certificate etc. in support of the same along with their techno-commercial offer.

Type under MSE	SC/ST owned	Women owned	Others (excluding SC/ ST & Women Owned)
— Micro			
— Small			

**Note:** – If the bidder does not furnish the above, offer shall be processed construing that the bidder is not falling under MSE category.

- a) MSE suppliers can avail the intended benefits in respect of the procurements related to the Goods and Services only (Definition of Goods and Services as enumerated by Govt. of India vide Office Memorandum F. No. 21(8)/2011 MA dtd. 09/11/2016 office of AS & DC, MSME) only if they submit along with the offer, attested copies of either Udyam Registration Certificate or EM-II certificate having deemed validity (five years from the date of issue of acknowledgement in EM-II) or valid NSIC certificate or Udyog Aadhar Memorandum (UAM) & Acknowledgement or EM-II Certificate along with attested copy of a CA certificate (format enclosed as Annexure – 3) where deemed validity of EM-II certificate of five years has expired applicable for the relevant financial year (latest audited). Date to be reckoned for determining the deemed validity will be the last date of Technical Bid submission. Non submission of such documents will lead to consideration of their bids at par with other bidders. No benefits shall be applicable for this enquiry if the above required documents are not submitted before price bid opening. If the tender is to be submitted through e-procurement portal, then the above required documents are

**BHEL PSWR**  
**Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 22 of 108

~~to be uploaded on the portal. Documents should be notarized or attested by a Gazetted officer. Documents submitted by the bidder may be verified by BHEL for rendering the applicable benefits.~~

30.0 The Bidder along with its associate/ collaborators/ sub-contractors/ sub-vendors/ consultants/ service providers shall strictly adhere to BHEL Fraud Prevention Policy displayed on BHEL website <http://www.bhel.com> and shall immediately bring to the notice of BHEL Management about any fraud or suspected fraud as soon as it comes to their notice.

**31.0 PREFERENCE TO MAKE IN INDIA:**

For this procurement, the local content to categorize a supplier as a Class I local supplier/ Class II local Supplier/Non-Local Supplier and purchase preferences to Class I local supplier, is as defined I Public Procurement (Preference to Make in India), Order 2017 dated 04.06.2020 issued by DPIIT. In case of subsequent orders issued by the nodal ministry, changing the definition of local content for the items of the NIT, the same shall be applicable even if issued after issue of this NIT, but before opening of Part-II bids against this NIT.

**31.1 Compliance to Restrictions under Rule 144 (xi) of GFR 2017**

- I. Any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. The Competent Authority for the purpose of this Clause shall be the Registration Committee constituted by the Department for Promotion of Industry and Internal Trade (DPIIT).
- II. "Bidder" (including the term 'tenderer', 'consultant' or 'service provider' in certain contexts) means any person or firm or company, including any member of a consortium or joint venture (that is an association of several persons, or firms or companies), every artificial juridical person not falling in any of the descriptions of bidders stated hereinbefore, including any agency branch or office controlled by such person, participating in a procurement process.
- III. "Bidder from a country which shares a land border with India" for the purpose of this Clause means:
  - a. An entity incorporated established or registered in such a country; or
  - b. A subsidiary of an entity incorporated established or registered in such a country; or
  - c. An entity substantially controlled through entities incorporated, established or registered in such a country; or
  - d. An entity whose beneficial owner is situated in such a country; or
  - e. An Indian (or other) agent of such an entity; or
  - f. A natural person who is a citizen of such a country; or
  - g. A consortium or joint venture where any member of the consortium or joint venture falls under any of the above.
- IV. The beneficial owner for the purpose of (III) above will be as under:
  1. In case of a company or Limited Liability Partnership, the beneficial owner is the natural person(s), who, whether acting alone or together or through one or more juridical person, has a controlling ownership interest or who exercises control through other means.

Explanation

    - a. "Controlling ownership interest" means ownership of or entitlement to more than twenty-five per cent of shares or capital or profits of the company.
    - b. "Control" shall include the right to appoint majority of the directors or to control the management or policy decisions including by virtue of their shareholding or management rights or shareholders agreements or voting agreements.

**BHEL PSWR**  
**Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 23 of 108

2. In case of a partnership firm, the beneficial owner is the natural person(s) who, whether acting alone or together, or through one or more juridical person, has ownership of entitlement to more than fifteen percent of capital or profits of the partnership.
3. In case of an unincorporated association or body of individuals, the beneficial owner is the natural person(s), who, whether acting alone or together, or through one or more juridical person has ownership of or entitlement to more than fifteen percent of the property or capital or profits of the such association or body of individuals.
4. Where no natural person is identified under (1) or (2) or (3) above, the beneficial owner is the relevant natural person who holds the position of senior managing official;
5. In case of a trust, the identification of beneficial owner(s) shall include identification of the author of the trust, the trustee, the beneficiaries with fifteen percent or more interest in the trust and any other natural person exercising ultimate effective control over the trust through a chain of control or ownership.

V. An Agent is a person employed to do any act for another, or to represent another in dealings with third person.

VI. The successful bidder shall not be allowed to sub-contract works to any contractor from a country which shares a land border with India unless such contractor is registered with the Competent Authority.

**Note:**

- (i) The bidder shall provide undertaking for their compliance to this Clause, in the Format provided in **Annexure-11**.
- (ii) Registration of the bidder with Competent Authority should be valid at the time of submission as well as acceptance of the bids.

32.0 Bid should be free from correction, overwriting, using corrective fluid, etc. Any interlineation, cutting, erasure or overwriting shall be valid only if they are attested under full signature(s) of person(s) signing the bid else bid shall be liable for rejection.

All overwriting/cutting, etc., will be numbered by bid opening officials and announced during bid opening.

33.0 In the course of evaluation, if more than one bidder happens to occupy L-1 status, effective L-1 will be decided by soliciting discounts from the respective L-1 bidders.

In case more than one bidder happens to occupy the L-1 status even after soliciting discounts, the L-1 bidder shall be decided by a toss/ draw of lots, in the presence of the respective L-1 bidder(s) or their representative(s).

Ranking will be done accordingly. BHEL's decision in such situations shall be final and binding.

34.0 The Bidder declares that they will not enter into any illegal or undisclosed agreement or understanding, whether formal or informal with other Bidder(s). This applies in particular to prices, specifications, certifications, subsidiary contracts, submission or non-submission of bids or any other actions to restrict competitiveness or to introduce cartelization in the bidding process.

In case, the Bidder is found having indulged in above activities, suitable action shall be taken by BHEL as per extant policies/ guidelines.

35.0 Order of Precedence:

In the event of any ambiguity or conflict between the Tender Documents, the order of precedence shall be in the order below:

**BHEL PSWR**  
**Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 24 of 108

- a. Amendments/Clarifications/Corrigenda/Errata etc. issued in respect of the tender documents by BHEL
- b. Notice Inviting Tender (NIT)
- c. Price Bid
- d. Technical Conditions of Contract (TCC)—Volume-1A
- e. Special Conditions of Contract (SCC) —Volume-1B
- f. General Conditions of Contract (GCC) —Volume-1C
- g. Forms and Procedures —Volume-1D

It may please be noted that guidelines/ circulars/ amendments/ govt. directives issued from time to time shall also be applicable.

For BHARAT HEAVY ELECTRICALS LTD

(General Manager - Purchase)

**Enclosure:**

- 1.0 Annexure-1: Pre Qualifying Requirements.
- 2.0 Annexure-2: Check List.
- ~~3.0 Annexure-3: Certificate by Chartered Accountant~~
- 4.0 Annexure-4: Reverse Auction Process Compliance Form
- 5.0 Annexure-5: Authorization of representative who will participate in the online Reverse Auction Process
- 6.0 Annexure-6: RA Price Confirmation and Breakup
- 7.0 Annexure-7: Integrity Pact
- 8.0 Annexure-8: Undertaking as per PQR C4 of Annexure-1 i.e. PQR
- 9.0 Annexure-9: Declaration reg. Related Firms & their areas of Activities
- 10.0 Annexure-10: Declaration regarding minimum local content
- 11.0 Annexure-11: Declaration regarding compliance to restrictions under rule 144 (xi) of GFR 2017
- 12.0 Annexure-12: Important information.
- 13.0 Annexure-13: Bid Security Declaration



**BHEL PSWR**  
**Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 25 of 108

**ANNEXURE - 1**

**PRE QUALIFYING CRITERIA**

<b>E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990</b>			
<b>JOB</b>	<b>HANDLING AT SITE STORES/STORAGE YARD, TRANSPORTATION TO SITE OF WORK, COMPLETE ERECTION, TESTING, COMMISSIONING AND HANDING OVER OF ELECTRICAL WORKS OF ESP R&amp;M SYSTEM AND ITS AUXILIARIES /ASSOCIATED EQUIPMENT FOR ESP R&amp;M WANAKBORI U# 5 PROJECT</b>		
<b>S No</b>	<b>PRE QUALIFICATION CRITERIA</b>	<b>Bidders claim in respect of fulfilling the PQR Criteria</b>	
		<b>Applicability</b>	
<b>A</b>	<b>Submission of Integrity Pact duly signed (if applicable)</b>  (Note: To be submitted by Prime Bidder & Consortium /Technical Tie up partner jointly in case Consortium bidding is permitted, otherwise by the sole bidder)	<b>NOT APPLICABLE</b>	
<b>B</b>	<b><u>B) Technical PQR</u></b> Bidder shall essentially meet all the Qualifying Requirements (i.e. <b>B.1 &amp; B.2</b> ) as under: <b>B.1:</b> Bidder should have Executed “ <b>Electrical or Electrical and C&amp;I works</b> ” for any one of the following in the last seven years from latest date of bid submission: <b>B.1.1)</b> Executed One work of value not less than <b>Rs 48.00 Lakhs</b> against single work order.  <b>OR</b> <b>B.1.2)</b> Executed Two works each of value not less than <b>Rs 30 Lakhs</b> against maximum two work orders.  <b>OR</b> <b>B.1.3)</b> Executed Three works each of value not less than <b>Rs 24 Lakhs</b> against maximum three work orders.  <b>AND</b> <b>B.2:</b> Bidder should have Executed Electrical Works consisting of following: <b>B.2.1)</b> LT Switchgears	<b>APPLICABLE</b>	
<b>C-1</b>	<b><u>Financial TURNOVER</u></b> Bidders must have achieved an average annual financial turnover (audited) of <b>Rs. 18.00 Lakhs</b> or more over last three Financial Years (FY) i.e. <b>2020-21, 2021-22 &amp; 2022-23.</b>	<b>APPLICABLE</b>	
<b>C-2</b>	<b><u>NETWORTH</u></b> (only in case of Companies) Net worth of the Bidder based on the latest Audited Accounts as furnished for ‘C-1’ above should be positive.	<b>APPLICABLE</b>	

**BHEL PSWR**  
**Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 26 of 108

<b>C-3</b>	<b><u>PROFIT</u></b> Bidder must have earned profit in any one of the five Financial Years as applicable in the last five Financial Years ( <b>i.e. 2018-2019, 2019-2020, 2020-2021, 2021-2022 &amp; 2022-2023</b> ) Bidders to submit audited balance sheets and profit & loss statements for the years as supporting documents.	<b>APPLICABLE</b>	
<b>C-4</b>	Bidder must not be under Bankruptcy Code Proceedings (IBC) by NCLT or under Liquidation / BIFR, which will render him ineligible for participation in this tender, and shall submit undertaking to this effect.	<b>APPLICABLE</b>	
<b>D</b>	<b>Assessment of Capacity of Bidder to execute the work as per sl no 9 of NIT (if applicable)</b>  Applicable, The "Assessment of Capacity of Bidders" for this Tender shall be carried out by considering the identified packages i.e. <b>"ELECTRICALS"</b> .	<b>NOT APPLICABLE</b>	<b>BY BHEL</b>
<b>E</b>	<b>Approval of Customer (if applicable)</b>  <b>Note:</b> Names of bidders (including consortium/Technical Tie up partners in case consortium bidding is permitted) who stand qualified after compliance of criteria A to D shall be forwarded to customer for their approval	<b>APPLICABLE</b>	<b>BY BHEL</b>
<b>F</b>	Price Bid Opening <b>Note:</b> Price Bids of only those bidders shall be opened who stand qualified after compliance of criteria A to E		<b>BY BHEL</b>
<b>G</b>	Consortium tie-ups	<b>APPLICABLE</b>	

**Explanatory Notes for the PQR (unless otherwise specified in the PQR):**

**Explanatory Notes for PQR B.1 (Technical)**

- For the criteria (B.1), actual executed value shall be considered.
- Value of work is to be updated with indices for "All India Avg. Consumer Price index for industrial workers" and "Monthly Whole Sale Price Index for All Commodities" with base month as per last month of work execution and indexed up to three (3) months prior to the month of latest due date of bid submission as per following formula-

$$P = R + 0.425 \times R \times \frac{(X_N - X_0)}{X_0} + 0.425 \times R \times \frac{(Y_N - Y_0)}{Y_0}$$

Where

P = Updated value of work

R = Value of executed work

X<sub>N</sub> = All India Avg. Consumer Price index for industrial workers for three months prior to the month of latest due date of bid submission (e.g. If latest bid submission date is 02-Mar-17, then bid submission month shall be reckoned as March'17 and index for Dec'2016 shall be considered).

X<sub>0</sub> = All India Avg. Consumer Price index for industrial workers for last month of work execution

Y<sub>N</sub> = Monthly Whole Sale Price Index for All Commodities for three months prior to the month of latest due date of bid submission (e.g. If latest bid submission date is 02-Mar-17, then bid submission month shall be reckoned as March'17 and index for Dec'2016 shall be considered).

Y<sub>0</sub> = Monthly Whole Sale Price Index for All Commodities for last month of work execution

- The evaluation currency for this tender shall be INR.

**Explanatory Notes for Technical Criteria (B2):**

1. VOID
2. Unless otherwise specified, for the purpose of "B2 Technical Criteria", the word 'EXECUTED' means achievement of milestones as defined below -
  - a. "ACHIEVEMENT OF PHYSICAL QUANTITIES" as per PQRs.
  - b. "READINESS FOR COAL FILLING" of at least one Bunker, in respect of Mill Bunker Structure.
  - c. "CHARGING" in respect of Power Transformers/ Bus Ducts/ "HT/LT Switchgears" / "HT/LT Cabling".
  - d. For C&I works: "SYNCHRONISATION" in case of power project / "WORK EXECUTION of the value as defined in PQR" in case of industry.
  - e. "BOILER LIGHT UP" in respect of Boiler / CFBC / ESP.
  - f. "CHARGING OF ATLEAST ONE PASS" in respect of ESP(R&M)
  - g. "GAS IN" in respect of HRSG.
  - h. "STEAM BLOWING" in respect of Power Cycle Piping.
  - i. "HYDRAULIC TEST"/ ANY OTHER EQUIVALENT TEST LIKE "100% RT/UT OF WELDED JOINTS" of the system in respect of Pressure parts/ LP Piping/CW Piping.
  - j. "FULL LOAD OPERATION OF THE UNIT" in respect of Insulation work.
  - k. "SYNCHRONISATION" in respect of STG / GTG.
  - l. "SPINNING" in respect of HTG.
  - m. "GAS IN" in respect of FGD
3. Boiler means HRSG or WHRB or any other types of Steam Generator.
4. Power Cycle piping means Main Steam, Hot Reheat, Cold Reheat, HP Bypass.
5. For the purpose of evaluation of the PQR, one MW shall be considered equivalent to 3.5 TPH where ever rating of HRSG/BOILER is mentioned in MW. Similarly, where ever rating of Gas Turbine is mentioned in terms of Frame size, ISO rating of the same in terms of MW shall be considered for evaluation.

**Explanatory Notes for PQR -C (Financial):**

**C-1:**

- i. Bidder to submit Audited Balance Sheet and Profit and Loss Account for the respective years as indicated against C-1 above.
- ii. Evaluation of Turnover criteria shall be calculated from the Audited Balance Sheet and Profit & Loss Account for the three Financial Years (FY).
- iii. In case audited Financial statements have not been submitted for all the three years as indicated against C-1 above, then the applicable audited statements submitted by the bidders against the requisite three years, will be averaged for three years.
- iv. If financial statements are not required to be audited statutorily, then instead of audited financial statements, financial statements are required to be certified by Chartered Accountant.

**C-2:** Net Worth (Only in case of companies) of the bidder should be positive.

**Note:** Net worth shall be calculated based on the latest Audited Accounts as furnished for 'C-1' above.

Net worth = Paid up share capital + Reserves

**C-3:** Bidder must have earned profit in any one of the three financial years as applicable in the last three financial years as furnished for 'C-1' above.

**Note:** PROFIT shall be PBT earned during any one year of last three financial years as in 'C-1' above.

**C-4:** Bidder must not be under Bankruptcy Code Proceedings (IBC) by NCLT or under Liquidation / BIFR, which will render him ineligible for participation in this tender, and shall submit undertaking to this effect.

**Common Explanatory Notes:**

1. For evaluation of PQR, in case Bidder alone does not meet the pre-qualifying technical criteria B1 above, bidder may utilize the experience of its Parent/ Subsidiary Company along with its own experience, subject to following:
  - a. The parent company shall have a controlling stake of  $\geq 50\%$  in the subsidiary company (as per Format-1).
  - b. The Parent Company/ Subsidiary Company of which experience is being utilized for bidding shall submit Security Deposit(SD) equivalent to 1% of the total contract value
  - c. The parent/ subsidiary company and bidder shall provide an undertaking that they are jointly or severally responsible for successful performance of the contract (as per Format-2).
  - d. In case Bidder is submitting bid as a Consortium Partner, option of utilizing experience of parent/subsidiary Company can be availed by Prime Bidder only.
  - e. Parent Company/ Subsidiary Company of which experience is being used for bidding, cannot participate as a 'Standalone Bidder' or as a 'Consortium bidder'.
2. Completion date for achievement of the technical criteria specified in the 'B' above should be in the last 7 years ending on the 'latest date of Bid Submission' of Tender irrespective of date of the start of work. Completion date shall be reckoned from the " Financial Year quarter of bid submission". (for e.g. -Work completed on 01.01.2014 shall be considered even if latest date of bid submission is 20.03.2021).
3. "Executed" means the bidder should have achieved the technical criteria specified in the Common QR even if the Contract has not been completed or closed.
4. In case the Experience/PO/WO certificate enclosed by bidders do not have separate break up of prices for the E&C portion for Electrical and C&I works (i.e. the certificates enclosed are for composite order for supply and erection of Electrical and C&I and other works if any), then value of Erection & Commissioning for the Electrical and C&I portion shall be considered as 15% of the price for supply & erection of Electrical and C&I.
5. Following shall be complied with in case of consortium:
  - a. The Prime Bidder and Consortium Partner(s) are required to enter in to a consortium agreement and certify to BHEL regarding existence and validity of their consortium agreement in line with validity period mentioned in NIT.
  - b. Prime Bidder and Consortium partners shall be approved by Customer for being considered for the tender (applicable if customer approval is required).
  - c. Number of partners including prime Bidder shall be NOT more than 3 (three).
  - d. Prime Bidder alone shall necessarily comply with "B1 Technical Criteria" except for mechanical package where B1 criteria is not applicable.

**BHEL PSWR**  
**Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 29 of 108

- e. Prime Bidder and Consortium Partner shall together comply with the 'Pre-Qualification Requirements' specified for the respective category of technical requirement as per "B2 technical criteria".
- f. Prime Bidder shall comply with all other Pre Qualifying criteria for the Tender unless otherwise specified.
- g. All other conditions shall be read in conjunction with clause no 23.0 of NIT.
- h. Prime Bidder shall be the Bidder who has a major share of work.
- i. Prime Bidder shall be responsible for the overall execution of the Contract.
- j. Performance shall be evaluated for Prime Bidder and the Consortium partner for their respective scope of work.
- k. In case the Consortium partner backs out, another consortium partner meeting the QRs, has to be engaged by Prime Bidder and if not, the respective work will be withdrawn and executed on risk and cost basis of the prime bidder.
- l. In case Prime Bidder withdraws or insolvency / liquidation / winding up proceedings have been initiated / admitted against the Prime Bidder, BHEL reserves the right to cancel, terminate or short close the contract or take any other action to safeguard BHEL's interest in the Project / Contract. This action will be without prejudice to any other action that BHEL can take under Law and the Contract to safeguard interests of BHEL
- m. After successful execution of one work with a consortium partner under direct orders of BHEL, the Prime Bidder shall be eligible for becoming a 'standalone' bidder for works similar to that for which consortium partner was engaged, for subsequent tenders.
- n. The Consortium partner shall submit SD equivalent to 1% of the total contract value in addition to the SD to be submitted by the Prime Bidder for the total contract value.

BIDDER SHALL SUBMIT ABOVE PRE-QUALIFICATION CRITERIA FORMAT, DULY FILLED-IN, SPECIFYING RESPECTIVE ANNEXURE NUMBER AGAINST EACH CRITERIA AND FURNISH RELEVANT DOCUMENT INCLUSIVE OF WORK ORDER AND WORK COMPLETION CERTIFICATE ETC IN THE RESPECTIVE ANNEXURES IN THEIR OFFER.

Credentials submitted by the bidder against "PRE QUALIFYING CRITERIAS" shall be verified for its authenticity. In case, any credential (s) is/are found unauthentic, offer of the bidder is liable to the rejection. BHEL reserves the right to initiate any further action as per extant guidelines for Suspension of Business Dealings.

**BHEL PSWR  
Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 30 of 108

Format-1

**Certificate for relationship between Parent Company / Subsidiary Company and the bidder**

To,

.....

.....

Dear Sir,

**Sub:** Bid for NIT No .....dated..... for “.....” (name of the tender).

We hereby certify that M/s..... is Parent Company/ Subsidiary Company of M/s.....(the bidder) and details of equity holding of the Parent Company in Subsidiary Company as on .....(not earlier than seven days prior to the Bid Submission Date) are given as below:

Name of Parent Company	Name of Subsidiary Company	Percentage of Equity Holding of Parent Company in Subsidiary Company

**(Insert Name and Signature of Statutory Auditor or practicing Company Secretary of the Bidder)**

**BHEL PSWR  
Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 31 of 108

Format-2

**Undertaking from the Parent Company/ Subsidiary Company of the bidder**

*(On the Letter Head of Parent Company/ Subsidiary Company, as applicable)*

From,  
Name:  
Full Address:

Telephone No.:  
E-mail address:  
Fax/No.:

To,

Dear Sir,

We refer to the NIT No ..... dated..... for "....." (name of the Tender).

"We have carefully read and examined in detail the NIT/Tender Terms and Conditions, including in particular, Clause .... of the NIT/Tender, regarding submission of an Undertaking, as per the prescribed Format 1 of the NIT/ Tender.

We confirm that M/s.....(the Bidder) has been authorized by us to use our Technical capability for meeting the Technical Criteria as specified in Clause.....of the PQR of the NIT/Tender referred above.

We agree to submit the Security Deposit equivalent to 1% of the total contract value in addition to Security Deposit to be submitted by Bidder as per Clause.....of the NIT/Tender for fulfillment of all obligations in terms of provisions of the contract, in the event of .....(the Bidder) being selected as the Successful Bidder.

We confirm that we along with M/s.....(the bidder), are jointly or severally responsible for successful performance of the contract.

We confirm that our company shall not participate in the above tender as a 'Standalone Bidder' or as a 'Consortium bidder' and also shall not authorize any other bidder to use our Technical capability for the above tender.

All the terms used herein but not defined, shall have the meaning as ascribed to the said terms under the referred NIT/Tender.

**Signature of Managing Director/Authorized signatory of Parent/ Subsidiary Company**

**ANNEXURE - 2**

**CHECK LIST**

**NOTE: - Tenderers are required to fill in the following details and no column should be left blank**

1	Name and Address of the Tenderer		
2	Details about type of the Firm/Company		
3.a	Details of Contact person for this Tender	Name : Mr/Ms Designation: Telephone No: Mobile No: Email ID: Fax No:	
3.b	Details of alternate Contact person for this Tender	Name : Mr/Ms Designation: Telephone No: Mobile No: Email ID: Fax No:	
4	EMD DETAILS	DD No:                      Date : Bank :                      Amount: <u>Please tick ( √ ) whichever applicable:-</u> <b>ONE TIME EMD / ONLY FOR THIS TENDER</b>	
5	Validity of Offer	TO BE VALID FOR SIX MONTHS FROM DUE DATE	
		APPLICABILITY (BY BHEL)	ENCLOSED BY BIDDER
6	Whether the format for compliance with <b>PRE QUALIFICATION CRITERIA</b> (ANNEXURE-I) is understood and filled with proper supporting documents referenced in the specified format	<b>Applicable</b>	YES / NO
7	Audited profit and Loss Account for the last three years	<b>Applicable/Not Applicable</b>	YES/NO
8	Copy of GST & PAN Card	<b>Applicable/Not Applicable</b>	YES/NO
9	Whether all pages of the Tender documents including annexures, appendices etc. are read understood and signed	<b>Applicable/Not Applicable</b>	YES/NO
10	Integrity Pact	<b>Applicable/Not Applicable</b>	YES/NO
11	OFFER FORWARDING LETTER / TENDER SUBMISSION LETTER	<b>Applicable/Not Applicable</b>	YES/NO
12	Declaration by Authorized Signatory	<b>Applicable/Not Applicable</b>	YES/NO
13	No Deviation Certificate	<b>Applicable/Not Applicable</b>	YES/NO
14	Declaration confirming knowledge about Site Conditions	<b>Applicable/Not Applicable</b>	YES/NO



**BHEL PSWR  
Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 33 of 108

15	Declaration for relation in BHEL	<del>Applicable/Not Applicable</del>	YES/NO
16	Non-Disclosure Certificate	<del>Applicable/Not Applicable</del>	YES/NO
17	Bank Account Details for E-Payment	<del>Applicable/Not Applicable</del>	YES/NO
18	Capacity Evaluation of Bidder for current Tender	<del>Applicable/Not Applicable</del>	YES/NO
19	Tie Ups/Consortium Agreement are submitted as per format	<del>Applicable/Not Applicable</del>	YES/ NO
20	Power of Attorney for Submission of Tender/Signing Contract Agreement Power of Attorney of Consortium Partner.	<del>Applicable/Not Applicable</del>	YES/NO
21	Analysis of Unit rates	<del>Applicable/Not Applicable</del>	YES/NO
22	Annexure-5: Authorization of representative who will participate in the online Reverse Auction Process	<del>Applicable/Not Applicable</del>	YES/NO
23	Annexure-6: RA Price Confirmation and Breakup	<del>Applicable/Not Applicable</del>	YES/NO
24	Annexure-8: Undertaking as per PQR C4 of Annexure-1 i.e. PQR	<del>Applicable/Not Applicable</del>	YES/NO
25	Annexure-9: Declaration reg. Related Firms & their areas of Activities (x) Other Tender documents as per this NIT.	<del>Applicable/Not Applicable</del>	YES/NO
26	Annexure-10 Declaration regarding minimum local content	<del>Applicable/Not Applicable</del>	YES/NO
27	Annexure-11: Declaration regarding compliance to restrictions under rule 144 (xi) of GFR 2017	<del>Applicable/Not Applicable</del>	YES/NO

NOTE: STRIKE OFF 'YES' OR 'NO', AS APPLICABLE. TENDER NOT ACCOMPANIED BY THE PRESCRIBED  
**ABOVE APPLICABLE DOCUMENTS** ARE LIABLE TO BE SUMMARILY REJECTED.

**DATE :**

**AUTHORISED SIGNATORY  
(With Name, Designation and Company seal)**

**BHEL PSWR  
Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 34 of 108

**ANNEXURE-3**

**Certificate by Chartered Accountant on letter head**

(applicable upto 31<sup>st</sup> March'2021 in line with MSME notification no. S.O. 2119 (E), dated 26<sup>th</sup> June'2020)

This is to Certify that M/S .....  
(hereinafter referred to as 'company') having its registered office at .....  
..... is registered under MSMED Act 2006, (Entrepreneur  
Memorandum No. (Part II)/ Udyam Registration Certificate No. ....  
..... dtd: ....., Category:  
..... (Micro/Small/Medium)). (Copy enclosed).

Further verified from the Books of Accounts that the investment of the company as  
per the latest audited financial year ..... as per MSMED Act 2006 is as follows:

1. ~~For Manufacturing Enterprises:~~ Investment in plant and machinery (i.e. original cost  
excluding land and building and the items specified by the Ministry of Small Scale Industries vide  
its notification No. S.O.1722(E) dated October 5, 2006:  
Rs. .... Lac
2. ~~For Service Enterprises:~~ Investment in equipment (original cost excluding land and building  
and furniture, fittings and other items not directly related to the service rendered or as may be notified  
under the **MSMED** Act, 2006:  
Rs. .... Lac
3. ~~For Enterprises (having EM-II Certificate/ valid NSIC Certificate or Udyog Aadhar Memorandum):~~ In-  
vestment in plant and machinery or equipment is Rs. .... Lac and turnover is Rs.  
..... Lac (as notified in MSME notification no. S.O. 2119 (E) dated 26.06.2020)
4. ~~For Enterprises (having EM-II Certificate/ valid NSIC Certificate or Udyog Aadhar Memorandum):~~ In-  
vestment in plant and machinery or equipment is Rs. .... Lac and turnover is Rs.  
..... Lac (as notified in MSME notification no. S.O. 2119 (E) dated 26.06.2020)

**~~(Strike off whichever is not applicable)~~**

~~The above investment of Rs. .... Lac is within permissible limit of  
Rs. .... Lac for ..... Micro / Small/ Medium (Strike off which is not applicable)  
Category under MSMED Act 2006.~~

~~Or~~

~~The enterprise has been graduated upward from its original category (micro/small/medium) (strike  
off which is not applicable), the enterprise shall maintain its prevailing status till expiry of one year  
from the close of year of registration, as notified vide S.O. No. 2119 (E) dated 26.06.2020 published  
in the gazette notification dated 26.06.2020 by Ministry of MSME.~~

~~Or~~

~~The enterprise has been reverse graduated from its original category (micro/small/medium) (strike  
off which is not applicable), the enterprise will continue in its present category till the closure of the  
financial year and it will be given the benefit of the changed status only with effect from 1<sup>st</sup> April of  
the financial year following the year in which such change took place, as notified vide S.O. No. 2119  
(E) dated 26.06.2020 published in the gazette notification dated 26.06.2020 by Ministry of MSME.~~

~~Date:~~

~~(Signature)~~

~~Name:~~

~~Membership Number:~~

Seal of the Chartered Accountant

[ANNEXURE-4](#)

**Reverse Auction Process Compliance Form**

**(The bidders are required to print this on their company's letterhead and sign, stamp before RA)**

To

- M/s. {Service provider}
- Postal address}

**Sub: Agreement to the Process related Terms and Conditions**

Dear Sir,

This has reference to the Terms & Conditions for the Reverse Auction mentioned in the RFQ document for {Items} against BHEL enquiry/ RFQ no. { BHE/PW/PUR/WNS-U5/2990 } dt. {.....}

This letter is to confirm that:

- 1) The undersigned is authorized official/ representative of the company to participate in RA and to sign the related documents.
- 2) We have studied the Reverse Auction guidelines (as available on [www.bhel.com](http://www.bhel.com)), and the Business rules governing the Reverse Auction as mentioned in your letter and confirm our agreement to them.
- 3) We also confirm that we have taken the training on the auction tool and have understood the functionality of the same thoroughly.
- 4) We also confirm that, in case we become L1 bidder, we will FAX/ email the price confirmation & break up of our quoted price as per Annexure - 6 within **two** working days (of BHEL) after completion of RA event, besides sending the same by registered post/ courier both to M/s. BHEL and M/s. {Service provider.}

We, hereby confirm that we will honor the Bids placed by us during the auction process.

With regards

Signature with company seal

Name:

Company / Organization:

Designation within Company / Organization:

Address of Company / Organization:

Sign this document and FAX/ email it to M/s {Service provider} at {.....} prior to start of the Event

**BHEL PSWR  
Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 36 of 108

**ANNEXURE-5**

**Authorization of representative who will participate in the on line Reverse Auction Process:**

1	NAME OF THE BIDDER	
2	NAME & DESIGNATION OF OFFICIAL	
3	POSTAL ADDRESS (COMPLETE)	
4	TELEPHONE NOS. (LAND LINE & MOBILE BOTH)	
5	E-MAIL ADDRESS	
6	NAME OF PLACE/ STATE/ COUNTRY, WHEREFROM S/HE WILL PARTICIPATE IN THE REVERSE AUCTION	

**BHEL PSWR  
Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 37 of 108

**ANNEXURE-6**

Reverse Auction price confirmation and breakup

*(To be submitted by L1 bidder after completion of Reverse Auction)*

To

- M/s. Service provider
- Postal address

CC: M/s BHEL  
BHEL-PSWR, 345, KINGSWAY, NAGPUR-440001

**Sub: Final price quoted during Reverse Auction and price breakup**

Dear Sir,

We confirm that we have quoted.

**Rs.{\_\_in value & in words\_\_} for item(s) covered under tender enquiry No. {**  
**BHE/PW/PUR/WNS-U5/2990} dt.{...}**

Total price of the items covered under above cited enquiries is inclusive of {Packing & forwarding, GST, E.D., C.S.T., freight and insurance charges up to {.....} District,{.....} State and Type Test Charges etc., (exclusive of service tax), other as per NIT}

as our final landed prices as quoted during the Reverse Auction conducted today {date} which will be valid for a period of {\_\_ in nos. & in words \_\_} days.

The price break-up is as given below.

Total

=====

- Rs. in value & in words

=====

Yours sincerely,

For \_\_\_\_\_

**Name:**

**Company:**

**Date:**

**Seal:**

**ANNEXURE-7**

**INTEGRITY PACT**

**Between**

Bharat Heavy Electricals Ltd. (BHEL), a company registered under the Companies Act 1956 and having its registered office at "BHEL House", Siri Fort, New Delhi - 110049 (India) hereinafter referred to as "The Principal", which expression unless repugnant to the context or meaning hereof shall include its successors or assigns of the ONE PART

**and**

\_\_\_\_\_, (~~description of the party along with address~~), hereinafter referred to as "The Bidder/ Contractor" which expression unless repugnant to the context or meaning hereof shall include its successors or assigns of the OTHER PART

**Preamble**

The Principal intends to award, under laid down organizational procedures, contract/s for **E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990 (Job Description: HANDLING AT SITE STORES/STORAGE YARD, TRANSPORTATION TO SITE OF WORK, COMPLETE ERECTION, TESTING, COMMISSIONING AND HANDING OVER OF ELECTRICAL WORKS OF ESP R&M SYSTEM AND ITS AUXILIARIES /ASSOCIATED EQUIPMENT FOR ESP R&M WANAKBORI U# 5 PROJECT,)**

(hereinafter referred to as "Contract"). The Principal values full compliance with all relevant laws of the land, rules and regulations, and the principles of economic use of resources, and of fairness and transparency in its relations with its Bidder(s)/ Contractor(s).

In order to achieve these goals, the Principal will appoint panel of Independent External Monitor(s) (IEMs), who will monitor the tender process and the execution of the contract for compliance with the principles mentioned above.

**Section 1-Commitments of the Principal**

1.1 ~~The Principal commits itself to take all measures necessary to prevent corruption and to observe the following principles:-~~

1.1.1 ~~No employee of the Principal, personally or through family members, will in connection with the tender for, or the execution of a contract, demand, take a promise for or accept, for self or third person, any material or immaterial benefit which the person is not legally entitled to.~~

1.1.2 ~~The Principal will, during the tender process treat all Bidder(s) with equity and reason. The Principal will in particular, before and during the tender process, provide to all Bidder(s) the same information and will not provide to any Bidder(s) confidential/ additional information through which the Bidder(s) could obtain an advantage in relation to the tender process or the contract execution.~~

1.1.3 ~~The Principal will exclude from the process all known prejudiced persons.~~

1.2 ~~If the Principal obtains information on the conduct of any of its employees which is a penal offence under the Indian Penal Code 1860 and Prevention of Corruption Act 1988 or any other statutory penal enactment, or if there be a substantive suspicion in this regard, the Principal will inform its Vigilance Office and in addition can initiate disciplinary actions.~~

**Section 2-Commitments of the Bidder(s)/ Contractor(s)**

~~2.1 The Bidder(s)/ Contractor(s) commit himself to take all measures necessary to prevent corruption. The Bidder(s)/ Contractor(s) commits himself to observe the following principles during participation in the tender process and during the contract execution.~~

~~2.1.1 The Bidder(s)/ Contractor(s) will not, directly or through any other person or firm, offer, promise or  
give to the Principal or to any of the Principal's employees involved in the tender process or the  
execution of the contract or to any third person any material, immaterial or any other benefit which  
he/ she is not legally entitled to, in order to obtain in exchange any advantage of any kind whatsoever  
during the tender process or during the execution of the contract.~~

~~2.1.2 The Bidder(s)/ Contractor(s) will not enter with other Bidder(s) into any illegal or undisclosed agreement or understanding, whether formal or informal. This applies in particular to prices, specifications, certifications, subsidiary contracts, submission or non-submission of bids or any other actions to restrict competitiveness or to introduce cartelization in the bidding process.~~

~~2.1.3 The Bidder(s)/ Contractor(s) will not commit any penal offence under the relevant Indian Penal Code (IPC) and Prevention of Corruption Act; further the Bidder(s)/ Contractor(s) will not use improperly, for purposes of competition or personal gain, or pass on to others, any information or document provided by the Principal as part of the business relationship, regarding plans, technical proposals and business details, including information contained or transmitted electronically.~~

~~2.1.4 Foreign Bidder(s)/ Contractor(s) shall disclose the name and address of agents and representatives in India and Indian Bidder(s)/ Contractor(s) to disclose their foreign principals or associates. The Bidder(s)/ Contractor(s) will, when presenting his bid, disclose any and all payments he has made, and is committed to or intends to make to agents, brokers or any other intermediaries in connection with the award of the contract.~~

~~2.2 The Bidder(s)/ Contractor(s) will not instigate third persons to commit offences outlined above or be an accessory to such offences.~~

~~2.3 The Bidder(s)/ Contractor(s) shall not approach the Courts while representing the matters to IEMs and shall await their decision in the matter.~~

### **Section 3—Disqualification from tender process and exclusion from future contracts**

If the Bidder(s)/ Contractor(s), before award or during execution has committed a transgression through a violation of Section 2 above, or acts in any other manner such as to put his reliability or credibility in question, the Principal is entitled to disqualify the Bidder(s)/ Contractor(s) from the tender process, terminate the contract, if already awarded, exclude from future business dealings and/ or take action as per the separate "Guidelines on Banning of Business dealings with Suppliers/ Contractors", framed by the Principal.

### **Section 4—Compensation for Damages**

Registered Office: BHEL House, Siri Fort, New Delhi – 110 049, India Website: <a href="http://www.bhel.com">www.bhel.com</a>
---

- 4.1 — If the Principal has disqualified the Bidder (s) from the tender process before award / or order acceptance according to Section 3, the Principal is entitled to demand and recover the damages equivalent to Earnest Money Deposit/ Bid Security.
- 4.2 — If the Principal is entitled to terminate the Contract according to Section 3, or terminates the Contract in application of Section 3 above, the Bidder(s)/ Contractor (s) transgression through a violation of Section 2 above shall be construed breach of contract and the Principal shall be entitled to demand and recover from the Contractor an amount equal to 5% of the contract value or the amount equivalent to Security Deposit/ Performance Bank Guarantee, whichever is higher, as damages, in addition to and without prejudice to its right to demand and recover compensation for any other loss or damages specified elsewhere in the contract.

#### **Section 5-Previous Transgression**

- 5.1 — The Bidder declares that no previous transgressions occurred in the last 3 (three) years with any other company in any country conforming to the anti-corruption approach or with any other Public Sector Enterprise in India that could justify his exclusion from the tender process.
- 5.2 — If the Bidder makes incorrect statement on this subject, he can be disqualified from the tender process or the contract, if already awarded, can be terminated for such reason or action can be taken as per the separate "Guidelines on Banning of Business dealings with Suppliers/ Contractors", framed by the Principal.

#### **Section 6 –Equal treatment of all Bidder (s)/ Contractor (s) / Sub-contractor (s)**

- 6.1 — The Principal will enter into Integrity Pacts with identical conditions as this Integrity Pact with all Bidders and Contractors.
- 6.2 — In case of Sub contracting, the Principal Contractor shall take the responsibility of the adoption of Integrity Pact by the Sub-contractor(s) and ensure that all Sub-contractors also sign the Integrity Pact.
- 6.3 — The Principal will disqualify from the tender process all Bidders who do not sign this Integrity Pact or violate its provisions.

#### **Section 7 –Criminal Charges against violating Bidders/ Contractors /Subcontractors**

If the Principal obtains knowledge of conduct of a Bidder, Contractor or Subcontractor, or of an employee or a representative or an associate of a Bidder, Contractor or Subcontractor which constitutes corruption, or if the Principal has substantive suspicion in this regard, the Principal will inform the Vigilance Office.

#### **Section 8 –Independent External Monitor(s)**

- 8.1 — The Principal appoints competent and credible panel of Independent External Monitor (s) (IEMs) for this Integrity Pact. The task of the IEMs is to review independently and objec-



**BHEL PSWR  
Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 41 of 108

tively, whether and to what extent the parties comply with the obligations under this Integrity Pact.

- 8.2 — The IEMs are not subject to instructions by the representatives of the parties and performs his functions neutrally and independently. He reports to the CMD, BHEL.
- 8.3 — The IEMs shall be provided access to all documents/ records pertaining to the Contract, for which a complaint or issue is raised before them as and when warranted. However, the documents/records/information having National Security implications and those documents which have been classified as Secret/Top Secret are not to be disclosed.
- 8.4 — The Principal will provide to the IEMs sufficient information about all meetings among the parties related to the Contract provided such meetings could have an impact on the contractual relations between the Principal and the Contractor. The parties offer to the IEMs the option to participate in such meetings.
- 8.5 — The advisory role of IEMs is envisaged as that of a friend, philosopher and guide. The advice of IEMs would not be legally binding and it is restricted to resolving issues raised by a Bidder regarding any aspect of the tender which allegedly restricts competition or bias towards some Bidders. At the same time, it must be understood that IEMs are not consultants to the Management. Their role is independent in nature and the advice once tendered would not be subject to review at the request of the organization.
- 8.6 — For ensuring the desired transparency and objectivity in dealing with the complaints arising out of any tendering process or during execution of Contract, the matter should be examined by the full panel of IEMs jointly, who would look into the records, conduct an investigation, and submit their joint recommendations to the Management.
- 8.7 — The IEMs would examine all complaints received by them and give their recommendations/ views to the CMD, BHEL at the earliest. They may also send their report directly to the CVO, in case of suspicion of serious irregularities requiring legal/ administrative action. Only in case of very serious issue having a specific, verifiable Vigilance angle, the matter should be reported directly to the Commission. IEMs will tender their advice on the complaints within 30 days.
- 8.8 — The CMD, BHEL shall decide the compensation to be paid to the IEMs and its terms and conditions.
- 8.9 — IEMs should examine the process integrity; they are not expected to concern themselves with fixing of responsibility of officers. Complaints alleging mala fide on the part of any officer of the Principal should be looked into by the CVO of the Principal.
- 8.10 — If the IEMs have reported to the CMD, BHEL, a substantiated suspicion of an offence under relevant Indian Penal Code / Prevention of Corruption Act, and the CMD, BHEL has not, within reasonable time, taken visible action to proceed against such offence or reported it to the Vigilance Office, the IEMs may also transmit this information directly to the Central Vigilance Commissioner, Government of India.
- 8.11 — After award of work, the IEMs shall look into any issue relating to execution of Contract, if specifically raised before them. As an illustrative example, if a Contractor who has been awarded the Contract, during the execution of Contract, raises issue of delayed payment etc. before the IEMs, the same shall be examined by the panel of IEMs. Issues like warranty/ guarantee etc. shall be outside the purview of IEMs.

~~8.12 — However, the IEMs may suggest systemic improvements to the management of the Principal, if considered necessary, to bring about transparency, equity and fairness in the system of procurement.~~

~~8.13 — The word 'Monitor' would include both singular and plural.~~

#### **Section 9—Pact Duration**

~~9.1 — This Integrity Pact shall be operative from the date this Integrity Pact is signed by both the parties till the final completion of contract for successful Bidder, and for all other Bidders 6 months after the Contract has been awarded. Any violation of the same would entail disqualification of the bidders and exclusion from future business dealings.~~

~~9.2 — If any claim is made/ lodged during currency of this Integrity Pact, the same shall be binding and continue to be valid despite the lapse of this Pact as specified above, unless it is discharged/ determined by the CMD, BHEL.~~

#### **Section 10—Other Provisions**

~~10.1 — This Integrity Pact is subject to Indian Laws and exclusive jurisdiction shall be of the competent Courts as indicated in the Tender or Contract, as the case may be.~~

~~10.2 — Changes and supplements as well as termination notices need to be made in writing.~~

~~10.3 — If the Bidder(s)/ Contractor(s) is a partnership or a consortium or a joint venture, this Integrity Pact shall be signed by all partners of the partnership or joint venture or all consortium members.~~

~~10.4 — Should one or several provisions of this Integrity Pact turn out to be invalid, the remainder of this Integrity Pact remains valid. In this case, the parties will strive to come to an agreement to their original intentions.~~

~~10.5 — Only those bidders / contractors who have entered into this Integrity Pact with the Principal would be competent to participate in the bidding. In other words, entering into this Integrity Pact would be a preliminary qualification.~~

~~10.6 — In the event of any dispute between the Principal and Bidder(s)/ Contractor(s) relating to the Contract, in case, both the parties are agreeable, they may try to settle dispute through Mediation before the panel of IEMs in a time bound manner. In case, the dispute remains unresolved even after mediation by the panel of IEMs, either party may take further action as the terms & conditions of the Contract. The fees/expenses on dispute resolution through mediation shall be shared by both the parties. Further, the mediation proceedings shall be confidential in nature and the parties shall keep confidential all matters relating to the mediation proceedings including any settlement agreement arrived at between the parties as outcome of mediation. Any views expressed, suggestions, admissions or proposals etc. made by either party in the course of mediation shall not be relied upon or introduced as evidence in any further arbitral or judicial proceedings, whether or not such proceedings relate to the dispute that is the subject of mediation proceedings. Neither of the parties shall present IEMs as witness in any Alternative Dispute Resolution or judicial proceedings in respect of the dispute that was subject of mediation.~~

**BHEL PSWR  
Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 43 of 108

Varun Vaidya (Manager/ Purchase)

\_\_\_\_\_

For & On behalf of the Principal \_\_\_\_\_ For & On behalf of the Bidder/ Contractor

(Office Seal) \_\_\_\_\_ (Office Seal)

Place \_\_\_\_\_

Date \_\_\_\_\_

Witness: \_\_\_\_\_ Witness: \_\_\_\_\_

(Name & Address) \_\_\_\_\_ (Name & Address) \_\_\_\_\_

\_\_\_\_\_

**BHEL PSWR  
Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 44 of 108

**ANNEXURE – 8**

**UNDERTAKING**

(To be typed and submitted in the Letter Head of the Company/Firm of Bidder)

**To,**

GM-PURCHASE, BHEL-PSWR,  
Floor No. 5&6, Shri Mohini Complex  
345, KINGSWAY, NAGPUR-440001

Dear Sir/Madam,

**Sub: DECLARATION REGARDING INSOLVENCY/ LIQUIDATION/ BANKRUPTCY PROCEEDINGS**

**Ref:** NIT/Tender Specification No: BHE/PW/PUR/WNS-U5/2990

I/We, \_\_\_\_\_ declare that, I/We  
am/are not under insolvency resolution process or liquidation or Bankruptcy Code Proceedings (IBC)  
as on date, by NCLT or any adjudicating authority/authorities, which will render us ineligible for  
participation in this tender.

**Sign. of the AUTHORISED SIGNATORY  
(With Name, Designation and Company seal)**

Place:

Date:

**BHEL PSWR  
Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 45 of 108

[ANNEXURE-9](#)

**DECLARATION**

Date: \_\_\_\_\_

To

GM-PURCHASE, BHEL-PSWR,  
Floor No. 5&6, Shri Mohini Complex  
345, KINGSWAY, NAGPUR-440001

**Sub: Details of related firms and their area of activities**

Dear Sir/ Madam,

Please find below details of firms owned by our family members that are doing business/ registered for same item with BHEL, \_\_\_\_\_ (NA, if not applicable).

1	Material Category/ Work Description	
	Name of Firm	
	Address of Firm	
	Nature of Business	
	Name of Family Member	
	Relationship	
2	Material Category/ Work Description	
	Name of Firm	
	Address of Firm	
	Nature of Business	
	Name of Family Member	
	Relationship	
.....		

***Note: I certify that the above information is true and I agree for penal action from BHEL in case any of the above information furnished is found to be false.***

Regards,  
( \_\_\_\_\_ )

From: M/s \_\_\_\_\_  
Supplier Code: \_\_\_\_\_  
Address: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**ANNEXURE-10**

**DECLARATION REGARDING MINIMUM LOCAL CONTENT IN LINE WITH  
REVISED PUBLIC PROCUREMENT (PREFERENCE TO MAKE IN INDIA), ORDER 2017 DATED  
04<sup>TH</sup> JUNE, 2020 AND SUBSEQUENT ORDER(S)**

*(To be typed and submitted in the Letter Head of the Entity/Firm providing certificate as applicable)*

To,

GM-PURCHASE, BHEL-PSWR,  
Floor No. 5&6, Shri Mohini Complex  
345, KINGSWAY, NAGPUR-440001

Dear Sir,

**Sub:** Declaration reg. minimum local content in line with Public Procurement (Preference to Make in India), Order 2017-Revision, dated 04<sup>th</sup> June, 2020 and subsequent order(s).

**Ref :** 1) NIT/Tender Specification No: BHE/PW/PUR/WNS-U5/2990,  
2) All other pertinent issues till date

We hereby certify that the items/works/services offered by..... *(specify the name of the organization here)* has a local content of \_\_\_\_\_ % and this meets the local content requirement for 'Class-I local supplier' / 'Class II local supplier' \*\* as defined in Public Procurement (Preference to Make in India), Order 2017-Revision dated 04.06.2020 issued by DPIIT and subsequent order(s).

The details of the location(s) at which the local value addition is made are as follows:

- |          |          |
|----------|----------|
| 1. _____ | 2. _____ |
| 3. _____ | 4. _____ |

...

Thanking you,  
Yours faithfully,

**(Signature, Date & Seal of  
Authorized Signatory of the Bidder)**

**\*\* - Strike out whichever is not applicable.**

**Note:**

1. Bidders to note that above format Duly filled & signed by authorized signatory, shall be submitted along with the techno-commercial offer.
2. In case the bidder's quoted value is in excess of Rs. 10 crores, the authorized signatory for this declaration shall necessarily be the statutory auditor or cost auditor of the company (in the case of companies) or a practising cost accountant or practicing chartered accountant (in respect of suppliers other than companies).

In the event of false declaration, actions as per the above order and as per BHEL Guidelines shall be initiated against the bidder.)

**ANNEXURE-11**

**DECLARATION REGARDING COMPLIANCE TO RESTRICTIONS UNDER RULE 144 (xi) OF GFR 2017**

*(To be typed and submitted in the Letter Head of the Entity/Firm providing certificate as applicable)*

To,

GM-PURCHASE, BHEL-PSWR,  
Floor No. 5&6, Shri Mohini Complex  
345, KINGSWAY, NAGPUR-440001

Dear Sir,

**Sub:** Declaration regarding compliance to Restrictions under Rule 144 (xi) of GFR 2017

**Ref :** 1) NIT/Tender Specification No: BHE/PW/PUR/WNS-U5/2990,  
2) All other pertinent issues till date

I have read the clause regarding restrictions on procurement from a bidder of a country which shares a land border with India and on sub-contracting to contractors from such countries. I certify that \_\_\_\_\_ *(specify the name of the organization here)*,

(a) is not from such a country / ☐

(b) has been registered with the Competent Authority *(attach valid registration by the Competent Authority, i.e., the Registration Committee constituted by the Dept. for Promotion of Industry and Internal Trade (DPIIT))*; ☐

and will not sub-contract any work to a contractor from such countries unless such contractor is registered with the Competent Authority. *(attach relevant valid registration, if applicable)*

I hereby certify that we fulfil all requirements in this regard and is eligible to be considered.

Thanking you,  
Yours faithfully,

**(Signature, Date & Seal of  
Authorized Signatory of the Bidder)**

**Note:** Bidders to note that in case above certification given by a bidder, whose bid is accepted, is found to be false, then this would be a ground for immediate termination and for taking further action in accordance with law and as per BHEL guidelines.

**BHEL PSWR  
Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 48 of 108

**Annexure-12: IMPORTANT INFORMATION**

**E -Tender** for this work is invited by BHEL PSWR NAGPUR and offer shall be submitted through BHEL e-procurement portal only. All correspondences regarding this tender shall be through E-procurement portal.

**Postal Address:**

GM /Purchase BHEL PSWR,  
SRIMOHINI COMPLEX, Floor No. 5 & 6, 345 KINGSWAY, NAGPUR 440001, INDIA

Following are the concerned BHEL officials to whom bidders can contact in case of any difficulty:

Manager Purchase, Email: [vaidya@bhel.in](mailto:vaidya@bhel.in) Ph: +91-9792334127

Manager Purchase, Email: [vivekjha@bhel.in](mailto:vivekjha@bhel.in); [Ph+91-9429198214](tel:+919429198214)

1. **Refer the abridged version of extant 'Guidelines for suspension of business dealings with suppliers/ contractors' which is available at [www.bhel.com](http://www.bhel.com) on "supplier registration page" at the following link: [https://www.bhel.com/sites/default/files/suspension\\_guidelines\\_abridged.pdf](https://www.bhel.com/sites/default/files/suspension_guidelines_abridged.pdf)**
2. **All Statutory Requirements as applicable for this project shall be complied with.**
3. **Following clause shall form part of the HSE documents issued under Chapter IX of Volume IB 'Special Conditions of Contract'**

"In case of any financial deduction made by Customer for lapses of safety other than what is provided elsewhere in the contract, the same shall be charged on back-to-back basis on the defaulting contractor without prejudice to any other right spelt anywhere in the tender /contract"

4. **BHEL Fraud Prevention Policy: "The Bidder along with its associate/ collaborators/ sub-contractors/ sub-vendors/ consultants/ service providers shall strictly adhere to BHEL Fraud Prevention Policy displayed on BHEL website <http://www.bhel.com> and shall immediately bring to the notice of BHEL Management about any fraud or suspected fraud as soon as it comes to their notice."**
5. **"Pradhan Mantri Kaushal Vikas Yojna:** The contractor shall, at all stages of work deploy skilled/semi-skilled tradesmen who are qualified and possess certificate in particular trade from CPWD Training Institute/Industrial Training Institute/ National Institute of Construction Management and Research (NICMAR), National Academy of Construction, CIDC or any similar reputed and recognized Institute managed/ certified by State/ Central Government. The number of such qualified tradesmen shall not be less than 20% of total skilled/semi-skilled workers required in each trade at any stage of work. The contractor shall submit number of man days required in respect of each trade, its scheduling and the list of qualified tradesmen along with requisite certificate from recognized Institute to Engineer-in-Charge for approval. Notwithstanding such approval, if the tradesmen are found to have inadequate skill to execute the work of respective trade, the contractor shall substitute such tradesmen within two days of written notice from Engineer-in-Charge. Failure on the part of contractor to obtain approval of Engineer-in-Charge or failure to deploy qualified tradesmen will attract a compensation to be paid by contractor at the rate of Rs.100 per such tradesman per day. Decision of Engineer-in-Charge as to whether particular tradesman possesses requisite skill and amount of compensation in case of default shall be final and binding".
6. Bidder to strictly follow all the necessary guidelines issued by Customer, District Magistrate, State Government and Central government to control Pandemic/Epidemic outbreak. The related towards quarantine Centre/Medical expenses etc., if any, shall be in the bidder's scope.
7. **~~The clause 2.7.9.1 below is added under the heading "Rights of BHEL" of General Conditions of Contract Volume-IC GCC:~~**

Registered Office: BHEL House, Siri Fort, New Delhi – 110 049, India  
Website: [www.bhel.com](http://www.bhel.com)



**2.7.9.1 Provision of Penalty in case of slippage of Intermediate Milestones:**

- ~~i) Two major Intermediate Milestones are mentioned as M1 & M2 in Chapter VI: Time Schedule of Vol IA Technical Conditions of Contract.~~
- ~~ii) In case of slippage of these identified Intermediate Milestones, Delay Analysis shall be carried out on achievement of each of these two Intermediate Milestones in reference to Form 14.~~
- ~~iii) In case delay in achieving M1 Milestone is solely attributable to the contractor, 0.5% per week of Executable Contract Value\*, limited to maximum 2% of Executable Contract Value, will be withheld.~~
- ~~iv) In case delay in achieving M2 Milestone is solely attributable to the contractor, 0.5% per week of Executable Contract Value\*, limited to maximum 3% of Executable Contract Value, will be withheld.~~
- ~~v) Amount already withheld, if any against slippage of M1 milestone, shall be released only if there is no delay attributable to contractor in achievement of M2 Milestone.~~
- ~~vi) Amount required to be withheld on account of slippage of identified intermediate milestone(s) shall be withheld out of respective milestone payment and balance amount (if any) shall be withheld @10% of RA Bill amount from subsequent RA bills.~~
- ~~vii) Final deduction towards LD (if applicable as per clause 2.7.9 above), on account of delay attributable to contractor shall be based on final delay analysis on completion / closure of contract. Withheld amount, if any due to slippage of identified intermediate milestone(s) shall be adjusted against LD or released as the case may be.~~
- ~~viii) In case of termination of contract due to any reason attributable to contractor before completion of work, the amount already withheld against slippage of intermediate milestones shall not be released and be converted into recovery.~~

~~\* **Executable Contract Value** Value of work for which inputs/ fronts were made available to contractor and were scheduled for execution till the date of achievement of that milestone.~~

**8. Conflict of Interest among Bidders/ Agents:**

"A bidder shall not have conflict of interest with other bidders. Such conflict of interest can lead to anti-competitive practices to the detriment of Procuring Entity's interests. ***The bidder found to have a conflict of interest shall be disqualified.*** A bidder may be considered to have a conflict of interest with one or more parties in this bidding process, if:

- a) they have controlling partner (s) in common; **or**
- b) they receive or have received any direct or indirect subsidy/ financial stake from any of them; **or**
- c) they have the same legal representative/agent for purposes of this bid; **or**
- d) they have relationship with each other, directly or through common third parties, that puts them in a position to have access to information about or influence on the bid of another Bidder; **or**
- e) Bidder participates in more than one bid in this bidding process. Participation by a Bidder in more than one Bid will result in the disqualification of all bids in which the parties are involved. However, this does not limit the inclusion of the components/ sub-assembly/ Assemblies from one bidding manufacturer in more than one bid; **or**
- f) In cases of agents quoting in offshore procurements, on behalf of their principal manufacturers, one agent cannot represent two manufacturers or quote on their behalf in a

particular tender enquiry. One manufacturer can also authorize only one agent/dealer. There can be only one bid from the following:

1. The principal manufacturer directly or through one Indian agent on his behalf; **and**
2. Indian/foreign agent on behalf of only one principal;

**or**

g) A Bidder or any of its affiliates participated as a consultant in the preparation of the design or technical specifications of the contract that is the subject of the Bid; **or**

h) In case of a holding company having more than one independently manufacturing units, or more than one unit having common business ownership/management, only one unit should quote. Similar restrictions would apply to closely related sister companies. Bidders must proactively declare such sister/ common business/ management units in same/ similar line of business."

**9. Acceptance of Bank Guarantee (BG)**

**Revision in Acceptance of Bank Guarantee (BG) Clause no. 1.10.3 (iii) of Vol I C GCC:**

**Clause No. 1.10.3 (iii) of Vol IC GCC is revised as below: -**

"Bank Guarantee issued by:

- a. Any of the BHEL consortium bank listed below:

State Bank of India  
ABN Amro Bank N.V.  
Bank of Baroda  
Canara Bank  
Citi Bank N.A.  
Corporation Bank  
Deutsche Bank  
HDFC Bank Ltd.  
The Hongkong and Shanghai Banking Corporation Ltd  
ICICI Bank Ltd.  
IDBI Ltd.  
Punjab National Bank  
Standard Chartered Bank  
State Bank of Travancore  
State Bank of Hyderabad  
Syndicate Bank

- b. Any public sector Bank (other than consortium banks) with a clause in the text of Bank Guarantee that "**It is enforceable at Nagpur, Maharashtra**".
- c. Any private sector banks, with a clause in the text of Bank Guarantee that "**It is enforceable by being presented at any branch of the bank**".

**Note: "Bank Guarantees issued by Co-operative Banks are not acceptable".**

**10. Broad Terms & Conditions of Reverse Auction:**

*In continuation to Clause 19.0 of NIT (Notice Inviting Tender) following are the broad terms and conditions of Reverse Auction:*

*"BHEL shall be resorting to Reverse Auction (RA) (Guidelines as available on [www.bhel.com](http://www.bhel.com)) (<https://www.bhel.com/guidelines-reverse-auction-2021>) for this tender. RA shall be conducted among the techno-commercially qualified bidders.*

*Price bids of all techno-commercially qualified bidders shall be opened and same shall be considered for RA. In case any bidder(s) do(es) not participate in online Reverse Auction, their sealed envelope price bid along with applicable loading, if any, shall be considered for ranking."*

**Note:-**

1. No benefits to MSE bidders w.r.t Reverse Auction Guidelines as available on [www.bhel.com](http://www.bhel.com) against works contract.
2. In case of enquiry through e-procurement the sealed electronic price bid (e-bid) is to be treated as sealed envelope price bid.
3. Reverse Auction will be conducted if two or more bidders are techno-commercially qualified. In case of two or three qualified bidders, there shall be no elimination of H1 bidder (whose quote is highest in sealed envelope price bid). **In case of four qualified bidders, the H1 bidder shall be eliminated whereas in case of five qualified bidders, H1 & H2 bidders shall be eliminated. However, in case of six or more qualified bidders are available, RA would be conducted amongst first 50% of the bidders arranged in the order of prices from lowest to highest.** Number of bidders eligible for participating in RA would be rounded off to next higher integer value if number of qualified bidders is odd (e.g. if 7 bids are qualified, then RA will be conducted amongst lowest four bidders). However, there will be no elimination of qualified bidders who are MSE or qualifying under PPP-MII, Order 2017, *provided their bids are within their respective margin of purchase preference {presently 15% for MSEs and 20% for PPP-MII, or as amended from time to time}.*

*In case of multiple H1 bidders, all H1 bidders (except MSEs and bidders qualifying under PPP-MII, Order 2017, who are within the margin of purchase preference) shall be removed provided minimum two bidders remain in fray, else no H1 removal*

11. **Commencement Period for "Performance Guarantee for Workmanship" as per clause no 2.24 of Vol-IC GCC:** This period shall commence after the completion of Contract as certified by Engineer-in-Charge
- ~~12. **Bidders kindly to take note that EMD (Earnest Money Deposit) shall be furnished by MSE bidders as well, as per the amount and procedure indicated in the NIT/GCC.**~~
13. **Performance Evaluation:**
  - 13.1 The Performance Evaluation shall be done when the contract is 'Under execution', i.e, works in progress as per the following:
    - i). Up to execution of 90% of anticipated Contract Value in case of Civil, MM, Structural and Turbo Blower Packages
    - ii). Up to Steam Blowing in case of Boiler/ESP/Piping Packages
    - iii). Up to Synchronization in all Balance Packages

Note: BHEL at its discretion can extend (or reduce in exceptional cases in line with Contract conditions) the period defined against (i), (ii) and (iii) above, depending upon the balance scope of work to be completed.
  - 13.2 Contractor shall provide the latest contact details i.e. mail-ID and Correspondence Address to SCT Department, so that same can be entered in the Contractor Performance Evaluation System, and in case of any change/discrepancy same shall be informed immediately. Login Details for viewing scores in Contractor Performance Evaluation System shall be provided to the Contractor by SCT Department.

- 13.3 Performance Evaluation for Activity Month shall be completed in Evaluation Month (i.e. month next to Activity Month) or in rare cases in Post Evaluation Month (i.e. month next to Evaluation Month) after approval from Competent Authority. In case scores are not acceptable, Contractor can submit Review Request to GM Site/ GM Project latest by 27th of Evaluation Month or 5 days after approval of score, whichever is later. However, acceptance/rejection of 'Review Request' solely depends on the discretion of GM Site/GM Project. After acceptance of Review Request, evaluation score shall be reviewed at site and the score after completion of review process shall be acceptable and binding on the contractor.
- 13.4 Project on Hold due to reasons not attributable to bidder –
- i. **Short hold:** Evaluation shall not be applicable for this period, however, Loading will be considered.
  - ii. **Long hold:** Short hold for continuous six months and beyond or hold on account of Force Majeure shall be considered as Long Hold. Evaluation as well as Loading shall not be considered for this period.
- 13.5 Performance evaluation as specified above in this clause is applicable to Prime bidder and Consortium partner (or Technical tie up partner) for their respective scope of work.
- 13.6 Bidders to note that the risk of non-evaluation or non-availability of the 'Monthly Performance Evaluation' reports as per relevant formats is to be borne by the Bidder.
14. **Liquidated Damage: (Clause no 2.7.9 of Vol-IC GCC has been amended as below)**  
If the contractor fails to maintain the required progress of work which results in delay in the completion of the work/extension in shutdown of unit as per the contractual completion period, BHEL shall have the right to impose Liquidated Damage/Penalty at the rate of 0.5 % of the contract value, per day of delay or part thereof subject to a maximum of 10% of the contract value. For this purpose, the period of delay shall be the delay attributable to the Contractor for the completion of work as per contract. Contract Value for this purpose, shall be the final executed value exclusive of ORC, Extra Works executed on Man-day rate basis, Supplementary/Additional Items and PVC.
15. **PVC clause no 2.17 of standard GCC: Not Applicable**
16. **ORC (Over Run Compensation) : Not Applicable**

**BHEL PSWR  
Notice Inviting Tender**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

Page 53 of 108

**ANNEXURE-13**

(To be typed and submitted in the Letter Head of the Company/Firm of Bidder)

**To,**

GM/Purchase  
BHEL PSWR  
Floor No. 5 & 6, Shree Mohini Complex,  
345-Kingsway, Nagpur-440001

Dear Sir/Madam,

**Sub: Bid Security Declaration**

**E-Tender Spec No: BHE/PW/PUR/WNS-U5/2990**

**JOB Description :**

HANDLING AT SITE STORES/STORAGE YARD, TRANSPORTATION TO SITE OF WORK, COMPLETE ERECTION, TESTING, COMMISSIONING AND HANDING OVER OF ELECTRICAL WORKS OF ESP R&M SYSTEM AND ITS AUXILIARIES /ASSOCIATED EQUIPMENT FOR ESP R&M WANAKBORI U# 5 PROJECT.

1. I/We Mr/ Ms..... authorised person to sign the bid documents for tender pertaining to the captioned scope do hereby declare that I/We have gone through the entire tender documents including terms and condition mentioned in the tender documents and undertake to comply with them.
2. I/We further declare that we will not withdraw our bid or modify our offer during the period of validity of the bid after the deadline for submission of such documents.
3. If I/we withdraw or modify the bids during the period of validity, or if I/We are awarded the contract and fail to sign the contract, if applicable or to submit security deposit as defined in the tender document/LOA, we will be suspended for the period of time as specified in the tender document from being eligible to submit bids/proposals to BHEL.

**Signature of the Authorised Signatory  
(With Name, Designation and Company seal)**

Place:

Date:

**2990**

# TECHNICAL CONDI- TIONS OF CON- TRACT (TCC)

## TECHNICAL CONDITIONS OF CONTRACT (TCC)

S. No.	DESCRIPTION	Chapter
<b>Volume—I</b>	<b>Part—I: Contract specific details</b>	
1	Project Information	Chapter-I
2	Scope of Works	Chapter-II
3	Facilities in the scope of Contractor/ BHEL (Scope Matrix)	Chapter-III
4	T&Ps and MMEs to be deployed by Contractor	Chapter-IV
5	Time Schedule	Chapter-V
6	Terms of Payment	Chapter-VI
7	Taxes and other Duties	Chapter-VII
8	Specific Inclusion	Chapter-VIII
9	BILL OF QUANTITY & Weightages/ Factor	Chapter-IX
10	Instruction to Bidders	Chapter-X

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

### 1. Project Information

Project Name: Unit-5 (210 MW) in stage-II at GSECL WANAKBORI ESP R&M.

The latitudes and longitudes of the site are as follows:

Sl. No.	Description	
1	Project Name	Unit-5 ESP R & M at GSECL Wanakbori –Stage –II
2	Location	Wanakbori (Gujarat)
3	Nearest Railway Station	Godhara
4	Nearest Airport	Ahmedabad/Baroda

The Bidder shall visit site and get acquainted himself with the conditions prevailing at site before submission of the bid. The information's given here in under are for general guidance and shall not be contractually binding on BHEL/ Owner. All relevant site data's/information's as may be necessary shall have to be obtained/ collected by the Bidder.



# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

### 2.0 SCOPE OF WORK.

The work under these specifications broadly covers the complete work of handling at storage yard/stores, transportation to work site, calibration, pre-assembly, erection, testing, pre-commissioning, and handing over of electrical system of Wanakbori ESP R&M

Supply & erection of consumable like conduit accessories & fittings, conduit boxes, saddles, clamps, flexible conduit, fixing hardware, anchors, wedges, nuts & bolts, concrete inserts, materials required for mounting the fixtures, consumable and other incidental materials required to complete the installation, testing & commissioning of complete lighting system for successful operation, & to the satisfaction of purchaser/ customer. Supply scope of these items shall form part of the installation rates quoted for the item.

LT Switchgear Boards /MCC/Electronic Control Panel with Areca Controller/ACP, IOS PC with furniture, Printer, Ash level indicator, Hopper/Shaft/Support Heaters, opacity Monitor with accessories, Illumination Work etc. LT Power and signal cable laying and termination work, Installation of Ladder/Perforated cable tray and steel support structure work and associated equipment & Associated Auxiliaries for the following: -

1. Junction boxes and Push button.
2. Structural Steel
3. 0.415 KV Switch gear
4. ONLY TESTING & COMMISSIONING of Electrical Equipment / Drives.
5. ELECTROSTATIC PRECIPITATOR (ESP).
6. Power/Control/Signal cables (LT)
7. Station Lighting.
8. Earthing Above / Below Ground
9. Other Misc. associated equipment.
10. Auxillary Control Panel
11. IOS Panel/RCU Panel
12. Lighting System
13. Other Misc Items

Minor civil works Plumbing/Grouting/Foundation required to complete the installation are covered under the scope of this contract and form part of the item installation cost and are not payable separately.

E&C of scope shall be done as per drawings & on instruction of BHEL Engineers.

### 2.1 GENERAL REQUIREMENTS

#### 2.1.1

The intent of specification is to procure services according to the most modern and proven techniques and codes. The omission of specific reference to any method, equipment or material necessary for proper

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

---

and efficient execution of this work shall not relieve the contractor of the responsibility of providing such facilities to complete the work without any extra compensation.

### 2.1.2

**The contractor must have the experience of erection of identical work in the past as specified in the tender documents and must have executed contract of similar nature. The contractor must furnish enough evidence to establish his capacity in erection, testing & commissioning of similar equipment's covered under this specification.**

### 2.1.3

**The contractor will have following valid certificates.**

- A) Contractor Electrical License for Extra High Voltage System installation work from Gujrat State authorities.**
- B) Supervisory Competency Certificate to deal with Electrical High Voltage equipment's for their erection, testing & commissioning. During the execution of work minimum two persons should be posted at site that has valid Supervisory Competency Certificate.**
- C) The contractor should have a very good engineering background and capability of carrying out erection & commissioning work as specified in this tender document.**

### 2.1.4

The work to be carried out under the scope of this specification covers the complete work of loading, handling, transporting, unloading, preassembly, erection, calibration, testing, air flushing, precommissioning tests, commissioning of systems, trial run of various auxiliaries and equipment's, achieving various milestones till handing over of the unit to BHEL's customer. The work shall conform to dimensions and tolerances specified in various drawings that will be provided during the erection. If any portion of the work is found to be defective in workmanship or not conforming to drawings or other specifications, the contractor shall dismantle and re-do the work duly replacing the defective materials at his cost, failing which the work will be got done by engaging other agencies or departmentally and recoveries will be effected from contractor's bills towards expenditure incurred including departmental charges.

### 2.1.5

The terminal points decided by BHEL shall be final and binding on the contractor for deciding the scope of work and effecting payment for the work done.

### 2.1.6

The work shall be executed under the usual conditions affecting major power plant construction and in conjunction with numerous other operations at site. The contractor and his personnel shall cooperate with personnel of BHEL, BHEL's customer, customer's consultants and other contractors, coordinating his work with others and proceed in a manner that shall not delay or hinder the progress of work of the project as a whole.

### 2.1.7

The work covered under this specification is of highly sophisticated nature, requiring the best quality workmanship, supervision, engineering and construction management. The contractor should ensure proper planning and successful & timely completion of the work to meet the overall project schedule.

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

---

The contractor must deploy adequate quantity of tools & plants, modern / latest construction aids etc. He must also deploy adequate trained, qualified and experienced supervisory staff and skilled personnel.

### 2.1.8

Contractor shall erect, align and commission all the equipment's and auxiliaries as per the sequence & methodology prescribed by BHEL depending upon the technical requirements. Availability of materials and fronts will decide this. BHEL engineer's decision regarding correctness of the work and method of working shall be final and binding on the contractor. No claims for extra payment from the contractor will be entertained on the ground of deviation from the methods / sequences adopted in erection of similar sets elsewhere.

### 2.1.9

**All necessary certificates and licenses, permits & clearances required to carry out this work from the respective statutory authorities are to be arranged by the contractor expeditiously at his cost in time to ensure smooth progress of work.**

### 2.1.10

The work shall conform to dimensions and tolerances specified in the various drawings / documents that will be provided during various stages of erection. If any portion of work is found to be defective in workmanship, not conforming to drawings or other stipulations due to contractor's fault, the contractor shall dismantle and re-do the work duly replacing the defective materials at his cost, failing which the work will be got done by BHEL and recoveries will be effected from the contractor's bills towards expenditure incurred including cost of materials and departmental overheads of BHEL.

### 2.1.11

BHEL reserves right to recover from the contractor any loss, which arises out of undue delay / discrepancy / shortage / damage, or any other causes due to contractor's lapse during any stage of work. Any loss to BHEL due to contractor's lapse shall have to be made good by the contractor.

### 2.1.12

All transport equipment, handling equipment, tools, tackles, fixtures, equipment, materials, skilled/unskilled manpower, supervisors/engineers, consumables etc., except otherwise specified as BHEL scope of free issue, required for this scope of work shall be provided by the contractor. All expenditure including taxes and incidentals in this connection will have to be borne by him unless otherwise specified in the relevant clauses. The contractor's quoted rates should be inclusive of all such contingencies.

### 2.1.13

During the course of erection, testing and commissioning certain rework / modification / rectification / repair / fabrication etc., may become necessary on account of feedback / revision of drawing. This will also include modifications / re-works suggested by BHEL / customer / other inspection group. Contractor shall carry out such rework / modification / rectification / fabrication / repair etc., promptly and expeditiously. Daily log sheets signed by BHEL engineer and indicating the details of work carried out, man-hours etc. shall be maintained by the contractor for such reworks. Claim of contractor if any, for such works.

### 2.1.14

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

All works such as cleaning, leveling, aligning, trial assembly, dismantling of certain equipment's / components for checking and cleaning, surface preparation, fabrication of sheets, tubes and pipes as per general engineering practice and as per BHEL engineer's instructions at site, cutting, gouging, weld depositing, grinding, straightening, chamfering, filing, chipping, drilling, reaming, scrapping, lapping, fitting up etc., as may be applicable in such erection works and which are treated incidental to the erection works and necessary to complete the work satisfactorily, shall be carried out by the contractor as part of the work within the quoted rates.

### 2.1.15

The contractor shall make all fixtures, temporary supports, steel structures required for jigs & fixtures, anchors for load and guide pulleys required for the work (excepting those specifically included in BHEL scope). However, necessary steel will be provided from the scrap / surplus materials available at site.

### 2.1.16

The contractor shall take delivery of the components, equipment's, chemicals, lubricants etc from the BHEL stores/ storage area after getting the approval of BHEL engineer on standard indent forms of BHEL. Complete and detailed account of the materials and equipment's after usage shall be submitted to the BHEL and reconciled periodically.

### 2.1.17

Contractor shall plan and transport equipment's, components from storage to erection site and erect them in such a manner and sequence that material accumulation at site does not lead to congestion at site of work. Materials shall be stacked neatly, preserved and stored in the contractor's shed and at work areas in an orderly manner. In case it is necessary to shift and re-stack the materials kept at work areas/ site to enable other agencies to carry out their work or for any other reason, contractor shall do it most expeditiously. No claim for extra payment for such work will be entertained.

### 2.1.18

The contractor shall take delivery of equipment, materials from the storage yard/ stores/sheds of BHEL/customer. He shall also make arrangements for verification of equipment, transportation up to site of work, safe custody, watch and ward of equipment after it has been handed over to him till these are fully erected, tested and commissioned and taken over by the customer. The contractor should note that the transport of equipment's to erection site, assembly yards etc. should be done by the prescribed route without disturbing the other works and contractors and in the most professional manner. Special equipment's such as measuring and control equipment's, panels, electronic items, SF6 breakers, switches, cables, conduits etc. shall be stored when taken over by the contractor in appropriate manner as per BHEL's instructions.

### 2.1.19

Plant materials should not be used for any temporary supports / scaffolding / preparing pre-assembly bed etc.

### 2.1.20

**The services, tests and support to be provided by the agency for the work mentioned in various sections of this tender are indicative and not exhaustive, and not limited to these for completion of the work in all respects.**

### 2.1.21

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

The weight & dimension as mentioned against any individual items in Rate Schedules or elsewhere in the tender specification are indicative approximate and there may be variation in dimension & weight in actual supply of equipment. No rate variation shall be considered on this account.

### 2.1.22

*The scope of work & description of system / equipment as given in the various clause of this tender specification and rate schedule are only for understanding the system requirement, contractor shall note this point and assess the volume of work prior to submit the offer.*

### 2.1.23

The contractor shall have total responsibility for all equipment and materials in his custody at contractor's stores, loose, semi-assembled, assembled or erected by him at site. He shall effectively protect the finished works from action of weather and from damages or defacement and shall also cover the finished parts immediately on completion of work as per BHEL engineer's instructions. The machined surfaces/finished surfaces should be greased and covered.

### 2.1.24

At all stages of work, equipment's/materials in the custody of contractor, including those erected, will have to be preserved as per the instructions of BHEL.

### 2.1.25

The contractor shall make suitable security arrangements including employment of security personnel and ensure protection of all materials/ equipment in their custody and installed equipment's from theft/fire/pilferage and any other damages and losses.

### 2.1.26

The contractor shall collect all scrap materials periodically from various levels of powerhouse, working area of the power station, auxiliary and piping around power station and collect the same at one place earmarked for the same. Loads of scraps are to be shifted to a place earmarked by BHEL. Failure to collect the scrap is likely to lead to accidents and as such, BHEL reserves the right to collect and remove the scrap at contractor's risk and cost, if there is any failure on the part of contractor in this respect. **1% value of each RA bill will be earmarked against compliance of the above, to be released only on satisfactory collection and deposit of scrap as stated above. In case of failure of contractor to comply with this requirement, BHEL will make suitable arrangement at contractor's risk and cost. In such case, any expenditure over and above the withheld 1% amount will also be recovered suitably from the RA bills of vendor.**

### 2.1.27

The entire surplus, damaged, unused materials, packaging materials / containers, special transporting frames, gunny bags, etc., shall be returned to BHEL stores by the contractor.

### 2.1.28

The contractor shall not waste any materials issued to him. In case it is observed at any stage that the wastage/excess utilization of materials is not within the permissible limits, recovery for the excess quantity used or wasted will be effected with departmental charges from the contractor. Decision of BHEL on this will be final and binding on the contractor.

### 2.1.29

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

---

For any class of work for which no specifications have been laid down in these specifications, work shall be executed as per the instructions of BHEL.

### 2.1.30

Housekeeping in the erection and preassembly area is as important as the well-planned and orderly work. The access to site for inspection approaches by BHEL and customer engineers and leading of the material shall be made available by the contractor at all times. The shifting and reshifting of erection materials, tools and plants and clearance of restrictions, filling of ditches, undulation near preassembly and switch yard area is the responsibility of the contractor. Contractor should visit the site and acquaint himself with all restrictions and difficulties that he may encounter during erection/commissioning stages.

### 2.1.31

The contractor shall handover all parts/materials remaining extra over the normal requirement with proper identification tags in a packed condition to BHEL stores. In case of any misuse or use over actual design requirements, BHEL reserves the right to recover the cost of parts/materials used in excess or misused. Decision of BHEL engineer in this regard will be final and binding on the contractor.

### 2.1.32

The contractor should take all reasonable care to protect equipment and materials under his custody either in his stores or at site. Copper tubing, brass fittings, brass valves etc. Forming an integral part of equipment or system are liable to greater damages / pilferages / theft / losses. It will be responsibility of contractor to arrange for adequate security round the clock for protection from such damages/pilferages/theft/losses.

### 2.1.33

The contractor shall ensure that all the packing materials and protection devices used for the various equipment's during transit and storage are removed before this equipment are erected in position.

### 2.1.34

Overhauling, cleaning, revisioning, servicing of equipment's during erection and commissioning stages will be arranged by the contractor. All equipment's shall be preserved and protected before and after erection as per the advice of BHEL engineer.

### 2.1.35

Substantial portion of cable laying & termination shall be done by other agencies for those equipment covered under this tender specification. The glands & lugs shall be supplied either loose or fitted with the equipment's. Contractor shall take care of this aspect at the time of receipt of the equipment from BHEL stores. Contractor shall account for the quantities received with equipment's and shall hand over the same to cabling agency under intimation to BHEL Engineer. Contractor shall extend all necessary help & co-ordinate with the cabling agency during the course of work.

### 2.1.36

**Contractor will be required to maintain in his site office at least one PC (computer) along with minimum accessories like printer, etc to enable him to carry out site activities in a planned, well-coordinated and smooth manner.**

### 2.1.37

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

---

Contractor shall prepare Marked-Up drawings incorporating modifications and deviations from original drawings or prepare fresh sketch for actual installation / connection details if need be, that can be converted to "As-built" drawing.

### **2.2 TESTING, PRE-COMMISSIONING, AND POST COMMISSIONING:**

#### **2.2.1**

The contractor shall perform various activities during pre-commissioning, integrated testing, post-commissioning stages of equipment covered under this tender specification. It is responsibility of contractor to arranged tools & plants, test equipment's, experienced engineers and technicians. Contractor shall earmark separate manpower for respective commissioning areas and they shall not be disturbed /diverted for other work. The contractor's commissioning group shall work as per the instruction of BHEL Engineer and they shall coordinate day-to-day activity with other agency and BHEL/ Customer. The testing activity may have to be repeated till satisfactory results are obtained and also to satisfy the requirement of Customer / statutory Authority.

#### **2.2.2**

The contractor shall simultaneously start testing & commissioning activities for equipment's to match the mile stone activities of the project.

#### **2.2.3**

The mobilization of these commissioning groups shall be such that planned activities are taken up in time and also completed as per schedule and work undertaken round the clock if required. It is responsibility of contractor to discuss on day to day / weekly / monthly basis the requirement of manpower, consumables, tools & tackles / testing equipment's with BHEL Engineers and arrange for the same. If at any time the requisite manpower, consumables, testing equipment's etc are not arranged then BHEL shall make alternative arrangements and necessary recoveries with overhead cost will be made from the running bills.

#### **2.2.4**

It shall be specifically noted that the contractor may have to work round the clock and in shifts during the pre-commissioning and commissioning period along with or without BHEL engineers and hence considerable overtime payment is involved. The contractor's quoted rates shall be inclusive of all these factors.

#### **2.2.5**

In case any rework/ repair / rectification/ modification / fabrication etc is required because of contractor's faulty workmanship which are noticed during the commissioning of, at any stages, the same shall be rectified by the contractor at his cost. If during the commissioning any improvement / repair / rework / rectification / fabrication / modification due to design improvement is required, the same shall be carried out by the contractor promptly and expeditiously.

#### **2.2.6**

During the commissioning activities and carrying out various tests, if any of temporarily work such mounting of test equipment's etc are required; the contractor shall carry out such work without any extra cost. The same shall be removed after completion of the activity.

#### **2.2.7**



# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

---

During this period, though BHEL/ client's staff will also be associated in the work, the contractor's responsibility will be to arrange for complete requirement of men and required Tools & Plants, Consumables, Scaffolding and approaches etc., till such time the commissioned unit is taken over for trial operations.

### 2.2.8

The contractor shall carry out any other tests as desired by BHEL engineer on erected equipment covered under the scope of this contract during testing, pre-commissioning and commissioning, to demonstrate the completion of any part or whole of work performed by the contractor.

### 2.2.9

The pre-commissioning activities will start in phased manner to meet the various milestones and shall continue till equipment's are commissioned fully with all connected equipment / devices or handed over to customer for regular operation. In this duration other erection activities such as cabling etc., shall be carried out by other agencies even though equipment's are partially commissioned / charged. In order to co-ordinate the work such as issue of safety permit, normalization and compliance of other requirement, contractor shall keep team of experienced engineer, supervisor, technician and helper in each shift as decided by BHEL Engineer. The team shall take instruction from BHEL Engineer for day-to-day work and shall not be diverted for other work. No extra payment shall be made for their services.

## 2.3 VOID

### 2.3.0.1 VOID

### 2.3.1 VOID

### 2.3.2 VOID

### 2.3.3 VOID

### 2.3.4

The scope of Testing and Commissioning of electrically operated actuators for valves, dampers, gates, soot blowers, Hoists, Cranes, Chain pulley etc., will include meggering, providing loop wire on actuator terminal block, adjustments of mechanical/ electrical or electronic position transmitters, setting of limit/torque switches, cable checking, internal wiring checking, local/remote operation from MCC & MMI package (max DNA system), replacement of limit/torque switches if required.

### 2.3.5

Contractor shall cut/open work, if needed, as per BHEL engineer's instructions during commissioning for inspection, checking and make good the works after inspection is over.

### 2.3.6

Contractor has to repeat any test free of cost, even if already conducted, whenever required to prove and check the healthiness of system before power flow, such test could be primary injection and primary injection in CTs. CVT, Insulation resistance of system / individual equipment, functional tests or any other tests as required by BHEL/ BHEL's client

2.3.7 Contractor shall execute as per drawings & FQP.



# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

---

### **2.4 WELDING, NON-DESTRUCTIVE TESTING ETC.**

- A) Installation of equipment involves good quality welding, NDE checks etc.
- B) Welder deployed for aluminum welding shall have experienced and approved by BHEL and BHEL's Customer after due qualification process/testing.
- C) Welding of all structural steel & aluminum shall be done only by the qualified and approved welders.
- D) All the welders shall be tested and approved by BHEL engineer before they are actually engaged on work though they may possess IBR/other certificate. BHEL reserves the right to reject any welder without assigning any reason.
- E) The welded surface shall be cleaned of slag and painted with primer paint to prevent corrosion. For this paint will be supplied by the contractor.
- F) Welding electrodes have to be stored in enclosures having temperature and humidity control arrangement. This enclosure shall meet BHEL specifications.
- G) Certain types of coated welding electrodes, prior to their use, call for baking for specified period and will have to be held at specified temperature for specified period. Also, during execution, the coated welding electrodes have to be carried in portable ovens.

### **2.5 MEASUREMENTS & WASTAGE & CUTTING ALLOWANCES:**

#### **2.5.1**

For all payment purposes, measurement shall be made on the basis of the execution of drawings/physical measurements. Physical measurements shall be made by the contractor in the presence of the Engineer.

#### **2.5.2**

The measurement for cable, impulse pipes/tubes, GI pipe, conduits, flexible conduits, trays etc., shall be made on the basis of length actually laid.

#### **2.5.3**

All the surplus, scrap and serviceable materials, out of the quantity issued to the contractor shall be returned to BHEL in good condition and as directed by the engineer.

#### **2.5.4**

All materials returned to stores should carry aluminum tag indicating the size and type. Cables more than 5 meters length is termed as serviceable material and shall be returned size wise and category wise to the owner's stores/yard. Cable of serviceable length being returned to the stores in drums shall have their free ends sealed and the balance lengths on the drum(s) shall be noted and certified by the Engineer-in-charge. This shall be applicable only for the purpose of accounting the cables issued for installation.

#### **2.5.5**

While carrying out material reconciliation with contractor, all the above points will be taken into account. All serviceable material returned by the contractor shall be deducted from the quantities issued for the respective sizes and categories and the balance quantity (ies) will be taken as the net quantity (ies) issued to the contractor. Material reconciliation shall be done and allowable scrap quantity calculated as per

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

wastage allowance percentage specified above. Any scrap/wastage generated by the contractor in excess of the allowable percentage shall be charged at the rates decided by the Engineer whose decision shall be final and binding on the contractor.

### 2.5.6

For all site-fabricated steel items such as supports, racks, frame, Canopy etc. physical measurement shall be made and then converted to tonnage. For steel material supplied to the contractor, all scrap shall be returned to BHEL stores with due accounting.

### 2.5.7

Every month the contractor shall submit an account for all the materials issued to him by BHEL in the standard Performa prescribed for this purpose by the site in charge.

### 2.5.8

The erection contractor shall make every effort to minimize wastage during erection work. Cutting and wastage allowance shall be computed on length, weight of material actually used, measured and accepted. In any case, the wastage shall not exceed the following limits;

Sl.No.	Item	% Wastage on issued Qty
01.	Each iron/steel section	2
02.	Each size of power cables	1
03.	Each size of control / shielded cable	2

### 2.5.9

If the actual wastage is more than the specified figure, then equivalent price of the excess portion will be deducted from the contractor's bill.

### 2.5.10

The cable taken off from drums shall be planned strategically such that jointing in the run of cables and wastage are avoided. For this purpose the exact route length between various equipment/panels as per the cable schedule shall be measured and the route length recorded before laying of the cables. Depending upon the route length and the type of cable required for various destinations, the cable drums shall be suitably selected for cable laying. Any jointing shall have to be approved by BHEL engineer. All the cut pieces/bits of cables, which are not used, shall be returned to the purchaser for accounting towards wastage. The cables damaged by the contractor shall have to be replaced by the contractor at his own cost.

### 2.5.11 NOTE:

Salvageable scrap shall mean lengths of pipes, multicables, other cables etc., that can be used one time or other at a later date and normally they are recovered from the cut-pieces of pipes, multicore cables, cables etc.

Non - Salvageable scrap means the lengths of tubes, pipes, multicore cables, cables, tray etc., and they are from cut-pieces of tubes, pipes, multicore cables, cables etc., that cannot be used at all one time or other.

### 2.5.12

For any items or classes of work not specified herein but required for total completion of work, the same shall be carried out as per BHEL requirement. However, payment for these items/class of work shall be regulated on the basis of rate arrived at by either of the following methods:

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

---

- A) Based on rate of identical/similar items in the rate schedule.
- B) Based on the rate arrived from nearby items in the rate schedule.
- C) Wherever any item rate for similar type of work or nearby item rate does not exist in the rate schedule, rate will be worked out on the basis of work element or from fundamentals of estimation.

Contractor shall provide necessary resources for completion of such work within the stipulated time schedule. Value of such work shall be included while computing the total value of work finally executed for all contractual purposes, particularly for contract variation purpose.

### 2.5.13

The contractor's scope of work is further described in the clauses hereafter:  
The work will comprise of, but not limited to the following:

### 2.5.14 JUNCTION BOXES/PUSH BUTTONS

- 1. Checking of installation for correctness.
- 2. Functional checking/ adjustment of JB / PB for their system.

### 2.5.15 VOID

## 2.6 STRUCTURAL FABRICATION AND INSTALLATION.

### A. INSTRUMENT/ PANEL FRAME / JUNCTION BOX FRAME & MISC STRUCTURES FABRICATION.

- 1. Structural steel material like MS angles, channels, beams, flats, plates etc. shall be supplied in running meter and the same shall be used for misc. fabrication if required. and the same shall be used for fabrication of panel base frame, Canopies for instruments/panels/ drives/JB's/Push Buttons etc., Instrument/Junction box frames, Impulse Pipe/Instrument Air Pipe supports and instruments etc.
- 2. This shall include cutting to size, contouring of ends for connections if required, welding, grinding of excess weld deposits/burrs, drilling of holes for mounting of device/instrument, installation at location, leveling, alignment, providing bracings and painting etc. No gas cut holes will be permitted.
- 3. All the fabricated supports/frames for instruments, trays, pipes, electrical equipment's, etc., shall be epoxy painted after sand blasting and surface preparation as per painting specifications. Paints and other associated items are in the scope of the contractor.
- 4. Frame installation at site may involve mounting either on concrete floor by grouting/using anchor fasteners or on steel structure by welding etc. All consumables including anchor fasteners shall be arranged by the contractor. Where required, as part of work, concrete floors may have to

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

---

be chipped out to reinforcement depth for anchoring the frames. Wherever grouting is required, contractor shall arrange all the required material including cement/grout mix, shuttering etc., necessary labor and meet all other requirements as part of work.

5. In certain packages, members of frames/rack for mounting of junction boxes/ instruments may be supplied readymade. These have to be assembled prior to installation. The installation rate as quoted shall include assembly of the frames.
6. Gas cutting of tray/impulse pipe support and holes in frame is not permitted. Only hacksaw cutting/ drilled hole shall be permitted.

### 2.7 INSTALLATION OF PANELS/LT SWITCHGEAR

1. Electrical control panels are normally supplied in suit of either one/two/three or loose shipping sections with integral base frame or loose base frame. These panels may have to be installed as stand-alone or in-group consisting of number of panels in each row, depending upon the plant layout and foundation arrangement.
2. The panels shall be transported from stores to the place of installation in vertical position. Care shall be taken such that the switches, lamps, instruments etc. mounted on the panel do not get damaged during transit.
3. Installation of panel shall include fixing of base frame, leveling, alignment, fixing of anti-vibration pads, removal of side covers, fixing of cubical interconnection hardware, interconnection of bus bar /bus bar jointing, wiring interconnection, welding and grouting of panels and base frames, mounting of panel canopy wherever supplied as part of panel, drilling of gland plates, sealing of panels/ cable entries. Where the base frame is not supplied as part of panel supply, the contractor shall fabricate the base frame from structural items at site. Payment for such fabrication will be effected on measured quantity at the rate applicable for structural steel fabrication and installation. Proper sealing of all the holes and cable entries (even if the cable has been laid by others) in the panel is in the contractor's scope.
4. Panels have to be shifted to their locations through floor openings, temporary openings like floor grills, door etc. Which shall be a part of work and no claim whatsoever will be entertained with regard to non-availability of opening as per shortest route etc. Panels have to be erected at different locations and elevation in powerhouse building, LT Switchgear room, unit control room etc.
5. Panel and instruments once erected in position should be properly protected using necessary care to prevent ingress of dust/moisture. This will have to be periodically cleaned and surroundings have to be kept tidy.
6. Whenever the panels are to be mounted on cable trenches, channel supports have to be provided across the cable trench over which the base frame of panel shall be mounted. For such work, structural steel fabrication & installation rate shall be applicable.
7. Normally the panels shall be supplied with meters, relays, electronic modules, and contactors, pushbuttons etc mounted and pre-wired. However, if such devices are supplied loose/separately for safety in transit, contractor shall mount the same as part of panel installation work and terminating the wires on devices. No extra payment shall be made for this.

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

---

8. Supplier's instruction manuals, packing slips, door keys etc. received along with the panels will be handed over to BHEL's engineer on opening of the panels.
9. Regular cleaning of the panels as per the instruction of BHEL engineer till handing over of the set to customer is to be carried out by the contractor free of cost.
10. Interposing Relays (24 / 48 Volt DC) along with mounting base shall be supplied separately for mounting in the various feeders of 415 Volt MCC Board / Switchgear Panel Boards for uni-directional / bi-directional drives, solenoid valves. 2 Nos. interposing relay are required to be mounted in each feeder. Internal wiring for these relay shall be pre-wired in the feeders, wires to be terminated on relay terminals. Approximately quantity is 500 Nos. Contractor shall mount the same and terminate the wire as part of panel installation work and no extra payment shall be made for this work.

### **2.8.B VOID**

### **2.9 ELECTROSTATIC PRECIPITATOR**

1. ESP shall have six flue gas passes and each pass comprises of HT rectifier transformer (silicon oil filled), Auxiliary Control Panels, electronic controller, LT Main switch board and its bus duct, Drives for Rapping/Collecting/ Gas damper screen, heating element for hoppers/shaft and supporting insulator housing, ash level indicator and EP management system (software based) including computer interface and associated interlock and protection.
2. HT rectifier transformer shall be erected by mechanical agencies. Scope of work covered under this contract is oil filtration of transformers and erection and testing of various devices as listed in rate schedule. Contractor shall provide silicon oil filter machine as a part of scope. Contractor has also to provide operator round-the-clock for oil filtration and other necessary testing equipment's. Necessary tests are same as mentioned above in clause no. 2.8. Contractor shall utilize power supply for filter machine from the source, which is given for the construction purpose, and shall arrange required cables.

### **2.10 VOID**

### **2.11 VOID**

### **2.12 VOID**

### **2.13 void**

### **2.14 ELECTRICAL HOIST**

Electrically operated Hoist/Cranes/Chain Pulley of capacity varying from 2 MT to 50 MT are provided for maintenance purpose for ID/FD/PA fans, Mill area, Air Heater, ESP,FGD and other area in boiler. Mechanical erections of hoist components such as runway beams, hoist carriage, drive unit, etc. shall be done by other agency. The scope of work covered in this tender specification for erection, commissioning & installation of DSL system and associated accessories.

### **CABLE TRAYS/CABLE DUCTS/ACCESSORIES**

A Various types of sheet metal, galvanized cable tray, i.e. perforated, ladder type, sheet metal duct, solid bottom trays, pre-fabricated structural trays etc., will be supplied in standard lengths along with accessories and hardware viz; coupler plate, tray covers and tray clamps etc.

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

B Installation of cable tray/cable duct shall include cutting, laying, jointing, fixing tee/reducers/bends/clamps, fixing of tray covers, hardware, welding of tray supports as per tray route layout etc.

C **Fabrication of bends/tee/ reducers from straight length of tray is within the scope of work and rate quoted shall be inclusive in unit rate (in running meter).** All site welds of cable trays shall be painted with approved primer and cold galvanizing paint, which shall be arranged by the contractor.

D In case structural cable trays, bends, tees, reducers etc., are required to be fabricated from structural steel and installed, unit rate applicable for fabrication and installation of structural steel shall be applicable in such instances. Fabricated Tray Bend, TEE, Cover supplied by the Customer shall be paid in running Meter of that Cable Route. **Alteration in readymade bends, tees, reducers etc shall not be paid extra cost.**

E Cable trays/duct etc may have to be routed underground in cable trench, over head on structure, along the walls, floors etc.

F As per the BOQ Main Cable tray and support shall be installed in Cable cellar , TG Hall, Boiler floors, and Mill, ID-Fan, PA-Fan, FD-Fan, FGD, ESP, Soot Blower area and BOP area. Looping Trays shall be laid for JB to Field also under the scope of the contract.

G. Cable trays where ever is required by the other BHEL vendor (from BHEL Equipment to BHEL Equipment) are included in this contract as sizes mentioned in BOQ.

H. Horizontal runs of cable trays shall be supported at intervals of 1.5 meters approximately. Vertical runs (risers) shall be supported at approximately every 1 meter interval. Spacing between cable trays shall normally be kept 300mm for cable laying convenience and effective heat dissipation. Where direct heat radiation exists, heat isolating barriers shall be adopted

I. The cable tray numbering shall be provided at every 30 meter and at each end of cable tray & branch connection floor/wall opening.

I. Cable trays philosophy shall be as per enclosed cable erection philosophy.

### **2.5.15 CABLE LAYING - (POWER / CONTROL / INSTRUMENTATION SHIELDED CABLES / PLUG-IN CABLES / DATA HIGHWAY, ARMOURED / UN-ARMOURED, SINGLE / MULTI-CORE, PVC / HR PVC / EPR/ FRLS / TEFLON / XLP INSULATION)**

1. Cable laying includes cutting to the required length, laying in overhead Cable racks / underground cable trenches, pipes, flexible conduits, dressing/clamping in tray, drilling of holes in gland plates in panels and junction box, glanding, splicing, dressing of spliced wire inside the panel and JBs, **providing printed ferrules (ferrule printing machines to be provided by contractor for printing necessary cross ferruling details) / PVC numerical / alphabetical ferrules (where printed ferrules not possible at all) machine engraved ferrules sleeve/ ferrule**, termination by using crimp type copper tinned/aluminium lugs, insulated/un-insulated, crimp and soldered termination, plug-in connections with insert type crimping, providing identification cable tags of PVC/aluminium at both the ends and at appropriate interval ( Approximately 30meters) throughout the route length, continuity checking, insulation resistance checking, high voltage test on HT cables.



# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

Contractor to arrange adequate numbers of his own ferrule printing machines. Buried cable routes shall have marker projecting 150 mm above ground and shall be spaced at an interval of 30 m along the route and at every bend.

2. Entry to the panels, JB's may be at top, side or bottom. All cable are required be supported and clamped near to the panel.
3. For sizes above 63 mm mild steel pipes with necessary fittings & accessories shall be provided and installed by the contractor. Pipes shall be manufactured by electric welding process. These pipes shall be of heavy duty class as per IS: 1239.
4. No single core cable shall pass through a GI conduit/ pipe or duct singly except DC single core cables. AC single core cables shall pass through GI conduit/ pipe in trefoil formation only, or through PVC pipes conforming to IS: 4985.
5. L.T. power cables of cross sectional area less than 95 sq. mm. and all control and Instrumentation cables shall be clamped in bunches by means of cable nylon ties.
6. Wherever cable glanding is not possible, either due to the gland plate size limitations or more number of cable entries, cables may have to be lifted inside the panel by making large cut-out in gland plate and providing 4 or 6 inch PVC pipe coupling glands. These pipe coupling glands shall be supplied by contractor within the quoted rates of cable lying.
7. Copper tinned lugs of various types up to 4 sq mm conforming to IS: 694 (pin, ring, fork, snap-on) for cables, PVC cable ties, PVC ferrules, PVC button and tapes, cable identification tag of PVC/metal as per site requirement, clamping and dressing material such as suitable cable ties/ clamps etc with hardware, PVC sleeves etc. shall be supplied by contractor within the quoted rate for cable laying. **However trefoil clamps with hardware for Single core power cable shall be supplied by BHEL.** The quality and make of cable lugs shall be got approved from BHEL engineer prior to their use on job.
8. All care should be taken to avoid abrasion, tension, twisting, kinking and stretching of cables during installation.
9. Testing and electrical measurement of cable installations shall conform to the requirement of IS: 1255.
10. Cable shielding – all signal cables are supplied with bare shielded copper wire/with braided wire shield. Generally, shield wire is kept isolated at instrument/field device end and continuity is maintained through JB's and earthed at panel end only. While terminating the shield wire in either panel or JB's, PVC sleeves are to be used to avoid two-point earthing.
11. Spare holes in the panels / Instruments / Actuators / Motors / JB's etc shall be sealed by suitable method by contractor. (The cost of work and Materials such as aluminum sheet or Adhesive tape / Plugs etc shall be within the quoted rates for laying of cables).
12. Many of the cable trays and cables have to be laid in cable trenches. For this purpose, the cover of the trenches have to be opened for working in site and whenever the cables are to be laid in existing cable tray, all safety precautions have to be observed. After completing the work, the trenches have to be cleaned and covers put back into position. Contractor shall also carry out de-watering from the trenches if required and arrange pumps etc. at his cost.

*Cables to be laid for exhaust fan and its starter box shall be laid on the wall/ beam/ceiling for that spacer, cleat and clamp material shall be supplied by the bidder. Cable laying rate shall be inclusive of hardware items.*

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

Looping wire at terminal block of panels and electrical actuator is to be done by contractor at no extra cost. *Re termination of control/power cable in panel or equipment side due to any reason will not be paid extra. Agency shall provide the electrician during commissioning of equipment after cable termination work if necessary.*

13 Cable clamping spacing for cables laid in cable trays shall be generally as under: (a) Trefoil clamps (Nylon clamps):

1) Horizontal run spacing: 750 mm (max.)

2) Vertical run spacing: 500 mm (max.)

(b) Other Clamps:

1. Power cables of sizes indicated under

(i) Single core cables: 500 sq. mm or higher (When not laid in trefoil formation e.g. dc circuits)

(ii) Multi core cables: 95 sq. mm or higher

Horizontal runs: Individually clamped at 750 mm interval (max.)

Vertical runs: Individually clamped at 500 mm interval (max.)

2. Power cables of other sizes

Horizontal runs: Collectively clamped at 750 mm interval (max.)

Vertical runs: Collectively clamped at 500 mm interval (max.)

3. Control Cables

Horizontal runs: Collectively clamped at 750 interval (max.)

Vertical runs: Collectively clamped at 500 mm interval (max.)

14 Contractor shall carefully plan the cutting schedule of each cable drum in consultation with BHEL site engineer such that wastages are minimized. Recovery will be made in case the wastages are exceeding the wastage allowances fixed in this contract.

15 Cable lying shall include drilling of gland holes, fixing of cables, glands, tagging, ferruling, termination & continuity checking. The erection contractor shall supply consumables like aluminum tags, lugs and ferrules.

16 Unit rate quoted for cable lying shall include the activities as defined above from Sl. No. 1 to 15.

### **2.5.16 JUNCTION BOXES/PUSH BUTTONS**

3. Checking of installation for correctness.
4. Functional checking/ adjustment of JB / PB for their system.
5. Erection/Testing/Commissioning



# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

### **2.5.17 SCOPE OF ABOVE GROUND EARTHING**

1. The contractor shall carry out above ground earthing for all Electrical equipment and cable tray erected BHEL vendor, which may be erected by him, or some other agency. Different type of earthing materials shall be supplied and the contractor shall lay and connect the earthing materials as per site requirement and as detailed in drawings. Unit rate for earthing material shall be paid on running meter basis.
2. All equipment shall be earthed by two separate and distinct connections. Earthing terminals will be available in all the equipment supplied by BHEL.
3. Generally risers are provided near the structure / equipment foundation, In case risers are not visible and buried below the foundation level, contractor shall carry out necessary earth excavation for connecting the above ground earthing strips. Wherever welding is involved necessary protective coating shall be applied on weld joints.
4. The earthing conductors shall be mild steel/G.I. strips/wires. All connections from the equipment to the main earthing conductors shall be made as illustrated in earthing drawings. A copy of earthing drawing shall be provided to the successful bidder.
5. A continuous earthing conductor shall be installed in all cables trays and securely clamped to each tray section by suitable connectors to form a continuous earthing system. When two or more trays supporting power cables run on parallel a continuous earthing conductors shall be provided on one tray only with tap-offs to the control cable trays. All valve and damper motor and rapping motors will be earthed to this conductor.
6. If the equipment is not available at the time of earthing conductor laying tap connections from the main earthing conductor shall be brought out up to slab equipment foundation level with at least 200 mm spare length left for further connections to equipment earthing terminals.
7. Entire system shall be earthed in accordance with the provisions of the relevant IEC recommendations/IS code of practice IS 3043-1947 and Indian Electricity Rules, so that the values of the step and contact potentials in case of faults are kept within safe permissible limits.
8. Parts of all electrical equipment and machinery not intended to be live shall have two separate and distinct earth connections each to conform to the stipulation of the Indian Electricity Rules and apparatus rated 240 V and below may have single earth connections.
9. If any outer shops and buildings as well as the electrical sub-stations and electrical rooms are also in contractor's scope, a ring main earthing system will be provided. Ring main earthing systems shall again be interconnected as a network to power plant main earthing mat. Internal earthing ring in the electrical equipment room provided by the contractor whether equipment of the area is in their scope or not.
10. For different floors in a building, localized internal earthing ring shall be formed and connected to the ground earthing through vertical risers. The earthing mat shall be common to both power and lighting installations.
11. A minimum of two spare earth rings will be provided in each floor of the building for earthing future building.
12. Each RCC steel column of the building will be interconnected to the floor-earthing grid in basement/ground floor. For protective earthing separate conductor shall be used for flow of earth fault current as elaborated below:

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

- 13 Contractor shall carry out minor civil i.e. chipping of floor (where earth strip is to be laid on floor), removal of topsoil for laying earth strip in switchyard area etc.
- 14 It is the responsibility of contractor to provide manpower for periodic maintenance after the initial commissioning till handing over the system to customer. During this period the activities are to be carried out such as checking the electrolyte & specific gravity of individual battery, topping up of electrolyte, cleaning etc.
- 15 Refer & follow the notes mentioned in Drg no. PE-DC-415-509-E004
- 15 Treated Earth Pits:** Preparation of Treated earth pit includes Supply of all items (except the electrode rod 3 M Long /Pipe 3 M Long with funnel) including charcoal; salt, civil chamber with cover (as indicated in the drawing) is in the scope of the contractor. The contractor shall also connect this pit to the earth grid (by other agency) at nominal distances of 5 to 10 meters by 40 mm rods, which are also in the scope of the contractor. Earth Pits/Electrodes for street lighting pole / equipment shall be executed as per the Typical Drg. Issued by PEM for illumination system
- 16 Earth electrode:**

Earth electrode shall be made of 40 mm dia MS/GI rod tapering of one end of electrode rod and buried as indicated in the drawing. Civil works are also to be carried out by the contractor. The contractor shall also connect this pit to the earth grid (by other agency) at nominal distances of 5 to 10 meters by 40 mm rods, which are also in the scope of the contractor.

### 2.6 STRUCTURAL FABRICATION AND INSTALLATION.

#### A. INSTRUMENT/ JUNCTION BOX FRAME/ CABLE TRAY & MISC STRUCTURES FABRICATION.

7. Structural steel material like MS angles, channels, beams, flats, plates etc. shall be supplied in running meter and the same shall be used for misc. fabrication if required. and the same shall be used for fabrication of panel base frame, cable tray supports, Canopies for instruments/panels/ drives/JB's/Push Buttons etc., Instrument/Junction box frames, Impulse Pipe/Instrument Air Pipe supports and instruments etc.
8. This shall include cutting to size, contouring of ends for connections if required, welding, grinding of excess weld deposits/burrs, drilling of holes for mounting of device/instrument, installation at location, leveling, alignment, providing bracings and painting etc. No gas cut holes will be permitted.
9. All the fabricated supports/frames for instruments, trays, pipes, electrical equipment's, etc., shall be epoxy painted after sand blasting and surface preparation as per painting specifications. Paints and other associated items are in the scope of the contractor.
10. Frame installation at site may involve mounting either on concrete floor by grouting/using anchor fasteners or on steel structure by welding etc. All consumables including anchor fasteners shall be arranged by the contractor. Where required, as part of work, concrete floors may have to be chipped out to reinforcement depth for anchoring the frames. Wherever grouting is required,

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

contractor shall arrange all the required material including cement/grout mix, shuttering etc., necessary labor and meet all other requirements as part of work.

11. In case, structural cable trays, bends, tees, reducers etc., are required to be fabricated from structural steel and installed, unit rate applicable for fabrication and installation of structural steel shall be applicable in such instances.
12. In certain packages, members of frames/rack for mounting of junction boxes/ instruments may be supplied readymade. These have to be assembled prior to installation. The installation rate as quoted shall include assembly of the frames.
13. Gas cutting of tray/impulse pipe support and holes in frame is not permitted. Only hacksaw cutting/ drilled hole shall be permitted.

### 1. METAL CHANNEL FLEXIBLE BOLTABLE CABLE SUPPORT SYSTEM (ESP)

Flexible GI cable support system, consisting of single/double channels, base plates, and cantilever arms are as per BOQ. Wherever necessary, the base plate beam clamps will be supplied for bolting. Otherwise, the base plates are to be welded to the racks or beams if necessary at 90 deg.

Angle fittings, flat plate fittings, clamps for single & double channels, fasteners etc. will be supplied for fixing trays and cantilever arms and for this no separate erection charges will be paid. Quoted Rate Rates shall be accommodated in support channel and cantilever arm erection. Brief scope of work is further defined as below:

3. Metal channel bolt able GI cable support shall be supplied. Each cable rack assembly comprises of sub components such as single or double channel, base plate for single/ double channel, angle fitting, clamps, cantilever arm, anchor fastener, associated hardware (spring loaded nuts, bolts and washers) etc.
4. Channel shall be supplied in standard length of six meter. Contractor shall cut the channel and assembly the rack as per site requirement. Cantilever arm is to be fixed on channel support with spring loaded nuts / bolts as per installation drawing.
5. Base plate / angle fitting shall be continuously welded all around to steel members /plate insert if provided. Brackets / clamps shall be welded to steel surface with channel as applicable in position to ensure alignment of clamps / channels. Weld thickness shall be 6 mm minimum. In case steel surface is not available for welding, anchor bolts is to be used for fixing the base / angle fitting.
6. Main support for longitudinal cable tray run in the cable vaults shall be fixed at both ends at top as well at bottom as outlined above.
7. Galvanization damaged due to welding / cutting shall be re-painted with cold galvanizing paint (paint in contractor's scope).
8. Unit rate for **"Single / Double Channel"** shall include cutting channel in required lengths, fixing of angle fittings/ base plate / clamps / brackets / fasteners/ cantilever arms /, welding etc as required as per type of installation.
9. The Nuts & bolts should be galvanized type.

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

---

### 5.19 STATION LIGHTING:

#### SCOPE OF WORK.

The work under these specifications broadly covers the complete work of handling at storage yard/stores, transportation to work site, calibration, pre-assembly, erection, testing, pre-commissioning, and handing over of lighting system (**Illumination**) including all lighting equipment specified under technical specification and all other materials required for completion of this package.

**Supply & erection of consumable like conduit accessories & fittings, conduit boxes, saddles, clamps, flexible conduit, fixing hardware, anchors, wedges, nuts & bolts, concrete inserts, materials required for mounting the fixtures, consumable and other incidental materials required to complete the installation, testing & commissioning of complete lighting system for successful operation, & to the satisfaction of purchaser/ customer. Supply scope of these items shall form part of the installation rates quoted for the item.**

The broad scope of E&C work includes:

1. LDB/WDB
2. Lighting Panels
3. Lighting Luminaries
4. Switch Boxes
5. Junction Boxes
6. Receptacles
7. Ceiling Fan
8. Lights/Poles
9. Wires/GI Flat/MS rod
10. Conduits
11. Hume Pipe
12. Supply Module/Lamp unit
13. High mast and accessories
14. Exit sign/Occupancy Sensor

Minor civil works Plumbing/Grouting/Foundation required to complete the lighting installation, concealed conduiting are covered under the scope of this contract and form part of the item installation cost and are not payable separately.

E&C of scope shall be done as per drawings & on instruction of BHEL Engineers.

- 1** Station lighting covers complete power plant and its auxiliary (BOP) area, handling transportation from BHEL stores / yard to work place. Erection & Commissioning of lighting material like LDB (Including Lighting transformer for AC /DC) Type, LP, Lighting luminaires ( with Complete accessories ), Switch Boxes, Junction Boxes, Receptacles, Ceiling Fan, Emergency lighting, Poles, Conduits, Rigid/Flexible PVC coated conduit, Wires, structural Steel, Hume Pipe, High Mast, Cabling in Tray and Underground excavated trench, Earthing above and below ground as per the drgs, etc.

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

---

2. All measuring and testing instruments required during erection, testing, commissioning and performance testing shall be arranged by the bidder.
6. Supply of necessary hardwares *such as double compression cable glands, conduit fittings viz. couplers, elbows, bends, tees, circular boxes etc., conduit accessories viz. clips, saddles, spacing plates, entry bushes, lock nuts, plugs, heavy duty lugs, ferrules, expansion fasteners, ball & sockets, earth clips, fan boxes, clamps, screws, pull out boxes etc.* are in the scope of bidder. No separate rate shall be payable for the above.

### **2.6 GUIDELINES FOR LIGHTING SYSTEM ERECTION WORK**

- 1 The contractor shall be responsible if any parts of lighting fixtures, LDBs, LPs are lost or damaged and lamps are broken during installation. All damage and thefts shall be made good by the contractor till the installation is handed over to the customer.
2. The contractor shall note that for any change in the location of lighting panels, lighting fixtures, switch boxes/receptacles, no extra charges will be paid so long as the modifications are indicated to the contractor before commencement of the work on that particular equipment or circuit.
- 3 The contractor shall have a separate cleaning gang to clean all equipment under erection as well as the work area and the project site at regular intervals to the satisfaction of Engineer-in-charge.
- 4 Except as specifically approved by the Engineer-in-Charge, installation of exposed conduits, mounting of lighting fixtures, etc. shall be taken up only after other services such as piping, air ducting, cable tray/bus duct hangers, structural bracing's etc. in a particular area have been installed
- 5 After installation of lighting fixtures/receptacles, panel number and circuit number shall be painted on them at a suitable place
- 6 Work to be in-line with drawing/design philosophy as per BHEL Engineer instruction.

#### **2.6.1 GUIDELINES FOR LIGHTING SYSTEM ERECTION WORK.**

- 1 The contractor shall work in co-ordination with civil, air-conditioning, ventilation & switchgear vendors. Where holes or openings in walls and floors are required for routing the conduits, the contractor shall provide the same. Cut-outs in false ceiling shall be provided by false ceiling contractor.
- 2 The contractor shall be responsible if any parts of lighting fixtures, LDBs, LPs are lost or damaged and lamps are broken during installation. All damage and thefts shall be made good by the contractor till the installation is handed over to the customer.
- 3 The contractor shall note that for any change in the location of lighting panels, lighting fixtures, switch boxes/receptacles, no extra charges will be paid so long as the modifications are indicated to the contractor before commencement of the work on that particular equipment or circuit.
- 4 The contractor shall have a separate cleaning gang to clean all equipment under erection as well as the work area and the project site at regular intervals to the satisfaction of Engineer-in-charge. In case this is not done, the purchaser will have the right to carry out the cleaning operation and any expenditure incurred in this regard will be to the contractor account.

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

- 5 Except as specifically approved by the Engineer-in-Charge, installation of exposed conduits, mounting of lighting fixtures, etc. shall be taken up only after other services such as piping, air ducting, cable tray/bus duct hangers, structural bracing's etc. in a particular area have been installed
- 6 After installation of lighting fixtures/receptacles, panel number and circuit number shall be painted on them at a suitable place.
7. Work to be in-line with drawing/design philosophy and as per BHEL Engineer instruction.

### 2.6.2 Lighting Fixtures and Accessories.

- 1 Lighting fixtures of appropriate type as per the lighting layout drawings shall be installed by the contractor. The type of mounting, arrangement of fixtures shall be selected from the typical arrangements shown in enclosed fixture mounting details drawings in section-E. The type of mounting will generally be indicated on the layout drawings. The exact mounting will, however, be decided at site depending upon the actual space/other facilities available at site.
- 2 The contractor shall submit for purchaser's approval the drawings showing the detailed mounting arrangements of various types of fixtures prior to installation.
- 3 Wooden plugs in walls and ceilings for fixing of lighting fixtures and accessories are not acceptable. A suitable fool-proof method (preferably using nylon rawl plug) of fixing these shall be offered and this be subject to the purchaser approval.
- 4 The bracket for mounting the lighting fixtures on boiler platforms shall be fabricated at site using GI conduit with a reducing socket to suit the fixture and clamped to the hand rails. However, the clamping of these conduits at points of large vibrations should be avoided. The fixing shall be strong enough to withstand vibrations and wind velocity. If a roof (or other platform over the platform is available, the fixture will be pendant mounted (supported to the structural members of the platform above).
- 5 Flood lights shall be mounted on steel base facing the tentative direction shown on drawings. Bolts shall be tightened with spring washers. Terminals connection to the flood lights shall be through flexible conduits.
- 6 In the rooms where false ceilings are provided, the lighting fixtures shall be supported separately by false ceiling grid or roof over false ceiling if it is of steel structural or form ceiling and not by the false ceiling board. The arrangement shall be to the approval of purchaser. The erection rate of lighting fixtures shall include the supply of steel brackets, supporting, anchoring material, hardware and also steel brackets/hangers for bridging the gap above false ceilings, etc., required for installation of lighting fixtures as shown in the approved fixture mounting arrangement drawings.
- 7 A four (4) way terminal junction box type F shall be provided near each lighting fixture, for loop-in, loop-out and off connection of lighting wires or as required.
- 8 To distinguish emergency AC fixtures from normal AC fixtures, red painted circular mark of 1 cm dia. shall be provided on emergency fixtures.



# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

- 9 The self-contained emergency lighting fixtures shall be installed in required areas. Mounting brackets are to be provided by the contractor.

### 2.6.3 Lighting distribution board and Lighting Panels.

- 1 Lighting DB's consisting of lighting transformer etc, shall be mounted on floor and LP's shall be mounted on the walls/columns/steel structures at the locations indicated in the drawings.
- 2 Suitable Space provision for LDB mounting on floor would be made by the purchaser. The contractor will supply necessary foundation bolts and do the grouting to fix up the LDBs.
- 3 LPs shall be installed by fastening to studs of not less than 12 mm dia. which will be suitably grouted/welded to the wall/column by the contractor. All the required accessories including studs for the erection of the panel shall be supplied by the contractor. If Mounting channels are required for, LPs the same will be provided by contractor.

### 2.6.4 Lighting control Switch Boxes & Receptacle Boxes.

- 1 The locations of switch/receptacle boxes will be approximately as shown in the drawings. The exact location shall be finalised by the contractor in consultation with the engineer-in-Chief.
- 2 All switch/receptacle boxes in offices and control room shall be flush mounted in the wall. In other areas they shall be mounted on wall or column.

### 2.6.5 Conduits and Accessories

- 1 All lighting wires shall be run inside the conduit. Size of conduit shall be selected as per the table given below.

Size of Wire	Max. number of wires in	
	20mm conduit	25mm conduit
1.5 sq. mm.	4	
2.5 sq. mm.	4	6

- 2 Conduit shall run along wall, floor, ceiling, on steel structures, embedded in wall, floor, for ceiling, in accordance with relevant layout drawings. The contractor shall closely co-ordinate his work with the civil contractor. Exposed conduits shall be run in straight lines parallel to building columns, beams and walls. Unnecessary bends and crossings shall be avoided to present a neat appearance. In the office area as specified conduits shall be embedded along the entire run. It is the responsibility of the lighting contractor to co-ordinate with the civil contractor of these buildings.
- 3 Conduit shall be clamped on to approved type spacer plates or brackets by saddles or U-bolts. The spacer plates or brackets in turn, shall be securely fixed to the building steel by welding and to concrete or brick work by grouting or by nylon rawl plugs.

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

- 4 Embedded conduits shall be securely fixed in position to preclude any movement. In fixing embedded conduit, if welding or brazing is used, extreme care should be taken to avoid any injury to the inner surface of the conduit.
- 5 Spacing of embedded conduits shall be such as to permit flow of concrete between them and in no case shall be less than 40mm.
- 6 For direct embedding in soil, the conduits shall be coated with an asphaltbase compound. Concrete pier or anchor shall be provided where necessary to support the conduit rigidly and to hold it in place.
- 7 Conduits shall be installed in such a way as to ensure against trouble from trapped condensation.
- 8 The contractor shall made available at site, dies for threading various conduits. Running threads shall be avoided as far as practicable. Where it is unavoidable, check nut shall be used. All field thread ends shall be reamed after threading and anti-corrosive paint applied.
- 9 Conduits shall be kept, wherever possible, at least 300 mm away from hot pipes, heating devices etc.
- 10 Slip joints shall be provided when conduits cross structural expansion joints or where long run of exposed conduits are installed, so that temperature change will cause no distortion due to expansion or contraction of conduit run
- 11 For long conduit runs junction/pull boxes shall be provided at suitable intervals (not exceeding 10 m) to facilitate wiring.
- 12 Conduits shall be securely terminated at LPs/junction boxes or lighting fixtures by proper fastening with a lock put on inside and outside. The number of conduits terminating at LP's shall not exceed the permissible number considering the glanding area of lighting panel. Conduit termination's shall be made water & vermin proof.
- 13 Conduits lengths shall be jointed by acrowed couplers. Conduit shall be cleanly cut. The cut ends shall be within three (3) degrees of square with the conduit axis. Cut ends shall be reamed and all burrs and sharp edges removed.
- 14 Conduits lengths shall be jointed connection and shall be made thoroughly water-tight and rust-proof by application of a thread compound which will not insulate the joints. White lead will be uses for embedded conduit and red lead for exposed conduit.
- 15 Water treatment plant chlorination plant lighting installations shall be made with epoxy coated steel conduits and accessories.
- 16 Field bends shall have a minimum radius of four (4) times the conduit diameter. All bends shall be free of kinks, indentations or flattened surfaces. Heat shall not be applied in making any conduct bend. Separate bends may be sued for this purpose.



# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

- 17 The entire metallic conduit system, whether embedded or exposed, shall be electrically continuous and thoroughly grounded where slip joints used, suitable bending shall be provided around the joint to ensure a continuous ground circuit.
- 18 Conduits and fittings shall be properly protected during construction period against mechanical injury. Conduit ends shall be plugged or capped to prevent entry of foreign material.
- 19 After installation, the conduits shall be thoroughly cleaned by compressed air before pulling in the wire.
- 20 Lighting fixtures shall not be suspended directly from the junction box in the main conduit run.
21. **Conduits in control room, service building, laboratory building and other air-conditioned areas will be surface mounted on the roof above false ceiling, however vertical drops of conduits will be concealed along walls and finally plastered by bidder (including minor chipping works) for better aesthetics.**

### 2.6.6 Lighting wires

- 1 Lighting wires from lighting panels to junction boxes and junction boxes to lighting fixtures, switch boxes and receptacle boxes shall run in conduits (Rigid/flexible).
- 2 All wires in a conduit shall be drawn simultaneously. No subsequent drawing is permissible.
- 3 Wires shall not be pulled through more than two equivalent 90 deg. bends in a single conduit run. Wherever required, suitable conduit junction boxes/pull boxes shall be provide. All types of wiring, concealed or unconcealed shall be capable of easy inspection.
- 4 Receptacles and lighting circuits shall be fed from different circuits. The switch controlling these circuits shall be on the live side (phase wire) of the circuits.
- 5 A.C. normal, A.C. emergency and D.C. emergency system wiring shall run throughout in separate conduits.
- 6 Wiring shall be spliced only at junction boxes. Maximum two wires shall be connected at each terminal.
- 7 In vertical run of wires in conduit the wires shall be suitably supported by means of wooden/hard rubber plugs at each pull/junction box.
- 8 All lighting wires shall be crimped using suitable type of solderless, crimping, tinned fork type copper lugs. Cost of the lugs shall be included in the erection price of wire.

### 2.6.7 Junction Boxes

- 1 Necessary holes for conduit/cable entry shall be done during installation depending on the requirement. The holes shall be drilled/punched neatly and shall be dust/vermin proof after installation of the conduit.

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

- 2 All welds, bolts holes, conduit entry holes etc., made during installation as mentioned above shall be wire brushed and touched up with metal primer (lead oxide and zinc chromate in synthetic medium)

### 2.6.8 Street Lighting/Flood Lighting Poles

1. The lighting poles and lighting Tower shall be erected by the contractor at locations shown in the street lighting layout to be prepared by contractor and shall be got approved from the BHEL. The erection work shall include making of foundations (with supply of all materials). Installation of necessary wiring/ cabling, junction/ switch box and mounting of assembled fittings The cable from junction box at the bottom of pole upto the lighting fixture shall be supplied by the contractor. All the above erection work shall be done by contractor for lighting masks including making of foundations. 50mm GI pipe shall be provided for cable protection from trench to junction box by the contractor for loop-in-loop-out cables.
- 2 The lighting poles shall be painted with two coats of aluminium paint after completion of installation or as specified by purchaser.
- 3 The flood light fixtures shall be mounted on galvanised M.S. base making use of shop drilled holes or by suitable clamps. No cutting or drilling of galvanised structure is permitted.
- 3 The bidder shall submit the foundation drgs of poles for purchaser's approval.

### 2.6.9 Earthing of Lighting system

- 1 All junction boxes, receptacles, switch boxes, lighting fixtures, conduit etc. shall be earthed in compliance with the provision of I.E. rules and applicable Indian Standard amended upto date or as specified in the approved Drg by PEM
- 2 A continuous earth conductor of G.I. wire shall be run all along each conduit run and bonded at every 600 mm by not less than two turns of the same size of wires. This conductor shall be connected to the earth bus of lighting panel from which the conduits originate. All junction boxes, receptacles, lighting fixtures etc. shall be connected to this GI earth conductor. All lighting panels and LDBs shall be earthed by GI flats to the purchasers earthing bus. The supply of GI flat and erection shall be in contractor's scope and rates of the same shall be included in the erection rates of the respective LDB/LP.

### 2.6.10 Ceiling Fans and Regulators (If Applicable)

- 1 The contractor shall install the ceiling fans and regulators at the locations shown in the relevant drawings. The exact location will however, be decided at site in consultation with engineer-in-charge.
- 2 The fan regulators shall be flush mounted on the lighting control switch boxes provided in that area.
- 3 Hook alongwith rubber bush shall be supplied and grouted by contractor in ceiling for mounting the fan. All necessary material and hard wares for installation shall be supplied by contractor.

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

### 2.6.11 Foundation & Civil Works

- 1 Equipment foundations, for street lighting Poles/Flood Lighting Poles, lighting mast, street lighting panel and other panels mounting foundation and other civil work including supply of cement, steel and other materials as per relevant drawings and specification clauses shall be provided by the contractor. Cost of foundation works, including supply of necessary material is to be quoted as part of E & C rates for these items.
- 2 All foundation drawings shall be subject to the purchaser's approval. However, it shall be the responsibility of the contractor to check these foundations before commencement of erection to ensure their suitability.
- 3 All final adjustment of foundation levels, chipping and dressing of foundation surfaces, setting and grouting of anchor bolts, sills, inserts and fastening devices shall be carried out by the contractor including minor modification of civil work as may be required for erection.
- 4 Any cutting of masonry/concrete work, which is necessary, shall be done by the contractor at his own cost and shall be made good to match the original work. The contractor shall obtain approval of the purchaser before proceeding with any cutting of masonry/concrete work.
- 5 The contractor shall perform all excavation and backfilling as required for ground connections and casting foundations.
- 6 Excavation shall be performed upto the required depth. Such measures shall be taken as may be necessary for protection of the wall.
- 7 The contractor shall make use of his own arrangements for pumping out any water that may be accumulated in the excavation.
- 8 All excavation shall be backfilled to the original

### 2.15 FINAL PAINTING

- A. The contractor shall provide all the primer, paint, and other consumables like brush, cleaning agents etc. All T&P, manpower, supervision is in contractor's scope. Painting shall be carried out as per colour scheme approved by BHEL/ BHEL customer.
- B. All metal parts of the equipment including supports, structures, etc., as applicable shall be painted after thoroughly cleaning the surface from dust, rust, greases, oils, scales, etc, by wire brush, scraping, sand blasting/ shot blasting (**as applicable**) as specified in relevant erection documents. The above parts shall then be painted with specified two coats of specified paint over the shop primer/paint. Also, where the shop primer/paint has peeled off, the affected area shall be cleaned thoroughly by the specified method and then primer coat applied. Similarly, certain components may be supplied without any primer/paint coat from shop. The surface of such items shall be cleaned as per specifications, coated with suitable primer and then coated with final paint coats. The dry film thickness after final coat should be as per specification. The color, shade etc. shall be as per specification.

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

Painting schedule will be furnished at site. The scope of painting work is for the following areas. Primer and paint shall be sourced only from the following manufacturers or any other manufacturers approved by BHEL.

Siemens Grey  
Berger Paints (I) Ltd.  
Asian Paints Ltd.  
Goodlass Nerolac Paint Ltd.  
Jenson & Nicholson Ltd.  
Shalimar paints Ltd.  
Any other , approved by BHEL

In order to have consistency in painting system, it is preferable that all the supplies are sourced from one single manufacturer.

- C. All the fabricated frames, racks, supports, panel base frame etc. wherever applicable shall be painted primer and with two coats of paint as specified earlier herein.
- D. Touch-up painting of switchgear panel, 415 Volt LT MCC, Control Panels or any other equipment /devices wherever necessary.
- E. The primer shall be compatible with the final coat paint schedule.
- F. Full painting of transformers, bus ducts with two coats of paint as per specification
- G. Supply of paint, primers, other consumables etc for above and any other scope in these specifications shall be in Contractor's scope.
- H. Irrespective to scopes of painting & supply of paint mentioned elsewhere it is to be noted that supply of paint, primers, other consumables etc for all primer/painting works to be done by the contractor, shall be in Contractor's scope. No dispute shall be entertained on the above matter.

### 2.15.1 Void

### 2.15.2 STRUCTURALS

Structural components may be supplied without any primer/paint coat from shop. The surface of such items shall be cleaned as per specifications and then coated with two coats of Primer.

### 2.15.3 PANELS, JUNCTION BOXES

Panels and Junction Boxes shall be Touch-up painted as and where original shop paint is peeled off. Necessary surface cleaning and preparation shall be done by the contractor as per relevant painting codes followed by two coats of Primer and two coats of Finish Paint.

### 2.15.4 Primers, Paints etc.

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

---

The contractor shall provide the Primer (ROZC as per IS:2074) for the scope of painting work indicated in Section-4 as well as for protection of site weld joints and gas cut locations. Contractor shall also arrange to provide the required thinner and other consumables, T&P etc required for application of ROZC Primer. All paints and thinners shall be sourced only from BHEL approved manufacturers. Some of them are as listed under.

1. M/s Asian Paints
2. M/s Berger paints
3. M/s Jenson & Nicholson
4. M/s Shalimar Paints

**Supply of paint, primers, other consumables etc for above and any other scope in these specifications shall be in Contractor's scope.**

### 2.16

**The work under this scope being quite sophisticated and also quite extensive, for proper planning, monitoring, reporting, etc of ongoing works, the contractor shall establish his own computer(1 no.) and printer(1 no.) at his site office, along with suitable operator(s), consumables, etc. Non-establishment of above equipment will attract penalty @ Rs 10000 (Rs Ten thousand only) per month.**

**BHEL uses its own software SOMS (Site Operation and Management System) for total project execution and billing. The contractor shall also provide adequate and suitable skilled manpower for updating / entries into SOMS in BHEL computers at site.**

### 2.17 Troubleshooting during plant operation

**During pre-commissioning / commissioning stages when the plant will be under various stages of operation, it will be necessary to have continuous (day and night) presence of suitable manpower along with required tools to attend to any defects etc that may arise during such operation. The contractor will be required to put such personnel in shifts in electrical area. The bidder must also take this aspect into consideration.**

### 2.18

**Equipment's / instruments etc., under the above scope of erection and commissioning are generally dispatched from BHEL's manufacturing units / vendor's works at site well before start of erection. Sometimes, such dispatched materials may get stuck up with transporters/railways. The**

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

contractor shall provide support / manpower for necessary chase up for removal of such bottlenecks in transportation. Also, for smaller items, it could be necessary to depute his person to personally carry certain items from works to site. Requirement of such activities, which will be decided by BHEL engineer and chase up activities, if required, shall be performed under authorization by BHEL. The above services shall be provided within the quoted rates.

### 2.19 STATUTORY CLEARANCES

1. Contractor shall be responsible for all necessary liaisoning work with Statutory Authority towards the certification of installation / works. BHEL shall reimburse Statutory Fees as per actual on submission of original receipt, however all incidental expenses shall be borne by Contractor. BHEL/ BHEL's Customer shall be providing technical assistance, drawing & document for submission to Statutory Authority. Contractor shall provide all logistics services in this regard.

4. The installation of all electrical equipment's shall be carried out only by persons holding valid certificates of Competency for the voltage classes as defined in this tender specification, issued by appropriate state or central Statutory Authority. Contractor shall submit the particulars of Licenses held by him.

5. The contractor has to arrange electrical license to work of the concerned state where the project being executed within a 6 weeks of mobilization at site for carrying out the works covered under this contract.

### 2.18 INSTALLATION OF PANELS (STARTER PANEL/ LOCAL STARTER BOX/ AC DC POWER DISTRIBUTION BOX/ MARSHALLING BOX/ CONTROL PANELS/ )

- 2.21.1 Electrical control panels, electronic control panels, 415-volt LT MCCs etc., are normally supplied in suite of either one/ two/ three or loose shipping sections with integral base frame or loose base frame. These panels may have to be installed as stand-alone or in-group consisting of number of panels in each row, depending upon the plant layout and foundation arrangement.
- 2.21.2 The panels shall be transported from stores to the place of installation in vertical position. Care shall be taken such that the switches, lamps, instruments etc. mounted on the panel do not get damaged during transit.
- 2.21.3 Installation of panel shall include fixing of base frame, levelling, alignment, fixing of anti-vibration pads, removal of side covers, fixing of cubical interconnection hardware, interconnection of bus bar/ bus bar jointing, wiring interconnection, welding and grouting of panels and base frames, mounting of panel canopy wherever supplied as part of panel, drilling of gland plates, sealing of panels/ cable entries. Where the base frame is not supplied as part of panel supply, the contractor shall fabricate the base frame from structural items at site. Payment for such fabrication will be effected on measured quantity at the rate applicable for structural steel fabrication and installation. Proper sealing of all the holes and cable entries (even if the cable has been laid by others) in the panel is in the contractor's scope.
- 2.21.4 Minor civil works like drilling, chipping, punching holes and opening in concrete floors, slabs and brick walls, grouting, related to Rack, support installation, minor civil works required for installation of control panels, Junction boxes etc., shall be included in the erection cost of such items. Also all miscellaneous civil works like chipping away and making good as necessary in floor slab/ wall for cabling/ earthing etc., as required are included in the scope for which no separate

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - II: Scope of Works

- payment is applicable. The scope also includes supply of grouting material, if any.
- 2.21.5 Panels have to be shifted to their locations through floor openings, temporary openings like floor grills, door etc. This shall be a part of work and no claim whatsoever will be entertained with regard to non-availability of opening as per shortest route etc. Panels have to be erected at different locations and elevation in depending on the detailed engineering.
- 2.21.6 Panel and instruments once erected in position should be properly protected using necessary care to prevent ingress of dust/ moisture and rainy water. This will have to be periodically cleaned and surroundings have to be kept tidy.
- 2.21.7 Whenever the panels are to be mounted on cable trenches, channel supports have to be provided across the cable trench over which the base frame of panel shall be mounted. For such work, structural steel fabrication & installation rate shall be applicable.
- 2.21.8 Normally the panels shall be supplied with instruments, relays, meters, electronic modules, contactors, push buttons, etc. mounted and pre-wired. However, if these are supplied loose/ separately for safety in transit, contractor shall mount and wire such devices as part of the panel installation work and no separate rates shall be applicable unless otherwise specially listed in the rate schedule.
- 2.21.9 Supplier's instruction manuals, packing slips, door keys etc. received along with the panels will be handed over to BHEL's engineer on opening of the panels and record of receipt of such things shall be maintained by contractor.
- 2.21.10 Regular cleaning of the panels as per the instruction of BHEL engineer till handing over of the set to customer is to be carried out by the contractor free of cost.
- 2.21.11 No separate payment shall be made for replacement of any devices like electronic modules, relays, conductors, terminal block, push buttons etc. which are found defective during pre-commissioning/ post-commissioning of any equipment/ item.
- 2.21.12. For the panels erected by other agencies, commissioning/ calibration work and troubleshooting has to be carried out by the contractor as part of testing and commissioning work as per the quoted rates.
- 2.21.13 Interposing Relays (24/ 48 Volt DC) along with mounting base if supplied shall be supplied separately for mounting in the various feeders of 11kV/ 3.3kV HT switchgear boards and 415 Volt MCC Board for unidirectional/ bi-directional drives, solenoid valves.
- 2.21.14 Wall mounted JB/ACDB/DCDB anchor fatteners should be in the scope the erection agency.
- 2.22A **SAFETY:**
- Deployment of HSE personnel(s) is mandatory requirement at site. Any dilution in deployment of HSE personnel(s) will attract penal deductions from the vendor's RA bills and in this regard decision of BHEL Site Construction Manager shall be final and binding on the contractor.
- 2.22B **Void**
- 2.23 **VOID**
- 2.24 **VOID**



# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter – III: Facilities in the scope of Contractor/BHEL

Sl. No	Description <b>PART I</b>	Scope / to be taken care by		Remarks
		BHEL	Bidder	
3.1	<b>ESTABLISHMENT</b>			
3.1.1	<b>FOR CONSTRUCTION PURPOSE:</b>			
a	Open space for office (as per availability)	Yes		<b>Free of Charge</b>
b	Open space for storage (as per availability)	Yes		<b>Free of Charge</b>
c	Construction of bidder's office, canteen and storage building including supply of materials and other services		Yes	
d	Bidder's all office equipments, office / store / canteen consumables		Yes	
e	Canteen facilities for the bidder's staff, supervisors and engineers etc		Yes	
f	Fire fighting equipments like buckets, extinguishers etc		Yes	
g	Fencing of storage area, office, canteen etc of the bidder		Yes	
3.1.2	<b>FOR LIVING PURPOSES OF THE BIDDER</b>			
a	Open space for labour colony (as per availability)		Yes	Contractor has to make his own arrangements shelter and transportation of labours as per their requirement
b	Labour Colony with internal roads, sanitation, complying with statutory requirements		Yes	
3.2.0	<b>ELECTRICITY</b>			
3.2.1	<b>Electricity For construction purposes only of Voltage 415/440 V</b>			
a	Single point source	Yes		<b>Chargeable basis</b> as per the tariff rate of GSECL/Madhya Gujarat Vij Company Limited (MGVCL) from time to time
b	Further distribution including all materials, Energy Meter, Protection devices and its service		Yes	<b>Minimum drawl power factor 0.8</b>
c	Duties and deposits including statutory clearances if applicable		Yes	
3.2.2	<b>Electricity for the office, stores, canteen etc of the bidder</b>			



# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter – III: Facilities in the scope of Contractor/BHEL

Sl. No	Description <b>PART I</b>	Scope / to be taken care by		Remarks
		BHEL	Bidder	
a	Single point source	Yes		<b>Chargeable basis</b> as per the tariff rate of GSECL/Madhya Gujarat Vij Company Limited (MGVCL) from time to time
b	Further distribution including all materials, Energy Meter, Protection devices and its service		Yes	
c	Duties and deposits including statutory clearances if applicable		Yes	
3.2.3	<b>Electricity for living accommodation of the bidder's staff, engineers, supervisors etc</b>			
a	Single point source		Yes	
b	Further distribution including all materials, Energy Meter, Protection devices and its service		Yes	
c	Duties and deposits including statutory clearances if applicable		Yes	
3.3.0	<b>WATER SUPPLY</b>			
3.3.1	<b>For construction purposes:</b>			Non chargeable basis
a	Making the water available at single point	<b>Yes</b>		
b	Further distribution as per the requirement of work including supply of materials and execution		Yes	
3.3.2	<b>Water supply for bidder's office, stores, canteen etc.</b>			
a	Making the water available at single point	<b>Yes</b>		
b	Further distribution as per the requirement of work including supply of materials and execution		Yes	
3.3.3	<b>Water supply for Living Purpose</b>			
a	Making the water available at single point		Yes	
b	Further distribution as per the requirement of work including supply of materials and execution		Yes	
3.4.0	<b>LIGHTING</b>			
a	For construction work (supply of all the necessary materials) 1. At office/storage area 2. At the preassembly area 3. At the construction site /area		Yes	

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter – III: Facilities in the scope of Contractor/BHEL

Sl. No	Description <b>PART I</b>	Scope / to be taken care by		Remarks
		BHEL	Bidder	
b	For construction work (execution of the lighting work/ arrangements) 1. At office/storage area 2. At the preassembly area 3 At the construction site /area		Yes	
c	Providing the necessary consumables like bulbs, switches, etc during the course of project work		Yes	
d	Lighting for the living purposes of the bidder at the colony / quarters		Yes	
3.5.0	<b>COMMUNICATION FACILITIES FOR SITE OPERATIONS OF THE BIDDER</b>			
a	Telephone, fax, internet, intranet, e-mail etc.		Yes	
3.6.0	<b>COMPRESSED AIR wherever required for the work</b>		YES	
3.7.0	<b>Demobilization of all the above facilities</b>		YES	
3.8.0	<b>TRANSPORTATION</b>			
a	For site personnel of the bidder		Yes	
b	For bidder's equipments and consumables (T&P, Consumables etc)		Yes	

Sl. No	Description <b>PART II</b>	Scope / to be taken care by		Remarks
		BHEL	Bidder	
<b>3.9.0</b>	<b>ERECTION FACILITIES</b>			
3.9.1	Engineering works for construction:			
A	Providing the erection drawings for all the equipments covered under this scope	Yes		
B	Drawings for construction methods	Yes	Yes	In consultation with BHEL
C	As-built drawings – where ever deviations observed and executed and also based on the decisions taken at site- example – routing of small bore pipes		YES	"
D	Shipping lists etc for reference and planning the activities	Yes		"
E	Preparation of site erection schedules and other input requirements		Yes	"
F	Review of performance and revision of site erection schedules in order to achieve the end dates and other commitments	Yes	Yes	"

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter – III: Facilities in the scope of Contractor/BHEL

Sl. No	Description  PART II	Scope / to be taken care by		Remarks
		BHEL	Bidder	
<b>3.9.0</b>	<b>ERECTION FACILITIES</b>			
G	Weekly erection schedules based on SL No. e		Yes	"
H	Daily erection / work plan based on SL No. g		Yes	"
I	Periodic visit of the senior official of the bidder to site to review the progress so that works are completed as per schedule. It is suggested this review by the senior official of the bidder should be done once in every two months.		Yes	
J	Preparation of preassembly bed		Yes	
K	Arranging the materials required for preassembly bed and rail.	Yes		

**Note:** Although the Electricity is free for construction, the same shall be used sparingly. Details of Electricity units consumed shall be submitted to BHEL office every month for records.

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter – IV: Tentative List of Major T&P and MME to be deployed by the Contractor

### **A: MAJOR TOOLS AND PLANTS & MMEs TO BE DEPLOYED BY THE CONTRACTOR**

SL. NO.	DESCRIPTION	QUANTITY
	TRANSFORMER OIL PURIFICATION PLANT WITH VACUUM PUMP FOR EVACUATION TRANSFORMER ALONGWITH ACCESSORIES & HOSES. A) CAPACITY 750 LTR. PER HOUR	APR
	PRIMARY INJECTION KIT UPTO 10000 AMPS WITH PAIR OF LEADS & CLAMPS FOR TESTING CTS	APR
	SECONDARY INJECTION KIT WITH INTEGRAL TIMER FOR RELAY TESTING WITH CABLES LEADS & BANNA PLUGS SELECTIVE RANGE 5 AMPS & 1 AMPS RANGE ( FOR RELAY TESTING)	APR
	CFB & ZFB KIT OR EQUIVALENT FOR TESTING OF RELAY & DISTANCE PROTECTION	APR
	PPM TESTER FOR TRANSFORMER OIL	APR
	METERS FOR TIME MEASUREMENT OF BREAKER OPENING & CLOSING TIME	APR
	3 PHASE VARIAC 15 Amps	APR
	SINGLE PHASE VARIAC 28 AMPS	APR
	TRANSFORMER TURNS RATIO TEST KIT	APR
	HV TEST KIT AC, 0 –20 KV &DC, 0- 100 KV PREFERSBLY WITH DRY TYPE TRANSFORMER	APR
	TRANSFORMER OIL BDV TEST KIT 0-100 KV WITH 2.5MM AIR GAP.	APR
	PORTABLE AIR COMPRESSOR WITH DRIER AND REGULATOR MAKE "TOSHNIWAL"/"KHOSLA" RATED FOR 7/10 KG/CM2	APR

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter – IV: Tentative List of Major T&P and MME to be deployed by the Contractor

SL. NO.	DESCRIPTION	QUANTITY
1.	SOLDERING IRON "SOLDRON" MAKE 25 WATT	APR
2.	VACUUM PUMP	APR
3.	MULTIMETRES	
4.	DIGITAL "MOTWANE" MAKE 3.1/2 DIGIT OR HIL MAKE ANALOG MOTWANE MAKE	APR
5.	DIGITAL 4.1/2 DIGIT Accuracy +/- 1% (HIL/MOTWANE/ Fluke make) STANDARD MILLI AMPS/MILLIVOLTS SOURCE MAKE RANGE 0 TO 60 mA AND 0 TO 100 mV	APR
6.	INSULATION TESTER MOTORISED OPERATED / ELECTRONIC WITH SELECTIVE RANGE OF 1000 / 2500/ 5000 VOLT. Range 0.5 Mega ohms to 10000 Mega ohms	APR
7.	INSULATION TESTER MAINS OPERATED/ ELECTRONIC 500 volt & 1000 Volts Range 0.5 Mega ohms to 1000 Mega ohms	APR
8.	VARIABLE DC POWER SUPPLY 0 TO 250 V DC, 10 A MAKE "APLAB" OR RQUIVALENT(VARIABLE SOURCE)	APR
9.	PHASE SEQUENCE INDICATOR	APR
10.	DIGITAL TONGUE TESTER A/C 5/10, 25/60/300 AMP RANGE AC KEW SNAP MAKE	APR
11.	DIGITAL TONGUE TESTER D/C 30/60/300 AMS	APR
12.	DIGITAL TONGUE TESTER 0-1 / 5 AMPS AC	APR
13.	STOP WATCH	APR
14.	CONTAINER FOR TRANSFORMER OIL SAMPLING	APR
15.	TARPOLIN FIRE PROOF	As Required
16.	INDUSTRIAL TYPE VACUUM CLEANER	APR
17.	MICRO OHM METER/DUCTER ( mV volt Drop Test Kit ) 0-200 A DC , 0-2000 Micro ohms with suitable calibrated cable leads for current injection & mv drop	APR
18.	CAPACITANCE METER HAVING RANGE 20 pf –100MFD +/- 1%	APR
19.	TELETALK 2 WIRE SYSTEM/MOBILE SYSTEM	APR
20.	PORTABLE BLOWER WITH HEATING ARRANGEMENT	APR
21.	TORQUE WRENCH (12-60Nm, 50-225 Nm)	APR

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter – IV: Tentative List of Major T&P and MME to be deployed by the Contractor

SL. NO.	DESCRIPTION	QUANTITY
22.	OIL SPECIFIC GRAVITY AND PPM MEASURING INSTRUMENT	APR
23.	RHEOSTAT	APR
24.	POLARITY TEST KIT	APR
25.	TEMPERATURE GUN DIGITAL TYPE	APR
26.	RELAY TESTING KIT	APR
27.	TWO WAY INTERCOM SET WITH 50 to 100 MTRS CABLES FOR CHECKING THE CABLES CONTINUITY	APR
28.	PROTECTIVE EARTH ROD SUITABLE FOR 220 / 400 KV SYSTEM HAVING LEAKAGE CURRENT METER, 70 SQMM CABLE & CLAMPS ANY REPUTED MAKE	APR
29.	OTHER PROTECTIVE DEVICES	AS REQUIRED

APR- As Per Requirement

### NOTE:

1. The list of instruments / equipments to be brought by the contractor as shown above sections are only indicative. any other instruments / equipments required for the execution of the work is to be necessarily arranged by the contractor within the quoted rates.
2. The testing/calibration instruments which are used to be duly calibrated in the interval prescribed by BHEL engineers from the reputed agencies decided by BHEL and test certificate to be furnished.
3. This above list is only indicative and neither exhaustive nor limiting. Contractor shall deploy all necessary T&P to meet the schedules & as prescribed by BHEL engineer and required for completion of work.

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter – V: TIME SCHEDULE

### 1.6.1 **TIME SCHEDULE :**

Sl. No	Unit	Tentative Shutdown Date
1	Unit-5	Aug-Sep 2024

**Note:** This is a Tentative Shutdown Schedule and is liable to change at GSECL Discretion

- 1.6.1.1 The entire work Transportation of materials from BHEL/ Customer storage to site of work and carrying out modifications as required, Erection, Testing and Commissioning of Electro-static Precipitator and ducts including Supply and Application of Final Painting for Unit-5 (210 MW) set at GSECL Wanakbori ESP R&M, as detailed in the Tender Specification shall be completed within **9 months** from the date of commencement of work at site.

#### 1.6.1.2 **Details of Time schedule:**

S No	Description	Duration in Days
1.	Pre-assy and preparatory works	15
2.	Replacement of ESP inlet and outlet gates during unit shutdown	10
3.	Shutdown of 02 passes (likely pass-AB) for R&M works	90
4.	Full unit shutdown (for inlet/outlet duct works and other integration etc. works)	35
5.	Shutdown of balance 02 passes (likely pass-CD)	90
6.	Closure & Completion of facilities etc.	30

- 1.6.1.3 During the total period of contract, the contractor has to carry out the activities in a phased manner as required by BHEL and the program of milestone events.

#### 1.6.1.4 **To complete the entire work during shutdown, the contractor shall carry out work round the clock (In shifts).**

- 1.6.1.5 The erection work shall commence on the mutually agreed date between the bidder and BHEL engineer.

- 1.6.1.6 **Site Mobilization** : Within 15 days from date of receipt of LOA.

### 1.6.2 **Liquidated Damage: (Clause no 2.7.9 of Vol-IC GCC has been amended as below)**

If the contractor fails to maintain the required progress of work which results in delay in the completion of the work/extension in shutdown of unit as per the contractual completion period, BHEL shall have the right to impose Liquidated Damage/Penalty at the **rate of 0.5 %** of the contract value, **per day** of delay or part thereof subject to a **maximum of 10%** of the contract value. For this purpose, the period of delay shall be the delay attributable to the Contractor for the completion of work as per contract. Contract Value for this purpose, shall be the final executed value exclusive of ORC, Extra Works executed on Man-day rate basis, Supplementary/Additional Items and PVC.

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter-VI: TERMS OF PAYMENT

### TERMS OF PAYMENT FOR ELECTRICAL WORKS

<b><u>TERMS OF PAYMENT FOR ELECTRICAL WORKS ( 90% )</u></b>		
<b>S. No.</b>	<b>Activity/ Work Description</b>	<b>%age of Unit Rate</b>
<b>E</b>	<b>PRO RATA PAYMENTS (90%)</b>	
<b>1.0</b>	<b>Cable tray and accessories</b>	
1.1	Fabrication and fixing/ welding/ bolting in position	75%
1.2	Earthing of cable trays	5%
1.3	Numbering of cable trays	5%
1.4	Covering of trays where ever envisaged	5%
	<b>Total =</b>	<b>90%</b>
<b>2.0</b>	<b>Cable laying including Earth wires</b>	
2.1	Laying of cables/ wires	65%
2.2	Glanding & Termination (Except HT Termination) & Testing	10%
2.3	Charging of cables	5%
2.4	Dressing and clamping of cables	10%
	<b>Total =</b>	<b>90%</b>
<b>3.0</b>	<b>Junction box/ Push button station (local)</b>	
3.1	Erection including fixing of terminal blocks where ever applicable	80%
3.2	Name plate fixing where ever applicable, Labelling (both inside and outside) and Commissioning of connected equipment	10%
	<b>Total =</b>	<b>90%</b>
<b>4.0</b>	<b>Miscellaneous Structural steel including frames for Panels/ Racks/ Instruments, supports for cable tray/ pipes/ tubes, Canopies etc.</b>	
4.1	Fabrication/Pre assembly/Erection, Alignment, welding/bolting and if applicable chipping/grouting/painting	90%
	<b>Total =</b>	<b>90%</b>
<b>5.0</b>	<b>DG sets/ Switch Gears/ MCC/ PCC/ Distribution Boards/ Marshalling Box/ Starter Units/ Dry Transformers/ Electrical Hoists/ Panels/ Cubicles/ Desks/ UPS/ Batteries/ Chargers/ VFD/ LA assy/ NGT/ NGR/ SP/ Miscellaneous Equipment/ etc.</b>	
5.1	Placement, Alignment and coupling/interconnection where ever applicable, erection of associated accessories etc.	50%
5.2	Pre-commissioning checks and tests	25%
5.3	Charging, Loop testing and commissioning	5%
5.4	Nomenclature/Name-plate/Painting etc	5%
5.5	System commissioning	5%
	<b>Total =</b>	<b>90%</b>
<b>6.0</b>	<b>Earthing/ Lightning protection strips, Earthing pits</b>	
6.1	Fabrication, erection, alignment, welding/ bolting of earthing/ lightning protection strips; earth pits completion	80%
6.2	Testing/commissioning/Connection to equipment	10%
	<b>Total =</b>	<b>90%</b>
<b>7.0</b>	<b>LT/ HT Bus Ducts</b>	



# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter-VI: TERMS OF PAYMENT

7.1	Pre assembly of Bus Ducts and accessories, erection, alignment, bolting/ welding etc. complete with supporting structure	70%
7.2	Pre commissioning checks	10%
7.3	Testing, Charging and Painting (as applicable)	10%
	<b>Total =</b>	<b>90%</b>
<b>8.0</b>	<b>Oil Filled Transformers (Generator, Station, UAT, Station Service etc.)</b>	
8.1	Placement on foundation and alignment	25%
8.2	Erection of associated auxiliaries/ assemblies, oil filling, etc.	30%
8.3	Dry out including oil filtration	20%
8.4	Pre-commissioning checks/Testing	10%
8.5	Charging and Painting (as applicable)	5%
	<b>Total =</b>	<b>90%</b>
<b>9.0</b>	<b>Testing/ Commissioning of Equipment (like motors, actuators, ESP transformer, misc. equipment, etc.) erected by other agencies</b>	
9.1	Testing & pre-commissioning checks	70%
9.2	System commissioning	20%
	<b>Total =</b>	<b>90%</b>
<b>10.0</b>	<b>HT termination/Straight through jointing kits</b>	
10.1	Kit termination	65%
10.2	Testing	15%
10.3	Charging	10%
10.4	Termination, HT Termination, Straight through jointing etc. : on pro rata basis	<b>90%</b>

**Note:** Payment shall be made on actual basis as per the work executed at site measured and certified by BHEL engineer.

### 2.0

<b>II</b>	<b>STAGE/ MILESTONE PAYMENTS (10%)</b>	
1	Punch List points/ pending points liquidation	3%
2	Area cleaning, temporary structures cutting/ removal and return of scrap	5%
3	Completion of Contractual Obligation	1%
4	Material Reconciliation	1%
	<b>Total for Stage/ Milestone Payments (10%)</b>	<b>10%</b>

**Note:** Payment shall be made on actual basis as per the work executed at site measured and certified by BHEL engineer.

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - VII: TAXES AND DUTIES

### 7.0 TAXES, DUTIES, LEVIES (Rev 14 dated 09/10/2020)

1. All taxes excluding GST, GST Cess & BOCW Cess **but including, Royalties, fees, license, deposits, commission, any State or Central Levy and other charges whatsoever, if any, shall be borne by you and shall not be payable extra.**
2. Any increase of the taxes excluding GST, GST Cess & BOCW Cess, at any stage during execution including extension of the contract shall have to be borne by the contractor. Quoted/ accepted rates/ price shall be inclusive of all such requirements. Please note that since GST on output will be paid by BHEL separately as enumerated below, your quoted rates/ price should be after considering the Input Credit under GST law at your end.
3. **GST :**  
The successful bidder shall furnish proof of GST registration .GST along with Cess (as applicable) legally leviable & payable by the successful bidder as per GST Law, shall be paid by BHEL. Hence Bidder shall not include GST along with Cess (as applicable) in their quoted price.
4. GST charged in the Tax Invoice/Debit note by the contractor shall be released separately to the contractor only after contractor files the outward supply details in GSTR-1 on GSTN portal and input tax credit of such invoice is matched with corresponding details of outward supply of the contractor and has paid the GST at the time of filing the monthly return
5. E-invoicing under GST has been implemented with effect from 1st October 2020 for all the taxable persons having turnover more than the threshold limit in any preceding financial year from 2017-18 onwards. Therefore, for all the taxable persons falling under the purview of E-invoice, it is mandatory to mention a valid unique Invoice Reference No. (IRN) and QR code as generated from E-Invoicing portal of the Government for the purpose of issuing a valid Tax Invoice. Only an E-invoice issued in the manner prescribed under rule 48(4) of CGST Rules shall be treated as valid invoice for reimbursement of GST amount.  
If the successful Bidder is not falling under the purview of E-Invoicing then he has to submit a declaration in that respect along with relevant financial statements.
6. Bidder shall note that the GST Tax Invoice complying with GST Invoice Rules (Section 31 of GST Act & Rules referred there under) wherein the 'Bill To' details will as below:  
BHEL GSTN – As per **Annexure -1**  
NAME -- Bharat Heavy Electricals Limited  
ADDRESS – Site address
7. Bidder to immediately intimate on the day of removal of Goods (in case of any supply of goods) to BHEL along with all relevant details and a scanned copy of Tax Invoice to below email ids to enable BHEL to meet its GST related compliances :-  
Email id ---- to be intimated later on.  
In case of delay in submission of the abovementioned documents on the date of dispatch, BHEL may incur penalty /interest for not adhering to Invoicing Rules under GST Law. The same will be liable to be recovered from the successful bidder, if such delay is not attributable to BHEL.
8. In case of raising any Supplementary Tax Invoice (Debit / Credit Note) Bidder shall issue the same containing all the details as referred to in Section 34 read with Rule 53.
9. Bidder shall note that in case GST credit is delayed/ denied to BHEL due to delayed / non receipt of goods and /or tax invoice or expiry of the timeline prescribed in GST Law for availing such ITC, or any other reasons not attributable to BHEL, GST amount shall be recoverable from the vendor along with interest levied / leviable on BHEL, as the case may be.
10. Bidder shall upload the Invoices raised on BHEL in GSTR-1 within the prescribed time as given in the GST Act. Bidder shall note that in case of delay in declaring such invoice in your return and GST credit availed by BHEL is denied or reversed subsequently as per GST Law , GST

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - VII: TAXES AND DUTIES

amount paid by BHEL towards such ITC reversal as per GST law shall be recoverable from the bidder along with interest levied / leviable on BHEL.

11. Way Bill: Successful Bidder to arrange for way bill / e-waybill for any transfer of goods for the execution of the contract.

The Bidder has to make their own arrangement at their cost for completing the formalities, if required, with Issuing Authorities, for bringing materials, plants & machinery at site for execution of the works under this contract, Road Permit/ Way Bill, if required, shall be arranged by the contractor and BHEL will not supply any Road Permit/ Way Bill for this purpose.

12. **New taxes and duties:-**Any New taxes & duties, if imposed subsequent to due date of offer submission as per NIT & TCN, by statutory authority during contract period including extension, if the same is not attributable to you, shall be reimbursed by BHEL on production of relevant supporting document to the satisfaction of BHEL. However, you shall obtain prior approval from BHEL before depositing new taxes and duties.

Benefits and/or abolition of all existing taxes must be passed on to BHEL against new Taxes, if any, proposed to be introduced at a later date.

In case any new tax/levy/duty etc. becomes applicable after the date of bidder's offer but before opening of the price bid, the bidder must convey its impact on his price duly substantiated by documentary evidence in support of the same before opening of the price bids. Claim for any such impact after opening the price bid will not be considered by BHEL for reimbursement of tax or reassessment of offer.

13. For transportation work, bidder shall declare in his quotation whether he is registered under GST, if yes, whether he intends to claim GST on forward charge basis. In absence of this declaration, BHEL will proceed further with the assumption that bidder intends not to claim GST on forward charge basis. However, in case of GST registered transporter, the amount to the extent of goods and service tax will be retained till BHEL avails the credit of GST. Further, transporter shall issue tax invoice which inter alia includes gross weight of the consignment, name of the consigner and the consignee, registration number of vehicle in which the goods are transported, details of goods transported, details of place of origin and destination, GSTIN of the person liable for paying tax whether as consigner, consignee or goods transport agency, and also containing other information as mentioned under rule 46.
14. **TDS under Income Tax shall be deducted at prevailing rates on gross invoice value from the running bills unless exemption certificate from the appropriate authority/ authorities is furnished.**
15. **TDS under GST shall be deducted at prevailing rates on applicable value from the running bills.**
16. **TCS under Income Tax 1961 has been implemented with effect from 1<sup>st</sup> October 2020 for every seller having turnover more than threshold limit during financial year immediately preceding financial year in which the sale of goods is carried out, who receives any amount as consideration for sale of any goods of the value or aggregate of such value exceeding threshold limit other than export of goods or who is already covered under other provision of section 206C, collect from the buyer, TCS as per applicable rates of the sale consideration exceeding threshold limit subject to following conditions**
  - i. Buyer shall be as per clause (a) of section 206C- (1H)
  - ii. Seller shall be as per clause (b) of section 206C- (1H)

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - VII: TAXES AND DUTIES

- iii. No TCS is to be collected, if the seller is liable to collect TCS under other provision of section 206C or the buyer is liable to deduct TDS under any provision of the Act and has deducted such amount.

**If Successful Bidder is falling under the purview of TCS then he has to submit a declaration in that respect along with relevant financial statements before the start of work or if bidder is falling under preview of TCS during the work in progress then bidder is compulsorily required to submit relevant financial statement in the beginning of the respective FY.**

**For TCS claim, vendor has to submit relevant documents required as per Income Tax Act.**

17. Refer Annexure – 2 for BOCW Act & Cess Act.

### ANNEXURE-1

#### State wise GSTIN no.s of BHEL

Sl. No	Projects under state	GSTIN
1	Andhra Pradesh	37AAACB4146P7Z8
2	Bihar	10AAACB4146P1ZU
3	Chhattisgarh	22AAACB4146P1ZP
4	Gujarat	24AAACB4146P1ZL
5	Jharkhand	20AAACB4146P5ZP
6	Madhya Pradesh	23AAACB4146P1ZN
7	Maharashtra	27AAACB4146P1ZF
8	Orissa	21AAACB4146P1ZR
9	Telangana	36AAACB4146P1ZG

### ANNEXURE-2

#### BOCW Act & Cess Act

Bidder may please note that the sub-contractor/bidder of BHEL engaging building or construction worker in connection with building or other construction work, are required to follow the procedures enumerated below:

1. It shall be the sole responsibility of the contractor as employer to ensure compliance of all the statutory obligations under the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 and the Building and other Construction Workers' Welfare Cess Act, 1996 and the rules made thereunder.
2. It shall be sole responsibility of the contractor engaging Building Workers in connection with the building or other construction works in the capacity of employer to apply and obtain registration certificate specifying the scope of work under the relevant provisions of the Building and Other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 from the appropriate Authorities.
3. It shall be responsibility of the contractor to furnish a copy of such Registration Certificate within a period of one month from the date of commencement of Work.
4. It is responsibility of the contractor to register under the Building and other Construction Workers' Welfare Cess Act, 1996 and deposit the required Cess for the purposes of the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 at such rate as the Central Government may , by notification in the Official Gazette, from time to time specify. However, before registering and deposit of Cess under the Building and other

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - VII: TAXES AND DUTIES

Construction Workers' Welfare Cess Act, 1996, the contractor will seek written prior approval from the Construction Manager.

5. It shall be sole responsibility of the contractor as employer to get registered every Building Worker, who is between the age of 18 to 60 years of age and who has been engaged in any building or other construction work for not less than ninety days during the preceding twelve months as Beneficiary under the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996.
6. It shall be sole responsibility of the contractor as employer to maintain all the registers, records, notices and submit returns under the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 and the Building and other Construction Workers' Welfare Cess Act, 1996 and the rules made thereunder.
7. It shall be sole responsibility of the contractor as employer to provide notice of poisoning or occupation notifiable diseases, to report of accident and dangerous occurrences to the concerned authorities under the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 and the rules made thereunder and to make payment of all statutory payments & compensation under the Employees' Compensation Act, 1923.
8. It shall be the responsibility of the sub-contractor as employer to make payment/deposit of applicable cess amount on the extent of work involving building or construction workers engaged by the sub-contractor within a period of one month from the receipt of payment. It shall also be responsibility of the Contractor to furnish BHEL on monthly basis, Receipts/ Challans towards Deposit of the Cess under the Building and other Construction Workers' Welfare Cess Act, 1996 and the rules made thereunder along with following statistics :
  - (i) Number of Building Workers employed during preceding one month.
  - (ii) Number of Building workers registered as Beneficiary during preceding one month.
  - (iii) Disbursement of Wages made to the Building Workers for preceding wage month.
  - (iv) Remittance of Contribution of Beneficiaries made during the preceding month
9. BHEL shall reimburse the contractor the Cess amount deposited for the purposes of the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 under the Building and other Construction Workers' Welfare Cess Act, 1996 and the rules made thereunder. However, BHEL shall not reimburse the Fee paid towards the registration of establishment, fees paid towards registration of Beneficiaries and Contribution of Beneficiaries remitted.
10. It shall be responsibility of the Building Worker engaged by the Contractor and registered as a beneficiary under the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 to contribute to the Fund at such rate per mensem as may be specified by the State government by notification in the Official Gazette. Where such beneficiary authorizes the contractor being his employer to deduct his contribution from his monthly wages and to remit the same, the contractor shall remit such contribution to the Building and other construction Workers' Welfare Board in such manner as may be directed by the Board , within the fifteen days from such deduction.
11. Bidders may please note that though the quoted price is exclusive of BOCW (which will be reimbursed by BHEL as per sub-clause 9 above) , however, If at any point of time during the contract period, non-compliance of the provisions of the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 and the Building and other Construction Workers' Welfare Cess Act, 1996 and the rules made thereunder is observed, BHEL reserves the right to deduct the applicable cess (1%) on the contract value and penalty ( if any, imposed by Cess Authorities) from the payables on account of non-compliance.
12. The contractor shall declare to undertake any liability or claim arising out of employment of building workers and shall indemnify BHEL from all consequences / liabilities / penalties in case

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - VII: TAXES AND DUTIES

---

of non-compliance of the provisions of the Building and other Construction Workers' (Regulation of Employment and Conditions of Service) Act, 1996 and the Building and other Construction Workers' Welfare Cess Act, 1996 and the rules made thereunder.

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - VIII: SPECIFIC EXCLUSIONS

### 8.0 SPECIFIC INCLUSIONS

#### 8.0.1 SPECIFIC INCLUSIONS

##### Consumables/items to be provided by BHEL free of charge

- 01 Metallic Cable glands
- 02 Steel for fabrication
- 03 Lugs beyond 4 sq.mm size

##### Consumables/items to be arranged by Bidder

- 01 Cable ferruling numbers and characters
- 02 Name plates/Tag plates with tying/fixing material for cable's at both end  
& field instruments
- 03 Cable Markers.

#### 8.0.2 SPECIFIC INCLUSIONS ELECTRICAL

Sl. No	Description	Scope / to be taken care by		Remarks
		BHEL	Bidder	
1	Lugs up to 4 sq mm size	-	Yes	
2	Lugs beyond 4 Sq. mm size	Yes		For GI wire earthing
3	Paint, primer and consumables		Yes	
4	LT cable straight through jointing Kits		Yes	
5	Trefoil Clamps with hardware	Yes	-	For single core LT cable
6	Identification tags PVC /Metals, sleeve and clamps with hardware. PVC ties, Ferrule, Buttons and tap		Yes	



# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - IX: BILL OF QUANTITY & Weightages/ Factor

SL. NO.	DESCRIPTION	Total Qty	FACTOR COMPONENT
<b>SECTION-E1 : CABLE TRAYS AND ACCESSORIES</b>			
E1.1	Ladder type 300(W)	688	0.008292868951435
E1.2	Ladder type 150(W)	318	0.003676684526790
E1.4	Ladder type 450(W)	75	0.001423362522829
<b>SECTION-E2: CABLES</b>			
<b>SECTION-E2B : CABLE LAYING, GLANDING, TERMINATION, FERRULING, CLAMPING &amp; DRESSING OF LT POWER &amp; CONTROL CABLES</b>			
E2B.1	1CX1000 Sq. mm Al	5900	0.061021962971788
E2B.2	2CX120 Sq. mm Al	12000	0.044881449857837
E2B.3	3C X 10 sq.mm Al	6500	0.015914896372855
E2B.4	3C X 35 sq.mm Al	1800	0.007700741303344
E2B.5	3C X 2.5 sq.mm Cu	35200	0.061623297488609
E2B.6	2C X 2.5 sq.mm Cu	6300	0.010042503519185
E2B.7	3C X 240 SQMM Al	500	0.006141272186359
E2B.8	3.5C X 50 SQMM Al	1300	0.007458532815651
E2B.9	12C X 2.5 sq.mm Cu	13700	0.039768090645178
E2B.10	4CX 1.5 sq.mm Screened Cable	8800	0.011721526249494
<b>SECTION-E3 : JUCTION BOXES AND PUSH BUTTON</b>			
E3.1	Junction Boxes 250X150X400 mm approx.	40	0.004472142478786
E3.2	Start Stop Push Button Station 180X100X250 mm approx.	60	0.005021437835255
E3.4	Junction Boxes for Hopper, Support & Shaft Heaters & APL 400X150X315 mm approx.	40	0.004677632035695
<b>SECTION-E4 : STRUCTURAL STEEL</b>			
E.4.1	Structural Steel fabrication & installation ( ISA, ISMC, Plate etc)	21	0.048758068807687
<b>SECTION-E5 : DG SETS/SWITCH GEARS/MCC/PCC/DISTRIBUTION BOARDS/MARSHALLING BOX/STARTER UNITS/ DRY TRANSFORMERS / ELECTRICAL HOISTS/ PANELS/CUBICLES/DESKS/UPS/ BATTERIES/ CHARGERS/VFD/ DAVR/LA ASSY/ NGT/ NGR/ SP/MISCELLANEOUS EQUIPMENTS/ ETC</b>			
<b>SECTION-E5A: STARTER PANEL/BOXES/POWER DISTRIBUTION BOX/MARSHALLING BOXES</b>			
E5A.1	Electronic Control Panel, Overall Dimensions Approx. 600 L x 550 W x 2000 H mm, Approx. Weight of each panel 0.3 MT. ARECA Controller approx dimension 280x210x210 mm, rotary switches, etc along with cables and connectors, shall be supplied loose for mounting in the panel at site	28	0.031341945775606
E5A.2	Auxillary Control Panel ,approx weight approx 4000kg/panel , supplied in loose shipping section	2	0.024243063102200
E5A.3	IOS PANEL overall dimension approx.1000x500x2050 mm,approx along with loose accessories such as IOS PC, Computer Furniture, Data Logger PC, Printer -1 Nos. PC termination box, peripheral cables etc.	1	0.002386904171627



# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - IX: BILL OF QUANTITY & Weightages/ Factor

E5A.4	RCU (DDM) PANEL overall dimension approx.1000x500x2050 mm,approx weight 200 kg/panel along with loose accessories such as IOS PC with colour monitor- 3 Nos, Computer Furniture, Data Logger PC with colour monitor- 3 Nos , Printer-3 Nos. ,PC termination box, peripheral cables etc.	1	0.001544860626828
<b>SECTION-E5B : MISCELLANEOUS EQUIPMENT</b>			
E5B.1	Ash Level Indicator comprising of level probe with extension lagging pipe, Electronic Unit, Interconnecting Cabling, Conduit, etc.( Dimesion 900X100X100 mm approx)	48	0.011925514796056
E5B.2	Opacity Monitor (dust density monitor) consisting of Transmitter & Receiver, Electronic Unit, Air Blower unit, Weather Proof housings, Junction boxes, flexible hoses, mounting flanges with pipe for Transmitter, Receiver & Air blower, interconnected cables etc. for mounting on ESP outlet duct.	8	0.020881696191001
<b>SECTION-E5C :ILLUMINATION WORK.</b>			
<b>E5C.1</b>	<b>Lighting Distribution Board (LDB)</b>		
E5C.1.1	AC LDB Type LDB-H (12)		
E5C.1.2	AC LDB Type LDB-H (12) without transformer (including cubicle suitable for 2 nos. 100 kVA transformer)	1	0.001791510120339
E5C.1.3	100kVA transformer for housing in 1.1.1 - Normal Non encapsulated type	2	0.003996601312513
E5C.1.4	AC LDB Type LDB-F (8) without transformer (including cubicle suitable for 2 nos. 50 kVA transformer)	1	0.001796208530824
E5C.1.5	50kVA transformer for housing in 1.2 - Normal encapsulated type	2	0.003561249388136
E5C.1.6	AC WDB Type WDB-H (12)	1	0.001969764402742
E5C.1.7	100kVA transformer for housing in AC WDB	2	0.004049741420537
<b>E5C.2</b>	<b>Lighting Panels (LP)</b>		
E5C.2.1	AC Normal /Emergency indoor Type LP – A (12) [with timer]	1	0.000407057569224
E5C.2.2	AC Normal /Emergency indoor Type LP – A (18) [with timer] Decorative	2	0.000882485539469
E5C.2.3	AC Normal /Emergency outdoor Type LP – A (18) [with timer]	4	0.001796157360017
<b>E5C.3</b>	<b>Lighting Luminaires (complete with accessories)</b>		
E5C.3.1	Industrial type LED tube fixture 2X20W suitable for conduit/surface/suspended mounting, with integral driver aesthetically designed for switchgear/ equipment room (Equivalent to FC02)	50	0.004055519069865
E5C.3.2	Panel (600X600) LED luminaire 36W suitable for recess mounting in false ceiling with integral driver aesthetically designed for control room/office (Equivalent to FC30)	28	0.002250076534277
E5C.3.3	Street Light LED Fixture SS62 (100W)	8	0.001109159810583
E5C.3.4	Well glass type, Vapour proof LED fixture 45W suitable for platforms SW41 (For Platform Lighting)	416	0.048522876147795

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - IX: BILL OF QUANTITY & Weightages/ Factor

E5C.3.5	Well glass type, vapour proof LED fixture 72W suitable for platforms (For Platform Lighting) SW42	190	0.024347969459603
<b>E5D.4</b>	<b>Switch boxes for individual control of circuits (Switchboards consisting of switch boxes, switches, switch plates and fixing accessories.)</b>		
E5C.4.1	Type SWB1	5	0.000275376474580
E5C.4.2	Type SWB2	2	0.000104186864841
E5C.4.3	Type SWB3	2	0.000099398517786
E5C.4.4	Type SWB4	5	0.000228562939091
<b>E5D.5</b>	<b>Junction boxes</b>		
E5C.5.1	Type JB-F (equal to nos of light fixture)	709	0.041810069462006
<b>E5C.6</b>	<b>Receptacles</b>		
E5C.6.1	Type RA (electrical room, pump house etc)	17	0.001372734436253
E5C.6.2	Type RB (Control room)	8	0.000784321323580
E5C.6.3	Type RC (welding receptacle)	8	0.000890992298518
<b>E5C.7</b>	<b>Ceiling fans with electronic regulators</b>		
E5C.7.1	Celing fans 1200 mm sweep	5	0.000341937289780
E5C.7.2	Pedastal fans	5	0.000460358942822
E5C.7.3	Emergency lighting Units (With Ni-Cd battery, Charger and 2 CFL lamp)	5	0.000905800820013
<b>E5C.8</b>	<b>Wires</b>		
E5C.8.1	1x1.5 mm <sup>2</sup> Cu PVC	18600	0.017103144542633
E5C.8.2	1x 4 mm <sup>2</sup> Cu PVC	6600	0.007624450281612
E5C.8.3	14 SWG GI wire	3500	0.005666003931058
<b>E5C.9</b>	<b>Hot dip Galvanised Rigid Steel Conduits (Heavy Duty)</b>		
E5C.9.1	20 mm dia GI conduit, 1.6 mm thick	4500	0.064217037164439
E5C.9.2	25 mm dia GI conduit, 1.6 mm thick	3250	0.049755469249270
E5C.9.3	40 mm dia GI conduit, 1.6 mm thick	3300	0.097546909878102
E5C.9.4	50mm dia GI conduit 2.0 mm thick	100	0.002681970552588
<b>E5C.10</b>	<b>Conduit/Hoses/Pipes/Poles</b>		
E5C.10.1	20 mm dia LEAD coated conduit	1038	0.018054372634448
E5C.10.2	Fabrication of J poles	20	0.000859204372797
<b>E5D</b>	<b>LT Switchgear</b>		
E5D.1	415V LT MCC for ESPSG Panel, approx Total Weight 11600KG	1	0.018482695550665
<b>SECTION-E 6 : EQUIPMENT EARTHING MATERIALS</b>			
E6.1	50 x 6 mm GI earthing flat	1540	0.025224137730321
E6.2	30 x 5 mm GI earthing flat	900	0.007150887719887
E6.3	GI earthing wire 8 SWG	66	0.000126856307772
<b>SECTION-E 8 : ONLY TESTING &amp; COMMISSIONING</b>			
E8.1	Heating elements for Hopper Heater of ESP	672	0.039371823913763
E8.2	Heating elements for Support Insulator Heater & Shaft Insulator Heaters of ESP	140	0.007542732053050
E8.3	High Voltage Rectifier Transformers (95 KV peak, 1000 mA) including oil filtration .	28	0.030440334759266

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - IX: BILL OF QUANTITY & Weightages/ Factor

E8.4	Testing & Commissioning of Collecting, Emitting, GD Screen Motor	60	0.014899450468560
E8.5	Thermostats for Hopper & Support Insulator	32	0.001610819797385
E8.6	Electrically (LT) Operated Valves, Dampers and Gates with Actuators, Limit Switches, etc. (Regulating & ON/OFF Type).	12	0.005819367492305
E8.7	Electrical Operated Hoist 3T at various area like ESP, Mill, IDF, PAF, FDF, Vacuum Pumps, BFP, CW & ACW area	2	0.000882882500883
<b>SECTION-E 9 : OTHER ITEMS</b>			
E9.1	Wall/floor mounted ACDB/DCDB	4	0.000213224101957
E9.2	Exit Sign	4	0.000562568753746
E9.3	Fire proof sealing materials (mortar seal) for ESP Control & Switchgear Room	15	0.001433084976208

# TECHNICAL CONDITIONS OF CONTRACT (TCC)

## Chapter - X: Instruction to Bidders

### Instructions to the bidders

1. **Bidders shall quote Total Lump-sum Price for the entire scope of work in Rupees in VOL II PRICE BID at BHEL E-procurement Portal.** Any other entry elsewhere in the offer of the bidder shall be treated as Null and Void. The total value including value of St No. A shall be automatically calculated on E-portal
2. This **Quoted** Lump-sum Price shall be distributed based on the BHEL fixed percentage weightages as per Chapter IX BILL OF QUANTITY & Weightages/ Factor w.r.t the total Total Lump-sum Price quoted by the bidder for the subject tender.
3. BHEL has pre-fixed the Weightage/Factor as detailed in Chapter IX BILL OF QUANTITY & Weightages/ Factor for deriving the Item Rates. By multiplying BHEL pre-fixed the Weightages / Factor and the total prices derived in sl no. 2 above; item rate of individual items shall be derived. Item Rate/Item Rate thus arrived shall be rounded off to two decimal places.
4. Item Rates derived in Sl. no. 4 shall be divided by quantity of respective items to derive Unit Rates. Unit Rates thus derived shall be rounded off to two decimal places
5. **Grand Total amount for the work shall be derived by BHEL by summing up respective total amounts.**
6. **Bidders to note that this is an item rate contract. Payment shall be made for the actual quantities of work executed at the unit rate arrived at as per Sl No.4 above.**
7. For the convenience of bidders, BHEL has issued an excel sheet with all the requisite formulae as described above. ***However the referred excel sheet shall not form part of contract document. Further, this sheet should not be uploaded at the e-Portal.***