

Domain :	bhel.abcpurchase.com	
Parent department:	TBG Noida	
Event ID	: 28697	RFQ/NIT/Enquiry no. : 159E027
Description	: Supply of 765kv and 420kv isolators in UPPTCL 765/400KV Extension at Bara TPS	
Corrigendum / Amendment No :1 (Published) (04/06/2019 13:03:28)		
Types of corrigendum :	1) Dates 2) Others	
Corrigendum Text :	Please note below clarification and due date extension: 1. Operating rod insulators for 765kV Disconnectors are in the scope of bidder. 2. Inter pole cabling for 765kV & 400kV disconnectors are not in the scope of bidder. Due date has been extended till 11.06.19.	
Field name	Old value	New value
Document downloading end date	04/06/2019 14:00:00	11/06/2019 14:00:00
Bid submission end date	04/06/2019 14:00:00	11/06/2019 14:00:00
Bid opening date	04/06/2019 14:30:00	11/06/2019 14:30:00