

Bharat Heavy Electricals Limited (A Govt. of India Undertaking)

Piping Centre, 80, G. N. Chetty Road, CHENNAI - 600 017

Phone: 91 (044) 28161245, Fax 044 28161 341 e-mail: prs@bhelmpc.co.in

REF: ENQ NO:37

DT: 15.03.2010

Sub: Procurement of fabricated Tees.

Ref: Enquiry No:PC:4101000037 dt 12.03.2010

Please find the following tender documents for reference.

1. List of items and sample drawings

2. Tech. delivery condition TDG: 108:04.

Pre qualification is the criteria for consideration for other than BHEL approved vendors. After qualifying for registration, the new vendors may be considered for future requirements, in line with BHEL system and policy. Such vendors will not be considered for this enquiry.

This is a limited tender and only vendors who are contacted through e-mail/courier may submit their offers.

New vendors may download vendor registration forms from BHEL web site www.bhel.com and relevant data for formal registration.

Dy Manager / Purchase BHEL / Piping Centre 80,GN Road, T.Nagar Chennai-600017

Ph: 044-28161245

Enquiry No:4101000037 dt 12.03.2010

Annexure - List of items

Enquir	Enquiry No:4101000037 dt 12.03.2010	7 dt 12.03.2010	Annexure - List of items Delivery required : 4 months from LOI/PO date	Tender Du: 4 months	Tender Due Date:29.03.2010 4 months from LOI/PO date	03.2010 O date
SI no	MATLCODE	Drawing No	DESCRI	Eng Qty Nos	CUR	Unit rate
1	925058510000	925058510000 3-80-999-97760/01	FABUNEQTEEOD355.6X29/OD273X25SA182F91	28		
2	925058530000	2 925058530000 3-80-999-97768/00	FABUNEQTEE OD 323.9 X31/219.1X36SA182F91	26		
3	925058540000	3 925058540000 3-80-999-97778/00	FABUNEQTEE OD 355.6X29/OD168.3X27.5 SA182F91	14		
4	925058270000	925058270000 3-80-423-26100/01	FABUNEQTEE OD 406.4X54/OD 273X36 SA105	8		
				71		



Bharat Heavy Electricals Limited, Piping Centre, Chennai Technical Delivery Conditions for Fabricated Tees and Y-pieces (Imported)

TDG:108 Rev 05 01.03.2010 Page 1 of 5

1.0 GENERAL

Fabricated Tees and Y-piece shall meet Indian Boiler Regulations (IBR) and the following requirements in addition to the latest version of relevant material specifications namely ASME SA 105, SA 106, SA 182, SA 335.

- 2.0 FORGINGS.
- 2.1 Material: SA 105, SA 182 F11, F12, F22, F91.
- 2.2 Carbon content of SA105 items shall be restricted to 0.25% maximum.
- 2.3 SA 182 F91 forgings shall be normalised at 1040 to1070 deg C (for wall thickness larger than 75 mm, accelerated cooling may be done to obtain a fully martensitic structure) and tempered at 760 ± 10 deg C
- 2.4 Unless otherwise specified in the P.O, items of SA182 F11/12 shall be supplied as per class 2 and SA182 F22 shall be supplied as per class 3 only
- 2.5 Product analysis shall be carried out on One piece / Heat / HT lot / Size.
- 2.6 Tension test shall be carried out on one Test piece for each specification, heat, heat treatment lot and size.
- 2.7 Bend test for CS (SA 105): One sample of 19 mm thick and 25mm width to be bent 180 deg around mandrel of radius 6.35mm.
- 2.8 Bend test for AS (SA182):One Sample of 25.4 mm width and thickness = t to be bent180deg around mandrel of radius =1.5 t. Test on representative sample is also acceptable.
- 2.9 Hardness test shall be carried out on all items of F91, and minimum 10% for other material Grades; acceptance norm shall be as per SA 105 / SA 182.
- 2.10 All fittings shall be tested by MT as per ASTM E-709 and acceptance norm shall be as per ASME B 31.1 Clause 136.4.3
- 2.11 Forgings of all thickness shall be ultrasonically tested as per SA 388 and acceptance norms shall be as per 3.3.4 of ASME Section VIII Division 2.
- 2.12 Metallography:- Metallography shall be carried out on one per heat, per size, per heat treatment lot of WP91 / F91 fittings. Acceptance norms The Material shall be free from any micro fissures. Microstructure shall show tempered martensite and also to be examined for any grain growth. Photomicrograph with 500x (Min) magnification along with Metallography report to be provided. The actual magnification shall be indicated.
- 3.0 PIPES.

3.1 Material: SA 106 Gr.C, SA 335 P11, P12, P22, P91.

Approved by

S. Jayakumar, Engg//////// K. Vedaprasad, QC

P. Elangovan, QA K. Ganeshan, MPL



Bharat Heavy Electricals Limited, Piping Centre, Chennal Technical Delivery Conditions for Fabricated Tees and Y-pieces (Imported)

TDG:108 Rev 05 01.03.2010 Page 2 of 5

The pipes used shall meet the requirements indicated in Technical delivery condition ref. TDG: 101. The applicable / latest revision number of this document is indicated in the Tender / Purchase order.

4.0 FABRICATION OF Y Piece and Tees

- 4.1 Fit up, fabrication, dimension and tolerance shall be as per BHEL drawing
- 4.2 Welding: WPS and PQR shall be approved by well known independent inspecting agencies like Lloyds, BV, SGS, Copy of approved WPS & PQR shall be furnished along with the Technical part of the bid for approval by BHEL
- 4.2.1 Welding of F91 / P91 material:

GTAW rods (ER 90S - B9) and SMAW electrodes (E9015 - B9) used shall be of following makes.

- a) Bohler Schweisstechnik Austria, Austria
- b) Bohler Thyssen Schweisstechnik, Germany
- c) Kobe Steels Ltd., Japan
- d) Oerlikon Welding Ltd, Switzerland
- e) Metrode Products, U.K.

The core wire chemistry shall be equivalent to F91/ P91. Synthetic electrodes are not permitted.

PWHT for F91 / P91 material shall be 760 ± 10 deg C. Holding time shall be minimum 2 hours for thickness up to 50mm; minimum 4 hours for thickness 51 to 100 mm. PWHT for other material shall be as per ASME B31.1.

5.0 NON DESTRUCTIVE EXAMINATION

- 5.1 All NDE shall be done after PWHT only and witnessed by Inspection authorities.
- 5.2 NDE procedures (MT-Wet, PT,RT,UT and Hardness)shall be approved by BHEL
- All welds shall be subjected to RT, Wet MT and PT as per ASME Sec V. Evaluation and acceptance norms shall be as per ASME B31.1 Clause 136.4.5 for RT, Clause 136.4.3 for MT, Clause 136.4.4 for PT. Hardness shall be as per SA 234.
- 5.4 All welds shall also be subjected to UT and its methodology and acceptance shall be as per AD 2000 Merkblatt HP 5/3-2002 Edition, with additional requirements as in 5.4.1 through 5.4.3 below.
- 5.4.1 The examination shall be conducted by Pulse Echo contact testing.

The following digital equipments or its equivalent models with A-scan presentation that generates and receives frequencies in the range of 1 MHz to 5 MHz. shall be used for examination:

GE Inspection Technology (Krautkramer make), Olympus (EPOCH IV, XT), Sonatest (Master scan series-350M/380M)U.K

S. Jayakumar, Engg

Approved by

K. Vedaprasad, QC

P. Elangovan, QA

K. Ganeshan, MPL



Bharat Heavy Electricals Limited, Piping Centre, Chennai Technical Delivery Conditions for Fabricated Tees and Y-pieces (Imported)

TDG:108 Rev 05 01.03.2010 Page 3 of 5

The calibration blocks used shall be of same material specification, diameter & thickness.

The UT equipment shall be calibrated at the beginning of each period of extended use or every 3 months whichever is less.

- 5.4.2 All recordable indications will be stored in memory of either the digital flaw detector or a PC for review at a later period.
- 5.4.3 The equipment calibration data for specific weld as well as the hard copy of 'Static echotrace pattern'— showing the flaw-echo amplitude with respect to DAC, flaw depth, projection surface distance (probe position) and beam-path shall be attached to UT test report. This hard-copy of echo-trace with equipment calibration data will form part of test documentation.
- 5.5 Qualified Level II personnel shall perform the examination as well as evaluation, and a test report shall be issued.
- Hardness test shall be carried out and report to be furnished. The maximum hardness (HV10) shall be 300 for F91 material; and 225 for F11,F12,F22.
- 6.0 POSITIVE MATERIAL IDENTIFICATION (PMI) FOR ALLOY STEEL FITTINGS.

Each alloy steel fitting shall be checked for the correctness of the material during manufacturing and final inspection using X-ray fluorescence principle or spark emission spectrography.

7.0 WORK MAN SHIP, FINISH AND REPAIR

All items shall have smooth, workman like finish, and to be free from scale & defects like laps, seams, folds, cracks, etc. Surface defects can be removed by mechanical means and defective areas smoothly dressed up with the adjacent surface. Minimum dimension after repair shall meet drawing / Specification. Repairs by fusion welding are prohibited.

- 8.0 PAINTING, COLOUR CODING, MARKING
- 8.1 PAINTING: All fittings shall be painted on the external surface as given below
 - a) Surface preparation: Blast cleaning
 - b) Painting : Seaworthy Epoxy painting of DFT 100 microns with colour shades as given below.
 - c) Shade: (i) smoke grey -- for all carbon steel fittings
 - (ii) Sea green -- for all Alloy steel fittings

The internal surface shall be protected with rust preventive coating or rust inhibitor. Stainless steel fittings need not be painted.

8.2 **COLOUR CODING**: All fittings shall be colour coded circumferentially at ends as given below

S. Jayakumar, Engg

Approved by

K. Vedaprasad, QC

P. Elangovan, QA

K. Ganeshan, MPL



Bharat Heavy Electricals Limited, Piping Centre, Chennai **Technical Delivery Conditions for Fabricated Tees and Y- pieces (Imported)**

TDG:108 Rev 05 01.03.2010 Page 4 of 5

SA 105 / SA 106 Gr.C = Blue SA 182 F11 / SA 335 P11 = Green & White SA 182 F12 / SA 335 P12 = Black & Red SA 182 F22 / SA 335 P22 = Blue & Red

SA 182 F22 / SA 335 P22 = SA 182 F91 / SA 335 P91 =

= Brown & Red

8.3 MARKING:

- 8.3.1 The fittings dispatched to **BHEL Stores** shall be punched <u>/ etched</u> with Material code, Heat number, material specification, maker's emblem, Inspectors seal and Statutory authorities seal (as applicable).

 In addition, the above details along with size shall be paint stenciled on the fittings.
- 8.3.2 The fittings dispatched directly to project site as DTS shall be <u>punched and paint</u> stenciled with <u>DU code</u> (14 digit work order du detail) as given by purchase in addition to marking done as per para 8.3.1.
- 9.0 PACKING AND END PROTECTION: Machined ends of the fittings shall be well protected using end caps and fittings shall be suitably packed in box / crate to avoid transit & other damages.
- 10.0 MANUFACTURING QUALITY PLAN.

Vendor shall submit manufacturing Quality plan along with technical part of the bid for BHEL approval.

11.0 INSPECTION & CERTIFICATION

- All items are to be inspected at the manufacturer's works by the Inspection agencies / authorities as per IBR. Inspection certificate for finished product in IBR Form III shall be submitted along with the Work Test Certificate (EN 10204 Type 3.2) countersigned by authorities as per IBR and shall include the following details. (Three ink signed originals required)
 - i. Test Certificate Number & date.
 - ii. BHEL P.O Number & Amendment Number(if anv)
 - iii. BHEL P.O. Serial Number
 - iv. BHEL TDC Number, Drawing number
 - v. Size-wise Quantity
 - vi. Specification, Grade & Year of code.
 - vii. Heat / Melt Number
 - viii. Steel making process.
 - ix. Material details
 - x. Ladle and product Analysis of Raw Material.
 - xi. Tensile Test
 - xii. Bend Test
 - xiii. Guarantee of HTP shall be given in the test certificate as follows, if hydro test is not carried out:

 "Fabricated Y piece / welded Tees are capable of withstanding

S. Jayakumar, Engg/

Approved by K. Vedaprasad, QC

K. Ganeshan, MPL

P. Elangovan, QA

D-but

without failure, breakage or impairment of their serviceability a hydrostatic test pressure equal to that prescribed for the specified matching pipe of equivalent material".

- xiv. References to the NDT & other test reports covered in 11.2 below.
- 11.2 The following reports shall be <u>furnished separately</u> along with the Form III & & MTC indicated in para 11.1 above.
 - i. NDE reports for VT, MT, RT, UT (UT Reports in soft copy + hard copy)
 - ii. Positive Material identification (PMI) report for Alloy steel.
 - iii. Heat Treatment Chart.
 - iv. Hardness Test report
 - v. Metallography Report along with photomicrograph with minimum 500x magnification.
 - vi. Dimensional report.

12.0 RECORDS OF REVISION.

- Rev 01: a) Para 3.0, 4.2.1,6.0, 10.0 are included
 - b) Para 1.0,4.2,4.3,8.2,11.0 are revised
- Rev 02: a) Para 2.10,4.2.1,8.1, 8.2, 9.0 are revised
- Rev 03: a) Para 2.12, 8.0 and 11.0 (18) are revised
- Rev 04: a) Para 8.1 modified as sea worthy painting.
 - b) Para 11 modified. Works TC 'EN 10204 Type 3.2' specified. Individual reports are required.
- Rev 05: a) Para 5.6 (Hardness test) included.
 - b) Para 8.1 modified indicating colour shades.
 - c) Para 11 modified for better clarity with respect to documentation

** ** *

S. Jayakumar, Engg

Approved by

K. Vedaprasad, QC

P. Elangovan, QA

& bank

K. Ganeshan, MPL



Bharat Heavy Electricals Limited, Piping Centre, Chennai

Technical Delivery Conditions for

Seamless Steel Pipes - with Supplementary tests

TDG: 101 Rev 02

Page 1 of 2 15 Dec. 2005

1.0 **GENERAL**

Materials: SA106GrB, GrC; SA 335 P11,P12,P22 & P91.

This Technical Delivery Conditions specify the requirements in addition to ASME SA 106. SA 335. If the blooms for SA 335 pipes are sourced from India, then the sources shall be, TISCO, MUSCO and ASP Durgapur - which are IBR approved.

2.0 CHEMICAL COMPOSITION

For SA106 Gr B and Gr C:- Carbon content shall be limited to 0.25% max. for pipe thickness up to and including 20 mm; and 0.30% max, for pipe thickness above 20 mm.

3.0 **TOLERANCES**

8

- 3.1 OD specified pipes:- Unless otherwise specified in the PO, tolerances shall be as below.
 - Outside diameter :
- + 1% (Max. 4 mm)
- Wall thickness as per SA 530
- Weight tolerance as per SA 530
- 3.2 ID specified pipes:- Unless otherwise specified in the PO, tolerances shall be:
 - ID: + 0.0mm, -3.2mm

• Thickness: +3.2mm, -0.0mm

4.0 MECHANICAL TESTS

Number of Test (as per IBR): 2 numbers up to first 100 pipes and additional 1 number per subsequent 100 pipes or part thereof.

- 5.0 SUPPLEMENTARY TESTS: These are applicable to SA 106 Cr C, SA335 P11, P12, P22, P91. The supplementary test results shall be indicated in the Test Certificate along with the mandatory test results.
- 5.1 Product Analysis -S1:- Product Analysis shall be carried out on 5% of pipes per lot per heat (minimum 2 Nos)
- 5.2 Transverse tension test- S2:- Transverse tension test shall be carried out (for size NB 200 mm and above) on one end of 5% of pipes per lot (minimum 1 No).

HARDNESS FOR SA 335 P91 PIPES:-6.0

Hardness test shall be carried out on each SA 335 P91 pipes. The values shall be 180-250 BHN and shall be indicated in the Test certificate.

7.0 NON DESTRUCTIVE TEST

Each pipe shall be ultrasonically tested as per ASTM E 213 in both clockwise & anticlockwise directions; calibration to be done on two axial notches of 50 mm length (inside & outside) and a depth of 5% of wall thickness (minimum 0.3 mm; maximum 1.5mm). The results shall be indicated in the Test Certificate.

8.0 **REPAIR:-**

Repair by welding is prohibited.

The pipe shall meet the dimensional tolerance (clause 3.0 above) after any mechanical repair as permitted in the standard.

Approved by S. Jayakumar, Engg

P. Elangovan, QA

K. Ganeshan, MM

V. Krishnan, Commercial

B. Prakash Rao, Q & MS-

R. Easwaran, Quality, HPBP Ora



Bharat Heavy Electricals Limited, Piping Centre, Chennai Technical Delivery Conditions for

Seamless Steel Pipes - with Supplementary tests

TDG: 101 Rev 02 Page 2 of 2

Page 2 of 2 15 Dec. 2005

9.0 WORKMANSHIP:-

All pipes shall have smooth surfaces, free from loose scales and defects like laps, seams, folds, cracks, pitting etc. The surface imperfection beyond the permissible limit of ASME SA106 / SA335 shall be removed mechanically without affecting the minimum thickness and workmanlike finish.

10.0 MARKING

The following details are to be marked on the consignment for identification

1) PO Number

2) Supplier's emblem/code

3) Specification & grade

4) Heat number

5) Size

6) No. of pipes

7) Inspector's seal

OD up to 31.8 mm (excluding)	Details 1 to 7 shall be stamped on metal / plastic tag attached to bundle
OD 31.8 mm to OD 76.1mm (including)	 Details 1 to 5 shall be paint stencilled on each pipe. Details1 to 7 to be stamped on Metal / Plastic tag attached to bundle.
OD above 76.1 mm	 Details 2,3,4,5 & 7 shall be hard stamped with round edged stamp at 100mm from an end of each pipe. Details 1 to 5 shall be paint stencilled on each pipe.

11.0 COLOUR CODING

Longitudinal colour bands shall be made throughout the length of the pipe. The colours shall be as per BHEL procedure SIP: PP: 21.

12.0 PRESERVATION

- Outside:- resin type rust preventive coating with visibility to stencilled details.
- Inside:- rust inhibitor or resin type rust preventive coating.
- Ends of the pipes shall be secured with caps.

13.0 INSPECTION AND CERTIFICATION

Products must be inspected and certified by the IBR approved Inspecting Authority in IBR FORM III B (i) for tubes and FORM III A (i) for pipes

Well-known pipe or tube maker (recognised in IBR) to submit IBR FORM III D or III E respectively (Mill Certificate).

** ** *

S. Jayakumar, Engg/

P. Elangovan, QA

K. Ganeshan, MM

Approved by

V. Krishnan, Commercial

B. Prakash Rao, O & M&

R. Easwaran, Quality, HPBP

