




Form no.2038

उत्पाद मानक
परिणामित्रPRODUCT STANDARD
TRANSFORMER

TR 24038 A

1 पृष्ठों में 1

PAGE 1 OF 1

शीर्षक :
TITLE : FLEXIBLE SEPARATOR FOR ATMOSEAL TYPE CONSERVATOR

$$W(\text{WIDTH}) = \pi/2 (\text{CONSERVATOR DIA}) + 40$$

$$L(\text{LENGTH}) = (\text{CONSERVATOR LENGTH} - \text{DIA OF CONSERVATOR}) + \text{WIDTH OF FLEXIBLE SEPARATOR}$$

$$G = (\text{CONSERVATOR LENGTH} - \text{DIA OF CONSERVATOR} - 200)$$

ITEM NO.	STYLE NO. OF FLEXIBLE SEPARATOR	CONSERVATOR SIZE	W	L	G	REMARKS
01		Ø 800 X LENGTH	1297			CALL DIMN. L & G ON INDENT
02	BF9026040173 ST 604217	Ø 1000 X 4400	1610	5010	3200	
03		Ø 1300 X LENGTH	2082			CALL DIMN. L & G ON INDENT
04						

NOTES:-

FLEXIBLE SEPRATOR SHALL MEET THE SPECIFICATION REQUIREMENT OF TR 10150A.

DRG NO WAS TR 20038A

पुनः Rev

दिनांक

वितरण
DISTRIBUTIONTRE/TRM/TRXTR
FBM

सं.

स्वीकृत किया :

APPROVED: Sanjay Pankaj

जारी किया : ISSUED :

टीआरई मानक / TRE STD.

तैयार किया / PREPD.

sd / D.T.K.

दिनांक DATE :

05/12/16